

**CPV Gulfcoast Power Generating Facility  
Application for Air Permit  
Document ID: CPV-GC**

Florida Department of Environmental Protection  
Division of Air Resources Management

---

***Prepared For:***

CPV Gulfcoast, Ltd.

***Prepared By:***

TRC Environmental Corporation

Boott Mills South

Foot of John Street

Lowell, Massachusetts

September, 2000

## TABLE OF CONTENTS

| <u>SECTION</u>   | <u>PAGE</u> |
|--|-------------|
| <b>1.0 INTRODUCTION.....</b>                                       | <b>1</b>    |
| <b>2.0 PROJECT DESCRIPTION .....</b>                               | <b>3</b>    |
| 2.1 SITE DESCRIPTION.....  | 3           |
| 2.2 EQUIPMENT DESCRIPTION .....                                    | 3           |
| 2.2.1 <i>Combustion Turbine Generator</i> .....                    | 5           |
| 2.2.2 <i>Heat Recovery Steam Generator</i> .....                   | 5           |
| 2.2.3 <i>Emission Control Equipment</i> .....                      | 6           |
| 2.2.4 <i>Cooling Tower</i> .....                                   | 6           |
| 2.2.5 <i>Proposed Fuel Use</i> .....                               | 7           |
| 2.3 PROJECT PHYSICAL LAYOUT AND DESIGN .....                       | 7           |
| 2.4 EQUIPMENT OPERATION.....                                       | 8           |
| 2.5 CONSTRUCTION SCHEDULE .....                                    | 9           |
| <b>3.0 APPLICABLE REGULATORY REQUIREMENTS .....</b>                | <b>10</b>   |
| 3.1 AMBIENT AIR QUALITY STANDARDS .....                            | 11          |
| 3.2 NON-ATTAINMENT NEW SOURCE REVIEW .....                         | 12          |
| 3.3 PREVENTION OF SIGNIFICANT DETERIORATION (PSD).....             | 12          |
| 3.4 NEW SOURCE PERFORMANCE STANDARDS (NSPS) .....                  | 14          |
| 3.5 NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS ..... | 14          |
| 3.6 ACID RAIN PROGRAMS.....  | 15          |
| 3.7 OPERATING PERMIT .....   | 15          |
| 3.8 RISK MANAGEMENT PLAN (RMP) .....                               | 16          |
| 3.9 FLORIDA AIR PERMIT APPLICATION.....                            | 16          |
| <b>4.0 ASSESSMENT OF IMPACTS .....</b>                             | <b>17</b>   |
| 4.1 EMISSION AND STACK PARAMETERS .....                            | 17          |
| 4.2 GEP STACK HEIGHT CALCULATION .....                             | 20          |
| 4.3 LAND USE DETERMINATION.....                                    | 21          |
| 4.4 BACKGROUND AIR QUALITY.....                                    | 21          |
| 4.5 METEOROLOGICAL DATA.....                                       | 22          |

|            |   |           |
|------------|---|-----------|
| 4.6        | RECEPTORS .....   | 23        |
| 4.7        | MODELING APPROACH.....  | 25        |
| 4.8        | PREDICTED IMPACTS .....   | 26        |
| 4.8.1      | <i>Sulfur Dioxide (SO<sub>2</sub>)</i> .....                          | 26        |
| 4.8.2      | <i>Nitrogen Dioxide (NO<sub>2</sub>)</i> .....                        | 27        |
| 4.8.3      | <i>Carbon Monoxide (CO)</i> .....                                     | 27        |
| 4.8.4      | <i>Particulate Matter (PM<sub>10</sub>)</i> .....                     | 27        |
| 4.9        | CLASS I AREA IMPACTS .....  | 28        |
| 4.9.1      | <i>Class I Area Impacts</i> .....                                     | 30        |
| 4.9.2      | <i>Significance and Increment Analyses</i> .....                      | 30        |
| 4.9.3      | <i>Regional Haze</i> .....  | 32        |
| 4.9.4      | <i>Air Quality Related Values (AQRVs)</i> .....                       | 35        |
| <b>5.0</b> | <b>CONTROL TECHNOLOGY ANALYSIS .....</b>                              | <b>39</b> |
| 5.1        | APPLICABILITY OF CONTROL TECHNOLOGY REQUIREMENTS.....                 | 39        |
| 5.1.1      | <i>PSD Contaminants Subject To BACT Under PSD Review</i> .....        | 40        |
| 5.1.2      | <i>Non-Attainment Pollutants Subject To LAER</i> .....                | 40        |
| 5.2        | APPROACH USED IN BACT ANALYSIS .....                                  | 40        |
| 5.2.1      | <i>Identification of Technically Feasible Control Options</i> .....   | 41        |
| 5.2.2      | <i>Economic (Cost-Effectiveness) Analysis</i> .....                   | 41        |
| 5.2.3      | <i>Energy Impact Analysis</i> .....                                   | 43        |
| 5.2.4      | <i>Environmental Impact Analysis</i> .....                            | 44        |
| 5.2.5      | <i>BACT Proposal</i> .....  | 44        |
| 5.3        | BACT ANALYSIS FOR CARBON MONOXIDE.....                                | 44        |
| 5.3.1      | <i>Identification of Technically Feasible Control Options</i> .....   | 44        |
| 5.3.2      | <i>Economic Impact of Oxidation Catalyst</i> .....                    | 46        |
| 5.3.3      | <i>Energy Impact of Oxidation Catalyst</i> .....                      | 46        |
| 5.3.4      | <i>Environmental Impacts of Technically Feasible CO Control</i> ..... | 47        |
| 5.3.5      | <i>BACT Proposal</i> .....  | 47        |
| 5.4        | BACT ANALYSIS FOR SULFUR DIOXIDE.....                                 | 47        |
| 5.5        | BACT ANALYSIS FOR PARTICULATE MATTER.....                             | 48        |
| 5.5.1      | <i>Combustion Turbine</i> .....                                       | 48        |

5.5.2 *Cooling Tower*..... 48

5.6 BACT ANALYSIS FOR NITROGEN OXIDES ..... 49

5.6.1 *Identification of Technically Feasible Control Options*..... 50

5.6.2 *Economic Impact of Oxidation Catalyst* ..... 52

5.6.3 *BACT Proposal* ..... 52

APPENDIX A - Air Permit Application Forms

APPENDIX B - Engineering Drawings

APPENDIX C - Air Pollutant Emissions

APPENDIX D - Air Quality Modeling

APPENDIX E - Control Technology Review

| <b><u>LIST OF FIGURES</u></b>           | <b><u>PAGE</u></b> |
|---|--------------------|
| Figure 2-1 Site Location Map .....      | 4                  |
| Figure 4-1. Land Use – 3 Km Radius..... | 24                 |

| <b><u>LIST OF TABLES</u></b>  | <b><u>PAGE</u></b> |
|---|--------------------|
| Table 3-1. New Power Generation Equipment Criteria Pollutant Emissions CPV Gulfcoast.....   | 11                 |
| Table 3-2. Ambient Air Quality Limits And Thresholds .....  | 12                 |
| Table 3-3. PSD Significant Emissions Increase Level And CPV Gulfcoast Project, Net Emission Rates (Pursuant To 40 CFR 52.21 (B) (23) (I)) ..... | 13                 |
| Table 4-1. Stack Exhaust Parameters CPV Gulfcoast Project .....   | 18                 |
| Table 4-2. Power Generation Equipment Projected Criteria Pollutant Emissions CPV Gulfcoast Project.....   | 19                 |
| Table 4-3. Air Quality Monitoring Stations .....  | 22                 |
| Table 4-4. Existing Air Quality .....   | 22                 |
| Table 4-5. Class I Area Screening Results Maximum 1-Hour Modeled Concentrations .....   | 37                 |
| Table 4-6. Maximum Modeled Class I Concentrations And Deposition Values.....  | 38                 |

# Section 1

## 1.0 INTRODUCTION

The purpose of this document is to provide the regulatory forms and technical information required to secure approval under Florida environmental regulations for a new electric power generation facility.

CPV Gulfcoast, Ltd. is proposing to construct a combined-cycle power generation facility capable of generating a net electrical output of 250 megawatts. The CPV Gulfcoast, Ltd. power generation facility will be located in Manatee County. CPV Gulfcoast, Ltd. identified a tract of land approximately 160 acres in size located near Piney Point in Manatee County, Florida (Figure 1-1) for the development of a power plant facility. The project is bounded on the west side by U.S. Route 41, by Buckeye Road to the north, Bud Rhoden Road to the east, and Chapman Road to the south.

CPV Gulfcoast, Ltd. will install a single, efficient gas turbine with heat recovery steam generator (HRSG). The gas turbine will provide approximately 170 MW of electrical power. The HRSG recovers otherwise lost heat from the gas turbine exhaust and provides steam energy to drive the steam turbines to provide approximately 74.9 MW of electric energy.

The new power generation equipment will be designed to meet federal Best Available Control Technology (BACT) standards, as appropriate for emissions control. The combustion turbine and HRSG will be built on a 10-acre portion of the Manatee County property. The new power generation facility includes a 150-foot stack. The steam turbine will be enclosed in a building, approximately 100 feet in height.

Section 2.0 provides a detailed description of the proposed facility. Section 3.0 describes the applicability of specific regulatory requirements to the CPV Gulfcoast project. Section 4.0 documents the air quality modeling study conducted to demonstrate compliance with ambient air quality standards and increments. Section 5.0 presents the air contaminant emissions control technology assessment. The application forms are contained in Appendix A. Other appendices

provide drawings, technical specifications, and data supporting the studies conducted to demonstrate compliance with applicable regulatory requirements.

## Section 2

### **2.0 PROJECT DESCRIPTION**

CPV Gulfcoast, Ltd. proposes to construct a generation facility in Manatee County using state-of-the-art combined-cycle power generation technology and air pollution control systems. The major components of the Project include a new combustion turbine generator, a heat recovery steam generator (HRSG), and state-of-the-art air pollution controls. Natural gas will be used as the primary source of fuel. To enhance overall reliability, the system will also be capable of burning very low sulfur content distillate as backup fuel for up to an equivalent of 30 days at full load each year.

#### **2.1 Site Description**


The CPV Gulfcoast power generation facility will be located in Manatee County, Florida. CPV Gulfcoast, Ltd. identified a tract of land approximately 120 acres in size located near Piney Point for the development of a power plant facility. The project is bounded on the west side undeveloped land, by Buckeye Road to the north, Bud Rhoden Road to the east, and Chapman Road to the south. Figure 2-1 shows the site location.

#### **2.2 Equipment Description**

To maximize efficiency and energy conservation, the Project facilities will include both gas and steam cycles. In the gas cycle, the new combustion turbine will fire natural gas as its primary fuel to produce approximately 170 megawatts (MW). The steam cycle will consist of a new HRSG and steam turbine generator. This cycle provides exceptional efficiency by employing the HRSG to recover otherwise lost heat from the gas turbine exhaust and using it to create steam and drive the steam turbine generator to produce an additional 74.9 MW. The steam that exhausts the steam turbine generator is cooled and condensed for re-use in the steam cycle. The combined-cycle technology achieves an operational efficiency on a unit of energy output per unit of energy input basis greater than operational efficiency for older plants.

A description of each major Project component is provided below.





BASE MAP IS A PORTION OF THE FOLLOWING 7.5' USGS TOPOGRAPHIC QUADRANGLES: RUSKIN, FLA, 1956, PHOTOREVISED 1987; PARRISH, FLA, 1973, PHOTOREVISED 1987; PALMETTO, FLA, 1964, PHOTOREVISED 1987; COCKROACH BAY, FLA, 1956, PHOTOREVISED 1981

L00-250/topo

0 2000 4000



scale in feet



**TRC**

Boott Mills South  
Foot of John Street  
Lowell, MA 01852  
978-970-5600

**SITE LOCATION MAP**  
**COMPETITIVE POWER VENTURES**  
**GULF COAST PROJECT**  
**PINEY POINT, FLORIDA**

FIGURE 1

PROJ. NO. 28365

### ***2.2.1 Combustion Turbine Generator***

The Project will use an advanced natural gas and distillate fired combustion turbine generator. The combustion turbine generator to be supplied by General Electric will be equipped with their two-stage, lean pre-mix dry low-nitrogen oxide (NO<sub>x</sub>) combustor.

The nominal 170 MW turbine generator is General Electric's 7241 FA. Basic elements include a compressor, a dry low NO<sub>x</sub> combustor, a power turbine, and a generator. Within the combustor, injected fuel (in this case, natural gas or distillate oil) mixes with compressed air from the compressor and burns, producing hot exhaust that drives the shaft-mounted turbine blades. Some of the rotational energy of the shaft compresses the incoming combustion air. The greater portion of the shaft's rotational energy drives the generator to produce the nominal 170 MW.

The power produced by the combustion turbine generator decreases as the ambient temperature rises. This is because the density of the air decreases with increasing temperature. Because the turbine section produces power based on mass flow, increases in ambient air temperature resulting in a decrease in ambient air density reduce the mass flow rate available for power generation by the turbine. In the proposed unit, power augmentation would be employed to minimize the effect of decreasing output with increasing temperature.

During warmer ambient temperatures, the combustion turbine is power augmented to make additional electrical output that is lost due to the increasing temperatures. Power augmentation involves using steam generated in the HRSG. The steam is injected into the turbine section of the combustion turbine generator. The injected steam increases the density of the air entering the turbine, thereby increasing power output. Power augmentation can only be used, however, when the ambient air temperature is above 59°F.

### ***2.2.2 Heat Recovery Steam Generator***

Exhaust gases leaving the combustion turbine retain considerable recoverable heat energy. The HRSG transfers the heat from this high temperature exhaust gas (about 1,100°F) to water in

order to generate useful steam for additional generating capacity. The temperature of the exhaust gas leaving the HRSG is approximately 190°F when firing natural gas.

The major sections of the HRSG include a superheater, an evaporator, and an economizer. Other HRSG components include a Selective Catalytic Reduction (SCR) NO<sub>x</sub> control system (with associated ammonium hydroxide injection and control systems) and an exhaust stack.

### ***2.2.3 Emission Control Equipment***

The exhaust flow from the combustion turbine will pass through the SCR system before venting through one, 150-foot stack. This stack height has been designed to provide sufficient emission dispersion while minimizing the potential for aerodynamic downwash of stack emissions, and limiting the effect upon visual aesthetics. The SCR control system will be capable of reducing NO<sub>x</sub> emissions to 3.5 ppmvd @15% O<sub>2</sub> when firing natural gas and 10 ppmvd @15% O<sub>2</sub> when firing distillate.

### ***2.2.4 Cooling Tower***

Wet cooling towers are employed to cool and condense steam in electric generation facilities. The cooling tower reduces the temperature of cooling water by air-water contact. The facility will include a five-cell mechanical draft cooling tower.

Water flows down through each cooling tower cell while air flows upward. Some of the cooling water evaporates and exits with the air as water vapor. The surface area of the water is increased as it flows or trickles through the fill section, which optimizes the heat transfer capability prior to it being collected in a basin at the bottom of the tower. Counter-currently, air, induced through the tower by fans, passes upward through the fill section, where heat transfers from the water and a small fraction of the water evaporates, thus cooling the remaining water. The cooled water, which is collected in the basin, is then recirculated back to the condenser. All of this occurs in a continuous fashion. A small percentage of the water is trapped in the air as small droplets. These remaining water droplets are referred to as cooling tower drift. Most of the water trapped in the air is removed using high-efficiency drift eliminators. However, some droplets remain and are released with the plume exiting the tower.

The water that is lost through the tower to the atmosphere must be replaced. In addition, as water is evaporated from the system, the dissolved solids concentration of the water remaining in circulation increases. To prevent dissolved solids from reaching levels where they would collect as scale on the exposed surfaces of the tower and condenser, some of the basin water is continuously bled off from the system. This is known as cooling tower blowdown. As with the evaporative losses, this blowdown must be replaced. The flow required to compensate for evaporative and blowdown losses is known as cooling tower makeup.

Air quality impacts would be expected with the mechanical draft cooling tower system due to the dissolved solids contained in the cooling tower drift, even if high efficiency drift eliminators were employed to limit the quantity of droplets in the plume were employed. The cooling tower will be designed to achieve a drift rate of 0.0005% of the circulating water flow rate, which represents the state of the art in drift elimination technology. Some of the solids would be less than 10 microns in size and would constitute PM-10 emissions. These cooling emissions would be in addition to emissions associated with the proposed Project stack.

#### **2.2.5 Proposed Fuel Use**

The equipment will be designed to generate electricity and steam using natural gas as the primary fuel source. During periods of natural gas interruption or when market conditions warrant, very low sulfur (0.05 percent) distillate oil will be used. The annual quantity of distillate use is limited to the equivalent of the facility operating at 100% load for no more than 30 days. The distillate would be delivered to the site by truck, and stored in an above ground tank.

### **2.3 Project Physical Layout and Design**

The new equipment associated with the Project will occupy an approximate 10-acre site. Site plans and facility arrangement drawings are contained in Appendix B.

**Steam Turbine Building:** This proposed building is designed to conform with all applicable zoning requirements. The building will house the steam turbine and associated mechanical and electrical equipment. The proposed building is approximately 100 feet wide by 160 feet long.

The highest portion of the building will be approximately 68 feet. This building will be a steel frame structure supported on a concrete foundation.

**Storage Tanks:** A tank will be constructed to store the distillate fuel. Two relatively small above ground storage tank will also be constructed: a de-mineralized water tank, and an ammonium hydroxide tank. A concrete containment dike will be built around the ammonium hydroxide tank.

#### **2.4 Equipment Operation**

The proposed design will be based on a General Electric STAG 107FA utilizing a single MS7001FA combustion turbine (CTG), a 3 pressure heat recovery steam generator (HRSG) and a steam turbine generator (STG) designed in conjunction with the HRSG steam conditions. The steam turbine generator output will be limited to less than 75 MW.

Control of STG output will be monitored and controlled to ensure the 75 MW output limit is not exceeded. A number of control options have been investigated and the most probable are described below.

When ambient temperature is at 59 °F or greater, excess steam generated in the HRSG will be extracted from the HRSG, bypassing the steam turbine, and injected into the CTG. This mode of operation is referred to as power augmentation. Since there is a limit on the quantity of steam that may be injected into the CTG, it may be necessary to further reduce steam flow to the STG to limit output or to reduce steam turbine output by other means

Bypass of a portion of heat exchange surface in the HRSG is an effective method of reducing steam production by reducing the heat recovered from the combustion turbine flue gas. The proposed design will make use of a low temperature economizer bypass to limit steam production by allowing more of the heat generated by the combustion turbine to be discharged to the atmosphere with the flue gas. This will limit STG output.

In many cases, application of both of these control modes will reduce steam output to the turbine to the required quantity. If additional reduction in STG output is required, raising the STG discharge pressure by raising the condenser operating temperature will reduce turbine efficiency, reducing electrical output. Output of the STG may be tuned to the desired value by turning cooling tower cells on and off as necessary.

When ambient temperature falls below 59 °F the manufacturer does not recommend injection of steam into the combustion turbine. If the low temperature economizer bypass combined with an increase cooling water temperature does not reduce STG output sufficiently, excess steam may bypass the steam turbine and be sent directly to the condenser.

Output of the STG will be controlled automatically utilizing the methods described above to ensure that the electrical power produced from steam does not exceed 74.9 MW.

## **2.5 Construction Schedule**

The development schedule for the Project calls for obtaining all required pre-construction approvals by the first quarter of 2001. Upon financial closing, groundbreaking for the facility would be initiated by the Engineering Procurement Construction (“EPC”) contractor. Construction of the Project would require approximately 22 months and is scheduled to be completed in the second quarter to third quarter of 2003. Start-up/testing activities would be ongoing during the later phases of construction. Commercial acceptance of the facility by CPV Gulfcoast, Ltd. would occur approximately six weeks after completion of the construction activities.

## Section 3

### **3.0 APPLICABLE REGULATORY REQUIREMENTS**

The CPV Gulfcoast Project (Project) proposed by CPV Gulfcoast, Ltd. must comply with air pollution control regulations administered by the Florida Department of Environmental Protection, Division of Air resources Management (DARM). Essential to understanding the regulatory requirements to which the Project must comply are the impacts of new power generation equipment on air pollutant emission rates.

The Project includes new combustion turbine, heat recovery steam generator (HRSG), and steam turbine that will produce approximately 250 megawatts (MW). This combination of equipment is considered a combined-cycle because it uses a gas cycle and a steam cycle to generate power.

Major pollutants of interest include: sulfur dioxide (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), particulate matter less than 10 microns (PM<sub>10</sub>), carbon monoxide (CO), and volatile organic compounds (VOC). Other pollutants including lead and regulated non-criteria air contaminants are not of concern because the new power generation equipment will fire natural gas as the primary fuel and very low-sulfur distillate (0.05 percent sulfur content) as the back-up fuel. The distillate fuel firing will be limited to the equivalent of 30-day operation at 100 percent load.

The annual emission rates that determine regulatory applicability are the potential annual emissions of the new power generation equipment.

Design data for the new power generation equipment specifies air pollutant emissions as a function of operating load and ambient temperature for both natural gas and distillate firing (see Appendix C). The annual potential emissions were calculated assuming 335 days of natural gas firing and 30 days of low sulfur distillate oil firing, and assuming the maximum pollutant emission rate over the range of operating conditions contained in the equipment design data. Table 3-1 shows the new power generation equipment's potential annual emissions.

| Pollutant                        | Potential Emissions (Tons/Year) |
|----------------------------------|---------------------------------|
| NO <sub>x</sub>                  | 125.7                           |
| SO <sub>2</sub>                  | 75.8                            |
| CO                               | 222.2                           |
| PM/PM <sub>10</sub> <sup>1</sup> | 101.8                           |
| VOC                              | 14.8                            |

1. Source: GE performance data in Appendix C.
2. Annual emission estimates based on combustion turbine operating 8760 hours at maximum hourly emission rate.
3. PM/PM<sub>10</sub> value includes combustion turbine (98.3 tons/year) and cooling tower drift (3.5 tons/year) emissions.

The U.S. Environmental Protection Agency (EPA) regulations establish air quality standards and air contaminant emission limits to which all new sources must comply. These regulations affect the design and operation of the new power generation equipment. This section describes the regulations and their impact on the Project.

### 3.1 Ambient Air Quality Standards

EPA has developed National Ambient Air Quality Standards (NAAQS) for six pollutants, referred to as criteria pollutants, for the protection of public health and welfare. The criteria pollutants are sulfur dioxide (SO<sub>2</sub>), nitrogen dioxide (NO<sub>2</sub>), carbon monoxide (CO), particulate matter (PM<sub>10</sub>), ozone (O<sub>3</sub>), and lead (Pb). The FLDEP enforces the NAAQS as state air quality standards. Table 3-2 shows the NAAQS.

Primary standards protect human health with a margin of safety and secondary standards protect public welfare (e.g., avoid damage to property or vegetation). Different averaging periods are established for the criteria pollutants based on their potential environmental effects.

Attaining and maintaining compliance with the state and national ambient air quality standards is the primary goal of all air regulations evolving from the original Clean Air Act and its subsequent amendments. All areas of the nation have been classified as to their status with regard to attaining the standards. The site location is classified as “unclassified” or “attainment” for all criteria pollutants.



| Pollutant                            | Averaging Period    | NAAQS ( $\mu\text{g}/\text{m}^3$ ) <sup>h</sup> |                   | PSD Increments ( $\mu\text{g}/\text{m}^3$ ) | Significant Impact Levels ( $\mu\text{g}/\text{m}^3$ ) |
|--------------------------------------|---------------------|---|-------------------|---|--|
|                                      |                     | Primary   | Secondary         |   |  |
| Sulfur Dioxide (SO <sub>2</sub> )    | 3-hour              | NA  | 1300 <sup>a</sup> | 512 <sup>a</sup>                            | 25   |
|                                      | 24-hour             | 365 <sup>a</sup>                                | NA                | 91 <sup>a</sup>                             | 5  |
|                                      | Annual              | 80 <sup>g</sup>                                 | NA                | 20 <sup>g</sup>                             | 1  |
| Nitrogen Dioxides (NO <sub>2</sub> ) | Annual              | 100 <sup>g</sup>                                | 100 <sup>g</sup>  | 25 <sup>g</sup>                             | 1  |
| Carbon Monoxide (CO)                 | 1-hour <sup>a</sup> | 40,000  | NA                | NA  | 2000   |
|                                      | 8-hour <sup>a</sup> | 10,000  | NA                | NA  | 500  |
| Particulate (PM <sub>10</sub> )      | 24-hour             | 150 <sup>d</sup>                                | NA                | 30 <sup>a</sup>                             | 5  |
|                                      | Annual              | 50 <sup>g</sup>                                 | NA                | 17 <sup>g</sup>                             | 1  |
| Ozone (O <sub>3</sub> )              | 1-hour              | 235 <sup>b</sup>                                | 235 <sup>b</sup>  | NA  | NA   |
|                                      | 8-hour              | 157 <sup>c</sup>                                | 157 <sup>c</sup>  | NA  | NA   |
| Lead (Pb)                            | Quarterly           | 1.5 <sup>g</sup>                                | NA                | NA  | NA   |

a Not to be exceeded more than once per year.  
b Not to be exceeded more than once per year on average.  
c 3-year average of annual 4th highest concentration.  
d The pre-existing form is exceedance-based. The revised form is the 99th percentile.  
e Spatially averaged over designated monitors.  
f The form is the 98<sup>th</sup> percentile.  
g Never to be exceeded.  
h  $\mu\text{g}/\text{m}^3$ , micrograms per cubic meter.

Implementation of the new PM<sub>10</sub> compliance criteria, the PM<sub>2.5</sub> standard, and the 8-hour ozone standard has been delayed. The delay is due to a recent court decision and the need to develop additional ambient air quality data and compliance assessment procedures.

### 3.2 Non-attainment New Source Review

Because Manatee County is currently designated as “unclassified” or “attainment” for all criteria pollutants, the Project is not subject to non-attainment new source review.

### 3.3 Prevention of Significant Deterioration (PSD)

The Federal PSD regulations affect areas classified as “unclassified” or “attainment” with respect to the NAAQS. The Manatee County is classified as such for all criteria pollutants.

As part of an air quality impact analysis, a facility classified as a new major source or major modification must demonstrate compliance with the NAAQS, and with the PSD increments shown in Table 3-2. The PSD regulations require assessments of potential impacts to soils and vegetation and to growth and visibility in the area surrounding the proposed plant.

Additionally, facilities within 100 kilometers (km) of a Class I (wilderness) area must also perform an assessment of potential impacts to Class I area(s). The Class I areas closest to the Project are the Chassahowitzka NWA. This Class I area is located approximately 109 km from the facility site, and therefore are beyond the distance for which an impact analysis is required under the PSD Rules.

A new major source in “unclassified” or “attainment” areas that will result in net emissions increases greater than the significant emissions increase levels presented in Table 3-3 are subject to PSD review. Other pollutants for which EPA promulgated annual emission thresholds are not listed because the new equipment will burn natural gas as the primary fuel producing negligible emissions of these pollutants. The annual emission thresholds shown in Table 3-3 are exceeded for NO<sub>x</sub>, SO<sub>2</sub>, CO, and PM/PM<sub>10</sub>. Accordingly, the addition of new power generation equipment is subject to PSD permitting requirements for these air pollutants.

| <b>Pollutant</b> | <b>Significant Emissions Increase Level (TPY)</b> | <b>Annual Net Emissions Increases (TPY)</b> |
|------------------|---|---|
| NO <sub>x</sub>  | 40  | 125.7                                       |
| SO <sub>2</sub>  | 40  | 75.8  |
| CO               | 100   | 222.2                                       |
| PM               | 25  | 101.8                                       |
| PM <sub>10</sub> | 15  | 101.8                                       |
| VOC              | 40  | 14.8  |

### **3.4 New Source Performance Standards (NSPS)**

The new combustion turbine associated with the Project is subject to the provisions of 40 CFR Part 60 Subpart GG (New Source Performance Standards for Combustion Turbines). NSPS Subpart GG affects combustion turbines having maximum firing capacity greater than 10 million Btu per hour and constructed after October 1977. The emission standards, contained in the NSPS rule, limit flue gas concentrations of NO<sub>x</sub> and SO<sub>2</sub>.

The NO<sub>x</sub> limit is 75 parts per million (ppm) (based on the turbine heat rate and the fuel bound nitrogen). The SO<sub>2</sub> limit is 150 ppm (or 0.8 percent sulfur in fuel). Additionally, the provisions of this subpart require the installation of a Continuous Emission Monitoring System (CEMS) to monitor fuel consumption and water to fuel ratio. Subpart GG also requires monitoring of fuel sulfur and nitrogen content and allows for the development of a custom schedule to monitor these parameters.

The new power generation equipment will combust natural gas and 0.05 percent sulfur content distillate oil. The proposed fuels contain less than 0.8 percent sulfur, complying with the NSPS requirements for SO<sub>2</sub>.

The new combustion turbine will generate no more than 9 ppm of NO<sub>x</sub> prior to the addition of SCR controls and no more than 3.5 ppmvd@15% O<sub>2</sub> after the SCR controls when firing natural gas. Backup distillate firing will generate no more than 10 ppmvd@15% O<sub>2</sub> of NO<sub>x</sub>. Therefore, the new combustion turbine will comply with the requirements of NSPS Subpart GG for NO<sub>x</sub>.

### **3.5 National Emission Standards for Hazardous Air Pollutants**

New stationary combustion turbines are subject to 40 CFR part 63 Subpart B - Requirements for the Control Technology Determinations for Major Sources in Accordance with Clean Air Act Sections 112(g) and 112(j). This regulation requires a case-by case determination of the Maximum Achievable Control Technology (MACT) for major sources which exceed the annual emission thresholds of 10 tons per year for an individual Hazardous Air Pollutant (HAP) or 25 tons per year for total HAP emissions.

Because the Project is using clean fuels (natural gas and distillate), HAP emissions do not exceed the regulatory thresholds. Accordingly, a MACT analysis will not be conducted.

### **3.6 Acid Rain Programs**

Title IV of the 1990 Clean Air Act amendments required EPA to establish a program to reduce emissions of acid rain-forming pollutants, called the Acid Rain Program. The overall goal of the Acid Rain Program is to achieve significant environmental benefits through reductions in SO<sub>2</sub> and NO<sub>x</sub> emissions. To achieve this goal, the program employs both traditional and market-based approaches for controlling air pollution.

Under the Federal program, the EPA allocates existing units SO<sub>2</sub> allowances. The affected facilities may use their allowances to cover emissions, or may trade their allowances to other units under a market-trading program. In addition, subject facilities are required to implement continuous emissions monitoring system (CEMS) for affected units. The CEMS requirements of the Acid Rain Program include: an SO<sub>2</sub> concentration monitor; a NO<sub>x</sub> concentration monitor; a volumetric flow monitor; an opacity monitor; a diluent gas (O<sub>2</sub> or CO<sub>2</sub>) monitor; and a computer-based data acquisition and handling system for recording and performing calculations.

Beginning in 2000, the Federal Acid Rain Program's annual emission limitations become effective. The new combustion turbine will not be given an annual emissions budget under the Federal Acid Rain Program. The new combustion turbine will obtain SO<sub>2</sub> through the market-trading program. The new power generation equipment incorporates the appropriate CEMS equipment in its design.

### **3.7 Operating Permit**

The CPV Gulf Coast facility is subject to the Federal Clean Air Act (CAA) Title V operating permit program. The Florida DARM regulations implementing the CAA Title V program are contained in Rule 62-213. The operating permit specifies the applicable regulatory requirements with which the CPV Gulf Coast facility must comply and the methods used to demonstrate compliance.

### **3.8 Risk Management Plan (RMP)**

In the case of a new facility, compliance with the RMP rule requires that the plan be submitted before the regulated substance is present at the facility above the applicable regulatory threshold. Because the SCR control technology proposed for the Project will utilize ammonia, a RMP may be required for the Project. If required, a RMP will be prepared before the presence of ammonia on-site above the applicable regulatory threshold.

### **3.9 Florida Air Permit Application**

The purpose of the new source permitting process is to ensure that the new source will be in compliance with all applicable federal and state regulatory requirements.

The Project requires the submittal of an Air Permit Application under the Florida permitting rules. Based on the regulatory applicability review presented in the previous sections, the plan application for the new power generation equipment is expected to include the following analyses:

- Air quality modeling study demonstrating compliance with state and federal ambient air quality standards and increments; and
- Federal PSD review for SO<sub>2</sub>, NO<sub>x</sub>, PM/PM<sub>10</sub>, and CO;

The Application is submitted to DARM for review and approval. The initial step in the agency review of the application is a completeness determination. Once the application is deemed complete, DARM conducts its review and issues a proposed permit for public review. A public hearing may be held and any comments addressed before issuing final approval.

## Section 4

### **4.0 ASSESSMENT OF IMPACTS**

Due to limitations in the spatial and temporal coverage of air quality measurements, monitoring data normally are not sufficient to demonstrate the adequacy of emission limits for existing sources. Also, the impacts of new sources that do not yet exist can only be determined through modeling. Thus, models have become the primary analytical tools in most air quality assessments.

The following section describes the evaluation of the Project ambient air quality impacts. The air quality modeling study was conducted using data, assumptions, and procedures consistent with Florida DEP modeling guidelines and was based on discussions with Florida DEP modeling staff to determine specific model input requirements and compliance criteria.

#### **4.1 Emission and Stack Parameters**

The new power generation equipment will operate over a range of load conditions typically from 50 to 100 percent. Operation below 50 percent load will only occur briefly during startup or shutdown. The equipment vendor developed emissions and stack parameters for eleven combinations of ambient temperature and load conditions for natural gas and distillate oil firing to represent the range of operating conditions.

Table 4-1 contains the stack parameters for each of the eleven operating conditions for the proposed power generation equipment. Table 4-2 contains the estimated emission rates for all eleven of the modeled conditions for the power generation equipment based on vendor data currently available.

| <b>Table 4-1. Stack Exhaust Parameters CPV Gulfcoast Project</b> |                             |                                   |
|--|-----------------------------|-----------------------------------|
| Stack Height: 150 feet   |                             |                                   |
| Stack Diameter: 18.5 feet  |                             |                                   |
| <b>Case ID</b>   | <b>Temperature<br/>(°F)</b> | <b>Velocity<br/>(feet/second)</b> |
| <b>Natural Gas</b>   |                             |                                   |
| <b>Temperature (°F)/<br/>Percent Load</b>                        |                             |                                   |
| 25/50  | 166                         | 41                                |
| 25/75  | 172                         | 50                                |
| 25/100   | 184                         | 65                                |
| 59/100FE   | 181                         | 65                                |
| 59/100   | 186                         | 62                                |
| 72/100   | 187                         | 60                                |
| 72/100FE   | 181                         | 63                                |
| 97/50  | 175                         | 39                                |
| 97/75  | 179                         | 46                                |
| 97/100   | 188                         | 57                                |
| 97/100FE   | 183                         | 59                                |
| <b>Low Sulfur<br/>Distillate Oil</b>                             |                             |                                   |
| <b>Temperature (°F)/<br/>Percent Load</b>                        |                             |                                   |
| 25/50  | 255                         | 47                                |
| 25/75  | 258                         | 59                                |
| 25/100   | 285                         | 79                                |
| 59/100   | 284                         | 74                                |
| 72/50  | 255                         | 46                                |
| 72/75  | 265                         | 56                                |
| 72/100   | 284                         | 72                                |
| 97/50  | 259                         | 44                                |
| 97/75  | 270                         | 54                                |
| 97/100   | 284                         | 67                                |
|  |                             |                                   |

**Table 4-2. Power Generation Equipment Projected Criteria Pollutant Emissions CPV Gulfcoast Project**

| Table 4-2. Power Generation Equipment Projected Criteria Pollutant Emissions CPV Gulfcoast Project |      |      |      |      |       |    |      |      |       |      |      |      |       |
|--|------|------|------|------|-------|----|------|------|-------|------|------|------|-------|
| <b>Ambient Temperature (°F)</b>  | 25   | 25   | 25   | 59   | 59    | 72 | 72   | 72   | 72    | 97   | 97   | 97   | 97    |
| <b>Load Condition (percent)</b>  | 50   | 75   | 100  | 100  | 100FE | 50 | 75   | 100  | 100FE | 50   | 75   | 100  | 100FE |
| <b>Natural Gas</b>   |      |      |      |      |       |    |      |      |       |      |      |      |       |
|  |      |      |      |      |       |    |      |      |       |      |      |      |       |
| SO <sub>2</sub>  | 7    | 8    | 10   | 10   | 10    |    |      | 9    | 9     | 6    | 7    | 9    | 9     |
| NO <sub>x</sub>  | 15.2 | 19.1 | 24.1 | 22.6 | 22.6  |    |      | 21.8 | 21.8  | 13.2 | 16.7 | 20.2 | 20.2  |
| CO   | 20   | 25   | 31   | 29   | 29    |    |      | 28   | 28    | 18   | 21   | 26   | 26    |
| PM   | 19   | 19   | 20   | 20   | 20    |    |      | 20   | 20    | 19   | 19   | 20   | 20    |
| <b>Distillate</b>  |      |      |      |      |       |    |      |      |       |      |      |      |       |
|  |      |      |      |      |       |    |      |      |       |      |      |      |       |
| SO <sub>2</sub>  | 63   | 80   | 99   | 94   |       | 58 | 74   | 92   |       | 54   | 69   | 84   |       |
| NO <sub>x</sub>  | 49.5 | 63.8 | 80   | 75.7 |       | 46 | 58.8 | 73.6 |       | 42.4 | 54.5 | 67.6 |       |
| CO   | 65   | 58   | 70   | 66   |       | 73 | 52   | 63   |       | 83   | 51   | 58   |       |
| PM   | 46   | 49   | 53   | 52   |       | 45 | 48   | 51   |       | 44   | 47   | 50   |       |
| Note: All emissions in pounds per hour.  |      |      |      |      |       |    |      |      |       |      |      |      |       |



If the maximum predicted air quality impact of the new power generation equipment for a specific pollutant and averaging time is below the significance levels shown in Table 3-2, no additional modeling is required.

#### **4.2 GEP Stack Height Calculation**

The project site is located in a rural setting with no existing nearby buildings that have the potential to affect plume dispersion from the combustion turbine stack. Two structures, identified as the HRSG and the Steam Turbine Building have physical dimensions that could potentially affect plume dispersion. The steam turbine building has a maximum height of 68 feet above grade. The HRSG height is 75 feet above grade and is connected to the stack. Appendix B contains site drawing showing structure location and dimensions.

A mechanical draft cooling tower will be constructed at the site consisting of five cells. The combined dimensions of the contiguous cells is approximately 270 feet long, 48 feet wide, and 49 feet in height. The fan opening at the top of each cell is 42 feet in diameter. The cooling tower is to be located to the south and east of the Combustion Turbine and Steam Turbine Building (see Site Plan in Appendix B) with the long axis oriented east-west. As the cooling towers are sources of PM<sub>10</sub>, the GEP analysis included these sources.

The Good Engineering Practice (GEP) stack height analysis was done following the procedures outlined in *Guideline for Determination of Good Engineering Practice Stack Height (Technical Support Document For the Stack Height Regulations, Revised, EPA-450/4-80-023R, June 1985)*.

Direction specific building downwash dimensions were determined using the EPA's BPIP software for the new combustion turbine stack assuming a height of 150 feet. Each building's location and dimensions and the location of the proposed stack were input to calculate the maximum building downwash height and projected width for each 10-degree sector surrounding each stack. The ISCST3 model was used to predict air quality impacts. Input files for ISCST3

included the 36 pairs of effective building height and projected width values for each stack (including the cooling tower cells) generated by BPIP.

Appendix D-1 includes the output file from the GEP program and a graphic showing the location of the stacks and buildings.

### **4.3 Land Use Determination**

The ISCST3 model options include using atmospheric dispersion coefficients characteristic of urban or rural land use. The determination of which set of dispersion coefficients to use is based on the land use within a three-kilometer radius circle centered on the project site (see Figure 4-1).

The project site is located in Piney Point, FL and is bordered by undeveloped land to the east, south and west. A mineral processing facility is located to the north (see Figure 4-1). The land use within three kilometers of the station is predominately rural. Based on the EPA recommended Auer Technique, the land use within the three-kilometer circle is rural.

### **4.4 Background Air Quality**

The FDEP maintains a network of ambient air monitors to evaluate existing air quality throughout the state. The existing air quality in the area of project site is described using data from the FDEP monitoring network.

The most recent three years (1997 to 1999) of available data from nearby monitoring locations were analyzed to determine existing ambient levels for the criteria air contaminants. The highest annual average and highest second-high short-term concentrations were identified, as appropriate, for each air contaminant. Table 4-3 lists the monitoring stations, and the FDEP's classifications of their associated land uses, used to determine existing ambient levels in the vicinity of the project site.

The air contaminant measurements are summarized in Tables 4-4. The short-term levels are the second highest average values for each year. The values noted with asterisks are the highest second high and highest annual concentrations for all years and monitoring stations and represent the conservative worst-case background levels used for the modeling study.

| <b>Monitor Address</b>                        | <b>Land Use</b> | <b>Location Type</b> | <b>Monitor ID</b> |
|---|-----------------|----------------------|-------------------|
| G. T. Bray Park, Bradenton (NO <sub>2</sub> ) | Residential     | Urban/Center City    | 120814012         |
| Port Manatee, Palmetto (SO <sub>2</sub> )     | Industrial      | Rural                | 120813002         |
| Holland House (PM <sub>10</sub> )             | Industrial      | Rural                | 120810008         |
| 220 Madison Avenue, Tampa                     | Commercial      | Suburban             | 120570063-1       |

| <b>Pollutant</b> | <b>Station</b> | <b>Averaging Time</b> | <b>Concentration (ppm)</b> |             |             |
|------------------|----------------|-----------------------|----------------------------|-------------|-------------|
|                  |                |                       | <b>1997</b>                | <b>1998</b> | <b>1999</b> |
| NO <sub>2</sub>  | Bradenton      | Annual                | N/A                        | N/A         | .007        |
| SO <sub>2</sub>  | Palmetto       | 3-hour                | N/A                        | .086        | .056        |
|                  |                | 24-hour               | N/A                        | .019        | .017        |
|                  |                | Annual                | N/A                        | .004        | .003        |
| PM <sub>10</sub> | Holland House  | 24-hour               | 40                         | 38          | 42          |
|                  |                | Annual                | 21.9                       | 23.1        | 24.7        |
| CO               | Tampa          | 1-hour                | 4.5                        | 6.7         | 8.5         |
|                  |                | 8-hour                | 2.6                        | 3.7         | 4.7         |

#### **4.5 Meteorological Data**

The FDEP approved using five years of hourly surface Tampa Airport data (1987 to 1991). This recording site is located approximately twenty miles to the north of the project site. TRC downloaded this data from the EPA's SCRAM bulletin board. The meteorological data sets consist of hourly values of wind speed and direction, temperature, stability class, and mixing height.

Mixing height data were developed using upper air data recorded concurrently at Tampa Airport.

Windroses for the years 1987 through 1991 (individually and cumulatively) are contained in Appendix D-2. The predominant wind direction is from the east, east-northeast and northeast at approximately nine percent of the time for each of the three compass directions for the five years of data used in the modeling. Winds are from the north through the east approximately forty percent of the time. Calm winds occur on an average of about 6 percent each year.


#### **4.6 Receptors**

A combination of receptor grid types was employed in the modeling analysis. Per recommendation of the FDEP, a rectangular grid was employed in the immediate vicinity of the plant. Receptors were also located at a greater density to the west, south and east of the perimeter to capture the maximum impact of the cooling tower. Proceeding away from the project site, a rectangular grid was centered on the project site out to a distance of approximately 8 kilometers. A total of 2944 rectangular grid receptors were developed.

A polar receptor grid was used to capture the maximum impacts from the combustion turbine stack emissions. Receptor rings were located at 9000, 10000, 12500, 15000, 20000, 30000 and 40000 meters at ten-degree intervals for a total of 252 polar receptors.

A total of 3,196 receptors contained in the three grids described above were used in the dispersion modeling analysis.

Per discussions with a FDEP representative, the receptor terrain values were set to zero along with the stack base elevations.



BASE MAP IS A PORTION OF THE FOLLOWING 7.5' USGS TOPOGRAPHIC QUADRANGLES: RUSKIN, FLA, 1956, PHOTOREVISED 1987; PARRISH, FLA, 1973, PHOTOREVISED 1987; PALMETTO, FLA, 1964, PHOTOREVISED 1987; COCKROACH BAY, FLA, 1956, PHOTOREVISED 1981

L00-250/3 k310



**TRC**

Boott Mills South  
Foot of John Street  
Lowell, MA 01852  
978-970-5600

**3-KILOMETER RADIUS MAP  
COMPETITIVE POWER VENTURES  
GULF COAST PROJECT  
PINEY POINT, FLORIDA**

FIGURE 2

PROJ. NO. 28365

#### 4.7 Modeling Approach

TRC Environmental conducted the modeling study after consultation with FDEP, consistent with the preceding discussions using EPA and FDEP approved methods.

Refined modeling was conducted using the ISCST3 model to demonstrate compliance with ambient air quality standards. ISCST3 is preferred by the EPA and other agencies for refined modeling because ISCST3 can simulate atmospheric dispersion associated with multiple stacks; simple, intermediate and complex terrain; and building wake effects. Rural dispersion coefficients were used, as more than 50 percent of the land use within a three-kilometer radius circle centered on the project site is classified as rural.

ISCST3 was run to predict concentrations using the regulatory default option, which includes:

- Stack-tip downwash;
- Buoyancy-induced dispersion;
- Final plume rise;
- Calm wind processing;
- Default wind profile exponents;
- Default vertical potential temperature gradients; and
- Use of upper bounds for super-squat buildings having an influence in the lateral dispersion of the plume.

The ISCST3 model was run with the simple terrain processing option selected as recommended by FDEP.

The modeling was conducted for each air contaminant and for the proposed power generation equipment operating scenarios using the five years of Tampa Airport meteorological data. If the

maximum predicted impact was less than the significant level for a particular pollutant and averaging time, then no further assessment was required.

#### **4.8 Predicted Impacts**

Impacts predicted by the ISCST3 model are presented for each criteria pollutant and averaging time for the Project. The short term air quality impacts are documented for natural gas and backup low-sulfur distillate oil firing. The annual impacts are based on a weighted average of natural gas (11 months) and distillate (1 month) firing.

In assessing the impacts of the proposed new combustion turbine, the ISC3 model was run for all 24 operating cases using an emission rate of 1.0 grams per second. The predicted impacts were then scaled for each pollutant of concern in an electronic spreadsheet. Model output summaries for the proposed new turbine are contained in Appendix D-3. The scaled model results are presented in Appendix D-4.

The cooling tower is a source of PM<sub>10</sub>. To address the combined impacts of this source and the proposed combustion turbine, separate model runs were conducted using estimated PM<sub>10</sub> emission rates for the cooling tower and a worst-case PM<sub>10</sub> scenario for the combustion turbine. For an ambient temperature of 97 F and at 50 percent load, the combustion turbine PM<sub>10</sub> emission rate is 43 pounds per hour. For this operating scenario, modeled impacts reflect the low exhaust gas temperature and flow rate. Additional information is available in Section 4.8.4 below and in Appendix D-5.

##### **4.8.1 Sulfur Dioxide (SO<sub>2</sub>)**

The maximum predicted 3-hour average impact for the five years of meteorological data modeled for the proposed combustion turbine alone was 10.4 µg/m<sup>3</sup> (distillate) and 2.2 µg/m<sup>3</sup> (natural gas). For the 24-hour average, the model predicted maximum impacts of 2.0 µg/m<sup>3</sup> (distillate) and 0.4 µg/m<sup>3</sup> (natural gas). These impacts are well below the 3-hour and 24-hour SO<sub>2</sub> Significant Impact Levels (SIL) of 25.0 and 5.0 µg/m<sup>3</sup>, respectively.

The maximum annual average SO<sub>2</sub> impact is predicted to be 0.023 µg/m<sup>3</sup>. This maximum impact is well below the annual SIL of 1.0 µg/m<sup>3</sup>.

#### **4.8.2 Nitrogen Dioxide (NO<sub>2</sub>)**

The modeled maximum annual impacts for a weighted average of the oil-fired and gas-fired scenarios were predicted to be 0.043 µg/m<sup>3</sup>, which is below the annual SIL of 1.0 µg/m<sup>3</sup>.

No additional modeling of this pollutant was performed.

#### **4.8.3 Carbon Monoxide (CO)**

The model predicted CO impacts for low-sulfur distillate oil firing were 22.8 µg/m<sup>3</sup> and 7.2 µg/m<sup>3</sup> for the 1-hour and 8-hour averaging periods, respectively. The predicted CO impacts for natural gas firing were 18.0 µg/m<sup>3</sup> and 4.0 µg/m<sup>3</sup> for the 1-hour and 8-hour averaging periods, respectively. With SILs for one-hour of 2,000 µg/m<sup>3</sup> and for 8-hours of 500 µg/m<sup>3</sup>, the predicted CO impacts from the new power generation equipment are well below the SILs.

#### **4.8.4 Particulate Matter (PM<sub>10</sub>)**

The maximum predicted PM<sub>10</sub> impacts for the combustion turbine for the 24-hour averaging period when firing low sulfur distillate oil firing was 1.6 µg/m<sup>3</sup> (1.3 µg/m<sup>3</sup> firing natural gas) and for the annual average was 0.053 µg/m<sup>3</sup>. The 24-hour and annual SILs for PM<sub>10</sub> are 5.0 and 1.0 µg/m<sup>3</sup>, respectively.

The cooling towers are sources of PM<sub>10</sub> emissions as dissolved solids and suspended particles in the cooling water will become airborne particles once the water from the drift droplets evaporates. A description of the method used to develop the PM<sub>10</sub> emission rate from the cooling tower is provided in Appendix D-5.



In addressing impacts from the cooling tower, it was assumed that the five cells operate continuously. This is a conservative assumption as the combustion turbine may not always be operating at maximum load and/or atmospheric conditions of temperature and dew point may not always require operation of all cells even when the combustion turbine is operating at full load.

Due to the location of the cooling tower on the project property, the maximum impacts are close to the property line. With the assumptions listed above, the maximum 24-hour combined impact for the cooling tower and combustion turbine is  $3.6 \mu\text{g}/\text{m}^3$  at a receptor located 35 meters to the east-southeast of the southeast corner of the property. At that location and time, the combustion turbine contributes  $1.2 \mu\text{g}/\text{m}^3$  to the combined impact with the balance due to the cooling tower. The maximum impact for each of the five years of modeling are located to the south or southeast of the cooling tower, suggesting that downwash is occurring due to the steam turbine building being upwind.

#### **4.9 Class I Area Impacts**

Proposed major sources within 200 km of a Class I area must perform an assessment of potential impacts in this area. The Class I area closest to CPV is the Chassahowitzka NWR area located approximately 120 km north of the proposed facility and within the distance for which an impact analysis is required.

In accordance with guidance from the FDEP, impacts at the Class I area were assessed using a distinct set of receptors placed along the boundary of the Class I area. The significance analysis consisted of modeling the “worst-case” operating scenario emissions of  $\text{SO}_2$ ,  $\text{NO}_2$ , and PM-10 and determining the proposed project’s impacts at the Chassahowitzka NWR.

Additional analyses to determine the impact of the proposed project on visibility, soils and vegetation, and regional haze at the Class I area were also conducted following the EPA’s New Source Review Workshop Manual - Draft (EPA, 1990) and the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling

Long Range Transport Impacts (USEPA, 1998). The methodology for the Class I analyses is discussed below.

The CALPUFF (version 990228) model was used for the Class I analyses. CALPUFF is recommended by IWAQM for modeling the long-range transport impacts on Class I areas such as the Chassahowitzka NWR.

CALPUFF is a multi-layer, multi-species, non-steady-state puff dispersion model, which can simulate the effects of time-and space-varying meteorological conditions on pollutant transport, transformation, and removal. It also contains algorithms for near-source effects such as building downwash, transitional plume rise option, partial plume penetration, subgrid scale terrain interactions as well as longer range effects such as pollutant removal (wet scavenging and dry deposition), chemical transformation, overwater transport, and coastal interaction effects. The model can be used in a screening mode, using single station winds as used in the ISCST3 model, or a refined mode, using multiple meteorological stations and vertical wind profiles.

Following the guidance provided in the EPA's IWAQM Phase 2 Summary Report and Recommendations for Modeling Long-Range Transport Impacts (EPA, 1998), the CALPUFF model was used in the screening mode to provide conservative results of the proposed project's impacts in the Class I area. Specifically, the model was used to demonstrate that the PSD Class I increments would not be threatened and the regional haze would not be significantly increased due to the proposed project.

In addition to the fence-line and polar receptors to be used for the refined air quality modeling, a separate set of receptors was used in the Class I impact analysis. In accordance with Mr. Chris Carlton of the FDEP, a set of 13 discrete receptors placed throughout the Chassahowitzka NWR was used to assess the impact at the Class I area.

#### ***4.9.1 Class I Area Impacts***

Because CPV is located within 200 km of a Class I area (Chassahowitzka NWR), separate Class I significance, increment, and regional haze analyses were required to ensure the proposed project will not adversely affect the Class I area. These analyses were conducted following the latest guidance provided by the EPA's Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts (EPA, 1998), the FDEP, the National Park Service (NPS), and the Federal Land Manager (FLM) of the Chassahowitzka NWR.

#### ***4.9.2 Significance and Increment Analyses***

The IWAQM Phase 2 Report (EPA, 1998) outlines the methodology for conducting a screening analysis to determine the impact on Class I areas from proposed sources. Results of the screening analysis were used to compare to the PSD Class I significance and increment levels and quantify the change in regional. Results of the screening analysis indicate that the proposed project's maximum impacts within the Class I area are well below the Class I significant impact concentrations and PSD Class I increment levels.

To determine the appropriate turbine operating load scenario to model in the Class I analyses, a screening analysis was conducted using the SCREEN3 model to determine each operating load's impact at the Class I area. The operating load, which yielded the maximum concentrations for SO<sub>2</sub>, PM-10, and NO<sub>2</sub>, was then used in the IWAQM screening analysis. The load analysis showed that operating Case 14 (turbine firing distillate oil at 100% load, 25°F) was the "worst-case" operating scenario for impacts at the Class I area for SO<sub>2</sub> and NO<sub>2</sub>. Case 12 (turbine firing distillate oil at 50% load, 25°F) was the "worst-case" operating load for PM-10 impacts; however, Case 14 was used in the Class I analyses because it was the worst-case for two of the three main pollutants modeled in the Class I analyses. Results of the Class I load analysis are presented in Table 4-5. All SCREEN3 input and output files for the Class I load analysis are included electronically in Appendix D-6.

The IWAQM screening analysis consisted of modeling the “worst-case” operating scenario (Case 14) using the CALPUFF (version 990228) model with five years (1987-1991) of hourly surface data and twice daily mixing height data from Tampa Bay, Florida. Emissions of SO<sub>2</sub>, PM-10, NO<sub>x</sub>, and sulfuric acid (H<sub>2</sub>SO<sub>4</sub>) as primary sulfate, from the turbine were modeled. A discrete set of receptors provided by the FDEP were used to locate the maximum concentrations and depositions. A sea level terrain height was input for each receptor. This height is recommended by the FDEP for receptors located in the NWR.

The modeling domain input to the CALPUFF model consisted of a 12x12 cell grid centered on the proposed facility. Each grid cell was 25 km x 25 km with the southwest corner of cell covering the proposed facility at 348.5 km UTM East, 3057.0 km UTM North, zone 17. Therefore, the entire modeling domain was 300 km x 300 km (southwest corner of entire grid at 198.5 km UTM East, 2907.0 km UTM North, zone 17). The modeling domain extends more than 50 km beyond the set of receptors as recommended in IWAQM Phase 2 Report (EPA, 1998). Nine vertical layers were input to the CALPUFF model. These vertical layers had heights of 20, 80, 160, 300, 600, 1000, 1500, 2200, and 3000 meters.

To create the CALPUFF input file, the ISC2PUF conversion program, available with the CALPUFF suite of programs, was used to convert an ISC input file previously created for the Class II significance modeling to a CALPUFF input file. The MESOPUFF II chemistry option was selected to account for chemical transformation and wet and dry deposition was calculated. A land use category of irrigated agricultural was input along with a default surface roughness length of 0.25 m and a leaf area index of 3.0. The default geometric mean mass diameter of 0.11 μm (with a standard deviation of 0 μm) was also input for primary particulate emissions. The CALPUFF defaults (0.48 μm ± 2 μm) were used for the mean diameters and standard deviations for sulfate and nitrate.

Default background concentrations of ozone (80 ppb) and ammonia (10 ppb) were also input to the CALPUFF model because these pollutants act as catalysts for the chemical reactions creating

sulfate and nitrate. The ammonia background concentration of 10 ppb was used as recommended in the IWAQM Phase 2 Report (EPA, 1998) for grasslands.

The CALPUFF input file was then run using the ISC meteorology option. The maximum modeled concentrations and deposition values are presented in Table 4-6. As shown in the table, the maximum concentrations of SO<sub>2</sub>, PM-10, and NO<sub>2</sub> are less than their respective Class I significance levels, and, therefore, less than their Class I increment levels. The maximum concentrations of SO<sub>4</sub>, NO<sub>3</sub>, and nitric acid (HNO<sub>3</sub>) presented in Table 4-6 were used in the regional haze analysis and the pollutant-specific deposition values were used in the AQRV analysis.

#### **4.9.3 Regional Haze**

Haze is a result of the suspension in the atmosphere of small aerosols, which individually are invisible to the naked eye, but collectively give the sky an opalescent appearance. Sources of aerosols are natural (e.g., sea spray, forest fires, dust storms) and anthropogenic (e.g., automobile and stack exhaust). Haze usually is associated with subsaturated air, whereas fog or mist indicates saturated conditions. To measure the amount of haze, light extinction, which is the attenuation of light (defined as the reduction in illuminance of a parallel beam of light as the light passes through a medium wherein absorption and scattering occur) is used. However, light extinction can also be caused by fog or mist and other atmospheric phenomenon (e.g., precipitation). Therefore, the change in light extinction should be based upon the change from the existing or background light extinction to the potential light extinction caused by a proposed source.

To determine the potential change in light extinction (the sum of light scattering and absorption) due to the proposed project at the Chassahowitzka NWR, the worst-case operating scenario determined in the load analysis was modeled. Emissions of SO<sub>2</sub>, NO<sub>x</sub>, PM-10, and sulfuric acid (H<sub>2</sub>SO<sub>4</sub>) (as primary sulfate) from the turbine were modeled with the CALPUFF model.

The maximum 24-hour sulfate, nitrate (NO<sub>3</sub> and HNO<sub>3</sub>), and particulate concentrations presented in Table 4-6 from the CALPUFF screening analysis were used to determine the change in regional haze due to the proposed project. The sulfate and nitrate concentrations were converted to concentrations of ammonium sulfate (NH<sub>4</sub>SO<sub>4</sub>) and ammonium nitrate (NH<sub>4</sub>NO<sub>3</sub>) using conversion factors of 1.375 and 1.29, respectively, which are ratios of the respective molecular weights. Thus, the 24-hour NH<sub>4</sub>SO<sub>4</sub> and NH<sub>4</sub>NO<sub>3</sub> concentrations were calculated to be 1.90x10<sup>-2</sup> µg/m<sup>3</sup> and 2.9x10<sup>-2</sup> µg/m<sup>3</sup>, respectively.

A relative humidity factor (6.0) from Appendix B of the IWAQM Phase I Report: Interim Recommendation for Modeling Long Range Transport and Impacts on Regional Visibility (EPA, 1993) was determined based on a relative humidity of 90 percent as recommended in the IWAQM Phase 2 Report (EPA, 1998). The light extinction coefficients for sulfate and nitrate were then calculated using the equation:

$$b_{\text{ext}(i)} = 0.003 * \text{conc} * f(\text{RH})$$

where:

- $b_{\text{ext}(i)}$  = the pollutant-specific extinction coefficient;
- 0.003 = a nominal dry scattering efficiency;
- conc = the pollutant-specific calculated concentration (µg/m<sup>3</sup>); and
- f(RH) = the relative humidity factor.

The IWAQM Phase 2 Report (EPA, 1998) provides light extinction calculation methods for four different particulate types: soil, coarse, organic, and elemental carbon (soot). The nominal dry scattering efficiencies for these four particulate types are 0.001, 0.0006, 0.004, and 0.01, respectively. Because the particulate emissions from the proposed project have not been categorized into these four particulate categories and the assumption that CALPUFF is not necessarily linear (i.e., the ratio of organic particulate emissions to total particulate emissions is not necessarily equal to the ratio of organic particulate impacts to the total particulate impacts),

the light extinction coefficient for particulates was conservatively estimated using the maximum particulate nominal dry scattering efficiency (0.01) in the equation:

$$b_{\text{ext(part)}} = 0.01 * \text{conc}$$

where:

$b_{\text{ext(part)}}$  = the particulate extinction coefficient; and

0.01 = the elemental carbon nominal dry scattering efficiency;

conc = the pollutant-specific calculated concentration ( $\mu\text{g}/\text{m}^3$ ).

Using the above equations yields pollutant-specific light extinction coefficients of  $8.91 \times 10^{-5} \text{ km}^{-1}$  for  $\text{SO}_4$ ,  $5.81 \times 10^{-4} \text{ km}^{-1}$  for nitrates ( $\text{NO}_3$  and  $\text{HNO}_3$ ), and  $5.28 \times 10^{-4} \text{ km}^{-1}$  for particulates. The pollutant-specific light extinction coefficients were then summed to determine the total light extinction coefficient,  $1.2 \times 10^{-3} \text{ km}^{-1}$ , due to the proposed project. Appendix D-7 contains all the calculations for the regional haze analysis.

According to the NPS, the background light extinction coefficient was calculated using the equation:

$$b_{\text{ext(back)}} = 3.912/\text{BVR}$$

where:

$b_{\text{ext(back)}}$  = the background light extinction coefficient; and

BVR = the background visual range (km).

The NPS recommends a BVR of 65 km for the Chassahowitzka NWR. The value represents the average visibility measured during the 20 percent of days with the greatest visual range at the NWR. Thus,  $b_{\text{ext(back)}}$  equals 0.06 for the Chassahowitzka NWR.

The total light extinction coefficient and the background light coefficient were then used to calculate the percent change in light extinction due to the proposed source using the ratio of:

$\Delta$ light extinction = (total light extinction)/(background light extinction)

Calculating the change in light extinction using the above equation results in a change of 2.0%. This change in light extinction is less than recommended (5%) in the IWAQM Phase 2 Report (EPA, 1998); therefore, the proposed project will not adversely affect the regional haze at the Chassahowitzka NWR.

#### ***4.9.4 Air Quality Related Values (AQRVs)***

There currently are no AQRVs for the Class I area; therefore, the deposition values have not been included in the Class I modeling analysis.



*References*

USEPA, 1998. Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Report and Recommendations for Modeling Long Range Transport Impacts. U.S. Environmental Protection Agency. Research Triangle Park, North Carolina.

USEPA, 1993. Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 1 Report: Interim Recommendation for Modeling Long Range Transport and Impacts on Regional Visibility. U.S. Environmental Protection Agency. Research Triangle Park, North Carolina. April 1993.

| <b>Operating Scenario</b> | <b><math>\lambda/Q</math></b> | <b>NO<sub>2</sub> (µg/m<sup>3</sup>)</b> | <b>SO<sub>2</sub> (µg/m<sup>3</sup>)</b> | <b>PM-10 (µg/m<sup>3</sup>)</b> |
|---------------------------|-------------------------------|--|--|---------------------------------|
| CASE01                    | 0.15                          | 0.29                                     | 0.13                                     | 0.36                            |
| CASE02                    | 0.14                          | 0.33                                     | 0.14                                     | 0.33                            |
| CASE03                    | 0.12                          | 0.36                                     | 0.15                                     | 0.30                            |
| CASE04                    | 0.12                          | 0.34                                     | 0.15                                     | 0.30                            |
| CASE05                    | 0.12                          | 0.34                                     | 0.15                                     | 0.30                            |
| CASE06                    | 0.12                          | 0.34                                     | 0.14                                     | 0.31                            |
| CASE07                    | 0.12                          | 0.33                                     | 0.14                                     | 0.31                            |
| CASE08                    | 0.15                          | 0.25                                     | 0.11                                     | 0.36                            |
| CASE09                    | 0.14                          | 0.29                                     | 0.12                                     | 0.33                            |
| CASE10                    | 0.12                          | 0.32                                     | 0.14                                     | 0.31                            |
| CASE11                    | 0.12                          | 0.32                                     | 0.14                                     | 0.31                            |
| CASE12                    | 0.12                          | 0.73                                     | 0.92                                     | 0.68                            |
| CASE13                    | 0.10                          | 0.83                                     | 1.04                                     | 0.64                            |
| CASE14                    | 0.09                          | 0.90                                     | 1.11                                     | 0.60                            |
| CASE15                    | 0.12                          | 0.68                                     | 0.86                                     | 0.67                            |
| CASE16                    | 0.10                          | 0.78                                     | 0.98                                     | 0.63                            |
| CASE17                    | 0.09                          | 0.85                                     | 1.06                                     | 0.59                            |
| CASE18                    | 0.12                          | 0.64                                     | 0.81                                     | 0.66                            |
| CASE19                    | 0.11                          | 0.73                                     | 0.92                                     | 0.63                            |
| CASE20                    | 0.09                          | 0.80                                     | 0.99                                     | 0.59                            |

<sup>a</sup>Concentrations calculated using the SCREEN3 model at a distance of 100 km (actual distance to Chassahowitzka NWR is 120 km; however, SCREEN3 limited to receptors within 100 km of source).

**Table 4-6. Maximum Modeled Class I Concentrations And Deposition Values**

| <b>Pollutant</b>  | <b>Averaging Period</b> | <b>Year of Maximum</b> | <b>Concentration (<math>\mu\text{g}/\text{m}^3</math>)</b> | <b>Class I Significance Level (<math>\mu\text{g}/\text{m}^3</math>)</b> | <b>Class I Increment Level (<math>\mu\text{g}/\text{m}^3</math>)</b> |
|-------------------|-------------------------|------------------------|--|---|--|
| Concentrations    |                         |                        |  |   |  |
| SO <sub>2</sub>   | 3-Hour                  | 1989                   | 0.38   | 1.0   | 25   |
|                   | 24-Hour                 | 1989                   | 0.099  | 0.2   | 5  |
|                   | Annual                  | 1989                   | 0.0040   | 0.1   | 2  |
| PM-10             | 24-Hour                 | 1989                   | 0.053  | 0.3   | 8  |
|                   | Annual                  | 1989                   | 0.0043   | 0.2   | 4  |
| NO <sub>2</sub>   | Annual                  | 1989                   | 0.0028   | 0.1   | 2.5  |
| SO <sub>4</sub>   | 24-Hour                 | 1989                   | 0.0036   | --  | --   |
| NO <sub>3</sub>   | 24-Hour                 | 1989                   | 0.010  | --  | --   |
| HNO <sub>3</sub>  | 24-Hour                 | 1989                   | 0.015  | --  | --   |
| -- Not Applicable |                         |                        |  |   |  |

## Section 5

### **5.0 CONTROL TECHNOLOGY ANALYSIS**

A control technology analysis has been performed for the new power generation equipment based upon guidance presented in the draft EPA document, New Source Review Workshop Manual (October 1990). Control technology requirements for each pollutant depend upon the project area's attainment status and the potential emissions of the pollutant. Air contaminants subject to non-attainment New Source Review (NSR) must apply Lowest Achievable Emission Rate (LAER) technology and those subject to PSD review must apply Best Available Control Technology (BACT).

Section 5.1 outlines the degree of control required (LAER or BACT) for each air contaminant, as determined in Section 3.0. Section 5.2 presents an overview of the "Top-Down" BACT assessment procedure used in this analysis. The procedure used in the economic analysis for technically feasible control options is detailed in Section 5.2.2. Sections 5.3 through 5.6 present control technology determinations for CO, SO<sub>2</sub>, PM/PM-10 and NO<sub>x</sub> respectively, for the proposed power generation equipment.

Note that throughout this section, "ppm" concentration levels for gaseous pollutants are parts per million by volume, dry basis, corrected to 15 percent O<sub>2</sub> content (ppmvd @ 15% O<sub>2</sub>), unless otherwise noted.

#### **5.1 Applicability of Control Technology Requirements**

An applicability determination, as discussed in this section, is the process of determining the level of emissions control required for each applicable air pollutant. Control technology requirements are generally based upon the potential emissions from the new or modified source and the attainment status of the area in which the source is to be located. A detailed determination of applicable regulations, including control technology requirements under the PSD and non-attainment rules, is provided in Section 3. The following sections discuss the applicability of BACT and LAER for emissions from equipment included in this permit application.

### ***5.1.1 PSD Contaminants Subject To BACT Under PSD Review***

Pollutants subject to PSD review are subject to BACT analysis. BACT is defined as an emission limitation based on the maximum degree of reduction, on a case-by-case basis, taking into account energy, environmental and economic impacts. Based upon the regulatory applicability analysis in Section 5.1, the existing facility is considered a major source for PSD purposes since potential emissions exceed the major source threshold. Therefore, individual regulated pollutants are subject to PSD review, including the BACT requirement, unless potential annual emission rate increases are below the significant emission rates presented in 40 CFR 52.21(b)(23) for a PSD area. A PSD area is defined as an attainment area. Based upon these criteria, the federal BACT requirements apply to SO<sub>2</sub>, PM/PM-10, CO, and NO<sub>x</sub> emissions.

### ***5.1.2 Non-Attainment Pollutants Subject To LAER***

Emissions of pollutants subject to non-attainment NSR must be limited to LAER levels. LAER is defined as either the most stringent emission limitation contained in a State Implementation Plan (SIP) (unless it is demonstrated to not be achievable) or the most stringent emission limitation which is achieved in practice by the class or category of source, whichever is the most stringent without regard to cost. The project location is classified as attainment for all criteria pollutants. Therefore, LAER requirements, including a control technology determination, are not applicable for any pollutant.

## **5.2 Approach Used in BACT Analysis**

As explained in Section 5.1, the new power generation equipment is subject to federal PSD BACT requirements for emissions of CO, SO<sub>2</sub>, PM/PM-10, and NO<sub>x</sub>. As previously stated, BACT defined under federal rules is the optimum level of control applied to pollutant emissions based upon consideration of energy, economic, and environmental factors. In a BACT analysis, the energy, economic, and environmental factors associated with each alternate control technology are evaluated, as necessary. The BACT analyses presented here consist of up to five steps for each pollutant, as outlined below.

### ***5.2.1 Identification of Technically Feasible Control Options***

The first step is identification of available technically feasible control technology options, including consideration of transferable and innovative control measures that may not have previously been applied to the source type under analysis. The minimum requirement for a BACT proposal is an option that meets federal NSPS limits or other minimum state or local requirements that would prevail in the absence of BACT decision-making, such as Reasonably Available Control Technology (RACT) or Florida emission standards. After elimination of technically infeasible control technologies, the remaining options are to be ranked by control effectiveness.

If there is only a single feasible option, or if the applicant is proposing the most stringent alternative, no further analysis is required. If two or more technically feasible options are identified, the next three steps are applied to identify and compare the energy, economic, and environmental impacts of the options. Technical considerations and site-specific sensitive issues will often play a role in BACT determinations. If the most stringent technology is rejected as BACT, the next most stringent technology is evaluated and so on.

In order to identify options for each class of equipment, a search of the USEPA RACT/BACT/LAER Clearinghouse (RBLC) has been performed. Individual searches were performed for each pollutant emitted from the new power generation equipment. Results of the RBLC search are summarized in Appendix E.

### ***5.2.2 Economic (Cost-Effectiveness) Analysis***

The cost-effectiveness evaluation relies on engineering estimates, vendor quotations, internal costing estimates, and environmental agency costing guidelines. The EPA guidance documents used in this analysis include *OAQPS Control Cost Manual*, (USEPA, EPA 450/3-90-006, January 1990) and *Alternate Control Techniques Document—NO<sub>x</sub> Emissions from Stationary Gas Turbines*, (USEPA, EPA 453/R-93-007, January 1993). The basic principles and assumptions used in the economic analysis are summarized below.

The economic portion of the BACT review consists of computing the ratio of the annualized cost of each emission control option to the annual emission reduction it can produce, represented as dollars per ton. The annualized cost of each emission control option has two components, which are the annualized total capital investment and the annual operating and maintenance cost.

The total capital investment (TCI) is the sum of the total direct costs (TDC) and total indirect costs. Direct costs are defined as the capital investment required to purchase equipment needed for the control system. Examples of direct costs include purchased equipment costs (PEC) and installation. Indirect costs include costs for site and building preparation, and contingency.

The PEC for a technically feasible control technology is based upon vendor quotations and engineering estimates for the control system specific to the proposed unit. Assumptions used to estimate elements of the TCI are provided as follows, unless site-specific values were available:

- Sales Tax - 5% of PEC;
- Freight - 4% of PEC;
- Installation - 45% of PEC;
- Engineering Costs - 33% of TDC + \$5,000; and
- Contingency - 20% of Direct and Indirect Costs.

The capital recovery factor (CRF) is used to convert capital cost estimates into equivalent annualized costs. In order to annualize capital costs, an interest rate and project life must be estimated. When the CRF is multiplied by the capital investment, the product is the uniform end-of-year payment necessary to repay the investment in a defined amount of years. The CRF can be calculated based upon the following equation:

$$CRF = \frac{i * (1+i)^n}{(1+i)^n - 1}$$

Where  $i$  = interest rate and  $n$  = number of years of the investment.

An 8% nominal interest rate has been selected for this evaluation. The investment life,  $n$ , has been assumed equal to a ten-year payback period. These values are consistent with values presented in the “*OAQPS Control Cost Manual*” and the latest update from William Vatauvuk’s companion text. Therefore, the TCI has been amortized over a ten-year period at an 8% interest rate.

The total annual operating cost is defined as the expenses associated with the annual operation of the control equipment and is the sum of direct annual costs and indirect annual costs. Direct annual costs include operating and supervisory labor, maintenance labor, and materials required to operate the control equipment. Direct annual costs also include catalyst replacement and utility costs. Indirect annual costs include overhead, property taxes, insurance and administration (including environmental reporting) associated with the operation of the control equipment. Assumptions used to estimate elements of the annual operating cost are as follows:

- Maintenance Labor - 1% of TCI;
- Maintenance Materials - 1% of TCI;
- Overhead - 60% of labor and maintenance materials;
- Property Tax - 1% of TCI;
- Insurance - 1% of TCI; and
- Administration - 2% of TCI.

Specific costing factors for feasible alternatives are identified in the appropriate pollutant-specific section. An economic analysis is not required if the most effective emission control option is proposed or if there are no technically feasible control options. An economic impact analysis was performed as part of the NO<sub>x</sub> control technology review process and the CO control technology review.

### **5.2.3 Energy Impact Analysis**

Two forms of energy impacts that may be associated with a control option can normally be quantified. Increases in energy consumption resulting from increased heat rate may be shown as incremental Btu’s or fuel consumed per year. Also, the installation of a control option may



reduce the output and/or reliability of the proposed equipment. This reduction would result in assumed loss of revenue from “lost” electric power sales to the local utility.

#### ***5.2.4 Environmental Impact Analysis***

The primary focus of the environmental impact analysis is the reduction in ambient concentrations of the pollutant being controlled. Increases or decreases in emissions of other criteria or non-criteria air contaminants may occur with some technologies, and should also be identified. Non-air impacts, such as solid waste disposal and increased water consumption/treatment, may be an issue for some projects and control options.

#### ***5.2.5 BACT Proposal***

The determination of BACT for each air pollutant and emissions unit is based on a review of the three impact categories and the technical factors that affect feasibility of the control alternatives under consideration. The methodology described above is applied to the proposed facility for the following pollutants: CO, SO<sub>2</sub>, PM/PM-10, NO<sub>x</sub>, and VOC.

### **5.3 BACT Analysis for Carbon Monoxide**

The new power generation equipment consists of a combustion turbine and a heat recovery steam generator (HRSG). The formation of CO in the operation of a combustion turbine is the result of incomplete combustion of fuel. Several conditions can lead to incomplete combustion, including insufficient O<sub>2</sub> availability, poor air and fuel mixing, cold wall flame quenching, reduced combustion temperature, decreased combustion residence time and load reduction. By controlling the combustion process carefully, CO emissions can be minimized.

#### ***5.3.1 Identification of Technically Feasible Control Options***

The proposed General Electric Model 7FA turbines have inherently low CO emissions, due to the dry low-NO<sub>x</sub> combustion technology employed. GE 7FA turbine CO emissions on natural gas are among the lowest offered for utility-scale units across the anticipated load range of 50% to 100% load. Turbine emissions are guaranteed to be no more than 9 ppmvd for this load range during gas fired operation and no more than 20 ppmvd during oil-fired operation. The part-load

emissions, in particular, compare favorably to other turbine models; some combustion turbine models have CO emissions of 100 ppm or greater at the 50% load level.

After combustion control, the only practical control method to reduce CO emissions from combustion turbine units is an oxidation catalyst. Exhaust gases from the combustion turbine are passed over a catalyst bed where excess air oxidizes the CO to carbon dioxide. CO reduction efficiencies in the range of 80 to 90 percent can be guaranteed, although CO reduction may be somewhat less than the design value at the very low inlet concentrations that are expected for the proposed turbine. A location downstream of the turbine or within the HRSG may be identified that will provide temperatures appropriate for the effective oxidation catalyst operation. Since the temperature profile will change with changing turbine load, a catalyst would be placed for optimum performance at full-load while providing some lesser degree of control at other load points. Likewise, since catalyst temperature is critical to the oxidation process, the oxidation catalyst will not be effective during combustion turbine start-up until the catalyst temperature is elevated to the necessary level. No other technically feasible options are identified for combustion turbine CO control.

Drawbacks of the oxidation catalyst include added cost, reduced turbine output and efficiency due to increased back pressure, and the potential for increased PM-10 and/or sulfuric acid mist emissions, as outlined in the following three subsections. For base-loaded units with the low emissions projected for these turbines, such controls may be ruled out as BACT, due to the high cost per ton of pollutant control. For this reason, the application of oxidation catalysts on turbines is limited; only five facility permits in the BACT/LAER Clearinghouse indicate the use of an oxidation catalyst as a control.

The energy losses associated with the use of an oxidation catalyst for CO control include reduced electrical output due to increased back-pressure, as well as the potential for lost generating capacity associated with any unplanned shutdowns for catalyst change-out, maintenance, and replacement.

A listing of economic, energy and environmental impacts associated with the proposed technology is provided under the following three subsections followed by the detailed proposal of BACT limits for the units.

### ***5.3.2 Economic Impact of Oxidation Catalyst***

The initial capital cost for the catalyst is \$1,005,200, based upon an estimate from a catalyst vendor that includes installation and contingency for the GE 7FA combustion turbines in simple cycle mode. Calculations of other costs used to derive an equivalent annual cost for the technology are detailed in Appendix E. The greatest factors in the annual operating cost are periodic catalyst replacement (a three-year guarantee is typical for a catalyst), lost revenue due to reduced turbine output and increased fuel cost due to adverse effect on turbine heat rate, or efficiency. Equivalent annual cost for this technology (annualized capital plus annual O&M costs) is \$522,842 per year. The uncontrolled CO emission levels of 9 ppmvd during natural gas firing and 20 ppmvd during oil firing can be reduced to 2 ppmvd and 4 ppmvd by an oxidation catalyst. Therefore, of the uncontrolled annual emissions of 124 tons of CO per year, an oxidation catalyst would control 99 tons of CO per year. The annual operating scenario used in the calculation (turbine operation at 100% load for 7884 hours per year firing gas and 720 hours per year firing oil) is conservative since it maximizes the tons of CO available for control by the catalyst. Since the catalyst vendor does not guarantee CO removal during start-up, these emissions are not included in the calculation. The resulting cost-effectiveness is \$5,266 per ton, which is calculated as follows:

$$(\$536,619/\text{yr})/(123 \text{ tons CO controlled}/\text{yr}) = \$4,350/\text{ton CO}$$

### ***5.3.3 Energy Impact of Oxidation Catalyst***

The energy losses associated with the use of an oxidation catalyst for CO control include reduced electrical output (193 kW reduction, or a total of, 1,517,670 kW-hr lost per year) due to increased back-pressure, as well as the potential for lost generating capacity associated with any unplanned shutdowns for catalyst change-out, maintenance, and replacement. The increase in heat rate predicted to result from the catalyst, 9 Btu/kW-hr, corresponds to an additional 14,638 MMBtu fuel consumption per year.

#### ***5.3.4 Environmental Impacts of Technically Feasible CO Control***

Based upon modeling results, all predicted CO impacts fall well below significance levels defined in the PSD regulations. Therefore, the differences in emission rates with and without the catalyst do not correlate to meaningful differences in air quality impacts. A possible benefit of using catalysts would be the oxidation of VOC's as well as CO, although the proposed VOC emissions are already quite low (maximum of 1.4 ppm) and VOC control efficiencies have not generally been guaranteed for catalysts on combustion turbines at these low emission levels. A drawback of the higher temperature catalyst location needed to reduce VOC emissions is the increased oxidation of SO<sub>2</sub> to SO<sub>3</sub>. Higher SO<sub>3</sub> concentrations increase the potential for formation of sulfuric acid mist. These substances not only add to PM/PM-10 emissions, but also may condense and stick to the ductwork and stack, resulting in corrosion and increased maintenance.

#### ***5.3.5 BACT Proposal***

The advanced dry low-NO<sub>x</sub> turbine combustion technology is proposed as BACT for CO emissions from the combined cycle unit. The proposed limits are 9 ppmvd during natural gas firing for operating loads greater than 50% (15 ppmvd during periods of power augmentation at 100% load) and 20 ppmvd during distillate fuel oil firing at 100% load (See Appendix C for CO concentrations at other loads.).

#### **5.4 BACT Analysis for Sulfur Dioxide**

Strategies for the control of SO<sub>2</sub> emissions can be divided into pre- and post-combustion categories. Pre-combustion controls entail the use of low sulfur fuels or fuel sulfur removal. Post-combustion controls comprise various wet and dry flue gas de-sulfurization (FGD) processes. However, FGD alternatives are undesirable for use on combustion turbine power facilities due to high pressure drops across the device, and would be particularly impractical for the large flue gas volumes and low SO<sub>2</sub> concentrations.

The new power generation equipment will fire natural gas as the primary fuel and 0.05% sulfur distillate as back-up, which is considered BACT for SO<sub>2</sub> emissions. The proposed maximum SO<sub>2</sub> emission rate for natural gas firing is 10 lb/hr and for distillate firing is 99 lb/hour.

## **5.5 BACT Analysis for Particulate Matter**

### **5.5.1 Combustion Turbine**

Particulate matter (PM/PM-10) emissions from combustion turbines are inherently very low, arising from impurities in combustion air and fuel, primarily from noncombustible metals present in trace quantities in liquid fuels. As a practical matter, turbine fuel specifications generally require that trace metals in the liquid fuel be kept to no more than a few parts per million to mitigate the potential deleterious action of PM/PM-10 on turbine blades. Other sources of PM/PM-10 include minerals in the injection water and PM/PM-10 present in the combustion air and NH<sub>3</sub>/sulfur salt formation due to the presence of the SCR.

The use of clean burning fuels, such as natural gas, is considered to be the most effective means for controlling PM/PM-10 emissions from combustion equipment. Post-combustion controls, such as baghouses, scrubbers, and electrostatic precipitators are impractical due to the high pressure drops associated with these units and the low concentrations of PM/PM-10 present in the exhaust gas. A review of PM/PM-10 emission limits for combustion turbines presented in the RBLC search shows that only good combustion techniques and low-sulfur fuel have been used as controls for PM/PM-10 emissions.

Because the facility plans to fire natural gas as the primary fuel and low sulfur (0.05%) distillate as the back-up fuel, the combination of clean fuels and good combustion is considered BACT for PM/PM-10 emissions. The proposed emission limits for PM/PM-10 are 20 lb/hr during natural gas firing, and 51 lb/hr during distillate firing.

### **5.5.2 Cooling Tower**

PM/PM-10 emissions from cooling towers occur because wet cooling towers provide direct contact between the cooling water and the air passing through the tower. Some of the liquid water may be entrained within the air stream and be carried out of the tower as "drift" droplets.

Therefore, the PM/PM-10 constituent (suspended and dissolved solids) of the drift droplets may be classified as an emission. Because drift droplets contain the same chemical impurities as the water circulating through the tower, these impurities can be converted into airborne emissions. To reduce drift from cooling towers, drift eliminators are usually incorporated into the tower design to prevent water droplets from leaving the tower and therefore reduce particulate emissions. The only alternative would be to reduce the solids content of the water, either by water treatment or by reducing the cycles of concentration. A review of PM/PM-10 emission limits for cooling towers, presented in the RBLC search, identifies drift eliminators as the most stringent control technique option for PM/PM-10 emissions.

Drift eliminators will be incorporated into the cooling tower design specifications, which will limit drift from the cooling tower to less than 0.0005% of the circulating water flow rate.

## **5.6 BACT Analysis for Nitrogen Oxides**

The formation of  $\text{NO}_x$  is determined by the interaction of chemical and physical processes occurring within the combustion chamber of the turbine. There are two principal forms of  $\text{NO}_x$  designated as "thermal"  $\text{NO}_x$  and "fuel"  $\text{NO}_x$ . Thermal  $\text{NO}_x$  formation is the result of oxidation of atmospheric nitrogen contained in the inlet gas in the high-temperature, post-flame region of the combustion zone. The major factors influencing thermal  $\text{NO}_x$  formation are temperature, concentrations of nitrogen and oxygen in the inlet air and residence time within the combustion zone. Fuel  $\text{NO}_x$  is formed by the oxidation of fuel-bound nitrogen. Fuel  $\text{NO}_x$  is responsible for only a small amount of the total  $\text{NO}_x$  formed in the combustion process. Adjusting the combustion process and/or installing post-combustion controls can control  $\text{NO}_x$  formation.

Typical gas turbines are designed to operate at a fuel to air ratio of 1.0. This is the point where the highest combustion temperature and quickest combustion reactions (including  $\text{NO}_x$  formation) occurs. Fuel-to-air ratios below 1.0 are referred to as fuel-lean mixtures (i.e. excess air in the combustion chamber); fuel-to-air ratios above 1.0 are referred to as fuel-rich (i.e. excess fuel in the combustion chamber). The rate of  $\text{NO}_x$  production falls off dramatically as the flame temperature decreases. Very lean dry combustors can be used to control emissions.

Based upon this concept, lean combustors are designed to operate below the 1:1 ratio thereby reducing thermal NO<sub>x</sub> formation within the combustion chamber. The lean combustors typically are two staged premixed combustors designed for use with natural gas fuel and capable of operation on liquid fuel. The first stage serves to thoroughly mix the fuel and air and to deliver a uniform, lean, unburned fuel-air mixture to the second stage. The General Electric 7FA turbine utilizes a dry low-NO<sub>x</sub> combustion system, which produces expected uncontrolled NO<sub>x</sub> emissions of 9 ppm during natural gas firing.

### ***5.6.1 Identification of Technically Feasible Control Options***

The “Top-Down” policy for BACT analysis starts at the lowest achievable emission rate (LAER) for NO<sub>x</sub>. To determine the most stringent permit limit, a search of the RBLC was performed. For a limit to be considered LAER, it requires more than just the issuance of a permit. If a facility was never built or operated, or has not demonstrated compliance through stack testing and/or continuous emissions monitoring, the facility’s emission limits have not been demonstrated to be achievable and are not considered LAER.



The most stringent permitted NO<sub>x</sub> emission limit for combustion turbines, at the time of this permit application, is 3.5 ppm for the Brooklyn Navy Yard facility. This facility utilizes a dry low-NO<sub>x</sub> GE turbine, which emits uncontrolled NO<sub>x</sub> emissions of 9 ppm and utilizes SCR NO<sub>x</sub> controls. The project had been in commercial operation for approximately three years, and was reported to be in compliance with emission limits based upon stack testing and CEM.

The new SCONO<sub>x</sub> technology has been installed on 32 MW natural gas-only plants using GE LM 2500 turbines. The facility is owned and operated by one of the parent companies of Goal Line Technologies, the SCONO<sub>x</sub> technology developer. To date, this technology has achieved a NO<sub>x</sub> emission rate comparable to those considered LAER or Best Available Control Technology (BACT) at other facilities using SCR. The NO<sub>x</sub> emission rate would not be lower with this technology based on information provided to date.

A recent assessment of the SCONO<sub>x</sub> technology (Appendix E-2) determined that this technology was not technically feasible based in part on the recent experience with the technology on a small

(5 MW) combustion turbine. The SCONO<sub>x</sub> system on this turbine is not able to meet the vendor guarantees.

SCR is an add-on NO<sub>x</sub> control technique that is placed in the exhaust stream following the gas turbine. SCR involves the injection of ammonia (NH<sub>3</sub>) into the exhaust gas stream upstream of a catalyst bed. On the catalyst surface, NH<sub>3</sub> reacts with NO<sub>x</sub> contained within the air to form nitrogen gas (N<sub>2</sub>) and water (H<sub>2</sub>O) in accordance with the following chemical equations:



The catalyst's active surface is usually a noble metal (platinum), base metal (titanium or vanadium) or a zeolite-based material. Metal based catalysts are usually applied as a coating over a metal or ceramic substrate. Zeolite catalysts are typically a homogeneous material that forms both the active surface and the substrate. The geometric configuration of the catalyst body is designed for maximum surface area and minimum obstruction of the flue gas flow path in order to achieve maximum conversion efficiency and minimum back-pressure on the gas turbine. The most common configuration is a "honeycomb" design. In a typical NH<sub>3</sub> injection system, NH<sub>3</sub> is drawn from a storage tank, vaporized and injected upstream of the catalyst bed. Excess NH<sub>3</sub> which is not reacted in the catalyst bed and which is emitted from the stack is referred to as NH<sub>3</sub> slip.

An important factor that affects the performance of an SCR is operating temperature. The temperature range for standard base metal catalyst is between 400 and 800 °F. Since SCR effective temperatures are below turbine exit temperature and above stack temperature, the catalyst must be located within the HRSG.

The only proposed, proven available technology for the proposed level of NO<sub>x</sub> control for the new power generation equipment is SCR.



### ***5.6.2 Economic Impact of Oxidation Catalyst***

In addition to having technical problems, SCONO<sub>x</sub> control technology is significantly more expensive than SCR. An economic analysis is provided in Appendix E. The estimated levelized cost per ton of NO<sub>x</sub> removal for the SCONO<sub>x</sub> technology is \$24,916/ton per year. The SCR annualized cost per ton, which is the proposed control technology for NO<sub>x</sub> removal, totaled \$2,835/ton per year.

### ***5.6.3 BACT Proposal***

The SCONO<sub>x</sub> control technology is not a demonstrated technology and SCR technology is significantly less expensive than SCONO<sub>x</sub> for the same level of NO<sub>x</sub> control. Therefore, the use of SCR technology is proposed as BACT for NO<sub>x</sub> emissions from the new power generation equipment. Proposed BACT emission limits for the new power generation equipment are 3.5 ppm (24.1 lb/hr) NO<sub>x</sub> during natural gas firing and 10 ppm (80.0 lb/hr) NO<sub>x</sub> during distillate firing.

**APPENDIX A**  
**AIR PERMIT APPLICATION FORMS**



# Department of Environmental Protection

## Division of Air Resources Management

### APPLICATION FOR AIR PERMIT - TITLE V SOURCE

See Instructions for Form No. 62-210.900(1)

#### I. APPLICATION INFORMATION

##### Identification of Facility

|  |   |
|--|---|
| 1. Facility Owner/Company Name:<br>CPV Gulfcoast, Ltd.   |   |
| 2. Site Name:<br>CPV Gulfcoast   |   |
| 3. Facility Identification Number: <span style="float: right;">[ X ]</span><br>Unknown   |   |
| 4. Facility Location:<br>Street Address or Other Locator:<br>City: <span style="margin-left: 150px;">County: Manatee</span> <span style="float: right;">Zip Code:</span> |   |
| 5. Relocatable Facility?<br>[ ] Yes [ X ] No   | 6. Existing Permitted Facility?<br>[ ] Yes [ X ] No |

##### Application Contact

|   |  |
|---|--|
| 1. Name and Title of Application Contact:<br>Sean Finnerty, Director of Development   |  |
| 2. Application Contact Mailing Address:<br>Organization/Firm: CPV Gulfcoast, Ltd.<br>Street Address: 45 Bristol Road, Suite 101<br>City: Easton <span style="margin-left: 150px;">State: MA</span> <span style="float: right;">Zip Code: 02375</span> |  |
| 3. Application Contact Telephone Numbers:<br>Telephone: ( 508 ) 238 - 0194 <span style="margin-left: 150px;">Fax: ( 508 ) 238 - 2844</span>   |  |

##### Application Processing Information (DEP Use)

|                                    |                |
|------------------------------------|----------------|
| 1. Date of Receipt of Application: | 9-11-00        |
| 2. Permit Number:                  | 0810194-001-AC |
| 3. PSD Number (if applicable):     | PSD-FL-300     |
| 4. Siting Number (if applicable):  |                |

**Purpose of Application**

**Air Operation Permit Application**

This Application for Air Permit is submitted to obtain: (Check one)

- Initial Title V air operation permit for an existing facility which is classified as a Title V source.
- Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number: \_\_\_\_\_

- Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number: \_\_\_\_\_

Operation permit number to be revised: \_\_\_\_\_

- Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.)

Operation permit number to be revised/corrected: \_\_\_\_\_

- Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.

Operation permit number to be revised: \_\_\_\_\_

Reason for revision: \_\_\_\_\_

**Air Construction Permit Application**

This Application for Air Permit is submitted to obtain: (Check one)

- Air construction permit to construct or modify one or more emissions units.
- Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.
- Air construction permit for one or more existing, but unpermitted, emissions units.

**Owner/Authorized Representative or Responsible Official**

|   |
|---|
| 1. Name and Title of Owner/Authorized Representative or Responsible Official:<br>Gary Lambert, Executive Vice President   |
| 2. Owner/Authorized Representative or Responsible Official Mailing Address:<br>Organization/Firm: CPV Gulfcoast, Ltd.<br>Street Address: 45 Bristol Road, Suite 101<br>City: Easton State: MA Zip Code: 02375   |
| 3. Owner/Authorized Representative or Responsible Official Telephone Numbers:<br>Telephone: ( 508 ) 238 - 0194 Fax: ( 508 ) 238 - 2844  |
| 4. Owner/Authorized Representative or Responsible Official Statement:<br><i>I, the undersigned, am the owner or authorized representative*(check here [ ], if so) or the responsible official (check here [ ], if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i><br><br>_____<br>Signature Date |

\* Attach letter of authorization if not currently on file.

**Professional Engineer Certification**

|  |
|--|
| 1. Professional Engineer Name:<br>Registration Number:   |
| 2. Professional Engineer Mailing Address:<br>Organization/Firm:<br>Street Address:<br>City: State: Zip Code: |
| 3. Professional Engineer Telephone Numbers:<br>Telephone: ( ) - Fax: ( ) -                                   |

4. Professional Engineer Statement:

*I, the undersigned, hereby certify, except as particularly noted herein\*, that:*

*(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and*

*(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.*

*If the purpose of this application is to obtain a Title V source air operation permit (check here [  ], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.*

*If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [  ], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.*

*If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [  ], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.*

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

(seal)

\* Attach any exception to certification statement.





**Construction/Modification Information**

1. Description of Proposed Project or Alterations:

Construction of a combined cycle power generation facility consisting of one 170-MW General Electric 107FA combustion turbine and heat recovery steam generator designed to power a steam turbine with an operationally controlled generating capacity of 74.9 MW.

2. Projected or Actual Date of Commencement of Construction: To be determined.

3. Projected Date of Completion of Construction: To be determined.

**Application Comment**

[Empty box for Application Comment]



**Facility Regulatory Classifications**

**Check all that apply:**

|   |                                  |
|---|----------------------------------|
| 1. <input type="checkbox"/> Small Business Stationary Source?   | <input type="checkbox"/> Unknown |
| 2. <input checked="" type="checkbox"/> Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)?                             |                                  |
| 3. <input type="checkbox"/> Synthetic Minor Source of Pollutants Other than HAPs?   |                                  |
| 4. <input type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)?  |                                  |
| 5. <input type="checkbox"/> Synthetic Minor Source of HAPs?   |                                  |
| 6. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS?   |                                  |
| 7. <input type="checkbox"/> One or More Emission Units Subject to NESHAP?   |                                  |
| 8. <input type="checkbox"/> Title V Source by EPA Designation?  |                                  |
| 8. Facility Regulatory Classifications Comment (limit to 200 characters):<br><br>Combustion turbine subject to 40 CFR Part 60 Subpart GG. |                                  |

**List of Applicable Regulations**

|                |  |
|----------------|--|
| Not Applicable |  |
|                |  |
|                |  |
|                |  |
|                |  |
|                |  |
|                |  |
|                |  |
|                |  |
|                |  |

## B. FACILITY POLLUTANTS

### List of Pollutants Emitted

| 1. Pollutant Emitted | 2. Pollutant Classif. | 3. Requested Emissions Cap |           | 4. Basis for Emissions Cap | 5. Pollutant Comment       |
|----------------------|-----------------------|----------------------------|-----------|----------------------------|----------------------------|
|                      |                       | lb/hour                    | tons/year |                            |                            |
| SO2                  | A                     |                            |           |                            | Sulfur Dioxide             |
| NOX                  | A                     |                            |           |                            | Nitrogen Oxides            |
| PM                   | A                     |                            |           |                            | Particulate Matter         |
| PM10                 | A                     |                            |           |                            | Particulate Matter < 10 µm |
| CO                   | A                     |                            |           |                            | Carbon Monoxide            |
| VOC                  | B                     |                            |           |                            | Volatile Organic Compounds |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |
|                      |                       |                            |           |                            |                            |

**C. FACILITY SUPPLEMENTAL INFORMATION**

**Supplemental Requirements**

|   |
|---|
| 1. Area Map Showing Facility Location:<br><input checked="" type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested  |
| 2. Facility Plot Plan:<br><input checked="" type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested  |
| 3. Process Flow Diagram(s):<br><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested  |
| 4. Precautions to Prevent Emissions of Unconfined Particulate Matter:<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested   |
| 5. Fugitive Emissions Identification:<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested   |
| 6. Supplemental Information for Construction Permit Application:<br><input checked="" type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable  |
| 7. Supplemental Requirements Comment:<br><br>Supplemental information includes air quality modeling study that demonstrates facility's maximum ambient air quality impacts are below Significant Impact Levels and emission control technology review that demonstrates facility's consistency with Best Available Control Technology requirements. |

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

|   |
|---|
| 8. List of Proposed Insignificant Activities:<br><input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable   |
| 9. List of Equipment/Activities Regulated under Title VI:<br><input type="checkbox"/> Attached, Document ID:_____<br><input type="checkbox"/> Equipment/Activities On site but Not Required to be Individually Listed<br><input type="checkbox"/> Not Applicable  |
| 10. Alternative Methods of Operation:<br><input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable   |
| 11. Alternative Modes of Operation (Emissions Trading):<br><input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable   |
| 12. Identification of Additional Applicable Requirements:<br><input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable   |
| 13. Risk Management Plan Verification:<br><input type="checkbox"/> Plan previously submitted to Chemical Emergency Preparedness and Prevention Office (CEPPO). Verification of submittal attached (Document ID:_____) or previously submitted to DEP (Date and DEP Office:_____)<br><input type="checkbox"/> Plan to be submitted to CEPPO (Date required:_____)<br><input type="checkbox"/> Not Applicable |
| 14. Compliance Report and Plan:<br><input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable   |
| 15. Compliance Certification (Hard-copy Required):<br><input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable  |

**III. EMISSIONS UNIT INFORMATION**

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION  
(All Emissions Units)**

**Emissions Unit Description and Status**

|   |   |  |  |
|---|---|--|--|
| <p>1. Type of Emissions Unit Addressed in This Section: (Check one)</p> <p><input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.</p> |   |  |  |
| <p>2. Regulated or Unregulated Emissions Unit? (Check one)</p> <p><input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.</p> <p><input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.</p>  |   |  |  |
| <p>1. Description of Emissions Unit Addressed in This Section (limit to 60 characters):</p> <p>General Electric 107FA combustion turbine</p>  |   |  |  |
| <p>4. Emissions Unit Identification Number: <input type="checkbox"/> No ID</p> <p>ID: <input checked="" type="checkbox"/> ID Unknown</p>  |   |  |  |
| <p>5. Emissions Unit Status Code:</p> <p>C</p>  | <p>6. Initial Startup Date:</p> <p>September 2003</p> | <p>7. Emissions Unit Major Group SIC Code:</p> <p>49</p> | <p>8. Acid Rain Unit?</p> <p><input checked="" type="checkbox"/></p> |
| <p>9. Emissions Unit Comment: (Limit to 500 Characters)</p> <p>Construction of a combined cycle power generation facility consisting of one 170-MW General Electric 107FA combustion turbine and heat recovery steam generator designed to power a steam turbine with an operationally controlled generating capacity of 74.9 MW.</p>   |   |  |  |

**Emissions Unit Control Equipment**

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

Selective Catalytic Reduction

2. Control Device or Method Code(s): 65

**Emissions Unit Details**

1. Package Unit:

Manufacturer: General Electric

Model Number: 107FA

2. Generator Nameplate Rating: 170 MW

3. Incinerator Information:

Dwell Temperature: °F

Dwell Time: seconds

Incinerator Afterburner Temperature: °F



**B. EMISSIONS UNIT CAPACITY INFORMATION  
(Regulated Emissions Units Only)**

**Emissions Unit Operating Capacity and Schedule**

|  |                    |                   |          |
|--|--------------------|-------------------|----------|
| 1. Maximum Heat Input Rate:  | 1700 (natural gas) | 1918 (distillate) | mmBtu/hr |
| 2. Maximum Incineration Rate:  | lb/hr              |                   | tons/day |
| 3. Maximum Process or Throughput Rate:   |                    |                   |          |
| 4. Maximum Production Rate:  |                    |                   |          |
| 5. Requested Maximum Operating Schedule:   | hours/day          | days/week         |          |
|  | weeks/year         | 8760 hours/year   |          |
| 6. Operating Capacity/Schedule Comment (limit to 200 characters):  |                    |                   |          |
| Maximum heat input based on lower heating values of fuels: <ul style="list-style-type: none"> <li>• Natural gas - 21,500 Btu/lb</li> <li>• Distillate - 18,200 Btu/lb</li> </ul> |                    |                   |          |

**C. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

**List of Applicable Regulations**

|                 |  |
|-----------------|--|
| Rule 62-204.220 | Ambient Air Quality Protection                                       |
| Rule 62-204.240 | Ambient Air Quality Standards  |
| Rule 62-204.260 | Prevention of Significant Deterioration<br>Increments                |
| Rule 62-204.800 | Federal Regulations Adopted by Reference                             |
| Rule 62-210.300 | Permits Required   |
| Rule 62-210.350 | Public Notice and Comments   |
| Rule 62-210.370 | Reports  |
| Rule 62-210.550 | Stack Height Policy  |
| Rule 62-210.650 | Circumvention  |
| Rule 62-210.700 | Excess Emissions   |
| Rule 62-210.900 | Forms and Instructions   |
| Rule 62-212.300 | General Preconstruction Review Requirements                          |
| Rule 62-212.400 | Prevention of Significant Deterioration                              |
| Rule 62-213     | Operation Permits for Major Sources of Air<br>Pollution              |
| Rule 62-214     | Requirements For Sources Subject To The Federal<br>Acid Rain Program |
| Rule 62-296.320 | General Pollutant Emission Limiting Standards                        |
| Rule 62-297.310 | General Test Requirements  |
| Rule 62-297.401 | Compliance Test Methods  |
| Rule 62-297.520 | EPA Continuous Monitor Performance<br>Specifications                 |



**D. EMISSION POINT (STACK/VENT) INFORMATION  
(Regulated Emissions Units Only)**

**Emission Point Description and Type**

|  |   |   |  |
|--|---|---|--|
| 1. Identification of Point on Plot Plan or Flow Diagram? See CPV-GC Appendix B. Drawing SC004  |   | 2. Emission Point Type Code: 1                  |  |
| 3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):<br><br>Exhaust through a single 150-foot stack. |   |   |  |
| 4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:  |   |   |  |
| 5. Discharge Type Code: V  | 6. Stack Height:<br><br>150 feet                          | 7. Exit Diameter:<br><br>18.5 feet              |  |
| 8. Exit Temperature:<br>See CPV-GC, Appendix C °F  | 9. Actual Volumetric Flow Rate:<br>See CPV-GC, Appendix C | 10. Water Vapor:<br>See CPV-GC, Appendix C %    |  |
| 11. Maximum Dry Standard Flow Rate:<br><br>dscfm   |   | 12. Nonstack Emission Point Height:<br><br>feet |  |
| 13. Emission Point UTM Coordinates:<br><br>Zone: 17 East (km): 348.5 North (km): 3057.0  |   |   |  |
| 14. Emission Point Comment (limit to 200 characters):<br><br>See CPV-GC, Appendix C for all operating conditions.  |   |   |  |

**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
**(All Emissions Units)**

**Segment Description and Rate:** Segment 1 of 2

|  |                                   |                                      |
|--|-----------------------------------|--------------------------------------|
| 1. Segment Description (Process/Fuel Type) (limit to 500 characters):<br><br>natural gas |                                   |                                      |
| 2. Source Classification Code (SCC):<br>20100201   |                                   | 3. SCC Units: Million Cubic Feet     |
| 4. Maximum Hourly Rate:<br>1.81  | 5. Maximum Annual Rate:<br>15,856 | 6. Estimated Annual Activity Factor: |
| 7. Maximum % Sulfur:<br>0.008  | 8. Maximum % Ash:                 | 9. Million Btu per SCC Unit:<br>940  |
| 10. Segment Comment (limit to 200 characters):   |                                   |                                      |

**Segment Description and Rate:** Segment 2 of 2

|  |                                   |                                       |
|--|-----------------------------------|---------------------------------------|
| 1. Segment Description (Process/Fuel Type ) (limit to 500 characters):<br><br>distillate |                                   |                                       |
| 2. Source Classification Code (SCC):<br>20100101   |                                   | 3. SCC Units: 1000 Gallons            |
| 4. Maximum Hourly Rate:<br>14.562  | 5. Maximum Annual Rate:<br>10,485 | 6. Estimated Annual Activity Factor:  |
| 7. Maximum % Sulfur:<br>0.05   | 8. Maximum % Ash:                 | 9. Million Btu per SCC Unit:<br>131.7 |
| 10. Segment Comment (limit to 200 characters):   |                                   |                                       |



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

|   |   |
|---|---|
| 1. Pollutant Emitted: SO <sub>2</sub>   | 2. Total Percent Efficiency of Control: |
| 3. Potential Emissions:<br>10 (natural gas), 99 (distillate) lb/hour 75.8 tons/year   | 4. Synthetically Limited? [ ]           |
| 5. Range of Estimated Fugitive Emissions:<br>[ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year   |   |
| 6. Emission Factor:<br>Reference: General Electric, Burns and Roe   | 7. Emissions Method Code: 2             |
| 8. Calculation of Emissions (limit to 600 characters):<br>Short term emissions:<br>See CPV-GC Appendix C<br>Values are maximum rates for all operating conditions<br>Annual emissions:<br>[(10 lb/hr) X (335 days/year) X (24 hr/day) + (99 lb/hr) X (30 days/year) X (24 hr/day)] / (2000 lb/ton) = 75.8 tons/year |   |
| 10. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):<br>Emissions are for worst case operating load condition. See CPV-GC, Appendix C for emissions at other load conditions.  |   |

**Allowable Emissions** Allowable Emissions  1  of  1

|   |   |
|---|---|
| 1. Basis for Allowable Emissions Code:<br>OTHER   | 2. Future Effective Date of Allowable Emissions:  |
| 3. Requested Allowable Emissions and Units:<br>Natural gas: 0.0065% (sulfur in fuel by weight)<br>Distillate: 0.05% (sulfur in fuel by weight)            | 4. Equivalent Allowable Emissions:<br>10 (natural gas), 99 (distillate) lb/hour<br>75.8 tons/year |
| 5. Method of Compliance (limit to 60 characters):<br>Fuel sampling  |   |
| 6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):<br>Concentration limits apply for operating loads greater than 50%. |   |

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

|   |   |
|---|---|
| 1. Pollutant Emitted: NOX   | 2. Total Percent Efficiency of Control: |
| 3. Potential Emissions:<br>24.1 (natural gas), 80 (distillate) lb/hour 125.7 tons/year  | 4. Synthetically Limited? [ ]           |
| 5. Range of Estimated Fugitive Emissions:<br>[ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year   |   |
| 6. Emission Factor:<br>Reference: General Electric, Burns and Roe   | 7. Emissions Method Code: 2             |
| 8. Calculation of Emissions (limit to 600 characters):<br><br>Short term emissions:<br>See CPV-GC Appendix C<br>Values are maximum rates for all operating conditions<br><br>Annual emissions:<br>[(24.1 lb/hr) X (335 days/year) X (24 hr/day) + (80 lb/hr) X (30 days/year) X (24 hr/day)] / (2000 lb/ton)<br>= 125.7 tons/year |   |
| 9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  |   |

**Allowable Emissions** Allowable Emissions  1  of  1

|   |  |
|---|--|
| 1. Basis for Allowable Emissions Code:<br>OTHER   | 2. Future Effective Date of Allowable Emissions:   |
| 4. Requested Allowable Emissions and Units:<br>Natural Gas: 3.5 ppmvd @ 15% O <sub>2</sub><br>Distillate: 10 ppmvd @ 15% O <sub>2</sub>                       | 4. Equivalent Allowable Emissions:<br>24.1 (natural gas), 80 (distillate) lb/hour<br>125.7 tons/year |
| 5. Method of Compliance (limit to 60 characters):<br>CEM - 3 hour block average   |  |
| 6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):<br><br>Concentration limits apply for operating loads greater than 50%. |  |



Emissions Unit Information Section  1  of  2

Pollutant Detail Information Page  3  of  6

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

|  |   |
|--|---|
| 1. Pollutant Emitted: PM   | 2. Total Percent Efficiency of Control: |
| 3. Potential Emissions:<br>20 (natural gas), 53 (distillate) lb/hour      99.5 tons/year   | 4. Synthetically Limited? [   ]         |
| 5. Range of Estimated Fugitive Emissions:<br>[   ] 1      [   ] 2      [   ] 3      _____ to _____ tons/year   |   |
| 6. Emission Factor:<br>Reference: General Electric, Burns and Roe  | 7. Emissions Method Code: 2             |
| 8. Calculation of Emissions (limit to 600 characters):<br><br>Short term emissions:<br>See CPV-GC Appendix C<br>Values are maximum rates for all operating conditions<br>Annual emissions:<br>[(20 lb/hr) X (335 days/year) X (24 hr/day) + (53 lb/hr) X (30 days/year) X (24 hr/day)] / (2000 lb/ton)<br>= 99.5 tons/year |   |
| 9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):   |   |

**Allowable Emissions** Allowable Emissions  1  of  1

|   |   |
|---|---|
| 1. Basis for Allowable Emissions Code:<br>OTHER   | 2. Future Effective Date of Allowable Emissions:  |
| 3. Requested Allowable Emissions and Units:<br>20 lb/hour (natural gas), 53 lb/hour (distillate)  | 4. Equivalent Allowable Emissions:<br>20 (natural gas), 53 (distillate) lb/hour<br>99.5 tons/year |
| 5. Method of Compliance (limit to 60 characters):<br>Annual stack test, USEPA Method 5  |   |
| 6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):<br><br>Concentration limits apply for operating loads greater than 50%. |   |

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

|  |   |
|--|---|
| 1. Pollutant Emitted: PM10   | 2. Total Percent Efficiency of Control: |
| 3. Potential Emissions:<br>20 (natural gas), 53 (distillate) lb/hour 99.5 tons/year  | 4. Synthetically Limited? [ ]           |
| 5. Range of Estimated Fugitive Emissions:<br>[ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year  |   |
| 6. Emission Factor:<br>Reference: General Electric, Burns and Roe  | 7. Emissions Method Code: 2             |
| 8. Calculation of Emissions (limit to 600 characters):<br><br>Short term emissions:<br>See CPV-GC Appendix C<br>Values are maximum rates for all operating conditions<br>Annual emissions:<br>[(20 lb/hr) X (335 days/year) X (24 hr/day) + (53 lb/hr) X (30 days/year) X (24 hr/day)] / (2000 lb/ton)<br>= 99.5 tons/year |   |
| 9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):   |   |

**Allowable Emissions** Allowable Emissions  1  of  1

|   |  |
|---|--|
| 1. Basis for Allowable Emissions Code:<br>OTHER   | 2. Future Effective Date of Allowable Emissions:   |
| 3. Requested Allowable Emissions and Units:<br>20 lb/hour (natural gas), 51 lb/hour (distillate)  | 4. Equivalent Allowable Emissions:<br>20 (natural gas), 53 (distillate) lb/hour 99.5 tons/year |
| 5. Method of Compliance (limit to 60 characters):<br>Annual stack test, USEPA Method 5  |  |
| 6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):<br><br>Concentration limits apply for operating loads greater than 50%. |  |

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

|   |  |
|---|--|
| 1. Pollutant Emitted: CO  | 2. Total Percent Efficiency of Control:                |
| 3. Potential Emissions:<br>See CPV-GC Appendix C. lb/hour <u> 222.2 </u> tons/year  | 4. Synthetically Limited? [ <input type="checkbox"/> ] |
| 5. Range of Estimated Fugitive Emissions:<br>[ <input type="checkbox"/> ] 1 [ <input type="checkbox"/> ] 2 [ <input type="checkbox"/> ] 3 _____ to _____ tons/year  |  |
| 6. Emission Factor:<br>Reference: General Electric, Burns and Roe   | 7. Emissions Method Code: 2                            |
| 8. Calculation of Emissions (limit to 600 characters):<br>Short term emissions:<br>See CPV-GC Appendix C<br>Values are maximum rates at 100% operating load<br>Annual emissions:<br>[(49 lb/hr) X (335 days/year) X (24 hr/day) + (70 lb/hr) X (30 days/year) X (24 hr/day)] / (2000 lb/ton)<br>= 222.2 tons/year |  |
| 9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):<br>Potential annual emission rate assumes continuous power augmentation when natural gas firing.   |  |

**Allowable Emissions** Allowable Emissions  1  of  1

|   |   |
|---|---|
| 1. Basis for Allowable Emissions Code:  | 2. Future Effective Date of Allowable Emissions:  |
| 3. Requested Allowable Emissions and Units:<br>See CPV-GC Appendix C.   | 4. Equivalent Allowable Emissions:<br>See CPV-GC Appendix C. lb/hour <u> 222.2 </u> tons/year |
| 5. Method of Compliance (limit to 60 characters):<br><br>24-hr block average demonstrated by CEMS               |   |
| 6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):<br>See CPV-GC Appendix C. |   |

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

|   |   |
|---|---|
| 1. Pollutant Emitted: VOC   | 2. Total Percent Efficiency of Control:         |
| 3. Potential Emissions:<br>3 (natural gas), 8 (distillate) lb/hour  | 4. Synthetically Limited? [ ]<br>14.8 tons/year |
| 5. Range of Estimated Fugitive Emissions:<br>[ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year   |   |
| 6. Emission Factor:<br>Reference: General Electric, Burns and Roe   | 7. Emissions Method Code: 2                     |
| 8. Calculation of Emissions (limit to 600 characters):<br><br>Short term emissions:<br>See CPV-GC Appendix C<br>Values are maximum rates for all operating conditions<br>Annual emissions:<br>[(3 lb/hr) X (335 days/year) X (24 hr/day) + (8 lb/hr) X (30 days/year) X (24 hr/day)] /<br>(2000 lb/ton)<br>= 14.8 tons/year |   |
| 9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  |   |

**Allowable Emissions** Allowable Emissions  1  of  1

|   |  |
|---|--|
| 1. Basis for Allowable Emissions Code:<br>OTHER   | 2. Future Effective Date of Allowable Emissions:   |
| 3. Requested Allowable Emissions and Units:<br>1.4 ppmvw as CH <sub>4</sub> (natural gas)<br>3.5 ppmvw as CH <sub>4</sub> (distillate)                        | 4. Equivalent Allowable Emissions:<br>3 (natural gas), 8 (distillate) lb/hour 14.8 tons/year |
| 5. Method of Compliance (limit to 60 characters):<br>USEPA Method 25A   |  |
| 6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):<br><br>Concentration limits apply for operating loads greater than 50%. |  |

**H. VISIBLE EMISSIONS INFORMATION**  
 (Only Regulated Emissions Units Subject to a VE Limitation)

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

|  |   |
|--|---|
| 1. Visible Emissions Subtype: VE20   | 2. Basis for Allowable Opacity:<br>[ X ] Rule [ ] Other |
| 3. Requested Allowable Opacity:<br>Normal Conditions: 20 %                      Exceptional Conditions: %<br>Maximum Period of Excess Opacity Allowed:                      min/hour |   |
| 4. Method of Compliance:<br>Annual test using USEPA Method 9   |   |
| 5. Visible Emissions Comment (limit to 200 characters):  |   |

**I. CONTINUOUS MONITOR INFORMATION**  
 (Only Regulated Emissions Units Subject to Continuous Monitoring)

**Continuous Monitoring System:** Continuous Monitor \_\_\_\_\_ of \_\_\_\_\_

|   |   |
|---|---|
| 1. Parameter Code: EM   | 2. Pollutant(s): NOX, CO                |
| 3. CMS Requirement:<br>[ X ] Rule [ ] Other   |   |
| 4. Monitor Information:<br>Manufacturer: Not yet determined.<br>Model Number:<br>Serial Number: |   |
| 5. Installation Date:   | 6. Performance Specification Test Date: |
| 7. Continuous Monitor Comment (limit to 200 characters):  |   |

**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)**

**Supplemental Requirements**

|  |
|--|
| 1. Process Flow Diagram<br><input type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested                                 |
| 2. Fuel Analysis or Specification<br><input checked="" type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested            |
| 3. Detailed Description of Control Equipment<br><input checked="" type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested |
| 4. Description of Stack Sampling Facilities<br><input checked="" type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested  |
| 5. Compliance Test Report<br><input type="checkbox"/> Attached, Document ID: _____<br><input type="checkbox"/> Previously submitted, Date: _____<br><input checked="" type="checkbox"/> Not Applicable     |
| 6. Procedures for Startup and Shutdown<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested               |
| 7. Operation and Maintenance Plan<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested                    |
| 8. Supplemental Information for Construction Permit Application<br><input checked="" type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable                        |
| 9. Other Information Required by Rule or Statute<br><input checked="" type="checkbox"/> Attached, Document ID: <u>CPV-GC</u> <input type="checkbox"/> Not Applicable                                       |
| 10. Supplemental Requirements Comment:<br><br><br><br><br><br><br><br><br><br>   |

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

|   |
|---|
| 11. Alternative Methods of Operation<br><input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable   |
| 12. Alternative Modes of Operation (Emissions Trading)<br><input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable   |
| 13. Identification of Additional Applicable Requirements<br><input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable   |
| 14. Compliance Assurance Monitoring Plan<br><input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable   |
| 15. Acid Rain Part Application (Hard-copy Required)<br><input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a))<br>Attached, Document ID:_____<br><input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.)<br>Attached, Document ID:_____<br><input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.)<br>Attached, Document ID:_____<br><input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.)<br>Attached, Document ID:_____<br><input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.)<br>Attached, Document ID:_____<br><input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.)<br>Attached, Document ID:_____<br><input checked="" type="checkbox"/> Not Applicable |

**III. EMISSIONS UNIT INFORMATION**

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION  
(All Emissions Units)**

**Emissions Unit Description and Status**

|   |   |  |  |
|---|---|--|--|
| <p>1. Type of Emissions Unit Addressed in This Section: (Check one)</p> <p><input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.</p> |   |  |  |
| <p>2. Regulated or Unregulated Emissions Unit? (Check one)</p> <p><input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.</p> <p><input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.</p>  |   |  |  |
| <p>3. Description of Emissions Unit Addressed in This Section (limit to 60 characters):</p> <p>Fresh Water Cooling Tower</p>  |   |  |  |
| <p>4. Emissions Unit Identification Number: <span style="float: right;"><input type="checkbox"/> No ID</span></p> <p>ID: <span style="float: right;"><input checked="" type="checkbox"/> ID Unknown</span></p>  |   |  |  |
| <p>5. Emissions Unit Status Code:</p> <p style="text-align: center;">C</p>  | <p>6. Initial Startup Date:</p> <p style="text-align: center;">September 2003</p> | <p>7. Emissions Unit Major Group SIC Code:</p> <p style="text-align: center;">49</p> | <p>8. Acid Rain Unit?</p> <p style="text-align: center;"><input checked="" type="checkbox"/></p> |
| <p>9. Emissions Unit Comment: (Limit to 500 Characters)</p><br><br><br><br>   |   |  |  |



**Emissions Unit Control Equipment**

6. Control Equipment/Method Description (Limit to 200 characters per device or method):

High efficiency drift eliminators.

2. Control Device or Method Code(s): 15

**Emissions Unit Details**

|                                |                                      |         |
|--------------------------------|--------------------------------------|---------|
| 1. Package Unit:               |                                      |         |
| Manufacturer:                  | General Electric                     |         |
| Model Number:                  |                                      |         |
| 2. Generator Nameplate Rating: | MW                                   |         |
| 3. Incinerator Information:    |                                      |         |
|                                | Dwell Temperature:                   | °F      |
|                                | Dwell Time:                          | seconds |
|                                | Incinerator Afterburner Temperature: | °F      |

**B. EMISSIONS UNIT CAPACITY INFORMATION  
(Regulated Emissions Units Only)**

**Emissions Unit Operating Capacity and Schedule**

|   |  |      |            |
|---|--|------|------------|
| 1. Maximum Heat Input Rate:                                       | mmBtu/hr   |      |            |
| 2. Maximum Incineration Rate:                                     | lb/hr  |      | tons/day   |
| 3. Maximum Process or Throughput Rate:                            | 75,000 gal/min   |      |            |
| 4. Maximum Production Rate:                                       |  |      |            |
| 5. Requested Maximum Operating Schedule:                          |  |      |            |
|   | 24 hours/day   | 7    | days/week  |
|   | 52 weeks/year  | 8760 | hours/year |
| 7. Operating Capacity/Schedule Comment (limit to 200 characters): | Maximum process rate (Item 3) is cooling tower water circulation rate. |      |            |



**D. EMISSION POINT (STACK/VENT) INFORMATION  
(Regulated Emissions Units Only)**

**Emission Point Description and Type**

|   |   |   |  |
|---|---|---|--|
| 1. Identification of Point on Plot Plan or Flow Diagram? Cooling Tower  |   | 2. Emission Point Type Code:                |  |
| 3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):  |   |   |  |
| 4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:   |   |   |  |
| 5. Discharge Type Code:   | 6. Stack Height:<br>58 feet             | 7. Exit Diameter:<br>42 feet                |  |
| 8. Exit Temperature:<br>°F  | 9. Actual Volumetric Flow Rate:<br>acfm | 10. Water Vapor:<br>%                       |  |
| 11. Maximum Dry Standard Flow Rate:<br>dscfm  |   | 12. Nonstack Emission Point Height:<br>feet |  |
| 13. Emission Point UTM Coordinates:<br>Zone: East (km): North (km):   |   |   |  |
| 14. Emission Point Comment (limit to 200 characters):<br><br>Cooling tower consists of 5 cells. Exhaust temperature and flow rate vary with changes in ambient temperature. |   |   |  |

**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
(All Emissions Units)

**Segment Description and Rate:** Segment  1  of  2

|   |                                       |  |
|---|---------------------------------------|--|
| 1. Segment Description (Process/Fuel Type) (limit to 500 characters):<br><br>Fresh water cooling tower re-circulation water flow rate |                                       |  |
| 2. Source Classification Code (SCC):  |                                       | 3. SCC Units: 1000 gallons of water circulated |
| 2. Maximum Hourly Rate:<br>4,500  | 3. Maximum Annual Rate:<br>39,420,000 | 6. Estimated Annual Activity Factor:           |
| 7. Maximum % Sulfur:  | 8. Maximum % Ash:                     | 9. Million Btu per SCC Unit:                   |
| 10. Segment Comment (limit to 200 characters):  |                                       |  |

**Segment Description and Rate:** Segment  2  of  2

|  |                         |                                      |
|--|-------------------------|--------------------------------------|
| 1. Segment Description (Process/Fuel Type ) (limit to 500 characters): |                         |                                      |
| 2. Source Classification Code (SCC):                                   |                         | 3. SCC Units:                        |
| 4. Maximum Hourly Rate:  | 5. Maximum Annual Rate: | 6. Estimated Annual Activity Factor: |
| 7. Maximum % Sulfur:   | 8. Maximum % Ash:       | 9. Million Btu per SCC Unit:         |
| 10. Segment Comment (limit to 200 characters):                         |                         |                                      |



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

|  |   |
|--|---|
| 1. Pollutant Emitted: PM/PM10  | 2. Total Percent Efficiency of Control: |
| 3. Potential Emissions:<br>0.79 lb/hour      3.5 tons/year   | 4. Synthetically Limited? [ ]           |
| 5. Range of Estimated Fugitive Emissions:<br>[ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year   |   |
| 6. Emission Factor:<br>Reference:  | 7. Emissions Method Code: 3             |
| 8. Calculation of Emissions (limit to 600 characters):<br><br>See CPV-GC Appendix D-5.<br><br>[(0.79 lb/hr) X ( 8760 hr/year)] / (2000 lb/ton) = 3.5 tons/year |   |
| 9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):   |   |

**Allowable Emissions** Allowable Emissions  1  of  1

|   |   |
|---|---|
| 1. Basis for Allowable Emissions Code:  | 2. Future Effective Date of Allowable Emissions:                      |
| 3. Requested Allowable Emissions and Units:<br>0.0005% drift loss                           | 4. Equivalent Allowable Emissions:<br>0.79 lb/hour      3.5 tons/year |
| 5. Method of Compliance (limit to 60 characters):<br><br>Cooling tower design and operation |   |
| 6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):       |   |

**H. VISIBLE EMISSIONS INFORMATION**  
 (Only Regulated Emissions Units Subject to a VE Limitation)

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

|  |  |
|--|--|
| 1. Visible Emissions Subtype:  | 2. Basis for Allowable Opacity:<br><input type="checkbox"/> Rule <input type="checkbox"/><br>Other |
| 3. Requested Allowable Opacity:<br>Normal Conditions: _____ %      Exceptional Conditions: _____ %<br>Maximum Period of Excess Opacity Allowed: _____ min/hour |  |
| 4. Method of Compliance:   |  |
| 5. Visible Emissions Comment (limit to 200 characters):  |  |

**I. CONTINUOUS MONITOR INFORMATION**  
 (Only Regulated Emissions Units Subject to Continuous Monitoring)

**Continuous Monitoring System:** Continuous Monitor \_\_\_\_\_ of \_\_\_\_\_

|   |  |
|---|--|
| 1. Parameter Code:  | 2. Pollutant(s):                                       |
| 3. CMS Requirement:<br>Other  | <input type="checkbox"/> Rule <input type="checkbox"/> |
| 4. Monitor Information:<br>Manufacturer:<br>Model Number:<br>Serial Number: |  |
| 5. Installation Date:   | 6. Performance Specification Test Date:                |
| 7. Continuous Monitor Comment (limit to 200 characters):                    |  |



**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)**

**Supplemental Requirements**

|  |
|--|
| 1. Process Flow Diagram<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested                          |
| 2. Fuel Analysis or Specification<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested                |
| 3. Detailed Description of Control Equipment<br><input checked="" type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested     |
| 4. Description of Stack Sampling Facilities<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested      |
| 5. Compliance Test Report<br><input type="checkbox"/> Attached, Document ID: _____<br><input type="checkbox"/> Previously submitted, Date: _____<br><input checked="" type="checkbox"/> Not Applicable |
| 6. Procedures for Startup and Shutdown<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested           |
| 7. Operation and Maintenance Plan<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested                |
| 8. Supplemental Information for Construction Permit Application<br><input checked="" type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable                            |
| 9. Other Information Required by Rule or Statute<br><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable   |
| 10. Supplemental Requirements Comment:<br><br><br><br><br><br><br><br><br><br>   |

Emissions Unit Information Section  2  of  2

Pollutant Detail Information Page  1  of  1

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

|  |
|--|
| 11. Alternative Methods of Operation<br><input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable                      |
| 12. Alternative Modes of Operation (Emissions Trading)<br><input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable    |
| 13. Identification of Additional Applicable Requirements<br><input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable  |
| 14. Compliance Assurance Monitoring Plan<br><input type="checkbox"/> Attached, Document ID:_____ <input checked="" type="checkbox"/> Not Applicable                  |
| 15. Acid Rain Part Application (Hard-copy Required)<br><input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a))<br>Attached, Document ID:_____ |
| <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.)<br>Attached, Document ID:_____  |
| <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.)<br>Attached, Document ID:_____   |
| <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.)<br>Attached, Document ID:_____   |
| <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.)<br>Attached, Document ID:_____   |
| <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.)<br>Attached, Document ID:_____   |
| <input checked="" type="checkbox"/> Not Applicable   |


**APPENDIX B**  
**ENGINEERING DRAWINGS**

11 10 9 8 7 6 5 4 3 2 1




**NOTES**

- PROPERTY LINES SHOWN ARE BASED ON SURVEY PREPARED BY LOE MILLS & ASSOCIATES, INC. 620 8TH AVENUE WEST, PALMETTO, FLORIDA 33561 JOB NO. A-9864 FOR FLORIDA CRUSHED STONE COMPANY, DATED 10/8/91.
- LOT IS SECTION 7 & 8, TOWNSHIP 33 SOUTH, RANGE 18 EAST, COUNTY OF MANATEE, FLORIDA.




**LEGEND**

FPL = FLORIDA POWER AND LIGHT CO.



**LOCATION PLAN**  
NTS

**GRAPHIC SCALE**



| Rev No | Revision | Date | Des | Chkd | Approved<br>Chief Eng | Rev No | Revision | Date | Des | Chkd | Approved<br>Chief Eng | Rev No | Revision | Date | Des | Chkd | Approved<br>Chief Eng |
|--------|----------|------|-----|------|-----------------------|--------|----------|------|-----|------|-----------------------|--------|----------|------|-----|------|-----------------------|
|        |          |      |     |      |                       |        |          |      |     |      |                       |        |          |      |     |      |                       |

| Drawing Control  |             |      |             |      |
|------------------|-------------|------|-------------|------|
| Purpose          | Approved By | Date | Released By | Date |
| For Information  |             |      |             |      |
| For Comment      |             |      |             |      |
| For Bid          |             |      |             |      |
| For Construction |             |      |             |      |



| Engineering Review |      |      |      |      |      |      |      |      |      |      |      |
|--------------------|------|------|------|------|------|------|------|------|------|------|------|
| Disc               | Engr | Date | Disc | Engr | Date | Disc | Engr | Date | Disc | Engr | Date |
|                    |      |      |      |      |      |      |      |      |      |      |      |





| GULF COAST POWER PROJECT<br>FLORIDA  |  |  |                      |  |  |  |            |  |        |  |
|--|--|--|----------------------|--|--|--|------------|--|--------|--|
| SITE PLAN  |  |  |                      |  |  |  |            |  |        |  |
| <b>BURNS AND ROE ENTERPRISES, INC.</b><br>Engineers and Constructors - Orade (I), NJ |  |  |                      |  | Reviewed By: <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> |  |            |  |        |  |
| Approved for Construction  |  |  | Date                 |  | Work Order   |  | Drawing No |  | Sh Rev |  |
| Manager-Design/Drafting  |  |  | Chief Civil Engineer |  | 2377   |  | SC008      |  | A      |  |



NAME: P:\prop\_00\801c1321f\_m005bc\_sh1.dwg DATE: AUG 22, 2000 TIME: 9:44 AM



| <p>REV. SYMBOLS</p> <table border="1"> <tr> <th>NO.</th> <th>DATE</th> <th>BY</th> <th>CHKD.</th> <th>DESCRIPTION</th> </tr> <tr> <td>1</td> <td>8/22/00</td> <td>...</td> <td>...</td> <td>...</td> </tr> </table> | NO.     | DATE | BY  | CHKD. | DESCRIPTION | 1 | 8/22/00 | ... | ... | ... | <p>NOTICE TO PURCHASER</p> <p>THIS DRAWING IS PRELIMINARY UNLESS IT BEARS IDENTIFICATION OF THE GENERAL ELECTRIC COMPANY PROJECT ENGINEER. GENERAL ELECTRIC COMPANY AND ITS SUBSIDIARIES MAKE NO WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, REGARDING THE ACCURACY OF THE INFORMATION CONTAINED HEREIN. THE USER OF THIS DRAWING SHALL BE RESPONSIBLE FOR VERIFYING THE ACCURACY OF ALL INFORMATION FURNISHED BY OTHERS. GENERAL ELECTRIC COMPANY SHALL NOT BE RESPONSIBLE FOR ANY LOSS OR DAMAGE RESULTING FROM ANY INFORMATION INCORPORATED IN THIS DRAWING UNLESS IT IS SUPPLIED FROM INFORMATION FURNISHED BY THE CONTRACTOR, OTHER EQUIPMENT MANUFACTURERS OR OTHER CONTRIBUTORS. IN THE EVENT OF A CONFLICT BETWEEN THE CONTRACT AND THIS DRAWING, THE CONTRACT SHALL GOVERN. THE PROVISIONS OF THE CONTRACT SHALL GOVERN.</p> | <p>PROJECT NO. 801C1321</p> <p>DATE: 8/22/00</p> | <p>SCALE: 1" = 20'</p> <p>DESIGNED BY: S. FARR</p> <p>CHECKED BY: N/A</p> <p>DRAWN BY: N/A</p> <p>APPROVED BY: N. KUMAR</p> | <p>PRELIMINARY</p> <p>STATION ARRANGEMENT</p> <p>107FA MULTI-SHAFT</p> <p>GULF COAST POWER PROJECT</p> <p>FLORIDA</p> | <p>GENERAL ELECTRIC</p> <p>POWER PLANT ENGINEERING</p> <p>POWER PLANT SYSTEMS DEPARTMENT</p> <p>801C1321F MO05BC</p> <p>1 2 A</p> |
|---|---------|------|-----|-------|-------------|---|---------|-----|-----|-----|---|--|---|---|---|
|   | NO.     | DATE | BY  | CHKD. | DESCRIPTION |   |         |     |     |     |   |  |   |   |   |
| 1   | 8/22/00 | ...  | ... | ...   |             |   |         |     |     |     |   |  |   |   |   |



|      |      |    |       |      |
|------|------|----|-------|------|
| REV. | DATE | BY | CHKD. | APP. |
| 1    |      |    |       |      |

THIS DRAWING IS THE PROPERTY OF  
 POWER PLANT SYSTEMS DEPARTMENT -  
 GENERAL ELECTRIC COMPANY AND IS  
 LOANED TO YOU CONDITIONED UPON IT BEING  
 USED ONLY FOR THE PURPOSES FOR WHICH  
 IT WAS ISSUED. IT IS NOT TO BE REPRODUCED  
 OR TRANSMITTED IN ANY FORM OR BY ANY  
 MEANS, ELECTRONIC OR MECHANICAL, FOR  
 ANY PURPOSES WITHOUT PERMISSION  
 OF POWER PLANT SYSTEMS DEPARTMENT.

NOTICE TO PURCHASER  
 THIS DRAWING IS PRELIMINARY UNLESS IT BEARS CERTIFICATION OF THE GENERAL ELECTRIC COMPANY PROJECT ENGINEER.  
 GENERAL ELECTRIC COMPANY HAS MADE EVERY EFFORT TO VERIFY ALL INFORMATION REPRESENTED ON THIS DRAWING.  
 HOWEVER, IT IS NECESSARY TO VERIFY TO THE EXTENT OF ALL INFORMATION FURNISHED BY OUTSIDE  
 SOURCES. GENERAL ELECTRIC COMPANY ACCEPTS LIABILITY FOR ALL LOSS OR DAMAGE RESULTING FROM ANY MIS-  
 INFORMATION INCORPORATED IN THIS DRAWING, WHICH IS SUPPLIED FROM INFORMATION FURNISHED BY THE CUSTOMER, SUCH  
 EQUIPMENT MANUFACTURERS OR OTHER CONTRIBUTORS. IN THE EVENT OF A CONFLICT BETWEEN THE CONTRACT AND THIS  
 DRAWING REFLECTING MATERIALS AND METHODS TO BE SUPPLIED BY GENERAL ELECTRIC COMPANY THE  
 PROVISIONS OF THE CONTRACT SHALL CONTROL.

|             |      |                  |                    |
|-------------|------|------------------|--------------------|
| DESIGNED BY | DATE | SCALE            | PROJECT            |
| S. FARR     | N/A  | 1" = 20'         | 1107 A MULTI-SHAFT |
| CHECKED BY  | DATE | PROJECT ENGINEER |                    |
| N/A         | N/A  | N. KUMAR         |                    |
| DATE        | DATE | DATE             |                    |
|             |      |                  |                    |
| NO. OF SETS | DATE | DATE             |                    |
| 8011421     |      |                  |                    |
| DATE        | DATE | DATE             |                    |
|             |      |                  |                    |

|                    |      |      |
|--------------------|------|------|
| PROJECT            | DATE | DATE |
| 1107 A MULTI-SHAFT |      |      |
| DATE               | DATE | DATE |
|                    |      |      |

PRELIMINARY  
 STATION ARRANGEMENT  
 1107 A MULTI-SHAFT  
 GULF COAST POWER PROJECT  
 FLORIDA

SEE LEGEND ON SH. 1  
 GENERAL ELECTRIC  
 POWER PLANT ENGINEERING  
 POWER PLANT SYSTEMS DEPARTMENT  
 PROJECT NO. 8011421  
 DRAWING NO. MO05BC  
 SHEET 2 OF 2  
 DATE 8/81

APPENDIX C  
AIR POLLUTANT EMISSIONS



PRELIMINARY

HRSO EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 25 F

Relative Humidity: 60%

100% Load METHANE

|                                     |       |               |                                     |       |     |
|-------------------------------------|-------|---------------|-------------------------------------|-------|-----|
| NOx                                 | 3.5   | ppmvd @ 15%O2 | NOx                                 | 24.1  | pph |
| CO                                  | 9.0   | ppmvd         | CO                                  | 31.0  | pph |
| UHC                                 | 7.0   | ppmvw         | UHC                                 | 15.0  | pph |
| VOC                                 | 1.4   | ppmvw         | VOC                                 | 3.0   | pph |
| SO2                                 | 2     | ppmvw         | SO2                                 | 10    | pph |
| SO3                                 | 1     | ppmvw         | SO3                                 | 1     | pph |
| Sulfur Mist                         | 2     | pph           | Sulfur Mist                         | 2     | pph |
| Front Half<br>+ Sulfates<br>Partic. | 11    | pph           | Front Half +<br>Sulfates<br>Partic. | 11    | pph |
| PM10<br>Particulates                | 20    | pph           | PM10<br>Particulates                | 20    | pph |
| Ammonia                             | 12    | pph           | Ammonia                             | 12    | pph |
| O2                                  | 12.77 | %             | O2                                  | 12.77 | %   |
| H2O                                 | 7.61  | %             | H2O                                 | 7.61  | %   |

PRELIMINARY

HRSG EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 25 F

Relative Humidity: 60%

75% Load METHANE

|                                     |       |             |                                     |       |     |
|-------------------------------------|-------|-------------|-------------------------------------|-------|-----|
| NOx                                 | 3.5   | ppmvd@15%O2 | NOx                                 | 19.1  | pph |
| CO                                  | 9.0   | ppmvd       | CO                                  | 25.0  | pph |
| UHC                                 | 7.0   | ppmww       | UHC                                 | 12.0  | pph |
| VOC                                 | 1.4   | ppmww       | VOC                                 | 2.4   | pph |
| SO2                                 | 2     | ppmww       | SO2                                 | 8     | pph |
| SO3                                 | 1     | ppmww       | SO3                                 | 1     | pph |
| Sulfur Mist                         | 1     | pph         | Sulfur Mist                         | 1     | pph |
| Front Half<br>+ Sulfates<br>Partic. | 11    | pph         | Front Half +<br>Sulfates<br>Partic. | 11    | pph |
| PM10<br>Particulates                | 19    | pph         | PM10<br>Particulates                | 19    | pph |
| Ammonia                             | 10    | pph         | Ammonia                             | 10    | pph |
| O2                                  | 12.63 | %           | O2                                  | 12.63 | %   |
| H2O                                 | 7.74  | %           | H2O                                 | 7.74  | %   |

**PRELIMINARY**

**HRSO EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

**Fuel 100% Methane**

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

**Gas Turbine @ 50% load**

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 25 F

Relative Humidity: 60 %

**50% Load METHANE**

|                                  |       |              |                                     |       |     |
|----------------------------------|-------|--------------|-------------------------------------|-------|-----|
| NOx                              | 3.5   | ppmvd@ 15%O2 | NOx                                 | 15.2  | pph |
| CO                               | 9.0   | ppmvd        | CO                                  | 20.0  | pph |
| UHC                              | 7.0   | ppmww        | UHC                                 | 10.0  | pph |
| VOC                              | 1.4   | ppmww        | VOC                                 | 2.0   | pph |
| SO2                              | 2     | ppmww        | SO2                                 | 7     | pph |
| SO3                              | 1     | ppmww        | SO3                                 | 1     | pph |
| Sulfur Mist                      | 1     | pph          | Sulfur Mist                         | 1     | pph |
| Front Half + Sulfates<br>Partic. | 11    | pph          | Front Half +<br>Sulfates<br>Partic. | 11    | pph |
| PM10 Particulates                | 19    | pph          | PM10<br>Particulates                | 19    | pph |
| Ammonia                          | 8     | pph          | Ammonia                             | 8     | pph |
| O2                               | 12.92 | %            | O2                                  | 12.92 | %   |
| H2O                              | 7.47  | %            | H2O                                 | 7.47  | %   |

**PRELIMINARY**

**HRSG EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

**Gas Turbine @ base load**

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 25 F

Relative Humidity: 60%

**100% Load Distillate**

|                               |                     |                               |          |
|-------------------------------|---------------------|-------------------------------|----------|
| NOx                           | 10.0 ppmvd @ 15% O2 | NOx                           | 80.0 pph |
| CO                            | 20.0 ppmvd          | CO                            | 70.0 pph |
| UHC                           | 7.1 ppmvw           | UHC                           | 16.0 pph |
| VOC                           | 3.6 ppmvw           | VOC                           | 8.0 pph  |
| SO2                           | 12 ppmvw            | SO2                           | 99 pph   |
| SO3                           | 1 ppmvw             | SO3                           | 7 pph    |
| Sulfur Mist                   | 11 pph              | Sulfur Mist                   | 11 pph   |
| Front Half + Sulfates Partic. | 36 pph              | Front Half + Sulfates Partic. | 36 pph   |
| PM10 Particulates             | 53 pph              | PM10 Particulates             | 53 pph   |
| Ammonia                       | 10 pph              | Ammonia                       | 10 pph   |
| O2                            | 11.44 %             | O2                            | 11.44 %  |
| H2O                           | 10.34 %             | H2O                           | 10.34 %  |

**GE does not recommend operation of the SCR during distillate fuel operation**

**PRELIMINARY**

**HRSG EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: **PG7241(FA)**

**Fuel Distillate**, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

**Gas Turbine @ 75% load**

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 25 F

Relative Humidity: 60%

**75% Load Distillate**

|                                     |                  |                                     |          |
|-------------------------------------|------------------|-------------------------------------|----------|
| NOx                                 | 10.0 ppmvd@15%O2 | NOx                                 | 63.8 pph |
| CO                                  | 22.0 ppmvd       | CO                                  | 58.0 pph |
| UHC                                 | 7.1 ppmvw        | UHC                                 | 12.0 pph |
| VOC                                 | 3.6 ppmvw        | VOC                                 | 6.0 pph  |
| SO2                                 | 12 ppmvw         | SO2                                 | 80 pph   |
| SO3                                 | 1 ppmvw          | SO3                                 | 6 pph    |
| Sulfur Mist                         | 9 pph            | Sulfur Mist                         | 9 pph    |
| Front Half +<br>Sulfates<br>Partic. | 32 pph           | Front Half +<br>Sulfates<br>Partic. | 32 pph   |
| PM10<br>Particulates                | 49 pph           | PM10<br>Particulates                | 49 pph   |
| Ammonia                             | 8 pph            | Ammonia                             | 8 pph    |
| O2                                  | 11.11 %          | O2                                  | 11.11 %  |
| H2O                                 | 10.45 %          | H2O                                 | 10.45 %  |

**GE does not recommend operation of the SCR during distillate fuel operation**

**PRELIMINARY**

**HRSG EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

**Gas Turbine @ 50% load**

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 25 F

Relative Humidity: 60%

**50% Load Distillate**

|                                     |       |               |                                     |       |     |
|-------------------------------------|-------|---------------|-------------------------------------|-------|-----|
| NOx                                 | 10.0  | ppmvd @ 15%O2 | NOx                                 | 49.5  | pph |
| CO                                  | 29.0  | ppmvd         | CO                                  | 65.0  | pph |
| UHC                                 | 7.0   | ppmvw         | UHC                                 | 10.0  | pph |
| VOC                                 | 3.5   | ppmvw         | VOC                                 | 5.0   | pph |
| SO2                                 | 12    | ppmvw         | SO2                                 | 63    | pph |
| SO3                                 | 1     | ppmvw         | SO3                                 | 5     | pph |
| Sulfur Mist                         | 7     | pph           | Sulfur Mist                         | 7     | pph |
| Front Half +<br>Sulfates<br>Partic. | 29    | pph           | Front Half +<br>Sulfates<br>Partic. | 29    | pph |
| PM10<br>Particulates                | 46    | pph           | PM10<br>Particulates                | 46    | pph |
| Ammonia                             | 6     | pph           | Ammonia                             | 6     | pph |
| O2                                  | 11.57 | %             | O2                                  | 11.57 | %   |
| H2O                                 | 9.59  | %             | H2O                                 | 9.59  | %   |

**GE does not recommend operation of the SCR during distillate fuel operation**

**PRELIMINARY**

**HRSG EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

**Gas Turbine @ base load**

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 59 F

Relative Humidity: 74%

**100% Load METHANE**

|                                     |       |             |                                     |       |     |
|-------------------------------------|-------|-------------|-------------------------------------|-------|-----|
| NOx                                 | 3.5   | ppmvd@15%O2 | NOx                                 | 22.6  | pph |
| CO                                  | 9.0   | ppmvd       | CO                                  | 29.0  | pph |
| UHC                                 | 7.0   | ppmww       | UHC                                 | 14.0  | pph |
| VOC                                 | 1.4   | ppmww       | VOC                                 | 2.8   | pph |
| SO2                                 | 2     | ppmww       | SO2                                 | 10    | pph |
| SO3                                 | 1     | ppmww       | SO3                                 | 1     | pph |
| Sulfur Mist                         | 1     | pph         | Sulfur Mist                         | 1     | pph |
| Front Half<br>+ Sulfates<br>Partic. | 11    | pph         | Front Half +<br>Sulfates<br>Partic. | 11    | pph |
| PM10<br>Particulates                | 20    | pph         | PM10<br>Particulates                | 20    | pph |
| Ammonia                             | 12    | pph         | Ammonia                             | 12    | %   |
| O2                                  | 12.55 | %           | O2                                  | 12.55 | %   |
| H2O                                 | 8.57  | %           | H2O                                 | 8.57  | %   |

**PRELIMINARY**

**HRSO EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

**Fuel Distillate**, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

**Gas Turbine @ base load**

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 59 F

Relative Humidity: 74%

**100% Load Distillate**

|                                     |       |             |                                     |       |     |
|-------------------------------------|-------|-------------|-------------------------------------|-------|-----|
| NOx                                 | 10.0  | ppmvd@15%O2 | NOx                                 | 75.7  | pph |
| CO                                  | 20.0  | ppmvd       | CO                                  | 66.0  | pph |
| UHC                                 | 7.1   | ppmww       | UHC                                 | 15.0  | pph |
| VOC                                 | 3.6   | ppmww       | VOC                                 | 7.5   | pph |
| SO2                                 | 1.2   | ppmww       | SO2                                 | 94    | pph |
| SO3                                 | 1.1   | ppmww       | SO3                                 | 7     | pph |
| Sulfur Mist                         | 10    | pph         | Sulfur Mist                         | 10    | pph |
| Front Half<br>+ Sulfates<br>Partic. | 35    | pph         | Front Half +<br>Sulfates<br>Partic. | 35    | pph |
| PM10<br>Particulates                | 52    | pph         | PM10<br>Particulates                | 52    | pph |
| Ammonia                             | 10    | pph         | Ammonia                             | 10    | pph |
| O2                                  | 11.21 | %           | O2                                  | 11.21 | %   |
| H2O                                 | 11.19 | %           | H2O                                 | 11.19 | %   |

GE does not recommend operation of the SCR during distillate fuel operation



**PRELIMINARY**

**HRSG EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

**Fuel 100% Methane**

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

**Gas Turbine @ base load**

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 72 F

Relative Humidity: 73%

**100% Load METHANE**

|                               |                   |                               |          |
|-------------------------------|-------------------|-------------------------------|----------|
| NOx                           | 3.5 ppmvd @ 15%O2 | NOx                           | 21.8 pph |
| CO                            | 9.0 ppmvd         | CO                            | 28.0 pph |
| UHC                           | 7.0 ppmvw         | UHC                           | 14.0 pph |
| VOC                           | 1.4 ppmvw         | VOC                           | 2.8 pph  |
| SO2                           | .2 ppmvw          | SO2                           | .9 pph   |
| SO3                           | .1 ppmvw          | SO3                           | .1 pph   |
| Sulfur Mist                   | .1 pph            | Sulfur Mist                   | .1 pph   |
| Front Half + Sulfates Partic. | 1.1 pph           | Front Half + Sulfates Partic. | 1.1 pph  |
| PM10 Particulates             | 2.0 pph           | PM10 Particulates             | 2.0 pph  |
| Ammonia                       | 1.1 pph           | Ammonia                       | 1.1 pph  |
| O2                            | 12.46 %           | O2                            | 12.46 %  |
| H2O                           | 9.19 %            | H2O                           | 9.19 %   |

PRELIMINARY

HRSG EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

**Fuel 100% Methane**

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

**Gas Turbine @ 75% load**

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 72 F

Relative Humidity: 73%

75% Load METHANE

|                                     |       |             |                                     |       |     |
|-------------------------------------|-------|-------------|-------------------------------------|-------|-----|
| NOx                                 | 3.5   | ppmvd@15%O2 | NOx                                 | 17.5  | pph |
| CO                                  | 9.0   | ppmvd       | CO                                  | 23.0  | pph |
| UHC                                 | 7.0   | ppmww       | UHC                                 | 11.0  | pph |
| VOC                                 | 1.4   | ppmww       | VOC                                 | 2.2   | pph |
| SO2                                 | 2     | ppmww       | SO2                                 | 8     | pph |
| SO3                                 | 1     | ppmww       | SO3                                 | 1     | pph |
| Sulfur Mist                         | 1     | pph         | Sulfur Mist                         | 1     | pph |
| Front Half +<br>Sulfates<br>Partic. | 1.1   | pph         | Front Half +<br>Sulfates<br>Partic. | 1.1   | pph |
| PM10<br>Particulates                | 19    | pph         | PM10<br>Particulates                | 19    | pph |
| Ammonia                             | 9     | pph         | Ammonia                             | 9     | pph |
| O2                                  | 12.50 | %           | O2                                  | 12.50 | %   |
| H2O                                 | 9.15  | %           | H2O                                 | 9.15  | %   |

PRELIMINARY

HRSG EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 72 F

Relative Humidity: 73%

50% Load METHANE

|                                     |       |             |                                     |       |     |
|-------------------------------------|-------|-------------|-------------------------------------|-------|-----|
| NOx                                 | 3.5   | ppmvd@15%O2 | NOx                                 | 14.0  | pph |
| CO                                  | 9.0   | ppmvd       | CO                                  | 19.0  | pph |
| UHC                                 | 7.1   | Ppmvw       | UHC                                 | 9.0   | pph |
| VOC                                 | 1.5   | Ppmvw       | VOC                                 | 1.8   | pph |
| SO2                                 | 2     | Ppmvw       | SO2                                 | 6     | pph |
| SO3                                 | 1     | Ppmvw       | SO3                                 | 1     | pph |
| Sulfur Mist                         | 1     | Pph         | Sulfur Mist                         | 1     | pph |
| Front Half +<br>Sulfates<br>Partic. | 11    | Pph         | Front Half +<br>Sulfates<br>Partic. | 11    | pph |
| PM10<br>Particulates                | 19    | Pph         | PM10<br>Particulates                | 19    | pph |
| Ammonia                             | 7     | Pph         | Ammonia                             | 7     | pph |
| O2                                  | 12.91 | %           | O2                                  | 12.91 | %   |
| H2O                                 | 8.79  | %           | H2O                                 | 8.79  | %   |

**PRELIMINARY**

**HRSG EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: **PG7241(FA)**

**Fuel Distillate**, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

**Gas Turbine @ base load**

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 72 F

Relative Humidity: 73%

**100% Load Distillate**

|                                     |       |             |                                     |       |     |
|-------------------------------------|-------|-------------|-------------------------------------|-------|-----|
| NOx                                 | 10.0  | ppmvd@15%O2 | NOx                                 | 73.6  | pph |
| CO                                  | 20.0  | Ppmvd       | CO                                  | 63.0  | pph |
| UHC                                 | 7.0   | Ppmvw       | UHC                                 | 14.0  | pph |
| VOC                                 | 3.5   | Ppmvw       | VOC                                 | 7.0   | pph |
| SO2                                 | 12    | Ppmvw       | SO2                                 | 92    | pph |
| SO3                                 | 1     | Ppmvw       | SO3                                 | 6     | pph |
| Sulfur Mist                         | 10    | Pph         | Sulfur Mist                         | 10    | pph |
| Front Half +<br>Sulfates<br>Partic. | 35    | Pph         | Front Half +<br>Sulfates<br>Partic. | 35    | pph |
| PM10<br>Particulates                | 51    | Pph         | PM10<br>Particulates                | 51    | pph |
| Ammonia                             | 10    | Pph         | Ammonia                             | 10    | pph |
| O2                                  | 11.08 | %           | O2                                  | 11.08 | %   |
| H2O                                 | 11.69 | %           | H2O                                 | 11.69 | %   |

**GE does not recommend operation of the SCR during distillate fuel operation**

# PRELIMINARY

## HRSO EMISSIONS (after SCR for NOx reduction)

### Assumptions:

Gas Turbine: PG7241(FA)

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

### Gas Turbine @ 75% load

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 72 F

Relative Humidity: 73%

### 75% Load Distillate

|                                     |                    |                                     |          |
|-------------------------------------|--------------------|-------------------------------------|----------|
| NOx                                 | 10.0 ppmvd @ 15%O2 | NOx                                 | 58.8 pph |
| CO                                  | 21.0 ppmvd         | CO                                  | 52.0 pph |
| UHC                                 | 7.1 ppmvw          | UHC                                 | 11.0 pph |
| VOC                                 | 3.6 ppmvw          | VOC                                 | 5.5 pph  |
| SO2                                 | 12 ppmvw           | SO2                                 | 7.4 pph  |
| SO3                                 | 1 ppmvw            | SO3                                 | 5 pph    |
| Sulfur Mist                         | 8 pph              | Sulfur Mist                         | 8 pph    |
| Front Half +<br>Sulfates<br>Partic. | 31 pph             | Front Half +<br>Sulfates<br>Partic. | 31 pph   |
| PM10<br>Particulates                | 48 pph             | PM10<br>Particulates                | 48 pph   |
| Ammonia                             | 8 pph              | Ammonia                             | 8 pph    |
| O2                                  | 11.12 %            | O2                                  | 11.12 %  |
| H2O                                 | 11.29 %            | H2O                                 | 11.29 %  |

GE does not recommend operation of the SCR during distillate fuel operation

# PRELIMINARY

## HRSG EMISSIONS (after SCR for NOx reduction)

### Assumptions:

Gas Turbine: PG7241(FA)

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

**Gas Turbine @ 50% load**

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 72 F

Relative Humidity: 73%

### 50% Load Distillate

|                                     |       |             |                                     |       |     |
|-------------------------------------|-------|-------------|-------------------------------------|-------|-----|
| NOx                                 | 10.0  | ppmvd@15%O2 | NOx                                 | 46.0  | pph |
| CO                                  | 34.0  | ppmvd       | CO                                  | 73.0  | pph |
| UHC                                 | 7.0   | ppmww       | UHC                                 | 9.0   | pph |
| VOC                                 | 3.5   | ppmww       | VOC                                 | 4.5   | pph |
| SO2                                 | 11    | ppmww       | SO2                                 | 58    | pph |
| SO3                                 | 1     | ppmww       | SO3                                 | 4     | pph |
| Sulfur Mist                         | 7     | pph         | Sulfur Mist                         | 7     | pph |
| Front Half +<br>Sulfates<br>Partic. | 28    | pph         | Front Half +<br>Sulfates<br>Partic. | 28    | pph |
| PM10<br>Particulates                | 45    | pph         | PM10<br>Particulates                | 45    | pph |
| Ammonia                             | 6     | pph         | Ammonia                             | 6     | pph |
| O2                                  | 11.83 | %           | O2                                  | 11.83 | %   |
| H2O                                 | 10.19 | %           | H2O                                 | 10.19 | %   |

GE does not recommend operation of the SCR during distillate fuel operation

PRELIMINARY

HRSG EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 97 F

Relative Humidity: 70%

100% Load METHANE

|                               |                  |                               |          |
|-------------------------------|------------------|-------------------------------|----------|
| NOx                           | 3.5 ppmvd@ 15%O2 | NOx                           | 20.2 pph |
| CO                            | 9.0 ppmvd        | CO                            | 26.0 pph |
| UHC                           | 7.0 ppmvw        | UHC                           | 13.0 pph |
| VOC                           | 1.4 ppmvw        | VOC                           | 2.6 pph  |
| SO2                           | 2.2 ppmvw        | SO2                           | 9 pph    |
| SO3                           | 1 ppmvw          | SO3                           | 1 pph    |
| Sulfur Mist                   | 1 pph            | Sulfur Mist                   | 1 pph    |
| Front Half + Sulfates Partic. | 11 pph           | Front Half + Sulfates Partic. | 11 pph   |
| PM10 Particulates             | 20 pph           | PM10 Particulates             | 20 pph   |
| Ammonia                       | 10 pph           | Ammonia                       | 10 pph   |
| O2                            | 12.10 %          | O2                            | 12.10 %  |
| H2O                           | 11.24 %          | H2O                           | 11.24 %  |

**PRELIMINARY**

**HRSG EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

**Fuel 100% Methane**

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

**Gas Turbine @ 75% load**

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 97 F

Relative Humidity: 70%

**75% Load METHANE**

|                                     |                 |                                     |          |
|-------------------------------------|-----------------|-------------------------------------|----------|
| NOx                                 | 3.5 ppmvd@15%O2 | NOx                                 | 16.7 pph |
| CO                                  | 9.0 ppmvd       | CO                                  | 21.0 pph |
| UHC                                 | 7.0 ppmvw       | UHC                                 | 11.0 pph |
| VOC                                 | 1.4 ppmvw       | VOC                                 | 2.2 pph  |
| SO2                                 | 2 ppmvw         | SO2                                 | 7 pph    |
| SO3                                 | 1 ppmvw         | SO3                                 | 1 pph    |
| Sulfur Mist                         | 1 pph           | Sulfur Mist                         | 1 pph    |
| Front Half<br>+ Sulfates<br>Partic. | 11 pph          | Front Half +<br>Sulfates<br>Partic. | 11 pph   |
| PM10<br>Particulates                | 19 pph          | PM10<br>Particulates                | 19 pph   |
| Ammonia                             | 8 pph           | Ammonia                             | 8 pph    |
| O2                                  | 12.19%          | O2                                  | 12.19%   |
| H2O                                 | 11.16%          | H2O                                 | 11.16%   |



# PRELIMINARY

## HRSG EMISSIONS (after SCR for NOx reduction)

### Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

**Gas Turbine @ 50% load**

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 97 F

Relative Humidity: 70 %

### 50% Load METHANE

|                                  |                 |                                     |          |
|----------------------------------|-----------------|-------------------------------------|----------|
| NOx                              | 3.5 ppmvd@15%O2 | NOx                                 | 13.2 pph |
| CO                               | 9.0 ppmvd       | CO                                  | 18.0 pph |
| UHC                              | 7.0 ppmvw       | UHC                                 | 9.0 pph  |
| VOC                              | 1.4 ppmvw       | VOC                                 | 1.8 pph  |
| SO2                              | 2 ppmvw         | SO2                                 | 6 pph    |
| SO3                              | 1 ppmvw         | SO3                                 | 1 pph    |
| Sulfur Mist                      | 1 pph           | Sulfur Mist                         | 1 pph    |
| Front Half + Sulfates<br>Partic. | 11 pph          | Front Half +<br>Sulfates<br>Partic. | 11 pph   |
| PM10 Particulates                | 19 pph          | PM10<br>Particulates                | 19 pph   |
| Ammonia                          | 7 pph           | Ammonia                             | 7 pph    |
| O2                               | 12.71 %         | O2                                  | 12.71 %  |
| H2O                              | 10.69 %         | H2O                                 | 10.69 %  |

**PRELIMINARY**

**HRSO EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

**Fuel Distillate**, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

**Gas Turbine @ base load**

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 97 F

Relative Humidity: 70%

**100% Load Distillate**

|                                     |       |                |                                     |       |     |
|-------------------------------------|-------|----------------|-------------------------------------|-------|-----|
| NOx                                 | 10.0  | ppmvd @ 15% O2 | NOx                                 | 67.6  | pph |
| CO                                  | 20.0  | ppmvd          | CO                                  | 58.0  | pph |
| UHC                                 | 7.1   | ppmvw          | UHC                                 | 13.0  | pph |
| VOC                                 | 3.6   | ppmvw          | VOC                                 | 6.5   | pph |
| SO2                                 | 1.1   | ppmvw          | SO2                                 | 84    | pph |
| SO3                                 | 1     | ppmvw          | SO3                                 | 6     | pph |
| Sulfur Mist                         | 9     | pph            | Sulfur Mist                         | 9     | pph |
| Front Half<br>+ Sulfates<br>Partic. | 33    | pph            | Front Half +<br>Sulfates<br>Partic. | 33    | pph |
| PM10<br>Particulates                | 50    | pph            | PM10<br>Particulates                | 50    | pph |
| Ammonia                             | 9     | pph            | Ammonia                             | 9     | pph |
| O2                                  | 10.95 | %              | O2                                  | 10.95 | %   |
| H2O                                 | 12.91 | %              | H2O                                 | 12.91 | %   |

**GE does not recommend operation of the SCR during distillate fuel operation**

# PRELIMINARY

## HRSG EMISSIONS (after SCR for NOx reduction)

### Assumptions:

Gas Turbine: PG7241(FA)

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

### Gas Turbine @ 75% load

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 97 F

Relative Humidity: 70%

### 75% Load Distillate

|                                      |                                      |
|--------------------------------------|--------------------------------------|
| NOx 10.0 ppmvd@15%O2                 | NOx 54.5 pph                         |
| CO 21.0 ppmvd                        | CO 51.0 pph                          |
| UHC 7.0 ppmvw                        | UHC 11.0 pph                         |
| VOC 3.5 ppmvw                        | VOC 5.5 pph                          |
| SO2 12 ppmvw                         | SO2 69 pph                           |
| SO3 1 ppmvw                          | SO3 5 pph                            |
| Sulfur Mist 8 pph                    | Sulfur Mist 8 pph                    |
| Front Half + Sulfates Partic. 30 pph | Front Half + Sulfates Partic. 30 pph |
| PM10 Particulates 47 pph             | PM10 Particulates 47 pph             |
| Ammonia 7 pph                        | Ammonia 7 pph                        |
| O2 11.10 %                           | O2 11.10 %                           |
| H2O 12.41 %                          | H2O 12.41 %                          |

GE does not recommend operation of the SCR during distillate fuel operation

**PRELIMINARY**

**HRSR EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

**Gas Turbine @ 50% load**

Fuel temperature 80 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 97 F

Relative Humidity: 70%

**50% Load Distillate**

|                               |                  |                               |          |
|-------------------------------|------------------|-------------------------------|----------|
| NOx                           | 10.0 ppmvd@15%O2 | NOx                           | 42.4 pph |
| CO                            | 40.9 ppmvd       | CO                            | 83.0 pph |
| UHC                           | 7.0 ppmvw        | UHC                           | 10.0 pph |
| VOC                           | 3.5 ppmvw        | VOC                           | 5.0 pph  |
| SO2                           | 1.1 ppmvw        | SO2                           | 5.4 pph  |
| SO3                           | 1 ppmvw          | SO3                           | 4 pph    |
| Sulfur Mist                   | 6 pph            | Sulfur Mist                   | 6 pph    |
| Front Half + Sulfates Partic. | 28 pph           | Front Half + Sulfates Partic. | 28 pph   |
| PM10 Particulates             | 44 pph           | PM10 Particulates             | 44 pph   |
| Ammonia                       | 5 pph            | Ammonia                       | 5 pph    |
| O2                            | 11.93%           | O2                            | 11.93%   |
| H2O                           | 11.22%           | H2O                           | 11.22%   |

**GE does not recommend operation of the SCR during distillate fuel operation**

PRELIMINARY

HRSG EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Steam Injection for Power Augmentation (3.5% of compressor flow)

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 97 F

Relative Humidity: 70%

100% Load METHANE

|                                     |       |               |                                     |       |     |
|-------------------------------------|-------|---------------|-------------------------------------|-------|-----|
| NOx                                 | 3.5   | ppmvd @ 15%O2 | NOx                                 | 21.6  | pph |
| CO                                  | 15.0  | ppmvd         | CO                                  | 43.0  | pph |
| UHC                                 | 7.1   | ppmvw         | UHC                                 | 14.0  | pph |
| VOC                                 | 1.5   | ppmvw         | VOC                                 | 2.8   | pph |
| SO2                                 | 2     | ppmvw         | SO2                                 | 9     | pph |
| SO3                                 | 1     | ppmvw         | SO3                                 | 1     | pph |
| Sulfur Mist                         | 1     | pph           | Sulfur Mist                         | 1     | pph |
| Front Half<br>+ Sulfates<br>Partic. | 1.1   | pph           | Front Half +<br>Sulfates<br>Partic. | 1.1   | pph |
| PM10<br>Particulates                | 20    | pph           | PM10<br>Particulates                | 20    | pph |
| Ammonia                             | 1.1   | pph           | Ammonia                             | 1.1   | pph |
| O2                                  | 11.06 | %             | O2                                  | 11.06 | %   |
| H2O                                 | 16.11 | %             | H2O                                 | 16.11 | %   |

PRELIMINARY

HRSG EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Steam Injection for Power Augmentation (3.5% of compressor flow)

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 72 F

Relative Humidity: 73%

100% Load METHANE

|                                     |       |             |                                     |       |     |
|-------------------------------------|-------|-------------|-------------------------------------|-------|-----|
| NOx                                 | 3.5   | ppmvd@15%O2 | NOx                                 | 23.0  | pph |
| CO                                  | 15.0  | ppmvd       | CO                                  | 47.0  | pph |
| UHC                                 | 7.1   | ppmww       | UHC                                 | 15.0  | pph |
| VOC                                 | 1.5   | ppmww       | VOC                                 | 3.0   | pph |
| SO2                                 | 2     | ppmww       | SO2                                 | 10    | pph |
| SO3                                 | 1     | ppmww       | SO3                                 | 1     | pph |
| Sulfur Mist                         | 1     | pph         | Sulfur Mist                         | 1     | pph |
| Front Half<br>+ Sulfates<br>Partic. | 11    | pph         | Front Half +<br>Sulfates<br>Partic. | 11    | pph |
| PM10<br>Particulates                | 20    | pph         | PM10<br>Particulates                | 20    | pph |
| Ammonia                             | 12    | pph         | Ammonia                             | 12    | pph |
| O2                                  | 11.44 | %           | O2                                  | 11.44 | %   |
| H2O                                 | 14.17 | %           | H2O                                 | 14.17 | %   |

**PRELIMINARY**

**HRSO EMISSIONS (after SCR for NOx reduction)**

**Assumptions:**

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

**Steam Injection for Power Augmentation (3.5% of compressor flow)**

**Gas Turbine @ base load**

Fuel temperature 365 F

Site elevation: 19ft

Site pressure: 14.69 psia

Ambient temperature: 59 F

Relative Humidity: 74%

**100% Load METHANE**

|  |  |
|--|--|
| NOx [3.5] ppmvd@ 15%O2                 | NOx [23.6] pph                         |
| CO [15.0] ppmvd                        | CO [49.0] pph                          |
| UHC [7.1] ppmvw                        | UHC [15.0] pph                         |
| VOC [1.5] ppmvw                        | VOC [3.0] pph                          |
| SO2 [2] ppmvw                          | SO2 [10] pph                           |
| SO3 [1] ppmvw                          | SO3 [1] pph                            |
| Sulfur Mist [2] pph                    | Sulfur Mist [2] pph                    |
| Front Half + Sulfates Partic. [11] pph | Front Half + Sulfates Partic. [11] pph |
| PM10 Particulates [20] pph             | PM10 Particulates [20] pph             |
| Ammonia [12] pph                       | Ammonia [12] pph                       |
| O2 [11.61] %                           | O2 [11.61] %                           |
| H2O [13.52] %                          | H2O [13.52] %                          |

| <b>Competative Power Ventures Maximum Potential Annual Emissions</b> |              |                       |           |            |                       |                       |           |                                    |                       |
|--|--------------|-----------------------|-----------|------------|-----------------------|-----------------------|-----------|------------------------------------|-----------------------|
|  | <b>Units</b> | <b>NO<sub>x</sub></b> | <b>CO</b> | <b>VOC</b> | <b>SO<sub>2</sub></b> | <b>SO<sub>3</sub></b> | <b>PM</b> | <b>H<sub>2</sub>SO<sub>4</sub></b> | <b>NH<sub>3</sub></b> |
| <b>Capacity Factor</b>   |              | 100%                  | 100%      | 100%       | 100%                  | 100%                  | 100%      | 100%                               | 100%                  |
| <b>Natural Gas</b>   |              |                       |           |            |                       |                       |           |                                    |                       |
| <b>Operating Period</b>  | Hours        | 8040                  | 8040      | 8040       | 8040                  | 8040                  | 8040      | 8040                               | 8040                  |
| <b>Emission Rate</b>   | lb/hr        | 24.1                  | 49.0      | 3.0        | 10.0                  | 1.0                   | 20.0      | 2.0                                | 12                    |
| <b>Annual Emissions</b>  | tons/year    | 96.9                  | 197.0     | 11.9       | 40.2                  | 3.9                   | 80.4      | 8.0                                | 48.2                  |
| <b>Distillate</b>  |              |                       |           |            |                       |                       |           |                                    |                       |
| <b>Operating Period</b>  | Hours        | 720                   | 720       | 720        | 720                   | 720                   | 720       | 720                                | 720                   |
| <b>Emission Rate</b>   | lb/hr        | 80.0                  | 70.0      | 8.0        | 99.0                  | 7.0                   | 53.0      | 11.0                               | 10.0                  |
| <b>Annual Emissions</b>  | tons/year    | 28.8                  | 25.2      | 2.9        | 35.6                  | 2.5                   | 19.1      | 4.0                                | 3.6                   |
| <b>Total Annual Emissions</b>  | tons/year    | 125.7                 | 222.2     | 14.8       | 75.8                  | 6.4                   | 99.5      | 12.0                               | 51.8                  |



| Competative Power Ventures Maximum Actual Annual Emissions |           |                 |              |       |      |                 |                 |      |                                |                 |
|--|-----------|-----------------|--------------|-------|------|-----------------|-----------------|------|--------------------------------|-----------------|
|  | Units     | NO <sub>x</sub> |              | CO    | VOC  | SO <sub>2</sub> | SO <sub>3</sub> | PM   | H <sub>2</sub> SO <sub>4</sub> | NH <sub>3</sub> |
|  |           | Controlled      | Uncontrolled |       |      |                 |                 |      |                                |                 |
| <b>Capacity Factor</b>                                     |           | 100%            | 100%         | 100%  | 100% | 100%            | 100%            | 100% | 100%                           | 100%            |
| <b>Natural Gas (with PA)</b>                               |           |                 |              |       |      |                 |                 |      |                                |                 |
| <b>Operating Period</b>                                    | Hours     | 2000            | 2000         | 2000  | 2000 | 2000            | 2000            | 2000 | 2000                           | 2000            |
| <b>Emission Rate</b>                                       | lb/hr     | 22.5            | 57.9         | 47.0  | 3.0  | 10.0            | 1.0             | 20.0 | 1.0                            | 12              |
| <b>Annual Emissions</b>                                    | tons/year | 22.5            | 57.9         | 47.0  | 3.0  | 10.0            | 1.0             | 20.0 | 1.0                            | 12.0            |
| <b>Natural Gas (without PA)</b>                            |           |                 |              |       |      |                 |                 |      |                                |                 |
| <b>Operating Period</b>                                    | Hours     | 6040            | 6040         | 6040  | 6040 | 6040            | 6040            | 6040 | 6040                           | 6040            |
| <b>Emission Rate</b>                                       | lb/hr     | 22.5            | 57.9         | 28.0  | 2.8  | 9.0             | 1.0             | 20.0 | 1.0                            | 11              |
| <b>Annual Emissions</b>                                    | tons/year | 68.0            | 174.8        | 84.6  | 8.5  | 27.2            | 2.9             | 60.4 | 3.0                            | 33.2            |
| <b>Distillate</b>  |           |                 |              |       |      |                 |                 |      |                                |                 |
| <b>Operating Period</b>                                    | Hours     | 720             | 720          | 720   | 720  | 720             | 720             | 720  | 720                            | 720             |
| <b>Emission Rate</b>                                       | lb/hr     | 73.6            | 311.5        | 63.0  | 7.0  | 92.0            | 6.0             | 51.0 | 10.0                           | 10.0            |
| <b>Annual Emissions</b>                                    | tons/year | 26.5            | 112.1        | 22.7  | 2.5  | 33.1            | 2.2             | 18.4 | 3.6                            | 3.6             |
| <b>Total Annual Emissions</b>                              | tons/year | 116.9           | 344.9        | 154.2 | 14.0 | 70.3            | 6.1             | 98.8 | 7.6                            | 48.8            |

| <b>Competitive Power Ventures - Gulfcoast Project<br/>Cooling Tower PM Emissions Calculations</b> |               |              |
|---|---------------|--------------|
| <b>Parameter</b>  | <b>Units</b>  | <b>Value</b> |
| Cooling Tower Circulating Flow*   | gal/min       | 75,000       |
| Drift Fraction of Circulating Flow*   | percent       | 0.0005       |
| Drift Rate  | gal/min       | 0.375        |
| Drift Rate  | gal/hr        | 22.5         |
|   |               |              |
| Water Density   | lb/gal        | 8.33         |
| Water Density Assumed for Cooling Water   | lb/gal        | 8.33         |
| Drift Rate  | lb/min        | 3.12         |
| Drift Rate  | lb/hr         | 187.43       |
|   |               |              |
| Convert lb/hr to g/s  | g/s per lb/hr | 0.126        |
| Drift Rate  | g/s           | 23.6         |
| Dissolved & Suspended Solids in Water   | mg/l          | 4200         |
| Dissolved & Suspended Solids in Water   | g/l           | 4.2          |
| Convert Liters to Gallons   | l/gal         | 3.785        |
| Dissolved & Suspended Solids in Water   | g/gal         | 15.90        |
| PM Emissions  | g/hr          | 357.7        |
| PM Emissions  | lb/hr         | 0.79         |
| PM Emissions  | g/s           | 0.099        |
|   |               |              |
| Number of Cells   |               | 5            |
| PM Emissions  | g/s per cell  | 0.020        |
| * per Marley specification  |               |              |

APPENDIX D  
AIR QUALITY MODELING

**Appendix D-1**

BEE-Line Software Version: 5.13

Input File - ct88.GPW  
Input File - ct88.PIP  
Output File - ct88.TAB  
Output File - ct88.SUM  
Output File - ct88.SO

BPIP (Dated: 95086)

DATE : 9/ 1/ 0

TIME : 15:24:21

O:\AIR\_ENG\PROJECTS\pineypt\ct88.BST BEESTWin GEP Files 9/1/2000 3:24:20  
PM

=====  
BPIP PROCESSING INFORMATION:  
=====

The ST flag has been set for processing for an ISCST2 run.

Inputs entered in METERS will be converted to meters using  
a conversion factor of 1.0000. Output will be in meters.

UTMP is set to UTMN. The input is assumed to be in a local  
X-Y coordinate system as opposed to a UTM coordinate system.  
True North is in the positive Y direction.

Plant north is set to 0.00 degrees with respect to True North.

O:\AIR\_ENG\PROJECTS\pineypt\ct88.BST BEESTWin GEP Files 9/1/2000 3:24:20  
PM

PRELIMINARY\* GEP STACK HEIGHT RESULTS TABLE  
(Output Units: meters)

| Stack Name | Stack Height | Stack-Building Base Elevation Differences | GEP** EQN1 | Preliminary* GEP Stack Height Value |
|------------|--------------|---|------------|-------------------------------------|
| 25/50A     | 31.09        | 0.00                                      | 55.66      | 65.00                               |
| CELL1      | 17.83        | 0.00                                      | 54.08      | 65.00                               |
| CELL2      | 17.83        | 0.00                                      | 57.15      | 65.00                               |
| CELL3      | 17.83        | 0.00                                      | 57.15      | 65.00                               |
| CELL4      | 17.83        | 0.00                                      | 57.15      | 65.00                               |
| CELL5      | 17.83        | 0.00                                      | 57.15      | 65.00                               |

\* Results are based on Determinants 1 & 2 on pages 1 & 2 of the GEP Technical Support Document. Determinant 3 may be investigated for additional stack height credit. Final values result after Determinant 3 has been taken into consideration.

\*\* Results were derived from Equation 1 on page 6 of GEP Technical Support Document. Values have been adjusted for any stack-building

base elevation differences.

Note: Criteria for determining stack heights for modeling emission limitations for a source can be found in Table 3.1 of the GEP Technical Support Document.

BPIP (Dated: 95086)

DATE : 9/ 1/ 0  
TIME : 15:24:21

O:\AIR\_ENG\PROJECTS\pineypt\ct88.BST BEESTwin GEP Files 9/1/2000 3:24:20 PM

BPIP output is in meters

|                    |       |       |       |       |       |       |
|--------------------|-------|-------|-------|-------|-------|-------|
| SO BUILDHGT 25/50A | 20.73 | 20.73 | 22.86 | 22.86 | 22.86 | 22.86 |
| SO BUILDHGT 25/50A | 22.86 | 22.86 | 22.86 | 22.86 | 22.86 | 22.86 |
| SO BUILDHGT 25/50A | 22.86 | 22.86 | 22.86 | 20.73 | 20.73 | 20.73 |
| SO BUILDHGT 25/50A | 20.73 | 20.73 | 22.86 | 22.86 | 22.86 | 22.86 |
| SO BUILDHGT 25/50A | 22.86 | 22.86 | 22.86 | 22.86 | 22.86 | 22.86 |
| SO BUILDHGT 25/50A | 22.86 | 22.86 | 22.86 | 20.73 | 20.73 | 20.73 |
| SO BUILDWID 25/50A | 50.32 | 53.39 | 19.88 | 21.87 | 21.87 | 21.87 |
| SO BUILDWID 25/50A | 21.87 | 21.87 | 21.87 | 21.87 | 21.87 | 21.87 |
| SO BUILDWID 25/50A | 21.87 | 21.87 | 19.88 | 85.71 | 78.95 | 69.80 |
| SO BUILDWID 25/50A | 50.32 | 53.39 | 19.88 | 21.87 | 21.87 | 21.87 |
| SO BUILDWID 25/50A | 21.87 | 21.87 | 21.87 | 21.87 | 21.87 | 21.87 |
| SO BUILDWID 25/50A | 21.87 | 21.87 | 19.88 | 85.71 | 78.95 | 69.80 |



|                   |       |       |       |       |       |       |
|-------------------|-------|-------|-------|-------|-------|-------|
| SO BUILDHGT CELL1 | 20.73 | 20.73 | 20.73 | 20.73 | 20.73 | 16.76 |
| SO BUILDHGT CELL1 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 |
| SO BUILDHGT CELL1 | 22.86 | 22.86 | 22.86 | 20.73 | 20.73 | 20.73 |
| SO BUILDHGT CELL1 | 20.73 | 20.73 | 20.73 | 20.73 | 20.73 | 16.76 |
| SO BUILDHGT CELL1 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 |
| SO BUILDHGT CELL1 | 22.86 | 22.86 | 22.86 | 20.73 | 20.73 | 20.73 |
| SO BUILDWID CELL1 | 67.79 | 63.72 | 57.71 | 54.62 | 52.74 | 20.82 |
| SO BUILDWID CELL1 | 19.53 | 17.65 | 15.24 | 17.65 | 19.53 | 20.82 |
| SO BUILDWID CELL1 | 20.82 | 20.82 | 19.88 | 85.71 | 78.95 | 45.72 |
| SO BUILDWID CELL1 | 50.32 | 53.39 | 54.83 | 54.62 | 52.74 | 20.82 |
| SO BUILDWID CELL1 | 19.53 | 17.65 | 15.24 | 17.65 | 19.53 | 20.82 |
| SO BUILDWID CELL1 | 20.82 | 20.82 | 19.88 | 85.71 | 78.95 | 69.80 |

|                   |       |       |       |       |       |       |
|-------------------|-------|-------|-------|-------|-------|-------|
| SO BUILDHGT CELL2 | 20.73 | 20.73 | 20.73 | 20.73 | 16.76 | 16.76 |
| SO BUILDHGT CELL2 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 | 22.86 |
| SO BUILDHGT CELL2 | 22.86 | 22.86 | 22.86 | 20.73 | 20.73 | 20.73 |
| SO BUILDHGT CELL2 | 20.73 | 20.73 | 20.73 | 20.73 | 16.76 | 16.76 |
| SO BUILDHGT CELL2 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 | 22.86 |
| SO BUILDHGT CELL2 | 22.86 | 22.86 | 22.86 | 20.73 | 20.73 | 20.73 |
| SO BUILDWID CELL2 | 67.79 | 63.72 | 57.71 | 54.62 | 21.47 | 20.82 |
| SO BUILDWID CELL2 | 19.53 | 17.65 | 15.24 | 17.65 | 19.53 | 24.68 |

|                   |       |       |       |       |       |       |
|-------------------|-------|-------|-------|-------|-------|-------|
| SO BUILDWID CELL2 | 23.79 | 22.17 | 19.88 | 53.39 | 50.32 | 45.72 |
| SO BUILDWID CELL2 | 50.32 | 53.39 | 54.83 | 54.62 | 21.47 | 20.82 |
| SO BUILDWID CELL2 | 19.53 | 17.65 | 15.24 | 17.65 | 19.53 | 24.68 |
| SO BUILDWID CELL2 | 23.79 | 22.17 | 19.88 | 53.39 | 78.95 | 69.80 |
| SO BUILDHGT CELL3 | 20.73 | 20.73 | 20.73 | 16.76 | 16.76 | 16.76 |
| SO BUILDHGT CELL3 | 16.76 | 16.76 | 16.76 | 16.76 | 22.86 | 22.86 |
| SO BUILDHGT CELL3 | 22.86 | 22.86 | 22.86 | 20.73 | 20.73 | 20.73 |
| SO BUILDHGT CELL3 | 20.73 | 20.73 | 20.73 | 16.76 | 16.76 | 16.76 |
| SO BUILDHGT CELL3 | 16.76 | 16.76 | 16.76 | 16.76 | 20.73 | 20.73 |
| SO BUILDHGT CELL3 | 20.73 | 20.73 | 20.73 | 20.73 | 20.73 | 20.73 |
| SO BUILDWID CELL3 | 67.79 | 63.72 | 54.83 | 21.47 | 21.47 | 20.82 |
| SO BUILDWID CELL3 | 19.53 | 17.65 | 15.24 | 17.65 | 24.82 | 24.68 |
| SO BUILDWID CELL3 | 23.79 | 22.17 | 19.88 | 53.39 | 50.32 | 45.72 |
| SO BUILDWID CELL3 | 50.32 | 53.39 | 54.83 | 21.47 | 21.47 | 20.82 |
| SO BUILDWID CELL3 | 19.53 | 17.65 | 15.24 | 17.65 | 79.15 | 85.84 |
| SO BUILDWID CELL3 | 89.93 | 91.28 | 54.83 | 85.71 | 78.95 | 69.80 |
| SO BUILDHGT CELL4 | 20.73 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 |
| SO BUILDHGT CELL4 | 16.76 | 16.76 | 16.76 | 16.76 | 22.86 | 22.86 |
| SO BUILDHGT CELL4 | 22.86 | 22.86 | 20.73 | 20.73 | 20.73 | 20.73 |
| SO BUILDHGT CELL4 | 20.73 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 |
| SO BUILDHGT CELL4 | 16.76 | 16.76 | 16.76 | 16.76 | 20.73 | 20.73 |
| SO BUILDHGT CELL4 | 20.73 | 20.73 | 16.76 | 16.76 | 20.73 | 20.73 |
| SO BUILDWID CELL4 | 67.79 | 19.53 | 20.82 | 21.47 | 21.47 | 20.82 |
| SO BUILDWID CELL4 | 19.53 | 17.65 | 15.24 | 17.65 | 24.82 | 24.68 |
| SO BUILDWID CELL4 | 23.79 | 22.17 | 54.83 | 53.39 | 50.32 | 45.72 |
| SO BUILDWID CELL4 | 50.32 | 19.53 | 20.82 | 21.47 | 21.47 | 20.82 |
| SO BUILDWID CELL4 | 19.53 | 17.65 | 15.24 | 17.65 | 79.15 | 85.84 |
| SO BUILDWID CELL4 | 89.93 | 54.62 | 20.82 | 19.53 | 78.95 | 69.80 |
| SO BUILDHGT CELL5 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 |
| SO BUILDHGT CELL5 | 16.76 | 16.76 | 16.76 | 16.76 | 22.86 | 22.86 |
| SO BUILDHGT CELL5 | 22.86 | 20.73 | 20.73 | 20.73 | 20.73 | 20.73 |
| SO BUILDHGT CELL5 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 | 16.76 |
| SO BUILDHGT CELL5 | 16.76 | 16.76 | 16.76 | 16.76 | 20.73 | 20.73 |
| SO BUILDHGT CELL5 | 16.76 | 16.76 | 16.76 | 16.76 | 20.73 | 20.73 |
| SO BUILDWID CELL5 | 17.65 | 19.53 | 20.82 | 21.47 | 21.47 | 20.82 |
| SO BUILDWID CELL5 | 19.53 | 17.65 | 15.24 | 17.65 | 24.82 | 24.68 |
| SO BUILDWID CELL5 | 23.79 | 54.62 | 54.83 | 53.39 | 50.32 | 45.72 |
| SO BUILDWID CELL5 | 17.65 | 19.53 | 20.82 | 21.47 | 21.47 | 20.82 |
| SO BUILDWID CELL5 | 19.53 | 17.65 | 15.24 | 17.65 | 79.15 | 85.84 |
| SO BUILDWID CELL5 | 21.47 | 21.47 | 20.82 | 19.53 | 78.95 | 69.80 |

**Appendix D-2**







WIND SPEED CLASS BOUNDARIES  
(METERS/SECOND)

# FIGURE 1 WINDROSE

STATION NO: 12842  
PERIOD: 1987

NOTES:  
 DIAGRAM OF THE FREQUENCY OF  
 OCCURRENCE OF EACH WIND DIRECTION.  
 WIND DIRECTION IS THE DIRECTION  
 FROM WHICH THE WIND IS BLOWING.  
 EXAMPLE - WIND IS BLOWING FROM THE  
 NORTH 3.8 PERCENT OF THE TIME.

BEE-LINE  
SOFTWARE




WIND SPEED CLASS BOUNDARIES  
(METERS/SECOND)

## FIGURE 1 WINDROSE

STATION NO: 12842  
PERIOD: 1988

NOTES:  
DIAGRAM OF THE FREQUENCY OF  
OCCURRENCE OF EACH WIND DIRECTION.  
WIND DIRECTION IS THE DIRECTION  
FROM WHICH THE WIND IS BLOWING.  
EXAMPLE - WIND IS BLOWING FROM THE  
NORTH 6.8 PERCENT OF THE TIME.

BEE-LINE  
SOFTWARE





# FIGURE 1 WINDROSE

STATION NO: 12842  
PERIOD: 1989

NOTES:  
 DIAGRAM OF THE FREQUENCY OF OCCURRENCE OF EACH WIND DIRECTION. WIND DIRECTION IS THE DIRECTION FROM WHICH THE WIND IS BLOWING. EXAMPLE - WIND IS BLOWING FROM THE NORTH 10.6 PERCENT OF THE TIME.

BEE-LINE  
SOFTWARE





WIND SPEED CLASS BOUNDARIES  
(METERS/SECOND)

## FIGURE 1 WINDROSE

STATION NO: 12842  
PERIOD: 1990

NOTES:  
 DIAGRAM OF THE FREQUENCY OF  
 OCCURRENCE OF EACH WIND DIRECTION.  
 WIND DIRECTION IS THE DIRECTION  
 FROM WHICH THE WIND IS BLOWING.  
 EXAMPLE - WIND IS BLOWING FROM THE  
 NORTH 4.3 PERCENT OF THE TIME.

BEE-LINE  
SOFTWARE





WIND SPEED CLASS BOUNDARIES  
(METERS/SECOND)

# FIGURE 1 WINDROSE

STATION NO: 12842  
PERIOD: 1991

NOTES:  
 DIAGRAM OF THE FREQUENCY OF OCCURRENCE OF EACH WIND DIRECTION.  
 WIND DIRECTION IS THE DIRECTION FROM WHICH THE WIND IS BLOWING.  
 EXAMPLE - WIND IS BLOWING FROM THE NORTH 3.8 PERCENT OF THE TIME.

BEE-LINE  
SOFTWARE



WIND SPEED CLASS BOUNDARIES  
(METERS/SECOND)

## FIGURE 1 WINDROSE

STATION NO: 12842  
PERIOD: 1987-1991

NOTES:  
DIAGRAM OF THE FREQUENCY OF  
OCCURRENCE OF EACH WIND DIRECTION.  
WIND DIRECTION IS THE DIRECTION  
FROM WHICH THE WIND IS BLOWING.  
EXAMPLE - WIND IS BLOWING FROM THE  
NORTH 5.9 PERCENT OF THE TIME.

BEE-LINE  
SOFTWARE

**Appendix D-3**

\*\*\* ISCST3 - VERSION 99155 \*\*\* \*\*\* gas 25 72 97F 9/8/00 1987 Tampa metdat

\*\*\*

BEE-Line ISCST3 "BEEST" Version 6.71

Input File - O:\AIR\_ENG\PROJECTS\pineypt\g15087.DTA  
 Output File - O:\AIR\_ENG\PROJECTS\pineypt\g15087.LST  
 Met File - O:\AIR\_ENG\PROJECTS\pineypt\met\12842-87.OUT

Number of sources - 11  
 Number of source groups - 11  
 Number of receptors - 3196

\*\*\* POINT SOURCE DATA \*\*\*

| SOURCE ID | NUMBER PART. CATS. | EMISSION RATE (GRAMS/SEC) | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | STACK HEIGHT (METERS) | STACK TEMP. (DEG.K) | STACK EXIT VEL. (M/SEC) | STACK DIAMETER (METERS) | BUILDING EXISTS | EMISSION RATE SCALAR VARY BY |
|-----------|--------------------|---------------------------|------------|------------|---------------------|-----------------------|---------------------|-------------------------|-------------------------|-----------------|------------------------------|
| 25/50     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 347.59              | 12.50                   | 5.64                    | YES             |                              |
| 25/75     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 350.93              | 15.24                   | 5.64                    | YES             |                              |
| 25F       | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 357.59              | 19.81                   | 5.64                    | YES             |                              |
| 59FE      | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 355.93              | 19.81                   | 5.64                    | YES             |                              |
| 59F       | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 358.71              | 18.90                   | 5.64                    | YES             |                              |
| 72F       | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 359.26              | 18.29                   | 5.64                    | YES             |                              |
| 72FE      | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 355.93              | 19.20                   | 5.64                    | YES             |                              |
| 97/50     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 352.59              | 11.89                   | 5.64                    | YES             |                              |
| 97/75     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 354.82              | 14.02                   | 5.64                    | YES             |                              |
| 97F       | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 359.82              | 17.37                   | 5.64                    | YES             |                              |
| 97FE      | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 357.04              | 17.98                   | 5.64                    | YES             |                              |

\*\*\* SOURCE IDs DEFINING SOURCE GROUPS \*\*\*

| GROUP ID | SOURCE IDs |
|----------|------------|
| 25/50    | 25/50 ,    |
| 25/75    | 25/75 ,    |
| 25F      | 25F ,      |
| 59FE     | 59FE ,     |



59F 59F ,  
 72F 72F ,  
 72FE 72FE ,  
 97/50 97/50 ,  
 97/75 97/75 ,  
 97F 97F ,  
 97FE 97FE ,

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |                       | AVERAGE CONC | RECEPTOR | (XR, YR, ZELEV, ZPLAG) | OF TYPE | NETWORK GRID-ID |
|----------|-----------------------|--------------|----------|------------------------|---------|-----------------|
| 25/50    | 1ST HIGHEST VALUE IS  | 0.02140 AT ( | 1650.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 2ND HIGHEST VALUE IS  | 0.02115 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 3RD HIGHEST VALUE IS  | 0.02001 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 4TH HIGHEST VALUE IS  | 0.01969 AT ( | 1320.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 5TH HIGHEST VALUE IS  | 0.01857 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 6TH HIGHEST VALUE IS  | 0.01844 AT ( | 1650.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 7TH HIGHEST VALUE IS  | 0.01835 AT ( | 1980.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 8TH HIGHEST VALUE IS  | 0.01800 AT ( | 1980.00, | -330.00,               | 0.00,   | 0.00) DC NA     |
|          | 9TH HIGHEST VALUE IS  | 0.01799 AT ( | 2310.00, | -330.00,               | 0.00,   | 0.00) DC NA     |
|          | 10TH HIGHEST VALUE IS | 0.01756 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
| 25/75    | 1ST HIGHEST VALUE IS  | 0.01684 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 2ND HIGHEST VALUE IS  | 0.01640 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 3RD HIGHEST VALUE IS  | 0.01634 AT ( | 1650.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 4TH HIGHEST VALUE IS  | 0.01555 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 5TH HIGHEST VALUE IS  | 0.01491 AT ( | 1980.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 6TH HIGHEST VALUE IS  | 0.01463 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 7TH HIGHEST VALUE IS  | 0.01455 AT ( | 2970.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 8TH HIGHEST VALUE IS  | 0.01450 AT ( | 2310.00, | -330.00,               | 0.00,   | 0.00) DC NA     |

|     |                       |              |          |          |       |       |    |    |
|-----|-----------------------|--------------|----------|----------|-------|-------|----|----|
|     | 9TH HIGHEST VALUE IS  | 0.01448 AT ( | 1650.00, | 330.00,  | 0.00, | 0.00) | DC | NA |
|     | 10TH HIGHEST VALUE IS | 0.01431 AT ( | 2640.00, | -330.00, | 0.00, | 0.00) | DC | NA |
| 25F | 1ST HIGHEST VALUE IS  | 0.01188 AT ( | 2310.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
|     | 2ND HIGHEST VALUE IS  | 0.01170 AT ( | 2640.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
|     | 3RD HIGHEST VALUE IS  | 0.01158 AT ( | 1980.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
|     | 4TH HIGHEST VALUE IS  | 0.01127 AT ( | 2970.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
|     | 5TH HIGHEST VALUE IS  | 0.01086 AT ( | 2310.00, | 330.00,  | 0.00, | 0.00) | DC | NA |
|     | 6TH HIGHEST VALUE IS  | 0.01073 AT ( | 2640.00, | 330.00,  | 0.00, | 0.00) | DC | NA |
|     | 7TH HIGHEST VALUE IS  | 0.01071 AT ( | 3300.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
|     | 8TH HIGHEST VALUE IS  | 0.01061 AT ( | 1980.00, | 330.00,  | 0.00, | 0.00) | DC | NA |
|     | 9TH HIGHEST VALUE IS  | 0.01054 AT ( | 2640.00, | -330.00, | 0.00, | 0.00) | DC | NA |
|     | 10TH HIGHEST VALUE IS | 0.01049 AT ( | 1650.00, | 0.00,    | 0.00, | 0.00) | DC | NA |

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3

\*\*

| GROUP ID |                       | AVERAGE CONC | RECEPTOR (XR, YR, ZELEV, ZFLAG) | OF TYPE  | NETWORK GRID-ID |       |    |    |
|----------|-----------------------|--------------|---------------------------------|----------|-----------------|-------|----|----|
| 59FE     | 1ST HIGHEST VALUE IS  | 0.01217 AT ( | 2310.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 2ND HIGHEST VALUE IS  | 0.01195 AT ( | 2640.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 3RD HIGHEST VALUE IS  | 0.01191 AT ( | 1980.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 4TH HIGHEST VALUE IS  | 0.01148 AT ( | 2970.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 5TH HIGHEST VALUE IS  | 0.01110 AT ( | 2310.00,                        | 330.00,  | 0.00,           | 0.00) | DC | NA |
|          | 6TH HIGHEST VALUE IS  | 0.01094 AT ( | 2640.00,                        | 330.00,  | 0.00,           | 0.00) | DC | NA |
|          | 7TH HIGHEST VALUE IS  | 0.01089 AT ( | 3300.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 8TH HIGHEST VALUE IS  | 0.01088 AT ( | 1980.00,                        | 330.00,  | 0.00,           | 0.00) | DC | NA |
|          | 9TH HIGHEST VALUE IS  | 0.01084 AT ( | 1650.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 10TH HIGHEST VALUE IS | 0.01078 AT ( | 2640.00,                        | -330.00, | 0.00,           | 0.00) | DC | NA |
| 59F      | 1ST HIGHEST VALUE IS  | 0.01223 AT ( | 2310.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 2ND HIGHEST VALUE IS  | 0.01200 AT ( | 2640.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 3RD HIGHEST VALUE IS  | 0.01198 AT ( | 1980.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 4TH HIGHEST VALUE IS  | 0.01153 AT ( | 2970.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 5TH HIGHEST VALUE IS  | 0.01116 AT ( | 2310.00,                        | 330.00,  | 0.00,           | 0.00) | DC | NA |
|          | 6TH HIGHEST VALUE IS  | 0.01099 AT ( | 2640.00,                        | 330.00,  | 0.00,           | 0.00) | DC | NA |
|          | 7TH HIGHEST VALUE IS  | 0.01094 AT ( | 3300.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 8TH HIGHEST VALUE IS  | 0.01093 AT ( | 1980.00,                        | 330.00,  | 0.00,           | 0.00) | DC | NA |
|          | 9TH HIGHEST VALUE IS  | 0.01091 AT ( | 1650.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 10TH HIGHEST VALUE IS | 0.01084 AT ( | 2640.00,                        | -330.00, | 0.00,           | 0.00) | DC | NA |
| 72F      | 1ST HIGHEST VALUE IS  | 0.01252 AT ( | 2310.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 2ND HIGHEST VALUE IS  | 0.01230 AT ( | 1980.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 3RD HIGHEST VALUE IS  | 0.01225 AT ( | 2640.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 4TH HIGHEST VALUE IS  | 0.01175 AT ( | 2970.00,                        | 0.00,    | 0.00,           | 0.00) | DC | NA |
|          | 5TH HIGHEST VALUE IS  | 0.01140 AT ( | 2310.00,                        | 330.00,  | 0.00,           | 0.00) | DC | NA |

|                       |              |          |          |       |       |    |    |
|-----------------------|--------------|----------|----------|-------|-------|----|----|
| 6TH HIGHEST VALUE IS  | 0.01126 AT ( | 1650.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
| 7TH HIGHEST VALUE IS  | 0.01120 AT ( | 2640.00, | 330.00,  | 0.00, | 0.00) | DC | NA |
| 8TH HIGHEST VALUE IS  | 0.01120 AT ( | 1980.00, | 330.00,  | 0.00, | 0.00) | DC | NA |
| 9TH HIGHEST VALUE IS  | 0.01112 AT ( | 3300.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
| 10TH HIGHEST VALUE IS | 0.01107 AT ( | 2640.00, | -330.00, | 0.00, | 0.00) | DC | NA |

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3

\*\*

| GROUP ID |                       | AVERAGE CONC | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK<br>GRID-ID |
|----------|-----------------------|--------------|----------|------------------------|---------|--------------------|
| 72FE     | 1ST HIGHEST VALUE IS  | 0.01252 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 2ND HIGHEST VALUE IS  | 0.01231 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 3RD HIGHEST VALUE IS  | 0.01226 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 4TH HIGHEST VALUE IS  | 0.01175 AT ( | 2970.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 5TH HIGHEST VALUE IS  | 0.01140 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
|          | 6TH HIGHEST VALUE IS  | 0.01127 AT ( | 1650.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 7TH HIGHEST VALUE IS  | 0.01121 AT ( | 1980.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
|          | 8TH HIGHEST VALUE IS  | 0.01121 AT ( | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
|          | 9TH HIGHEST VALUE IS  | 0.01112 AT ( | 3300.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 10TH HIGHEST VALUE IS | 0.01108 AT ( | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
| 97/50    | 1ST HIGHEST VALUE IS  | 0.02065 AT ( | 1650.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 2ND HIGHEST VALUE IS  | 0.02054 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 3RD HIGHEST VALUE IS  | 0.01952 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 4TH HIGHEST VALUE IS  | 0.01882 AT ( | 1320.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 5TH HIGHEST VALUE IS  | 0.01818 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 6TH HIGHEST VALUE IS  | 0.01787 AT ( | 1650.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
|          | 7TH HIGHEST VALUE IS  | 0.01787 AT ( | 1980.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
|          | 8TH HIGHEST VALUE IS  | 0.01754 AT ( | 2310.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
|          | 9TH HIGHEST VALUE IS  | 0.01747 AT ( | 1980.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
|          | 10TH HIGHEST VALUE IS | 0.01716 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 97/75    | 1ST HIGHEST VALUE IS  | 0.01723 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 2ND HIGHEST VALUE IS  | 0.01676 AT ( | 1650.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 3RD HIGHEST VALUE IS  | 0.01675 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 4TH HIGHEST VALUE IS  | 0.01586 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 5TH HIGHEST VALUE IS  | 0.01517 AT ( | 1980.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
|          | 6TH HIGHEST VALUE IS  | 0.01487 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
|          | 7TH HIGHEST VALUE IS  | 0.01487 AT ( | 2310.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
|          | 8TH HIGHEST VALUE IS  | 0.01482 AT ( | 2970.00, | 0.00,                  | 0.00,   | 0.00) DC NA        |
|          | 9TH HIGHEST VALUE IS  | 0.01476 AT ( | 1650.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
|          | 10TH HIGHEST VALUE IS | 0.01465 AT ( | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA        |

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3

\*\*

| GROUP ID |                       | AVERAGE CONC | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK GRID-ID |
|----------|-----------------------|--------------|----------|------------------------|---------|-----------------|
| 97F      | 1ST HIGHEST VALUE IS  | 0.01302 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 2ND HIGHEST VALUE IS  | 0.01288 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 3RD HIGHEST VALUE IS  | 0.01269 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 4TH HIGHEST VALUE IS  | 0.01212 AT ( | 2970.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 5TH HIGHEST VALUE IS  | 0.01188 AT ( | 1650.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 6TH HIGHEST VALUE IS  | 0.01182 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 7TH HIGHEST VALUE IS  | 0.01168 AT ( | 1980.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 8TH HIGHEST VALUE IS  | 0.01158 AT ( | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 9TH HIGHEST VALUE IS  | 0.01149 AT ( | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA     |
|          | 10TH HIGHEST VALUE IS | 0.01145 AT ( | 3300.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
| 97FE     | 1ST HIGHEST VALUE IS  | 0.01310 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 2ND HIGHEST VALUE IS  | 0.01296 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 3RD HIGHEST VALUE IS  | 0.01275 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 4TH HIGHEST VALUE IS  | 0.01217 AT ( | 2970.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 5TH HIGHEST VALUE IS  | 0.01198 AT ( | 1650.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 6TH HIGHEST VALUE IS  | 0.01188 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 7TH HIGHEST VALUE IS  | 0.01175 AT ( | 1980.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 8TH HIGHEST VALUE IS  | 0.01163 AT ( | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 9TH HIGHEST VALUE IS  | 0.01155 AT ( | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA     |
|          | 10TH HIGHEST VALUE IS | 0.01149 AT ( | 3300.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3

\*\*

| GROUP ID |                        | AVERAGE CONC | DATE (YYMMDDHH) | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE  | NETWORK GRID-ID |             |
|----------|------------------------|--------------|-----------------|----------|------------------------|----------|-----------------|-------------|
| 25/50    | HIGH 1ST HIGH VALUE IS | 2.67856      | ON 87033114:    | AT (     | 150.00,                | -143.00, | 0.00,           | 0.00) DC NA |
| 25/75    | HIGH 1ST HIGH VALUE IS | 1.81547      | ON 87033114:    | AT (     | 150.00,                | -143.00, | 0.00,           | 0.00) DC NA |
| 25F      | HIGH 1ST HIGH VALUE IS | 1.07978      | ON 87090514:    | AT (     | -660.00,               | 660.00,  | 0.00,           | 0.00) DC NA |
| 59FE     | HIGH 1ST HIGH VALUE IS | 1.08383      | ON 87090514:    | AT (     | -660.00,               | 660.00,  | 0.00,           | 0.00) DC NA |
| 59F      | HIGH 1ST HIGH VALUE IS | 1.08479      | ON 87090514:    | AT (     | -660.00,               | 660.00,  | 0.00,           | 0.00) DC NA |
| 72F      | HIGH 1ST HIGH VALUE IS | 1.08909      | ON 87090514:    | AT (     | -660.00,               | 660.00,  | 0.00,           | 0.00) DC NA |
| 72FE     | HIGH 1ST HIGH VALUE IS | 1.08920      | ON 87090514:    | AT (     | -660.00,               | 660.00,  | 0.00,           | 0.00) DC NA |
| 97/50    | HIGH 1ST HIGH VALUE IS | 2.78041      | ON 87033114:    | AT (     | 150.00,                | -143.00, | 0.00,           | 0.00) DC NA |
| 97/75    | HIGH 1ST HIGH VALUE IS | 2.05733      | ON 87033114:    | AT (     | 150.00,                | -143.00, | 0.00,           | 0.00) DC NA |
| 97F      | HIGH 1ST HIGH VALUE IS | 1.09708      | ON 87090514:    | AT (     | -660.00,               | 660.00,  | 0.00,           | 0.00) DC NA |
| 97FE     | HIGH 1ST HIGH VALUE IS | 1.09825      | ON 87090514:    | AT (     | -660.00,               | 660.00,  | 0.00,           | 0.00) DC NA |

\*\*\* THE SUMMARY OF HIGHEST 3-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |      |                   |  | AVERAGE CONC | DATE<br>(YYMMDDHH) | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK<br>GRID-ID |
|----------|------|-------------------|--|--------------|--------------------|----------|------------------------|---------|--------------------|
| 25/50    | HIGH | 1ST HIGH VALUE IS |  | 1.60643      | ON 87033115: AT (  | 150.00,  | -143.00,               | 0.00,   | 0.00) DC NA        |
| 25/75    | HIGH | 1ST HIGH VALUE IS |  | 0.70226      | ON 87091915: AT (  | 2310.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
| 25F      | HIGH | 1ST HIGH VALUE IS |  | 0.53377      | ON 87091915: AT (  | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
| 59FE     | HIGH | 1ST HIGH VALUE IS |  | 0.54451      | ON 87091915: AT (  | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
| 59F      | HIGH | 1ST HIGH VALUE IS |  | 0.54507      | ON 87091915: AT (  | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
| 72F      | HIGH | 1ST HIGH VALUE IS |  | 0.55437      | ON 87091915: AT (  | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
| 72FE     | HIGH | 1ST HIGH VALUE IS |  | 0.55656      | ON 87091915: AT (  | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
| 97/50    | HIGH | 1ST HIGH VALUE IS |  | 1.68190      | ON 87033115: AT (  | 150.00,  | -143.00,               | 0.00,   | 0.00) DC NA        |
| 97/75    | HIGH | 1ST HIGH VALUE IS |  | 0.88916      | ON 87033112: AT (  | 250.00,  | -143.00,               | 0.00,   | 0.00) DC NA        |
| 97F      | HIGH | 1ST HIGH VALUE IS |  | 0.57182      | ON 87091915: AT (  | 2310.00, | -330.00,               | 0.00,   | 0.00) DC NA        |
| 97FE     | HIGH | 1ST HIGH VALUE IS |  | 0.57657      | ON 87091915: AT (  | 2310.00, | -330.00,               | 0.00,   | 0.00) DC NA        |

\*\*\* THE SUMMARY OF HIGHEST 8-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |      |                   |  | AVERAGE CONC | DATE<br>(YYMMDDHH) | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK<br>GRID-ID |
|----------|------|-------------------|--|--------------|--------------------|----------|------------------------|---------|--------------------|
| 25/50    | HIGH | 1ST HIGH VALUE IS |  | 0.86893      | ON 87033116: AT (  | 200.00,  | -143.00,               | 0.00,   | 0.00) DC NA        |
| 25/75    | HIGH | 1ST HIGH VALUE IS |  | 0.42059c     | ON 87081916: AT (  | 1320.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 25F      | HIGH | 1ST HIGH VALUE IS |  | 0.32436      | ON 87042416: AT (  | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 59FE     | HIGH | 1ST HIGH VALUE IS |  | 0.32849      | ON 87042416: AT (  | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 59F      | HIGH | 1ST HIGH VALUE IS |  | 0.32980      | ON 87042416: AT (  | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 72F      | HIGH | 1ST HIGH VALUE IS |  | 0.33421      | ON 87042416: AT (  | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 72FE     | HIGH | 1ST HIGH VALUE IS |  | 0.33393      | ON 87042416: AT (  | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 97/50    | HIGH | 1ST HIGH VALUE IS |  | 0.90652      | ON 87033116: AT (  | 200.00,  | -143.00,               | 0.00,   | 0.00) DC NA        |
| 97/75    | HIGH | 1ST HIGH VALUE IS |  | 0.42482c     | ON 87081916: AT (  | 1320.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 97F      | HIGH | 1ST HIGH VALUE IS |  | 0.34192      | ON 87042416: AT (  | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA        |
| 97FE     | HIGH | 1ST HIGH VALUE IS |  | 0.34268      | ON 87042416: AT (  | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA        |

\*\*\* THE SUMMARY OF HIGHEST 24-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |      |                   | AVERAGE CONC | DATE<br>(YYMMDDHH) | RECEPTOR  | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK<br>GRID-ID |
|----------|------|-------------------|--------------|--------------------|-----------|------------------------|---------|--------------------|
| 25/50    | HIGH | 1ST HIGH VALUE IS | 0.28964      | ON 87033124: AT (  | 200.00,   | -143.00,               | 0.00,   | 0.00) DC NA        |
| 25/75    | HIGH | 1ST HIGH VALUE IS | 0.16645      | ON 87100424: AT (  | -2310.00, | -1320.00,              | 0.00,   | 0.00) DC NA        |
| 25F      | HIGH | 1ST HIGH VALUE IS | 0.11920c     | ON 87041024: AT (  | 2640.00,  | -330.00,               | 0.00,   | 0.00) DC NA        |
| 59FE     | HIGH | 1ST HIGH VALUE IS | 0.12164c     | ON 87041024: AT (  | 2640.00,  | -330.00,               | 0.00,   | 0.00) DC NA        |
| 59F      | HIGH | 1ST HIGH VALUE IS | 0.12272c     | ON 87041024: AT (  | 2640.00,  | -330.00,               | 0.00,   | 0.00) DC NA        |
| 72F      | HIGH | 1ST HIGH VALUE IS | 0.12551c     | ON 87041024: AT (  | 2640.00,  | -330.00,               | 0.00,   | 0.00) DC NA        |
| 72FE     | HIGH | 1ST HIGH VALUE IS | 0.12504c     | ON 87041024: AT (  | 2640.00,  | -330.00,               | 0.00,   | 0.00) DC NA        |
| 97/50    | HIGH | 1ST HIGH VALUE IS | 0.30217      | ON 87033124: AT (  | 200.00,   | -143.00,               | 0.00,   | 0.00) DC NA        |
| 97/75    | HIGH | 1ST HIGH VALUE IS | 0.17055      | ON 87100424: AT (  | -2310.00, | -1320.00,              | 0.00,   | 0.00) DC NA        |
| 97F      | HIGH | 1ST HIGH VALUE IS | 0.13035c     | ON 87041024: AT (  | 2640.00,  | -330.00,               | 0.00,   | 0.00) DC NA        |
| 97FE     | HIGH | 1ST HIGH VALUE IS | 0.13058c     | ON 87041024: AT (  | 2640.00,  | -330.00,               | 0.00,   | 0.00) DC NA        |

\*\*\* ISCST3 - VERSION 99155 \*\*\*      \*\*\* oil 25 72 97F 150 ft stax flat terrain 9/8/00 1987 Tampa metdat      \*\*\*

BEE-Line ISCST3 "BEEST" Version 6.71

Input File - O:\AIR\_ENG\PROJECTS\pineypt\oil87150.DTA  
 Output File - O:\AIR\_ENG\PROJECTS\pineypt\oil87150.LST  
 Met File - O:\AIR\_ENG\PROJECTS\pineypt\met\12842-87.OUT

Number of sources -            10  
 Number of source groups -    10  
 Number of receptors -        3196

\*\*\* POINT SOURCE DATA \*\*\*

| SOURCE ID | NUMBER PART. CATS. | EMISSION RATE (GRAMS/SEC) | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | STACK HEIGHT (METERS) | STACK TEMP. (DEG.K) | STACK EXIT VEL. (M/SEC) | STACK DIAMETER (METERS) | BUILDING EXISTS | EMISSION RATE |         |
|-----------|--------------------|---------------------------|------------|------------|---------------------|-----------------------|---------------------|-------------------------|-------------------------|-----------------|---------------|---------|
|           |                    |                           |            |            |                     |                       |                     |                         |                         |                 | SCALAR        | VARY BY |
| 25/50     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 397.04              | 14.33                   | 5.64                    | YES             |               |         |
| 25/75     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 398.71              | 17.98                   | 5.64                    | YES             |               |         |
| 25F       | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 413.71              | 24.08                   | 5.64                    | YES             |               |         |
| 59F       | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 413.15              | 22.56                   | 5.64                    | YES             |               |         |
| 72/50     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 397.04              | 14.02                   | 5.64                    | YES             |               |         |
| 72/75     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 402.59              | 17.07                   | 5.64                    | YES             |               |         |
| 72F       | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 413.15              | 21.95                   | 5.64                    | YES             |               |         |
| 97/50     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 399.26              | 13.41                   | 5.64                    | YES             |               |         |
| 97/75     | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 405.37              | 16.46                   | 5.64                    | YES             |               |         |
| 97F       | 0                  | 0.10000E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 413.15              | 20.42                   | 5.64                    | YES             |               |         |

\*\*\* SOURCE IDs DEFINING SOURCE GROUPS \*\*\*

| GROUP ID | SOURCE IDs |
|----------|------------|
| 25/50    | 25/50 ,    |
| 25/75    | 25/75 ,    |
| 25F      | 25F ,      |
| 59F      | 59F ,      |

72/50 72/50 ,  
 72/75 72/75 ,  
 72F 72F ,  
 97/50 97/50 ,  
 97/75 97/75 ,  
 97F 97F ,

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID | AVERAGE CONC          | RECEPTOR (XR, YR, ZELEV, ZFLAG)            | OF TYPE | NETWORK GRID-ID |
|----------|-----------------------|--|---------|-----------------|
| 25/50    | 1ST HIGHEST VALUE IS  | 0.01081 AT ( 2310.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 2ND HIGHEST VALUE IS  | 0.01078 AT ( 2640.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 3RD HIGHEST VALUE IS  | 0.01048 AT ( 2970.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 4TH HIGHEST VALUE IS  | 0.01037 AT ( 1980.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 5TH HIGHEST VALUE IS  | 0.01003 AT ( 3300.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 6TH HIGHEST VALUE IS  | 0.00992 AT ( 2310.00, 330.00, 0.00, 0.00)  | DC      | NA              |
|          | 7TH HIGHEST VALUE IS  | 0.00991 AT ( 2640.00, 330.00, 0.00, 0.00)  | DC      | NA              |
|          | 8TH HIGHEST VALUE IS  | 0.00968 AT ( 2970.00, 330.00, 0.00, 0.00)  | DC      | NA              |
|          | 9TH HIGHEST VALUE IS  | 0.00968 AT ( 2970.00, -330.00, 0.00, 0.00) | DC      | NA              |
|          | 10TH HIGHEST VALUE IS | 0.00966 AT ( 2640.00, -330.00, 0.00, 0.00) | DC      | NA              |
| 25/75    | 1ST HIGHEST VALUE IS  | 0.00843 AT ( 2640.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 2ND HIGHEST VALUE IS  | 0.00839 AT ( 2970.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 3RD HIGHEST VALUE IS  | 0.00821 AT ( 2310.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 4TH HIGHEST VALUE IS  | 0.00819 AT ( 3300.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 5TH HIGHEST VALUE IS  | 0.00790 AT ( 3630.00, 0.00, 0.00, 0.00)    | DC      | NA              |
|          | 6TH HIGHEST VALUE IS  | 0.00781 AT ( 2640.00, 330.00, 0.00, 0.00)  | DC      | NA              |
|          | 7TH HIGHEST VALUE IS  | 0.00777 AT ( 2970.00, 330.00, 0.00, 0.00)  | DC      | NA              |
|          | 8TH HIGHEST VALUE IS  | 0.00777 AT ( 2970.00, -330.00, 0.00, 0.00) | DC      | NA              |
|          | 9TH HIGHEST VALUE IS  | 0.00775 AT ( 3300.00, -330.00, 0.00, 0.00) | DC      | NA              |
|          | 10TH HIGHEST VALUE IS | 0.00763 AT ( 2310.00, 330.00, 0.00, 0.00)  | DC      | NA              |
| 25F      | 1ST HIGHEST VALUE IS  | 0.00555 AT ( 3300.00, 0.00, 0.00, 0.00)    | DC      | NA              |



|                       |         |      |          |          |       |       |    |    |
|-----------------------|---------|------|----------|----------|-------|-------|----|----|
| 2ND HIGHEST VALUE IS  | 0.00551 | AT ( | 3630.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
| 3RD HIGHEST VALUE IS  | 0.00549 | AT ( | 2970.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
| 4TH HIGHEST VALUE IS  | 0.00540 | AT ( | 3960.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
| 5TH HIGHEST VALUE IS  | 0.00530 | AT ( | 2640.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
| 6TH HIGHEST VALUE IS  | 0.00526 | AT ( | 4290.00, | 0.00,    | 0.00, | 0.00) | DC | NA |
| 7TH HIGHEST VALUE IS  | 0.00523 | AT ( | 3630.00, | -330.00, | 0.00, | 0.00) | DC | NA |
| 8TH HIGHEST VALUE IS  | 0.00523 | AT ( | 3300.00, | 330.00,  | 0.00, | 0.00) | DC | NA |
| 9TH HIGHEST VALUE IS  | 0.00520 | AT ( | 3960.00, | -330.00, | 0.00, | 0.00) | DC | NA |
| 10TH HIGHEST VALUE IS | 0.00519 | AT ( | 2970.00, | 330.00,  | 0.00, | 0.00) | DC | NA |

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |                       | AVERAGE CONC | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF       | TYPE  | NETWORK | GRID-ID |
|----------|-----------------------|--------------|----------|------------------------|----------|-------|---------|---------|
| .59F     | 1ST HIGHEST VALUE IS  | 0.00598      | AT (     | 3300.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 2ND HIGHEST VALUE IS  | 0.00596      | AT (     | 2970.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 3RD HIGHEST VALUE IS  | 0.00590      | AT (     | 3630.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 4TH HIGHEST VALUE IS  | 0.00579      | AT (     | 2640.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 5TH HIGHEST VALUE IS  | 0.00576      | AT (     | 3960.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 6TH HIGHEST VALUE IS  | 0.00566      | AT (     | 3300.00,               | 330.00,  | 0.00, | 0.00)   | DC NA   |
|          | 7TH HIGHEST VALUE IS  | 0.00565      | AT (     | 2970.00,               | 330.00,  | 0.00, | 0.00)   | DC NA   |
|          | 8TH HIGHEST VALUE IS  | 0.00559      | AT (     | 3630.00,               | -330.00, | 0.00, | 0.00)   | DC NA   |
|          | 9TH HIGHEST VALUE IS  | 0.00558      | AT (     | 3630.00,               | 330.00,  | 0.00, | 0.00)   | DC NA   |
|          | 10TH HIGHEST VALUE IS | 0.00558      | AT (     | 4290.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
| 72/50    | 1ST HIGHEST VALUE IS  | 0.01104      | AT (     | 2310.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 2ND HIGHEST VALUE IS  | 0.01098      | AT (     | 2640.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 3RD HIGHEST VALUE IS  | 0.01066      | AT (     | 2970.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 4TH HIGHEST VALUE IS  | 0.01063      | AT (     | 1980.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 5TH HIGHEST VALUE IS  | 0.01019      | AT (     | 3300.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 6TH HIGHEST VALUE IS  | 0.01012      | AT (     | 2310.00,               | 330.00,  | 0.00, | 0.00)   | DC NA   |
|          | 7TH HIGHEST VALUE IS  | 0.01009      | AT (     | 2640.00,               | 330.00,  | 0.00, | 0.00)   | DC NA   |
|          | 8TH HIGHEST VALUE IS  | 0.00985      | AT (     | 2970.00,               | -330.00, | 0.00, | 0.00)   | DC NA   |
|          | 9TH HIGHEST VALUE IS  | 0.00985      | AT (     | 2640.00,               | -330.00, | 0.00, | 0.00)   | DC NA   |
|          | 10TH HIGHEST VALUE IS | 0.00984      | AT (     | 2970.00,               | 330.00,  | 0.00, | 0.00)   | DC NA   |
| 72/75    | 1ST HIGHEST VALUE IS  | 0.00866      | AT (     | 2640.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 2ND HIGHEST VALUE IS  | 0.00860      | AT (     | 2970.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 3RD HIGHEST VALUE IS  | 0.00846      | AT (     | 2310.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 4TH HIGHEST VALUE IS  | 0.00837      | AT (     | 3300.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 5TH HIGHEST VALUE IS  | 0.00806      | AT (     | 3630.00,               | 0.00,    | 0.00, | 0.00)   | DC NA   |
|          | 6TH HIGHEST VALUE IS  | 0.00804      | AT (     | 2640.00,               | 330.00,  | 0.00, | 0.00)   | DC NA   |
|          | 7TH HIGHEST VALUE IS  | 0.00799      | AT (     | 2970.00,               | 330.00,  | 0.00, | 0.00)   | DC NA   |
|          | 8TH HIGHEST VALUE IS  | 0.00795      | AT (     | 2970.00,               | -330.00, | 0.00, | 0.00)   | DC NA   |
|          | 9TH HIGHEST VALUE IS  | 0.00791      | AT (     | 3300.00,               | -330.00, | 0.00, | 0.00)   | DC NA   |

10TH HIGHEST VALUE IS 0.00788 AT ( 2310.00, 330.00, 0.00, 0.00) DC NA

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |                       | AVERAGE CONC | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK GRID-ID |
|----------|-----------------------|--------------|----------|------------------------|---------|-----------------|
| 72F      | 1ST HIGHEST VALUE IS  | 0.00625 AT ( | 3300.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 2ND HIGHEST VALUE IS  | 0.00625 AT ( | 2970.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 3RD HIGHEST VALUE IS  | 0.00616 AT ( | 3630.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 4TH HIGHEST VALUE IS  | 0.00608 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 5TH HIGHEST VALUE IS  | 0.00601 AT ( | 3960.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 6TH HIGHEST VALUE IS  | 0.00590 AT ( | 3300.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 7TH HIGHEST VALUE IS  | 0.00590 AT ( | 2970.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 8TH HIGHEST VALUE IS  | 0.00582 AT ( | 3630.00, | -330.00,               | 0.00,   | 0.00) DC NA     |
|          | 9TH HIGHEST VALUE IS  | 0.00582 AT ( | 3630.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 10TH HIGHEST VALUE IS | 0.00581 AT ( | 4290.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
| 97/50    | 1ST HIGHEST VALUE IS  | 0.01134 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 2ND HIGHEST VALUE IS  | 0.01125 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 3RD HIGHEST VALUE IS  | 0.01096 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 4TH HIGHEST VALUE IS  | 0.01089 AT ( | 2970.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 5TH HIGHEST VALUE IS  | 0.01039 AT ( | 3300.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 6TH HIGHEST VALUE IS  | 0.01038 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 7TH HIGHEST VALUE IS  | 0.01033 AT ( | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 8TH HIGHEST VALUE IS  | 0.01011 AT ( | 2640.00, | -330.00,               | 0.00,   | 0.00) DC NA     |
|          | 9TH HIGHEST VALUE IS  | 0.01008 AT ( | 2970.00, | -330.00,               | 0.00,   | 0.00) DC NA     |
|          | 10TH HIGHEST VALUE IS | 0.01005 AT ( | 2970.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
| 97/75    | 1ST HIGHEST VALUE IS  | 0.00886 AT ( | 2640.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 2ND HIGHEST VALUE IS  | 0.00879 AT ( | 2970.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 3RD HIGHEST VALUE IS  | 0.00867 AT ( | 2310.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 4TH HIGHEST VALUE IS  | 0.00855 AT ( | 3300.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 5TH HIGHEST VALUE IS  | 0.00823 AT ( | 2640.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 6TH HIGHEST VALUE IS  | 0.00823 AT ( | 3630.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |
|          | 7TH HIGHEST VALUE IS  | 0.00818 AT ( | 2970.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 8TH HIGHEST VALUE IS  | 0.00808 AT ( | 2970.00, | -330.00,               | 0.00,   | 0.00) DC NA     |
|          | 9TH HIGHEST VALUE IS  | 0.00807 AT ( | 2310.00, | 330.00,                | 0.00,   | 0.00) DC NA     |
|          | 10TH HIGHEST VALUE IS | 0.00806 AT ( | 1980.00, | 0.00,                  | 0.00,   | 0.00) DC NA     |

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |                       | AVERAGE CONC | RECEPTOR      | (XR, YR, ZELEV, ZFLAG) | OF TYPE  | NETWORK GRID-ID |
|----------|-----------------------|--------------|---------------|------------------------|----------|-----------------|
| 97F      | 1ST HIGHEST VALUE IS  | 0.00673      | AT ( 2970.00, | 0.00, 0.00,            | 0.00) DC | NA              |
|          | 2ND HIGHEST VALUE IS  | 0.00670      | AT ( 3300.00, | 0.00, 0.00,            | 0.00) DC | NA              |
|          | 3RD HIGHEST VALUE IS  | 0.00660      | AT ( 2640.00, | 0.00, 0.00,            | 0.00) DC | NA              |
|          | 4TH HIGHEST VALUE IS  | 0.00657      | AT ( 3630.00, | 0.00, 0.00,            | 0.00) DC | NA              |
|          | 5TH HIGHEST VALUE IS  | 0.00638      | AT ( 3960.00, | 0.00, 0.00,            | 0.00) DC | NA              |
|          | 6TH HIGHEST VALUE IS  | 0.00633      | AT ( 2970.00, | 330.00, 0.00,          | 0.00) DC | NA              |
|          | 7TH HIGHEST VALUE IS  | 0.00630      | AT ( 3300.00, | 330.00, 0.00,          | 0.00) DC | NA              |
|          | 8TH HIGHEST VALUE IS  | 0.00624      | AT ( 2310.00, | 0.00, 0.00,            | 0.00) DC | NA              |
|          | 9TH HIGHEST VALUE IS  | 0.00623      | AT ( 2640.00, | 330.00, 0.00,          | 0.00) DC | NA              |
|          | 10TH HIGHEST VALUE IS | 0.00622      | AT ( 3300.00, | -330.00, 0.00,         | 0.00) DC | NA              |

\*\*\* THE SUMMARY OF HIGHEST 1-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3

| GROUP ID |                        | AVERAGE CONC | DATE (YYMMDDHH) | RECEPTOR     | (XR, YR, ZELEV, ZFLAG) | OF TYPE  | NETWORK GRID-ID |
|----------|------------------------|--------------|-----------------|--------------|------------------------|----------|-----------------|
| 25/50    | HIGH 1ST HIGH VALUE IS | 1.48293      | ON 87033114:    | AT ( 150.00, | -143.00, 0.00,         | 0.00) DC | NA              |
| 25/75    | HIGH 1ST HIGH VALUE IS | 0.72940      | ON 87082111:    | AT ( 330.00, | 1320.00, 0.00,         | 0.00) DC | NA              |
| 25F      | HIGH 1ST HIGH VALUE IS | 0.59668      | ON 87072311:    | AT ( 330.00, | 1320.00, 0.00,         | 0.00) DC | NA              |
| 59F      | HIGH 1ST HIGH VALUE IS | 0.60294      | ON 87072311:    | AT ( 330.00, | 990.00, 0.00,          | 0.00) DC | NA              |
| 72/50    | HIGH 1ST HIGH VALUE IS | 1.54803      | ON 87033114:    | AT ( 150.00, | -143.00, 0.00,         | 0.00) DC | NA              |
| 72/75    | HIGH 1ST HIGH VALUE IS | 0.97919      | ON 87033114:    | AT ( 150.00, | -143.00, 0.00,         | 0.00) DC | NA              |
| 72F      | HIGH 1ST HIGH VALUE IS | 0.60714      | ON 87072311:    | AT ( 330.00, | 990.00, 0.00,          | 0.00) DC | NA              |
| 97/50    | HIGH 1ST HIGH VALUE IS | 1.66806      | ON 87033114:    | AT ( 150.00, | -143.00, 0.00,         | 0.00) DC | NA              |
| 97/75    | HIGH 1ST HIGH VALUE IS | 1.05073      | ON 87033114:    | AT ( 150.00, | -143.00, 0.00,         | 0.00) DC | NA              |
| 97F      | HIGH 1ST HIGH VALUE IS | 0.69077      | ON 87082111:    | AT ( 330.00, | 1320.00, 0.00,         | 0.00) DC | NA              |

\*\*\* THE SUMMARY OF HIGHEST 3-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3

| GROUP ID |                        | AVERAGE CONC | DATE (YYMMDDHH) | RECEPTOR      | (XR, YR, ZELEV, ZFLAG) | OF TYPE  | NETWORK GRID-ID |
|----------|------------------------|--------------|-----------------|---------------|------------------------|----------|-----------------|
| 25/50    | HIGH 1ST HIGH VALUE IS | 0.60864      | ON 87033112:    | AT ( 250.00,  | -143.00, 0.00,         | 0.00) DC | NA              |
| 25/75    | HIGH 1ST HIGH VALUE IS | 0.38780      | ON 87091915:    | AT ( 2970.00, | -330.00, 0.00,         | 0.00) DC | NA              |
| 25F      | HIGH 1ST HIGH VALUE IS | 0.26164      | ON 87091915:    | AT ( 3300.00, | -330.00, 0.00,         | 0.00) DC | NA              |
| 59F      | HIGH 1ST HIGH VALUE IS | 0.29295      | ON 87042412:    | AT ( 3960.00, | 660.00, 0.00,          | 0.00) DC | NA              |
| 72/50    | HIGH 1ST HIGH VALUE IS | 0.63712      | ON 87033112:    | AT ( 250.00,  | -143.00, 0.00,         | 0.00) DC | NA              |

|       |      |                   |         |                   |          |          |       |       |    |    |
|-------|------|-------------------|---------|-------------------|----------|----------|-------|-------|----|----|
| 72/75 | HIGH | 1ST HIGH VALUE IS | 0.39477 | ON 87091915: AT ( | 2970.00, | -330.00, | 0.00, | 0.00) | DC | NA |
| 72F   | HIGH | 1ST HIGH VALUE IS | 0.29465 | ON 87042412: AT ( | 3960.00, | 660.00,  | 0.00, | 0.00) | DC | NA |
| 97/50 | HIGH | 1ST HIGH VALUE IS | 0.68915 | ON 87033112: AT ( | 250.00,  | -143.00, | 0.00, | 0.00) | DC | NA |
| 97/75 | HIGH | 1ST HIGH VALUE IS | 0.40051 | ON 87091915: AT ( | 2640.00, | -330.00, | 0.00, | 0.00) | DC | NA |
| 97F   | HIGH | 1ST HIGH VALUE IS | 0.31065 | ON 87091915: AT ( | 2970.00, | -330.00, | 0.00, | 0.00) | DC | NA |

\*\*\* THE SUMMARY OF HIGHEST 8-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |      |                   | AVERAGE CONC | DATE<br>(YYMMDDHH) | RECEPTOR  | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK<br>GRID-ID |    |    |
|----------|------|-------------------|--------------|--------------------|-----------|------------------------|---------|--------------------|----|----|
| 25/50    | HIGH | 1ST HIGH VALUE IS | 0.31015      | ON 87042416: AT (  | 2640.00,  | 330.00,                | 0.00,   | 0.00)              | DC | NA |
| 25/75    | HIGH | 1ST HIGH VALUE IS | 0.20785      | ON 87051716: AT (  | -2310.00, | 1980.00,               | 0.00,   | 0.00)              | DC | NA |
| 25F      | HIGH | 1ST HIGH VALUE IS | 0.14254      | ON 87081616: AT (  | 990.00,   | 3300.00,               | 0.00,   | 0.00)              | DC | NA |
| 59F      | HIGH | 1ST HIGH VALUE IS | 0.16398      | ON 87042416: AT (  | 2970.00,  | 330.00,                | 0.00,   | 0.00)              | DC | NA |
| 72/50    | HIGH | 1ST HIGH VALUE IS | 0.31373      | ON 87042416: AT (  | 2640.00,  | 330.00,                | 0.00,   | 0.00)              | DC | NA |
| 72/75    | HIGH | 1ST HIGH VALUE IS | 0.21256      | ON 87051716: AT (  | -2310.00, | 1980.00,               | 0.00,   | 0.00)              | DC | NA |
| 72F      | HIGH | 1ST HIGH VALUE IS | 0.16657      | ON 87042416: AT (  | 2970.00,  | 330.00,                | 0.00,   | 0.00)              | DC | NA |
| 97/50    | HIGH | 1ST HIGH VALUE IS | 0.31840      | ON 87042416: AT (  | 2640.00,  | 330.00,                | 0.00,   | 0.00)              | DC | NA |
| 97/75    | HIGH | 1ST HIGH VALUE IS | 0.28404      | ON 87042416: AT (  | 2970.00,  | 330.00,                | 0.00,   | 0.00)              | DC | NA |
| 97F      | HIGH | 1ST HIGH VALUE IS | 0.17370      | ON 87042416: AT (  | 2970.00,  | 330.00,                | 0.00,   | 0.00)              | DC | NA |

\*\*\* THE SUMMARY OF HIGHEST 24-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |      |                   | AVERAGE CONC | DATE<br>(YYMMDDHH) | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK<br>GRID-ID |    |    |
|----------|------|-------------------|--------------|--------------------|----------|------------------------|---------|--------------------|----|----|
| 25/50    | HIGH | 1ST HIGH VALUE IS | 0.11272c     | ON 87041024: AT (  | 2970.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |
| 25/75    | HIGH | 1ST HIGH VALUE IS | 0.09112c     | ON 87041024: AT (  | 2970.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |
| 25F      | HIGH | 1ST HIGH VALUE IS | 0.06321c     | ON 87041024: AT (  | 3630.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |
| 59F      | HIGH | 1ST HIGH VALUE IS | 0.06753c     | ON 87041024: AT (  | 3630.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |
| 72/50    | HIGH | 1ST HIGH VALUE IS | 0.11470c     | ON 87041024: AT (  | 2970.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |
| 72/75    | HIGH | 1ST HIGH VALUE IS | 0.09331c     | ON 87041024: AT (  | 2970.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |
| 72F      | HIGH | 1ST HIGH VALUE IS | 0.06928c     | ON 87041024: AT (  | 3630.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |
| 97/50    | HIGH | 1ST HIGH VALUE IS | 0.11768c     | ON 87041024: AT (  | 2640.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |
| 97/75    | HIGH | 1ST HIGH VALUE IS | 0.09721      | ON 87042424: AT (  | 2970.00, | 330.00,                | 0.00,   | 0.00)              | DC | NA |
| 97F      | HIGH | 1ST HIGH VALUE IS | 0.07419c     | ON 87041024: AT (  | 3300.00, | -330.00,               | 0.00,   | 0.00)              | DC | NA |

\*\*\* ISCST3 - VERSION 99155 \*\*\* \*\*\* cooling tower Marley data stak=150ft cart grid 9/8/00 1987 Tampa \*\*\*

BEE-Line ISCST3 "BEEST" Version 6.71

Input File - O:\AIR\_ENG\PROJECTS\pineypt\ct87.DTA  
 Output File - O:\AIR\_ENG\PROJECTS\pineypt\ct87.LST  
 Met File - O:\AIR\_ENG\PROJECTS\pineypt\met\12842-87.OUT

Number of sources - 6  
 Number of source groups - 3  
 Number of receptors - 3520

\*\*\* POINT SOURCE DATA \*\*\*

| SOURCE ID | NUMBER PART. CATS. | EMISSION RATE (GRAMS/SEC) | X (METERS) | Y (METERS) | BASE ELEV. (METERS) | STACK HEIGHT (METERS) | STACK TEMP. (DEG.K) | STACK EXIT VEL. (M/SEC) | STACK DIAMETER (METERS) | BUILDING EXISTS | EMISSION RATE SCALAR VARY BY |
|-----------|--------------------|---------------------------|------------|------------|---------------------|-----------------------|---------------------|-------------------------|-------------------------|-----------------|------------------------------|
| 25/50A    | 0                  | 0.56700E+01               | 0.0        | 0.0        | 0.0                 | 45.72                 | 397.04              | 14.20                   | 5.64                    | YES             |                              |
| CELL1     | 0                  | 0.20000E-01               | 13.4       | -21.2      | 0.0                 | 17.83                 | 310.93              | 11.57                   | 8.50                    | YES             |                              |
| CELL2     | 0                  | 0.20000E-01               | 28.6       | -21.2      | 0.0                 | 17.83                 | 310.93              | 11.57                   | 8.50                    | YES             |                              |
| CELL3     | 0                  | 0.20000E-01               | 43.9       | -21.2      | 0.0                 | 17.83                 | 310.93              | 11.57                   | 8.50                    | YES             |                              |
| CELL4     | 0                  | 0.20000E-01               | 59.1       | -21.2      | 0.0                 | 17.83                 | 310.93              | 11.57                   | 8.50                    | YES             |                              |
| CELL5     | 0                  | 0.20000E-01               | 74.4       | -21.2      | 0.0                 | 17.83                 | 310.93              | 11.57                   | 8.50                    | YES             |                              |

\*\*\* SOURCE IDs DEFINING SOURCE GROUPS \*\*\*

| GROUP ID | SOURCE IDs                                       |
|----------|--|
| ALL      | 25/50A , CELL1 , CELL2 , CELL3 , CELL4 , CELL5 , |
| CELLS1_5 | CELL1 , CELL2 , CELL3 , CELL4 , CELL5 ,          |
| STAX     | 25/50A ,   |

\*\*\* THE SUMMARY OF MAXIMUM ANNUAL ( 1 YRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3 \*\*

| GROUP ID |                       | AVERAGE CONC | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE | NETWORK GRID-ID   |
|----------|-----------------------|--------------|----------|------------------------|---------|-------------------|
| ALL      | 1ST HIGHEST VALUE IS  | 0.06607 AT ( | 2313.43, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 2ND HIGHEST VALUE IS  | 0.06604 AT ( | 2414.02, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 3RD HIGHEST VALUE IS  | 0.06587 AT ( | 2212.85, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 4TH HIGHEST VALUE IS  | 0.06581 AT ( | 2514.60, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 5TH HIGHEST VALUE IS  | 0.06540 AT ( | 2112.26, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 6TH HIGHEST VALUE IS  | 0.06533 AT ( | 2313.43, | 100.58,                | 0.00,   | 0.00) DC NA       |
|          | 7TH HIGHEST VALUE IS  | 0.06528 AT ( | 2414.02, | 100.58,                | 0.00,   | 0.00) DC NA       |
|          | 8TH HIGHEST VALUE IS  | 0.06527 AT ( | 2414.02, | -100.58,               | 0.00,   | 0.00) DC NA       |
|          | 9TH HIGHEST VALUE IS  | 0.06517 AT ( | 2313.43, | -100.58,               | 0.00,   | 0.00) DC NA       |
|          | 10TH HIGHEST VALUE IS | 0.06515 AT ( | 2212.85, | 100.58,                | 0.00,   | 0.00) DC NA       |
| CELLS1_5 | 1ST HIGHEST VALUE IS  | 0.04671 AT ( | 121.92,  | -76.20,                | 0.00,   | 0.00) DC NA       |
|          | 2ND HIGHEST VALUE IS  | 0.04591 AT ( | 105.16,  | -76.20,                | 0.00,   | 0.00) DC NA       |
|          | 3RD HIGHEST VALUE IS  | 0.04558 AT ( | 137.16,  | -76.20,                | 0.00,   | 0.00) DC NA       |
|          | 4TH HIGHEST VALUE IS  | 0.04268 AT ( | 137.16,  | -60.96,                | 0.00,   | 0.00) DC NA       |
|          | 5TH HIGHEST VALUE IS  | 0.03802 AT ( | 152.40,  | -76.20,                | 0.00,   | 0.00) DC NA       |
|          | 6TH HIGHEST VALUE IS  | 0.03693 AT ( | 137.16,  | -91.44,                | 0.00,   | 0.00) DC NA       |
|          | 7TH HIGHEST VALUE IS  | 0.03659 AT ( | 152.40,  | -91.44,                | 0.00,   | 0.00) DC NA       |
|          | 8TH HIGHEST VALUE IS  | 0.03587 AT ( | 121.92,  | -91.44,                | 0.00,   | 0.00) DC NA       |
|          | 9TH HIGHEST VALUE IS  | 0.03575 AT ( | 121.92,  | -60.96,                | 0.00,   | 0.00) DC NA       |
|          | 10TH HIGHEST VALUE IS | 0.03418 AT ( | 105.16,  | -91.44,                | 0.00,   | 0.00) DC NA       |
| STAX     | 1ST HIGHEST VALUE IS  | 0.06195 AT ( | 2414.02, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 2ND HIGHEST VALUE IS  | 0.06188 AT ( | 2514.60, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 3RD HIGHEST VALUE IS  | 0.06181 AT ( | 2313.43, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 4TH HIGHEST VALUE IS  | 0.06142 AT ( | 2212.85, | 0.00,                  | 0.00,   | 0.00) DC NA       |
|          | 5TH HIGHEST VALUE IS  | 0.06136 AT ( | 2414.02, | 100.58,                | 0.00,   | 0.00) DC NA       |
|          | 6TH HIGHEST VALUE IS  | 0.06127 AT ( | 2514.60, | 100.58,                | 0.00,   | 0.00) DC NA       |
|          | 7TH HIGHEST VALUE IS  | 0.06124 AT ( | 2313.43, | 100.58,                | 0.00,   | 0.00) DC NA       |
|          | 8TH HIGHEST VALUE IS  | 0.06114 AT ( | 2514.60, | -100.58,               | 0.00,   | 0.00) DC NA       |
|          | 9TH HIGHEST VALUE IS  | 0.06113 AT ( | 2743.20, | 0.00,                  | 0.00,   | 0.00) GP FARFIELD |
|          | 10TH HIGHEST VALUE IS | 0.06113 AT ( | 2743.20, | 0.00,                  | 0.00,   | 0.00) GP FARFIELD |

\*\*\* THE SUMMARY OF HIGHEST 24-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN MICROGRAMS/M\*\*3

\*\*

| GROUP ID |                        | AVERAGE CONC | DATE (YMMDDHH) | RECEPTOR | (XR, YR, ZELEV, ZFLAG) | OF TYPE  | NETWORK GRID-ID |             |
|----------|------------------------|--------------|----------------|----------|------------------------|----------|-----------------|-------------|
| ALL      | HIGH 1ST HIGH VALUE IS | 2.67234      | ON 87033124:   | AT (     | 121.92,                | -76.20,  | 0.00,           | 0.00) DC NA |
|          | HIGH 2ND HIGH VALUE IS | 1.58206      | ON 87120424:   | AT (     | 137.16,                | -76.20,  | 0.00,           | 0.00) DC NA |
| CELLS1_5 | HIGH 1ST HIGH VALUE IS | 2.26030      | ON 87033124:   | AT (     | 121.92,                | -76.20,  | 0.00,           | 0.00) DC NA |
|          | HIGH 2ND HIGH VALUE IS | 1.57666      | ON 87120424:   | AT (     | 137.16,                | -76.20,  | 0.00,           | 0.00) DC NA |
| STAX     | HIGH 1ST HIGH VALUE IS | 0.64297c     | ON 87041024:   | AT (     | 2514.60,               | -301.75, | 0.00,           | 0.00) DC NA |

HIGH 2ND HIGH VALUE IS 0.60504 ON 87042424: AT ( 2414.02, 301.75, 0.00, 0.00) DC NA

**Appendix D-4**



**Gulfcoast - Single CT Firing Gas (150-foot stack)**

| <b>1-hour</b>             | <b>UNIT IMPACT (ug/m3)</b> |             |             |             |             |            | <b>CO</b>               |                                  |
|---------------------------|----------------------------|-------------|-------------|-------------|-------------|------------|-------------------------|----------------------------------|
| <b>Operating Scenario</b> | <b>1987</b>                | <b>1988</b> | <b>1989</b> | <b>1990</b> | <b>1991</b> | <b>MAX</b> | <b>Emissions(lb/hr)</b> | <b>Impact (ug/m<sup>3</sup>)</b> |
| 25/50                     | 2.67856                    | 3.13364     | 2.24116     | 3.15833     | 2.95004     | 3.16       | 20.0                    | 7.96                             |
| 25/75                     | 1.81547                    | 2.17883     | 1.53633     | 2.19053     | 2.07994     | 2.19       | 25.0                    | 6.90                             |
| 25F                       | 1.07978                    | 0.93656     | 0.86144     | 0.85568     | 1.35653     | 1.36       | 31.0                    | 5.30                             |
| 59FE*                     | 1.08383                    | 0.93938     | 0.90042     | 0.85777     | 1.37502     | 1.38       | 29.0                    | 5.02                             |
| 59F                       | 1.08479                    | 0.93964     | 0.90038     | 0.85806     | 1.44937     | 1.45       | 29.0                    | 5.30                             |
| 72F                       | 1.08909                    | 1.26011     | 0.90032     | 0.85995     | 1.51772     | 1.52       | 19.0                    | 3.63                             |
| 72FE*                     | 1.0892                     | 0.94257     | 0.90032     | 0.86146     | 1.44508     | 1.45       | 19.0                    | 3.46                             |
| 97/50                     | 2.78041                    | 5.09782     | 2.30172     | 3.26775     | 3.03449     | 5.10       | 28.0                    | 17.99                            |
| 97/75                     | 2.05733                    | 2.43932     | 1.71801     | 2.41534     | 2.29886     | 2.44       | 18.0                    | 5.53                             |
| 97F                       | 1.09708                    | 1.36869     | 0.90047     | 1.08846     | 1.63037     | 1.63       | 21.0                    | 4.31                             |
| 97FE*                     | 1.09825                    | 1.32409     | 0.90547     | 1.08846     | 1.5831      | 1.58       | 21.0                    | 4.19                             |
|                           |                            |             |             |             |             |            | <b>Maximum</b>          | <b>17.99</b>                     |
|                           |                            |             |             |             |             |            |                         |                                  |
| <b>8-hour</b>             | <b>UNIT IMPACT (ug/m3)</b> |             |             |             |             |            | <b>CO</b>               |                                  |
| <b>Operating Scenario</b> | <b>1987</b>                | <b>1988</b> | <b>1989</b> | <b>1990</b> | <b>1991</b> | <b>MAX</b> | <b>Emissions(lb/hr)</b> | <b>Impact (ug/m<sup>3</sup>)</b> |
| 25/50                     | 0.86893                    | 1.04087     | 0.61122     | 0.58916     | 1.10792     | 1.11       | 20.0                    | 2.79                             |
| 25/75                     | 0.42059                    | 0.43708     | 0.51354     | 0.48789     | 0.78026     | 0.78       | 25.0                    | 2.46                             |
| 25F                       | 0.32436                    | 0.30325     | 0.38176     | 0.35831     | 0.30406     | 0.38       | 31.0                    | 1.49                             |
| 59FE*                     | 0.32849                    | 0.30975     | 0.38993     | 0.36633     | 0.31229     | 0.39       | 29.0                    | 1.42                             |
| 59F                       | 0.3298                     | 0.31039     | 0.39063     | 0.36694     | 0.31356     | 0.39       | 29.0                    | 1.43                             |
| 72F                       | 0.33421                    | 0.31628     | 0.39793     | 0.37405     | 0.32135     | 0.40       | 19.0                    | 0.95                             |
| 72FE*                     | 0.33393                    | 0.31732     | 0.39933     | 0.37551     | 0.3222      | 0.40       | 19.0                    | 0.96                             |
| 97/50                     | 0.90652                    | 1.08422     | 0.63099     | 0.62981     | 1.13797     | 1.14       | 28.0                    | 4.01                             |
| 97/75                     | 0.42482                    | 0.78649     | 0.5187      | 0.49275     | 0.86719     | 0.87       | 18.0                    | 1.97                             |
| 97F                       | 0.34192                    | 0.32669     | 0.41077     | 0.38658     | 0.33508     | 0.41       | 21.0                    | 1.09                             |
| 97FE*                     | 0.34268                    | 0.32891     | 0.41358     | 0.38963     | 0.33757     | 0.41       | 21.0                    | 1.09                             |
|                           |                            |             |             |             |             |            | <b>Maximum</b>          | <b>4.01</b>                      |
|                           |                            |             |             |             |             |            |                         |                                  |

**Gulfoast - Single CT Firing Natural Gas (150-foot stack)**

| Annual Average | UNIT IMPACT (ug/m3) |         |         |         |         |         | Emission Rate (lb/hr) |      |     | Gas-Fired Impact (ug/m3) |       |       | Combined Impact (ug/m3) |       |       |       |
|----------------|---------------------|---------|---------|---------|---------|---------|-----------------------|------|-----|--------------------------|-------|-------|-------------------------|-------|-------|-------|
|                | 1987                | 1988    | 1989    | 1990    | 1991    | MAX     | NOX                   | PM10 | SO2 | NOX                      | PM10  | SO2   | NOX                     | PM10  | SO2   |       |
| 25/50          | 0.0214              | 0.01483 | 0.0209  | 0.02054 | 0.01745 | 0.0214  | 15.2                  | 19   | 7   | 0.04                     | 0.05  | 0.02  | 0.043                   | 0.053 | 0.023 |       |
| 25/75          | 0.01684             | 0.01169 | 0.01623 | 0.01622 | 0.01377 | 0.01684 | 19.1                  | 19   | 8   | 0.04                     | 0.04  | 0.02  | 0.043                   | 0.043 | 0.021 |       |
| 25F            | 0.01188             | 0.00847 | 0.01131 | 0.01137 | 0.0097  | 0.01188 | 24.1                  | 20   | 10  | 0.04                     | 0.03  | 0.01  | 0.039                   | 0.033 | 0.019 |       |
| 59FE*          | 0.01217             | 0.00864 | 0.0116  | 0.01165 | 0.00993 | 0.01217 | 22.6                  | 20   | 10  | 0.03                     | 0.03  | 0.02  | 0.037                   | 0.034 | 0.020 |       |
| 59F            | 0.01223             | 0.00873 | 0.01166 | 0.01168 | 0.00998 | 0.01223 | 22.6                  | 20   | 10  | 0.03                     | 0.03  | 0.02  | 0.038                   | 0.034 | 0.020 |       |
| 72F            | 0.01252             | 0.00897 | 0.01195 | 0.01196 | 0.01021 | 0.01252 | 21.8                  | 20   | 9   | 0.03                     | 0.03  | 0.01  | 0.037                   | 0.034 | 0.019 |       |
| 72FE*          | 0.01252             | 0.00888 | 0.01197 | 0.012   | 0.01023 | 0.01252 | 21.8                  | 20   | 9   | 0.03                     | 0.03  | 0.01  | 0.037                   | 0.034 | 0.019 |       |
| 97/50          | 0.02065             | 0.0145  | 0.02013 | 0.01977 | 0.01685 | 0.02065 | 13.2                  | 19   | 6   | 0.03                     | 0.05  | 0.02  | 0.037                   | 0.051 | 0.020 |       |
| 97/75          | 0.01723             | 0.01198 | 0.01652 | 0.01644 | 0.01403 | 0.01723 | 16.7                  | 19   | 7   | 0.04                     | 0.04  | 0.02  | 0.039                   | 0.043 | 0.019 |       |
| 97F            | 0.01302             | 0.00931 | 0.01248 | 0.01249 | 0.01068 | 0.01302 | 20.2                  | 20   | 9   | 0.03                     | 0.03  | 0.01  | 0.036                   | 0.036 | 0.019 |       |
| 97FE*          | 0.0131              | 0.00933 | 0.01256 | 0.01259 | 0.01074 | 0.0131  | 20.2                  | 20   | 9   | 0.03                     | 0.03  | 0.01  | 0.036                   | 0.036 | 0.019 |       |
|                |                     |         |         |         |         |         |                       |      |     |                          |       |       |                         |       |       |       |
|                |                     |         |         |         |         |         |                       |      |     | Maximum                  | 0.041 | 0.051 | 0.019                   | 0.043 | 0.053 | 0.023 |

| 3-Hour<br>Operating Scenario | UNIT IMPACT (ug/m3) |         |         |         |         |         | SO2               |                |
|------------------------------|---------------------|---------|---------|---------|---------|---------|-------------------|----------------|
|                              | 1987                | 1988    | 1989    | 1990    | 1991    | MAX     | Emissions (lb/hr) | Impact (ug/m3) |
| 25/50                        | 1.60643             | 2.45398 | 1.06803 | 1.05411 | 1.79223 | 2.45398 | 7                 | 2.16           |
| 25/75                        | 0.70226             | 1.16554 | 0.75043 | 0.73018 | 1.27315 | 1.27315 | 8                 | 1.28           |
| 25F                          | 0.53377             | 0.52203 | 0.48715 | 0.51849 | 0.50386 | 0.53377 | 10                | 0.67           |
| 59FE*                        | 0.54451             | 0.53935 | 0.49781 | 0.52917 | 0.51729 | 0.54451 | 10                | 0.69           |
| 59F                          | 0.54507             | 0.53993 | 0.49852 | 0.53006 | 0.51752 | 0.54507 | 10                | 0.69           |
| 72F                          | 0.55437             | 0.55491 | 0.50787 | 0.54314 | 0.52893 | 0.55491 | 9                 | 0.63           |
| 72FE*                        | 0.55656             | 0.55888 | 0.50989 | 0.5456  | 0.53222 | 0.55888 | 9                 | 0.63           |
| 97/50                        | 1.6819              | 2.55479 | 1.10374 | 1.18048 | 1.83672 | 2.55479 | 6                 | 1.93           |
| 97/75                        | 0.88916             | 1.85433 | 0.76315 | 0.80511 | 1.40867 | 1.85433 | 7                 | 1.64           |
| 97F                          | 0.57182             | 0.58177 | 0.53643 | 0.56645 | 0.54932 | 0.58177 | 9                 | 0.66           |
| 97FE*                        | 0.57657             | 0.58859 | 0.54256 | 0.57153 | 0.55471 | 0.58859 | 9                 | 0.67           |
|                              |                     |         |         |         |         |         | Maximum           | 2.16           |

| 24-Hour<br>Operating Scenario | UNIT IMPACT (ug/m3) |         |         |         |         |         | Emissions (lb/hr) |      | Impact (ug/m3) |      |      |
|-------------------------------|---------------------|---------|---------|---------|---------|---------|-------------------|------|----------------|------|------|
|                               | 1987                | 1988    | 1989    | 1990    | 1991    | MAX     | SO2               | PM10 | SO2            | PM10 |      |
| 25/50                         | 0.28964             | 0.48044 | 0.26693 | 0.23332 | 0.51222 | 0.51222 | 7                 | 19   | 0.45           | 1.23 |      |
| 25/75                         | 0.16645             | 0.15203 | 0.21104 | 0.18143 | 0.26009 | 0.26009 | 8                 | 19   | 0.26           | 0.62 |      |
| 25F                           | 0.1192              | 0.1076  | 0.1465  | 0.12993 | 0.13391 | 0.1465  | 10                | 20   | 0.18           | 0.37 |      |
| 59FE*                         | 0.12164             | 0.11038 | 0.14996 | 0.1325  | 0.137   | 0.14996 | 10                | 20   | 0.19           | 0.38 |      |
| 59F                           | 0.12272             | 0.11099 | 0.15016 | 0.13254 | 0.13721 | 0.15016 | 10                | 20   | 0.19           | 0.38 |      |
| 72F                           | 0.12551             | 0.11376 | 0.15389 | 0.13471 | 0.13995 | 0.15389 | 9                 | 20   | 0.17           | 0.39 |      |
| 72FE*                         | 0.12504             | 0.11387 | 0.15439 | 0.13535 | 0.14055 | 0.15439 | 9                 | 20   | 0.18           | 0.39 |      |
| 97/50                         | 0.30217             | 0.50222 | 0.2583  | 0.22364 | 0.52829 | 0.52829 | 6                 | 19   | 0.40           | 1.26 |      |
| 97/75                         | 0.17055             | 0.27356 | 0.21425 | 0.18382 | 0.3309  | 0.3309  | 7                 | 19   | 0.29           | 0.79 |      |
| 97F                           | 0.13035             | 0.11865 | 0.16079 | 0.13902 | 0.14483 | 0.16079 | 9                 | 20   | 0.18           | 0.41 |      |
| 97FE*                         | 0.13058             | 0.11938 | 0.16213 | 0.14018 | 0.14596 | 0.16213 | 9                 | 20   | 0.18           | 0.41 |      |
|                               |                     |         |         |         |         |         |                   |      | Maximum        | 0.45 | 1.26 |

Gulfcoast - Single CT Firing Oil (150-foot stack)

| 1-hour<br>Operating Scenario | UNIT IMPACT (ug/m3) |         |         |         |         |      | CO                |                             |
|------------------------------|---------------------|---------|---------|---------|---------|------|-------------------|-----------------------------|
|                              | 1987                | 1988    | 1989    | 1990    | 1991    | MAX  | Emissions (lb/hr) | Impact (ug/m <sup>3</sup> ) |
| 25/50                        | 1.48293             | 2.01041 | 1.18874 | 1.73531 | 1.71884 | 2.01 | 65.0              | 16.47                       |
| 25/75                        | 0.7294              | 0.97782 | 0.75699 | 0.82519 | 1.22706 | 1.23 | 58.0              | 8.97                        |
| 25F                          | 0.59668             | 0.65964 | 0.62512 | 0.7999  | 0.69993 | 0.80 | 70.0              | 7.06                        |
| 59F                          | 0.60294             | 0.66617 | 0.63133 | 0.80445 | 0.70528 | 0.80 | 66.0              | 6.69                        |
| 72/50                        | 1.54803             | 2.07195 | 1.23901 | 1.80037 | 2.03176 | 2.07 | 73.0              | 19.06                       |
| 72/75                        | 0.97919             | 1.19012 | 0.75993 | 1.2103  | 1.30741 | 1.31 | 52.0              | 8.57                        |
| 72F                          | 0.60714             | 0.66887 | 0.63392 | 0.80623 | 0.80587 | 0.81 | 63.0              | 6.40                        |
| 97/50                        | 1.66806             | 2.18042 | 1.32903 | 1.91583 | 2.15837 | 2.18 | 83.0              | 22.80                       |
| 97/75                        | 1.05073             | 1.27023 | 0.76207 | 1.28242 | 1.36427 | 1.36 | 51.0              | 8.77                        |
| 97F                          | 0.69077             | 0.76569 | 0.68676 | 0.81086 | 0.92283 | 0.92 | 58.0              | 6.74                        |
|                              |                     |         |         |         |         |      |                   |                             |
|                              |                     |         |         |         |         |      | Maximum           | 22.80                       |

| 8-hour<br>Operating Scenario | UNIT IMPACT (ug/m3) |         |         |         |         |      | CO                |                             |
|------------------------------|---------------------|---------|---------|---------|---------|------|-------------------|-----------------------------|
|                              | 1987                | 1988    | 1989    | 1990    | 1991    | MAX  | Emissions (lb/hr) | Impact (ug/m <sup>3</sup> ) |
| 25/50                        | 0.31015             | 0.55886 | 0.34353 | 0.32058 | 0.62185 | 0.62 | 65.0              | 5.09                        |
| 25/75                        | 0.20785             | 0.23134 | 0.27299 | 0.25265 | 0.22602 | 0.27 | 58.0              | 2.00                        |
| 25F                          | 0.14254             | 0.17019 | 0.18154 | 0.16808 | 0.1571  | 0.18 | 70.0              | 1.60                        |
| 59F                          | 0.16398             | 0.17969 | 0.19521 | 0.17893 | 0.16794 | 0.20 | 66.0              | 1.62                        |
| 72/50                        | 0.31373             | 0.58496 | 0.34997 | 0.32682 | 0.64627 | 0.65 | 73.0              | 5.94                        |
| 72/75                        | 0.21256             | 0.23531 | 0.279   | 0.25848 | 0.33007 | 0.33 | 52.0              | 2.16                        |
| 72F                          | 0.16657             | 0.18354 | 0.20131 | 0.184   | 0.17228 | 0.20 | 63.0              | 1.60                        |
| 97/50                        | 0.3184              | 0.63345 | 0.35787 | 0.33447 | 0.69007 | 0.69 | 83.0              | 7.22                        |
| 97/75                        | 0.28404             | 0.23816 | 0.28338 | 0.26265 | 0.35036 | 0.35 | 51.0              | 2.25                        |
| 97F                          | 0.1737              | 0.19385 | 0.21762 | 0.19934 | 0.18373 | 0.22 | 58.0              | 1.59                        |
|                              |                     |         |         |         |         |      |                   |                             |
|                              |                     |         |         |         |         |      | Maximum           | 7.22                        |

**Gulfcoast - Single CT Firing Oil (150-foot stack)**

| Annual Average | UNIT IMPACT (ug/m3) |         |         |         |         |         | Emission Rate (lb/hr) |      |         | Oil-Fired Impact (ug/m3) |      |      |
|----------------|---------------------|---------|---------|---------|---------|---------|-----------------------|------|---------|--------------------------|------|------|
|                | 1987                | 1988    | 1989    | 1990    | 1991    | MAX     | NOX                   | PM10 | SO2     | NOX                      | PM10 | SO2  |
| 25/50          | 0.01081             | 0.00792 | 0.01031 | 0.01019 | 0.00874 | 0.01081 | 49.5                  | 46.0 | 63.0    | 0.07                     | 0.06 | 0.09 |
| 25/75          | 0.00843             | 0.00626 | 0.0082  | 0.00805 | 0.00704 | 0.00843 | 63.8                  | 49.0 | 80.0    | 0.07                     | 0.05 | 0.08 |
| 25F            | 0.00555             | 0.00431 | 0.00544 | 0.00537 | 0.00482 | 0.00555 | 80.0                  | 53.0 | 99.0    | 0.06                     | 0.04 | 0.07 |
| 59F            | 0.00598             | 0.00466 | 0.00588 | 0.00579 | 0.00524 | 0.00598 | 75.7                  | 52.0 | 94.0    | 0.06                     | 0.04 | 0.07 |
| 72/50          | 0.01104             | 0.00813 | 0.01056 | 0.0104  | 0.00894 | 0.01104 | 46.0                  | 45.0 | 58.0    | 0.06                     | 0.06 | 0.08 |
| 72/75          | 0.00866             | 0.0064  | 0.00837 | 0.00823 | 0.00719 | 0.00866 | 58.8                  | 48.0 | 74.0    | 0.06                     | 0.05 | 0.08 |
| 72F            | 0.00625             | 0.0048  | 0.00609 | 0.00595 | 0.00537 | 0.00625 | 73.6                  | 51.0 | 92.0    | 0.06                     | 0.04 | 0.07 |
| 97/50          | 0.01134             | 0.00835 | 0.01088 | 0.01067 | 0.00917 | 0.01134 | 42.4                  | 44.0 | 54.0    | 0.06                     | 0.06 | 0.08 |
| 97/75          | 0.00886             | 0.00651 | 0.00852 | 0.00835 | 0.0073  | 0.00886 | 54.5                  | 47.0 | 69.0    | 0.06                     | 0.05 | 0.08 |
| 97F            | 0.00673             | 0.00512 | 0.00654 | 0.00639 | 0.00577 | 0.00673 | 67.6                  | 50.0 | 84.0    | 0.06                     | 0.04 | 0.07 |
|                |                     |         |         |         |         |         |                       |      |         |                          |      |      |
|                |                     |         |         |         |         |         |                       |      | Maximum | 0.07                     | 0.06 | 0.09 |

| 3-Hour<br>Operating Scenario | UNIT IMPACT (ug/m3) |         |         |         |         |         | SO2               |                |
|------------------------------|---------------------|---------|---------|---------|---------|---------|-------------------|----------------|
|                              | 1987                | 1988    | 1989    | 1990    | 1991    | MAX     | Emissions (lb/hr) | Impact (ug/m3) |
| 25/50                        | 0.60864             | 1.31444 | 0.43603 | 0.57844 | 1.01809 | 1.31444 | 63.0              | 10.43          |
| 25/75                        | 0.3878              | 0.36331 | 0.38202 | 0.37396 | 0.40902 | 0.40902 | 80.0              | 4.12           |
| 25F                          | 0.26164             | 0.26429 | 0.33507 | 0.26822 | 0.30662 | 0.33507 | 99.0              | 4.18           |
| 59F                          | 0.29295             | 0.2808  | 0.33794 | 0.33684 | 0.31031 | 0.33794 | 94.0              | 4.00           |
| 72/50                        | 0.63712             | 1.37571 | 0.44444 | 0.60012 | 1.05721 | 1.37571 | 58.0              | 10.05          |
| 72/75                        | 0.39477             | 0.39784 | 0.38363 | 0.40343 | 0.7057  | 0.7057  | 74.0              | 6.58           |
| 72F                          | 0.29465             | 0.28734 | 0.33906 | 0.33827 | 0.31178 | 0.33906 | 92.0              | 3.93           |
| 97/50                        | 0.68915             | 1.48933 | 0.62208 | 0.64188 | 1.12735 | 1.48933 | 54.0              | 10.13          |
| 97/75                        | 0.40051             | 0.4246  | 0.38483 | 0.42747 | 0.74902 | 0.74902 | 69.0              | 6.51           |
| 97F                          | 0.31065             | 0.30443 | 0.34348 | 0.34382 | 0.3168  | 0.34382 | 84.0              | 3.64           |
|                              |                     |         |         |         |         |         |                   |                |
|                              |                     |         |         |         |         |         | Maximum           | 10.43          |

| 24-Hour<br>Operating Scenario | UNIT IMPACT (ug/m3) |         |         |         |         |         | Emissions (lb/hr) |         | Impact (ug/m3) |      |
|-------------------------------|---------------------|---------|---------|---------|---------|---------|-------------------|---------|----------------|------|
|                               | 1987                | 1988    | 1989    | 1990    | 1991    | MAX     | SO2               | PM10    | SO2            | PM10 |
| 25/50                         | 0.11272             | 0.19439 | 0.13952 | 0.1171  | 0.23687 | 0.23687 | 63.0              | 46.0    | 1.88           | 1.37 |
| 25/75                         | 0.09112             | 0.07756 | 0.10612 | 0.09648 | 0.09461 | 0.10612 | 80.0              | 49.0    | 1.07           | 0.66 |
| 25F                           | 0.06321             | 0.05976 | 0.07494 | 0.06786 | 0.06653 | 0.07494 | 99.0              | 53.0    | 0.93           | 0.50 |
| 59F                           | 0.06753             | 0.06129 | 0.07801 | 0.07225 | 0.07073 | 0.07801 | 94.0              | 52.0    | 0.92           | 0.51 |
| 72/50                         | 0.1147              | 0.20346 | 0.14141 | 0.11903 | 0.24632 | 0.24632 | 58.0              | 45.0    | 1.80           | 1.40 |
| 72/75                         | 0.09331             | 0.07936 | 0.10832 | 0.09809 | 0.11002 | 0.11002 | 74.0              | 48.0    | 1.03           | 0.67 |
| 72F                           | 0.06928             | 0.06196 | 0.07933 | 0.07402 | 0.07258 | 0.07933 | 92.0              | 51.0    | 0.92           | 0.51 |
| 97/50                         | 0.11768             | 0.25695 | 0.14397 | 0.12136 | 0.29841 | 0.29841 | 54.0              | 44.0    | 2.03           | 1.65 |
| 97/75                         | 0.09721             | 0.08064 | 0.1099  | 0.09924 | 0.11679 | 0.11679 | 69.0              | 47.0    | 1.02           | 0.69 |
| 97F                           | 0.07419             | 0.06481 | 0.08483 | 0.07873 | 0.07747 | 0.08483 | 84.0              | 50.0    | 0.90           | 0.53 |
|                               |                     |         |         |         |         |         |                   |         |                |      |
|                               |                     |         |         |         |         |         |                   | Maximum | 2.03           | 1.65 |

Appendix D-5

| <b>Date</b>        | <b>CALPUFF 24-hr<br/>SO<sub>4</sub><br/>concentration<br/>(ug/m<sup>3</sup>)</b> | <b>CALPUFF 24-hr<br/>NO<sub>3</sub><br/>concentration<sup>a</sup><br/>(ug/m<sup>3</sup>)</b> | <b>CALPUFF 24-hr<br/>PM<sub>10</sub><br/>concentration<br/>(ug/m<sup>3</sup>)</b> | <b>24-hr (NH<sub>4</sub>)<sub>2</sub>SO<sub>4</sub><br/>concentration<br/>(ug/m<sup>3</sup>) {SO<sub>4</sub>]<br/>* 1.375}</b> | <b>24-hr NH<sub>4</sub>NO<sub>3</sub><br/>concentration<br/>(ug/m<sup>3</sup>) {NO<sub>3</sub>]<br/>* 1.29}</b> | <b>Relative<br/>Humidity</b> | <b>RH factor<br/>(from<br/>IWAQM<br/>Figure B-1)</b> |
|--------------------|--|--|---|--|---|------------------------------|--|
| Overall Worst-Case | 0.004  | 0.025  | 0.053   | 0.005  | 0.032   | 90.0                         | 6.00   |

| <b>Sulfate Extinction<br/>Coefficient {0.003 *<br/>RH factor *<br/>[(NH<sub>4</sub>)<sub>2</sub>SO<sub>4</sub>]</b> | <b>Nitrate Extinction<br/>Coefficient {0.003<br/>* RH factor *<br/>[NH<sub>4</sub>NO<sub>3</sub>]</b> | <b>PM<sub>10</sub> Extinction<br/>Coefficient {0.01 *<br/>[PM<sub>10</sub>]</b> | <b>Extinction<br/>Coefficient Sum<br/>(bexts)</b> | <b>Background<br/>Extinction (bext)<br/>{3.912 / BVR (65<br/>km)}</b> | <b>% Change</b> |
|---|---|---|---|---|-----------------|
| 8.91E-05  | 5.81E-04  | 5.28E-04  | 1.20E-03  | 6.02E-02  | 1.99%           |

<sup>a</sup>As per FLM, NO<sub>3</sub> concentration is equivalent to the sum of NO<sub>3</sub> and HNO<sub>3</sub> concentrations.

Appendix D-6

APPENDIX E  
CONTROL TECHNOLOGY REVIEW



Appendix E-1

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - NOx**

| FACILITY  | CITY                        | STATE | PERMIT     | PROCESS  | MW   | PPM* | CTRLDESC  | BASIS      |
|---|-----------------------------|-------|------------|--|------|------|---|------------|
| CITY OF ANAHEIM GAS TURBINE PROJECT               |                             | CA    | 09/15/1989 | TURBINE, GAS, GE PGLM 5000                     | 55   | 2.3  | SCR, STEAM INJECTION, CO REACTOR                          | BACT-PSD   |
| DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION | LOWESVILLE                  | NC    | 12/20/1991 | TURBINE, COMBUSTION                            | 164  | 2.5  | COMBUSTION CONTROL  | BACT-PSD   |
| GORHAM ENERGY LIMITED PARTNERSHIP                 | GORHAM                      | ME    | 12/04/1998 | TURBINE, COMBINED CYCLE                        | 900  | 2.5  | SELECTIVE CATALYTIC REDUCTION. EMISSION IS FROM           | LAER       |
| UNION OIL CO.                                     | RODEO                       | CA    | 03/03/1986 | TURBINE, GAS & DUCT BURNER                     | 54   | 2.5  | SCR, STEAM INJECTION                                      | BACT-PSD   |
| WESTBROOK POWER LLC                               | WESTBROOK                   | ME    | 12/04/1998 | TURBINE, COMBINED CYCLE, TWO                   | 528  | 2.5  | SELECTIVE CATALYTIC REDUCTION AND DRY LOW NOX BUR- NER    | LAER       |
| SEPCO   | RIO LINDA                   | CA    | 10/05/1994 | TURBINE, GAS COMBINED CYCLE GE MODEL 7         | 115  | 2.6  | SELECTIVE CATALYTIC REDUCTION AND DRY LOW NOX COMBU       | BACT       |
| SACRAMENTO COGENERATION AUTHORITY P&G             | SACRAMENTO                  | CA    | 08/19/1994 | TURBINE, GAS, COMBINED CYCLE LM6000            | 53   | 3.0  | SELECTIVE CATALYTIC REDUCTION AND WATER INJECTION         | BACT       |
| SACRAMENTO POWER AUTHORITY CAMPBELL SOUP          | SACRAMENTO                  | CA    | 08/19/1994 | TURBINE GAS, COMBINE CYCLE SIEMENS V84.2       | 157  | 3.0  | SELECTIVE CATALYTIC REDUCTION AND DRY LOW NOX COMBU       | BACT       |
| SACRAMENTO POWER AUTHORITY CAMPBELL SOUP          | SACRAMENTO                  | CA    | 08/19/1994 | TURBINE, GAS, COMBINED CYCLE, SIEMENS V84.2    | 157  | 3.0  | SELECTIVE CATALYTIC REDUCTION AND DRY LOW NOX CO MBUS     | BACT       |
| BERKSHIRE POWER DEVELOPMENT, INC.                 | AGAWAM                      | MA    | 09/22/1997 | TURBINE, COMBUSTION, ABB GT24                  | 224  | 3.1  | DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD-ON NO      | BACT-PSD   |
| DIGHTON POWER ASSOCIATE, LP                       | DIGHTON                     | MA    | 10/06/1997 | TURBINE, COMBUSTION, ABB GT11N2                | 166  | 3.5  | DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD-ON NO      | BACT-PSD   |
| BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.     | NEW YORK CITY               | NY    | 06/06/1995 | TURBINE, NATURAL GAS FIRED                     | 240  | 3.5  | SCR   | LAER       |
| CASCO RAY ENERGY CO                               | VEAZIE                      | ME    | 07/13/1998 | TURBINE, COMBINED CYCLE, NATURAL GAS, TWO      | 170  | 3.5  | SELECTIVE CATALYTIC REDUCTION                             | BACT-PSD   |
| GRANITE ROAD LIMITED                              |                             | CA    | 05/06/1991 | TURBINE, GAS, ELECTRIC GENERATION              | 58   | 3.5  | SCR, STEAM INJECTION                                      | BACT-PSD   |
| MILLENNIUM POWER PARTNER, LP                      | CHARLTON                    | MA    | 02/02/1998 | TURBINE, COMBUSTION, WESTINGHOUSE MODEL 50     | 317  | 3.5  | DRY LOW NOX COMBUSTION TECHNOLOGY IN CONJUNCTION WITH     | BACT-PSD   |
| NEWARK BAY COGENERATION PARTNERSHIP, L.P.         | NEWARK                      | NJ    | 06/09/1993 | TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)    | 77   | 3.5  | SCR   | BACT-PSD   |
| RUMFORD POWER ASSOCIATES                          | RUMFORD                     | ME    | 05/01/1998 | TURBINE GENERATOR, COMBUSTION, NATURAL GAS     | 238  | 3.5  | SCR AMMONIA INJECTION SYSTEM AND CATALYTIC REACTOR TO F   | BACT-PSD   |
| TIVERTON POWER ASSOCIATES                         | TIVERTON                    | RI    | 02/13/1998 | COMBUSTION TURBINE, NATURAL GAS                | 265  | 3.5  | SCR   | LAER       |
| ALABAMA POWER COMPANY - THEODORE COGENERATION     | THEODORE                    | AL    | 03/16/1999 | 170 MW TURBINE W/ DUCT BURNER, HR BOILER, SCR  | 170  | 3.5  | DLN COMBUSTOR IN CT, LNB IN DUCT BURNER, SCR              | BACT-PSD   |
| ALABAMA POWER PLANT BARRY                         | BUCKS                       | AL    | 08/07/1998 | TURBINES, COMBUSTION, NATURAL GAS              | 510  | 3.5  | NATURAL GAS, CT-DLN COMBUSTORS, DUCTBURNER, LOW NOX       | BACT-PSD   |
| LSP-COTTAGE GROVE, L.P.                           | COTTAGE GROVE               | MN    | 03/01/1995 | COMBUSTION TURBINE/GENERATOR                   | 246  | 3.6  | FUEL SELECTION, GOOD COMBUSTION                           | BACT-PSD   |
| BADGER CREEK LIMITED                              |                             | CA    | 10/30/1989 | TURBINE, GAS COGENERATION                      | 57   | 3.7  | SCR, STEAM INJECTION                                      | BACT-PSD   |
| BLUE MOUNTAIN POWER, LP                           | RICHLAND                    | PA    | 07/31/1996 | COMBUSTION TURBINE WITH HEAT RECOVERY BOIL     | 153  | 4.0  | DRY LNB WITH SCR WATER INJECTION IN PLACE WHEN FIRING OIL | LAER       |
| EMPIRE DISTRICT ELECTRIC CO.                      | JOPLIN                      | MO    | 05/17/1994 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES          | 168  | 4.3  | NONE  | BACT-PSD   |
| ECOELECTRICA, L.P.                                | PENUELAS                    | PR    | 10/01/1996 | TURBINES, COMBINED-CYCLE COGENERATION          | 461  | 4.4  | STEAMWATER INJECTION AND SELECTIVE CATALYTIC REDUCTIO     | BACT-PSD   |
| HERMISTON GENERATING CO.                          | HERMISTON                   | OR    | 07/07/1994 | TURBINES, NATURAL GAS (2)                      | 212  | 4.5  | SCR   | BACT-PSD   |
| LSP - COTTAGE GROVE, L.P.                         | COTTAGE GROVE               | MN    | 11/10/1998 | GENERATOR, COMBUSTION TURBINE & DUCT BURNE     | 1988 | 4.5  | SELECTIVE CATALYTIC REDUCTION (SCR) WITH A NOX CEM AND A  | BACT-PSD   |
| PILGRIM ENERGY CENTER                             | ISLIP                       | NY    |            | (2) WESTINGHOUSE W50105 TURBINES (EP #S 00001  | 175  | 4.5  | STEAM INJECTION FOLLOWED BY SCR                           | BACT       |
| PORTLAND GENERAL ELECTRIC CO.                     | BOARDMAN                    | OR    | 05/31/1994 | TURBINES, NATURAL GAS (2)                      | 215  | 4.5  | SCR   | BACT-PSD   |
| SITHEINDEPENDENCE POWER PARTNERS                  | OSWEGO                      | NY    | 11/24/1992 | TURBINES, COMBUSTION (4) (NATURAL GAS) (1012 M | 267  | 4.5  | SCR AND DRY LOW NOX                                       | BACT-OTHER |
| SOUTHWESTERN PUBLIC SERVICE COMPANY/CUNNINGHAM S  | HOBBS                       | NM    | 02/15/1997 | COMBUSTION TURBINE, NATURAL GAS                | 100  | 4.5  | DRY LOW NOX COMBUSTION                                    | BACT-PSD   |
| WYANDOTTE ENERGY                                  | WYANDOTTE                   | MI    | 02/08/1999 | TURBINE, COMBINED CYCLE, POWER PLANT           | 500  | 4.5  | SCR   | BACT       |
| PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)      | ARECIBO                     | PR    | 07/31/1995 | COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE E  | 248  | 4.8  | FUEL SPEC: FIRING #2 FUEL OIL                             | BACT-PSD   |
| BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT         | PERRYMAN                    | MD    |            | TURBINE, 140 MW NATURAL GAS FIRED ELECTRIC     | 140  | 5.0  | DRY BURN LOW NOX BURNERS                                  | BACT-PSD   |
| CARSON ENERGY GROUP & CENTRAL VALLEY FINANCING AU | ELK GROVE                   | CA    | 07/23/1993 | TURBINE, GAS, COMBINED CYCLE, GE LM6000        | 56   | 5.0  | SELECTIVE CATALYTIC REDUCTION AND WATER INJECTION ALSO    | BACT       |
| CROCKETT COGENERATION - C&H SUGAR                 | CROCKETT                    | CA    | 10/05/1993 | TURBINE, GAS, GENERAL ELECTRIC MODEL PG7221(   | 240  | 5.0  | DRY LOW-NOX COMBUSTERS AND A MITSUBISHI HEAVY INDUSTRI    | BACT-OTHER |
| KALAMAZOO POWER LIMITED                           | COMSTOCK                    | MI    | 12/03/1991 | TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS   | 226  | 5.0  | DRY LOW NOX TURBINES                                      | BACT-PSD   |
| MOBILE ENERGY LLC                                 | MOBILE                      | AL    | 01/05/1999 | TURBINE, GAS, COMBINED CYCLE                   | 168  | 5.1  | SCR & DLN COMBUSTORS DURING GAS FIRING. STEAMWAT          | BACT-PSD   |
| KERN FRONT LIMITED                                | BAKERSFIELD                 | CA    | 11/04/1986 | TURBINE, GAS, GENERAL ELECTRIC LM-2500         | 25   | 5.5  | WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION         | BACT-OTHER |
| BRIDGEPORT ENERGY, LLC                            | BRIDGEPORT                  | CT    | 06/29/1998 | TURBINES, COMBUSTION MODEL V84.3A, 2 SIEMES    | 260  | 6.0  | DRY LOW NOX BURNER WITH SCR                               | BACT-PSD   |
| SOUTH MISSISSIPPI ELECTRIC POWER ASSOC.           | MOSELL                      | MS    | 04/09/1996 | COMBUSTION TURBINE, COMBINED CYCLE             | 162  | 6.0  | GOOD COMBUSTION CONTROLS                                  | BACT-PSD   |
| SUMAS ENERGY INC.                                 | SUMAS                       | WA    | 06/25/1991 | TURBINE, NATURAL GAS                           | 88   | 6.0  | SCR   | BACT-PSD   |
| AES PLACERITA, INC.                               |                             | CA    | 07/02/1987 | TURBINE, GAS                                   | 66   | 6.2  | SCR, STEAM INJECTION                                      | BACT-PSD   |
| SIMPSON PAPER CO.                                 |                             | CA    | 06/22/1987 | TURBINE, GAS                                   | 50   | 6.6  | SCR, STEAM INJECTION                                      | OTHER      |
| MIDWAY - SUNSET PROJECT                           |                             | CA    | 01/06/1987 | TURBINE, GAS, 3                                | 122  | 7.2  | H2O INJECTION   | BACT-PSD   |
| SALINAS RIVER COGENERATION COMPANY                |                             | CA    | 11/19/1990 | TURBINE,GAS, W/ HEAT RECOVERY STEAM GENERA     | 43   | 7.8  | TURBINE DRY LOW NOX COMBUST SYS W/ SCR CNTRL SYS          | BACT-PSD   |
| SARGENT CANYON COGENERATION COMPANY               |                             | CA    | 11/19/1990 | TURBINE, GAS W/ HEAT RECOVERY STEAM GENERA     | 43   | 6.0  | TURBINE DRY LOW NOX COMBUST SYS W/ SCR CNTRL SYS          | BACT-PSD   |
| BASF CORPORATION                                  | GEISMAR                     | LA    | 12/30/1997 | TURBINE, COGEN UNIT 2, GE FRAME 6              | 42   | 8.0  | STEAM INJECTION AND SCR TO LIMIT NOX TO 8 PPM FOR NATURA  | BACT-PSD   |
| CHAMPION INTERNATL CORP. & CHAMP. CLEAN ENERGY    | BUCKSPORT                   | ME    | 09/14/1998 | TURBINE, COMBINED CYCLE, NATURAL GAS           | 175  | 8.0  |   | BACT-OTHER |
| RICHMOND POWER ENTERPRISE PARTNERSHIP             | RICHMOND                    | VA    | 12/12/1989 | TURBINE, GAS FIRED, 2                          | 145  | 8.2  | SCR, STEAM INJECTION                                      | LAER       |
| MOJAVE COGENERATION CO.                           |                             | CA    | 01/12/1989 | TURBINE, GAS                                   | 61   | 8.4  | FUEL SPEC: OIL FIRING LIMITED TO 11 H/D                   | BACT-PSD   |
| CAROLINA POWER & LIGHT                            | GOLDSBORO                   | NC    | 04/11/1996 | COMBUSTION TURBINE, 4 EACH                     | 238  | 8.9  | COMBUSTION CONTROL  | BACT-PSD   |
| LAKEWOOD COGENERATION, L.P.                       | LAKEWOOD TOWNSHIP           | NJ    | 04/01/1991 | TURBINES (NATURAL GAS) (2)                     | 149  | 8.9  | SCR, DRY LOW NOX BURNER                                   | BACT-OTHER |
| NEWARK BAY COGENERATION PARTNERSHIP               | NEWARK                      | NJ    | 11/01/1990 | TURBINE, NATURAL GAS FIRED                     | 73   | 8.9  | STEAM INJECTION AND SCR                                   | BACT-PSD   |
| AIR LIQUIDE AMERICA CORPORATION                   | GEISMAR                     | LA    | 02/13/1998 | TURBINE GAS, GE, 7ME 7                         | 121  | 9.0  | DRY LOW NOX TO LIMIT NOX EMISSION TO 9PPMV                | BACT-PSD   |
| BAF ENERGY  |                             | CA    | 07/08/1987 | TURBINE, GENERATOR                             | 111  | 9.0  | SCR, STEAM INJECTION                                      | BACT-PSD   |
| BEAR ISLAND PAPER COMPANY, L.P.                   | ASHLAND                     | VA    | 10/30/1992 | TURBINE, COMBUSTION GAS                        | 59   | 9.0  | SELECTIVE CATALYTIC REDUCTION (SCR)                       | BACT-PSD   |
| BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP        | CHESTERFIELD                | VA    | 03/03/1992 | TURBINE, COMBUSTION                            | 147  | 9.0  | SCR, STEAM INJECTION                                      | BACT-PSD   |
| DOSWELL LIMITED PARTNERSHIP                       |                             | VA    | 05/04/1990 | TURBINE, COMBUSTION                            | 158  | 9.0  | DRY COMBUSTOR TO 25 PPM SCR TO 9 PPM USING NAT GAS        | OTHER      |
| DUKE ENERGY NEW SOMYRNA BEACH POWER CO. LP        | CHARLOTTE NC (HEADQUARTERS) | FL    | 10/15/1999 | TURBINE-GAS, COMBINED CYCLE                    | 500  | 9.0  | DLN GE DLN2.6 BURNERS                                     | BACT-PSD   |
| EMPIRE DISTRICT ELECTRIC CO.                      | JOPLIN                      | MO    | 02/28/1995 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES          | 89   | 9.0  | GOOD COMBUSTION CONTROL                                   | BACT-PSD   |
| FORMOSA PLASTICS CORPORATION, BATON ROUGE PLANT   | BATON ROUGE                 | LA    | 03/07/1997 | TURBINE/HSRG, GAS COGENERATION                 | 56   | 9.0  | DRY LOW NOX BURNER/COMBUSTION DESIGN AND CONSTRUCTIO      | BACT-PSD   |

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - NOx**

| FACILITY   | CITY                     | STATE | PERMIT     | PROCESS  | MW*  | PPM* | CTRLDESC   | BASIS      |
|--|--------------------------|-------|------------|--|------|------|--|------------|
| FORMOSA PLASTICS CORPORATION, LOUISIANA            | BATON ROUGE              | LA    | 03/02/1995 | TURBINE/HRSRG, GAS COGENERATION                  | 56   | 9.0  | DRY LOW NOX BURNER/COMBUSTION DESIGN AND CONTROL         | LAER       |
| KAMINE/BESICORP BEAVER FALLS COGENERATION FACILITY | BEAVER FALLS             | NY    | 11/09/1992 | TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW) | 81   | 9.0  | DRY LOW NOX OR SCR                                       | BACT-OTHER |
| KAMINE/BESICORP CORNING L.P.                       | SOUTH CORNING            | NY    | 11/05/1992 | TURBINE, COMBUSTION (79 MW)                      | 82   | 9.0  | DRY LOW NOX OR SCR                                       | BACT-OTHER |
| MID-GEORGIA COGEN.                                 | KATHLEEN                 | GA    | 04/03/1996 | COMBUSTION TURBINE (2), NATURAL GAS              | 116  | 9.0  | DRY LOW NOX BURNER WITH SCR                              | BACT-PSD   |
| NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO.        | PROVIDENCE               | RI    | 04/13/1992 | TURBINE, GAS AND DUCT BURNER                     | 170  | 9.0  | SCR  | BACT-PSD   |
| NEVADA COGENERATION ASSOCIATES #2                  | LAS VEGAS                | NV    | 01/17/1991 | COMBINED-CYCLE POWER GENERATION                  | 85   | 9.0  | SELECTIVE CATALYTIC SYSTEM ON ONE UNIT                   | BACT-PSD   |
| NEVADA POWER COMPANY, HARRY ALLEN PEAKING PLANT    | LAS VEGAS                | NV    | 09/18/1992 | COMBUSTION TURBINE ELECTRIC POWER GENERAT        | 600  | 9.0  | PRECISION CONTROL FOR THE LOW NOX COMBUSTOR              | BACT-PSD   |
| OCEAN STATE POWER                                  | BURRILLVILLE             | RI    | 12/13/1988 | TURBINE, GAS, GE FRAME 7, 4 EA                   | 132  | 9.0  | SCR, H2O INJECTION                                       | BACT-PSD   |
| OLEANDER POWER PROJECT                             | BALTIMORE (HEADQUARTERS) | FL    | 10/01/1999 | TURBINE-GAS, COMBINED CYCLE                      | 190  | 9.0  | DLN 2.6 GE ADVANCED DRY LOW NOX BU                       | BACT-PSD   |
| PASNY/HOLTSVILLE COMBINED CYCLE PLANT              | HOLTSVILLE               | NY    | 09/01/1992 | TURBINE, COMBUSTION GAS (150 MW)                 | 143  | 9.0  | DRY LOW NOX  | BACT-OTHER |
| SARANAC ENERGY COMPANY                             | PLATTSBURGH              | NY    | 07/31/1992 | TURBINES, COMBUSTION (2) (NATURAL GAS)           | 140  | 9.0  | SCR  | BACT-OTHER |
| SUMAS ENERGY INC                                   | SUMAS                    | WA    | 12/01/1990 | TURBINE, GAS-FIRED                               | 87   | 9.0  | SELECTIVE CATALYTIC REDUCTION (SCR)                      | BACT-PSD   |
| SUNLAW/INDUSTRIAL PARK 2                           |                          | CA    | 06/28/1985 | TURBINE, GAS W/2 FUEL OIL BACKUP, 2 EA, GE FRA   | 52   | 9.0  | SCR, STEAM INJECTION                                     | OTHER      |
| SANTA ROSA ENERGY LLC                              | NORTHBROOK               | FL    | 12/04/1998 | TURBINE, COMBUSTION, NATURAL GAS                 | 241  | 9.8  | DRY LOW NOX BURNER                                       | BACT-PSD   |
| LAS VEGAS COGENERATION LTD. PARTNERSHIP            | NORTH LAS VEGAS          | NV    | 10/18/1990 | TURBINE, COMBUSTION COGENERATION                 | 50   | 10.0 | H2O INJECTION/SCR  | BACT-PSD   |
| TAMPA ELECTRIC COMPANY (TEC)                       | APOLLO BEACH             | FL    | 10/15/1999 | TURBINE, COMBUSTION, SIMPLE CYCLE                | 165  | 10.5 | DLN  | BACT-PSD   |
| PEDRICKTOWN COGENERATION LIMITED PARTNERSHIP       | OLDMANS TOWNSHIP         | NJ    | 02/23/1990 | TURBINE, NATURAL GAS FIRED                       | 125  | 11.8 | STEAM INJECTION AND SCR                                  | BACT-PSD   |
| FLORIDA POWER CORPORATION POLK COUNTY SITE         | BARTOW                   | FL    | 02/25/1994 | TURBINE, NATURAL GAS (2)                         | 189  | 12.0 | DRY LOW NOX COMBUSTOR                                    | BACT-PSD   |
| ALABAMA POWER COMPANY                              | MCINTOSH                 | AL    | 12/17/1997 | COMBUSTION TURBINE W/ DUCT BURNER (COMBINE       | 100  | 15.0 | DRY LOW NOX BURNERS                                      | BACT-PSD   |
| AUBURNDALE POWER PARTNERS, LP                      | AUBURNDALE               | FL    | 12/14/1992 | TURBINE, GAS                                     | 152  | 15.0 | DRY LOW NOX COMBUSTOR                                    | BACT-PSD   |
| GAINESVILLE REGIONAL UTILITIES                     | GAINESVILLE              | FL    | 04/11/1995 | SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL    | 74   | 15.0 | DRY LOW NOX BURNERS GE FRAME UNIT, CAN ANNULAR COMBUS    | BACT-PSD   |
| KALAMAZOO POWER LIMITED                            | COMSTOCK                 | MI    | 12/03/1991 | TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS     | 226  | 15.0 | DRY LOW NOX TURBINES                                     | BACT-PSD   |
| KISSIMEE UTILITY AUTHORITY                         | INTERCESSION CITY        | FL    | 04/07/1993 | TURBINE, NATURAL GAS                             | 109  | 15.0 | DRY LOW NOX COMBUSTOR                                    | BACT-PSD   |
| PANDA-KATHLEEN, L.P.                               | LAKELAND                 | FL    | 06/01/1995 | COMBINED CYCLE COMBUSTION TURBINE (TOTAL 11      | 75   | 15.0 | DRY LOW NOX BURNER                                       | BACT-PSD   |
| PEPCO - CHALK POINT PLANT                          | EAGLE HARBOR             | MD    | 06/25/1990 | TURBINE, 84 MW NATURAL GAS FIRED ELECTRIC        | 84   | 15.0 | QUIET COMBUSTION AND WATER INJECTION                     | BACT-PSD   |
| PUBLIC SERVICE OF COLO.-FORT ST VRAIN              | PLATTEVILLE              | CO    | 05/01/1996 | COMBINED CYCLE TURBINES (2), NATURAL             | 471  | 15.0 | DRY LOW NOX COMBUSTION SYSTEMS FOR TURBINES AND DUC      | BACT-PSD   |
| SEMINOLE HARDEE UNIT 3                             | FORT GREEN               | FL    | 01/01/1996 | COMBINED CYCLE COMBUSTION TURBINE                | 140  | 15.0 | DRY LNB STAGED COMBUSTION                                | BACT-PSD   |
| SOUTHWESTERN PUBLIC SERVICE CO/CUNNINGHAM STATION  | HOBBS                    | NM    | 11/04/1996 | COMBUSTION TURBINE, NATURAL GAS                  | 100  | 15.0 | DRY LOW NOX COMBUSTION                                   | BACT-PSD   |
| TENUSKA GEORGIA PARTNERS, L.P.                     | FRANKLIN                 | GA    | 12/18/1998 | TURBINE, COMBUSTION, SIMPLE CYCLE, 6             | 160  | 15.0 | USING 15% EXCESS AIR. NOX EMISSION IS BECAUSE OF NATURAL | BACT-PSD   |
| TIGER BAY LP                                       | FT. MEADE                | FL    | 05/17/1993 | TURBINE, GAS                                     | 202  | 15.0 | DRY LOW NOX COMBUSTOR                                    | BACT-PSD   |
| WESTPLAINS ENERGY                                  | PUEBLO                   | CO    | 06/14/1996 | SIMPLE CYCLE TURBINE, NATURAL GAS                | 219  | 15.0 | DRY LOW NOX COMBUSTION SYSTEM (DLN). COMMITMENT TOUPO    | BACT-PSD   |
| STAR ENTERPRISE                                    | DELAWARE CITY            | DE    | 03/30/1998 | TURBINES, COMBINED CYCLE, 2                      | 103  | 16.0 | NITROGEN INJECTION WHILE FIRING SYNGAS AND STEAM INJECT  | LAER       |
| WEST CAMPUS COGENERATION COMPANY                   | COLLEGE STATION          | TX    | 05/02/1994 | GAS TURBINES                                     | 75   | 20.5 | INTERNAL COMBUSTION CONTROLS                             | BACT-PSD   |
| SC ELECTRIC AND GAS COMPANY - HAGOOD STATION       | CHARLESTON               | SC    | 12/11/1989 | INTERNAL COMBUSTION TURBINE                      | 110  | 21.7 | WATER INJECTION  | BACT-PSD   |
| SOUTHERN MARYLAND ELECTRIC COOPERATIVE (SMECO)     | EAGLE HARBOR             | MD    | 10/01/1989 | TURBINE, NATURAL GAS FIRED ELECTRIC              | 90   | 22.0 | WATER INJECTION  | BACT-PSD   |
| ANITEC COGEN PLANT                                 | BINGHAMTON               | NY    | 07/07/1993 | GE LM5000 COMBINED CYCLE GAS TURBINE EP #000     | 56   | 25.0 | NO CONTROLS  | BACT-OTHER |
| CHARLES LARSEN POWER PLANT                         | CITY OF OF LAKELAND      | FL    | 07/25/1991 | TURBINE, GAS, 1 EACH                             | 80   | 25.0 | WET INJECTION  | BACT-PSD   |
| CITY OF LAKELAND ELECTRIC AND WATER UTILITIES      | LAKELAND                 | FL    | 07/10/1998 | TURBINE, COMBUSTION, GAS FIRED W/ FUEL OIL ALS   | 272  | 25.0 | DRY LOW NOX BURNERS FOR SIMPLE CYCLE, SCR WHEN C         | BACT-PSD   |
| COLORADO SPRINGS UTILITIES-NIXON POWER PLANT       | FOUNTAIN                 | CO    | 06/30/1998 | SIMPLE CYCLE TURBINE, NATURAL GAS                | 1122 | 25.0 | DRY LOW NOX COMBUSTION                                   | BACT-PSD   |
| COMMONWEALTH ATLANTIC LTD PARTNERSHIP              | CHESAPEAKE               | VA    | 03/05/1991 | TURBINE, NAT GAS & #2 OIL                        | 192  | 25.0 | H2O INJECTION & LOW NOX COMBUSTION, ANNUAL STACK TESTIN  | BACT-PSD   |
| FLORIDA POWER AND LIGHT                            | NORTH PALM BEACH         | FL    | 06/05/1991 | TURBINE, GAS, 4 EACH                             | 400  | 25.0 | LOW NOX COMBUSTORS                                       | BACT-PSD   |
| GEORGIA GULF CORPORATION                           | PLAQUEMINE               | LA    | 03/26/1996 | GENERATOR, NATURAL GAS FIRED TURBINE             | 140  | 25.0 | CONTROL NOX USING STEAM INJECTION                        | BACT-PSD   |
| GEORGIA POWER COMPANY, ROBINS TURBINE PROJECT      | ROBINS AIR FORCE BASE    | GA    | 05/13/1994 | TURBINE, COMBUSTION, NATURAL GAS                 | 80   | 25.0 | WATER INJECTION, FUEL SPEC: NATURAL GAS                  | BACT-PSD   |
| GEORGIA POWER COMPANY, ROBINS TURBINE PROJECT      | ROBINS AIR FORCE BASE    | GA    | 05/13/1994 | TURBINE, COMBUSTION, NATURAL GAS                 | 80   | 25.0 | WATER INJECTION, FUEL SPEC: NATURAL GAS                  | BACT-PSD   |
| HARTWELL ENERGY LIMITED PARTNERSHIP                | HARTWELL                 | GA    | 07/28/1992 | TURBINE, GAS FIRED (2 EACH)                      | 227  | 25.0 | MAXIMUM WATER INJECTION                                  | BACT-PSD   |
| JMC SELKIRK, INC.                                  | SELKIRK                  | NY    | 11/21/1989 | TURBINE, GE FRAME 7, GAS FIRED                   | 80   | 25.0 | STEAM INJECTION  | BACT-PSD   |
| KAMINE/BESICORP SYRACUSE LP                        | SOLVAY                   | NY    | 12/10/1994 | SIEMENS V64.3 GAS TURBINE (EP #00001)            | 81   | 25.0 | WATER INJECTION  | BACT       |
| LORDSBURG L.P.                                     | LORDSBURG                | NM    | 06/18/1997 | TURBINE, NATURAL GAS-FIRED, ELEC. GEN.           | 100  | 25.0 | DRY LOW-NOX TECHNOLOGY WHICH ADOPTS STAGED OR SCH        | BACT-PSD   |
| MARCH POINT COGENERATION CO                        |                          | WA    | 10/26/1990 | TURBINE, GAS-FIRED                               | 80   | 25.0 | MASSIVE STEAM INJECTION                                  | BACT-PSD   |
| MEAD COATED BOARD, INC.                            | PHENIX CITY              | AL    | 03/12/1997 | COMBINED CYCLE TURBINE (25 MW)                   | 71   | 25.0 | FUEL OIL SULFUR CONTENT <=0.05% BY WEIGHT DRY LOW NOX C  | BACT-PSD   |
| PACIFIC THERMOMETICS, INC.                         | CROCKETT                 | CA    | 12/10/1985 | TURBINE, GAS, FRAME 7, 2 EA                      | 127  | 25.0 | QUIET COMBUSTOR. FUEL SPEC: NATURAL GAS FIRING LIMITED   | BACT-PSD   |
| PEABODY MUNICIPAL LIGHT PLANT                      | PEABODY                  | MA    | 11/30/1989 | TURBINE, 38 MW NATURAL GAS FIRED                 | 52   | 25.0 | WATER INJECTION  | BACT-OTHER |
| PEPCO - STATION A                                  | DICKERSON                | MD    | 05/31/1990 | TURBINE, 124 MW NATURAL GAS FIRED                | 125  | 25.0 | WATER INJECTION  | BACT-PSD   |
| PG & E, STATION T                                  | SAN FRANCISCO            | CA    | 08/25/1986 | TURBINE, GAS, GE LM5000                          | 50   | 25.0 | STEAM INJECTION AT STEAM/FUEL RATIO = 1.7/1              | BACT-PSD   |
| PROJECT ORANGE ASSOCIATES                          | SYRACUSE                 | NY    | 12/01/1993 | GE LM-5000 GAS TURBINE                           | 69   | 25.0 | STEAM INJECTION, FUEL SPEC: NATURAL GAS ONLY             | BACT       |
| SYRACUSE UNIVERSITY                                | SYRACUSE                 | NY    | 09/01/1989 | TURBINE, GAS FIRED                               | 79   | 25.0 | STEAM INJECTION  | OTHER      |
| UNION CARBIDE CORPORATION                          | HAHNVILLE                | LA    | 09/22/1995 | GENERATOR, GAS TURBINE                           | 164  | 25.0 | DRY LOW NOX COMBUSTOR                                    | BACT-PSD   |
| WI ELECTRIC POWER CO.                              | CONCORD STATION          | WI    | 10/18/1990 | TURBINES, COMBUSTION, SIMPLE CYCLE, 4            | 75   | 25.0 | H2O INJECTION  | BACT-PSD   |
| DELMARVA POWER                                     | WILMINGTON               | DE    | 09/27/1990 | TURBINE, COMBUSTION                              | 100  | 27.1 | LOW NOX BURNER   | BACT-PSD   |
| ONEIDA COGENERATION FACILITY                       | ONEIDA                   | NY    | 02/26/1990 | TURBINE, GE FRAME 6                              | 52   | 32.0 | COMBUSTION CONTROL                                       | OTHER      |
| CHAMPION INTERNATIONAL CORP.                       | SHELDON                  | TX    | 03/05/1985 | TURBINE, GAS, 2                                  | 168  | 33.2 |  | BACT-PSD   |
| FULTON COGENERATION ASSOCIATES                     | FULTON                   | NY    | 01/29/1990 | TURBINE, GE LM5000, GAS FIRED                    | 63   | 36.0 | H2O INJECTION  | BACT-PSD   |

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - NOx**

| FACILITY                                       | CITY              | STATE | PERMIT     | PROCESS                                     | MW  | PPM <sup>1</sup> | CTRLDESC   | BASIS    |
|--|-------------------|-------|------------|---|-----|------------------|--|----------|
| KAMINE SYRACUSE COGENERATION CO.               | SOLVAY            | NY    | 09/01/1989 | TURBINE, GAS FIRED                          | 79  | 36.0             | WATER INJECTION                                  | OTHER    |
| MIDWAY-SUNSET COGENERATION CO.                 |                   | CA    | 01/27/1988 | TURBINE, GE FRAME 7, 3 EA                   | 75  | 38.4             | H2O INJECTION, QUIET COMBUSTOR™                  | BACT-PSD |
| O'BRIEN COGENERATION                           | HARTFORD          | CT    | 08/08/1988 | TURBINE, GAS FIRED                          | 62  | 39.0             | WATER INJECTION                                  | BACT-PSD |
| CAPITOL DISTRICT ENERGY CENTER                 | HARTFORD          | CT    | 10/23/1989 | ENGINE, GAS TURBINE                         | 92  | 42.0             | STEAM INJECTION                                  | BACT-PSD |
| CITY UTILITIES OF SPRINGFIELD                  | SPRINGFIELD       | MO    | 03/04/1991 | GENERATION OF ELECTRICAL POWER              | 73  | 42.0             | WATER INJECTION                                  | BACT-PSD |
| CITY UTILITIES OF SPRINGFIELD                  | SPRINGFIELD       | MO    | 03/06/1991 | GENERATION OF ELECTRICAL POWER              | 94  | 42.0             | WATER INJECTION                                  | BACT-PSD |
| DELMARVA POWER                                 | WILMINGTON        | DE    | 08/23/1988 | TURBINE, COMBUSTION, 2 EA                   | 100 | 42.0             | LOW NOX BURNER, WATER INJECTION                  | BACT-PSD |
| EMPIRE ENERGY - NIAGARA COGENERATION CO.       | LOCKPORT          | NY    | 05/02/1989 | TURBINE, GR FRAME 6, 3 EA                   | 52  | 42.0             | STEAM INJECTION                                  | BACT-PSD |
| FLORIDA POWER AND LIGHT                        | LAVOGROME         | FL    | 03/14/1991 | TURBINE, GAS, 4 EACH                        | 240 | 42.0             | COMBUSTION CONTROL                               | BACT-PSD |
| HOPEWELL COGENERATION LIMITED PARTNERSHIP      |                   | VA    | 07/01/1988 | TURBINE, NAT GAS FIRED, 3 EA                | 129 | 42.0             |  | BACT-PSD |
| INDECK-YERKES ENERGY SERVICES                  | TONAWANDA         | NY    | 06/24/1992 | GE FRAME 6 GAS TURBINE (EP #00001)          | 54  | 42.0             | STEAM INJECTION                                  | BACT     |
| KAMINE SOUTH GLENS FALLS COGEN CO              | SOUTH GLENS FALLS | NY    | 09/10/1992 | GE FRAME 6 GAS TURBINE                      | 62  | 42.0             | WATER INJECTION                                  | BACT     |
| KAMINE/BESICORP NATURAL DAM LP                 | NATURAL DAM       | NY    | 12/31/1991 | GE FRAME 6 GAS TURBINE                      | 63  | 42.0             | STEAM INJECTION                                  | BACT     |
| LEDERLE LABORATORIES                           | PEARL RIVER       | NY    |            | (2) GAS TURBINES (EP #S 00101&102)          | 14  | 42.0             | STEAM INJECTION                                  | BACT-PSD |
| LOCKPORT COGEN FACILITY                        | LOCKPORT          | NY    | 07/14/1993 | (6) GE FRAME 6 TURBINES (EP #S 00001-00006) | 53  | 42.0             | STEAM INJECTION                                  | BACT     |
| MEGAN-RACINE ASSOCIATES, INC                   | CANTON            | NY    | 08/05/1989 | GE LM5000-N COMBINED CYCLE GAS TURBINE      | 401 | 42.0             | WATER INJECTION                                  | BACT     |
| MEGAN-RACINE ASSOCIATES, INC.                  | CANTON            | NY    | 03/08/1989 | TURBINE, LM5000                             | 54  | 42.0             | H2O INJECTION                                    | BACT-PSD |
| MIDLAND COGENERATION VENTURE                   | MIDLAND           | MI    | 02/16/1988 | TURBINE, 12 TOTAL                           | 123 | 42.0             | STEAM INJECTION                                  | BACT-PSD |
| THE DEXTER CORP.                               | WINDSOR LOCKS     | CT    | 09/29/1989 | TURBINE, NAT GAS & #2 FUEL OIL FIRED        | 69  | 42.0             | STEAM INJECTION                                  | BACT-PSD |
| VIRGINIA POWER                                 | CHESTERFIELD      | VA    | 04/15/1988 | TURBINE, GE 2 EA                            | 234 | 42.0             | STEAM INJECTION W/MAXIMIZATION (NSPS SUBPART GG) | LAER     |
| VIRGINIA POWER                                 |                   | VA    | 09/07/1989 | TURBINE, GAS                                | 164 | 42.0             | H2O INJECTION, RECORD KEEPING OF FUEL N2 CONTENT | BACT-PSD |
| PANDA-ROSEMARY CORP.                           | ROANOKE RAPIDS    | NC    | 09/06/1989 | TURBINE, COMBUSTION, #7 FRAME               | 131 | 44.8             | H2O INJECTION                                    | BACT-PSD |
| LONG ISLAND LIGHTING CO.                       |                   | NY    | 11/01/1988 | TURBINE, GE FRAME 7, 3 EA                   | 75  | 55.0             | WATER INJECTION                                  | BACT-PSD |
| PROCTOR AND GAMBLE PAPER PRODUCTS CO (CHARMIN) | MEHOOPANY         | PA    | 05/31/1995 | TURBINE, NATURAL GAS                        | 73  | 55.0             | STEAM INJECTION                                  | RACT     |
| TRIGEN MITCHEL FIELD                           | HEMPSTEAD         | NY    | 04/16/1993 | GE FRAME 6 GAS TURBINE                      | 53  | 60.0             | STEAM INJECTION                                  | BACT     |
| ALASKA ELECTRICAL GENERATION & TRANSMISSION    | BIG LAKE          | AK    | 03/18/1987 | TURBINE, NAT GAS FIRED                      | 80  | 75.0             | H2O INJECTION                                    | BACT-PSD |
| CONTINENTAL ENERGY ASSOC.                      | HAZELTON          | PA    | 07/26/1988 | TURBINE, NAT GAS                            | 98  | 75.0             | STEAM INJECTION                                  | BACT-PSD |
| SOUTHEAST PAPER CORP.                          | DUBLIN            | GA    | 10/13/1987 | TURBINE, COMBUSTION                         | 68  | 100.0            | STEAM INJECTION                                  | BACT-PSD |

- 1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr  
2) Some PPM values were calculated using a conversion factor based on the F-Factor and molecular weight of NO<sub>2</sub>: 1 (PPM) = (lb/mmBtu) \* 271  
lb/mmBtu values were also calculated from lb/hr, lb/yr or ton/yr values  
All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - CO**

| FACILITY                                      | CITY                | STATE | PERMIT     | PROCESS   | MW  | PPM* | CTRLDESC   | BASIS      |
|---|---------------------|-------|------------|---|-----|------|--|------------|
| PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)  | ARECIBO             | PR    | 07/31/1995 | COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EA  | 248 | 1.0  | MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND    | BACT-PSD   |
| HARTWELL ENERGY LIMITED PARTNERSHIP           | HARTWELL            | GA    | 07/28/1992 | TURBINE, GAS FIRED (2 EACH)                     | 227 | 1.8  | MAXIMUM WATER INJECTION                            | BACT-PSD   |
| NEWARK BAY COGENERATION PARTNERSHIP, L.P.     | NEWARK              | NJ    | 06/09/1993 | TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)     | 77  | 1.8  | OXIDATION CATALYST                                 | OTHER      |
| VIRGINIA POWER                                |                     | VA    | 09/07/1989 | TURBINE, GAS                                    | 164 | 2.1  |  | BACT-PSD   |
| SC ELECTRIC AND GAS COMPANY - HAGOOD STATION  | CHARLESTON          | SC    | 12/11/1989 | INTERNAL COMBUSTION TURBINE                     | 110 | 2.7  | GOOD COMBUSTION PRACTICES                          | BACT-PSD   |
| CHARLES LARSEN POWER PLANT                    | CITY OF OF LAKELAND | FL    | 07/25/1991 | TURBINE, GAS, 1 EACH                            | 80  | 3.0  | FUEL SPEC: NATURAL GAS                             | BACT-PSD   |
| SARANAC ENERGY COMPANY                        | PLATTSBURGH         | NY    | 07/31/1992 | TURBINES, COMBUSTION (2) (NATURAL GAS)          | 140 | 3.0  | OXIDATION CATALYST                                 | BACT-OTHER |
| TIGER BAY LP                                  | FT. MEADE           | FL    | 05/17/1993 | TURBINE, GAS                                    | 202 | 3.0  | GOOD COMBUSTION PRACTICES                          | BACT-PSD   |
| WYANDOTTE ENERGY                              | WYANDOTTE           | MI    | 02/08/1999 | TURBINE, COMBINED CYCLE, POWER PLANT            | 500 | 3.0  | CATALYTIC OXIDIZER                                 | LAER       |
| BLUE MOUNTAIN POWER, LP                       | RICHLAND            | PA    | 07/31/1996 | COMBUSTION TURBINE WITH HEAT RECOVERY BOILER    | 153 | 3.1  | OXIDATION CATALYST 16 PPM @ 15% O2 WHEN FIRING NO  | OTHER      |
| BERKSHIRE POWER DEVELOPMENT, INC.             | AGAWAM              | MA    | 09/22/1997 | TURBINE, COMBUSTION, ABB GT24                   | 224 | 3.6  | DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD     | BACT-PSD   |
| FLORIDA POWER AND LIGHT                       | NORTH PALM BEACH    | FL    | 06/05/1991 | TURBINE, CG, 4 EACH                             | 405 | 3.6  | LOW NOX COMBUSTORS                                 | BACT-PSD   |
| AES PLACERITA, INC.                           |                     | CA    | 03/10/1986 | TURBINE & RECOVERY BOILER                       | 65  | 3.7  | OXIDATION CATALYST                                 | BACT-PSD   |
| BROOKLYN NAVY YARD COGENERATION PARTNERS L    | NEW YORK CITY       | NY    | 06/06/1995 | TURBINE, NATURAL GAS FIRED                      | 240 | 4.0  | OXIDATION CATALYST                                 | LAER       |
| CAROLINA POWER & LIGHT                        | GOLDSBORO           | NC    | 04/11/1996 | COMBUSTION TURBINE, 4 EACH                      | 236 | 4.3  | COMBUSTION CONTROL                                 | BACT-PSD   |
| CHAMPION INTERNATIONAL CORP.                  | SHELDON             | TX    | 03/05/1985 | TURBINE, GAS, 2                                 | 188 | 5.3  |  | BACT-PSD   |
| PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)  | ARECIBO             | PR    | 07/31/1995 | COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EA  | 248 | 5.3  | MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND    | BACT-PSD   |
| CROCKETT COGENERATION - C&H SUGAR             | CROCKETT            | CA    | 10/05/1993 | TURBINE, GAS, GENERAL ELECTRIC MODEL PG7221(F   | 240 | 5.9  | ENGELHARD OXIDATION CATALYST                       | BACT-OTHER |
| PUBLIC SERVICE OF COLO.-FORT ST VRAIN         | PLATTEVILLE         | CO    | 05/01/1996 | COMBINED CYCLE TURBINES (2), NATURAL            | 471 | 5.9  | GOOD COMBUSTION CONTROL PRACTICES. COMMITMENT      | BACT-PSD   |
| SUMAS ENERGY INC.                             | SUMAS               | WA    | 06/25/1991 | TURBINE, NATURAL GAS                            | 88  | 6.0  | CO CATALYST  | BACT-PSD   |
| KISSIMMEE UTILITY AUTHORITY                   | INTERCESSION CITY   | FL    | 04/07/1993 | TURBINE, NATURAL GAS                            | 109 | 6.1  | DRY LOW NOX COMBUSTOR                              | BACT-PSD   |
| PASNY/HOLTSVILLE COMBINED CYCLE PLANT         | HOLTSVILLE          | NY    | 09/01/1992 | TURBINE, COMBUSTION GAS (150 MW)                | 143 | 8.5  | COMBUSTION CONTROL                                 | BACT-OTHER |
| DOSWELL LIMITED PARTNERSHIP                   |                     | VA    | 05/04/1990 | TURBINE, COMBUSTION                             | 158 | 8.8  | COMBUSTOR DESIGN & OPERATION                       | OTHER      |
| FULTON COGENERATION ASSOCIATES                | FULTON              | NY    | 01/29/1990 | TURBINE, GE LM5000, GAS FIRED                   | 63  | 8.9  | COMBUSTION CONTROL                                 | BACT-PSD   |
| KAMINE/BESICORP NATURAL DAM LP                | NATURAL DAM         | NY    | 12/31/1991 | GE FRAME 6 GAS TURBINE                          | 63  | 8.9  | NO CONTROLS  | BACT-OTHER |
| CHAMPION INTERNATL CORP. & CHAMP. CLEAN ENERG | BUCKSPORT           | ME    | 09/14/1998 | TURBINE, COMBINED CYCLE, NATURAL GAS            | 175 | 9.0  | NONE   | BACT-OTHER |
| FLORIDA POWER AND LIGHT                       | LAVOGROME REPOWER   | FL    | 03/14/1991 | TURBINE, GAS, 4 EACH                            | 240 | 9.0  | FUEL SPEC: NATURAL GAS AS FUEL                     | BACT-PSD   |
| KAMINE SOUTH GLENS FALLS COGEN CO             | SOUTH GLENS FALLS   | NY    | 09/10/1992 | GE FRAME 6 GAS TURBINE                          | 62  | 9.0  | NO CONTROLS  | BACT-OTHER |
| KAMINE/BESICORP BEAVER FALLS COGENERATION FA  | BEAVER FALLS        | NY    | 11/09/1992 | TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW | 81  | 9.5  | COMBUSTION CONTROLS                                | BACT-OTHER |
| KAMINE/BESICORP SYRACUSE LP                   | SOLVAY              | NY    | 12/10/1994 | SIEMENS V64.3 GAS TURBINE (EP #00001)           | 81  | 9.5  | NO CONTROLS  | BACT-OTHER |
| PANDA-ROSEMARY CORP.                          | ROANOKE RAPIDS      | NC    | 09/06/1989 | TURBINE, COMBUSTION, #6 FRAME                   | 62  | 9.6  | COMBUSTION CONTROL                                 | BACT-PSD   |
| BRIDGEPORT ENERGY, LLC                        | BRIDGEPORT          | CT    | 06/29/1998 | TURBINES, COMBUSTION MODEL V84.3A, 2 SIEMES     | 260 | 10.0 | PRE-MIX FUEL FAIR TO OPTIMIZE EFFICIENCY ACTUAL EM | BACT-PSD   |
| INDECK-YERKES ENERGY SERVICES                 | TONAWANDA           | NY    | 06/24/1992 | GE FRAME 6 GAS TURBINE (EP #00001)              | 54  | 10.0 | NO CONTROLS  | BACT-OTHER |
| LOCKPORT COGEN FACILITY                       | LOCKPORT            | NY    | 07/14/1993 | (6) GE FRAME 6 TURBINES (EP #S 00001-00006)     | 53  | 10.0 | NO CONTROLS  | BACT-OTHER |
| LONG ISLAND LIGHTING CO.                      |                     | NY    | 11/01/1988 | TURBINE, GE FRAME 7, 3 EA                       | 75  | 10.0 | COMBUSTION CONTROL                                 | OTHER      |
| MID-GEORGIA COGEN.                            | KATHLEEN            | GA    | 04/03/1996 | COMBUSTION TURBINE (2), NATURAL GAS             | 116 | 10.0 | COMPLETE COMBUSTION                                | BACT-PSD   |
| PILGRIM ENERGY CENTER                         | ISLIP               | NY    |            | (2) WESTINGHOUSE W501D5 TURBINES (EP #S 000018  | 175 | 10.0 |  | BACT-OTHER |
| SUNLAW/INDUSTRIAL PARK 2                      |                     | CA    | 06/28/1985 | TURBINE, GAS W/#2 FUEL OIL BACKUP, 2 EA, GE FRA | 52  | 10.0 | MFG GUARANTEE ON CO EMISSIONS                      | OTHER      |
| SYCAMORE COGENERATION CO.                     | BAKERSFIELD         | CA    | 03/06/1987 | TURBINE, GAS FIRED, 4 EA                        | 75  | 10.0 | CO OXIDIZING CATALYST, COMBUSTION CONTROL          | BACT-PSD   |
| TRIGEN MITCHEL FIELD                          | HEMPSTEAD           | NY    | 04/16/1993 | GE FRAME 6 GAS TURBINE                          | 53  | 10.0 | NO CONTROLS  | BACT-OTHER |
| WESTPLAINS ENERGY                             | PUEBLO              | CO    | 06/14/1996 | SIMPLE CYCLE TURBINE, NATURAL GAS               | 219 | 10.0 | DRY LOW NOX COMBUSTION SYSTEM (DLN). COMMITMENT    | BACT-PSD   |
| BEAR ISLAND PAPER COMPANY, L.P.               | ASHLAND             | VA    | 10/30/1992 | TURBINE, COMBUSTION GAS                         | 59  | 10.3 | GOOD COMBUSTION                                    | BACT-PSD   |
| PORTSIDE ENERGY CORP.                         | PORTAGE             | IN    | 05/13/1986 | TURBINE, NATURAL GAS-FIRED                      | 63  | 10.6 | GOOD COMBUSTION AND EMISSIONS NOT TO EXCEED 10 P   | BACT-PSD   |
| EMPIRE ENERGY - NIAGARA COGENERATION CO.      | LOCKPORT            | NY    | 05/02/1989 | TURBINE, GR FRAME 6, 3 EA                       | 52  | 10.7 | COMBUSTION CONTROL                                 | BACT-PSD   |
| HOPEWELL COGENERATION LIMITED PARTNERSHIP     |                     | VA    | 07/01/1988 | TURBINE, NAT GAS FIRED, 3 EA                    | 129 | 10.9 | STEAM INJECTION                                    | BACT-PSD   |
| NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO    | PROVIDENCE          | RI    | 04/13/1992 | TURBINE, GAS AND DUCT BURNER                    | 170 | 11.0 | NONE   | BACT-PSD   |
| SEPCO   | RIO LINDA           | CA    | 10/05/1994 | TURBINE, GAS COMBINED CYCLE GE MODEL 7          | 115 | 11.6 | OXIDATION CATALYST                                 | BACT       |
| LAKWOOD COGENERATION, L.P.                    | LAKWOOD TOWNSHIP    | NJ    | 04/01/1991 | TURBINES (NATURAL GAS) (2)                      | 149 | 11.6 | TURBINE DESIGN                                     | BACT-OTHER |
| MEGAN-RACINE ASSOCIATES, INC                  | CANTON              | NY    | 08/05/1989 | GE LM5000-N COMBINED CYCLE GAS TURBINE          | 401 | 11.6 | NO CONTROLS  | BACT-OTHER |
| MEGAN-RACINE ASSOCIATES, INC.                 | CANTON              | NY    | 03/08/1989 | TURBINE, LM5000                                 | 54  | 11.6 | COMBUSTION CONTROL                                 | OTHER      |
| MIDLAND COGENERATION VENTURE                  | MIDLAND             | MI    | 02/16/1988 | TURBINE, 12 TOTAL                               | 123 | 11.8 | TURBINE DESIGN                                     | BACT-PSD   |
| DUKE ENERGY NEW SOMYRNA BEACH POWER CO. LP    | CHARLOTTE NC (HEADQ | FL    | 10/15/1999 | TURBINE-GAS, COMBINED CYCLE                     | 500 | 12.0 | GOOD COMBUSTION                                    | BACT-PSD   |
| GRANITE ROAD LIMITED                          |                     | CA    | 05/06/1991 | TURBINE, GAS, ELECTRIC GENERATION               | 58  | 12.0 | SCR, STEAM INJECTION                               | BACT-PSD   |
| OLEANDER POWER PROJECT                        | BALTIMORE (HEADQUAR | FL    | 10/01/1999 | TURBINE-GAS, COMBINED CYCLE                     | 190 | 12.0 | GOOD COMBUSTION                                    | BACT-PSD   |
| TIVERTON POWER ASSOCIATES                     | TIVERTON            | RI    | 02/13/1998 | COMBUSTION TURBINE, NATURAL GAS                 | 265 | 12.0 | GOOD COMBUSTION                                    | BACT-PSD   |

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - CO**

| FACILITY                                      | CITY                 | STATE | PERMIT     | PROCESS  | MW'  | PPM' | CTRLDESC   | BASIS       |
|---|----------------------|-------|------------|--|------|------|--|-------------|
| KAMINE SYRACUSE COGENERATION CO.              | SOLVAY               | NY    | 09/01/1989 | TURBINE, GAS FIRED                             | 79   | 12.5 | COMBUSTION CONTROL                                 | OTHER       |
| SITHE/INDEPENDENCE POWER PARTNERS             | OSWEGO               | NY    | 11/24/1992 | TURBINES, COMBUSTION (4) (NATURAL GAS) (1012 M | 267  | 13.0 | COMBUSTION CONTROLS                                | BACT-OTHER  |
| TIGER BAY LP                                  | FT. MEADE            | FL    | 05/17/1993 | TURBINE, GAS                                   | 202  | 13.5 | GOOD COMBUSTION PRACTICES                          | BACT-PSD    |
| AUBURNDALE POWER PARTNERS, LP                 | AUBURNDALE           | FL    | 12/14/1992 | TURBINE, GAS                                   | 152  | 15.0 | GOOD COMBUSTION PRACTICES                          | BACT-PSD    |
| DELMARVA POWER                                | WILMINGTON           | DE    | 08/23/1988 | TURBINE, COMBUSTION, 2 EA                      | 100  | 15.0 | GOOD COMBUSTION PRACTICES                          | BACT-PSD    |
| GEORGIA POWER COMPANY, ROBINS TURBINE PROJE   | ROBINS AIR FORCE BAS | GA    | 05/13/1994 | TURBINE, COMBUSTION, NATURAL GAS               | 80   | 15.0 | FUEL SPEC: LOW SULFUR FUEL (.3% AVG) FUEL 0.1      | BACT-PSD    |
| HERMISTON GENERATING CO.                      | HERMISTON            | OR    | 07/07/1994 | TURBINES, NATURAL GAS (2)                      | 212  | 15.0 | GOOD COMBUSTION PRACTICES                          | BACT-PSD    |
| MEAD COATED BOARD, INC.                       | PHENIX CITY          | AL    | 03/12/1997 | COMBINED CYCLE TURBINE (25 MW)                 | 71   | 15.0 | PRIMARY FUEL IS NATURAL GAS WITH BACKUP FUEL AS    | BACT-PSD    |
| PORTLAND GENERAL ELECTRIC CO.                 | BOARDMAN             | OR    | 05/31/1994 | TURBINES, NATURAL GAS (2)                      | 215  | 15.0 | GOOD COMBUSTION PRACTICES                          | BACT-PSD    |
| PSI ENERGY, INC. WABASH RIVER STATION         | WEST TERRE HAUTE     | IN    | 05/27/1993 | COMBINED CYCLE SYNGAS TURBINE                  | 222  | 15.0 | OPERATION PRACTICES AND GOOD COMBUSTION, COMBIN    | BACT-PSD    |
| PUBLIC SERVICE OF COLO.-FORT ST VRAIN         | PLATTEVILLE          | CO    | 05/01/1996 | COMBINED CYCLE TURBINES (2), NATURAL           | 471  | 15.0 | GOOD COMBUSTION CONTROL PRACTICES. COMMITMENT      | BACT-PSD    |
| RUMFORD POWER ASSOCIATES                      | RUMFORD              | ME    | 05/01/1998 | TURBINE GENERATOR, COMBUSTION, NATURAL GAS     | 238  | 15.0 | GE DRY LOW-NOX COMBUSTOR DESIGN. GOOD COMBUSTI     | BACT-PSD    |
| SUMAS ENERGY INC                              | SUMAS                | WA    | 12/01/1990 | TURBINE, GAS-FIRED                             | 67   | 15.0 | CO CATALYST  | BACT-PSD    |
| TENUSKA GEORGIA PARTNERS, L.P.                | FRANKLIN             | GA    | 12/18/1998 | TURBINE, COMBUSTION, SIMPLE CYCLE, 6           | 160  | 15.0 | USING 15% EXCESS AIR. CO EMISSION IS BECAUSE OF NA | BACT-PSD    |
| WESTBROOK POWER LLC                           | WESTBROOK            | ME    | 12/04/1998 | TURBINE, COMBINED CYCLE, TWO                   | 528  | 15.0 | USING 15 % EXCESS AIR.                             | BACT-PSD    |
| LORDSBURG L.P.                                | LORDSBURG            | NM    | 06/18/1997 | TURBINE, NATURAL GAS-FIRED, ELEC. GEN.         | 100  | 15.0 | DRY LOW-NOX TECHNOLOGY BY MAINTAINING PROPER AIR   | BACT-PSD    |
| UNION CARBIDE CORPORATION                     | HAHNVILLE            | LA    | 09/22/1995 | GENERATOR, GAS TURBINE                         | 164  | 15.4 | NO ADD-ON CONTROL GOOD COMBUSTI                    | BACT-PSD    |
| FORMOSA PLASTICS CORPORATION, BATON ROUGE P   | BATON ROUGE          | LA    | 03/07/1997 | TURBINE/HSRG, GAS COGENERATION                 | 56   | 15.8 | COMBUSTION DESIGN AND CONSTRUCTION.                | BACT-PSD    |
| PROJECT ORANGE ASSOCIATES                     | SYRACUSE             | NY    | 12/01/1993 | GE LM-5000 GAS TURBINE                         | 69   | 17.0 | NO CONTROLS  | BACT-OTHER  |
| MOBILE ENERGY LLC                             | MOBILE               | AL    | 01/05/1999 | TURBINE, GAS, COMBINED CYCLE                   | 168  | 17.8 | GOOD COMBUSTION PRACTICES                          | BACT-PSD    |
| DUKE POWER CO. LINCOLN COMBUSTION TURBINE ST  | LOWESVILLE           | NC    | 12/20/1991 | TURBINE, COMBUSTION                            | 164  | 20.0 | COMBUSTION CONTROL                                 | BACT-PSD    |
| BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT     | PERRYMAN             | MD    |            | TURBINE, 140 MW NATURAL GAS FIRED ELECTRIC     | 140  | 20.0 | GOOD COMBUSTION PRACTICES                          | BACT-PSD    |
| CASCO RAY ENERGY CO                           | VEAZIE               | ME    | 07/13/1998 | TURBINE, COMBINED CYCLE, NATURAL GAS, TWO      | 170  | 20.0 | 15% EXCESS AIR                                     | BACT-PSD    |
| KALAMAZOO POWER LIMITED                       | COMSTOCK             | MI    | 12/03/1991 | TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS   | 226  | 20.0 | DRY LOW NOX TURBINES                               | BACT-PSD    |
| SEMINOLE HARDEE UNIT 3                        | FORT GREEN           | FL    | 01/01/1996 | COMBINED CYCLE COMBUSTION TURBINE              | 140  | 20.0 | DRY LNB GOOD COMBUSTION PRA                        | BACT-PSD    |
| BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP    | CHESTERFIELD         | VA    | 03/03/1992 | TURBINE, COMBUSTION                            | 147  | 23.5 | FURNACE DESIGN                                     | BACT-PSD    |
| AIR LIQUIDE AMERICA CORPORATION               | GEISMAR              | LA    | 02/13/1998 | TURBINE GAS, GE, 7ME 7                         | 121  | 25.0 | GOOD EQUIPMENT DESIGN, PROPER COMBUSTION TECHN     | BACT-PSD    |
| FLORIDA POWER CORPORATION POLK COUNTY SITE    | BARTOW               | FL    | 02/25/1994 | TURBINE, NATURAL GAS (2)                       | 189  | 25.0 | GOOD COMBUSTION PRACTICES                          | BACT-PSD    |
| JMC SELKIRK, INC.                             | SELKIRK              | NY    | 11/21/1989 | TURBINE, GE FRAME 7, GAS FIRED                 | 80   | 25.0 | COMBUSTION CONTROL                                 | BACT-PSD    |
| OCEAN STATE POWER                             | BURRILLVILLE         | RI    | 12/13/1988 | TURBINE, GAS, GE FRAME 7, 4 EA                 | 132  | 25.0 |  | BACT-PSD    |
| PANDA-KATHLEEN, L.P.                          | LAKELAND             | FL    | 06/01/1995 | COMBINED CYCLE COMBUSTION TURBINE (TOTAL 115   | 75   | 25.0 | COMBUSTION CONTROLS STANDARD ONLY APPLIES IF GE    | BACT-PSD    |
| ALABAMA POWER PLANT BARRY                     | BUCKS                | AL    | 08/07/1998 | TURBINES, COMBUSTION, NATURAL GAS              | 510  | 25.4 | EFFICIENT COMBUSTION                               | BACT-PSD    |
| NEVADA POWER COMPANY, HARRY ALLEN PEAKING P   | LAS VEGAS            | NV    | 09/18/1992 | COMBUSTION TURBINE ELECTRIC POWER GENERATI     | 75   | 25.8 | PRECISION CONTROL FOR THE LOW NOX COMBUSTOR        | BACT-PSD    |
| NEVADA COGENERATION ASSOCIATES #1             | LAS VEGAS            | NV    | 01/17/1991 | COMBINED-CYCLE POWER GENERATION                | 85   | 26.2 | CATALYTIC CONVERTER                                | BACT-PSD    |
| SOUTH MISSISSIPPI ELECTRIC POWER ASSOC.       | MOSELL               | MS    | 04/09/1998 | COMBUSTION TURBINE, COMBINED CYCLE             | 162  | 26.3 | GOOD COMBUSTION CONTROLS                           | BACT-PSD    |
| COLORADO SPRINGS UTILITIES-NIXON POWER PLANT  | FOUNTAIN             | CO    | 06/30/1998 | SIMPLE CYCLE TURBINE, NATURAL GAS              | 1122 | 30.0 | DRY LOW NOX COMBUSTION                             | BACT-PSD    |
| COMMONWEALTH ATLANTIC LTD PARTNERSHIP         | CHESAPEAKE           | VA    | 03/05/1991 | TURBINE, NAT GAS & #2 OIL                      | 192  | 30.0 | COMBUSTION CONTROLS, ANNUAL STACK TESTING          | BACT-PSD    |
| CITY OF LAKELAND ELECTRIC AND WATER UTILITIES | LAKELAND             | FL    | 07/10/1998 | TURBINE, COMBUSTION, GAS FIRED W/ FUEL OIL ALS | 272  | 31.2 | DRY LOW NOX BURNERS FOR SIMPLE CYCLE, SCR          | BACT-PSD    |
| MILLENNIUM POWER PARTNER, LP                  | CHARLTON             | MA    | 02/02/1998 | TURBINE, COMBUSTION, WESTINGHOUSE MODEL 501    | 317  | 31.2 | DRY LOW NOX COMBUSTION TECHNOLOGY IN CONJUNCTI     | BACT-PSD    |
| ECOELCTRICA, L.P.                             | PENUELAS             | PR    | 10/01/1996 | TURBINES, COMBINED-CYCLE COGENERATION          | 461  | 33.0 | COMBUSTION CONTROLS.                               | BACT-PSD    |
| VIRGINIA POWER                                | CHESTERFIELD         | VA    | 04/15/1988 | TURBINE, GE, 2 EA                              | 234  | 33.2 | EQUIPMENT DESIGN                                   | LAER        |
| ANITEC COGEN PLANT                            | BINGHAMTON           | NY    | 07/07/1993 | GE LM5000 COMBINED CYCLE GAS TURBINE EP #0000  | 56   | 36.0 | BAFFLE CHAMBER                                     | SEE NOTE #4 |
| MARCH POINT COGENERATION CO                   |                      | WA    | 10/26/1990 | TURBINE, GAS-FIRED                             | 80   | 37.0 | GOOD COMBUSTION                                    | BACT-PSD    |
| CAROLINA COGENERATION CO., INC.               | NEW BERN             | NC    | 07/11/1986 | TURBINE, GAS, PEAT FIRED                       | 52   | 37.0 | PROPER OPERATION                                   | BACT-PSD    |
| CARSON ENERGY GROUP & CENTRAL VALLEY FINANCI  | ELK GROVE            | CA    | 07/23/1993 | TURBINE, GAS SIMPLE CYCLE LM6000               | 56   | 39.5 | OXIDATION CATALYST                                 | BACT        |
| INDECK ENERGY COMPANY                         | SILVER SPRINGS       | NY    | 05/12/1993 | GE FRAME 6 GAS TURBINE EP #00001               | 61   | 40.0 | NO CONTROLS  | BACT-OTHER  |
| ONEIDA COGENERATION FACILITY                  | ONEIDA               | NY    | 02/26/1990 | TURBINE, GE FRAME 6                            | 52   | 40.0 | COMBUSTION CONTROL                                 | OTHER       |
| PEABODY MUNICIPAL LIGHT PLANT                 | PEABODY              | MA    | 11/30/1989 | TURBINE, 36 MW NATURAL GAS FIRED               | 52   | 40.0 | GOOD COMBUSTION PRACTICES                          | BACT-OTHER  |
| GAINESVILLE REGIONAL UTILITIES                | GAINESVILLE          | FL    | 04/11/1995 | OIL FIRED COMBUSTION TURBINE                   | 74   | 42.0 | FUEL SPEC: LOW S OIL 0.05% S                       | BACT-PSD    |
| CAPITOL DISTRICT ENERGY CENTER                | HARTFORD             | CT    | 10/23/1989 | ENGINE, GAS TURBINE                            | 92   | 49.8 |  | BACT-PSD    |
| THE DEXTER CORP.                              | WINDSOR LOCKS        | CT    | 09/29/1989 | TURBINE, NAT GAS & #2 FUEL OIL FIRED           | 69   | 49.8 |  | BACT-PSD    |
| SACRAMENTO COGENERATION AUTHORITY P&G         | SACRAMENTO           | CA    | 08/19/1994 | TURBINE, GAS, COMBINED CYCLE LM6000            | 53   | 50.0 | OXIDATION CATALYST                                 | BACT        |
| WEST CAMPUS COGENERATION COMPANY              | COLLEGE STATION      | TX    | 05/02/1994 | GAS TURBINES                                   | 75   | 50.6 | INTERNAL COMBUSTION CONTROLS                       | BACT        |
| CARSON ENERGY GROUP & CENTRAL VALLEY FINANCI  | ELK GROVE            | CA    | 07/23/1993 | TURBINE, GAS, COMBINED CYCLE, GE LM6000        | 450  | 50.7 | SELECTIVE CATALYTIC REDUCTION AND WATER INJECTION  | BACT        |
| FORMOSA PLASTICS CORPORATION                  | BATON ROUGE          | LA    | 09/20/1990 | TURBINE, GAS-FIRED, 2                          | 73   | 53.1 | COMBUSTION CONTROL                                 | BACT-PSD    |

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - CO**

| FACILITY                       | CITY       | STATE | PERMIT     | PROCESS                               | MW <sup>1</sup> | PPM <sup>2</sup> | CTRLDESC                                      | BASIS      |
|--------------------------------|------------|-------|------------|---------------------------------------|-----------------|------------------|---|------------|
| SIMPSON PAPER CO.              |            | CA    | 06/22/1987 | TURBINE, GAS                          | 50              | 61.0             | COMBUSTION CONTROLS                           | OTHER      |
| EMPIRE DISTRICT ELECTRIC CO.   | JOPLIN     | MO    | 02/28/1995 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES | 89              | 61.2             | GOOD COMBUSTION CONTROL                       | BACT-PSD   |
| MIDWAY-SUNSET COGENERATION CO. |            | CA    | 01/27/1986 | TURBINE, GE FRAME 7, 3 EA             | 75              | 69.7             | GOOD COMBUSTION PRACTICES                     | BACT-PSD   |
| PROJECT ORANGE ASSOCIATES      | SYRACUSE   | NY    | 12/01/1993 | GE LM-5000 GAS TURBINE                | 69              | 74.4             | NO CONTROLS                                   | BACT-OTHER |
| SYRACUSE UNIVERSITY            | SYRACUSE   | NY    | 09/01/1989 | TURBINE, GAS FIRED                    | 79              | 75.7             | CATALYTIC OXIDATION                           | OTHER      |
| GEORGIA GULF CORPORATION       | PLAQUEMINE | LA    | 03/26/1996 | GENERATOR, NATURAL GAS FIRED TURBINE  | 140             | 88.0             | GOOD COMBUSTION PRACTICE AND PROPER OPERATION | BACT-PSD   |

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some PPM values were calculated using a conversion factor based on the F-Factor and molecular weight of CO: 1 (PPM) = (lb/mmBtu) \* 445

lb/mmBtu values were also calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - SO<sub>2</sub>**

| FACILITY                               | CITY             | STATE | PERMIT     | PROCESS                                       | MW <sup>1</sup> | lb/mmBtu <sup>2</sup> | CTRLDESC                              | BASIS      |
|--|------------------|-------|------------|---|-----------------|-----------------------|---------------------------------------|------------|
| ECOELECTRICA, L.P.                     | PENUELAS         | PR    | 10/01/1996 | TURBINES, COMBINED-CYCLE COGENERATION         | 461             | 0.00014               | MAINTAIN EACH TURBINE IN GOOD WORKING | BACT-PSD   |
| EMPIRE DISTRICT ELECTRIC CO.           | JOPLIN           | MO    | 05/17/1994 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES         | 1345            | 0.00011               | LOW SULFUR CONTENT & COMBUSTION CONT  | BACT-PSD   |
| PROCTOR AND GAMBLE PAPER PRODUCTS C    | MEHOOPANY        | PA    | 05/31/1995 | TURBINE, NATURAL GAS                          | 73              | 0.00014               | STEAM INJECTION                       | RACT       |
| PUERTO RICO ELECTRIC POWER AUTHORITY   | ARECIBO          | PR    | 07/31/1995 | COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE E | 248             | 0.00035               | MAINTAIN EACH TURBINE IN GOOD WORKING | BACT-PSD   |
| CAROLINA POWER & LIGHT                 | GOLDSBORO        | NC    | 04/11/1996 | COMBUSTION TURBINE, 4 EACH                    | 238             | 0.00052               | COMBUSTION CONTROL                    | BACT-PSD   |
| DUKE POWER CO. LINCOLN COMBUSTION TU   | LOWESVILLE       | NC    | 12/20/1991 | TURBINE, COMBUSTION                           | 164             | 0.00053               | COMBUSTION CONTROL                    | BACT-PSD   |
| PANDA-ROSEMARY CORP.                   | ROANOKE RAPIDS   | NC    | 09/06/1989 | TURBINE, COMBUSTION, #6 FRAME                 | 62              | 0.00058               | FUEL SPEC: LOW S FUEL                 | BACT-PSD   |
| PANDA-ROSEMARY CORP.                   | ROANOKE RAPIDS   | NC    | 09/06/1989 | TURBINE, COMBUSTION, #7 FRAME                 | 131             | 0.00059               | FUEL SPEC: LOW S FUEL                 | BACT-PSD   |
| FLORIDA POWER CORPORATION POLK COUN    | BARTOW           | FL    | 02/25/1994 | TURBINE, NATURAL GAS (2)                      | 189             | 0.00066               | FUEL SPEC: LOW SULFUR IN NATURAL GAS  | BACT-PSD   |
| CAROLINA POWER AND LIGHT CO.           | DARLINGTON       | SC    | 09/23/1991 | TURBINE, I.C.                                 | 80              | 0.00078               | FUEL SPEC: LOW SULFUR FUEL            | BACT-PSD   |
| CHAMPION INTERNATIONAL CORP.           | SHELDON          | TX    | 03/05/1985 | TURBINE, GAS, 2                               | 168             | 0.00085               |                                       | BACT-PSD   |
| WEST CAMPUS COGENERATION COMPANY       | COLLEGE STATION  | TX    | 05/02/1994 | GAS TURBINES                                  | 75              | 0.0011                | INTERNAL COMBUSTION CONTROLS          | BACT       |
| SC ELECTRIC AND GAS COMPANY - HAGOOD   | CHARLESTON       | SC    | 12/11/1989 | INTERNAL COMBUSTION TURBINE                   | 110             | 0.0011                | GOOD COMBUSTION PRACTICES             | BACT-PSD   |
| BERKSHIRE POWER DEVELOPMENT, INC.      | AGAWAM           | MA    | 09/22/1997 | TURBINE, COMBUSTION, ABB GT24                 | 224             | 0.0022                | DRY LOW NOX COMBUSTION TECHNOLOGY W   | BACT-PSD   |
| DIGHTON POWER ASSOCIATE, LP            | DIGHTON          | MA    | 10/06/1997 | TURBINE, COMBUSTION, ABB GT11N2               | 166             | 0.0023                | DRY LOW NOX COMBUSTION TECHNOLOGY W   | BACT-PSD   |
| MILLENNIUM POWER PARTNER, LP           | CHARLTON         | MA    | 02/02/1998 | TURBINE, COMBUSTION, WESTINGHOUSE MODEL 50    | 317             | 0.0023                | DRY LOW NOX COMBUSTION TECHNOLOGY IN  | BACT-PSD   |
| BEAR ISLAND PAPER COMPANY, L.P.        | ASHLAND          | VA    | 10/30/1992 | TURBINE, COMBUSTION GAS                       | 59              | 0.0032                | FUEL SPEC: LOW SULFUR FUEL            | BACT-PSD   |
| CASCO RAY ENERGY CO                    | VEAZIE           | ME    | 07/13/1998 | TURBINE, COMBINED CYCLE, NATURAL GAS, TWO     | 170             | 0.0060                |                                       | BACT-PSD   |
| TIVERTON POWER ASSOCIATES              | TIVERTON         | RI    | 02/13/1998 | COMBUSTION TURBINE, NATURAL GAS               | 265             | 0.0060                | FUEL SPEC: NATURAL GAS FIRED          | BACT-PSD   |
| WESTBROOK POWER LLC                    | WESTBROOK        | ME    | 12/04/1998 | TURBINE, COMBINED CYCLE, TWO                  | 528             | 0.0060                |                                       | BACT-PSD   |
| CHAMPION INTERNATL CORP. & CHAMP. CLEA | BUCKSPORT        | ME    | 09/14/1998 | TURBINE, COMBINED CYCLE, NATURAL GAS          | 175             | 0.0086                |                                       | BACT-OTHER |
| MIDLAND COGENERATION VENTURE           | MIDLAND          | MI    | 02/16/1988 | TURBINE, 12 TOTAL                             | 123             | 0.016                 | FUEL SPEC: NAT GAS FUEL               | BACT-PSD   |
| FLORIDA POWER AND LIGHT                | NORTH PALM BEACH | FL    | 06/05/1991 | TURBINE, GAS, 4 EACH                          | 400             | 0.029                 | FUEL SPEC: NATURAL GAS AS FUEL        | BACT-PSD   |
| AUBURNDALE POWER PARTNERS, LP          | AUBURNDALE       | FL    | 12/14/1992 | TURBINE,GAS                                   | 152             | 0.033                 | FUEL SPEC: LOW SULFUR IN NATURAL GAS  | BACT-PSD   |
| COMMONWEALTH ATLANTIC LTD PARTNERSH    | CHESAPEAKE       | VA    | 03/05/1991 | TURBINE, NAT GAS & #2 OIL                     | 192             | 0.057                 | FUEL SPEC: LOW SULFUR FUEL & NAT GAS  | BACT-PSD   |
| DOSWELL LIMITED PARTNERSHIP            |                  | VA    | 05/04/1990 | TURBINE, COMBUSTION                           | 158             | 0.059                 | FUEL SPEC: LOW SULFUR FUELS, NAT GAS  | OTHER      |
| DELMARVA POWER                         | WILMINGTON       | DE    | 09/27/1990 | TURBINE, COMBUSTION                           | 100             | 0.070                 | FUEL SPEC: SULFUR IN FUEL             | BACT-PSD   |

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some lb/mmBtu values were calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list



**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - PM/PM10**

| FACILITY   | CITY                | STATE | PERMIT     | PROCESS  | MW <sup>1</sup> | lb/mmBtu <sup>2</sup> | CTRLDESC   | BASIS      |
|--|---------------------|-------|------------|--|-----------------|-----------------------|--|------------|
| MIDLAND COGENERATION VENTURE                       | MIDLAND             | MI    | 02/16/1988 | TURBINE, 12 TOTAL                                | 123             | 0.00051               | FUEL SPEC: NAT GAS FUEL                                | BACT-PSD   |
| EMPIRE DISTRICT ELECTRIC CO.                       | JOPLIN              | MO    | 05/17/1994 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES            | 1345            | 0.00052               | NONE   | BACT-PSD   |
| BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.      | NEW YORK CITY       | NY    | 06/06/1995 | TURBINE, NATURAL GAS FIRED                       | 240             | 0.0013                |  | LAER       |
| LAKEWOOD COGENERATION, L.P.                        | LAKEWOOD TOWNSHIP   | NJ    | 04/01/1991 | TURBINES (NATURAL GAS) (2)                       | 149             | 0.0023                | TURBINE DESIGN   | BACT-OTHER |
| PUBLIC SERVICE OF COLO.-FORT ST VRAIN              | PLATTEVILLE         | CO    | 05/01/1996 | COMBINED CYCLE TURBINES (2), NATURAL             | 471             | 0.0024                | FUEL SPEC: COMBUSTION OF PIPE LINE QUALITY GAS. CLOSE  | BACT-PSD   |
| CHAMPION INTERNATIONAL CORP.                       | SHELDON             | TX    | 03/05/1985 | TURBINE, GAS, 2                                  | 168             | 0.0030                | LOW NOX BURNERS  | BACT-PSD   |
| ECOELECTRICA, L.P.                                 | PENUELAS            | PR    | 10/01/1996 | TURBINES, COMBINED-CYCLE COGENERATION            | 461             | 0.0033                | MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND IMP    | BACT-PSD   |
| LILCO SHOREHAM                                     | HICKSVILLE          | NY    | 05/10/1993 | (3) GE FRAME 7 TURBINES (EP #S 00007-9)          | 106             | 0.0035                | NO CONTROLS  | BACT-OTHER |
| DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION  | LOWESVILLE          | NC    | 12/20/1991 | TURBINE, COMBUSTION                              | 164             | 0.0038                | COMBUSTION CONTROL                                     | BACT-PSD   |
| PILGRIM ENERGY CENTER                              | ISLIP               | NY    |            | (2) WESTINGHOUSE W501D5 TURBINES (EP #S 00001    | 175             | 0.0039                |  | BACT-OTHER |
| COMMONWEALTH ATLANTIC LTD PARTNERSHIP              | CHESAPEAKE          | VA    | 03/05/1991 | TURBINE, NAT GAS & #2 OIL                        | 192             | 0.0039                | FUEL SPEC: LOW ASH FUEL                                | BACT-PSD   |
| EMPIRE DISTRICT ELECTRIC CO.                       | JOPLIN              | MO    | 02/28/1995 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES            | 89              | 0.0039                | GOOD COMBUSTION CONTROL                                | BACT-PSD   |
| MEAD COATED BOARD, INC.                            | PHENIX CITY         | AL    | 03/12/1997 | COMBINED CYCLE TURBINE (25 MW)                   | 71              | 0.0044                | PRIMARY FUEL IS NATURAL GAS WITH BACKUP FUEL AS DISTIL | BACT-PSD   |
| NEVADA COGENERATION ASSOCIATES #1                  | LAS VEGAS           | NV    | 01/17/1991 | COMBINED-CYCLE POWER GENERATION                  | 85              | 0.0044                | FUEL SPEC: BURN NATURAL GAS                            | BACT-PSD   |
| CAROLINA POWER & LIGHT                             | GOLDSBORO           | NC    | 04/11/1996 | COMBUSTION TURBINE, 4 EACH                       | 238             | 0.0047                | COMBUSTION CONTROL                                     | BACT-PSD   |
| PACIFIC THERMONETICS, INC.                         | CROCKETT            | CA    | 04/06/1989 | BURNER, HRSG, 2                                  | 53              | 0.0048                | FUEL SPEC: NAT GAS USE ONLY                            | OTHER      |
| VIRGINIA POWER                                     |                     | VA    | 09/07/1989 | TURBINE, GAS                                     | 164             | 0.0048                |  | BACT-PSD   |
| INDECK ENERGY COMPANY                              | SILVER SPRINGS      | NY    | 05/12/1993 | GE FRAME 6 GAS TURBINE EP #00001                 | 61              | 0.0050                | NO CONTROLS  | BACT-OTHER |
| KAMINE/BESICORP CARTHAGE L.P.                      | CARTHAGE            | NY    | 01/18/1994 | GE FRAME 6 GAS TURBINE                           | 61              | 0.0050                | FUEL SPEC: SULFUR CONTENT NOT TO EXCEED 0.20% BY WEI   | BACT-OTHER |
| MILLENNIUM POWER PARTNER, LP                       | CHARLTON            | MA    | 02/02/1998 | TURBINE, COMBUSTION, WESTINGHOUSE MODEL 50       | 317             | 0.0050                | DRY LOW NOX COMBUSTION TECHNOLOGY IN CONJUNCTION       | BACT-PSD   |
| NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO.        | PROVIDENCE          | RI    | 04/13/1992 | TURBINE, GAS AND DUCT BURNER                     | 170             | 0.0050                | NONE   | BACT-PSD   |
| PANDA-ROSEMARY CORP.                               | ROANOKE RAPIDS      | NC    | 09/06/1989 | TURBINE, COMBUSTION, #6 FRAME                    | 62              | 0.0050                | COMBUSTION CONTROL                                     | BACT-PSD   |
| HERMISTON GENERATING CO.                           | HERMISTON           | OR    | 07/07/1994 | TURBINES, NATURAL GAS (2)                        | 212             | 0.0053                | GOOD COMBUSTION PRACTICES                              | BACT-PSD   |
| LSP-COTTAGE GROVE, L.P.                            | COTTAGE GROVE       | MN    | 03/01/1995 | COMBUSTION TURBINE/GENERATOR                     | 246             | 0.0054                | FUEL SELECTION; GOOD COMBUSTION                        | BACT-PSD   |
| ANITEC COGEN PLANT                                 | BINGHAMTON          | NY    | 07/07/1993 | GE LM5000 COMBINED CYCLE GAS TURBINE EP #0000    | 56              | 0.0055                | NO CONTROLS  | BACT-OTHER |
| TIGER BAY LP                                       | FT. MEADE           | FL    | 05/17/1993 | TURBINE, GAS                                     | 202             | 0.0056                | GOOD COMBUSTION PRACTICES                              | BACT-PSD   |
| FLORIDA POWER AND LIGHT                            | NORTH PALM BEACH    | FL    | 06/05/1991 | TURBINE, GAS, 4 EACH                             | 400             | 0.0056                | COMBUSTION CONTROL                                     | BACT-PSD   |
| FLORIDA POWER CORPORATION POLK COUNTY SITE         | BARTOW              | FL    | 02/25/1994 | TURBINE, NATURAL GAS (2)                         | 189             | 0.0060                | GOOD COMBUSTION PRACTICES                              | BACT-PSD   |
| CHARLES LARSEN POWER PLANT                         | CITY OF OF LAKELAND | FL    | 07/25/1991 | TURBINE, GAS, 1 EACH                             | 80              | 0.0060                | COMBUSTION CONTROL                                     | BACT-PSD   |
| EMPIRE ENERGY - NIAGARA COGENERATION CO.           | LOCKPORT            | NY    | 05/02/1989 | TURBINE, GR FRAME 6, 3 EA                        | 52              | 0.0060                | COMBUSTION CONTROL                                     | BACT-PSD   |
| KAMINE/BESICORP NATURAL DAM LP                     | NATURAL DAM         | NY    | 12/31/1991 | GE FRAME 6 GAS TURBINE                           | 63              | 0.0060                | STEAM INJECTION  | BACT       |
| LONG ISLAND LIGHTING CO.                           |                     | NY    | 11/01/1988 | TURBINE, GE FRAME 7, 3 EA                        | 75              | 0.0060                | COMBUSTION CONTROL                                     | BACT-PSD   |
| NEWARK BAY COGENERATION PARTNERSHIP, L.P.          | NEWARK              | NJ    | 06/09/1993 | TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)      | 77              | 0.0060                | TURBINE DESIGN   | BACT-PSD   |
| ONEIDA COGENERATION FACILITY                       | ONEIDA              | NY    | 02/26/1990 | TURBINE, GE FRAME 6                              | 52              | 0.0060                | COMBUSTION CONTROL                                     | OTHER      |
| SOUTH MISSISSIPPI ELECTRIC POWER ASSOC.            | MOSELL              | MS    | 04/09/1996 | COMBUSTION TURBINE, COMBINED CYCLE               | 162             | 0.0062                | GOOD COMBUSTION CONTROLS                               | BACT-PSD   |
| SEMINOLE HARDEE UNIT 3                             | FORT GREEN          | FL    | 01/01/1996 | COMBINED CYCLE COMBUSTION TURBINE                | 140             | 0.0063                | DRY LNB FUEL SPEC: LOW S OIL, LIMITE                   | BACT-PSD   |
| HARTWELL ENERGY LIMITED PARTNERSHIP                | HARTWELL            | GA    | 07/28/1992 | TURBINE, GAS FIRED (2 EACH)                      | 227             | 0.0064                | FUEL SPEC: CLEAN BURNING FUELS                         | BACT-PSD   |
| CHAMPION INTERNATL CORP. & CHAMP. CLEAN ENERGY     | BUCKSPORT           | ME    | 09/14/1998 | TURBINE, COMBINED CYCLE, NATURAL GAS             | 175             | 0.0064                | NONE   | BACT-OTHER |
| LORDSBURG L.P.                                     | LORDSBURG           | NM    | 06/18/1997 | TURBINE, NATURAL GAS-FIRED, ELEC. GEN.           | 100             | 0.0066                | WATER INJECTION  | BACT-PSD   |
| JMC SELKIRK, INC.                                  | SELKIRK             | NY    | 11/21/1989 | TURBINE, GE FRAME 7, GAS FIRED                   | 80              | 0.0070                | COMBUSTION CONTROL                                     | BACT-PSD   |
| KAMINE/BESICORP BEAVER FALLS COGENERATION FACILITY | BEAVER FALLS        | NY    | 11/09/1992 | TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW) | 81              | 0.0077                | COMBUSTION CONTROLS                                    | BACT-OTHER |
| SARANAC ENERGY COMPANY                             | PLATTSBURGH         | NY    | 07/31/1992 | TURBINES, COMBUSTION (2) (NATURAL GAS)           | 140             | 0.0080                | SCR  | BACT-OTHER |
| FLORIDA POWER AND LIGHT                            | LAVOGROME           | FL    | 03/14/1991 | TURBINE, GAS, 4 EACH                             | 240             | 0.0080                | COMBUSTION CONTROL                                     | BACT-PSD   |
| KISSIMMEE UTILITY AUTHORITY                        | INTERCESSION CITY   | FL    | 04/07/1993 | TURBINE, NATURAL GAS                             | 109             | 0.0081                | GOOD COMBUSTION PRACTICES                              | BACT-PSD   |
| SITHE/INDEPENDENCE POWER PARTNERS                  | OSWEGO              | NY    | 11/24/1992 | TURBINES, COMBUSTION (4) (NATURAL GAS) (1012 M   | 267             | 0.0082                | FUEL SPEC: USE OF NATURAL GAS                          | BACT-OTHER |
| LSP - COTTAGE GROVE, L.P.                          | COTTAGE GROVE       | MN    | 11/10/1998 | GENERATOR, COMBUSTION TURBINE & DUCT BURNE       | 249             | 0.0089                | COMBUSTING NATURAL GAS                                 | BACT-PSD   |
| MOBILE ENERGY LLC                                  | MOBILE              | AL    | 01/05/1999 | TURBINE, GAS, COMBINED CYCLE                     | 168             | 0.0089                | COMBUSTION OF CLEAN FUELS                              | BACT-PSD   |
| TIVERTON POWER ASSOCIATES                          | TIVERTON            | RI    | 02/13/1998 | COMBUSTION TURBINE, NATURAL GAS                  | 265             | 0.0089                | GOOD COMBUSTION  | BACT-PSD   |
| O'BRIEN COGENERATION                               | HARTFORD            | CT    | 08/08/1988 | TURBINE, GAS FIRED                               | 62              | 0.0090                | GOOD COMBUSTION PRACTICES                              | BACT-PSD   |
| DIGHTON POWER ASSOCIATE, LP                        | DIGHTON             | MA    | 10/06/1997 | TURBINE, COMBUSTION, ABB GT11N2                  | 166             | 0.0094                | DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD-ON      | BACT-PSD   |
| BERKSHIRE POWER DEVELOPMENT, INC.                  | AGAWAM              | MA    | 09/22/1997 | TURBINE, COMBUSTION, ABB GT24                    | 224             | 0.0097                | DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD-ON      | BACT-PSD   |
| PORTSIDE ENERGY CORP.                              | PORTAGE             | IN    | 05/13/1996 | TURBINE, NATURAL GAS-FIRED                       | 63              | 0.0099                | NONE   | BACT-PSD   |
| TENUSKA GEORGIA PARTNERS, L.P.                     | FRANKLIN            | GA    | 12/18/1998 | TURBINE, COMBUSTION, SIMPLE CYCLE, 6             | 160             | 0.010                 | PM EMISSION IS BECAUSE OF NATURAL GAS.                 | BACT-PSD   |
| TENUSKA GEORGIA PARTNERS, L.P.                     | FRANKLIN            | GA    | 12/18/1998 | TURBINE, COMBUSTION, SIMPLE CYCLE, 6             | 160             | 0.010                 | PM EMISSION IS BECAUSE OF NATURAL GAS.                 | BACT-PSD   |
| KAMINE SOUTH GLENS FALLS COGEN CO                  | SOUTH GLENS FALLS   | NY    | 09/10/1992 | GE FRAME 6 GAS TURBINE                           | 62              | 0.010                 | NO CONTROLS  | BACT-OTHER |
| GRAYS FERRY CO. GENERATION PARTNERSHIP             | PHILADELPHIA        | PA    | 11/04/1992 | TURBINE (NATURAL GAS & OIL)                      | 144             | 0.010                 | DRY LOW NOX BURNER, COMBUSTION CONTROL                 | BACT-OTHER |

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Natural Gas) - PM/PM10**

| FACILITY  | CITY            | STATE | PERMIT     | PROCESS                                       | MW <sup>1</sup> | lb/mmBtu <sup>2</sup> | CTRLDESC   | BASIS      |
|---|-----------------|-------|------------|---|-----------------|-----------------------|--|------------|
| VIRGINIA POWER                                  | CHESTERFIELD    | VA    | 04/15/1988 | TURBINE, GE,2 EA                              | 234             | 0.011                 | EQUIPMENT DESIGN                                       | LAER       |
| ALABAMA POWER PLANT BARRY                       | BUCKS           | AL    | 08/07/1998 | TURBINES, COMBUSTION, NATURAL GAS             | 510             | 0.011                 | NATURAL GAS ONLY, EFFICIENT COMBUSTION                 | BACT-PSD   |
| INDECK-YERKES ENERGY SERVICES                   | TONAWANDA       | NY    | 06/24/1992 | GE FRAME 6 GAS TURBINE (EP #00001)            | 54              | 0.012                 | NO CONTROLS  | BACT-OTHER |
| NEVADA POWER COMPANY, HARRY ALLEN PEAKING PLANT | LAS VEGAS       | NV    | 09/18/1992 | COMBUSTION TURBINE ELECTRIC POWER GENERATI    | 75              | 0.012                 | PRECISION CONTROL FOR THE COMBUSTOR                    | BACT-PSD   |
| GAINESVILLE REGIONAL UTILITIES                  | GAINESVILLE     | FL    | 04/11/1995 | SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL | 74              | 0.012                 | FUEL SPEC: LOW SULFUR FUELS                            | BACT-PSD   |
| ALABAMA POWER COMPANY - THEODORE COGENERATION   | THEODORE        | AL    | 03/16/1999 | 170 MW TURBINE W/ DUCT BURNER, HR BOILER, SCR | 170             | 0.012                 | COMBUSTION OF NATURAL GAS ONLY                         | BACT-PSD   |
| AUBURNDALE POWER PARTNERS, LP                   | AUBURNDALE      | FL    | 12/14/1992 | TURBINE,GAS                                   | 152             | 0.014                 | GOOD COMBUSTION PRACTICES                              | BACT-PSD   |
| KAMINE/BESICORP SYRACUSE LP                     | SOLVAY          | NY    | 12/10/1994 | SIEMENS V64.3 GAS TURBINE (EP #00001)         | 81              | 0.014                 | NO CONTROLS  | BACT-OTHER |
| UNION CARBIDE CORPORATION                       | HAHNVILLE       | LA    | 09/22/1995 | GENERATOR, GAS TURBINE                        | 164             | 0.014                 | NO CONTROL CLEAN FUEL                                  | BACT-PSD   |
| THE DEXTER CORP.                                | WINDSOR LOCKS   | CT    | 09/29/1989 | TURBINE, NAT GAS & #2 FUEL OIL FIRED          | 69              | 0.014                 |  | BACT-PSD   |
| PROJECT ORANGE ASSOCIATES                       | SYRACUSE        | NY    | 12/01/1993 | GE LM-5000 GAS TURBINE                        | 69              | 0.014                 | NO CONTROLS  | BACT-OTHER |
| PASNY/HOLTSVILLE COMBINED CYCLE PLANT           | HOLTSVILLE      | NY    | 09/01/1992 | TURBINE, COMBUSTION GAS (150 MW)              | 143             | 0.016                 | COMBUSTION CONTROL                                     | BACT-OTHER |
| MOJAVE COGENERATION CO.                         |                 | CA    | 01/12/1989 | TURBINE, GAS                                  | 61              | 0.017                 | FUEL SPEC: OIL FIRING LIMITED TO 11 H/D                | BACT-PSD   |
| TENUSKA GEORGIA PARTNERS, L.P.                  | FRANKLIN        | GA    | 12/18/1998 | TURBINE, COMBUSTION, SIMPLE CYCLE, 6          | 160             | 0.017                 | PM IS BECAUSE OF FUEL OIL. WHEN GROSS OUTPUT IS BELOW  | BACT-PSD   |
| GEORGIA GULF CORPORATION                        | PLAQUEMINE      | LA    | 03/26/1996 | GENERATOR, NATURAL GAS FIRED TURBINE          | 140             | 0.019                 | GOOD COMBUSTION PRACTICE AND PROPER OPERATION          | BACT-PSD   |
| AIR LIQUIDE AMERICA CORPORATION                 | GEISMAR         | LA    | 02/13/1998 | TURBINE GAS, GE, 7ME 7                        | 121             | 0.019                 | GOOD COMBUSTION PRACTICES AND USE CLEAN NATURAL GAS    | BACT-PSD   |
| MID-GEORGIA COGEN.                              | KATHLEEN        | GA    | 04/03/1996 | COMBUSTION TURBINE (2), NATURAL GAS           | 116             | 0.019                 | CLEAN FUEL   | BACT-PSD   |
| WEST CAMPUS COGENERATION COMPANY                | COLLEGE STATION | TX    | 05/02/1994 | GAS TURBINES                                  | 75              | 0.020                 | INTERNAL COMBUSTION CONTROLS                           | BACT       |
| SYRACUSE UNIVERSITY                             | SYRACUSE        | NY    | 09/01/1989 | TURBINE, GAS FIRED                            | 79              | 0.020                 | COMBUSTION CONTROL                                     | OTHER      |
| TRIGEN MITCHEL FIELD                            | HEMPSTEAD       | NY    | 04/16/1993 | GE FRAME 6 GAS TURBINE                        | 53              | 0.021                 | NO CONTROLS  | BACT-OTHER |
| LOCKPORT COGEN FACILITY                         | LOCKPORT        | NY    | 07/14/1993 | (6) GE FRAME 6 TURBINES (EP #S 00001-00006)   | 53              | 0.021                 | STEAM INJECTION  | BACT       |
| KAMINE/BESICORP CORNING L.P.                    | SOUTH CORNING   | NY    | 11/05/1992 | TURBINE, COMBUSTION (79 MW)                   | 82              | 0.024                 | DRY LOW NOX OR SCR                                     | BACT-OTHER |
| FULTON COGEN PLANT                              | FULTON          | NY    | 09/15/1994 | GE LM5000 GAS TURBINE                         | 63              | 0.024                 | FUEL SPEC: SULFUR CONTENT NOT TO EXCEED 0.3% BY WEIGHT | BACT-OTHER |
| FULTON COGENERATION ASSOCIATES                  | FULTON          | NY    | 01/29/1990 | TURBINE, GE LM5000, GAS FIRED                 | 63              | 0.024                 |  | BACT-PSD   |
| DOSWELL LIMITED PARTNERSHIP                     |                 | VA    | 05/04/1990 | TURBINE, COMBUSTION                           | 158             | 0.026                 | FUEL SPEC: CLEAN BURNING FUEL, NAT GAS & DIST. #2 OIL  | OTHER      |
| MEGAN-RACINE ASSOCIATES, INC                    | CANTON          | NY    | 08/05/1989 | GE LM5000-N COMBINED CYCLE GAS TURBINE        | 401             | 0.028                 | NO CONTROLS  | BACT-OTHER |
| MEGAN-RACINE ASSOCIATES, INC.                   | CANTON          | NY    | 03/06/1989 | TURBINE, LM5000                               | 54              | 0.028                 |  | BACT-PSD   |
| BEAR ISLAND PAPER COMPANY, L.P.                 | ASHLAND         | VA    | 10/30/1992 | TURBINE, COMBUSTION GAS                       | 59              | 0.036                 | FUEL SPEC: CLEAN BURN FUEL                             | BACT-PSD   |
| PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)    | ARECIBO         | PR    | 07/31/1995 | COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE E | 248             | 0.036                 | MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND IMP    | BACT-PSD   |
| PEABODY MUNICIPAL LIGHT PLANT                   | PEABODY         | MA    | 11/30/1989 | TURBINE, 38 MW OIL FIRED                      | 52              | 0.050                 | FUEL SPECIFICATION: NO. 2 LIGHT OIL                    | BACT-OTHER |
| SC ELECTRIC AND GAS COMPANY - HAGOOD STATION    | CHARLESTON      | SC    | 12/11/1989 | INTERNAL COMBUSTION TURBINE                   | 110             | 0.051                 | FUEL SPEC: LOW ASH CONTENT FUELS                       | BACT-PSD   |
| KAMINE SYRACUSE COGENERATION CO.                | SOLVAY          | NY    | 09/01/1989 | TURBINE, GAS FIRED                            | 79              | 0.053                 | COMBUSTION CONTROL                                     | OTHER      |
| CASCO RAY ENERGY CO                             | VEAZIE          | ME    | 07/13/1998 | TURBINE, COMBINED CYCLE, NATURAL GAS, TWO     | 170             | 0.060                 | NONE   | BACT-PSD   |
| WESTBROOK POWER LLC                             | WESTBROOK       | ME    | 12/04/1998 | TURBINE, COMBINED CYCLE, TWO                  | 528             | 0.060                 | NONE   | BACT-PSD   |
| WI ELECTRIC POWER CO.                           | CONCORD STATION | WI    | 10/18/1990 | TURBINES, COMBUSTION, SIMPLE CYCLE, 4         | 75              | 0.065                 | GOOD COMBUSTION  | BACT-PSD   |
| SOUTHEAST PAPER CORP.                           | DUBLIN          | GA    | 10/13/1987 | TURBINE, COMBUSTION                           | 68              | 0.10                  |  | OTHER      |

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some lb/mmBtu values were calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Fuel Oil) - NOx**

| FACILITY   | CITY                | STATE | PERMIT     | PROCESS  | MW <sup>1</sup> | PPM <sup>2</sup> | CTRLDESC  | BASIS      |
|--|---------------------|-------|------------|--|-----------------|------------------|---|------------|
| BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.      | NEW YORK CITY       | NY    | 08/06/1995 | TURBINE, OIL FIRED                                 | 240             | 10.0             | FUEL SPEC: DISTILLATE #2 FUEL OIL               | BACT-PSD   |
| GAINESVILLE REGIONAL UTILITIES                     | GAINESVILLE         | FL    | 04/11/1995 | SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL B-UP | 74              | 15.0             | FUEL SPEC: LOW SULFUR FUEL OIL                  | BACT-PSD   |
| BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP         | CHESTERFIELD        | VA    | 03/03/1992 | TURBINE, COMBUSTION                                | 140             | 15.0             |   |            |
| BEAR ISLAND PAPER COMPANY, L.P.                    | ASHLAND             | VA    | 10/30/1992 | TURBINE, COMBUSTION GAS                            | 59              | 15.0             |   | 91         |
| KALAMAZOO POWER LIMITED                            | COMSTOCK            | MI    | 12/03/1991 | TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS       | 226             | 15.0             | DRY LOW NOX TURBINES                            | 80.8       |
| NEWARK BAY COGENERATION PARTNERSHIP, L.P.          | NEWARK              | NJ    | 06/09/1993 | TURBINES, COMBUSTION, KEROSENE-FIRED (2)           | 80              | 16.0             | COMBUSTION CONTROL                              | BACT-PSD   |
| NEWARK BAY COGENERATION PARTNERSHIP                | NEWARK              | NJ    | 11/01/1990 | TURBINE, KEROSENE FIRED                            | 73              | 16.2             | STEAM INJECTION AND SCR                         | BACT-PSD   |
| MID-GEORGIA COGEN.                                 | KATHLEEN            | GA    | 04/03/1996 | COMBUSTION TURBINE (2), FUEL OIL                   | 116             | 20.0             | WATER INJECTION WITH SCR                        | BACT-PSD   |
| SARANAC ENERGY COMPANY                             | PLATTSBURGH         | NY    | 07/31/1992 | BURNERS, DUCT (2)                                  | 69              | 20.6             | COMBUSTION CONTROL                              | BACT-PSD   |
| LAKEWOOD COGENERATION, L.P.                        | LAKEWOOD TOWNSHIP   | NJ    | 04/01/1991 | TURBINES (#2 FUEL OIL) (2)                         | 149             | 21.1             | FUEL SPEC: NO. 2 FUEL OIL AS FUEL               | BACT-PSD   |
| MEAD COATED BOARD, INC.                            | PHENIX CITY         | AL    | 03/12/1997 | COMBINED CYCLE TURBINE (25 MW)                     | 71              | 25.0             | FUEL OIL SULFUR CONTENT <=0.05% BY WEIGHT       | BACT-PSD   |
| SAVANNAH ELECTRIC AND POWER CO.                    |                     | GA    | 02/12/1992 | TURBINES, 8  | 129             | 25.0             | MAX WATER INJECTION                             | BACT-PSD   |
| HARTWELL ENERGY LIMITED PARTNERSHIP                | HARTWELL            | GA    | 07/28/1992 | TURBINE, OIL FIRED (2 EACH)                        | 230             | 25.0             | MAXIMUM WATER INJECTION                         | BACT-PSD   |
| PEPCO - CHALK POINT PLANT                          | EAGLE HARBOR        | MD    | 06/25/1990 | TURBINE, 105 MW OIL FIRED ELECTRIC                 | 105             | 25.0             | DRY PREMIX BURNER                               | BACT-PSD   |
| OKLAHOMA MUNICIPAL POWER AUTHORITY                 | PONCA CITY          | OK    | 12/17/1992 | TURBINE, COMBUSTION                                | 58              | 25.0             | COMBUSTION CONTROLS                             | BACT-OTHER |
| PATOWMACK POWER PARTNERS, LIMITED PARTNERSHIP      | LEESBURG            | VA    | 09/15/1993 | TURBINE, COMBUSTION, SIEMENS MODEL V84.2.3         | 146             | 28.9             | WET INJECTION                                   | BACT-PSD   |
| FULTON COGEN PLANT                                 | FULTON              | NY    | 09/15/1994 | GE LM5000 GAS TURBINE                              | 63              | 36.0             | WATER INJECTION                                 | BACT       |
| PEABODY MUNICIPAL LIGHT PLANT                      | PEABODY             | MA    | 11/30/1989 | TURBINE, 38 MW OIL FIRED                           | 52              | 40.0             | WATER INJECTION                                 | BACT-OTHER |
| STAR ENTERPRISE                                    | DELAWARE CITY       | DE    | 03/30/1998 | TURBINES, COMBINED CYCLE, 2                        | 103             | 42.0             | COMBUSTION CONTROL                              | BACT-PSD   |
| CHARLES LARSEN POWER PLANT                         | CITY OF OF LAKELAND | FL    | 07/25/1991 | TURBINE, OIL, 1 EACH                               | 80              | 42.0             | WET INJECTION                                   | BACT-PSD   |
| FLORIDA POWER GENERATION                           | DEBARY              | FL    | 10/18/1991 | TURBINE, OIL, 6 EACH                               | 93              | 42.0             | WET INJECTION                                   | BACT-PSD   |
| TIGER BAY LP                                       | FT. MEADE           | FL    | 05/17/1993 | TURBINE, OIL                                       | 231             | 42.0             | WATER INJECTION                                 | BACT-PSD   |
| KISSIMMEE UTILITY AUTHORITY                        | INTERCESSION CITY   | FL    | 04/07/1993 | TURBINE, FUEL OIL                                  | 116             | 42.0             | WATER INJECTION                                 | BACT-PSD   |
| AUBURNDALE POWER PARTNERS, LP                      | AUBURNDALE          | FL    | 12/14/1992 | TURBINE, OIL                                       | 146             | 42.0             | STEAM INJECTION                                 | BACT-PSD   |
| TECO POLK POWER STATION                            | BARTOW              | FL    | 02/24/1994 | TURBINE, FUEL OIL                                  | 221             | 42.0             | WET INJECTION                                   | BACT-PSD   |
| FLORIDA POWER CORPORATION POLK COUNTY SITE         | BARTOW              | FL    | 02/25/1994 | TURBINE, FUEL OIL (2)                              | 216             | 42.0             | WATER INJECTION                                 | BACT-PSD   |
| FLORIDA POWER CORPORATION                          | INTERCESSION CITY   | FL    | 08/17/1992 | TURBINE, OIL                                       | 129             | 42.0             | WET INJECTION                                   | BACT-PSD   |
| GAINESVILLE REGIONAL UTILITIES                     | GAINESVILLE         | FL    | 04/11/1995 | OIL FIRED COMBUSTION TURBINE                       | 74              | 42.0             | WATER INJECTION                                 | BACT-PSD   |
| KENTUCKY UTILITIES COMPANY                         | MERCER              | KY    | 03/10/1992 | TURBINE, #2 FUEL OIL/NATURAL GAS (8)               | 188             | 42.0             | WATER INJECTION                                 | BACT-PSD   |
| EAST KENTUCKY POWER COOPERATIVE                    |                     | KY    | 03/24/1993 | TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED       | 187             | 42.0             | WATER INJECTION                                 | SEE NOTES  |
| PASNY/HOLTSVILLE COMBINED CYCLE PLANT              | HOLTSVILLE          | NY    | 09/01/1992 | TURBINE, COMBUSTION GAS (150 MW)                   | 143             | 42.0             | WATER INJECTOR                                  | BACT-OTHER |
| KAMINE/BESICORP CARTHAGE L.P.                      | CARTHAGE            | NY    | 01/18/1994 | GE FRAME 6 GAS TURBINE                             | 61              | 42.0             | STEAM INJECTION                                 | BACT       |
| EMPIRE DISTRICT ELECTRIC CO.                       | JOPLIN              | MO    | 05/17/1994 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES              | 168             | 49.5             | LOW NOX BURNERS, AND WATER INJECTION            | BACT-PSD   |
| KAMINE/BESICORP BEAVER FALLS COGENERATION FACILITY | BEAVER FALLS        | NY    | 11/09/1992 | TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW)   | 81              | 55.0             | DRY LOW NOX OR SCR                              | BACT-OTHER |
| PEPCO - CHALK POINT PLANT                          | EAGLE HARBOR        | MD    | 06/25/1990 | TURBINE, 84 MW OIL FIRED ELECTRIC                  | 84              | 58.0             | QUIET COMBUSTION AND WATER INJECTION            | BACT-PSD   |
| CAROLINA POWER AND LIGHT                           | HARTSVILLE          | SC    | 08/31/1994 | STATIONARY GAS TURBINE                             | 190             | 62.0             | FUEL SPEC: FUEL QUALITY                         | BACT-PSD   |
| FLORIDA POWER AND LIGHT                            | NORTH PALM BEACH    | FL    | 06/05/1991 | TURBINE, OIL, 2 EACH                               | 400             | 65.0             | LOW NOX COMBUSTORS                              | BACT-PSD   |
| BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT          | PERRYMAN            | MD    |            | TURBINE, 140 MW OIL FIRED ELECTRIC                 | 140             | 65.0             | WATER INJECTION                                 | BACT-PSD   |
| OKLAHOMA MUNICIPAL POWER AUTHORITY                 | PONCA CITY          | OK    | 12/17/1992 | TURBINE, COMBUSTION                                | 58              | 65.0             | COMBUSTION CONTROLS                             | BACT-OTHER |
| HOPEWELL COGENERATION LIMITED PARTNERSHIP          |                     | VA    | 07/01/1988 | TURBINE, OIL FIRED, 3 EA                           | 129             | 65.0             |   | BACT-PSD   |
| DOSWELL LIMITED PARTNERSHIP                        |                     | VA    | 05/04/1990 | TURBINE, COMBUSTION                                | 158             | 65.0             | STEAM INJECTION & FUEL SPEC: USE OF #2 OIL      | OTHER      |
| PANDA-ROSEMARY CORP.                               | ROANOKE RAPIDS      | NC    | 09/06/1989 | TURBINE, COMBUSTION, #7 FRAME                      | 133             | 67.2             |   |            |
| KALAELOE PARTNERS, L.P.                            |                     | HI    | 03/09/1990 | TURBINE, LSFO, 2                                   | 225             | 69.0             | STEAM INJECTION AT 1.3 TO 1 STEAM TO FUEL RATIO | BACT-PSD   |
| CAROLINA POWER & LIGHT                             | GOLDSBORO           | NC    | 04/11/1996 | COMBUSTION TURBINE, 4 EACH                         | 238             | 69.0             | WATER INJECTION; FUEL SPEC: 0.04% N FUEL OIL    | BACT-PSD   |
| PEPCO - STATION A                                  | DICKERSON           | MD    | 05/31/1990 | TURBINE, 124 MW OIL FIRED                          | 125             | 77.0             | WATER INJECTION                                 | BACT-PSD   |
| SOUTHERN MARYLAND ELECTRIC COOPERATIVE (SMECO)     | EAGLE HARBOR        | MD    | 10/01/1989 | TURBINE, OIL FIRED ELECTRIC                        | 90              | 142.8            | WATER INJECTION                                 | BACT-PSD   |
| UNION ELECTRIC CO                                  | WEST ALTON          | MO    | 05/06/1979 | CONSTRUCTION OF A NEW OIL FIRED COMBUSTION TURBINE | 78              | 494.5            | WATER INJECTION FOR NOX EMISSIONS               | BACT-PSD   |

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some PPM values were calculated using a conversion factor based on the F-Factor and molecular weight of NO<sub>2</sub>: 1 (PPM) = (lb/mmBtu) \* 257

lb/mmBtu values were also calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Fuel Oil) - CO**

| FACILITY                                    | CITY                | STATE | PERMIT     | PROCESS                                      | MW' | PPM'  | CTRLDESC                                  | BASIS            |
|---|---------------------|-------|------------|--|-----|-------|---|------------------|
| GORHAM ENERGY LIMITED PARTNERSHIP           | GORHAM              | ME    | 12/04/1998 | TURBINE, COMBINED CYCLE                      | 900 | 5.0   | 0.05% SULFUR DISTILLATE OIL #2 IS USED.   | EMISSION IS FROM |
| BROOKLYN NAVY YARD COGENERATION PARTNERSHIP | NEW YORK CITY       | NY    | 06/06/1995 | TURBINE, OIL FIRED                           | 240 | 5.0   | COMBUSTION DESIGN                         | BACT-PSD         |
| UNION ELECTRIC CO                           | WEST ALTON          | MO    | 05/06/1979 | CONSTRUCTION OF A NEW OIL FIRED COMBUSTION   | 622 | 9.0   |   | BACT-PSD         |
| SAVANNAH ELECTRIC AND POWER CO.             |                     | GA    | 02/12/1992 | TURBINES, 8                                  | 129 | 9.0   | WATER INJECTION                           | BACT-PSD         |
| PANDA-ROSEMARY CORP.                        | ROANOKE RAPIDS      | NC    | 09/06/1989 | TURBINE, COMBUSTION, #7 FRAME                | 133 | 9.2   |   |                  |
| SELKIRK COGENERATION PARTNERS, L.P.         | SELKIRK             | NY    | 06/18/1992 | COMBUSTION TURBINES (2) (252 MW)             | 147 | 10.0  | COMBUSTION CONTROLS                       | BACT-OTHER       |
| INDECK-OSWEGO ENERGY CENTER                 | OSWEGO              | NY    | 10/06/1994 | GE FRAME 6 GAS TURBINE                       | 533 | 10.0  | NO CONTROLS                               | BACT-OTHER       |
| HOPEWELL COGENERATION LIMITED PARTNERSHIP   |                     | VA    | 07/01/1988 | TURBINE, OIL FIRED, 3 EA                     | 129 | 10.5  |   | BACT-PSD         |
| MEGAN-RACINE ASSOCIATES, INC.               | CANTON              | NY    | 03/06/1989 | TURBINE, LM5000                              | 54  | 11.0  |   |                  |
| FLORIDA POWER CORPORATION                   | INTERCESSION CITY   | FL    | 06/17/1992 | TURBINE, OIL                                 | 233 | 17.9  | GOOD COMBUSTION PRACTICES                 | BACT-PSD         |
| CAROLINA POWER & LIGHT                      | GOLDSBORO           | NC    | 04/11/1996 | COMBUSTION TURBINE, 4 EACH                   | 238 | 18.0  | COMBUSTION DESIGN                         | BACT-PSD         |
| KENTUCKY UTILITIES COMPANY                  | MERCER              | KY    | 03/10/1992 | TURBINE, #2 FUEL OIL/NATURAL GAS (8)         | 188 | 21.2  | COMBUSTION CONTROL                        | BACT-PSD         |
| EAST KENTUCKY POWER COOPERATIVE             |                     | KY    | 03/24/1993 | TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED | 187 | 21.3  | PROPER COMBUSTION TECHNIQUES              | BACT-OTHER       |
| FLORIDA POWER CORPORATION                   | INTERCESSION CITY   | FL    | 08/17/1992 | TURBINE, OIL                                 | 129 | 22.2  | GOOD COMBUSTION PRACTICES                 | BACT-PSD         |
| TIGER BAY LP                                | FT. MEADE           | FL    | 05/17/1993 | TURBINE, OIL                                 | 231 | 22.5  | WATER INJECTION                           | BACT-PSD         |
| CHARLES LARSEN POWER PLANT                  | CITY OF OF LAKELAND | FL    | 07/25/1991 | TURBINE, OIL, 1 EACH                         | 80  | 25.0  | COMBUSTION CONTROL                        | BACT-PSD         |
| AUBURNDALE POWER PARTNERS, LP               | AUBURNDALE          | FL    | 12/14/1992 | TURBINE, OIL                                 | 146 | 25.0  | GOOD COMBUSTION PRACTICES                 | BACT-PSD         |
| HARTWELL ENERGY LIMITED PARTNERSHIP         | HARTWELL            | GA    | 07/28/1992 | TURBINE, OIL FIRED (2 EACH)                  | 230 | 25.0  | FUEL SPEC: CLEAN BURNING FUELS            | BACT-PSD         |
| SELKIRK COGENERATION PARTNERS, L.P.         | SELKIRK             | NY    | 06/18/1992 | COMBUSTION TURBINE (79 MW)                   | 147 | 25.0  | COMBUSTION CONTROL                        | BACT-OTHER       |
| LAKEWOOD COGENERATION, L.P.                 | LAKEWOOD TOWNSHIP   | NJ    | 04/01/1991 | TURBINES (#2 FUEL OIL) (2)                   | 149 | 25.4  | COMBUSTOR WATER INJECTOR, WATER INJECTION | BACT-PSD         |
| SARANAC ENERGY COMPANY                      | PLATTSBURGH         | NY    | 07/31/1992 | BURNERS, DUCT (2)                            | 69  | 25.4  | COMBUSTION DESIGN                         | BACT-PSD         |
| NEWARK BAY COGENERATION PARTNERSHIP         | NEWARK              | NJ    | 11/01/1990 | TURBINE, KEROSENE FIRED                      | 73  | 26.6  | CATALYTIC OXIDATION                       | BACT-PSD         |
| KISSIMMEE UTILITY AUTHORITY                 | INTERCESSION CITY   | FL    | 04/07/1993 | TURBINE, FUEL OIL                            | 116 | 29.6  | GOOD COMBUSTION PRACTICES                 | BACT-PSD         |
| FLORIDA POWER CORPORATION POLK COUNTY       | BARTOW              | FL    | 02/25/1994 | TURBINE, FUEL OIL (2)                        | 216 | 30.0  | GOOD COMBUSTION PRACTICES                 | BACT-PSD         |
| MID-GEORGIA COGEN.                          | KATHLEEN            | GA    | 04/03/1996 | COMBUSTION TURBINE (2), FUEL OIL             | 116 | 30.0  | WATER INJECTION                           | BACT-OTHER       |
| FLORIDA POWER GENERATION                    | DEBARY              | FL    | 10/18/1991 | TURBINE, OIL, 6 EACH                         | 93  | 30.7  | GOOD COMBUSTION                           | BACT-PSD         |
| FLORIDA POWER AND LIGHT                     | NORTH PALM BEACH    | FL    | 06/05/1991 | TURBINE, OIL, 2 EACH                         | 400 | 33.0  | WET INJECTION                             | BACT-PSD         |
| TECO POLK POWER STATION                     | BARTOW              | FL    | 02/24/1994 | TURBINE, FUEL OIL                            | 221 | 40.0  | GOOD COMBUSTION                           | BACT-PSD         |
| UNION ELECTRIC CO                           | WEST ALTON          | MO    | 05/06/1979 | CONSTRUCTION OF A NEW OIL FIRED COMBUSTION   | 78  | 71.9  | GOOD COMBUSTION PRACTICES                 | BACT-PSD         |
| EMPIRE DISTRICT ELECTRIC CO.                | JOPLIN              | MO    | 05/17/1994 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES        | 168 | 92.6  | COMBUSTION DESIGN                         | BACT-PSD         |
| ECOELECTRICA, L.P.                          | PENUELAS            | PR    | 10/01/1996 | TURBINES, COMBINED-CYCLE COGENERATION        | 461 | 100.0 | COMBUSTION DESIGN                         | BACT-PSD         |
| FULTON COGEN PLANT                          | FULTON              | NY    | 09/15/1994 | GE LM5000 GAS TURBINE                        | 63  | 107.0 | NO CONTROLS                               | BACT-OTHER       |
| CAROLINA POWER AND LIGHT                    | HARTSVILLE          | SC    | 08/31/1994 | STATIONARY GAS TURBINE                       | 190 | 115.2 | COMBUSTION DESIGN                         | BACT-PSD         |

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some PPM values were calculated using a conversion factor based on the F-Factor and molecular weight of CO: 1 (PPM) = (lb/mmBtu) \* 423

lb/mmBtu values were also calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Fuel Oil) - SO<sub>2</sub>**

| FACILITY  | CITY              | STATE | PERMIT     | PROCESS                                      | MW <sup>1</sup> | lb/mmBtu <sup>2</sup> | CTRLDESC                                   | BASIS     |
|---|-------------------|-------|------------|--|-----------------|-----------------------|--|-----------|
| GORHAM ENERGY LIMITED PARTNERSHIP                 | GORHAM            | ME    | 12/04/1998 | TURBINE, COMBINED CYCLE                      | 900             | 0.0068                | 0.05% SULFUR DISTILLATE OIL #2 USED.       | BACT-PSD  |
| MOJAVE COGENERATION CO.                           |                   | CA    | 01/12/1989 | TURBINE, GAS                                 | 81              | 0.0012                | FUEL SPEC: OIL FIRING LIMITED TO 11 H/D    | BACT-PSD  |
| TECO POLK POWER STATION                           | BARTOW            | FL    | 02/24/1994 | TURBINE, FUEL OIL                            | 221             | 0.048                 | FUEL SPEC: LOW SULFUR FUEL OIL             | BACT-PSD  |
| VIRGINIA POWER                                    |                   | VA    | 09/07/1989 | TURBINE, GAS                                 | 164             | 0.051                 | FUEL SPEC: 0.06% BY WT ANN AVG S FUEL, G   | BACT-PSD  |
| WI ELECTRIC POWER CO.                             | CONCORD STATION   | WI    | 10/18/1990 | TURBINES, COMBUSTION, SIMPLE CYCLE, 4        | 75              | 0.052                 | FUEL SPEC: 0.05% S OIL ALLOWED ONLY IF NA  | BACT-PSD  |
| FLORIDA POWER CORPORATION POLK COUNTY SITE        | BARTOW            | FL    | 02/25/1994 | TURBINE, FUEL OIL (2)                        | 216             | 0.054                 | FUEL SPEC: LOW SULFUR FUEL OIL (MAX 0.05   | BACT-PSD  |
| KISSIMEE UTILITY AUTHORITY                        | INTERCESSION CITY | FL    | 04/07/1993 | TURBINE, FUEL OIL                            | 116             | 0.056                 | FUEL SPEC: LOW SULFUR FUEL                 | BACT-PSD  |
| AUBURNDALE POWER PARTNERS, LP                     | AUBURNDALE        | FL    | 12/14/1992 | TURBINE, OIL                                 | 146             | 0.060                 | FUEL SPEC: LOW SULFUR FUEL OIL             | BACT-RSD  |
| BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT         | PERRYMMAN         | MD    |            | TURBINE, 140 MW OIL FIRED ELECTRIC           | 140             | 0.078                 | FUEL SPEC: LOW SULFUR OIL (0.05%)          | BACT-PSD  |
| GAINESVILLE REGIONAL UTILITIES                    | GAINESVILLE       | FL    | 04/11/1995 | OIL FIRED COMBUSTION TURBINE                 | 74              | 0.090                 | FUEL SPEC: LOW S OIL 0.05% S               | BACT-PSD  |
| THE DEXTER CORP.                                  | WINDSOR LOCKS     | CT    | 09/29/1989 | TURBINE, NAT GAS & #2 FUEL OIL FIRED         | 69              | 0.12                  | FUEL SPEC: LOW SULFUR FUEL - 0.28%         | BACT-PSD  |
| CAROLINA POWER & LIGHT                            | GOLDSBORO         | NC    | 04/11/1996 | COMBUSTION TURBINE, 4 EACH                   | 238             | 0.16                  | FUEL SPEC: 0.15% S FUEL OIL                | BACT-PSD  |
| O'BRIEN COGENERATION                              | HARTFORD          | CT    | 08/08/1988 | TURBINE, GAS FIRED                           | 62              | 0.19                  | FUEL SPEC: LOW S OIL, ANNUAL FUEL LIMIT    | BACT-PSD  |
| DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION | LOWESVILLE        | NC    | 12/20/1991 | TURBINE, COMBUSTION                          | 156             | 0.19                  | FUEL SPEC: 0.2% SULFUR FUEL OIL            | BACT-PSD  |
| PANDA-ROSEMARY CORP.                              | ROANOKE RAPIDS    | NC    | 09/06/1989 | TURBINE, COMBUSTION, #7 FRAME                | 133             | 0.21                  | FUEL SPEC: LOW S FUEL                      | BACT-PSD  |
| HOPEWELL COGENERATION LIMITED PARTNERSHIP         |                   | VA    | 07/01/1988 | TURBINE, OIL FIRED, 3 EA                     | 129             | 0.21                  | FUEL SPEC: SULFUR CONTENT OF FUEL          | BACT-PSD  |
| BEAR ISLAND PAPER COMPANY, L.P.                   | ASHLAND           | VA    | 10/30/1992 | TURBINE, COMBUSTION GAS                      | 59              | 0.21                  | FUEL SPEC: LOW SULFUR FUEL                 | BACT-PSD  |
| FLORIDA POWER CORPORATION                         | INTERCESSION CITY | FL    | 08/17/1992 | TURBINE, OIL                                 | 129             | 0.22                  | FUEL SPEC: LOW SULFUR FUEL OIL             | BACT-PSD  |
| FLORIDA POWER CORPORATION                         | INTERCESSION CITY | FL    | 08/17/1992 | TURBINE, OIL                                 | 233             | 0.22                  | FUEL SPEC: LOW SULFUR FUEL OIL             | BACT-PSD  |
| DOSWELL LIMITED PARTNERSHIP                       |                   | VA    | 05/04/1990 | TURBINE, COMBUSTION                          | 158             | 0.22                  | USING #2 OIL                               | OTHER     |
| KALAELOE PARTNERS, L.P.                           |                   | HI    | 03/09/1990 | TURBINE, LSFO, 2                             | 225             | 0.27                  |  | BACT-PSD  |
| FLORIDA POWER AND LIGHT                           | NORTH PALM BEACH  | FL    | 06/05/1991 | TURBINE, OIL, 2 EACH                         | 400             | 0.29                  | FUEL SPEC: NO. 2 FUEL OIL                  | BACT-PSD  |
| KENTUCKY UTILITIES COMPANY                        | MERCER            | KY    | 03/10/1992 | TURBINE, #2 FUEL OIL/NATURAL GAS (8)         | 188             | 0.30                  | FUEL SPEC: LOW SULFUR FUEL (0.3% SULFUR    | BACT-PSD  |
| CAPITOL DISTRICT ENERGY CENTER                    | HARTFORD          | CT    | 10/23/1989 | ENGINE, GAS TURBINE                          | 92              | 0.31                  | FUEL SPEC: LOW S OIL                       | BACT-PSD  |
| VIRGINIA POWER                                    | CHESTERFIELD      | VA    | 04/15/1988 | TURBINE, GE,2 EA                             | 234             | 0.33                  | FUEL SPEC: 0.3% BY WT SULFUR LIMIT ON FUEL | LAER      |
| EAST KENTUCKY POWER COOPERATIVE                   |                   | KY    | 03/24/1993 | TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED | 187             | 0.34                  | FUEL SPEC: LOW SULFUR FUEL (0.3% SULFUR    | SEE NOTES |
| FLORIDA POWER GENERATION                          | DEBARY            | FL    | 10/18/1991 | TURBINE, OIL, 6 EACH                         | 93              | 0.75                  | FUEL SPEC: #2 FUEL OIL                     | BACT-PSD  |

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some lb/mmBtu values were calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results  
Combustion Turbines (Fuel Oil) - PM/PM10**

| FACILITY                                    | CITY                | STATE | PERMIT     | PROCESS  | MW <sup>1</sup> | lb/mmBtu <sup>2</sup> | CTRLDESC                                 | BASIS      |
|---|---------------------|-------|------------|--|-----------------|-----------------------|--|------------|
| SELKIRK COGENERATION PARTNERS, L.P.         | SELKIRK             | NY    | 06/18/1992 | COMBUSTION TURBINES (2) (252 MW)                   | 147             | 0.004                 | 0.5 % SULFUR DISTILLATE OIL #2 IS USED.  | BACT-PSD   |
| KAMINE/BESICORP CARTHAGE L.P.               | CARTHAGE            | NY    | 01/18/1994 | GE FRAME 6 GAS TURBINE                             | 61              | 0.005                 | FUEL SPEC: SULFUR CONTENT NOT TO EXCEED  | BACT-OTHER |
| SAVANNAH ELECTRIC AND POWER CO.             |                     | GA    | 02/12/1992 | TURBINES, 8  | 129             | 0.006                 | FUEL SPEC: FUEL LIMITED AND 0.3 % S      | BACT-PSD   |
| PILGRIM ENERGY CENTER                       | ISLIP               | NY    |            | (2) WESTINGHOUSE W501D5 TURBINES (EP #S 00001&2)   | 175             | 0.007                 | FUEL SPEC: SULFUR CONTENT NOT TO EXCEED  | BACT-OTHER |
| INDECK-OSWEGO ENERGY CENTER                 | OSWEGO              | NY    | 10/06/1994 | GE FRAME 6 GAS TURBINE                             | 67              | 0.008                 | FUEL SPEC: SULFUR CONTENT NOT TO EXCEED  | BACT-OTHER |
| TECO POLK POWER STATION                     | BARTOW              | FL    | 02/24/1994 | TURBINE, FUEL OIL                                  | 221             | 0.009                 | GOOD COMBUSTION                          | BACT-PSD   |
| CAROLINA POWER & LIGHT                      | GOLDSBORO           | NC    | 04/11/1996 | COMBUSTION TURBINE, 4 EACH                         | 238             | 0.009                 | WATER INJECTION FOR NOX EMISSIONS        | BACT-PSD   |
| TECO POLK POWER STATION                     | BARTOW              | FL    | 02/24/1994 | TURBINE, FUEL OIL                                  | 221             | 0.009                 | FUEL SPEC: LOW SULFUR FUEL OIL           | BACT-PSD   |
| FLORIDA POWER CORPORATION                   | INTERCESSION CITY   | FL    | 08/17/1992 | TURBINE, OIL                                       | 233             | 0.009                 | GOOD COMBUSTION PRACTICES                | BACT-PSD   |
| TIGER BAY LP                                | FT. MEADE           | FL    | 05/17/1993 | TURBINE, OIL                                       | 231             | 0.009                 | FUEL SPEC: LOW SULFUR FUEL OIL           | BACT-PSD   |
| PANDA-ROSEMARY CORP.                        | ROANOKE RAPIDS      | NC    | 09/06/1989 | TURBINE, COMBUSTION, #7 FRAME                      | 133             | 0.009                 |  |            |
| FLORIDA POWER CORPORATION POLK COUNTY SITE  | BARTOW              | FL    | 02/25/1994 | TURBINE, FUEL OIL (2)                              | 216             | 0.010                 | GOOD COMBUSTION PRACTICES                | BACT-PSD   |
| GAINESVILLE REGIONAL UTILITIES              | GAINESVILLE         | FL    | 04/11/1995 | SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL B-UP | 74              | 0.012                 | FUEL SPEC: LOW SULFUR FUEL               | BACT-OTHER |
| SAVANNAH ELECTRIC AND POWER CO.             |                     | GA    | 02/12/1992 | TURBINES, 8  | 122             | 0.012                 | FUEL SPEC: LOW SULFUR FUEL OIL           | BACT-PSD   |
| OKLAHOMA MUNICIPAL POWER AUTHORITY          | PONCA CITY          | OK    | 12/17/1992 | TURBINE, COMBUSTION                                | 58              | 0.013                 | FUEL SPEC: USE OF DISTILLATE FUEL        | BACT-OTHER |
| CAROLINA POWER AND LIGHT                    | HARTSVILLE          | SC    | 08/31/1994 | STATIONARY GAS TURBINE                             | 190             | 0.014                 | 0.05% SULFUR DISTILLATE OIL #2 USED.     | BACT-PSD   |
| FLORIDA POWER CORPORATION                   | INTERCESSION CITY   | FL    | 08/17/1992 | TURBINE, OIL                                       | 129             | 0.015                 | GOOD COMBUSTION PRACTICES                | BACT-PSD   |
| HARTWELL ENERGY LIMITED PARTNERSHIP         | HARTWELL            | GA    | 07/28/1992 | TURBINE, OIL FIRED (2 EACH)                        | 230             | 0.016                 | FUEL SPEC: CLEAN BURNING FUELS           | BACT-PSD   |
| COMMONWEALTH ATLANTIC LTD PARTNERSHIP       | CHESAPEAKE          | VA    | 03/05/1991 | TURBINE, NAT GAS & #2 OIL                          | 175             | 0.016                 | FUEL SPEC: LOW ASH FUEL, GRADE 76 #2 OIL | BACT-PSD   |
| ECELECTRICA, L.P.                           | PENUELAS            | PR    | 10/01/1996 | TURBINES, COMBINED-CYCLE COGENERATION              | 461             | 0.016                 | FUEL SPEC: 0.2% SULFUR FUEL OIL          | BACT-PSD   |
| KISSIMEE UTILITY AUTHORITY                  | INTERCESSION CITY   | FL    | 04/07/1993 | TURBINE, FUEL OIL                                  | 116             | 0.016                 | FUEL SPEC: LOW SULFUR FUEL OIL           | BACT-PSD   |
| FLORIDA POWER AND LIGHT                     | NORTH PALM BEACH    | FL    | 06/05/1991 | TURBINE, OIL, 2 EACH                               | 400             | 0.019                 | MAX WATER INJECTION                      | BACT-PSD   |
| FLORIDA POWER GENERATION                    | DEBARY              | FL    | 10/18/1991 | TURBINE, OIL, 6 EACH                               | 93              | 0.020                 | WATER INJECTION                          | BACT-PSD   |
| NEWARK BAY COGENERATION PARTNERSHIP, L.P.   | NEWARK              | NJ    | 06/09/1993 | TURBINES, COMBUSTION, KEROSENE-FIRED (2)           | 80              | 0.023                 |  | BACT-PSD   |
| FULTON COGEN PLANT                          | FULTON              | NY    | 09/15/1994 | GE LM5000 GAS TURBINE                              | 63              | 0.024                 | FUEL SPEC: SULFUR CONTENT NOT TO EXCEED  | BACT-OTHER |
| CHARLES LARSEN POWER PLANT                  | CITY OF OF LAKELAND | FL    | 07/25/1991 | TURBINE, OIL, 1 EACH                               | 80              | 0.025                 | COMBUSTION CONTROL                       | BACT-PSD   |
| LAKEWOOD COGENERATION, L.P.                 | LAKEWOOD TOWNSHIP   | NJ    | 04/01/1991 | TURBINES (#2 FUEL OIL) (2)                         | 149             | 0.026                 | FUEL SPEC: LOW SULFUR OIL (0.05%)        | BACT-PSD   |
| EMPIRE DISTRICT ELECTRIC CO.                | JOPLIN              | MO    | 05/17/1994 | INSTALL TWO NEW SIMPLE-CYCLE TURBINES              | 168             | 0.028                 | FUEL SPEC: 0.2% SULFUR FUEL OIL          | BACT-PSD   |
| KAMINE/BESICORP BEAVER FALLS COGENERATION F | BEAVER FALLS        | NY    | 11/09/1992 | TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW)   | 81              | 0.030                 | COMBUSTION CONTROLS                      | BACT-OTHER |
| PANDA-ROSEMARY CORP.                        | ROANOKE RAPIDS      | NC    | 09/06/1989 | TURBINE, COMBUSTION, #6 FRAME                      | 64              | 0.033                 |  |            |
| HOPEWELL COGENERATION LIMITED PARTNERSHIP   |                     | VA    | 07/01/1988 | TURBINE, OIL FIRED, 3 EA                           | 129             | 0.034                 |  | BACT-PSD   |
| CAPITOL DISTRICT ENERGY CENTER              | HARTFORD            | CT    | 10/23/1989 | ENGINE, GAS TURBINE                                | 92              | 0.035                 |  |            |
| EAST KENTUCKY POWER COOPERATIVE             |                     | KY    | 03/24/1993 | TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED       | 187             | 0.036                 | PROPER COMBUSTION TECHNIQUES             | BACT-OTHER |
| KALAELOE PARTNERS, L.P.                     |                     | HI    | 03/09/1990 | TURBINE, LSFO, 2                                   | 225             | 0.044                 |  | BACT-PSD   |
| KENTUCKY UTILITIES COMPANY                  | MERCER              | KY    | 03/10/1992 | TURBINE, #2 FUEL OIL/NATURAL GAS (8)               | 188             | 0.045                 | COMBUSTION CONTROL                       | BACT-PSD   |
| AUBURNDALE POWER PARTNERS, LP               | AUBURNDALE          | FL    | 12/14/1992 | TURBINE, OIL                                       | 146             | 0.047                 | GOOD COMBUSTION PRACTICES                | BACT-PSD   |
| PEABODY MUNICIPAL LIGHT PLANT               | PEABODY             | MA    | 11/30/1989 | TURBINE, 38 MW OIL FIRED                           | 52              | 0.050                 | QUIET COMBUSTION AND WATER INJECTION     | BACT-PSD   |
| MID-GEORGIA COGEN.                          | KATHLEEN            | GA    | 04/03/1996 | COMBUSTION TURBINE (2), FUEL OIL                   | 116             | 0.059                 | PROPER COMBUSTION TECHNIQUE              | BACT-OTHER |
| UNION ELECTRIC CO                           | WEST ALTON          | MO    | 05/06/1979 | CONSTRUCTION OF A NEW OIL FIRED COMBUSTION TURBINE | 78              | 0.064                 |  | BACT-PSD   |
| MID-GEORGIA COGEN.                          | KATHLEEN            | GA    | 04/03/1996 | COMBUSTION TURBINE (2), FUEL OIL                   | 116             | 55.000                | CLEAN FUEL                               | BACT-PSD   |

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some lb/mmBtu values were calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results  
Cooling Towers - PM/PM10**

| FACILITY                            | CITY             | STATE | PERMIT     | PROCESS                         | EMISSIONS | UNIT          | CTRLDESC                       | % EFF | BASIS      |
|-------------------------------------|------------------|-------|------------|---------------------------------|-----------|---------------|--------------------------------|-------|------------|
| LAKWOOD COGENERATION, L.P.          | LAKWOOD TOWNSHIP | NJ    | 09/04/1992 | COOLING TOWER, MECHANICAL DRAFT | 0.9       | LB/H          | DRIFT ELIMINATOR               |       | BACT-PSD   |
| TEXACO REFINING AND MARKETING, INC. | BAKERSFIELD      | CA    | 01/19/1996 | COOLING TOWER                   | 1.3       | LB/H          | CELLULAR TYPE DRIFT ELIMINATOR | 75.0  | BACT-OTHER |
| CROWN/VISTA ENERGY PROJECT (CVEP)   | WEST DEPTFORD    | NJ    | 10/01/1993 | COOLING TOWER (2)               | 5.9       | LB/H          | DRIFT ELIMINATOR               | 0.0   | BACT-PSD   |
| FLORIDA POWER CORPORATION           | CRYSTAL RIVER    | FL    | 08/30/1990 | COOLING TOWER, 4 EACH           | 0.004     | % OF CIRC WAT | DRIFT ELIMINATOR               |       | BACT-PSD   |

Appendix E-2



Excerpt from::

ENVIRONMENTAL REVIEW OF THE  
CANAL STATION REDEVELOPMENT PROJECT

Tech Environmental, Inc.

June 20, 2000

The SCONOx system uses a catalyst bed to oxidize NO to NO<sub>2</sub> and absorb the NO<sub>2</sub> onto the surface of the catalyst during the “oxidation/absorption” cycle. The catalyst is divided into a number of sections, each of which is equipped with isolation dampers so that some sections can be regenerated while the plant is operating. A catalyst “regeneration” cycle is required periodically and involves passing hydrogen gas mixed with steam over the catalyst surface, producing nitrogen gas and water vapor. Since hydrogen and nitrogen are present in a high temperature environment, the formation of ammonia during the regeneration cycle is likely, since these conditions are similar to the Haber process of nitrogen fixation used to chemically create ammonia.<sup>8</sup> Neither Goal Line nor AAP have presented any test data to prove that SCONOx does not emit ammonia.

---

<sup>8</sup> Hiller and Herber, Principles of Chemistry, McGraw-Hill, 1960, p. 246.

Since small amounts of sulfur dioxide (SO<sub>2</sub>) will blind (contaminate) the catalyst bed and cause it to stop working, SO<sub>2</sub> must be removed upstream of the SCONOx catalyst, and this is accomplished using the SCOSOx system. SCOSOx uses an oxidation/absorption cycle with a separate catalyst and a regeneration cycle with hydrogen gas just as the SCONOx system does.

The sulfur is not however permanently removed from the exhaust gas, but instead is most often re-emitted downstream of the SCONOx catalyst in the form of hydrogen sulfide (H<sub>2</sub>S) and SO<sub>2</sub> according to Goal Line's technical literature.<sup>9</sup> The regeneration chemistry favors H<sub>2</sub>S when operating temperatures are below 500° F, and it favors SO<sub>2</sub> when temperatures are highest. H<sub>2</sub>S is an exceptionally poisonous gas and is hazardous at low concentrations. If a SCONOx/SCOSOx system were to be used on Unit 2, the 134 tons per year of potential SO<sub>2</sub> emissions from the combustion turbines could convert to 71 tons per year of H<sub>2</sub>S if the regeneration cycle did not consistently operate at temperatures above 500° F. Even at high temperatures, some H<sub>2</sub>S emissions may occur. Goal Line and AAP have presented no information on H<sub>2</sub>S concentrations in the exhaust gas leaving a SCONOx/SCOSOx system.

A recent BACT analysis for a large (350 MW) combustion turbine project in the State<sup>10</sup> documented that SCONOx may impose an energy penalty twice that of SCR on a large power-generating unit, namely a 4 MW penalty for the SCONOx system (equipment electrical use, regeneration gas steam, and performance loss due to pressure drop). Coupled with the fact that the claimed zero-ammonia benefit of SCONOx remains undemonstrated and the likelihood that SCONOx creates another toxic air pollutant, hydrogen sulfide (H<sub>2</sub>S), it has not been proven that SCONOx, on balance, offers environmental and energy benefits over SCR.

SCONOx is installed on only two turbine facilities at present: a single 30 MW gas turbine in Vernon, California owned and operated by a partner in the SCONOx technology and a 5 MW gas turbine at the Genetics Institute (G.I.). Only the Genetics Institute plant is providing independent information on how SCONOx is performing on a commercial turbine application.

---

<sup>9</sup> MacDoonald, R. and Debbage, L., "The SCONOx Catalytic Absorption System for Natural Gas Fired Power Plants," presented at Power-Gen International '97 Dallas, TX, December, 1997, page 8.

<sup>10</sup> Cabot LNG Corporation, "Supplemental BACT Analysis on SCONOx for the Island End Cogeneration Plant," DEP Application MBR-97-COM-014, January 25, 2000.

And, given the overly optimistic information Goal Line has disseminated over the past year about the performance and commercial availability of SCONOx, we believe the Genetics Institute test data provide the best source of reliable information on how well SCONOx performs.

At the Northeast Energy and Commerce Association (NECA) meeting that was held on May 16-17, 2000 in Boxboro, the Manager for Environmental Engineering and Compliance at the Genetics Institute, Mr. Robert McGinnis, gave a presentation on how SCONOx is working at his facility. Although it has been nine months since SCONOx was installed and this is the simplest commercial application for SCONOx (a small combustion turbine), there are still unresolved problems with the SCONOx system, and it is not consistently meeting the NO<sub>x</sub> emissions limits promised by Goal Line and written into the facility's permit. In addition, we note that no SCONOx system has ever been built or installed for large (100 MW) turbines.

During the NECA conference, G.I. gave conference attendees a tour of the plant. At the time, the turbine was burning natural gas and the SCONOx system was emitting 9 ppm of NO<sub>x</sub>, or 360% of the 2.5 ppm permit limit. Mr. McGinnis has since determined that the turbine combustors were not properly tuned and the inlet concentration of NO<sub>x</sub> to the SCONOx system was about 50% higher than it was designed for. This incident has, however, revealed that the SCONOx system does not consistently achieve the 90% NO<sub>x</sub> removal rates demonstrated in practice by SCR systems. Mr. McGinnis notes that when the inlet concentration to SCONOx is 20 ppm of NO<sub>x</sub>, the outlet concentration is about 2 ppm (90% removal). However, higher inlet concentrations cause a substantial degradation in SCONOx performance. When fired with distillate oil, the turbine emits about 50 ppm, and SCONOx, thus far, emits 20 ppm of NO<sub>x</sub>, only a 60% removal rate. So far, the SCONOx system has been exceeding the ultimate 15 ppm NO<sub>x</sub> limit for oil-firing in the DEP permit.

If the turbine was not running twice as clean as the manufacturer's guarantee (only 50 ppm of NO<sub>x</sub> versus the guaranteed emissions of 96 ppm), NO<sub>x</sub> emissions from the SCONOx system would be even higher. This same situation carries over to gas-fired operation. Mr. McGinnis

notes that here again the turbine is generally cleaner than expected, emitting only 17 ppm of NO<sub>x</sub> versus 25 ppm guaranteed and helping to lower the NO<sub>x</sub> emitted by SCONOx.

In the past year, the SCONOx unit at G.I. has had a recurring problem with leaking dampers. Goal Line has redesigned the dampers three times. Goal Line has also been washing the catalyst blocks (there are 45 separate modules in the system for this single 5 MW turbine) every 2 to 2-1/2 months, which is more frequently than G.I. expected. Washing involves catalyst block removal, soaking in a potassium carbonate solution, and reinstallation of each block. Not only does catalyst washing involve substantial costs in terms of labor and wastewater disposal, during this maintenance period the turbine unit has to be shutdown. Availability of the turbine unit has been as low as 75% during some months according to G.I. The loss of electrical generation for unscheduled maintenance (e.g., to wash catalysts in order to stay within permit limits) greatly concerns G.I. and raises questions about the commercial reliability of SCONOx for much larger turbines in electric generating stations. Mr. McGinnis summed up the situation by stating that after nine months of experimentation, it is not clear if SCONOx will really work as promised over the long term.

One of the first steps of a BACT analysis, is to determine if a control technology option is "technically feasible." According to U.S. EPA guidance,<sup>11</sup> to be technically feasible a control technology must have been commercially demonstrated, i.e., installed and operated successfully on a source similar to the one under review. As discussed above, SCONOx has not been installed and operated on any large (100+ MW) turbine project similar to the Canal Redevelopment Project, and in the only independent commercial installation to date (a small 5 MW turbine), it has not yet been successful in consistently meeting permit limits. Thus, it is concluded that SCONOx is not technically feasible for the repowering of Unit 2 at Canal Station.

In summary, while SCONOx is a promising new technology being developed for commercial use, it is not the Best Available Control Technology for the repowering of Canal Unit 2 because:

---

<sup>11</sup> U.S. EPA, "New Source Review Workshop Manual," Research Triangle Park, NC, 1990.

- (1) The only independent commercial application of SCONOx on a combustion turbine has not consistently met its ultimate permit emission limits,
- (2) The only independent commercial application of SCONOx on a combustion turbine has not demonstrated a level of reliability, availability and performance equal to that of SCR,
- (3) SCONOx has never been built for, installed and operated on a large (100+ MW) turbine unit,
- (4) SCONOx is not technically feasible for the Project by EPA guidelines,
- (5) It has not been proven that SCONOx, on balance, offers environmental and energy benefits over SCR.

Appendix E-3

# ENGELHARD

101 WOOD AVENUE  
ISELIN, NJ 08830  
732-205-5000

POWER GENERATION SALES:  
ENGELHARD CORPORATION  
2205 CHEQUERS COURT  
BEL AIR, MD 21015  
PHONE 410-569-0297  
FAX 410-569-1841  
E-Mail fred.booth@engelhard.com

---

|   |                  |                                     |
|---|------------------|-------------------------------------|
| <b>DATE:</b> August 2, 2000                       | <b>NO. PAGES</b> | <b>3</b>                            |
| <b>TO:</b> TRC ENVIRONMENTAL<br>ATTN: Dave Shotts |                  | via e-mail                          |
| <b>ATTN:</b> ENGELHARD<br>Nancy Ellison           |                  |                                     |
| <b>FROM:</b> Fred Booth                           |                  | Ph 410-569-0297 // FAX 410-569-1841 |

---

**RE: GE 7FA Combined Cycle Project  
CO Catalyst - Engelhard Budgetary Proposal EPB00893**

We provide Engelhard Budgetary Proposal EPB00893 for One (1) Engelhard **Camet**<sup>®</sup> CO Catalyst system for the above project. This is per e-mail request on August 1, 2000.

Catalyst selection and pricing are based on:

- Given Data for Siemens V84.2 combustion turbine;
- CO reduction from noted inlet levels to 2 ppmvd @ 15% O<sub>2</sub> (NG) and 4 ppmvd @ 15% O<sub>2</sub> (Oil);
- Three (3) year Performance Guarantee - expected life 5 – 7 years;
- Meet assumed HRSG inside liner dimensions of 67 ft H x 26 ft W;
- Scope: Normal to HRSG supplier - Catalyst modules with internal frame and tongue seals with interface engineering only.
- By others: Duct / catalyst housing (including any transitions), internal insulation, grooved internal liner sheets, and frame supports and bottom pedestals are provided by others, along with catalyst loading door, personnel manway and sample ports.

We request the opportunity to work with you on this project.

Sincerely yours,

ENGELHARD CORPORATION



Frederick A. Booth  
Senior Sales Engineer



**ENGELHARD CORPORATION**  
**CAMET® CATALYTIC OXIDATION SYSTEM**

Engelhard Corporation, ("Engelhard"), offers to supply the CAMET® metal substrate catalytic oxidation system ("CO System") based upon Buyer's technical data and site conditions provided.

**DELIVERABLES:** Equipment and services consisting of:

1. Catalyst modules;
2. Removable and replaceable sample catalysts;
3. Internal support frame and internal tongue seals;
4. Drawings showing installation details, loadings, and support requirements;
5. Installation and operating manuals;
6. Technical service for inspection of equipment installation performed by others - Five (5) days total and two (2) trips are provided.

|                                      |                                     |
|--------------------------------------|-------------------------------------|
| <b><u>BUDGET PRICE:</u></b> Per Unit | Delivery: FOB, plant gate, job site |
| CO System                            | \$ 560,000 – Per Turbine            |
| Replacement CO Catalyst Modules      | \$ 480,000 – Per Turbine            |

**SPENT CATALYST**

Engelhard agrees to support buyer's efforts in the disposal of spent catalyst and potential metal reclaim from spent catalyst. The catalyst proposed contains platinum group metals, and unless contaminated in operation by others, is not a hazardous material. Buyer may receive credit for recovered platinum metals based upon the quantity of platinum group metals recovered and the world price of platinum group metals then in effect, net of recovery cost and disposal costs.

**WARRANTY AND GUARANTEE:**

|                        |  |
|------------------------|--|
| Mechanical Warranty:   | Twelve (12) months from date of start up or eighteen (18) months from date of delivery, whichever is earlier.  |
| Performance Guarantee: | Thirty-six (36) months of operation from date of start up provided start up is no later than ninety (90) days from date of delivery. Catalyst warranty is prorated over the guaranteed life. |
| Expected Life:         | Five – Seven Years   |

**DOCUMENT / MATERIAL DELIVERY SCHEDULE**

|                       |  |
|-----------------------|--|
| Drawings for Approval | 3 – 4 weeks after notice to proceed with complete engineering specifications and Engelhard receipt of all engineering details. |
| Frame and Seals       | 16 weeks after release   |
| Catalyst Modules      | 20 - 24 weeks after release  |

**CO SYSTEM DESIGN BASIS:**

|                                      |   |
|--------------------------------------|---|
| Gas Flow from:                       | GE 7FA Combustion Turbine   |
| Gas Flow:                            | Assumed Horizontal  |
| Fuel:                                | Natural Gas and Oil   |
| Gas Flow Rate (At catalyst face):    | Gas Velocities must be within $\pm 25\%$ of the mean velocity at the catalyst face  |
| Temperature (At catalyst face):      | All Gas Temperatures must be within $\pm 20^{\circ}\text{F}$ of given average temperatures at all points at the catalyst face |
| CO Concentration (At catalyst face): | See Performance Data  |
| CO Outlet:                           | To 2 ppmvd @ 15% O <sub>2</sub> (NG) / 4 ppmvd @ 15% O <sub>2</sub> (NG)  |



# ENGELHARD

TRC  
CO Oxidation Catalyst – GE 7FA Combined Cycle  
Engelhard Budgetary Proposal EPB00893  
August 2, 2000

## CATALYST MODULES


The CO Catalyst is manufactured with a special stainless steel foil substrate which is corrugated and coated with an alumina washcoat. The washcoat is impregnated with platinum group metals. The catalyzed foil is folded and encased in welded steel frames, approximately 2 ft. square, to form individual modules. Two of the modules are provided with four (4) replaceable test buttons; eight (8) total buttons provided.

## INTERNAL SUPPORT FRAME & SEALS

The internal support frame and internal tongue seals are fabricated from standard structural steel members and shapes. Mechanical tongue and groove expansion seals around the perimeter of the frame and inside the liner sheet prevent bypass around the catalyst. Design accommodates movement of the frame due to thermal expansion while maintaining a continuous seal. The internal frame system interfaces with two types of customer provided connections; ductplate mounted slide plates and liner sheet grooves, both designed by Engelhard.

### Dimensions:

|                        |     |          |
|------------------------|-----|----------|
| Inside Liner Width     | (A) | 26 ft    |
| Inside Liner Height    | (B) | 67 ft    |
| Catalyst + frame depth | (C) | 18" est. |



## Table A - Performance Data

Refer to separate attachment – file TRC-GE7FA-DATA-080200-ENGELHARD-CO-0.xls

From: Howard Hurwitz [hhurwitz@roe.com]  
Sent: Tuesday, July 25, 2000 8:46 AM  
To: llabrie@trccos.com  
Cc: sfinnerty@cpowerventures.com; Nabil Keddis  
Subject: SCR cost information

Larry: Information from Engelhard Corporation, supplier of SCR catalyst for combustion turbine applications, is as follows

Scope of Supply

Internal catalyst support frames - installed inside internally insulated casing (by others)

NOxCat SCR catalyst modules

Ammonia Delivery System including AIG, manifold with flow control valves, air dilution skid, controls, etc.

Excluding

Ammonia Storage Tank

HRSG Casing

Field piping

Foundations

Utilities

Cost Information

SCR System Described Above - \$950,000

Ammonia Storage Tank - \$110,000

Replacement Catalyst (3 year life guarantee) - \$520,000

Please let me know if this is sufficient information.

Howard Hurwitz  
Burns and Roe Enterprises  
(201) 986-4311

From: Nabil Keddis [nkeddis@roe.com]  
Sent: Wednesday, July 26, 2000 9:29 AM  
To: llabrie@trccos.com  
Cc: Sfinnrty@cpowerventures.com  
Subject: CPV- Gule Coast Project; Cost Estimate for Sconox Equipment

Lari:

The following information was verbally provided by ABB, as a cost estimate basis for the SCONox equipment (manufactured by Goalline), based on the following parameters:

a) Natural Gas firing

Emission: NOx  
Current: 9.0 ppmvd, 61.00 lb/hr  
Required: 3.0 ppmvd, 20.00 lb/hr  
Estimated Cost: \$ 14,000,000.00

b) Oil Firing (with water injection)

Emission: NOx  
Current: 42.0 ppmvd, 341.00 lb/hr  
Required: 10.0 ppmvd, 81.00 lb/hr  
Estimated Cost: \$ 16,000,000.00

The delivery schedule for the equipment is: 8 - 10 months.

The estimated cost of installation is: \$ 1,500,000.00

Duration for installation is approximately 60 (sixty) days.

As soon as I receive ABB quotation I'll forward a copy to you and Sean.

## Cost Quote Provided by Alstom-ABB

### Sconox Base

**Direct Costs**

|                           |                      |
|---------------------------|----------------------|
| a) Capital Cost           | \$ 14,000,000        |
| b) Taxes (3%)             | \$ 420,000           |
| c) Freight (4%)           | \$ -                 |
| <hr/>                     |                      |
| Purchased Equip Cost      | \$ 14,420,000        |
| Installation              | \$ 1,700,000         |
| <b>Total Direct Costs</b> | <b>\$ 16,120,000</b> |

|                   |            |
|-------------------|------------|
| Engineering Costs | \$ 200,000 |
| Contingency       | \$ 250,000 |
| <hr/>             |            |

**Total Capital Investment**                   \$ 16,570,000

**Direct Annual Costs**

|                      |            |
|----------------------|------------|
| Maintenance          | \$ 331,400 |
| Steam & Natural Gas  | \$ 406,400 |
| Pressure Drop        | \$ 129,360 |
| Catalyst Replacement | \$ 190,000 |
| <hr/>                |            |

**Total Annual Direct Costs**               \$ 1,057,160

**Indirect Annual Costs**

|                |            |                    |
|----------------|------------|--------------------|
| Overhead       | \$ 198,840 | 60% of maintenance |
| Property Tax   | \$ 0       | No property taxes  |
| Insurance      | \$ 165,700 | 1% of TCI          |
| Administration | \$ 125,000 |                    |
| <hr/>          |            |                    |

**Total Annual Investment**               \$ 1,546,700

Capital Recovery Factor                   0.1424      10 yrs & 7% interest

|                        |               |
|------------------------|---------------|
| Total Capital Required | \$ 16,570,000 |
| Total Annual Costs     | \$ 1,546,700  |
| <hr/>                  |               |

**Total Annualized Costs**               **\$ 3,906,268**

Appendix E-4



**Table E-2. CPV Gulf Coast  
SCONOX to achieve 3.5 ppm NO<sub>x</sub>**

| <b>COST COMPONENT</b>  | <b>COST</b>       |
|--|-------------------|
| <b>DIRECT COSTS</b>  |                   |
| <i>Purchased Equipment Costs</i>   |                   |
| SCONOX System  | 16,000,000        |
| Sales Tax (6% of equipment costs)  | 960,000           |
| Freight (4% of equipment costs)  | 640,000           |
| <i>Subtotal-Purchased Equipment Costs (PEC)</i>  | 17,600,000        |
| <i>Direct Installation Costs</i>   |                   |
| Construction   | 1,700,000         |
| <b>TOTAL DIRECT COSTS (TDC)</b>  | <b>19,300,000</b> |
| <b>INDIRECT INSTALLATION COSTS</b>   |                   |
| Engineering Costs  | 200,000           |
| <b>CONTINGENCY (20% of Direct and Indirect Costs)</b>  | <b>3,900,000</b>  |
| <b>TOTAL CAPITAL INVESTMENT (TCI)</b>  | <b>23,400,000</b> |
| <b>DIRECT ANNUAL COSTS</b>   |                   |
| Maintenance Materials and Labor  | 331,400           |
| Regeneration Natural Gas and Steam   | 406,400           |
| Catalyst Pressure Derate   | 129,360           |
| Catalyst Replacment  | 190,000           |
| <b>TOTAL ANNUAL DIRECT COSTS</b>   | <b>1,057,160</b>  |
| <b>INDIRECT ANNUAL COSTS</b>   |                   |
| Overhead (60% of maintenance materials and labor)  | 198,840           |
| Property Tax (1% of TCI)   | 234,000           |
| Insurance (1% of TCI)  | 234,000           |
| Administration (2% of TCI)   | 468,000           |
| <b>TOTAL INDIRECT ANNUAL COSTS</b>   | <b>1,134,840</b>  |
| <b>TOTAL ANNUAL INVESTMENT</b>   | <b>2,192,000</b>  |
| <b>CAPITAL RECOVERY FACTOR, <math>CFR = (i * (1+i)^n) / ((1+i)^n - 1)</math></b><br>Equipment Life (years) = 10<br>Interest Rate (%) = 8 |                   |
| Capital Recovery Factor  | 0.1490            |
| <b>CAPITAL RECOVERY COSTS</b>  |                   |
| <b>TOTAL CAPITAL REQUIREMENT</b>   | <b>23,400,000</b> |
| <b>TOTAL ANNUAL CAPITAL REQUIREMENT</b>  | <b>3,487,290</b>  |
| <b>TOTAL ANNUALIZED COST</b><br>(Total annual O&M cost and annualized capital cost)  | <b>5,679,290</b>  |
| <b>BASELINE POTENTIAL NO<sub>x</sub> EMISSIONS (TPY) FROM TURBINE</b><br>(emissions based on 100% load at 72°F)                          |                   |
| <b>Uncontrolled</b>  | <b>345</b>        |
| <b>Controlled</b>  | <b>117</b>        |
| <b>ANNUAL TONS OF NO<sub>x</sub> REMOVED</b>   | <b>228</b>        |
| <b>COST-EFFECTIVENESS</b>  |                   |
| <b>ENVIRONMENTAL BASIS</b><br>(\$ per ton of NO <sub>x</sub> removed)  | <b>24,916</b>     |

| <b>Table E-3. CPV Gulf Coast<br/>CO Catalyst</b>   |   | <b>COST COMPONENT</b> | <b>COST</b>        |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
|--|---|-----------------------|--------------------|---|--|---------|---|--|--------|---|--|------|----------------------|--|-----------|----------------------------|--|---|-----------------|--|--|
| <b>DIRECT COSTS</b>  |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Purchased Equipment Costs  |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| CO Catalyst (Engelhard Budgetary Quote)  |   |                       | \$560,000          |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Sales Tax (6% of purchased equipment costs)  |   |                       | \$33,600           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Freight (4% of purchased equipment costs)  |   |                       | \$22,400           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Subtotal-Purchased Equipment Costs (PEC)   |   |                       | \$616,000          |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Direct Installation Costs  |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Installation/Foundation (35% of Catalyst Capital Cost)   |   |                       | \$196,000          |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Subtotal-Direct Installation Costs   |   |                       | \$196,000          |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL DIRECT COSTS (TDC)</b>  |   |                       | <b>\$812,000</b>   |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>INDIRECT INSTALLATION COSTS</b>   |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Engineering Costs (5% of PEC)  |   |                       | \$30,800           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Contingency (20% of TDC)   |   |                       | \$162,400          |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL INDIRECT COSTS</b>  |   |                       | <b>\$193,200</b>   |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL CAPITAL INVESTMENT (TCI)</b>  |   |                       | <b>\$1,005,200</b> |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>DIRECT ANNUAL COSTS</b>   |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <table border="0" style="width: 100%;"> <tr> <td style="width: 10%; text-align: center;">100%</td> <td style="width: 5%;">Capacity factor</td> <td style="width: 85%;"></td> </tr> <tr> <td style="text-align: center;">8,760</td> <td>Equivalent Operating Hours per Year (per CTG)</td> <td></td> </tr> <tr> <td style="text-align: center;">720</td> <td>Oil-Fired operating hours/year</td> <td></td> </tr> </table>   |   |                       | 100%               | Capacity factor                                       |  | 8,760   | Equivalent Operating Hours per Year (per CTG) |  | 720    | Oil-Fired operating hours/year                  |  |      |                      |  |           |                            |  |   |                 |  |  |
| 100%   | Capacity factor                                       |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 8,760  | Equivalent Operating Hours per Year (per CTG)         |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 720  | Oil-Fired operating hours/year                        |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Maintenance Materials and Labor (2% of TCI)  |   |                       | \$20,104           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Replacement Catalyst (3 Year Service Life)   |   |                       | \$160,000          |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <table border="0" style="width: 100%;"> <tr> <td style="width: 10%; text-align: center;">\$ 480,000</td> <td style="width: 5%;">* Capital Recovery Factor (0.3880 for n = 3 &amp; i = 8%)</td> <td style="width: 85%;"></td> </tr> <tr> <td style="text-align: center;">3</td> <td>Guaranteed catalyst life</td> <td></td> </tr> </table>  |   |                       | \$ 480,000         | * Capital Recovery Factor (0.3880 for n = 3 & i = 8%) |  | 3       | Guaranteed catalyst life                      |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| \$ 480,000   | * Capital Recovery Factor (0.3880 for n = 3 & i = 8%) |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 3  | Guaranteed catalyst life                              |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Pressure Drop Derate (Lost Revenue From Sale Of Power)   |   |                       | \$101,178          |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <table border="0" style="width: 100%;"> <tr> <td style="width: 10%; text-align: center;">0.7</td> <td style="width: 5%;">Pressure drop across catalyst, inches H2O</td> <td style="width: 85%;"></td> </tr> <tr> <td style="text-align: center;">206,300</td> <td>Full load CTG output (annual average), kW</td> <td></td> </tr> <tr> <td style="text-align: center;">275</td> <td>Output reduction for pressure drop, kW/inch H2O</td> <td></td> </tr> <tr> <td style="text-align: center;">193</td> <td>kW derate</td> <td></td> </tr> <tr> <td style="text-align: center;">1,686,300</td> <td>kW-hr output lost per year</td> <td></td> </tr> <tr> <td style="text-align: center;">6</td> <td>cents per kW-hr</td> <td></td> </tr> </table> |   |                       | 0.7                | Pressure drop across catalyst, inches H2O             |  | 206,300 | Full load CTG output (annual average), kW     |  | 275    | Output reduction for pressure drop, kW/inch H2O |  | 193  | kW derate            |  | 1,686,300 | kW-hr output lost per year |  | 6 | cents per kW-hr |  |  |
| 0.7  | Pressure drop across catalyst, inches H2O             |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 206,300  | Full load CTG output (annual average), kW             |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 275  | Output reduction for pressure drop, kW/inch H2O       |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 193  | kW derate   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 1,686,300  | kW-hr output lost per year                            |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 6  | cents per kW-hr                                       |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Fuel Penalty (Increase Fuel Consumption due to back pressure heat rate impact)   |   |                       | \$36,596           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <table border="0" style="width: 100%;"> <tr> <td style="width: 10%; text-align: center;">1.807E+09</td> <td style="width: 5%;">Annual CTG output, kW-hr</td> <td style="width: 85%;"></td> </tr> <tr> <td style="text-align: center;">9</td> <td>Btu/kW-hr</td> <td></td> </tr> <tr> <td style="text-align: center;">16,265</td> <td>mmBtu/yr natural gas</td> <td></td> </tr> <tr> <td style="text-align: center;">2.25</td> <td>\$/mmBtu natural gas</td> <td></td> </tr> </table>   |   |                       | 1.807E+09          | Annual CTG output, kW-hr                              |  | 9       | Btu/kW-hr                                     |  | 16,265 | mmBtu/yr natural gas                            |  | 2.25 | \$/mmBtu natural gas |  |           |                            |  |   |                 |  |  |
| 1.807E+09  | Annual CTG output, kW-hr                              |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 9  | Btu/kW-hr   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 16,265   | mmBtu/yr natural gas                                  |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 2.25   | \$/mmBtu natural gas                                  |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Catalyst Disposal  |   |                       | \$16,667           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <table border="0" style="width: 100%;"> <tr> <td style="width: 10%; text-align: center;">\$ 50,000</td> <td style="width: 5%;">at the end of catalyst guaranteed life</td> <td style="width: 85%;"></td> </tr> </table>  |   |                       | \$ 50,000          | at the end of catalyst guaranteed life                |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| \$ 50,000  | at the end of catalyst guaranteed life                |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL DIRECT ANNUAL COSTS</b>   |   |                       | <b>\$334,544</b>   |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>INDIRECT ANNUAL COSTS</b>   |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Overhead (60% of labor and maintenance materials)  |   |                       | \$12,062           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Property Tax (1% of TCI)   |   |                       | \$10,052           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Insurance (1% of TCI)  |   |                       | \$10,052           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Administration (2% of TCI)   |   |                       | \$20,104           |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL INDIRECT ANNUAL COSTS</b>   |   |                       | <b>\$52,270</b>    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL ANNUAL COSTS</b>  |   |                       | <b>\$386,815</b>   |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>CAPITAL RECOVERY FACTOR, CFR = <math>(i * (1+i)^n) / ((1+i)^n - 1)</math></b>   |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <table border="0" style="width: 100%;"> <tr> <td style="width: 10%; text-align: center;">10</td> <td style="width: 5%;">Equipment Life (years)</td> <td style="width: 85%;"></td> </tr> <tr> <td style="text-align: center;">8</td> <td>Interest Rate (%)</td> <td></td> </tr> </table>  |   |                       | 10                 | Equipment Life (years)                                |  | 8       | Interest Rate (%)                             |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 10   | Equipment Life (years)                                |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| 8  | Interest Rate (%)                                     |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Capital Recovery Factor  |   |                       | 0.1490             |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>CAPITAL RECOVERY COSTS</b>  |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL CAPITAL REQUIREMENT</b>   |   |                       | <b>\$1,005,200</b> |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL ANNUALIZED CAPITAL REQUIREMENT</b>  |   |                       | <b>\$149,804</b>   |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TOTAL ANNUALIZED COST</b><br>(Total annual O&M cost and annualized capital cost)  |   |                       | <b>\$536,619</b>   |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>BASELINE POTENTIAL CO EMISSIONS (TPY) FROM TURBINE</b>  |   |                       | <b>154</b>         |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Uncontrolled General Electric 7FA Turbine Emissions = 9 ppm on gas for 6040 hr/yr (no power augmentation)/ 15 ppm on gas for 2000 hr/yr (power augmentation)/20 ppm on oil for 720 hr/yr   |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>TONS OF CO REMOVED PER YEAR</b>   |   |                       | <b>123</b>         |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| Controlled General Electric 7FA Turbine Emissions = assume 80% control efficiency  |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>COST-EFFECTIVENESS</b>  |   |                       |                    |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |
| <b>ENVIRONMENTAL BASIS</b><br>(\$ per ton of CO removed)   |   |                       | <b>\$4,350</b>     |   |  |         |   |  |        |   |  |      |                      |  |           |                            |  |   |                 |  |  |