

Barbara / file



# Department of Environmental Protection

Lawton Chiles  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

September 29, 1998

Ms. Mary Archer  
Sr. Environmental Specialist  
Florida Power & Light Company  
Martin Plant  
P.O. Box 176  
Indiantown, FL 34956-0176


Re: Permit No. 0850001-004-AV  
FPL Martin Plant FINAL Title V Permit

Dear Ms. Archer:

We have reviewed your two letters dated July 29, 1998, that requested three administrative changes to the FINAL Title V Permit for the Martin plant. The first request, concerning the replacement of EPA Method 20 with EPA Method 7E, will require an application for an Alternate Sampling Method to implement, pursuant to Rule 297.620, F.A.C. Please send this request to Mr. Michael Harley, the Supervisor of our Emissions Monitoring Section for review. The second request, dealing with the timing of the initial compliance test and initial firing of oil, is acceptable and will be incorporated in the permit. The third request, dealing with NOx testing at one versus four different load conditions, is being evaluated. We will provide status on this item as soon as it is resolved.

If you have any questions concerning these matters, please contact Tom Cascio at 850/921-9526.

Sincerely,

  
Scott M. Sheplak, P.E.  
Administrator  
Title V Section

cc: Michael Harley



Florida Power & Light Company  
Martin Plant, P. O. Box 176, Indiantown, FL 34956-0176

RECEIVED

JUL 31 1998

BUREAU OF  
AIR REGULATION

July 29, 1998

Mr. Scott M. Sheplak, P.E.  
State of Florida  
Department of Environmental Protection  
Division of Air Resources Management  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Re: **Permit No. 0850001-004-AV**  
**FPL Martin Plant Final Title V Permit**

Dear Mr. Sheplak:

After reviewing the subject Title V permit, FPL has identified the following issues which need to be addressed. Each issue is described as follows:

Page 31 of 61. Specific Condition B.23. We request Method 20 be replaced with Method 7E as the test method. The cited method creates inaccuracies in the testing due to the span levels required.


Page 32 of 61. Specific Condition B.27. Please add following the first sentence in this condition "It is not necessary to plan the firing of a fuel solely to complete the initial compliance test, instead, the initial test may be postponed until such time as the untested fuel is ready for service".

Thank you for your assistance in resolving these issues. If you have any questions, please do not hesitate to contact me at (561) 691-7057.

Sincerely,

A handwritten signature in cursive script that reads "Vito Guarnaschi".

Handwritten initials "MA" in cursive.  
Mary Archer  
Sr. Environmental Specialist  
Florida Power & Light Company





Florida Power & Light Company  
Martin Plant, P. O. Box 176, Indiantown, FL 34956-0176

July 29, 1998

Mr. Scott M. Sheplak, P.E.  
State of Florida  
Department of Environmental Protection  
Division of Air Resources Management  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

**Re: Permit No. 0850001-004-AV ADDMUM**  
**FPL Martin Plant Final Title V Permit**

Dear Mr. Sheplak:

An additional administrative type change has been identified and needs to be made to the above referenced permit.

Page 31 Specific Condition B.23. States the NO<sub>x</sub> emissions shall be determined at each of the load conditions specified in 40CFR 60.335(c)(2). This regulation requires testing at four different loads. Several years we negotiated with your Department that testing at only one load would be required. Therefore we request the permit language be revised to include this change.

Thank you for your assistance, if you have any questions, please do not hesitate to contact me at (561) 691-7057.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Mary Archer'.

Mary Archer  
Sr. Environmental Specialist  
Florida Power & Light Company

