

**Friday, Barbara**

---

**To:** iclark@rwbeck.com; Blackburn, Ron; edward.garcia@keysenergy.com

**Cc:** Arif, Syed

**Subject:** DRAFT Title V Permit Renewal #0870003-006-AV-D - Keys Energy Services Stock Island Power Plant

Find attached the zip file for subject DRAFT Title V Permit Renewal for your information and files.

If I may be of further assistance, please feel free to contact me.

Barbara J. Friday  
Planner II  
Bureau of Air Regulation  
(850)921-9524  
[Barbara.Friday@dep.state.fl.us](mailto:Barbara.Friday@dep.state.fl.us)

Note: Mr. Garcia, please publish the Public Notice as soon as possible.

# Memorandum

# Florida Department of Environmental Protection

---


TO: Trina L. Vielhauer  
THRU: Al Linero *aaf*  
FROM: Syed Arif *Syed Arif 9/30*  
DATE: September 30, 2004  
SUBJECT: DRAFT Permit Project No.: 0870003-006-AV  
Keys Energy Services  
Stock Island Power Plant  
Monroe County

Attached is the draft permit package for the Title V Permit Renewal for this facility. The Statement of Basis shows that changes were made to the Acid Rain part of the permit. Retired and New Unit Exemption sections were added to the Acid Rain part. The changes were considered insignificant.

We recommend your approval of the attached draft Title V Permit Renewal.

AAL/sa

Attachments



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Colleen M. Castille  
Secretary

## P.E. Certification Statement

**Permittee:**

Keys Energy Services  
Stock Island Power Plant

**DRAFT Permit No.:** 0870003-006-AV

**Project type:** Title V Air Operation Permit Renewal

*I HEREBY CERTIFY that the engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including but not limited to the electrical, mechanical, structural, hydrological, and geological features).*

*Syed Arif*


Syed Arif, P.E.  
Registration Number: 51861

9/30/2004

Date


Permitting Authority:

Department of Environmental Protection  
Bureau of Air Regulation  
111 South Magnolia Drive, Suite 4  
Tallahassee, Florida 32301  
Telephone: 850/488-0144  
Fax: 850/922-6979



"More Protection, Less Process"

Printed on recycled paper.



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Colleen M. Castille  
Secretary

October 1, 2004

Mr. Daniel Cassel  
Director of Generation  
Keys Energy Services  
1001 James Street  
P.O. Box 6100  
Key West, Florida 33041-6100

Re: Draft Title V Air Operation Permit No. **0870003-006-AV**  
Keys Energy Services – Stock Island Power Plant  
Title V Permit Renewal

Dear Mr. Cassel:

On July 2, 2004, you submitted an application for a Title V air permit renewal to operate Stock Island Power Plant located at 6900 Front Street, Stock Island, Monroe County. Enclosed are the following documents: "Statement of Basis", "DRAFT Permit", "Written Notice of Intent to Issue Title V Air Operation Permit", and "Public Notice of Intent to Issue Title V Air Operation Permit".

The "Statement of Basis" summarizes the Permitting Authority's technical review of the application and provides the rationale for making the preliminary determination to issue a DRAFT Permit. The proposed "DRAFT Permit" includes specific conditions that regulate the emissions units at this facility. The "Written Notice of Intent to Issue Title V Air Operation Permit" provides important information regarding: the Permitting Authority's intent to issue a Title V air operation permit (DRAFT Permit); the requirements for publishing a Public Notice of the Permitting Authority's intent to issue the DRAFT Permit; the procedures for submitting comments on the DRAFT Permit; the requirements for requesting a public meeting; the requirements for filing a petition for an administrative hearing; and the availability of mediation. The "Public Notice of Intent to Issue Title V Air Operation Permit" is the actual notice that you must have published in the legal advertisement section of a newspaper of general circulation in the area affected by this project.

If you have any questions, please contact the Project Engineer, Syed Arif, at 850-921-9528.

Sincerely,

Trina L. Vielhauer, Chief  
Bureau of Air Regulation

Enclosures

*"More Protection, Less Process"*

Printed on recycled paper.

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
 (Domestic Mail Only; No Insurance Coverage Provided)

7430  
1577  
0002  
1140  
7001

**OFFICIAL USE**  
 Mr. Daniel Cassel, Director of Generation

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
<b>Total Postage &amp; Fees</b>	<b>\$</b>

Postmark  
Here

**Sent To**  
 Mr. Daniel Cassel, Director of Generation  
 Street, Apt. No.;  
 or PO Box No. 1001 James Street, P.O. Box 6100  
 City, State, ZIP+4  
 Key West, Florida 33041-6100

**SENDER: COMPLETE** PS Form 3800, January 2001 See Reverse for Instructions /ERY

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:  
 Mr. Daniel Cassel  
 Director of Generation  
 Keys Energy Services  
 1001 James Street  
 P.O. Box 6100  
 Key West, Florida 33041-6100

A. Received by (Please Print Clearly) *[Signature]* B. Date of Delivery *10/5/04*

C. Signature *[Signature]*  Agent  Addressee

D. Is delivery address different from item 1?  Yes  
 If YES, enter delivery address below:  No

3. Service Type  
 Certified Mail  Express Mail  
 Registered  Return Receipt for Merchandise  
 Insured Mail  C.O.D.

4. Restricted Delivery? (Extra Fee)  Yes

2. Article Number (Copy from service label) **7001 1140 0002 1577 7430**

**WRITTEN NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT**

---

*In the Matter of an*

*Application for Title V Air Operation Permit by:*

Mr. Daniel Cassel, Director of Generation  
Keys Energy Services  
1001 James Street  
P.O. Box 6100  
Key West, Florida 33041-6100

DRAFT Air Permit No. **0870003-006-AV**  
Stock Island Power Plant  
Title V Permit Renewal  
Monroe County, Florida

**Facility Location:** The applicant requests a Title V air operation permit (Permit) to operate Stock Island Power Plant located at 6900 Front Street in Stock Island, Monroe County, Florida.

**Project:** On July 2, 2004, the applicant applied to the Permitting Authority for a Permit renewal. The facility consists of five regulated emission units with a total generating capacity of 80.7 MW. There are two regulated diesel generators, three simple cycle combustion turbines, and miscellaneous unregulated units. To reduce pollution, a combination of control techniques is used including water injection, ignition timing retardation, and low sulfur fuel oil. The Ralph Garcia Steam Plant [EPA ID #1] was retired January 1, 1998. Also included in this permit are insignificant emissions units and activities.

This permit will be a Title V Air Operation Permit Renewal to initial Title V Operation Permit issued in 1999 as revised in 2002. The main change compared with the present permit relate to the identification of Retired and New Unit Exemption emission units. The change was considered insignificant.

Emissions from this facility will not be increased as a result of this project. This facility is subject to applicable provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-256, 62-257, 62-281, 62-296, and 62-297, F.A.C.

Details of the project are provided in the in the application and the enclosed "Statement of Basis".

**Permitting Authority:** Applications for Title V air operation permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, and 62-213 and 62-214, Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and an air permit is required to operate the facility. The Department of Environmental Protection, Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination regarding this project. The Permitting Authority's physical address is: Florida Department of Environmental Protection, Bureau of Air Regulation, 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301. The Permitting Authority's mailing address is: Florida Department of Environmental Protection, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Mail Station #5505. The Permitting Authority's telephone number is 850/488-0114 and facsimile number is 850/922-6979.

**Project File:** A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at the address indicated above for the Permitting Authority. The complete project file includes the DRAFT Permit, the Statement of Basis, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may view the DRAFT Permit and file electronic comments by visiting the following website: <http://www.dep.state.fl.us/air/eproducts/ards/>. A copy of the complete project file is also available at the Florida Department of Environmental Protection, Southwest District Office, 3804 Coconut Palm Drive, Tampa, Florida 33619-1352. Telephone: 813/744-6100.

**Notice of Intent to Issue Air Permit:** The Permitting Authority gives notice of its intent to issue a permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of the facility will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-256, 62-257, 62-281, 62-296, and 62-297, F.A.C. The Permitting Authority will issue a PROPOSED Permit and

**Keys Energy Services  
Stock Island Power Plant**

**DRAFT Air Permit No. 0870003-006-AV**

---

**WRITTEN NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT**

---

subsequent FINAL Permit in accordance with the conditions of the DRAFT Permit unless a response received in accordance with the following procedures results in a different decision or a significant change of terms or conditions.

**Public Notice:** Pursuant to Section 403.815, F.S. and Rules 62-110.106 and 62-210.350, F.A.C., you (the applicant) are required to publish at your own expense the enclosed "Public Notice of Intent to Issue Title V Air Operation Permit" (Public Notice). The Public Notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected by this project. The newspaper used must meet the requirements of Sections 50.011 and 50.031, F.S. in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the Permitting Authority at above address or phone number. Pursuant to Rule 62-110.106(5), F.A.C., the applicant shall provide proof of publication to the Permitting Authority at the above address within seven (7) days of publication. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rule 62-110.106(11), F.A.C.

**Comments:** The Permitting Authority will accept written comments concerning the DRAFT Permit for a period of thirty (30) days from the date of publication of this Public Notice. Written comments must be post-marked, and all e-mail or facsimile comments must be received by the close of business (5 pm), on or before the end of this 30-day period by the Permitting Authority at the above address, email or facsimile. As part of his or her comments, any person may also request that the Permitting Authority hold a public meeting on this permitting action. If the Permitting Authority determines there is sufficient interest for a public meeting, it will publish notice of the time, date, and location on the Department's official web site for notices at <http://thora6.dep.state.fl.us/onw> and in a newspaper of general circulation in the area affected by the permitting action. For additional information, contact the Permitting Authority at the above address or phone number. If written comments or comments received at a public meeting result in a significant change to the DRAFT Permit, the Permitting Authority issue a Revised DRAFT Permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.

**Petitions:** A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by the applicant or any of the parties listed below must be filed within fourteen (14) days of receipt of this Written Notice of Intent to Issue Title V Air Operation Permit. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within fourteen (14) days of publication of the attached Public Notice or within fourteen (14) days of receipt of this Written Notice of Intent to Issue Title V Air Operation Permit, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within fourteen (14) days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the

**WRITTEN NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT**

---


address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when each petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so state; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Written Notice of Intent to Issue Title V Air Operation Permit. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

**Mediation:** Mediation is not available in this proceeding.

**Objections:** Finally, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within sixty (60) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to the issuance of any Title V air operation permit. Any petition shall be based only on objections to the Permit that were raised with reasonable specificity during the thirty (30) day public comment period provided in the Public Notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460. For more information regarding EPA review and objections, visit EPA's Region 4 web site at <http://www.epa.gov/region4/air/permits/Florida.htm>.

Executed in Tallahassee, Florida.



Trina L. Vielhauer, Chief  
Bureau of Air Regulation



**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this "Written Notice of Intent to Issue Air Permit" package (including the Public Notice, the Statement of Basis, and the Draft Permit) was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on 10/11/04 to the persons listed below.

Mr. Daniel Cassel, Keys Energy Services\*  
Mr. Ivan Clark, P.E., R.W. Beck, Inc. (iclark@rwbeck.com)  
Mr. Edward Garcia, Keys Energy Services (edward.garcia@keysenergy.com)  
Mr. Ron Blackburn, DEP-SD  
U. S. EPA Region 4

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

Barbara J. Friday 10/11/04  
(Clerk) (Date)

**PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT**

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

DRAFT Title V Major Source Air Operation Permit No. **0870003-006-AV**  
**Stock Island Power Plant**  
Monroe County

**Applicant:** The applicant for this project is Keys Energy Services, 1001 James Street, P.O. Box 6100, Key West, Florida 33041-6100. The applicant's responsible official is Mr. Daniel Cassel, Director of Generation.

**Facility Location:** The applicant operates a nominal 80.7 MW Power Plant, which is located at 6900 Front Street, Stock Island, Monroe County, Florida.

**Project:** The applicant submitted an application for a Title V Air Operation Permit (Permit). The facility consists of five regulated emission units with a total generating capacity of 80.7 MW. There are two regulated diesel generators, three simple cycle combustion turbines, and miscellaneous unregulated units. To reduce pollution, a combination of control techniques is used including water injection, ignition timing retardation, and low sulfur fuel oil. The Ralph Garcia Steam Plant [EPA ID #1] was retired January 1, 1998. Also included in this permit are insignificant emissions units and activities. This permit will be a Title V Air Operation Permit Renewal to initial Title V Operation Permit issued in 1999 as revised in 2002. The main change compared with the present permit relate to the identification of Retired and New Unit Exemption emission units. The change was considered insignificant.

Emissions from this facility will not be increased as a result of this project.

**Permitting Authority:** Applications for Title V major source air operation permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, 62-213 and 62-214 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and an air permit is required to operate the facility. The Department of Environmental Protection, Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination regarding this project. The Permitting Authority's physical address is: Florida Department of Environmental Protection, Bureau of Air Regulation, 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301. The Permitting Authority's mailing address is: Florida Department of Environmental Protection, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400. Mail Station #5505. The Permitting Authority's telephone number is 850/488-0114 and facsimile number is 850/922-6979.

**Project File:** A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at address indicated above for the Permitting Authority. The complete project file includes the Draft Permit, the Statement of Basis, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may view the DRAFT Permit and file electronic comments by visiting the following website: <http://www.dep.state.fl.us/air/eproducts/ards/>. A copy of the complete project file is also available at the Florida Department of Environmental Protection, Southwest District Office, 3804 Coconut Palm Drive, Tampa, Florida 33619-1352. Telephone: 813/744-6100.

**Notice of Intent to Issue Air Permit:** The Permitting Authority gives notice of its intent to issue a permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of the facility will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-256, 62-257, 62-281, 62-296, and 62-297, F.A.C. The Permitting Authority will issue a PROPOSED Permit and subsequent FINAL Permit in accordance with the conditions of the DRAFT Permit unless a response received in accordance with the following procedures results in a different decision or a significant change of terms or conditions.

**(Public Notice to be Published in the Newspaper)**

## PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT

**Comments:** The Permitting Authority will accept written comments concerning the DRAFT Permit renewal for a period of thirty (30) days from the date of publication of this Public Notice. Written comments must be post-marked and all e-mail or facsimile comments must be received by the close of business (5 pm) on or before the end of this 30-day period by the Permitting Authority at the above address, e-mail or facsimile. As part of his or her comments, any person may also request that the Permitting Authority hold a public meeting on this permitting action. If the Permitting Authority determines there is sufficient interest for a public meeting, it will publish notice of the time, date, and location on the Department's official web site for notices (<http://tlhora6.dep.state.fl.us/onw/>) and in a newspaper of general circulation in the area affected by the permitting action. For additional information, contact the Permitting Authority at the above address or phone number. If written comments or comments received at a public meeting result in a significant change to the DRAFT Permit, the Permitting Authority shall revise the DRAFT Permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.

**Petitions:** A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S. must be filed within fourteen (14) days of publication of this Public Notice or receipt of a written notice, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within fourteen (14) days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address and telephone number of the petitioner; the name address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial rights will be affected by the agency determination; (c) A statement of how and when the petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so state; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Public Notice of intent. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

**Mediation:** Mediation is not available for this proceeding.

**Objections:** In addition to the above right to petition, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within sixty (60) days of the

**PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT**

expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to the issuance of any Title V major source air operation permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the thirty (30) day public comment period provided in the Public Notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460. For more information regarding objections, visit the EPA Region 4 web site at: [www.epa.gov/region4/air/permits](http://www.epa.gov/region4/air/permits).

## STATEMENT OF BASIS

Keys Energy Services  
Stock Island Power Plant  
Facility ID No.: 0870003  
Monroe County

### TITLE V AIR OPERATION PERMIT RENEWAL DRAFT Permit No.: 0870003-006-AV

This Title V air operation permit renewal is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

This facility consists of five regulated emission units with a total generating capacity of 80.7 MW. There are two regulated diesel generators, three simple cycle combustion turbines, and miscellaneous unregulated units. To reduce pollution, a combination of control techniques is used including water injection, ignition timing retardation, and low sulfur fuel oil. This facility has an Acid Rain Retired Unit Exemption (Ralph Garcia Steam Plant) and Phase II Acid Rain New Unit Exemptions (D-1 & D-2). The Ralph Garcia Steam Plant [EPA ID #1] was retired January 1, 1998.

Emissions units 005 and 006 are each 8.8 MW (nominal) electric Fairbanks Morse diesel generator (Model PC-2.6V) which burns No. 2 distillate fuel oil, and each has a maximum heat input rate of 85.4 million Btu per hour. Sulfur dioxide emissions are controlled by limiting the sulfur content of the No. 2 fuel oil to 0.05% by weight. Nitrogen oxides emissions are controlled by ignition timing retard and by limiting the hours of operation. Visible emissions and NO<sub>x</sub> emissions are continuously monitored. Commercial operation commenced April 1, 1991. The Department has determined that the appropriate particulate matter testing frequency for the diesel generators is annually whenever fuel oil is used for more than 400 hours in the preceding year. This frequency is justified because the units 005 and 006 are uncontrolled and have documented low emissions in previous emissions tests while firing fuel oil. The applicant's historical PM test results show that the average results are well below the applicable standards of 8.5 lb/hr for each unit and 16 tpy for both units combined.

Emissions unit 007 is a General Electric (GE) Frame 5 model PG5341 CT equipped with water injection for fuel oil firing. It has a rated capacity of 23.5 MW at ISO conditions. The GE CT has a heat input of 312 MMBtu per hour (at 59° F) while burning oil. The CT is fired with No. 2 fuel oil with a sulfur content not to exceed 0.05 % by weight. NO<sub>x</sub> emissions are controlled by a water injection system. The water to fuel ratio is continuously monitored. This turbine began operation January 1, 1996.

Emissions units 008 and 009 are two refurbished General Electric Model MS-5001R 19.77 MW combustion turbines. CT-2 had a startup date of June 1, 1998, and CT-3 had a startup date of August 1, 1998.

The units 007, 008, and 009 are not affected by the Acid Rain Program, since they meet the requirements of 40 CFR 72.7 by serving a generator with less than 25 MW.

All emissions units at the Stock Island Power Plant are for peaking or emergency purposes only. This facility is used when the loads peak, usually during the summer, and when there are emergency situations such as hurricanes.

STATEMENT OF BASIS

Keys Energy Services

Stock Island Power Plant

Facility ID No.: 0870003

Page 2 of 2

This permit renewal does include some changes compared to the Revised Title V permit issued on July 9, 2002. The Acid Rain Part of the Permit has been corrected to reflect Retired and New Units Exemption section.

Also included in this permit are miscellaneous unregulated and insignificant emissions units and activities. Based on the Title V permit renewal application received July 2, 2004, this facility is not a major source of hazardous air pollutants (HAPs).

Keys Energy Services  
Stock Island Power Plant  
**Facility ID No. 0870003**  
Monroe County

**TITLE V AIR OPERATION PERMIT RENEWAL**

**DRAFT Permit No. 0870003-006-AV**

Permitting Authority:

State of Florida  
Department of Environmental Protection  
Division of Air Resources Management  
Bureau of Air Regulation

Mail Station #5505  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400  
Telephone: 850/488-0114  
Fax: 850/922-6979

Compliance Authority:

Department of Environmental Protection  
South District  
2295 Victoria Avenue, Suite 364  
Ft. Myers, Florida 33901-3381  
Telephone: 239/332-6975  
Fax: 239/332-6969

**TITLE V AIR OPERATION PERMIT RENEWAL**

**DRAFT Permit No.: 0870003-006-AV**

**TABLE OF CONTENTS**

<b>Section</b>	<b>Page Number</b>
Placard Page .....	1
I. Facility Information.....	2
A. Facility Description	
B. Summary of Emissions Unit ID Nos. and Brief Descriptions	
C. Retired Acid Rain Units	
D. Relevant Documents	
II. Facility-wide Conditions.....	3 - 5
III. Emissions Units and Conditions	
A. Two Diesel Generators, 8.8 MW.....	6 - 10
B. 23.5 MW Combustion Turbine .....	11 - 13
C. 19.77 MW Combustion Turbine .....	14 - 16
D. Common Conditions I .....	17 - 18
E. Common Conditions II.....	19 - 31
IV. Acid Rain Part.....	32 - 34



**PERMITTEE:**

Keys Energy Services  
P.O. Drawer 6100  
Key West, Florida 33041-6100

**Permit No.** 0870003-006-AV**Facility ID No.:** 0870003**SIC Nos.:** 49, 4911**Project:** Title V Air Operation Permit Renewal

This permit is for the operation of the Stock Island Power Plant. This facility is located at 6900 Front Street, Stock Island, Monroe County; UTM Coordinates: Zone 17, 425.65 km East and 2716.67 km North; Latitude: 24° 33' 49" North and Longitude: 81° 44' 03" West.

STATEMENT OF BASIS: This Title V air operation permit renewal is issued under the provisions of Chapter 403, Florida Statutes (F.S.) and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The Keys Energy Services is authorized to operate the Stock Island Power Plant as shown in the application and approved drawings, plans, and other documents, in accordance with the terms and conditions of this permit.

**Referenced attachments made a part of this permit:**

Appendix U-1, List of Unregulated Emissions Units

Appendix I-1, List of Insignificant Emissions Units and Activities

APPENDIX TV-4, Title V Conditions (Version Dated 02/12/02)

APPENDIX SS-1, Stack Sampling Facilities (Version dated 10/07/96)

TABLE 297.310-1, Calibration Schedule (Version Dated 10/07/96)

FIGURE 1 - Summary Report - Gaseous And Opacity Excess Emission And Monitoring System Report  
(version dated 7/96)

Acid Rain Retired Unit Exemption (Ralph Garcia Steam Plant)

Phase II Acid Rain New Unit Exemptions (D-1 &amp; D-2)

**Effective Date:** January 1, 2005**Renewal Application Due Date:** July 5, 2009**Expiration Date:** December 31, 2009

---

Michael G. Cooke, Director  
Division of Air Resource  
Management

MGC/sa

## **Section I. Facility Information**

### **Subsection A. Facility Description**

This facility consists of five regulated emission units with a total generating capacity of 80.7 MW. There are two regulated diesel generators, three simple cycle combustion turbines, and miscellaneous unregulated units. To reduce pollution, a combination of control techniques is used including water injection, ignition timing retardation, and low sulfur fuel oil. The Ralph Garcia Steam Plant [EPA ID #1] was retired January 1, 1998. Also included in this permit are insignificant emissions units and activities.

Based on the Title V permit renewal application received September 3, 2004, this facility is not a major source of hazardous air pollutants (HAPs).

### **Subsection B. Summary of Emissions Units**

#### **E.U.**

#### **ID No.      Brief Description**

005	8.8 MW Medium Speed Diesel Generator [Unit #1; EPA ID #D-1]
006	8.8 MW Medium Speed Diesel Generator [Unit #2; EPA ID #D-2]
007	23.5 MW Simple Cycle Combustion Turbine [CT-1]
008	19.77 MW Simple Cycle Combustion Turbine [CT-2]
009	19.77 MW Simple Cycle Combustion Turbine [CT-3]
010	Unregulated Emissions Units (See Appendix U-1.)

Emission units 002, 003, and 004 were moved to emissions unit 010.

### **Subsection C. Retired Acid Rain Unit**

001 37 MW Ralph Garcia Steam Plant [EPA ID #1][Retired January 1998]

*Please reference the Permit No., Facility ID No., and appropriate Emissions Unit ID Nos. on all correspondence, test report submittals, applications, and other information.*

### **Subsection D. Relevant Documents**

The documents listed below are not a part of this permit; however they are specifically related to this permitting action.

These documents are provided to the Permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History/ID Number Transfers

Statement of Basis

These documents are on file with permitting authority:

Initial Title V Permit Application received June 12, 1996.

Title V Permit Renewal Application received on July 2, 2004.

Title V Permit Renewal Application complete on September 3, 2004.

## **Section II. Facility-wide Conditions**

1. APPENDIX TV-4, TITLE V CONDITIONS (version dated February 12, 2002), is a part of this permit. {Permitting note: APPENDIX TV-4, TITLE V CONDITIONS, is distributed to the Permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}

2. **Not federally enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited.** The Permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.  
[Rule 62-296.320(2), F.A.C.]

3. **General Particulate Emission Limiting Standards. General Visible Emissions Standard.**  
Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.  
[Rule 62-296.320(4)(b)1. & 4., F.A.C.]

{Permitting Note: Although the Permittee is not required to perform a visible emissions compliance test to demonstrate compliance with the facility-wide limitations annually or before renewal, if the Department believes that the general visible emissions standard is being violated, the Department may require that the owner or operator perform a visible emissions compliance test per Chapter 62-297.310(7)(b), Special Compliance Tests. In addition, Department personnel who are certified to perform visible emissions tests may determine compliance with the general visible emissions standard.}

4. **Prevention of Accidental Releases (Section 112(r) of CAA).**

a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable. Any Risk Management Plans, original submittals, revisions or updates to submittals, should be sent to:

RMP Reporting Center  
Post Office Box 1515  
Lanham-Seabrook, Maryland 20703-1515  
Telephone: 301/429-5018

and,

b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.  
[40 CFR 68]

5. **General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions.** The Permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic

solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.

**“Nothing was deemed necessary and ordered at this time.”**

[Rule 62-296.320(1)(a), F.A.C.]

**6. Insignificant Emissions Units and/or Activities.** Appendix I-1, List of Exempt Emissions Units and/or Activities, is a part of this permit.

[Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]

**7. Emissions of Unconfined Particulate Matter.** Pursuant to Rules 62-296.320(4)(c)1., 3. & 4., F.A.C., reasonable precautions to prevent emissions of unconfined particulate matter at this facility include the following requirements (see Condition 57. of APPENDIX TV-4, TITLE V CONDITIONS):

The following requirements are “not federally enforceable”:

- a. Maintenance of paved areas as needed;
- b. Regular mowing of grass and care of vegetation; and,
- c. Limiting access to plant property by unnecessary vehicles.

[Rule 62-296.320(4)(c)2., F.A.C.; Proposed by applicant in the initial Title V permit application received June 12, 1996]

**8. Statement of Compliance.** The annual statement of compliance pursuant to Rule 62-213.440(3)(a)2., F.A.C., shall be submitted to the Department and EPA within 60 (sixty) days after the end of the calendar year using DEP Form No. 62-213.900(7), F.A.C.

[Rules 62-213.440(3) and 62-213.900, F.A.C.]

***{Permitting Note: This condition implements the requirements of Rules 62-213.440(3)(a)2. & 3., F.A.C. (see Condition 51. of APPENDIX TV-4, TITLE V CONDITIONS)}***

**9.** The Permittee shall submit all compliance, annual operating reports and other correspondence required of this permit to the Department’s South District and Marathon Branch offices:

Department of Environmental Protection  
South District Office  
2295 Victoria Avenue, Suite 364  
Fort Myers, Florida, 33901  
Telephone: 239/332-6975  
Fax: 239/332-6969

Department of Environmental Protection  
Marathon Branch Office  
2796 Overseas Highway, Suite 221  
Marathon Florida, 33901  
Telephone: 305/289-2310  
Fax: 305/289-2314

10. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency  
Region 4  
Air, Pesticides, & Toxics Management Division  
Air and EPCRA Enforcement Branch, Air Enforcement Section  
61 Forsyth Street  
Atlanta, Georgia 30303  
Telephone: 404/562-9155  
Fax: 404/562-9163

{Permitting note: Condition no. 51 of Appendix TV-4, lists the necessary elements of a compliance certification required under 40 CFR 70.6(c)(5)(iii).}

11. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.  
[Rule 62-213.440, F.A.C.]

12. Certification by Responsible Official (RO). In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Any responsible official who fails to submit any required information or who has submitted incorrect information shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary information or correct information.  
[Rule 62-213.420(4), F.A.C.]

### **Section III. Emissions Units and Conditions**

#### **Subsection A. Two Medium Speed Diesel Generators**

##### **E.U.**

##### **ID No.      Brief Description**

005	8.8 MW Medium Speed Diesel Generator [Unit #1; EPA ID #D-1]
006	8.8 MW Medium Speed Diesel Generator [Unit #2; EPA ID #D-2]

Each of the two 8.8 MW (nominal) electric Fairbanks Morse diesel generators (Model PC-2.6V) burns No. 2 distillate fuel oil and has a maximum heat input rate of 85.4 million Btu per hour. Sulfur dioxide emissions are controlled by limiting the sulfur content of the No. 2 fuel oil to 0.05% by weight. Nitrogen oxides emissions are controlled by ignition timing retard and by limiting the hours of operation. Visible emissions and NOx emissions are continuously monitored. Commercial operation commenced April 1, 1991. {Rule 212.400, F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination dated 6/5/89, AO44-207419 & PSD-FL-135}

##### **Essential Potential to Emit (PTE) Parameters**

**A.1.    Permitted Capacity.** The maximum heat input rate to each diesel generator shall not exceed 85.4 MMBtu per hour (606 gallons per hour). The sum total consumption of fuel oil for both diesel generators combined shall not exceed 2.27 million gallons in any consecutive 12-month period. [Rule 62-4.160(2), F.A.C. and Rule 62-210.200, F.A.C., Definitions - (PTE) and AC44-207419/PSD-FL-135]

**A.2.    Emissions Unit Operating Rate Limitation During and After Testing.** Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity [Rule 62-297.310(2), F.A.C.]

**A.3.    Methods of Operation - Fuels.** The only fuel to be burned in this unit is new (virgin) No. 2 fuel oil. The sulfur content shall not exceed 0.05 percent by weight. [Rules 62-213.440(1), F.A.C.; AC44-221256/PSD-FL-135; and Acid Rain Program New Unit Exemptions]

**A.4.    Hours of Operation.** For both units combined, the hours of operation shall not exceed a combined total of 3,740 full load equivalent engine hours in any consecutive 12-month period. [Rule 62-212.400(6), F.A.C. and PSD-FL-135]

**Emission Limitations and Standards**

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting Note: Unless otherwise specified, the averaging times for specific conditions **A.5.- A.10.** are based on the specified averaging time of the applicable test method.}

**A.5. Oxides of Nitrogen.** NO<sub>x</sub> emissions shall not exceed any of the following limits:

- a. 160.9 pounds per hour from each engine;
  - b. 6.0 grams per horsepower-hour from each engine;
  - c. 300.9 tons in any consecutive 12-month period for the combined sum total from both engines.
- [Rule 62-212.400(6), 62-212.400(1)(c), and 62-212.400(2)(d)4., F.A.C., and AC44-221256]

**A.6. Sulfur Dioxide.** SO<sub>2</sub> emissions shall not exceed either of the following limits:

- a. 43.6 pounds per hour from each engine;
  - b. 81.6 tons in any consecutive 12-month period for the combined sum total from both engines.
- [Rule 62-212.400(6), 62-212.400(1)(c), and 62-212.400(2)(d)4., F.A.C., and AC44-221256]

**A.7.**

**a. Particulate Matter.** PM/PM<sub>10</sub> emissions shall not exceed any of the following limits:

- a. 8.5 pounds per hour from each engine;
- b. 0.1 pound per million Btu heat input;
- c. 16.0 tons in any consecutive 12-month period for the combined sum total from both engines.

**b. Visible Emissions.** Visible emissions (VE) shall not exceed 20% opacity.

[Rule 62-212.400(6), 62-212.400(1)(c), and 62-212.400(2)(d)4., F.A.C., AC44-221256 and PSD-FL-135]

**A.8. Carbon Monoxide.** CO emissions shall not exceed any of the following limits:

- a. 53.6 pounds per hour from each engine;
- b. 2.0 grams per horsepower-hour from each engine;
- c. 100.3 tons in any consecutive 12-month period for the combined sum total from both engines.

[Rule 62-212.400(6), 62-212.400(1)(c), and 62-212.400(2)(d)4., F.A.C., and AC44-221256]

**A.9. Volatile Organic Compounds.** VOC emissions shall not exceed any of the following limits:

- a. 26.8 pounds per hour from each engine;
- b. 1.0 grams per horsepower-hour from each engine;
- c. 50.1 tons in any consecutive 12-month period for the combined sum total from both engines.

[Rule 62-212.400(6), 62-212.400(1)(c), and 62-212.400(2)(d)4., F.A.C., and AC44-221256]

**A.10. Beryllium (Be).** Beryllium emissions shall not exceed 0.00054 pounds per hour from each engine and shall not exceed 2.0 pounds in any consecutive 12-month period for the combined sum total from both engines.

[Rule 62-212.400(6), 62-212.400(1)(c), and 62-212.400(2)(d)4., F.A.C., AC44-221256]

**A.11. Objectionable Odor.** The Permittee shall not discharge air pollutants which cause or contribute to an objectionable odor.

[Rule 62-296.320(1)(a)2, F.A.C., AC44-221256]

### **Excess Emissions**

{Permitting Note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.}

**A.12.** Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24-hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

**A.13.** Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

### **Monitoring Requirements**

**A.14.** The Permittee shall calibrate, maintain, and operate continuous monitoring equipment, in accordance with the manufacturer's instructions, to continuously monitor and record opacity and NOx emissions. The Permittee shall maintain a complete file of all measurements, including continuous emissions monitoring system, monitoring device, and performance testing measurements; all continuous emissions monitoring system performance evaluations, all continuous emissions monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required, recorded in an a permanent legible form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records.

[Rule 62-4.070(3), F.A.C. and AC44-221256/PSD-FL-135]

### **Test Methods and Procedures**

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any terms or conditions of this permit.}

**A.15.** The Permittee shall conduct a compliance test for each diesel generator on an *annual basis* for the following pollutants. Each compliance test shall be conducted in accordance with 40 CFR 60, Appendix A, using the method indicated.

- a) Oxides of Nitrogen (NOx) - EPA Method 20.
- b) Sulfur Dioxide (SO<sub>2</sub>) - EPA Method 6 or ASTM D 2880-71 for sulfur in oil.
- c) Visible Emissions - EPA Method 9.
- d) Particulate Matter (PM/PM<sub>10</sub>) - EPA Method 5.



An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

[Rule 62-297.310(7)(a)4. & 5., F.A.C., AC44-152197]

**A.16.** The Permittee shall conduct a compliance test for each of the following pollutants *prior to obtaining a renewed operation permit*. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy this requirement. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of compliance test results for any emissions unit that, during the year prior to renewal: a) did not operate; or b) in the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours. Each compliance test shall be conducted in accordance with 40 CFR 60 Appendix A, using the method indicated.

- a) Carbon Monoxide (CO) – EPA Method 10.
- b) Beryllium (Be) – EPA Method 104.
- c) Volatile Organic Compounds (VOC) - EPA Method 25.

[Rule 62-297.310(7)(a)3., F.A.C., AC44-152197]

**A.17.** By this permit, annual emissions compliance testing for visible emissions and particulate matter is not required for these emissions units while burning liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

**A.18.** The specific conditions of Subsection D, Common Conditions I, apply to these emission units.

### **Reporting and Recordkeeping Requirements**

**A.19.** In order to document compliance with the hours of operation limitation of specific condition A.4, the fuel oil consumption limit of specific condition A.1, and the annual NOx emission limit of specific condition A.5, the Permittee shall keep daily records of the hours of operation, the fuel oil consumption, and the NOx emissions. At a minimum, the records shall indicate:

- (a) the daily hours of operation for each individual diesel generator,
- (b) the daily hours of operation expressed as full load equivalent engine hours(both units combined);
- (c) the daily sum total fuel oil consumption in gallons for both units combined;
- (d) the daily sum total NOx emissions in pounds for both units combined;
- (e) a cumulative total hours of operation expressed as full load equivalent engine hours for the current month;
- (f) a cumulative sum total fuel oil consumed in gallons for the current month;
- (g) a cumulative sum total NOx emissions in tons for the current month;
- (h) a rolling cumulative total hours of operation expressed as full load equivalent engine hours for the previous 12 consecutive months;
- (i) a rolling cumulative sum total fuel oil consumed in gallons for the previous 12 months; and
- (j) a rolling cumulative sum total NOx emissions in tons for the previous 12 consecutive months.

[Rule 62-4.070(3), F.A.C. and AC44-221256/PSD-FL-135]

**A.20.** For each calendar quarter, the Permittee shall submit to the Department a written report of emissions in excess of the emission limiting standards as set forth in this permit. The report shall be postmarked by the 30th day following the end of each calendar quarter. The report shall include at least the following information:

1. The quarterly hours of operation for each individual diesel generator.
2. The magnitude of excess emissions, any conversion factors used, and the date and time of commencement and completion of each time period of excess emissions.
3. Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions.
4. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks, and the nature of the system repairs or adjustments.
5. When no excess emissions have occurred or the continuous monitoring systems have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[Rule 62-4.070(3), F.A.C. and AC44-221256/PSD-FL-135]

**A.21.** In order to document compliance with the hourly SO<sub>2</sub> emission limit of specific condition A.6 and the fuel sulfur limit of specific condition A.3, the Permittee shall keep records of the as-fired fuel sulfur content, in percent by weight. For each shipment of fuel oil, the sulfur content shall be based on either vendor provided analysis or other analysis using ASTM D2622-94, ASTM D4294-90 (95), ASTM D1552-95, ASTM D1266-91, or both ASTM D4057-88 and ASTM D129-95 (or the latest editions). The records shall be maintained for a minimum of five years and shall be made available to the Department upon request.

[Rule 62-4.070(3), F.A.C. and AC44-221256/PSD-FL-135]

### **Source Commitments**

**A.22.** If the Permittee requests relaxation of any federally enforceable limits for these units, then the Department will determine whether the NSR requirements of Rule 62-212.400, F.A.C. shall apply, as though the construction permit AC44-221256 had not been issued.

[Rule 62-4.070(3), F.A.C., and AC44-221256/PSD-FL-135]

**A.23.** Best Available Control Technology (BACT) will be re-evaluated if the Permittee requests an increase in or exceeds the permitted hours of operation. Selective Catalytic Reduction for NO<sub>x</sub> control will be required at a minimum for BACT if deemed technologically feasible. In no event shall the BACT control installation and compliance testing occur later than 30 months from the date that the Permittee requested to exceed the permitted hours of operation or actually exceeded the permitted hours of operation.

[Rule 62-4.070(3), F.A.C., and AC44-221256/PSD-FL-135]

**A.24.** The three existing 16.5 MW steam units at the Key West Plant shall not operate.

[AC44-221256/PSD-FL-135 and AC44-152197]

## **Subsection B. 23.5 MW Combustion Turbine**

### **E.U.**

#### **ID No.      Brief Description**

007            23.5 MW Simple Cycle Combustion Turbine [CT-1]

Emissions unit 007 is a General Electric (GE) Frame 5 model PG5341 CT equipped with water injection for fuel oil firing. It has a rated capacity of 23.5 MW at ISO conditions. The GE CT has a heat input of 312 MMBtu per hour (at 59° F) while burning oil. The CT is fired with No. 2 fuel oil with a sulfur content not to exceed 0.05 % by weight. NOx emissions are controlled by a water injection system. The water to fuel ratio is continuously monitored. This turbine began operation January 1, 1996.

{Permitting notes: This emissions unit is regulated under Rule 62-210.300, F.A.C., Permits Required; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7)(b) 38., F.A.C.; NSPS - 40 CFR 60 Subpart A; Rule 212.400, F.A.C., Prevention of Significant Deterioration; PSD-FL-210; and AC44-245399. The unit is not affected by the Acid Rain Program, since it meets the requirements of 40 CFR 72.7 by serving a generator with less than 25 MW.}

### **Essential Potential to Emit (PTE) Parameters**

**B.1.    Permitted Capacity.** The maximum heat input to the GE combustion turbine (CT) at an ambient temperature of 59° F shall not exceed 312 MMBtu/hr while firing fuel oil. Heat input may vary depending on ambient conditions and the CT's characteristics. The approved manufacturer's curves shall be used to establish heat input rates over a range of temperatures for the purpose of compliance determination.

[Rule 62-210.200, F.A.C., AC44-245399/PSD-FL-210]

**B.2.    Methods of Operation - Fuels.** The only fuel to be burned in this unit is new No. 2 fuel oil. The sulfur content shall not exceed 0.050 percent by weight.

[Rules 62-4.160(2), 62-210.200, and 62-213.440(1), F.A.C., AC44-245399/PSD-FL-210]

**B.3.    Hours of Operation/Fuel Consumption.** The maximum No. 2 fuel oil consumption allowed to be burned in the CT is 7.1 million gallons per year, which is equivalent to 2,888.5 hours per year at full-load; the CT may operate for more than this if operating at part-load.

[Rule 62-212.500(56), F.A.C., AC44-245399, PSD-FL-210]

### **Emission Limitations and Standards**

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting Note: Unless otherwise specified, the averaging times for specific conditions **B.6.- B.8.** are based on the specified averaging time of the applicable test method.}

**B.4. Oxides of Nitrogen.** NOx emissions shall not exceed any of the following limits:

- a. Nitrogen oxides emissions, expressed as NO<sub>x</sub>, shall not exceed:  $STD = 0.0075 (14.4)/Y + F$

where:

STD = allowable NOx emissions (percent by volume at 15 percent oxygen and on a dry basis).

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility.

The value of Y shall not exceed 14.4 kilojoules per watt-hour.

F = NOx emission allowance for fuel-bound nitrogen as defined in 40 CFR 60.332(a)(3).

F shall be defined according to the nitrogen content of the fuel as follows:

<u>Fuel-bound nitrogen (% by weight)</u>	<u>F (NO<sub>x</sub>% by volume)</u>
$N \leq 0.015$	0
$0.015 < N \leq 0.1$	$0.04(N)$
$0.1 < N \leq 0.25$	$0.004 + 0.0067(N - 0.1)$
$N > 0.25$	0.005

where:

N = the nitrogen content of the fuel (percent by weight);

- b. 75 ppmvd, based on a 1-hour average at 15% O<sub>2</sub>;
- c. 96 lbs./hour, based on a 1-hour average at 15% O<sub>2</sub>;
- d. 138 TPY.

[AC44-245399/PSD-FL-210, 40 CFR 60.332]

**B.5. Sulfur Dioxide.** SO<sub>2</sub> emissions shall be controlled by limiting the sulfur content of the fuel to a maximum of 0.05 percent by weight.

[AC44-245399/PSD-FL-210, 40 CFR 60.333]

**B.6. Particulate Matter/PM<sub>10</sub>.** PM/PM<sub>10</sub> emissions shall be limited to 18 lbs./hour, based on a 1-hour average; 43 TPY.

[AC44-245399, PSD-FL-210]

**B.7. Carbon Monoxide.** CO shall be limited to 20 PPM at 100% load, and 136 PPM at 50% load; 64 lbs. per hour, based on a 1-hour average; 152 TPY.

[AC44-245399/PSD-FL-210]

**B.8. Visible Emissions.** Visible emissions shall be limited to 20 percent opacity.

[AC44-245399/PSD-FL-210]

**Excess Emissions, Monitoring Requirements, and Test Methods & Procedures, and Reporting & Recordkeeping Requirements**

**B.9.** Two copies of the results of the emission tests for the pollutants listed in conditions B.4. through B.7. shall be submitted within forty-five days of the last sampling run to the South District office in Fort Myers. All reports shall be in a format consistent with and shall include the information in accordance with Rule 62-297.310 (8), F.A.C.  
[Rule 62-297.310(8), F.A.C.]

**B.10.** The specific conditions of Subsection D, Common Conditions I, and Subsection E, Common Conditions II, apply to these emissions units.

### **Subsection C. 19.77 MW Combustion Turbines**

#### **E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
008	19.77 MW Simple Cycle Combustion Turbine [CT-2]
009	19.77 MW Simple Cycle Combustion Turbine [CT-3]

These emissions units are two refurbished General Electric Model MS-5001R 19.77 MW combustion turbines. CT-2 had a startup date of June 21, 1998, while CT-3 had a startup date of August 1, 1998.

{Permitting notes: These emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required; NSPS - 40 CFR 60, Subparts A (General Provisions) and GG, (Standards of Performance for Stationary Gas Turbines), adopted and incorporated by reference in Rule 62-204.800(7)(b)38., F.A.C.; Rule 212.400, F.A.C., Prevention of Significant Deterioration; and AC0870003-003, issued January 8, 1998. The units are not affected by the Acid Rain Program, since they meet the requirements of 40 CFR 72.7 by serving a generator with less than 25 MW.}

#### **General Provisions**

##### **Notification and Record Keeping**

**C.1.** A notification of the date upon which demonstration of the continuous monitoring system performance commences in accordance with 40 CFR 60.13(c) shall be postmarked not less than 30 days prior to such date. The notification shall be sent to the Department's South District Office and Marathon Branch Office.

[40 CFR 60.7(a)(5)]

**C.2.** When it has been demonstrated that these units meet the emission limitations established in permit AC-0870003-003, a properly signed and sealed certification from the permittee's Professional Engineer shall be submitted to the offices listed in C.1. stating that 1) the construction of CT-2 and CT-3 was completed in accordance with permit AC-870003-003 and, 2) the units have been tested and are in compliance with the terms and conditions contained within permit AC-870003-003.

[Rules 62-212.400(7)(b) and 62-213.420(1)(a)5., F.A.C., AC-870003-003]

##### **Performance Tests**

**C.3.** Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup, the Permittee shall conduct performance test(s) and furnish the offices listed in C.1. a written report of the results of such performance test(s).

[40 CFR 60.8(a)]

{Permitting note: See Subsection E. for additional requirements.}

#### **Essential Potential to Emit (PTE) Parameters**

**C.4. Hours of Operation.** Each emission unit is allowed to operate 4,000 hours per year. The combined operation of both units shall also be limited to 4,000 hours per year. The facility is required to keep daily records of the operating hours.

[AC-870003-003]

**C.5. Method of Operation - Fuels.** Only No. 2 fuel oil can be fired in the combustion turbines. The maximum sulfur content of the No. 2 fuel oil shall not exceed 0.05 percent, by weight.

[AC-870003-003]

**C.6. Permitted Capacity.** The maximum heat input rate to each combustion turbine shall not exceed 305 million Btu per hour (MMBtu/hr).

[AC-870003-003]

**C.7. Fuel Consumption.** The maximum No. 2 fuel oil consumption allowed to be burned in either emission unit No. 008 or emission unit No. 009 is 8,840,000 gallons per year, which is equivalent to 4,000 hours per year of operation at full load. The combined fuel oil consumption for both units shall be limited to 8,840,000 gallons per year.

[AC-870003-003]

**Emission Limitations and Standards**

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

{Permitting Note: Unless otherwise specified, the averaging times for specific conditions C.10.- C.12. are based on the specified averaging time of the applicable test method.}

{Note: The emission limits of lb/hr apply to each unit, while the TPY limit apply to each unit individually and both units collectively.}

**C.8. Oxides of Nitrogen.** For each turbine, NO<sub>x</sub> emissions shall not exceed any of the following limits:

- a. Nitrogen oxides emissions, expressed as NO<sub>x</sub>, shall not exceed:

$$STD = 0.0075(14.4)/Y + F$$

where:

STD = allowable NO<sub>x</sub> emissions (percent by volume at 15 percent oxygen and on a dry basis).

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour.

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in 40 CFR 60.332(a)(3).

F shall be defined according to the nitrogen content of the fuel as follows:

<u>Fuel-bound nitrogen (% by weight)</u>	<u>F (NO<sub>x</sub>% by volume)</u>
N ≤ 0.015	0
0.015 < N ≤ 0.1	0.04(N)

$0.1 < N \leq 0.25$	$0.004 + 0.0067(N - 0.1)$
$N > 0.25$	0.005

where: N = the nitrogen content of the fuel (percent by weight);

- b. 75 ppmvd, based on a 1-hour average at 15% O<sub>2</sub>; and
- c. 93.8 lb./hour, based on a 1-hour average at 15% O<sub>2</sub>; and 40 degrees F from each turbine.
- d. 172 TPY, based on an average hourly concentration of 86 pounds per hour at 85 degrees F ambient temperature from both turbines combined.
- e. no more than 4,000 hours per year of operation, from either or both turbines combined.

[40 CFR 60.332, AC-870003-003]

**C.9. Sulfur Dioxide.** For each turbine, SO<sub>2</sub> emissions shall be controlled by limiting the sulfur content of the fuel to a maximum of 0.05 percent by weight.

[40 CFR 60.333, AC-870003-003]

**C.10. Particulate Matter/PM<sub>10</sub>.** For each turbine, PM/PM<sub>10</sub> emissions shall be limited to 16.6 lb/hour, based on a 1-hour average; PM and PM<sub>10</sub> from both turbines combined shall be limited to 55 TPY and 45 TPY, respectively.

[AC-870003-003]

**C.11. Carbon Monoxide.** For each turbine, CO shall be limited to 25.2 lb./hour, based on a 1-hour average; and from both turbines combined, 101 TPY.

[AC-870003-003]

**C.12. Visible Emissions.** Visible emissions shall be limited to 20 percent opacity.

[AC-870003-003]

**Excess Emissions, Monitoring Requirements, Test Methods & Procedures, and Reporting & Recordkeeping Requirements**

**C.13.** Two copies of the results of the emission tests for the pollutants listed in conditions C.8. through C.11. shall be submitted within forty-five days of the last sampling run to the South District office in Ft. Myers. All reports shall be in a format consistent with and shall include the information in accordance with Rule 62-297.310 (8), F.A.C.

[Rule 62-297.310(8), F.A.C.]

**C.14.** The specific conditions of Subsection D, Common Conditions I, and Subsection E, Common Conditions II, apply to these emissions units.



### **Subsection D. Common Conditions I**

The following conditions apply to all emissions units listed in Section III, Subsections A., B., and C., of this permit.

#### **Test Methods & Procedures**

**D.1. Required Number of Test Runs.** For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

**D.2. Calculation of Emission Rate.** The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

**D.3. Applicable Test Procedures.**

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.
2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur.

Exceptions to these requirements are as follows:

- a. (not applicable)
  - b. (not applicable)
  - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.
- (b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.
- (c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.
- (d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1. (See attachment.)
- (e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

**D.4. Special Compliance Tests**. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

[Rule 62-297.310(7)(b), F.A.C., SIP approved]

**D.5. Waiver of Compliance Test Requirements**. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7)(c), F.A.C., SIP approved]

### **Subsection E. Common Conditions II**

The following conditions apply only to the Combustion Turbines listed in listed in Section III, Subsections B. and C. of this permit.

#### **Excess Emissions**

{Permitting Note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.}

**E.1.** Excess emissions from the CT resulting from start-up, shutdown, malfunction, or load change shall be acceptable providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized, but in no case exceed two hours in any 24-hour period unless specifically authorized by the Department for a longer duration.  
[AC44-245399/PSD-FL-210, 0870003-003-AC]

**E.2.** Excess Emissions Defined. For the purpose of reports required under 40 CFR 60.7(c) (see specific condition C.24.), periods of excess emissions that shall be reported are defined as follows:

- a. *Nitrogen oxides.* Any one-hour period during which the average water-to-fuel ratio, as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with 40 CFR 60.332 by the performance test required in 40 CFR 60.8 or any period during which the fuel-bound nitrogen of the fuel is greater than the maximum nitrogen content allowed by the fuel-bound nitrogen allowance used during the performance test required in 40 CFR 60.8. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, gas turbine load, and nitrogen content of the fuel during the period of excess emissions, and the graphs or figures developed under 40 CFR 60.335(a).
- b. *Sulfur dioxide.* Any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.05 percent.

[40 CFR 60.334(c)(1)&(c)(2), 0870003-003-AC]

#### **Monitoring Requirements**

**E.3.** CMS Requirements. The Permittee shall install, operate, and maintain a continuous monitoring system (CMS) to monitor and record the fuel consumption, the ratio of water to fuel being fired in the turbine, and the electrical output in MW. The system shall be accurate to within  $\pm 5.0$  percent and shall be approved by the Department. Quarterly calibrations shall be performed on the CMS.

[40 CFR 60.334(a); AC44-245399/PSD-FL-210, 0870003-003-AC]

**E.4.** Critical Fuel Parameters. The Permittee shall monitor sulfur content, nitrogen content, and the lower heating value of the fuel being fired in the turbine. The frequency of determination of these values shall be as follows:

- a. If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source.
- b. If the turbine is supplied its fuel without intermediate bulk storage, the values shall be determined and recorded daily. Owners, operators or fuel vendors may develop custom schedules for determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Bureau of Air Regulation before they can be used to comply with 40 CFR 60.334(b).

[AC44-245399/PSD-FL-210, 40 CFR 60.334(b)(1)&(b)(2), 0870003-003-AC]

### **Test Methods & Procedures**

**E.5** Testing of emissions shall be conducted with the source operating at capacity. Capacity is defined as 95 to 100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned) air temperature during the test. If it is impracticable to test at capacity, then sources may be tested at less than capacity. In such cases, the entire heat input versus inlet temperature curve will be adjusted by the increment equal to the difference between the design heat input value and 105 percent of the value reached during the test. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report.

To demonstrate compliance with federal new source performance standard Subpart GG - Standards of performance Stationary Gas Turbines, the initial test shall be conducted at four load points and corrected to ISO conditions for comparison to the NSPS allowable. Subsequent annual compliance tests conducted to establish compliance with NO<sub>x</sub> limits that are more stringent than the NSPS standard shall not require an ISO correction or testing at four load points; rather, the testing shall be done at capacity, as defined above. However, when testing shows that NO<sub>x</sub> emissions exceed the standard when operating at capacity, the company shall recalibrate the NO<sub>x</sub> emission control system using emission testing at four loads as required in Subpart GG.

[Rule 62-4.070(3), F.A.C.]

**E.6.** Performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in each applicable subpart unless the Department (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology, (2) waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Department's satisfaction that the affected facility is in compliance with the standard, or (3) approves shorter sampling times and smaller sample volumes when necessitated by process variables or other factors. Nothing in 40 CFR 60.8 shall be construed to abrogate the Department's authority to require testing under section 114 of the Act.

[40 CFR 60.8(b)(1), (4) & (5)]

**E.7.** Performance tests shall be conducted under such conditions, as the Department shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Department such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not

constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

**E.8.** The Keys Energy Services shall provide, or cause to be provided, performance testing facilities as follows:

1. Sampling ports adequate for test methods applicable to such facility. This includes (a) constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures and (b) providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures.
2. Safe sampling platform(s).
3. Safe access to sampling platform(s).
4. Utilities for sampling and testing equipment.

[40 CFR 60.8(e)]

**E.9.** Each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic means of results of the three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the three runs must be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances, beyond the owner or operator's control, compliance may, upon the Department's approval, be determined using the arithmetic mean of the results of the two other runs.

[40 CFR 60.8(f)]

**E.10.** Compliance tests shall be performed on the CT while firing oil. Testing of emissions shall be conducted at 95-100% of the manufacturer's rated heat input based on the average ambient air temperature during the test.

Annual compliance tests shall be performed on the CT if the No. 2 fuel was used for more than 400 hours in the preceding 12-month period. Tests shall be conducted using EPA reference methods in accordance with 40 CFR 60, Appendix A, as adopted by reference in Chapter 62-297, F.A.C.:

- a. Reference Method 5B for PM.
- b. Reference Method 9 for VE.
- c. Reference Method 10 for CO.
- d. Reference Method 20 for NOx.
- e. Other methods may be used for compliance testing after obtaining prior Departmental approval, in writing.

[Rule 62-297.310(7)(a)(4), F.A.C., AC44-2445399, 0870003-003-AC]

**E.11. Sulfur Content.** The Permittee shall determine compliance with the sulfur content standard in 40 CFR 60.333(b) as follows: ASTM D 2880-96, or more recent version, shall be used to determine the sulfur content of liquid fuels and ASTM D 1072-90(94) E-1, D 3031-81(86), D 4084-94, or D 3246-92, or more recent versions, shall be used for the sulfur content of gaseous fuels (incorporated by reference-see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Department.  
[40 CFR 60.335(d)]

**E.12.** To compute the nitrogen oxides emissions, the Permittee shall use analytical methods and procedures that are accurate to within +5 percent and are approved by the Department to determine the nitrogen content of the fuel being fired.  
[40 CFR 60.335(a)]

**E.13.** The NO<sub>x</sub> emission rate shall be computed for each run using the following equation:

$$NO_x = (NO_{xO}) (P_r/P_o)^{0.5} e^{19(H_o-0.00633)} (288^\circ K/T_a)^{1.53}$$

where:

NO<sub>x</sub> = emission rate of NO<sub>x</sub> at 15 percent O<sub>2</sub> and ISO standard ambient conditions, volume percent.

NO<sub>xO</sub> = observed NO<sub>x</sub> concentration, PPM by volume.

P<sub>r</sub> = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg.

P<sub>o</sub> = observed combustor inlet absolute pressure at test, mm Hg.

H<sub>o</sub> = observed humidity of ambient air, g H<sub>2</sub>O/g air.

e = transcendental constant, 2.718.

T<sub>a</sub> = ambient temperature, °K. [40 CFR 60.335(c)(1)]

1. :Compliance with the allowable emission limiting standards for NO<sub>x</sub> given in...

**E.14.** The owner or operator may use the following as an alternative to the reference methods and procedures specified in 40 CFR 60.335:

Instead of using the equation in paragraph 40 CFR 60.335(c)(1), manufacturers may develop ambient condition correction factors to adjust the nitrogen oxides emission level measured by the performance test as provided in 40 CFR 60.8 to ISO standard day conditions. These factors are developed for each gas turbine model they manufacture in terms of combustion inlet pressure, ambient air pressure, ambient air humidity, and ambient air temperature. They shall be substantiated with data and must be approved for use by the Department before the initial performance test required by 40 CFR 60.8. Notices of approval of custom ambient condition correction factors will be published in the Federal Register.

[40 CFR 60.335(f)(1)]

**E.15.** The monitoring device of 40 CFR 60.334(a) shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with 40 CFR 60.332 at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer.

[40 CFR 60.335(c)(2)]

**E.16.** Compliance with the allowable emission limiting standards for NO<sub>x</sub> given in Subsections B. and C. shall be determined by using EPA Reference Method 20 as described in 40 CFR 60, Appendix A (1996, version) adopted by reference in Rule 62-204.800, F.A.C. The span values shall be 300 PPM of nitrogen oxide and 21 percent oxygen. The NO<sub>x</sub> emissions shall be determined at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. An annual compliance test shall be performed on the unit if operated for more than 400 hours in the preceding 12-month period.

[Rule 62-297.310, F.A.C. and 40 CFR 60.335(c)(3)]

**E.17.** In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of 40 CFR 60 or other methods and procedures as specified in this permit, except as provided for in 40 CFR 60.8(b). Acceptable alternative methods and procedures are given in paragraph 40 CFR 60.335(f).

[40 CFR 60.335(b)]

**E.18.** (a) For the purposes of this section, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of this section upon promulgation of performance specifications for continuous monitoring systems under appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, appendix F to 40 CFR 60, unless otherwise specified in an applicable subpart or by the Department. Appendix F is applicable December 4, 1987.

(b) All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests under 40 CFR 60.8. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device.

(c) If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he/she shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system (CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in appendix B of 40 CFR 60. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Department under section 114 of the Act.

- (1) The owner or operator of an affected facility using a COMS to determine opacity compliance during any performance test required under 40 CFR 60.8 and as described in 40 CFR 60.11(e)(5), shall furnish the Department two or, upon request, more copies of a written report of the results of the COMS performance evaluation described in 40 CFR 60.13(c) at least 10 days before the performance test required under 40 CFR 60.8 is conducted.
  - (2) Except as provided in 40 CFR 60.13(c)(1), the owner or operator of an affected facility shall furnish the Department within 60 days of completion two or, upon request, more copies of a written report of the results of the performance evaluation.
- (d)
- (1) Permittee's of all continuous emission monitoring systems installed in accordance with the provisions of 40 CFR 60 shall check the zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For continuous monitoring systems measuring opacity of emissions, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments except that for systems using automatic zero adjustments. The optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.
  - (2) Unless otherwise approved by the Department, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a method for producing a simulated zero opacity condition and upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly.
- (e) Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:
- (1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.
  - (2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.



- (f) All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of appendix B of 40 CFR 60 shall be used.
- (g) When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Department. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system.
- (h) Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorder during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non-reduced form (e.g., PPM pollutant and percent O<sub>2</sub> or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).

[Rule 62-296.800, F.A.C.; 40 CFR 60.13(a)-(h)]

**E.19.** After receipt and consideration of written application, the Department may approve alternatives to any monitoring procedures or requirements of 40 CFR 60 including, but not limited to the following:

- (1) Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by 40 CFR 60 would not provide accurate measurements due to liquid water or other interferences caused by substances with the effluent gases.
- (2) Alternative monitoring requirements when the affected facility is infrequently operated.
- (3) Alternative monitoring requirements to accommodate continuous monitoring systems that require additional measurements to correct for stack moisture conditions.
- (4) Alternative locations for installing continuous monitoring systems or monitoring devices when the owner or operator can demonstrate that installation at alternate locations will enable accurate and representative measurements.

- (5) Alternative methods of converting pollutant concentration measurements to units of the standards.
- (6) Alternative procedures for performing daily checks of zero and span drift that do not involve use of span gases or test cells.
- (7) Alternatives to the ASTM test methods or sampling procedures specified by any subpart.
- (8) Alternative continuous monitoring systems that do not meet the design or performance requirements in Performance Specification 1, appendix B, but adequately demonstrate a definite and consistent relationship between its measurements and the measurements of opacity by a system complying with the requirements in Performance Specification 1. The Department may require that such demonstration be performed for each affected facility.
- (9) Alternative monitoring requirements when the effluent from a single affected facility or the combined effluent from two or more affected facilities are released to the atmosphere through more than one point.

[Rule 62-296.800, F.A.C.; 40 CFR 60.13(i)]

#### **Reporting and Recordkeeping Requirements**

**E.20.** To determine compliance with the fuel oil firing heat input limitation, the Permittee shall maintain daily records of fuel oil consumption for the turbine and the heating value for the fuel. All records shall be maintained for a minimum of five years after the date of each record and shall be made available to representatives of the Department upon request.

[Rule 62-4.070(3)]

**E.21. Excess Emissions Report.** The Permittee shall record the occurrence and duration of any startup, shutdown, or malfunctions of the turbine and any malfunction of the air pollution control equipment or CMS. Additionally, the Permittee shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C., and 40 CFR 60.7(b)]

**E.22. Quarterly Report.** The Permittee shall submit a quarterly excess emissions and monitoring systems performance report. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:

1. The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
2. Specific identification of each period of excess emissions that occurs during startups, shutdowns and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
3. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
4. When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)]

**E.23. Summary Report.** The summary report form shall contain the information and be in the format shown in Figure 1 of 40 CFR 60.7(d) unless otherwise specified by the Department. One summary report form shall be submitted for each pollutant monitored.

1. If the total duration of excess emissions for the reporting period is less than one percent of the operating time for the reporting period and CMS downtime for the reporting period is less than five percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Department.
2. If the total duration of excess emissions for the reporting period is one percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is five percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

[40 CFR 60.7(d)]

**E.24. Reporting Frequency.**

- (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:
  - (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under 40 CFR 60 continually demonstrate that the facility is in compliance with the applicable standard;
  - (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and
  - (iii) The Department does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).
- (2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Department in writing of his or her intention to make such a change and the Department does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Department may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Department to make a judgment about the source's potential for noncompliance in the future. If the Department disapproves the Permittee's request to reduce the frequency of reporting, the Department will notify the Permittee in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Department to the Permittee will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

- (3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the Permittee shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the non-complying event. After demonstrating compliance with the applicable standard for another full year, the Permittee may again request approval from the Department to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)]

**E.25. Records Retention.** The Permittee shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

#### **Additional General Provisions - 40 CFR 60 Subpart A**

**E.26. Department Notification.**

- (a) The Permittee shall provide to the Department's South District office at least 15 days prior notice of any compliance or performance test, except as specified under other subparts, to afford the District office the opportunity to have an observer present. Test results shall be submitted to the District office no later than 45 days after completion of the test.
- (b) The Permittee shall give written notification to the Department when there is any modification to this facility. This notice shall be submitted timely and in advance of any critical date involved to allow sufficient time for review, discussion, and revision of plans, if necessary. Such notice shall include, but not be limited to, information describing the precise nature of the change; modifications to any emission control system; production capacity of the facility before and after the change; and, the anticipated completion date of the change.

[40 CFR 60.8(d) and Rule 62-297.310(7)(a)9., F.A.C.]

#### **Compliance with Standards and Maintenance Requirements**

**E.27.** Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in appendix A of 40 CFR 60, any alternative method that is approved by the Department, or as provided in 40 CFR 60.11(e)(5). For purposes of determining initial compliance, the minimum total time of observations shall be 3 hours (30 6-minute averages) for the performance test or other set of observations (meaning those fugitive-type emission sources subject only to an opacity standard).

[40 CFR 60.11(b)]

**E.28.** The Permittee shall follow the manufacturer's instructions during periods of start-up, shutdown, malfunction, or load change to ensure that the best operational practices to minimize emissions will be adhered to and the duration of any excess emissions will be minimized. The instructions shall be kept on file at the plant site and made available for inspection upon request by the Department.

[40 CFR 60.11(d)]

**E.29. Credible Evidence.** For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard in 40 CFR 60, nothing in 40 CFR 60 shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.

[40 CFR 60.11(g)]

**E.30. Circumvention.** No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment, or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

### **Monitoring Requirements**

**E.31.** An alternative to the relative accuracy test specified in Performance Specification 2 of 40 CFR 60 Appendix B, may be requested as follows:

- (1) An alternative to the reference method tests for determining relative accuracy is available for sources with emission rates demonstrated to be less than 50 percent of the applicable standard. A source owner or operator may petition the Department to waive the relative accuracy test in section 7 of Performance Specification 2 and substitute the procedures in section 10 if the results of a performance test conducted according to the requirements in 40 CFR 60.8 of this subpart or other tests performed following the criteria in 40 CFR 60.8 demonstrate that the emission rate of the pollutant of interest in the units of the applicable standard is less than 50 percent of the applicable standard. For sources subject to standards expressed as control efficiency levels, a source owner or operator may petition the Department to waive the relative accuracy test and substitute the procedures in section 10 of Performance Specification 2 if the control device exhaust emission rate is less than 50 percent of the level needed to meet the control efficiency requirement. The alternative procedures do not apply if the continuous emission monitoring system is used to determine compliance continuously with the applicable standard. The petition to waive the relative accuracy test shall include a detailed description of the procedures to be applied. Included shall be location and procedure for conducting the alternative, the concentration, or response levels of the alternative RA materials, and the other equipment checks included in the alternative procedure. The Department will review the petition for completeness and applicability. The determination to grant a waiver will depend on the intended use of the CEMS data (e.g., data collection purposes other than NSPS) and may require specifications more stringent than in Performance Specification 2 (e.g., the applicable emission limit is more stringent than NSPS).

- (2) The waiver of a CEMS relative accuracy test will be reviewed and may be rescinded at such time following successful completion of the alternative RA procedure that the CEMS data indicate the source emissions approaching the level of the applicable standard. The criterion for reviewing the waiver is the collection of CEMS data showing that emissions have exceeded 70 percent of the applicable standard for seven, consecutive, averaging periods as specified by the applicable regulation(s). For sources subject to standards expressed as control efficiency levels, the criterion for reviewing the waiver is the collection of CEMS data showing that exhaust emissions have exceeded 70 percent of the level needed to meet the control efficiency requirement for seven, consecutive, averaging periods as specified by the applicable regulation(s) [e.g., 40 CFR 60.45(g)(2) and 40 CFR 60.45(g)(3), 40 CFR 60.73(e), and 40 CFR 60.84(e)] It is the responsibility of the source operator to maintain records and determine the level of emissions relative to the criterion on the waiver of relative accuracy testing. If this criterion is exceeded, the owner or operator must notify the Department within 10 days of such occurrence and include a description of the nature and cause of the increasing emissions. The Department will review the notification and may rescind the waiver and require the owner or operator to conduct a relative accuracy test of the CEMS as specified in section 7 of Performance Specification 2.

[Rule 62-296.800, F.A.C.; 40 CFR 60.13(j)]

### **Modifications**

**E.32.** Except as provided under 40 CFR 60.14(e) and 40 CFR 60.14(f), any physical or operational change to an existing facility which results in an increase in the emission rate to the atmosphere of any pollutant to which a standard applies shall be considered a modification within the meaning of section 111 of the Act. Upon modification, an existing facility shall become an affected facility for each pollutant to which a standard applies and for which there is an increase in the emission rate to the atmosphere.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(a)]

**E.33.** Emission rate shall be expressed as kg/hr (lbs./hour) of any pollutant discharged into the atmosphere for which a standard is applicable. The Department shall use the following to determine emission rate:

- (1) Emission factors as specified in the latest issue of "Compilation of Air Pollutant Emission Factors", EPA Publication No. AP-42, or other emission factors determined by the Department to be superior to AP-42 emission factors, in cases where utilization of emission factors demonstrate that the emission level resulting from the physical or operational change will either clearly increase or clearly not increase.
- (2) Material balances, continuous monitor data, or manual emission tests in cases where utilization of emission factors as referenced in 40 CFR 60.14(b)(1) does not demonstrate to the Department's satisfaction whether the emission level resulting from the physical or operational change will either clearly increase or clearly not increase, or where an owner or operator demonstrates to the Department's satisfaction that there are reasonable grounds to dispute the result obtained by the Department utilizing emission factors as referenced in 40 CFR 60.14(b)(1). When the emission rate is based on results from manual emission tests or continuous monitoring systems, the procedures specified in 40 CFR 60 appendix C of 40 CFR 60 shall be used to determine whether an increase in emission rate has occurred. Tests

shall be conducted under such conditions as the Department shall specify to the owner or operator based on representative performance of the facility. At least three valid test runs must be conducted before and at least three after the physical or operational change. All operating parameters which may affect emissions must be held constant to the maximum feasible degree for all test runs.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(b)]

**E.34.** The addition of an affected facility to a stationary source as an expansion to that source or as a replacement for an existing facility shall not by itself bring within the applicability of 40 CFR 60 any other facility within that source.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(c)]

**E.35.** The following shall not, by themselves, be considered modifications under 40 CFR 60:

- (1) Maintenance, repair, and replacement which the Department determines to be routine for a source category, subject to the provisions of 40 CFR 60.14(c) and 40 CFR 60.15.
- (2) An increase in production rate of an existing facility, if that increase can be accomplished without a capital expenditure on that facility.
- (3) An increase in the hours of operation.
- (4) Use of an alternative fuel or raw material if, prior to the date any standard under 40 CFR 60 becomes applicable to that source type, as provided by 40 CFR 60.1, the existing facility was designed to accommodate that alternative use. A facility shall be considered to be designed to accommodate an alternative fuel or raw material if that use could be accomplished under the facility's construction specifications as amended prior to the change. Conversion to coal required for energy considerations, as specified in section 111(a)(8) of the Act, shall not be considered a modification.
- (5) The addition or use of any system or device whose primary function is the reduction of air pollutants, except when an emission control system is removed or is replaced by a system which the Department determines to be less environmentally beneficial.
- (6) The relocation or change in ownership of an existing facility.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(e)]

**E.36.** Special provisions set forth under an applicable subpart of 40 CFR 60 shall supersede any conflicting provisions of this section.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(f)]

**E.37.** Within 180 days of the completion of any physical or operational change subject to the control measures specified in 40 CFR 60.14(a), compliance with all applicable standards must be achieved.

[Rule 62-296.800, F.A.C.; 40 CFR 60.14(g)]

**Section IV. Acid Rain Part**

**Operated by: Keys Energy Services**  
**ORIS code: 6584**

The following emissions units are regulated under the Acid Rain Program:

**E.U.**

<b><u>ID No.</u></b>	<b><u>Description</u></b>
001	Ralph Garcia Steam Plant [EPA ID #1][Retired]
005	8.8 MW Medium Speed Diesel Generator [Unit #1; EPA ID #D-1]
006	8.8 MW Medium Speed Diesel Generator [Unit #2; EPA ID #D-2]

**Subsection A. This Subsection addresses Acid Rain, Phase II, Retired and New Unit Exemption.**

The emissions unit listed below is regulated under Phase II of the federal Acid Rain Program.

<b>E.U. ID No.</b>	<b>Description</b>
-001	Ralph Garcia Steam Plant – PERMANENTLY RETIRED
-005	8.8 MW Medium Speed Diesel Generator (Unit #1) – NEW UNIT EXEMPTION
-006	8.8 MW Medium Speed Diesel Generator (Unit #2) – NEW UNIT EXEMPTION

**IV.A.1.** The New and Retired Unit Exemption forms submitted for this facility constitutes the Acid Rain Part application pursuant to 40 CFR 72.7 and 40 CFR 72.8 and is a part of this permit. The owners and operators of this acid rain unit shall comply with the standard requirements and special provisions set forth in DEP Form No. 62-210.900(1)(a)2 and 62-210.900(1)(a)3., effective April 16, 2001, signed by the Designated Representative on September 27, 2004, and received by the Department on September 28, 2004. This unit is subject to the following: 40 CFR 72.1 which requires the unit to have an Acid Rain Part as part of its Title V permit; 40 CFR 72.2 which provides associated definitions; 40 CFR 72.3 which provides measurements, abbreviations, and acronyms; 40 CFR 72.4 which provides the federal authority of the Administrator; 40 CFR 72.5 which provides the authority of the states; 40 CFR 72.6 which makes the boiler a Phase II unit; 40 CFR 72.10 which gives the public access to information about this unit; and, 40 CFR 72.13 which incorporates certain ASTM methods into 40 CFR Part 72. [Chapter 62-213, F.A.C.; and Rule 62-214.340, F.A.C.]



**IV.A.2.** Sulfur dioxide (SO<sub>2</sub>) allowance allocations for the Acid Rain unit are as follows:

E.U. ID No.	EPA ID No.	YEAR	2005	2006	2007	2008	2009
001 (retired)	1	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	2571*	2571*	2571*	2571*	2571*
005, 006 (New Units Exemption)	D-1, D-2	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	100	100	100	100	100

\*The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the US EPA under Table 2 of 40 CFR 73.]

**IV.A.3. Emission Allowances.** Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.440(3), F.A.C.

b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain program.

c. Allowances shall be accounted for under the Federal Acid Rain Program.  
 [Rules 62-213.440(1)(c)1., 2., & 3., F.A.C.]

**IV.A.4.** The designated representative of this acid rain unit applied for an exemption from the requirements of the Federal Acid Rain Program by submitting a completed and signed "Retired Unit Exemption" form (DEP Form No. 62-210.900(1)(a)3., F.A.C., attached) and "New Unit Exemption" form (DEP Form No. 62-210.900(1)(a)2., F.A.C., attached) to the Department. The date of permanent retirement is January 1, 1998.

[Rule 62-214.340(2), F.A.C.; and 40 CFR 72.8.]

**IV.A.5. Statement of Compliance.** The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year.

{See Condition No. 51., Appendix TV-4, Title V Conditions.}

[Rule 62-214.420(11), F.A.C.]

**IV.A.6.** Where an applicable requirement of the Act is more stringent than applicable regulations promulgated under Title IV of the Act, both provisions shall be incorporated into the permit and shall be enforceable by the Administrator.

[40 CFR 70.6(a)(1)(ii); and Rule 62-210.200, F.A.C., Definitions – Applicable Requirements.]

**IV.A.7.** Comments, notes, and justifications: None.

**Appendix H-1, Permit History/ID Number Changes**

Keys Energy Services  
Stock Island Power Plant

**DRAFT Permit No. 0870003-006-AV**  
**Facility ID No. 0870003**

---

**Permit History (For tracking purposes):**

<u>E.U. ID No.</u>	<u>Description</u>	<u>Permit No.</u>	<u>Issued</u>	<u>Expiration Date</u>	
001	Steam Turbine (EPA ID #1)	AO44-245479 AC44-61820	05/03/94 12/17/82	04/25/99 06/15/83	RETIRED January, 1998
002	Diesel Peaking Unit #1	AO44-175804	02/20/90	02/20/95	Now in E.U. 010
003	Diesel Peaking Unit #2	AO44-175804	02/20/90	02/20/95	Now in E.U. 010
004	Diesel Peaking Unit #3	AO44-175804	02/20/90	02/20/95	Now in E.U. 010
005 & 006	8.8 MW Medium Speed Diesel Generators D-1 & D-2	AO44-207419 AC44-221256/ AC4452197/ PSD-FL-135	03/19/93 03/19/93 06/05/89	12/31/97 03/18/94 04/01/91	
007	23.5 MW Simple Cycle Combustion Turbine CT-1	AC44-245399/ PSD-FL-210	09/28/95	12/31/96	
008 & 009	19.8 MW Simple Cycle Combustion Turbines CT-2 & CT-3	0870003-003-AC & 0870003-004-AC	01/08/98 04/13/98	01/08/00 05/19/00	
010	Unregulated Emissions Units	0870003-001-AV	01/01/00	12/31/04	

---

**ID Number Changes:** From: Facility ID No. 52FTM440003; To: Facility ID No. 0870003  
From: E.U. ID No. 002, 003, 004; To: E.U. ID No. 010; Note: 010 units are all unregulated units.

Notes: 1 - AO permits automatic extensions in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.  
{Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}

## **Appendix I-1, List of Insignificant Emissions Units and Activities**

Keys Energy Services  
Stock Island Plant  
Page 1 of 2

**DRAFT Permit No. 0870003-006-AV**

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62-210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

### **Brief Description of Emissions Units and Activities**

1. Internal combustion engines in boats, aircraft and vehicles used for transportation of passengers or freight.
2. Cold storage refrigeration equipment, except for any such equipment located at a Title V source using an ozone-depleting substance regulated under 40 CFR Part 82.
3. Vacuum pumps in laboratory operations.
4. Equipment used for steam cleaning.
5. Belt or drum sanders having a total sanding surface of five square feet or less and other equipment used exclusively on wood or plastics or their products having a density of 20 pounds per cubic foot or more.
6. Equipment used exclusively for space heating, other than boilers.
7. Laboratory equipment used exclusively for chemical or physical analyses.
8. Brazing, soldering or welding equipment.
9. One or more emergency generators located within a single facility provided:
  - a. None of the emergency generators is subject to the Federal Acid Rain Program; and
  - b. Total fuel consumption by all such emergency generators within the facility is limited to 32,000 gallons per year of diesel fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.

## Appendix I-1, List of Insignificant Emissions Units and Activities

Keys Energy Services  
Stock Island Plant  
Page 2 of 2

DRAFT Permit No. 0870003-006-AV

10. One or more heating units and general purpose internal combustion engines located within a single facility provided:
  - a. None of the heating units or general purpose internal combustion engines is subject to the Federal Acid Rain Program; and
  - b. Total fuel consumption by all such heating units and general purpose internal combustion engines within the facility is limited to 32,000 gallons per year of diesel fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
11. Fire and safety equipment.
12. Surface coating operations within a single facility if the total quantity of coatings containing greater than 5.0 percent VOCs, by volume, used is 6.0 gallons per day or less, averaged monthly, provided:
  - a. Such operations are not subject to a volatile organic compound Reasonably Available Control Technology (RACT) requirement of Chapter 62-296, F.A.C.; and
  - b. The amount of coatings used shall include any solvents and thinners used in the process including those used for cleanup.
13. Surface coating operations utilizing only coatings containing 5.0 percent or less VOCs, by volume.
14. Degreasing units using heavier-than-air vapors exclusively, except any such unit using or emitting any substance classified as a hazardous air pollutant.

Note: No exemption shall be granted to any emissions unit or activity if:

1. Such unit or activity would be subject to any unit-specific applicable requirement;
2. Such unit or activity, in combination with other units and activities proposed for exemption, would cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s); or
3. Such unit or activity would emit or have the potential to emit:
  - a. 500 pounds per year or more of lead and lead compounds expressed as lead;
  - b. 1,000 pounds per year or more of any hazardous air pollutant;
  - c. 2,500 pounds per year or more of total hazardous air pollutants; or
  - d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C.]

**Appendix U-1, List of Unregulated Emissions Units and Activities**

Keys Energy Services  
Stock Island

**DRAFT Permit No. 0870003-006-AV**

Unregulated Emissions Units and Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and activities are neither “regulated emissions units” nor “insignificant emissions units”.

**E.U.**

**ID No.**

**Brief Description of Emissions Units and Activities**

- 010 Two No. 2 Fuel Oil Storage Tanks - 500,000 gallons each; subject only to 40 CFR 60.116b (a) and (b)  
  
No. 6 Fuel Oil Storage Tank - 1.9 million gallons; no applicable standards  
  
Two No. 2 Fuel Oil Storage “day” Tanks - 16,000 gallons each  
  
Eight Vehicular Fleet Fuel Tanks - 2,000 gallons each  
  
Three Diesel Peaking Generators (2 MW): Units #1, #2, #3 (formerly E.U. 002, 003, & 004)

**Table 1-1, Summary of Air Pollutant Standards and Terms**

Keys Energy Services  
Stock Island Power Plant

**DRAFT Permit No.0870003-006-AV**  
**Facility ID No. 0870003**

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

**E.U. 005, 006**                      **8.8 MW 85.4 MMBtu/hr Medium Speed Diesel Generators, Two Units**  
**Emission Limits are for Each Engine**

Pollutant/Parameter	Fuel	Hours/Year	Allowable Emissions			Equivalent Emissions		Regulatory Citations	See Permit Condition
			Standards	lbs/hour	TPY	lbs./hour	TPY		
SO2	#2 oil	3740 Full-load equivalent	0.05% fuel	43.6	41.00			Rule 62-212.400, BACT	III.A.3, A.6
PM	#2 oil	Engine hours	0.1 lbs/MMBtu	8.5	8			Rule 62-296.702	III.A.7
VE	#2 oil		20% opacity					Rule 62-296.320(4)(b)1	II.3
NOx	#2 oil		6.0 grams/hp-hour	160.9	151			Rule 62-212.400, BACT	III.A.5
CO	#2 oil		2.0 grams/hp-hour	53.6	50			Rule 62-212.400, BACT	III.A.8
Beryllium (Be)	#2 oil			0.00054	1			Rule 62-212.400, BACT	III.A.10
VOC	#2 oil		1.0 grams/hp-hour	26.8	25			Rule 62-212.400, BACT	III.A.9

Notes:  
\*Equivalent Emissions provided for information only.

**Table 1-1, Summary of Air Pollutant Standards and Terms**

Keys Energy Services  
Stock Island Power Plant

**DRAFT Permit No. 0870003-006-AV**  
**Facility ID No. 0870003**

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

**E.U. 008, 009      19.77 MW 305 MMBtu/hour Simple Cycle Combustion Turbine, Two Units**

Pounds/hour apply to each turbine, while TPY limit is for both units combined

Pollutant/Parameter	Fuel	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citations	See Permit Condition
			Standard(s)	lbs/hour	TPY	lbs./hour	TPY		
SO2	#2 oil		0.05% fuel only			15.9	31.8	AC-0870003-003	III.C.5,C.9
PM	#2 oil			16.6	45	16.6	55	AC-0870003-003	III.C.10
CO	#2 oil			25.2	101	25.2	50.5	AC-0870003-003	III.C.11
NOx	#2 oil		75 ppm	93.8	172			AC-0870003-003	III.C.8
VE	#2 oil		20%				n/a	AC-0870003-003	III.C.11

Notes:

\*Equivalent Emissions provided for information only.



**Table 1-1, Summary of Air Pollutant Standards and Terms**

Keys Energy Services  
Stock Island Power Plant

**DRAFT Permit No. 0870003-006-AV**  
**Facility ID No. 0870003**

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

**E.U. 007      23.5 MW 312 MMBtu/hour Simple Cycle Combustion Turbine CT-1**

Pollutant/Parameter	Fuel	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citations	See Permit Condition
			Standard(s)	lbs/hour	TPY	lbs./hour	TPY		
SO2	#2 oil		0.05% fuel only					AC44-245399 PSD-FL-210	III.B.5.
PM	#2 oil			18	43	18	43	AC44-245399 PSD-FL-210	III.B.6.
CO	#2 oil		100% load: 20 ppm 50% load: 136 ppm	64	152	64	152	AC44-245399 PSD-FL-210	III.B.7.
NOx	#2 oil		75 ppmvd at 15% O2	96	138	96	138	AC44-245399 PSD-FL-210	III.B.4.
VE	#2 oil		20%				n/a	AC44-245399 PSD-FL-210	III.B.8.

Notes:  
\*Equivalent Emissions provided for information only.

**Table 2-1, Summary of Compliance Requirements**

Keys Energy Services  
 Stock Island Power Plant

**DRAFT Permit No. 0870003-006-AV**  
**Facility ID No. 0870003**

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

**E.U. 005.006**  
**8.8 MW 85.4 MMBtu/hour Two Medium Speed Diesel Generators**

Pollutant/ Parameter	Fuel	Compliance Method	Frequency of Sampling	Frequency Base Date *	Min. Compliance Test Duration	CMS**	Permit Condition
CO	#2 oil	EPA Method 10	annual	01-Jun			III.A.15
VE	#2 oil	DEP Method 9	permit renewal	01-Jun			II.3 & III.A.17
NOx	#2 oil	EPA Method 20	annual	01-Jun			III.A.15
SO2	#2 oil	EPA Method 6 or ASTM D 2880-71	permit renewal	01-Jun			III.A.16
PM	#2 oil	EPA Method 5	annual	01-Jun			III.A.15
VOC	#2 oil	EPA Method 25	permit renewal	01-Jun			III.A.16
Beryllium	#2 oil	EPA Method 104	annual	01-Jun			III.A.15

**Notes:**

\*Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

\*\*CMS = continuous monitoring system

**Table 2-1, Summary of Compliance Requirements**

Keys Energy Services  
Stock Island Power Plant

**DRAFT Permit No.0870003-006-AV**  
**Facility ID No. 0870003**

This table summarizes information for convenience purposes only, & does not supersede any terms or conditions of this permit.

**E.U. 007                    23.5 MW 312 MMBtu/hour Simple Cycle Combustion Turbine**  
**E.U. 008, 009            19.77 MW 305 MMBtu/hour Simple Cycle Combustion Turbine, Two Units**

Pollutant/ Parameter	Fuel	Compliance Method	Frequency of Sampling	Frequency Base Date *	Min. Compliance Test Duration	CMS**	Permit Condition
SO <sub>2</sub>	No. 2 oil	ASTM4294 or equivalent	After each fuel oil shipment	Per 40 CFR 60.334			III.E.11
PM	No. 2 oil	EPA Method 5B	annual				III.E.10
VE	No. 2 oil	DEP Method 9	annual				III.E.10
CO	No. 2 oil	EPA Method 10	annual				III.E.10
NO <sub>x</sub>	No. 2 oil	EPA Method 20	annual				III.E.10

**Notes:**

\*Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C.

\*\*CMS = continuous monitoring system

# New Unit Exemption

For more information, see instructions and refer to Rule 62-214.340(1), F.A.C. and 40 CFR 72.7

This submission is:  New  Revised

Page 1 of 2

**STEP 1**  
Identify the new unit by plant name, State, ORIS Code (if assigned) and unit ID#.

Plant Name	Stock Island Power Plant	State	Florida	ORIS Code	7143	Unit ID#	D-1
------------	--------------------------	-------	---------	-----------	------	----------	-----

**STEP 2**  
List to one decimal place the nameplate capacity of each generator served by the unit. Then total these entries and enter the result.

						TOTAL
8.8						8.8
MWe	MWe	MWe	MWe	MWe	MWe	MWe

**STEP 3**  
List all fuels currently burned or expected to be burned, by the unit, and the percent sulfur content by weight of each.

Fuel (current)	Sulfur Content (current)	Fuel (expected)	Sulfur Content (expected)
No. 2 Fuel Oil	0.05 %	No. 2 Fuel Oil	0.05 % or less
	%		%
	%		%

**STEP 4**  
Identify the first full calendar year in which the unit meets (or will meet) the requirements of 40 CFR 72.7(a).

January 1, 2004 \_\_\_\_\_.

**STEP 5**  
Read the special provisions.

### Special Provisions

- (1) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(1), F.A.C., shall (i) comply with the requirements of 40 CFR 72.7(a) for all periods for which the unit is exempt under Rule 62-214.340(1), F.A.C., and (ii) comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (2) For any period for which a unit is exempt under Rule 62-214.340(1), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR part 74. As a non-Acid Rain unit, the unit shall continue to be subject to any other applicable requirements under 40 CFR part 70.
- (3) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(1), F.A.C., shall retain at the source that includes the unit records demonstrating that the requirements of 40 CFR 72.7(a) are met. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the Department. Such records shall include, for each delivery of fuel to the unit or for fuel delivered to the unit continuously by pipeline, the type of fuel, the sulfur content, and the sulfur content of each sample taken. The owners and operators bear the burden of proof that the requirements of paragraph 40 CFR 72.7(a) are met.
- (4) On the earliest of the following dates, a unit exempt under Rule 62-214.340(1), F.A.C., shall lose its exemption and become an Acid Rain unit: (i) the date on which the unit first serves one or more generators with total nameplate capacity in excess of 25 MWe; (ii) the date on which the unit burns any coal or coal-derived fuel except for coal-derived gaseous fuel with a total sulfur content no greater than natural gas; or (iii) January 1 of the year following the year in which the annual average sulfur content for gaseous fuel burned at the unit exceeds 0.05 percent by weight (as determined under 40 CFR 72.7(d)) or for nongaseous fuel burned at the unit exceeds 0.05 percent by weight (as determined under 40 CFR 72.7(d)). Notwithstanding 40 CFR 72.30(b) and (c), the designated representative for a unit that loses its exemption under 40 CFR 72.7 shall submit a complete Acid Rain part application 60 days after the first date on which the unit is no longer exempt. For the purpose of applying monitoring requirements under 40 CFR part 75, a unit that loses its exemption under Rule 62-214.340(1), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit is no longer exempt.

Plant Name (from Step 1)

**STEP 6**  
Read the appropriate  
certification and sign  
and date.

**Certification (for designated representative only)**

I am authorized to make this submission on behalf of the owners and operators of the acid rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name <i>Edward Garcia</i>	
Signature <i>Edward Garcia</i>	Date <i>9/27/04</i>

**Certification (for certifying officials only)**

I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	
Signature	Date

**Certification (for additional certifying officials, if applicable)**

I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	
Signature	Date

**Certification (for additional certifying officials, if applicable)**

I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	
Signature	Date

# New Unit Exemption

For more information, see instructions and refer to Rule 62-214.340(1), F.A.C. and 40 CFR 72.7

This submission is:  New  Revised

Page / of 2

**STEP 1**  
Identify the new unit by plant name, State, ORIS Code (if assigned) and unit ID#.

Plant Name	Stock Island Power Plant	State	Florida	ORIS Code	7144	Unit ID#	D-2
------------	--------------------------	-------	---------	-----------	------	----------	-----

**STEP 2**  
List to one decimal place the nameplate capacity of each generator served by the unit. Then total these entries and enter the result.

					TOTAL
8.8					8.8
MWe	MWe	MWe	MWe	MWe	MWe

**STEP 3**  
List all fuels currently burned or expected to be burned, by the unit, and the percent sulfur content by weight of each.

Fuel (current)	Sulfur Content (current)	Fuel (expected)	Sulfur Content (expected)
No. 2 Fuel Oil	0.05 %	No. 2 Fuel Oil	0.05 % or less
	%		%
	%		%

**STEP 4**  
Identify the first full calendar year in which the unit meets (or will meet) the requirements of 40 CFR 72.7(a).

January 1, 2004 \_\_\_\_\_

**STEP 5**  
Read the special provisions.

### Special Provisions

- (1) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(1), F.A.C., shall (i) comply with the requirements of 40 CFR 72.7(a) for all periods for which the unit is exempt under Rule 62-214.340(1), F.A.C., and (ii) comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (2) For any period for which a unit is exempt under Rule 62-214.340(1), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR part 74. As a non-Acid Rain unit, the unit shall continue to be subject to any other applicable requirements under 40 CFR part 70.
- (3) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(1), F.A.C., shall retain at the source that includes the unit records demonstrating that the requirements of 40 CFR 72.7(a) are met. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the Department. Such records shall include, for each delivery of fuel to the unit or for fuel delivered to the unit continuously by pipeline, the type of fuel, the sulfur content, and the sulfur content of each sample taken. The owners and operators bear the burden of proof that the requirements of paragraph 40 CFR 72.7(a) are met.
- (4) On the earliest of the following dates, a unit exempt under Rule 62-214.340(1), F.A.C., shall lose its exemption and become an Acid Rain unit: (i) the date on which the unit first serves one or more generators with total nameplate capacity in excess of 25 MWe; (ii) the date on which the unit burns any coal or coal-derived fuel except for coal-derived gaseous fuel with a total sulfur content no greater than natural gas; or (iii) January 1 of the year following the year in which the annual average sulfur content for gaseous fuel burned at the unit exceeds 0.05 percent by weight (as determined under 40 CFR 72.7(d)) or for nongaseous fuel burned at the unit exceeds 0.05 percent by weight (as determined under 40 CFR 72.7(d)). Notwithstanding 40 CFR 72.30(b) and (c), the designated representative for a unit that loses its exemption under 40 CFR 72.7 shall submit a complete Acid Rain part application 60 days after the first date on which the unit is no longer exempt. For the purpose of applying monitoring requirements under 40 CFR part 75, a unit that loses its exemption under Rule 62-214.340(1), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit is no longer exempt.

Plant Name (from Step 1)

**STEP 6**  
Read the appropriate  
certification and sign  
and date.

**Certification (for designated representative only)**

I am authorized to make this submission on behalf of the owners and operators of the acid rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name <i>Edward Garcia</i>	
Signature <i>Edward Garcia</i>	Date <i>9/27/04</i>

**Certification (for certifying officials only)**

I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	
Signature	Date

**Certification (for additional certifying officials, if applicable)**

I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	
Signature	Date

**Certification (for additional certifying officials, if applicable)**

I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	
Signature	Date

# Retired Unit Exemption

For more information, see instructions and refer to Rule 62-214.340(2), F.A.C., and 40 CFR 72.8

This submission is:  New  Revised

Page 1

**STEP 1**  
Identify the unit by plant name, State, ORIS code and unit ID#.

Ralph Garcia Steam Plant	Florida	6584	# 1
Plant Name	State	ORIS Code	Unit ID#

**STEP 2**  
Identify the first full calendar year in which the unit meets (or will meet) the requirements of Rule 62-214.340(2)(a), F.A.C.

January 1, 1998 \_\_\_\_\_.

**STEP 3**  
Read the special provisions.

**Special Provisions**

- (1) A unit exempt under Rule 62-214.340(2), F.A.C., shall not emit any sulfur dioxide and nitrogen oxides starting on the date that the exemption takes effect. The owners and operators of the unit will be allocated allowances in accordance with 40 CFR part 73 subpart B. If the unit is a Phase I unit, for each calendar year in Phase I, the designated representative of the unit shall submit a Phase I permit application in accordance with 40 CFR part 72 subparts C and D and an annual certification report in accordance with 40 CFR 72.90 through 72.92 and is subject to 40 CFR 72.95 and 72.96.
- (2) A unit exempt under Rule 62-214.340(2), F.A.C., shall not resume operation unless the designated representative of the source that includes the unit submits a complete Acid Rain part application under Rule 62-214.320, F.A.C., for the unit not less than 24 months prior to the date on which the unit is first to resume operation.
- (3) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(2), F.A.C., shall comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) For any period for which a unit is exempt under Rule 62-214.340(2), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR part 74. As a non-Acid Rain Unit, the unit shall continue to be subject to any other applicable requirements under 40 CFR part 70.
- (5) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(2), F.A.C., shall retain at the source that includes the unit records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the Department. The owners and operators bear the burden of proof that the unit is permanently retired.
- (6) On the earlier of the following dates, a unit exempt under Rule 62-214.340(2), F.A.C., shall lose its exemption and become an Acid Rain Unit: (i) the date on which the designated representative submits an Acid Rain part application under paragraph (2); or (ii) the date on which the designated representative is required under paragraph (2) to submit an Acid Rain part application. For the purpose of applying monitoring requirements under 40 CFR part 75, a unit that loses its exemption under Rule 62-214.340(2), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit resumes operation.

**STEP 4**  
Read the appropriate certification and sign and date.

**Certification ( for designated representatives only)**

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name <i>Edward Garcia</i>	
Signature <i>Edward Garcia</i>	Date <i>9/27/04</i>



Tom - Can you please compare  
what they will do with rules?  
How does this square with their  
Title V permits?

Please call Deborah Slaw  
and tell her Tina & I Al  
will likely drop by on Monday afternoon.

AL -  
I called  
DEBORAH  
TOLA WERE  
TO GO  
RACIC -  
OK  
AHEAD -  
Tom  
12-3-04