



FLORIDA KEYS ELECTRIC COOPERATIVE ASSOCIATION, INC. - FKEC

91805 OVERSEAS HIGHWAY P.O. BOX 700377, TAVERNIER, FL 33070-0377 PHONE (305) 852-2431 FAX: (305) 852-4754

Mr. Cleve Holladay
Dept. of Environmental Protection
Bureau of Air Resources
Mail Station 5505
2600 Blairstone Rd.
Tallahassee, FL 32399-2400

Post-it® Fax Note 7671		Date 3-4-98	# of pages 2
To CLAVE HOLLADAY		From DEB. SHAW	
Co./Dept. FDEP		Co. FKEC	
Phone # 850/488-1344		Phone # 305/852-2431	
Fax # 850/922-6929		Fax # 305/852-9129	

Re: Design and engineering measures taken to reduce emissions on Unit #8.

4 March 1998

Dear Mr. Holladay:

As per your request of Monday, 3/2/98, I am faxing additional information describing exactly what measures were taken to reduce emissions from Unit #8 at the Marathon Generating Plant. The information was supplied by Mr. Robin Weeks of Engine Systems, Inc.

Please call me if you need more information or the fax is not legible. I will be working in the field later today and I can be reached at 305/852-6501. I will take my copy with me if you wish to discuss details. Thanks for your assistance, Cleve.

Sincerely,


Deborah A. Shaw, Ph.D.

Environmental Affairs Coordinator/Biologist

Enc:
Letter from Robin Weeks, ESL

PC:

C. Russell
T. Planner

ENGINE SYSTEMS INC.PO BOX 1928
ROCKY MOUNT, NC 27802-19281220 S WASHINGTON STREET
ROCKY MOUNT, NC, 27801**Fax Cover Sheet**

DATE: March 3, 1998

TO: Chris Pankow
FKECPHONE: 305-743-5323
FAX: 305-743-9191FROM: Robin L Weeks *Ph*
Sales Support/EngineeringPHONE: 919-977-2720
FAX: 919-446-3830

RE: Unit 8 Emissions modifications to Engine

CC:

Number of pages including cover sheet: 1

Message

The following modifications were made to the standard engine configuration to reach the emissions goals:

1. The four pass aftercoolers we used were of a higher flow rate design on the water side, i.e. through the tubes. This allowed us to use an aggressive flow rate of 150 gpm through each aftercooler core, and enabled a lowered airbox temperature relative to utilizing the standard aftercooler cores EMD provides with this engine.
2. The separately cooled circuit uses the available sea water as a relatively cool medium in the heat exchanger. By utilizing the design value of 88°F sea water, we are able to supply the aftercooler cores with approximately 90-92°F fresh water on the engine side of the aftercooler heat exchanger. This greatly reduces the engine airbox temperature relative to using 175-180°F fresh water as would have been the case using the standard EMD cooling system.
3. The 6° retarded fuel injection timing was the third modification. We originally intended to retard 4°, however after much discussion with Tim Paulson at EMD, it was decided that 6° retarded fuel injection timing was probably necessary to guarantee meeting our contractual requirements.

I believe the comment about fuel injectors concerns the spray tip pattern. EMD found that an older version of the injector tip was spraying some fuel directly onto the crowns of some of the valves, which caused incomplete atomization to occur. They changed the angle of the orifices in the spray tip to prevent this from occurring. All of their engines use the new pattern, and we did not change these.

I hope this clarifies the questions you have. Please forward this information to Deborah Shaw and Tim Planer.

Thank you

6132F121.DOC

*Do they have a continuous
combustion monitoring system*

February 20, 1998

FKEC's facility was remodeled to reflect its request for a higher NO_x limit for Unit 8. The requested limit is 68 lb/hr or 8.57 g/s. The results of the modeling reflecting this change are shown below

Requested Emission Rates and Stack Parameters for FKEC

Emission Units	Emission Rate (g/s)	Stack Height (m)	Stack Temp °K	Stack Vel (m/s)	Stack Diameter (m)
Unit 8	8.57	11.79	625	34.6	0.71
Unit 1	2.96	6.15	669	27.3	0.71
Unit 2	3.85	6.15	669	27.3	0.71
Unit 3	4.64	11.43	677	38.9	0.66
Unit 4	4.44	11.43	677	38.9	0.66
Unit 5	5.11	11.43	677	38.9	0.66
Unit 6	4.72	7.20	664	23.8	0.76
Unit 7	4.40	7.20	664	23.8	0.76

Location of Emission Units in Smith

Emission Units	x (m)	y (m)
No. 8	0.0	0.0
No. 1	-71.1	-34.8
No. 2	-71.1	-28.2
No. 3	-6.7	0.0
No. 4	-14.8	0.0
No. 5	-20.4	0.0
No. 6	-74.0	-48.9
No. 7	-74.0	-43.0

MODEL RESULTS FKEC (All Values in ug/m³, annual average)

	MET DATA	AAQS=100	PSD Class II=25	PSD Class I SIL=0.1
		CONC	CONC	CONC
1987	Key West/Miami	77	18	0.04
1988	Key West/Miami	89	16	0.04
1989	Key West/Miami	89	18	0.03
1990	Key West/Miami	87	21	0.02
1991	Key West/Miami	97	21	0.02

Files: fk50_68.o87 through fk50_68.o91 for AAQS, fkpspd68.o87 through fkpspd68.o91 for PSD Class II, fkpsdc1.o87 through fkpsdc1.o90



South Florida Environmental Services

FINAL TEST REPORT

EMISSIONS COMPLIANCE TEST PROGRAM

FLORIDA KEYS ELECTRIC COOPERATIVE

MARATHON FACILITY

PREPARED FOR:

Engine Systems, Inc.
1220 Washington Street
Rocky Mount, NC 27802-1928

CONCERNING:

NO_x, CO, VOC and Opacity Compliance Testing
Emission Unit #8 3.58 MW Diesel Electric Generator
Florida Keys Electric Cooperative Association, Inc.
Marathon Facility
December 17, 1997

PREPARED BY:

South Florida Environmental Services
6821 Vista Parkway North
West Palm Beach, Florida 33411
SFES #97-581



Ron C. Cook Jr.
Senior Project Director



Date

RECEIVED

JAN 28 1998

BUREAU OF
AIR REGULATION

TABLE OF CONTENTS

1.	COMPENDIUM	p. 1
2	REFERENCE METHOD SAMPLING LOCATION	p. 3
3.	SAMPLE POINT LOCATIONS	p. 4
4.	SAMPLING TRAIN AND ANALYTICAL PROCEDURES	p. 5
5.	QUALITY CONTROL PROCEDURES	p. 11

APPENDICES

A	CEMS/VOC EMISSION CALCULATIONS
B	OPACITY OBSERVATIONS
C	CALIBRATION GAS CERTIFICATIONS
D	FIELD DATA SHEETS
E	STRIP CHARTS
F	NOMENCLATURE
G	FACILITY OPERATING DATA

1.0 COMPENDIUM

South Florida Environmental Services conducted an emissions compliance test program on behalf of Engine Systems, Inc. at Florida Keys Electric Cooperative Association, Inc. located in Marathon, Florida. The testing was conducted on the newly installed EMD generator set rated at 3.58 MW and took place on December 17, 1997.

The objective of the testing program was to determine the Compliance/Performance status of EMD diesel generator #8 with respect to oxides of nitrogen, carbon monoxide, total hydrocarbons and opacity limits. Set forth by the Florida, Department of Environmental Protection (FDEP) and Florida Keys Electric Cooperative.

All test methods and procedures were conducted in strict accordance with EPA Methods 3A, 7E, 9, 10 and 25A as found in the Federal Register (40CFR60), Appendix A. The approved test plan was adhered to throughout the program. All lb/MMBtu emission rates are based on the F-factor for oil in accordance with EPA Method 19.

The gaseous (CEM/VOC) sampling consisted of three 1-hour runs during the test program while the unit was operating at 100% of rated capacity. Final results can be found in Table 1-1.

The opacity determination was an hour visible emissions run consisting of 240 readings, 4 readings per minute, from which the highest 6-minute average and maximum opacity values were obtained and reported as percent opacity. Final results can be found in Table 1-2.

Ron C. Cook Jr. Senior Project Director, was responsible for all phases of the test program he was assisted by a team of qualified environmental professionals. Robin L. Weeks of Engine Systems, Inc. coordinated unit operation with testing. Tim Planner of Florida Keys Electric Cooperative was the company's representative.

1.0 COMPENDIUM (cont.)

The following tables summarize the results of the emissions testing program.

Table 1-1
Summary of Results
FKEC Emission Unit # 8
EMD Diesel Electric Generator
NO_x

Run #	Time	BHP	NO _x Gms/bhp-hr	NO _x lb/hr	NO _x Tons/yr
1	1500-1600	4981	6.01	65.95	288.86
2	1635-1735	4988	6.01	66.09	289.47
3	1800-1900	4983	5.93	65.10	285.14
Average			5.98	65.71	287.82

CO

Run #	Time	BHP	CO Gms/bhp-hr	CO lb/hr	CO Tons/yr
1	1500-1600	4981	.49	5.40	23.65
2	1635-1735	4988	.49	5.38	23.56
3	1800-1900	4983	.49	5.38	23.56
Average			.49	5.39	23.59

THC

Run #	Time	BHP	THC Gms/bhp-hr	THC lb/hr	THC Tons/yr
1	1500-1600	4981	.15	1.70	7.45
2	1635-1735	4988	.16	1.72	7.53
3	1800-1900	4983	.15	1.69	7.40
Average			.15	1.70	7.46


Note: Tons/yr were calculated using 8760 hours or continuous operation

Table 1-2
Visible Emission Results

Unit #	Length of Test	Highest 6 min. Average	Readings above 20%
EMD #8	60	5.0%	NONE

2.0 REFERENCE METHOD SAMPLING LOCATION

The emissions were measured in the 2.3-foot diameter exhaust duct. The sampling location is indoors, and is accessible via a man lift platform. Two 3-inch diameter sampling ports are installed 90° apart. Figure 2-1 depicts the sampling location.



Description	Dimension
Port To Downstream (A)	9.5 feet
Upstream To Port (B)	23.5 feet
Duct Diameter (C)	2.3 feet
Number Of Ports	2

Figure 2-1
Stack Sampling Location

3.0 SAMPLING POINT LOCATIONS

The stack has an inside diameter of 2.3-feet at the sampling location. The distance from the sampling ports to the nearest downstream disturbance is 9.5 feet or 4.1 diameters. The distance from the nearest upstream disturbance to the sampling ports is 23.5 feet or 10.2 diameters. Based upon the requirements of Methods in Appendix B, Specification 2, the CEM probe was placed at a total of 3 sampling points. The CEM probe was marked according to the measurements in Table 3-1. A rake probe was used to satisfy this criteria.

Table 3-1
CEM Sampling Points

Traverse Point	Distance %	Probe Marking
1	16.7	4.68"
2	50.0	14.00"
3	83.3	23.32"

4.0 SAMPLING TRAIN AND ANALYTICAL PROCEDURES

The subject unit was tested for nitrogen oxides, carbon monoxide, opacity and volatile organic compound emissions. Each pollutant parameter was tested in strict accordance with official EPA procedures at the sampling locations described in Sections 1, 2 and 3. In this section, the test procedures that were used, including sampling and analysis, are discussed.

4.1 DESCRIPTION OF METHODOLOGY

4.1.1 Nitrogen Oxides

Nitrogen oxides were measured in accordance with EPA Method 7E. This Method utilizes continuous emissions monitoring instrumentation. South Florida Environmental Services uses a Thermo Electron Model 10A NOx chemiluminescent monitor with 8 ranges from 0-10,000 ppm. The instrument meets all of the performance specifications of the Method. It was calibrated before and after each test period using calibration gases prepared according to EPA Protocol #1. Three 60-minute runs were conducted.

4.1.2 Carbon Monoxide/Carbon Dioxide

Carbon monoxide was measured in accordance with EPA Method 10 and carbon dioxide in accordance with EPA Method. This Method utilizes continuous emissions monitoring instrumentation. South Florida Environmental services uses a Fuji Model 3400 non-dispersive infra red analyzer with a range of 0-500 ppm for CO and 0-25% for CO₂. The instrument meets all of the performance specifications of the Methods. It was calibrated before and after each test period using calibration gases prepared according to EPA Protocol #1. Three 60-minute runs were conducted.

4.1.3 Volatile Organic Compounds

VOCs (Total Hydrocarbons) were determined in accordance with EPA Method 25A. This method utilizes a FID analyzer which is calibrated with certified methane standards. South Florida Environmental Services uses a TECO Model #51 flame ionization analyzer with four ranges between 0-10,000 ppm. The instrument meets all of the performance specifications of the Method. It was calibrated before and after each test period using three concentrations of calibration gas in the working range of the instrument. The calibration gases were prepared according to EPA Protocol #1. Three 60-minute runs were conducted.

4.0 SAMPLING TRAIN AND ANALYTICAL PROCEDURES

4.1.4 Oxygen

Oxygen was measured in accordance with EPA Method 3A. This Method utilizes continuous emissions monitoring instrumentation. South Florida Environmental Services uses a Teledyne Model 326A analyzer with a range of 0-25%. The instrument meets all of the performance specifications of the Method. It was calibrated before and after each test period using calibration gases prepared according to EPA Protocol #1.

4.1.5 Opacity

Opacity observations were conducted in accordance with EPA Method 9. South Florida Environmental Services provided an EPA certified visible emissions observer. Measurements were made during each of the compliance test runs. Three 60-minute runs were conducted. Each run consisted of 240 opacity observations which were recorded on Visible Emissions Data Sheets (appended).

4.0 SAMPLING TRAIN AND ANALYTICAL PROCEDURES (cont.)

4.2 DESCRIPTION OF CEM SAMPLING

4.2.1 CEM Sampling System

What follows is a description of the transportable continuous emissions monitor system that was used to quantify oxygen, carbon dioxide, oxides of nitrogen, and carbon monoxide, from the subject unit at the facility. The system meets all the specifications of Reference Methods 3A (O₂/CO₂), 7E (NO_x), and 10 (CO).

Sample Probe - A stainless steel rake probe of sufficient length was used to sample at the location specified in Section 2.0.

Sample Line - Approximately 100' to 150' of 3/8" Teflon tubing (1/16" wall) was used to transport the sample gas from the probe to the sample conditioning system.

Sample Conditioning System-

Filter - A heated spun glass fiber filter was located at the end of the probe to remove particulate from the gas stream.

Condenser (2) - a Universal Analyzer Sample Cooler or ice cooled condenser was located near the probe for bulk moisture removal and a thermo-electric condenser system was located downstream from the pump to remove any remaining moisture from the gas stream

Sample Pump - A diaphragm type vacuum pump was used to draw gas from the probe through the conditioning system and to the analyzers. The pump head is stainless steel, the valve disks are Viton and the diaphragm is Teflon coated.

Calibration Valve - A t-valve, located at the base of the probe, allows the operator to select either the sample stream or inject calibration gas to the CEM system.

4.0 SAMPLING TRAIN AND ANALYTICAL PROCEDURES (cont.)

Sample Distribution System - A series of flow meters, valves and back pressure regulators allowed the operator to maintain constant flow and pressure conditions during sampling and calibration.

Gas Analyzers - capable of the continuous determination of O₂, CO₂, CO, and NO_x concentrations in a sample gas stream. They each meet or exceed the following specifications:

Calibration Error	- Less than $\pm 2\%$ of span for the zero, mid- and hi-range calibration gases.
System Bias	- Less than $\pm 5\%$ of span for the zero, mid- or hi-range calibration gases.
Zero Drift	- Less than $\pm 3\%$ of span over the period of each test run.
Calibration Drift	- Less than $\pm 3\%$ of span over the period of each test run.

Data Acquisition System - A Molytek strip chart/data logger system was used to record analyzer response to the sample and calibration gas streams. The chart recorder operated continuously while the data logger recorded thirty (30) minute interval averages.

The Molytek was linked, via an RS232 cable, to an IBM compatible computer system with a VGA screen. Data was written to file at fifteen (15) second intervals. Separate files for each run, and associated calibrations, were generated. Data was loaded into a spreadsheet for calculation of interval averages and emission rates. Preliminary reports were available on-site.

4.2.2 CEMS Sampling Procedures

All sampling and analytical procedures were conducted in accordance with EPA Reference Methods 3A, 7E, and 10 (40CFR60, Appendix A). The following is the sequence of events leading up to and including the compliance test:

Selection of Sampling Traverse Point Locations - Sampling point locations were determined prior to testing in accordance with EPA Methods 3A, 7E, and 10.

Determination of System Response Time - System response time was determined prior to testing. System response time was determined according to procedures delineated in Performance Specification 2 (40CFR60, Appendix B).

4.0 SAMPLING TRAIN AND ANALYTICAL PROCEDURES (cont.)

Determination of Analyzer Calibration Error - Analyzer calibration error was determined immediately prior to testing in accordance with EPA Methods 3A, 7E, and 10.

Determination of Sampling System Bias - Sampling system bias was determined immediately prior to testing in accordance with EPA Methods 3A, 7E and 10.

Determination of Zero and Calibration Drift - Before and after each test run, each analyzer's response to zero and mid- or hi-range calibration gases were determined. The pre-and post-test analyzer responses were compared to determine drift. The results were evaluated based upon specifications defined in EPA Methods 3A, 7E and 10.

Data Reduction - An average pollutant/diluent concentration for each test run was determined from the data acquisition system. This data was then reduced to determine relative pollutant concentrations.

4.3 DESCRIPTION OF VOLATILE ORGANIC COMPOUNDS SAMPLING

4.3.1 VOC Sampling Equipment

Probe - A single opening 3/8" OD stainless steel probe was used at each sample location.

Calibration Valve - A three way valve was located at the end of each sample line to select either sample mode or system calibration mode.

Sample Line - A heated 3/8" OD Teflon sample line was used to transport the sample stream from the test locations to the analyzers. The lines were heated to the temperature of the sample duct, or to a maximum of 300°F, to maintain integrity of the sample.

System Calibration Line - A 1/4" OD Teflon tube was used to transfer calibration gas from the cylinder to the calibration valve.

VOC Analyzer - The analyzer used was a TECO Model #51 flame ionization analyzer (FIA).

Data Acquisition - The FIA's response was sent to a Molytek Data Acquisition System (DAS). The DAS recorded the response of each FIA on a strip chart recorder and IBM compatible computer via an RS-232 cable. The computer stored each analyzer's response at fifteen second intervals over the course of each run. Run averages were determined from all stored data points over the course of the run.

4.0 SAMPLING TRAIN AND ANALYTICAL PROCEDURES (cont.)

4.3.2 VOC Sampling Procedures

Calibrations - The FIA was calibrated prior to sampling using zero, low, mid and high calibration gases of certified cylinders of methane in a balance of nitrogen. Calibrations were conducted through the entire sample system. A description of the specific procedures is provided below.

Zero: The zero point of the analyzer was determined using a pre-purified cylinder of nitrogen. The zero point was analyzed for a minimum of five minutes to monitor drift before sampling commenced.

High Span: The high calibration gas, ~ 85% of span, was introduced to the sample system and the response of the analyzer was adjusted accordingly.

Mid & Low Span: The mid and low calibration gases, ~50% and 30% of span respectively, were introduced to the sample system and the response of the analyzer was recorded. The analyzer met Method 25A criteria for accuracy.

Sampling - Once the analyzer was calibrated, the system calibration valve was switched to sample mode and sampling was conducted. The response time of the system was determined by the time the valve is actuated to the time the response of the FIA is 95% of the steady state sample value.

Post Calibration - Immediately following each test run, the sample system was switched into calibration mode, and the zero and mid span gas was introduced to monitor analyzer drift. All post calibrations met or exceeded the Method 25A criteria for drift.

5.0 QUALITY CONTROL PROCEDURES

Sampling was conducted by trained personnel with extensive experience in Reference Method sampling.

All sampling and analysis was conducted in strict accordance with EPA test procedures. The quality control procedures found in the EPA Quality Assurance Handbook for Air Pollution Measurement Systems was adhered to as well.

South Florida Environmental Services entire equipment inventory is on a schedule of routine maintenance and calibration. This includes meter boxes, thermocouples, barometers, pitot tubes, sampling nozzles and CEM instrumentation.

All CEM analyzer and system calibrations were performed using NIST-traceable gas prepared in accordance with EPA Protocol #1.

All calculations were conducted in strict accordance with the equations found in the individual Methods. Emission rate calculations were conducted on a computer and the input data was checked by a person other than the original calculator to ensure that it is correct.

These specific procedures in addition to South Florida Environmental Services usual high standard of quality control validated the results obtained in this test program. South Florida Environmental Services is staffed by a team of qualified, experienced environmental professionals. As the majority of our emissions testing work is done for compliance purposes, strict QC procedures are incorporated into our everyday work performance.

APPENDIX A
CEMS/VOC EMISSION CALCULATIONS

EMISSION CALCULATION SHEET

PLANT	FREC	RQNT	NOXCT
LOCATION	GENERATOR #	DATE	1/10/07

Load = 3580 KW

PPMV NOx = 652.65

BTu/gl = 138870

O2 % DRY = 13.26

gl/hr = 242.43

Humidity = 0.008 lb/lbdry air
58.8 gr/lbdry air

Fuel Density = 7.189 lb/gl

" K " = 0.994958

Air Temp = 70 ° F

NOx @15% O2 = NOx PPMV X (20.9-15(20.9-%O2)) = 503.98 ppmvd

NOx Corrected = " K " X NOx @15% O2 = 501.44 ppmvd

CS NOx = NOx PPMV X (1.194 e -7) = 7.79E-05 lb/scf

NOx lb/mmbtu = CS NOx X Fd X 20.9/(20.9-%O2) = 1.96 lb/mmbtu
Fd = 9190

Qs SCFM = NOx lb/hr / CS NOx / 60 = 14105 scfm

NOx lb/hr = NOx lb/btu X btu/gl X gl/hr = 65.95 lb/hr

NOx gms/BHP_HR = NOx lb/hr x 454gms/lb / BHP = 6.01 gms/bhp-hr

TEST BHP = 4981

EMISSION CALCULATION SHEET

PLANT LOCATION	FKEC Generator # 8	RUN #	NOX-2
		DATE	17DEC97

Load = 3580 KW

PPMV NOx = 646.79

BTu/gl = 138870

O2 % DRY = 13.35

gl/hr = 242.27

Humidity = 0.008 lb/lbdry air
58.8 gr/lbdry air

Fuel Density = 7.189 lb/gl

" K " = 0.994956

Air Temp = 70 ° F

NOx @15% O2 = NOx PPMV X (20.9-15(20.9-%O2)) = 505.34 ppmv

NOx Corrected = " K " X NOx @15% O2 = 502.79 ppmv

CS NOx = NOx PPMV X (1.194 e -7) = 7.72E-05 lb/scf

NOx lb/mmbtu = CS NOx X Fd X 20.9/(20.9-%O2) = 1.96 lb/mmbtu
Fd = 9190

Qs SCFM = NOx lb/hr / CS NOx / 60 = 14262 scfm

NOx lb/hr = NOx lb/btu X btu/gl X gl/hr = 66.09 lb/hr

NOx gms/BHP_HR = NOx lb/hr x 454gms/lb / BHP = 6.01

TEST BHP = 4988

EMISSION CALCULATION SHEET

PLANT	FREC	RUN	NOX
LOCATION	Generator # 8	DATE	17DEC97

Load = 3580 KW

PPMV NOx = 646.80

BTu/gl = 138870

O2 % DRY = 13.26

gl/hr = 241.47

Humidity = 0.008 lb/lbdry air
58.8 gr/lbdry air

Fuel
Density = 7.189 lb/gl

" K " = 1.017222

Air Temp = 60 ° F

NOx @15% O2 = NOx PPMV X (20.9-15(20.9-%O2)) = 499.49 ppmv

NOx Corrected = " K " X NOx @15% O2 = 508.09 ppmv

CS NOx = NOx PPMV X (1.194 e -7) = 7.72E-05 lb/scf

NOx lb/mmbtu = CS NOx X Fd X 20.9/(20.9-%O2) = 1.94 lb/mmbtu
Fd = 9190

Qs SCFM = NOx lb/hr / CS NOx / 60 = 14050 scfm

NOx lb/hr = NOx lb/btu X btu/cf X cf/hr = 65.10 lb/hr

NOx gms/
BHP_HR = NOx lb/hr x 454gms/lb / BHP = 5.93

TEST BHP = 4983

EMISSION CALCULATION SHEET

PLANT	FREQ	RUN#	NOX-1
LOCATION	GENERATOR #6	DATE	17DEC97

Load = 3580 KW

PPMV CO = 87.94 BTu/gl 138870

O2 % DRY = 13.26 gl/hr 242.43

Humidity = 0.008 lb/lbdry air Fuel
58.8 gr/lbdry air Density 7.189 lb/gl

" K " = 0.994956 Air Temp 70 ° F

CO @15% O2 = CO PPMVD X (20.9-15(20.9-%O2) = 67.90 ppmvd

CO Corrected = " K " X CO @15% O2 = 67.56 ppmvd

CS CO = CO PPMVD X (28.010/386.3)/1000000 = 6.38E-06 lb/scf

CO lb/mmbtu = CS CO X Fd X 20.9/(20.9-%O2) = 0.16 lb/mmbtu
Fd = 9190

Qs SCFM = CO lb/hr / CS CO / 60 = 14105 scfm

CO lb/hr = CO lb/btu X btu/gl X gl/hr = 5.40 lb/hr

CO gms/
BHP_HR = CO lb/hr x 454gms/lb / BHP = 0.49 gms/bhp-hr

TEST BHP = 4981

EMISSION CALCULATION SHEET

PLANT	FREQ	RUN #	NOX2
LOCATION	GENERATOR #8	DATE	17DEC97

Load = 3580 KW

PPMV CO = 86.70 BTu/gl 138870

O2 % DRY = 13.35 gl/hr 242.27

Humidity = 0.008 lb/lbdry air
58.8 gr/lbdry air Fuel Density 7.189 lb/gl

"K" = 0.994956 Air Temp 70 ° F

CO @15% O2 = CO PPMVD X (20.9-15(20.9-%O2) = 67.74 ppmvd

CO Corrected = "K" X CO @15% O2 = 67.40 ppmvd

CS CO = CO PPMVD X (28.010/386.3)/1000000 = 6.29E-06 lb/scf

CO lb/mmbtu = CS CO X Fd X 20.9/(20.9-%O2) = 0.16 lb/mmbtu
Fd = 9190

Qs SCFM = CO lb/hr / CS CO / 60 = 14262 scfm

CO lb/hr = CO lb/btu X btu/gl X gl/hr = 5.38 lb/hr

CO gms/
BHP_HR = CO lb/hr x 454gms/lb / BHP = 0.49 gms/bhp-hr

TEST BHP = 4988

EMISSION CALCULATION SHEET

PLANT	REC	DATE	NOX
LOCATION : GENERATOR #6		DATE	17DEC97

Load = 3580 KW

PPMV CO = 87.98 BTu/gl 138870

O2 % DRY = 13.26 gl/hr 241.47

Humidity = 0.008 lb/lbdry air Fuel
58.8 gr/lbdry air Density 7.189 lb/gl

"K" = 0.994956 Air Temp 70 ° F

CO @15% O2 = CO PPMVD X (20.9-15)/(20.9-%O2) = 67.94 ppmvd

CO Corrected = "K" X CO @15% O2 = 67.60 ppmvd

CS CO = CO PPMVD X (28.010/386.3)/1000000 = 6.38E-06 lb/scf

CO lb/mmbtu = CS CO X Fd X 20.9/(20.9-%O2) = 0.16 lb/mmbtu
Fd = 9190

Qs SCFM = CO lb/hr / CS CO / 60 = 14050 scfm

CO lb/hr = CO lb/btu X btu/gl X gl/hr = 5.38 lb/hr

CO gms/
BHP_HR = CO lb/hr x 454gms/lb / BHP = 0.49 gms/bhp-hr

TEST BHP = 4983

EMISSION CALCULATION SHEET

POINT	FREQ	RUNTIME	NOV
LOCATION : GENERATOR #8		DATE	12DEC97

Load = 3580 KW

PPMVD THC = 48.36

BTu/gl = 138870

O2 % DRY = 13.26

gl/hr = 242.43

Humidity = 0.008 lb/lbdry air
58.8 gr/lbdry air

Fuel Density = 7.189 lb/gl

" K " = 0.994956

Air Temp = 70 ° F

THC @15% O2 = THC PPMVD X (20.9-15(20.9-%O2)) = 37.34 ppmvd

THC Corrected = " K " X CO @15% O2 = 37.16 ppmvd

CS THC = THC PPMVD X (16.043/386.3)/100000 = 2.01E-06 lb/scf

THC lb/mmbtu = CS THC X Fd X 20.9/(20.9-%O2) = 0.05 lb/mmbtu
Fd = 9190

Qs SCFM = THC lb/hr / CS THC / 60 = 14105 scfm

THC lb/hr = THC lb/btu X btu/gl X gl/hr = 1.70 lb/hr

THC gms/BHP_HR = THC lb/hr x 454gms/lb / BHP = 0.15 gms/bhp-hr

TEST BHP = 4981

EMISSION CALCULATION SHEET

PLANT	TYPE	RUN	NO.
LOCATION	GENERATOR #	DATE	DATE

Load = 3580 KW

PPMVD THC = 48.36

BTu/gl = 138870

O2 % DRY = 13.35

gl/hr = 242.27

Humidity = 0.008 lb/lbdry air
58.8 gr/lbdry air

Fuel Density = 7.189 lb/gl

"K" = 0.994956

Air Temp = 70 ° F

THC @15% O2 = THC PPMVD X (20.9-15(20.9-%O2)) = 37.78 ppmvd

THC Corrected = "K" X CO @15% O2 = 37.59 ppmvd

CS THC = THC PPMVD X (16.043/386.3)/100000 = 2.01E-06 lb/scf

THC lb/mmbtu = CS THC X Fd X 20.9/(20.9-%O2) = 0.05 lb/mmbtu
Fd = 9190

Qs SCFM = THC lb/hr / CS THC / 60 = 14262 scfm

THC lb/hr = THC lb/btu X btu/gl X gl/hr = 1.72 lb/hr

THC gms/BHP_HR = THC lb/hr x 454gms/lb / BHP = 0.16 gms/bhp-hr

TEST BHP = 4988

EMISSION CALCULATION SHEET

PLANT LOCATION	FREQ GENERATOR #8	RUN DATE	NOX3 17DEC87
-------------------	----------------------	-------------	-----------------

Load = 3580 KW

PPMVD THC = 48.36

BTu/gl = 138870

O2 % DRY = 13.26

gl/hr = 241.47

Humidity = 0.008 lb/lbdry air
58.8 gr/lbdry air

Fuel
Density = 7.189 lb/gl

" K " = 0.994956

Air Temp = 70 ° F

THC @15% O2 = THC PPMVD X (20.9-15(20.9-%O2)) = 37.35 ppmvd

THC Corrected = " K " X CO @15% O2 = 37.16 ppmvd

CS THC = THC PPMVD X (16.043/386.3)/100000 = 2.01E-06 lb/scf

THC lb/mmbtu = CS THC X Fd X 20.9/(20.9-%O2) = 0.05 lb/mmbtu
Fd = 9190

Qs SCFM = THC lb/hr / CS THC / 60 = 14050 scfm

THC lb/hr = THC lb/btu X btu/gl X gl/hr = 1.69 lb/hr

THC gms/
BHP_HR = THC lb/hr x 454gms/lb / BHP = 0.15 gms/bhp-hr

TEST BHP = 4983

CALIBRATION CORRECTION SHEET

PLANT	FRESH	DISTRICT	DATE
LOCATION	CHROMIUM	DATE	1981/05/11
START TIME	1000		
END TIME	1600		

SYSTEM CALIBRATION DATA

	POLLUTANT	O2	CO2	CO	SO2	NOX
	INITIAL ZERO	0.00	0.00	1.60		3.80
	FINAL ZERO	0.00	0.10	-0.10		5.00
Co=	AVG ZERO	0.00	0.05	0.75		4.40
	INIT SPAN	12.00	10.20	153.30		913.20
	FINAL SPAN	12.10	10.30	153.10		931.80
Cm=	AVG SPAN	12.05	10.25	153.20		922.50
Cma=	CAL GAS	12.30	10.40	154.00		902.00
$C_{gas} = (C' - Co) \times Cma / (Cm - Co)$						
C'=	Raw RM Data	12.99	6.00	87.80		668.70
Cgas=	Adj. RM data	13.26	6.07	87.94		652.65

CALIBRATION CORRECTION SHEET

PLANT	FUEL	RUN #	NOX #
LOCATION	SPAN/DATE	DATE	17DEC07
START TIME	1635		
END TIME	1735		

SYSTEM CALIBRATION DATA

	POLLUTANT	O2	CO2	CO	SO2	NOX
	INITIAL ZERO	0.00	0.10	-0.10		5.00
	FINAL ZERO	0.00	0.20	1.10		2.40
Co=	AVG ZERO	0.00	0.15	0.50		3.70
	INIT SPAN	12.10	10.30	153.10		931.80
	FINAL SPAN	12.30	10.30	153.80		926.30
Cm=	AVG SPAN	12.20	10.30	153.45		929.05
Cma=	CAL GAS	12.30	10.40	154.00		902.00
$C_{gas} = (C' - C_o) \times C_{ma} / (C_m - C_o)$						
C'=	Raw RM Data	13.24	6.01	86.61		667.23
Cgas=	Adj. RM data	13.35	6.00	86.70		646.79

CALIBRATION CORRECTION SHEET

PLANT	FERRIS	RUN#	NOX#
LOCATION	SHIMMEL 18	DATE	HYDECO
START TIME	1805		
END TIME	1900		

SYSTEM CALIBRATION DATA

	POLLUTANT	O2	CO2	CO	SO2	NOX
	INITIAL ZERO	0.00	0.20	1.10		2.40
	FINAL ZERO	0.00	0.20	3.50		2.40
Co=	AVG ZERO	0.00	0.20	2.30		2.40
	INIT SPAN	12.30	10.30	153.80		926.30
	FINAL SPAN	12.30	10.30	155.80		912.60
Cm=	AVG SPAN	12.30	10.30	154.80		919.45
Cma=	CAL GAS	12.30	10.40	154.00		902.00
$C_{gas} = (C' - Co) \times Cma / (Cm - Co)$						
C'=	Raw RM Data	13.26	6.05	87.98		659.99
Cgas=	Adj. RM data	13.26	6.02	86.52		646.80

APPENDIX B
OPACITY OBSERVATIONS

VISIBLE EMISSIONS TEST
DATA REDUCTION SHEET

COMPANY: FKEC

DATE: 17DEC97

SOURCE: UNIT #8

RUN TIME: 1500-1600

MIN/SEC	0	15	30	45	MIN/SEC	0	15	30	45
1.	5	5	5	5	31.	5	5	5	5
2.	5	5	5	5	32.	5	5	5	5
3.	5	5	5	5	33.	5	5	5	5
4.	5	5	5	5	34.	5	5	5	5
5.	5	5	5	5	35.	5	5	5	5
6.	5	5	5	5	36.	5	5	5	5
7.	5	5	5	5	37.	5	5	5	5
8.	5	5	5	5	38.	5	5	5	5
9.	5	5	5	5	39.	5	5	5	5
10.	5	5	5	5	40.	5	5	5	5
11.	5	5	5	5	41.	5	5	5	5
12.	5	5	5	5	42.	5	5	5	5
13.	5	5	5	5	43.	5	5	5	5
14.	5	5	5	5	44.	5	5	5	5
15.	5	5	5	5	45.	5	5	5	5
16.	5	5	5	5	46.	5	5	5	5
17.	5	5	5	5	47.	5	5	5	5
18.	5	5	5	5	48.	5	5	5	5
19.	5	5	5	5	49.	5	5	5	5
20.	5	5	5	5	50.	5	5	5	5
21.	5	5	5	5	51.	5	5	5	5
22.	5	5	5	5	52.	5	5	5	5
23.	5	5	5	5	53.	5	5	5	5
24.	5	5	5	5	54.	5	5	5	5
25.	5	5	5	5	55.	5	5	5	5
26.	5	5	5	5	56.	5	5	5	5
27.	5	5	5	5	57.	5	5	5	5
28.	5	5	5	5	58.	5	5	5	5
29.	5	5	5	5	59.	5	5	5	5
30.	5	5	5	5	60.	5	5	5	5

NUMBER OF READINGS ABOVE 20% - 0

HIGHEST SIX MINUTE AVERAGE - 5.0 %

OVERALL AVERAGE OPACITY - 5.0 %

READINGS RANGED FROM - 5 TO 5 %



EPA

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)
Methods 203A 203B Other: _____

Company Name
FKEC

Facility Name
SAME

Street Address
MM 29

City
Marathon State **FL** Zip _____

Process
Generator # 8 Unit **8** Operating Mode
3.58 MW

Control Equipment
Operating Mode

Describe Emission Point
Leftmost Silver STACK

Height of Emis. Pt.
Start **~30'** End **~30'**

Distance to Emis. Pt.
Start **~200'** End **~200'**

Height of Emis. Pt. Rel. to Observer
Start **~30'** End **~30'**

Direction to Emis. Pt. (Degrees)
Start **90°** End **90°**

Vertical Angle to Obs. Pt.
Start **~15°** End **~15°**

Distance and Direction to Observation Point from Emission Point
Start **~200'** End **~200'** Direction **90°** End **90°**

Describe Emissions
Start **Smoke** End **Smoke**

Emission Color
Start **LT grey** End **SAME**

Water Droplet Plume
Attached ☐ Detached ☐ None ☒

Describe Plume Background
Start **SKY** End **SKY**

Background Color
Start **Blue** End **SAME**

Wind Speed
Start **~5-10"** End **~5-10"**

Wind Direction
Start **WEST** End **WEST**

Ambient Temp.
Start **70** End **65**

Wet Bulb Temp.
Start _____ End _____

RH Percent
Start _____ End _____

Source Layout Sketch

Draw North Arrow
☐ TN ☐ MN

Observer's Position

Observation Point

Sun Location Line

140°

Side View

Stack With Plume

Sun

Wind

Longitude _____ Latitude _____ Declination _____

Form Number _____ Page **1** of **2**

Continued on VEO Form Number _____

Observation Date		Time Zone		Start Time	End Time	
12/17/97		EST		1500	1600	
Min	Sec	0	15	30	45	Comments
1	5	5	5	5		
2	5	5	5	5		
3	5	5	5	5		
4	5	5	5	5		
5	5	5	5	5		
6	5	5	5	5		
7	5	5	5	5		
8	5	5	5	5		
9	5	5	5	5		
10	5	5	5	5		
11	5	5	5	5		
12	5	5	5	5		
13	5	5	5	5		
14	5	5	5	5		
15	5	5	5	5		
16	5	5	5	5		
17	5	5	5	5		
18	5	5	5	5		
19	5	5	5	5		
20	5	5	5	5		
21	5	5	5	5		
22	5	5	5	5		
23	5	5	5	5		
24	5	5	5	5		
25	5	5	5	5		
26	5	5	5	5		
27	5	5	5	5		
28	5	5	5	5		
29	5	5	5	5		
30	5	5	5	5		

Observer Name (Print)
Ron C Cook

Observer Signature
Ron C Cook

Organization
SFES

Certified By
ETA

Date
12/17/97

Date
7/15/97

EPA

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)
Method 1 203A 203B Other: _____

Company Name FKEC
 Facility Name SAME
 Street Address MM 29
 City Marathon State FL Zip _____

Process Generator #8 Unit 8 Operating Mode _____
 Control Equipment _____ Operating Mode _____

Describe Emission Point
Leftmost Silver Stack

Height of Emis. Pt. Start ~30 End ~30 Height of Emis. Pt. Rel. to Observer Start ~30 End ~30
 Distance to Emis. Pt. Start ~200 End ~200 Direction to Emis. Pt. (Degrees) Start _____ End _____

Vertical Angle to Obs. Pt. Start ~150 End ~150 Direction to Obs. Pt. (Degrees) Start 90° End 90°
 Distance and Direction to Observation Point from Emission Point Start ~200 90° End ~200 90°

Describe Emissions
 Start Smoke End Smoke
 Emission Color Start Grey End SAME Water Droplet Plume Attached ☐ Detached ☐ None ☒

Describe Plume Background
 Start SKY End SKY
 Background Color Start Blue End Blue Sky Conditions Start Scattered End SAME
 Wind Speed Start 5-10 End ~5-10 Wind Direction Start West End West
 Ambient Temp Start 70 End 65 Wet Bulb Temp. _____ RH Percent 55

Source Layout Sketch

Draw North Arrow ☐ TN ☐ MN

Observer's Position

Observation Point

140°

Sun Location Line

Side View

Stack With Plume

Sun

Wind

Longitude _____ Latitude _____ Declination _____

Form Number _____ Page 2 of 2
 Continued on VEO Form Number _____

Observation Date			Time Zone		Start Time	End Time	Comments
					1530	1600	
Sec	0	15	30	45			
Min							
1	5	5	5	5			
2	5	5	5	5			
3	5	5	5	5			
4	5	5	5	5			
5	5	5	5	5			
6	5	5	5	5			
7	5	5	5	5			
8	5	5	5	5			
9	5	5	5	5			
10	5	5	5	5			
11	5	5	5	5			
12	5	5	5	5			
13	5	5	5	5			
14	5	5	5	5			
15	5	5	5	5			
16	5	5	5	5			
17	5	5	5	5			
18	5	5	5	5			
19	5	5	5	5			
20	5	5	5	5			
21	5	5	5	5			
22	5	5	5	5			
23	5	5	5	5			
24	5	5	5	5			
25	5	5	5	5			
26	5	5	5	5			
27	5	5	5	5			
28	5	5	5	5			
29	5	5	5	5			
30	5	5	5	5			

Observer's Name (Print) Ron C Cook Jr
 Observer's Signature Ron C Cook Jr Date 12/17/97
 Organization SPES
 Certified By ETA Date 7/15/97

APPENDIX C
CALIBRATION GAS CERTIFICATIONS

NATIONAL SPECIALTY GASES
630 UNITED DRIVE
DURHAM, NC
27713
(919)544-3772

CERTIFICATE OF ANALYSIS - EPA PROTOCOL MIXTURES

REFERENCE #:	88-52889	CYLINDER #:	CC 50751	CYL. PRESSURE:	2000 PSIG	P.O. #:	43416
EXP. DATE:	5/29/99	LAST ANALYSIS DATE:	5/29/97	CUSTOMER:	SOUTHEAST AIRGAS		
METHOD: ANALYZED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS-SEPTEMBER 1993-G-1 THIS STANDARD SHOULD NOT BE USED WHEN ITS GAS PRESSURE IS BELOW 1.0 MEGAPASCALS (150 PSIG).							

COMPONENT: NITRIC OXIDE STANDARD SRM #: 1687B CYL. #: CLM 9893 CONC: 986.0 PPM INSTRUMENT: BECKMAN CHEMILUMINESCENT MODEL #: 951A SERIAL #: 0100532 LAST CAL: 5/1/97		COMPONENT: CARBON MONOXIDE STANDARD SRM #: 1680B CYL. #: CLM 9511 CONC: 490.4 PPM INSTRUMENT: BOEHRMANN NDIR MODEL #: 880A SERIAL #: 2000172 LAST CAL: 5/15/97	
MEAN CONC.: 722 PPM REPLICATE CONC. DATE: 5/22/97 898 PPM 899 PPM 898 PPM		MEAN CONC.: 286 PPM REPLICATE CONC. DATE: 5/22/97 286 PPM 286 PPM 285 PPM	
DATE: 5/29/97 906 PPM 905 PPM 906 PPM		DATE: 5/29/97 285 PPM 286 PPM 286 PPM	

BALANCE GAS: NITROGEN

TRACE GASES: NITROGEN DIOXIDE < 0.1 PPM

REPLICATE DATA DATE: 5/22/97 Z 0 R 420.4 C 382.9 R 420.3 Z 0 C 383.2 Z 0 C 383.0 R 420.5 DATE: 5/29/97 Z 0 R 440.4 C 404.7 R 440.5 Z 0 C 404.3 Z 0 C 404.9 R 440.6				REPLICATE DATA DATE: 5/22/97 Z 0 R 490 C 286 R 490 Z 0 C 286 Z 0 C 284 R 489 DATE: 5/29/97 Z 0 R 490 C 285 R 491 Z 0 C 286 Z 0 C 286 R 490			
---	--	--	--	---	--	--	--

ANALYST: *[Signature]*

Z= ZERO C=CANDIDATE R=REFERENCE

APPROVED BY: *[Signature]*

THIS REPORT STATED ACCURATELY THE RESULTS OF THE INVESTIGATION MADE UPON THE MATERIAL SUBMITTED TO THE ANALYTICAL LABORATORY. EVERY EFFORT HAS BEEN MADE TO DETERMINE OBJECTIVELY THE INFORMATION REQUESTED. HOWEVER, IN CONNECTION WITH THIS REPORT, NATIONAL SPECIALTY GASES SHALL HAVE NO LIABILITY IN EXCESS OF ITS ESTABLISHED CHARGE FOR THE SERVICE.

ANALYZED AT: NATIONAL SPECIALTY GASES, 630 UNITED DRIVE, DURHAM, NC 27713

(919)544-3772

325 McCausland Court
Cheshire, CT 06410
Phone: (203) 250-6827
FAX: (203) 250-6842

Certificate of Analysis: E.P.A. Protocol Gas Mixture

Rec#	<u>2085</u>	Purchase Order #	<u>100416</u>
Cylinder No :	<u>CC46126</u>	Expiration Date:	<u>3/31/99</u>
Cylinder Pressure:	<u>2000</u>	Laboratory:	<u>Cheshire, CT</u>
Certification Date	<u>3/31/97</u>		

Reference Standard Information:

<u>Type</u>	<u>Component</u>	<u>Cyl. Number</u>	<u>Concentration</u>
NTRM	Nitric Oxide	CC50149	980 ppm

Instrumentation:

<u>Instrument/Model/Serial No.</u>	<u>Analytical Principle</u>
Nicolet/550/ACN9402102	FTIR

Analytical Methodology does not require correction for analytical interferences.

Certified Concentrations:

Component	Concentration	Accuracy	Procedure
Nitric Oxide	1778.00 ppm	± 0.4%	61
Nitrogen	Balanced		

Analytical Results:

1st Component:

Nitric Oxide

1st Analysis Date: 3/24/97

R	<u>973.600</u>	S	<u>1766.300</u>
S	<u>1766.300</u>	Z	<u>0.117</u>
Z	<u>0.226</u>	R	<u>974.200</u>

Z	<u>0.406</u>
R	<u>974.300</u>
S	<u>1766.600</u>

Conc	<u>1778.244</u> ppm
Conc	<u>1778.741</u> ppm
Conc	<u>1777.504</u> ppm
AVG:	<u>1778.163</u> ppm

2nd Analysis Date: 3/31/97

R	<u>980.500</u>	S	<u>1785.000</u>
S	<u>1766.700</u>	Z	<u>0.336</u>
Z	<u>0.363</u>	R	<u>974.700</u>

Z	<u>0.289</u>
R	<u>975.900</u>
S	<u>1773.100</u>

Conc	<u>1784.327</u> ppm
Conc	<u>1774.396</u> ppm
Conc	<u>1783.040</u> ppm
AVG:	<u>1780.588</u> ppm

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1993)" using the assay procedures listed.

Do not use cylinder below 150 psig.


Approved for Release



Scott Specialty Gases

1760 EAST CLUB BLVD, DURHAM, NC 27704

Phone: 919-220-0803

Fax: 919-220-0808

CERTIFICATE OF ANALYSIS: Interference-Free™ Multi-Component EPA Protocol Gas

Customer
EASTMOUNT ENVIRONMENTAL
STEVEN BLAKE
C/O S FLORIDA ENV SERV
6821 VISTA PARKWAY NORTH
WEST PALM BEACH, FL 33411

Assay Laboratory
SCOTT SPECIALTY GASES
1760 EAST CLUB BLVD
DURHAM, NC 27704

Project No.: 12-20784-003
P.O. No.: 2289

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #011 September, 1993.

Cylinder Number: ALMO11221
Cylinder Pressure: 1940 PSIG

Certification Date: 2/19/97

Exp. Date: 2/19/1999

COMPONENT
CARBON MONOXIDE
NITRIC OXIDE
SULFUR DIOXIDE
OXIDES OF NITROGEN
NITROGEN - OXYGEN FREE

CERTIFIED CONCENTRATION
154.0 PPM
124.7 PPM
122.8 PPM
124.7 PPM
BALANCE

ANALYTICAL ACCURACY**
+/- 1% NIST Traceable
+/- 1% NIST Traceable
+/- 1% NIST Traceable
Reference Value

** Do not use when cylinder pressure is below 150 psig.

** Analytical Accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

Product Certified as +/- 1% analytical accuracy is directly traceable to NIST standards.

This Protocol has been certified using corrected NIST 802 standard values, per EPA guidance dated 7/24/96 and will not correlate with uncorrected Protocols.

REFERENCE STANDARD

TYPE/BRN NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NITR1685	1/06/98	ALMO24842	474.0 PPM	CO/N2
NITR1685	7/10/97	ALMO60738	247.8 PPM	NO/N2
NITR1685	6/24/97	ALMO42284	268.0 PPM	SO2/N2

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#
FTIR System/8120/AB9400252
FTIR System/8220/AB9400252
FTIR System/8220/AB9400252

LAST DATE CALIBRATED

02/17/97
02/17/97
02/17/97

ANALYTICAL PRINCIPLE

Scott Enhanced FTIR
Scott Enhanced FTIR
Scott Enhanced FTIR

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

CARBON MONOXIDE

Date: 02/11/97 Response Unit: PPM
Z1=0.0050 R1=473.88 T1=154.15
Z2=473.88 R2=0.0411 T2=153.70
Z3=0.0739 T3=154.15 R3=474.78
Avg. Concentration: 154.0 PPM

Second Triad Analysis

Date: 02/18/97 Response Unit: PPM
Z1=0.00617 R1=474.27 T1=153.87
Z2=473.45 R2=0.0597 T2=153.85
Z3=0.1111 T3=154.03 R3=474.26
Avg. Concentration: 153.8 PPM

Calibration Curve

Concentration = A + Bx + Cx2 + Dx3 + Ex4
r = 0.999990
Constants: A = 0.000000
B = 1.000000 C = 0.000000
D = 0.000000 E = 0.000000

NITRIC OXIDE

Date: 02/11/97 Response Unit: PPM
Z1=0.1947 R1=247.41 T1=124.58
Z2=247.31 R2=0.1040 T2=124.52
Z3=0.2508 T3=124.81 R3=247.77
Avg. Concentration: 124.7 PPM

Date: 02/18/97 Response Unit: PPM
Z1=0.2334 R1=247.35 T1=124.85
Z2=247.41 R2=0.3540 T2=124.68
Z3=0.3822 T3=124.80 R3=247.72
Avg. Concentration: 124.8 PPM

Concentration = A + Bx + Cx2 + Dx3 + Ex4
r = 0.999990
Constants: A = 0.000000
B = 1.000000 C = 0.000000
D = 0.000000 E = 0.000000

SULFUR DIOXIDE

Date: 02/11/97 Response Unit: PPM
Z1=0.0074 R1=264.88 T1=122.38
Z2=264.57 R2=0.3377 T2=122.52
Z3=0.2508 T3=122.86 R3=265.25
Avg. Concentration: 122.7 PPM

Date: 02/18/97 Response Unit: PPM
Z1=0.2060 R1=264.57 T1=122.59
Z2=265.11 R2=0.3188 T2=123.10
Z3=0.1043 T3=123.14 R3=265.32
Avg. Concentration: 122.8 PPM

Concentration = A + Bx + Cx2 + Dx3 + Ex4
r = 0.999990
Constants: A = 0.000000
B = 1.000000 C = 0.000000
D = 0.000000 E = 0.000000

Notes:

ANALYST: B. Becton
B. Becton



Scott Specialty Gases

1750 EAST CLUB BLVD, DURHAM, NC 27704

Phone: 919-220-0803

Fax: 919-220-0808

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer

EASTMOUNT ENVIRONMENTAL
STEVEN BLAKE
C/O S FLORIDA ENV SERV
6821 VISTA PARKWAY NORTH
WEST PALM BEACH, FL 33411

Assay Laboratory

SCOTT SPECIALTY GASES
1750 EAST CLUB BLVD
DURHAM, NC 27704

Project No.: 12-20784-001
P.O. No.: 2289

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #01; September, 1993.

Cylinder Number: AAL17320
Cylinder Pressure***: 2000 PSIG

Certification Date: 2/12/97

Exp. Date: 2/12/2000

COMPONENT

CARBON DIOXIDE
OXYGEN
NITROGEN

CERTIFIED CONCENTRATION

10.4 %
12.3 %

BALANCE

ANALYTICAL ACCURACY**

+/- 1% NIST TRACEABLE
+/- 1% NIST TRACEABLE

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.
Product certified as +/- 1% analytical accuracy is directly traceable to NIST standards.

REFERENCE STANDARD

TYPE/RM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NFM 1800	4/30/87	ALMO47888	17.95 %	CARBON DIOXIDE
NFM 2859	11/30/98	AAL17320	20.72 PCT	OXYGEN

INSTRUMENTATION

INSTRUMENT MODEL/SERIAL#

VARIAN GC/3400/0180
VARIAN GC/3400/18804

LAST DATE CALIBRATED

01/31/87
01/13/97

ANALYTICAL PRINCIPLE

GC / TCD
GC / TCD

ANALYZER READINGS

First Triad Analysis

(Z = Zero Gas R = Reference Gas T = Test Gas

Second Triad Analysis

r = Correlation Coefficient)

Calibration Curve

CARBON DIOXIDE

Date: 02/10/97 Response Unit: AREA
Z1 = 0.0000 T1 = 117119 T1 = 875884
R2 = 117049 T2 = 0.0000 T2 = 876483
T3 = 0.0000 T3 = 878403 R3 = 117049
Avg. Concentration: 10.37 %

Concentration = A + Bx + Cx2 + Dx3 + Ex4

r = 0.999990

Constants: A = 0.00

B = 1.00 C = 0.00

D = 0.00 E = 0.00

OXYGEN

Date: 02/12/97 Response Unit: AREA
Z1 = 0.0000 T1 = 818460 T1 = 305164
R2 = 817018 T2 = 0.0000 T2 = 308089
T3 = 0.0000 T3 = 308023 R3 = 817592
Avg. Concentration: 12.30 %

Concentration = A + Bx + Cx2 + Dx3 + Ex4

r = 0.99999

Constants: A = 0.00

B = 1.00 C = 0.00

D = 0.00 E = 0.00

Special Notes:

ANALYST:

B. Becton

B. BECTON



Scott Specialty Gases

1750 EAST CLUB BLVD, DURHAM, NC 27704

Phone: 919-220-0803

Fax: 919-220-0808

CERTIFICATE OF ANALYSIS: Interference-Free™ Multi-Component EPA Protocol Gas

Customer
EASTMOUNT ENVIRONMENTAL
STEVEN BLAKE
C/O S FLORIDA ENV SERV
6821 VISTA PARKWAY NORTH
WEST PALM BEACH, FL 33411

Assay Laboratory
SCOTT SPECIALTY GASES
1750 EAST CLUB BLVD
DURHAM, NC 27704

Project No.: 12-20783-004
P.O. No.: 2289

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #G1; September, 1993.

Cylinder Number: ALM045678
Cylinder Pressure*:** 1790 PSIG

Certification Date: 1/20/97

Exp. Date: 1/20/1999

COMPONENT
CARBON MONOXIDE
NITRIC OXIDE
SULFUR DIOXIDE *
OXIDES OF NITROGEN
NITROGEN - OXYGEN FREE

CERTIFIED CONCENTRATION
296.6 PPM
229.7 PPM
223.7 PPM
229.8 PPM
BALANCE

ANALYTICAL ACCURACY**
+/- 1% NIST Traceable
+/- 1% NIST Traceable
+/- 1% NIST Traceable
Reference Value

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is inclusive of usual known error sources which at least include precision of the measurement processes.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST standards.

* This Protocol has been certified using corrected NIST SO2 standard values, per EPA guidance dated 7/24/95 and will not correlate with uncorrected Protocols.

REFERENCE STANDARD

TYPE/SHR NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1880	1/08/98	ALM024780	474.0 PPM	CO/N2
NTRM 1885	7/10/97	ALM050988	247.5 PPM	NO/N2
NTRM R0280	5/24/97	ALM042108	266.0 PPM	SO2/N2

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#
FTIR System/8220/AAB9400252
FTIR System/8220/AAB9400252
FTIR System/8220/AAB9400252

LAST DATE CALIBRATED

01/18/97
01/18/97
01/18/97

ANALYTICAL PRINCIPLE

Scott Enhanced FTIR
Scott Enhanced FTIR
Scott Enhanced FTIR

ANALYZER READINGS

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Trial Analysis

CARBON MONOXIDE

Date: 01/13/97 Response Unit: PPM
Z1 = -0.055 R1 = 473.33 T1 = 295.77
R2 = 473.85 Z2 = -0.026 T2 = 296.61
Z3 = -0.064 T3 = 296.66 R3 = 475.02
Avg. Concentration: 296.3 PPM

Second Trial Analysis

Date: 01/20/97 Response Unit: PPM
Z1 = 0.0248 R1 = 473.82 T1 = 297.32
R2 = 474.16 Z2 = 0.0182 T2 = 296.72
Z3 = 0.0449 T3 = 296.58 R3 = 474.01
Avg. Concentration: 296.9 PPM

Calibration Curve

Concentration = A + Bx + Cx2 + Dx3 + Ex4
r = 0.999990
Constants: A = 0.000000
B = 1.000000 C = 0.000000
D = 0.000000 E = 0.000000

NITRIC OXIDE

Date: 01/13/97 Response Unit: PPM
Z1 = 0.2842 R1 = 247.88 T1 = 231.31
R2 = 247.96 Z2 = 0.2889 T2 = 230.21
Z3 = 0.3162 T3 = 229.86 R3 = 248.38
Avg. Concentration: 230.4 PPM

Date: 01/20/97 Response Unit: PPM
Z1 = 0.1665 R1 = 247.48 T1 = 229.43
R2 = 247.53 Z2 = 0.1928 T2 = 229.08
Z3 = 0.2059 T3 = 228.84 R3 = 247.48
Avg. Concentration: 229.1 PPM

Concentration = A + Bx + Cx2 + Dx3 + Ex4
r = 0.999990
Constants: A = 0.000000
B = 1.000000 C = 0.000000
D = 0.000000 E = 0.000000

SULFUR DIOXIDE *

Date: 01/13/97 Response Unit: PPM
Z1 = 0.0659 R1 = 264.87 T1 = 223.05
R2 = 264.88 Z2 = 0.2208 T2 = 223.56
Z3 = 0.2775 T3 = 223.41 R3 = 265.24
Avg. Concentration: 223.3 PPM

Date: 01/20/97 Response Unit: PPM
Z1 = 0.118 R1 = 265.38 T1 = 224.11
R2 = 264.98 Z2 = 0.0720 T2 = 224.19
Z3 = 0.0493 T3 = 224.20 R3 = 264.69
Avg. Concentration: 224.2 PPM

Concentration = A + Bx + Cx2 + Dx3 + Ex4
r = 0.999990
Constants: A = 0.000000
B = 1.000000 C = 0.000000
D = 0.000000 E = 0.000000

Special Notes:

ANALYST:

B. Becton
B. Becton



Scott Specialty Gases

1780 EAST CLUB BLVD, DURHAM, NC 27704

Phone: 919-220-0803

Fax: 919-220-0808

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer:
EASTMOUNT ENVIRONMENTAL
STEVEN E. KENNERLY
C/O 8 FLORENCE AVE
6821 VICTORY PARKWAY NORTH
WEST PATENT, NC 27411

Analyst:
SCOTT SPECIALTY GASES
5700 FLORENCE AVE
DURHAM, NC 27704

Project No.: 12-20784-002
P.O. No.: 2289

DESCRIPTION

Gas analyzed according to EPA Method 2100-1, 2100-2, 2100-3, 2100-4, 2100-5, 2100-6, 2100-7, 2100-8, 2100-9, 2100-10, 2100-11, 2100-12, 2100-13, 2100-14, 2100-15, 2100-16, 2100-17, 2100-18, 2100-19, 2100-20, 2100-21, 2100-22, 2100-23, 2100-24, 2100-25, 2100-26, 2100-27, 2100-28, 2100-29, 2100-30, 2100-31, 2100-32, 2100-33, 2100-34, 2100-35, 2100-36, 2100-37, 2100-38, 2100-39, 2100-40, 2100-41, 2100-42, 2100-43, 2100-44, 2100-45, 2100-46, 2100-47, 2100-48, 2100-49, 2100-50, 2100-51, 2100-52, 2100-53, 2100-54, 2100-55, 2100-56, 2100-57, 2100-58, 2100-59, 2100-60, 2100-61, 2100-62, 2100-63, 2100-64, 2100-65, 2100-66, 2100-67, 2100-68, 2100-69, 2100-70, 2100-71, 2100-72, 2100-73, 2100-74, 2100-75, 2100-76, 2100-77, 2100-78, 2100-79, 2100-80, 2100-81, 2100-82, 2100-83, 2100-84, 2100-85, 2100-86, 2100-87, 2100-88, 2100-89, 2100-90, 2100-91, 2100-92, 2100-93, 2100-94, 2100-95, 2100-96, 2100-97, 2100-98, 2100-99, 2100-100.

Batch No.: ALM039900
Pressure: 2000 PSIG

Expiry Date: 12/12/2000

Exp. Date: 12/12/2000

Component:
CARBON DIOXIDE
OXYGEN
NITROGEN

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

Component:

ANALYTICAL ACCURACY**

±1% NIST TRACEABLE

±1% NIST TRACEABLE

** Do not use if cylinder pressure is below 150 psig.
** Analytical accuracy is based on the use of standard gases and the measurement processes.

REFERENCE STANDARD

TYPE OF STANDARD: EXPIRATION DATE
NTRM 2000
NTRM 2000

CYLINDER NUMBER: CONCENTRATION
ALM039900
ALM039900

COMPONENT:
CARBON DIOXIDE
OXYGEN

INSTRUMENTATION

INSTRUMENT MODEL: SERIAL
VARIAN GC/3400/1001
VARIAN GC/3400/1001

ANALYST CALIBRATION

ANALYST:
ALM039900

ANALYTICAL PRINCIPLE

GC / TCD
GC / TCD

ANALYSIS READINGS

(Z = Zero Gas, Y = Reference Gas, X = Test Gas, R = Correlation Coefficient)
First Third Analysis Second Third Analysis Calibration Curve

CARBON DIOXIDE

Date: 02/10/01
Z1 = 0.0000
Y1 = 118329
X1 = 118329
Z2 = 0.0000
Y2 = 118467
X2 = 118467
Z3 = 118467
Y3 = 118467
X3 = 117049
Avg. Conc. = 118467 %

OXYGEN

Date: 02/10/01
Z1 = 0.0000
Y1 = 822300
X1 = 822300
Z2 = 0.0000
Y2 = 822300
X2 = 822300
Z3 = 822300
Y3 = 822300
X3 = 822300
Avg. Conc. = 822300 %

Concentration = A + Bx + Cx2 + Dx3 + Ex4

r = 0.999990

Constants: A = 0.00

B = 1.00 C = 0.00

D = 0.00 E = 0.00

Concentration = A + Bx + Cx2 + Dx3 + Ex4

r = 0.999990

Constants: A = 0.00

B = 1.00 C = 0.00

D = 0.00 E = 0.00

ANALYST

B. Becton
B. BECTON



Scott Specialty Gases, Inc.

1750 EAST CLAY ALVO,
DURHAM NC 27704
Phone: 919-220-0909

Fax: 919-220-0809

CERTIFICATE OF ANALYSIS

ALVO CLAY ALVO
INDUSTRIAL SERVICES
ALVO CLAY ALVO
ALVO CLAY ALVO
ALVO CLAY ALVO

AL 33411

PROJECT #: 12-10320 004
Q08: ACCT #20851300
ITEM #: 12022750 49L
DATE: 3/09/95

CYLINDER #: ALMO31004

ANALYTICAL ACCURACY: 17-2%

GAS TYPE: CERTIFIED MASTER GAS

COMPONENT
4-1000
11-1000

REQUESTED GAS

CONC MOLES

30.

PPM

BALANCE

ANALYSIS

(MOLES)

30.2

PPM

BALANCE

John W. Cook

K. COOKE



Scott Specialty Gases, Inc.

1750 EAST GLOBE BLVD.
DURHAM NC 27704
Phone: 919 220 0800

Fax: 919-220-0808

CERTIFICATE OF ANALYSIS

SCOTT FLORIDA
ENVIRONMENTAL SERVICES
4000 AIRS RIDGE
101 VISTA PARKWAY NORTH
FARMER'S BEACH FL 33411

PROJECT #: 12-10000-006
POR: ACCT #20051300
ITEM #: 12022751 #41
DATE: 3/09/95

CALIBRATION #: AA6500

ANALYTICAL ACCURACY: 1/-2%

ALLOY TYPE : CERTIFIED MASTER GAS

COMPONENT	REQUESTED GAS		ANALYSIS	
	CONC	MOLES	(MOLES)	
ARGON	85.	PPM	86.1	PPM
NEON		BALANCE		BALANCE

Q10 1ST:

K. COOKE

PLUMSTEADVILLE, PENNSYLVANIA / TROY, MICHIGAN / HOUSTON, TEXAS / DURHAM, NORTH CAROLINA
SOUTH PLAINFIELD, NEW JERSEY / FREMONT, CALIFORNIA / WAKEFIELD, MASSACHUSETTS / LONGMONT, COLORADO
BATON ROUGE, LOUISIANA



Scott Specialty Gases, Inc.

Shipped
to:

1750 EAST CLUB BLVD.

DURHAM

NC 27704

Phone: 919-220-0800

Fax: 919-220-0800

C E R T I F I C A T E O F A N A L Y S I S

100% FLUORINE
ENVIRONMENTAL SERVICES
P.O. BOX 61000
2000 VIA PARKWAY NORTH
P.O. PALM BEACH FL 33411

PROJECT #: 12-10820 005
PO#: ACCT #20351300
ITEM #: 12022751 BAL
DATE: 3/09/95

CYLINDER #: ALM004055

ANALYTICAL ACCURACY: 1/2%

GAS TYPE: CERTIFIED MASTER GAS

SUBSTRATE
ALUMINUM
ALUMINUM

REQUESTED GAS

CONC. MOLES

50%

PPM

BALANCE

ANALYSIS

(MOLES)

50%

PPM

BALANCE

ANALYST:

Ken D. Cook

K. COOKE

APPENDIX D
FIELD DATA SHEETS

ANALYZER CALIBRATION SHEET

CLIENT: FKEC OPERATOR: RCook
 PLANT: Marathon DATE: 12/17/82
 LOCATION: _____

SPAN: O₂ % CO₂ % CO PPM SO₂ PPM NOx PPM

GAS / RANGE		CYLINDER VALUE	ANALYZER RESPONSE	ABSOLUTE DIFFERENCE	PERCENT SPAN
O ₂	LOW	0.0	0.0	0.0	0.0
	MID	12.3	12.2	0.1	0.4
	HIGH	21.0	21.0	0.0	0.0
CO ₂	LOW	0.0	0.0	0.0	0.0
	MID	10.4	10.4	0.0	0.0
	HIGH	18.16	18.4	0.24	1.2
CO	LOW	0.0	2.2	2.2	0.4
	MID	154.0	154.2	0.2	0.1
	HIGH	296.6	297.3	0.7	0.1
SO ₂	LOW	0.0			
	MID				
	HIGH				
NOx	LOW	0.0	2.5	2.5	0.1
	MID	902	906.4	4.4	0.2
	HIGH	1779.38	1758.9	20.48	1.02

PERCENT SPAN = (CYLINDER VALUE - ANALYZER RESPON) / SPAN * 100

(ALLOWED 2% SPAN)



SYSTEM CALIBRATION DATA SHEET

CLIENT: FKEC
 PLANT: Maathon
 LOCATION: unit #8

TIME: 1500 to 1600
 DATE: 12/17/87
 RUN #: 1

SPAN: O2 % CO2 % CO PPM SO2 PPM NOX PPM

GAS	ANALYZER CAL RESPONSE	INITIAL SYSTEM CAL RESPON	SYSTEM BIAS %SPAN	FINAL SYSTEM CAL RESPON	SYSTEM BIAS %SPAN	DRIFT
O2 ZERO	0.0	0.0	0.0	0.0	0.0	0.0
O2 UPSCALE	12.2	12.0	-0.8	12.1	-0.4	0.4
CO2 ZERO	0.0	0.0	0.0	0.1	0.5	0.4
CO2 UPSCALE	10.4	10.2	-1.0	10.3	-0.5	0.5
CO ZERO	2.2	1.6	-0.1	-0.1	-0.5	-0.3
CO UPSCALE	154.2	153.3	-0.2	153.1	-0.2	-0.1
SO2 ZERO	-	-	-	-	-	-
SO2 UPSCALE	-	-	-	-	-	-
NOX ZERO	2.5	3.8	0.1	5.0	0.2	0.1
NOX UPSCALE	906.4	913.2	0.7	931.8	2.5	1.9

SYSTEM CAL BIAS = (SYS CAL RESPON - ANALYZER RESPON)/SPAN * 100 (5%)
 DRIFT = (FNL SYS CAL RESPON - INTL SYS CAL RESPON)/SPAN * 100 (3%)

	O2	CO2	CO	SO2	NOX
RAW	12.55	6.00	87.80		668.70
CAL CORR	13.26	6.07	87.94		652.65
POUND PER MILLION BTU ^{gms/DHP-HR}			0.49		6.01
POUND PER HOUR			5.40		65.95
PLANT					
POUND PER MILLION BTU					
POUND PER HOUR					

THC gms/BHP-HR = 0.15



SYSTEM CALIBRATION DATA SHEET

CLIENT: FKEC
 PLANT: Marathon
 LOCATION: Unit #8

TIME: 635 to 735
 DATE: 12/17/77
 RUN #: 2

SPAN: O2 1 CO2 1 CO 1 SO2 1 NOX 1
 PPM PPM PPM PPM PPM

GAS	ANALYZER CAL RESPONSE	INITIAL SYSTEM CAL RESPON	SYSTEM BIAS %SPAN	FINAL SYSTEM CAL RESPON	SYSTEM BIAS %SPAN	DRIFT
O2 ZERO	0.0	0.0	0.0	0.0	0.0	0.0
O2 UPSCALE	12.2	12.1	-0.4	12.3	0.4	0.8
CO2 ZERO	0.0	0.1	0.5	0.2	1.0	0.5
CO2 UPSCALE	10.4	10.3	-0.5	10.3	-0.5	0.0
CO ZERO	2.2	-0.1	-0.5	1.1	-0.2	0.2
CO UPSCALE	154.2	153.1	-0.2	153.8	-0.1	0.1
SO2 ZERO	—	—	—	—	—	—
SO2 UPSCALE	—	—	—	—	—	—
NOX ZERO	2.5	5.0	0.2	2.4	-0.1	-0.2
NOX UPSCALE	906.4	931.8	2.5	926.3	2.0	-0.6

SYSTEM CAL BIAS = (SYS CAL RESPON - ANALYZER RESPON)/SPAN * 100 (5%)
 DRIFT = (FNL SYS CAL RESPON - INTL SYS CAL RESPON)/SPAN * 100 (3%)

	O2	CO2	CO	SO2	NOX
RAW	13.24	6.01	86.61		667.23
CAL CORR	13.35	6.00	86.70		646.75
POUND PER MILLION BTU $\frac{\text{gms}}{\text{BHP-HR}}$					
POUND PER HOUR					66.09
PLANT					
POUND PER MILLION BTU					
POUND PER HOUR					

SYSTEM CALIBRATION DATA SHEET

CLIENT: FKEC TIME: 1800 to 1900
 PLANT: Marathon DATE: 12/17/87
 LOCATION: Unit #8 RUN #: 3

SPAN: 02 % CO2 % CO PPM SO2 PPM NOX PPM

GAS	ANALYZER CAL RESPONSE	INITIAL SYSTEM CAL RESPON	SYSTEM BIAS %SPAN	FINAL SYSTEM CAL RESPON	SYSTEM BIAS %SPAN	DRIFT
O2 ZERO	0.0	0.0	0.0	0.0	0.0	0.0
O2 UPSCALE	12.2	12.3	0.4	12.3	0.4	0.0
CO2 ZERO	0.0	0.2	1.0	0.2	1.0	0.0
CO2 UPSCALE	10.4	10.3	-0.5	10.3	-0.5	0.0
CO ZERO	2.2	1.1	-0.2	3.5	0.3	0.5
CO UPSCALE	154.2	153.8	-0.1	155.8	0.3	0.4
SO2 ZERO	-	-	-	-	-	-
SO2 UPSCALE	-	-	-	-	-	-
NOX ZERO	2.5	2.4	-0.1	2.4	-0.1	0.0
NOX UPSCALE	906.4	926.3	2.0	912.6	0.6	-1.4

SYSTEM CAL BIAS = (SYS CAL RESPON - ANALYZER RESPON) / SPAN * 100 (5%)
 DRIFT = (FNL SYS CAL RESPON - INTL SYS CAL RESPON) / SPAN * 100 (3%)

	O2	CO2	CO	SO2	NOX
RAW	13.26	6.05	87.98		659.55
CAL CORR	13.26	6.02	86.52		648.80
POUND PER MILLION BTU gms/BHP HR			5.93		5.93
POUND PER HOUR			25.10		65.10
PLANT					
POUND PER MILLION BTU					
POUND PER HOUR					

EPA METHOD 25A FIELD DATA SHEET

ANALYZER ERROR DATA

LOCATION: FKEC
DATE: 12/17/97
INSTRUMENT: RS55 RANGE: 0 TO 100

GAS	CALIBRATION CYLINDER VALUE (PPM)	ANALYZER RESPONSE (PPM)	ANALYZER ERROR
ZERO	0.0	0.3	0.3
LOW	30.2	30.9	0.7
MID	50.6	51.6	1.0
HIGH	86.1	86.9	0.8

$$\text{ANALYZER CALIBRATION ERROR} = \frac{\text{CYLINDER VALUE} - \text{ANALYZER RESPONSE}}{\text{CYLINDER VALUE}} \times 100$$

EPA METHOD 25A FIELD DATA SHEET

SYSTEM DRIFT DATA

LOCATION: EKEC RUN #: 1-3
 DATE: 10/17/84 RUN TIME: SEE TO CEM SYS CAL
 INSTRUMENT: K555 RANGE: 0 TO 100


GAS	ANALYZER CAL RESPONSE	INITIAL		FINAL		SYSTEM DRIFT	
		SYSTEM CAL RESPONSE	SYSTEM BIAS % SPAN	SYSTEM CAL RESPONSE	SYSTEM BIAS % SPAN		
ZERO	0.3	0.1	-0.2	0.6	0.3	0.5	48.36
SPAN	30.9	30.8	-0.1	30.9	0.0	0.1	
ZERO	0.3	0.6	0.3	0.3	0.0	-0.3	42.62
SPAN	30.9	30.9	0.0	30.7	-0.2	-0.2	
ZERO	0.3	0.3	0.0	0.1	-0.2	-0.2	47.10
SPAN	30.9	30.7	-0.2	30.7	-0.2	0.0	

$$\text{SYSTEM BIAS} = \frac{\text{SYSTEM RESPONSE} - \text{ANALYZER RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{SYSTEM DRIFT} = \frac{\text{SYSTEM RESPONSE IN.} - \text{SYSTEM RESPONSE OUT.}}{\text{SPAN}} \times 100$$



APPENDIX E
STRIP CHARTS



ANA CAS

RECORDED DATA LOGGER VRS SH

START FKFC

END FKAA

17 DEC 97 17:23:50
12:2 PCT 02
16 DEC 97 17:23:59
1 - 12
16 DEC 97 17:23:27
16 DEC 97 17:23:21

17 DEC 97 11 32:11
 4 - 123.7 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 11 31:52
 4 - 123.5 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 11 30:50

5 = 147.9 PPM NOX
 2 = 0.6 PCT UO2
 6
 5
 5 = 147.9 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU
 6
 5
 5 = 138.1 PPM THU
 4 = 153.5 PPM UU

SYS OK

17 DEC 97 11 28:33
 4 - 123.7 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 11 28:14


5 = 148.4 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU

17 DEC 97 11 28:26
 4 - 0.0 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 11 28:7
 17 DEC 97 11 28:1

5 = 148.4 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU



17 DEC 97 11 24:40
 4 - 123.7 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 11 24:21
 17 DEC 97 11 24:16

5 = 148.4 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU

SYS OK

17 DEC 97 8:41:42
 4 - 123.7 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 8:41:23

5 = 148.4 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU

17 DEC 97 8:41:11
 4 - 123.7 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 8:40:53
 17 DEC 97 8:40:47

5 = 148.4 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU

17 DEC 97 8:40:32
 4 - 123.7 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 8:40:14
 17 DEC 97 8:40:8

5 = 148.4 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU

17 DEC 97 8:39:12
 4 - 123.7 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 8:38:53
 17 DEC 97 8:38:47

5 = 148.4 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU

17 DEC 97 8:38:30
 4 - 123.7 PPM SU2
 1 - 0.0 PCT U2
 17 DEC 97 8:35:30

5 = 148.4 PPM NOX
 2 = 0.6 PCT UO2

5 = 138.1 PPM THU
 4 = 153.5 PPM UU

ANA OK

80 70 60 50 40 30 20 10

10 DEC 97 14:55:16 \$02

1 = 12.9 PCT 02

10 DEC 97 14:54:57

10 DEC 97 14:49:50 \$02

1 = 8.1 PCT 02

10 DEC 97 14:48:12

10 DEC 97 14:47:48 \$02

1 = 8.8 PCT 02

10 DEC 97 14:47:50

10 DEC 97 14:45:4 \$02

1 = 8.8 PCT 02

10 DEC 97 14:44:45

10 DEC 97 14:44:40

10 DEC 97 14:43:11 \$02

1 = 8.8 PCT 02

10 DEC 97 14:42:52

10 DEC 97 14:41:59 \$02

1 = 8.8 PCT 02

10 DEC 97 14:41:40

[illegible]

15:30 PPM SD2
1 = 0.0 PCT D2
DEC 97 16 12:31

5 = 18.0 PPM NOK
2 = 0.1 PCT CDP

5 = 0.6 PPM THC
3 = 11.5 PPM CD

DEC 97 16 9:39
1 = 12.5 PPM SD2
1 = 0.0 PCT D2
DEC 97 16 9:27

5 = 158.6 PPM NOK
2 = 0.1 PCT CDP

5 = 45.8 PPM THC
3 = 153.1 PPM CD

DEC 97 16 8:7
1 = 1.0 PPM SD2
1 = 0.1 PCT D2
DEC 97 16 7:50
DEC 97 16 7:45

5 = 93.8 PPM NOK
2 = 0.1 PCT CDP

5 = 48.3 PPM THC
3 = 274.3 PPM CD

DEC 97 16 6:45
1 = 8.4 PPM SD2
1 = 12.1 PCT D2
DEC 97 16 6:28
DEC 97 16 6:23

5 = 2.5 PPM NOK
2 = 10.7 PCT CDP

5 = 49.9 PPM THC
3 = 0.4 PPM CD

DEC 97 16 4:42
1 = 2.8 PPM SD2
1 = 0.0 PCT D2
DEC 97 16 4:25
DEC 97 16 4:20

5 = 5.0 PPM NOK
2 = 0.1 PCT CDP

5 = 47.2 PPM THC
3 = 0.1 PPM CD

DEC 97 15 46:57
1 = 0.0 PPM SD2
1 = 13.0 PCT D2
DEC 97 15 44:37

5 = 67.5 PPM NOK
2 = 6.0 PCT CDP

5 = 47.2 PPM THC
3 = 91.3 PPM CD

DEC 97 15 45:34
1 = 0.0 PPM SD2
1 = 13.0 PCT D2

5 = 67.5 PPM NOK
2 = 6.0 PCT CDP

5 = 47.2 PPM THC
3 = 91.3 PPM CD

90 80 70 60 50 40 30 20 10
10 20 30 40 50 60 70 80 90

DEC 97 15 32:58
1 = 8.1 PPM SD2
1 = 13.0 PCT D2

5 = 663.8 PPM NOK
2 = 5.0 PCT CDP

5 = 47.2 PPM THC
3 = 33.2 PPM CD

DEC 97 15 32:41
DEC 97 15 32:36

5 = 663.8 PPM NOK
2 = 5.0 PCT CDP

5 = 47.2 PPM THC
3 = 33.2 PPM CD

DEC 97 15 32:28
1 = 12.9 PPM SD2
1 = 12.9 PCT D2
DEC 97 15 32:18

5 = 663.8 PPM NOK
2 = 5.0 PCT CDP

5 = 47.2 PPM THC
3 = 33.2 PPM CD

DEC 97 15
1 = 2.2 PPM SD2
1 = 13.0 PCT D2

5 = 663.8 PPM NOK
2 = 5.0 PCT CDP

5 = 47.2 PPM THC
3 = 33.2 PPM CD

17 DEC 97 17:46:52
17 DEC 97 17:46:48
17 DEC 97 17:46:44

17 DEC 97 17:46:47
17 DEC 97 17:46:42

17 DEC 97 17:43:19
17 DEC 97 17:43:12
17 DEC 97 17:43:02

17 DEC 97 17:42:57

17 DEC 97 17:48:57
17 DEC 97 17:48:49
17 DEC 97 17:48:35

17 DEC 97 17:38:42
17 DEC 97 17:38:35

17 DEC 97 17:38:25

17 DEC 97 17:24:08
17 DEC 97 17:23:51

17 DEC 97 17:05:36

17 DEC 97 16:44:33

17 DEC 97 16:24:13

17 DEC 97 16:23:55
17 DEC 97 16:23:51

17 DEC 97 16:14:58
17 DEC 97 16:14:33
17 DEC 97 16:14:28

17 DEC 97 16:12:48
17 DEC 97 16:12:31

17 DEC 97 16:12:31

17 DEC 97 16:12:31

17 DEC 97 16:12:31

17 DEC 97 16:12:31

17 DEC 97 16:12:31

5 = 147.8 PPM NOX
2 = 0.2 PCT CO2

5 = 926.3 PPM NOX
2 = 0.2 PCT CO2

5 = 1.7 PPM NOX
2 = 10.3 PCT CO2

5 = 2.4 PPM NOX
2 = 0.2 PCT CO2

5 = 676.8 PPM NOX
2 = 5.8 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 18.0 PPM NOX
2 = 0.1 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 17.9 PPM NOX
2 = 0.2 PCT CO2

5 = 11.6 PPM THC
3 = 7.2 PPM CO

5 = 44.2 PPM THC
3 = 163.9 PPM CO

5 = 43.3 PPM THC
3 = 274.7 PPM CO

5 = 42.9 PPM THC
3 = 1.2 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

5 = 42.8 PPM THC
3 = 1.1 PPM CO

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

THC 575.6

DEC 97 19 9:47
 128.3 PPM SD2
 8.0 PCT DP
 DEC 97 19 3:30
 DEC 97 19 1:41
 1.2 PPM SD2
 10.0 PCT DP
 DEC 97 19 7:24

5 = 162.1 PPM NOX
 2 = 0.2 PCT CO2
 5 = 8.2 PPM THC
 3 = 15.9 PPM CO
 5 = 912.6 PPM NOX
 2 = 0.2 PCT CO2
 5 = 8.2 PPM THC
 3 = 276.0 PPM CO

DEC 97 19 5:47
 12.3 PPM SD2
 12.3 PCT DP
 DEC 97 19 9:26
 DEC 97 19 5:21
 DEC 97 19 4:22
 3.1 PPM SD2
 6.0 PCT DP
 DEC 97 19 4:13
 DEC 97 19 4:13

5 = 0.2 PPM NOX
 2 = 10.3 PCT CO2
 5 = 8.2 PPM THC
 3 = 2.2 PPM CO
 5 = 2.4 PPM NOX
 2 = 0.2 PCT CO2
 5 = 1.5 PPM THC
 3 = 2.5 PPM CO

DEC 97 19 3:10
 2.6 PPM SD2
 13.3 PCT DP
 DEC 97 19 1:53
 80 70
 20 20

5 = 222.5 PPM NOX
 2 = 6.0 PCT CO2
 5 = 20.7 PPM THC
 3 = 67.9 PPM CO
 60 50 40 30 20 10
 40 50 60 70 Ref

DEC 97 19 1:0
 281.0 PPM SD2
 10.3 PCT DP
 DEC 97 19 8:62

5 = 401.1 PPM NOX
 2 = 6.0 PCT CO2
 5 = 0.1 PPM THC
 3 = 0.0 PPM CO

THC SIX CR4

DEC 97 18 49:13
 1.2 PPM SD2
 12.3 PCT DP
 DEC 97 18 48:46

5 = 669.1 PPM NOX
 2 = 6.0 PCT CO2
 5 = 40.1 PPM THC
 3 = 87.0 PPM CO

DEC 97 18 38:30

DEC 97 18 9:46

DEC 97 17 49:7

90 80 70 60 50 40 30 20 10 0
 4 = 7.0 PPM SD2
 1 = 0.2 PCT DP
 DEC 97 17 48:50
 DEC 97 17 48:45
 DEC 97 17 48:17
 5.2 PPM SD2
 6.4 PCT DP
 DEC 97 17 48:0

5 = 140.3 PPM NOX
 2 = 0.2 PCT CO2
 5 = 700.7 PPM THC
 3 = 4.0 PPM CO
 5 = 12.9 PPM NOX
 2 = 0.2 PCT CO2
 5 = 21.8 PPM THC
 3 = 3.5 PPM CO

5 = 0.2 PPM THC

APPENDIX F
NOMENCLATURE

NOMENCLATURE

%DRE	= percent destruction/removal efficiency
% ISO	= percent isokinetic sampling rate
%CO ₂	= percent carbon dioxide by volume (dry)
%H ₂ O	= percent moisture
%N ₂	= percent nitrogen by volume (dry)
%O ₂	= percent oxygen by volume (dry)
μg	= micrograms
ΔH _@	= pressure drop across orifice of meter for 0.75 CFM at standard conditions
ΔP _{avg}	= average velocity pressure
A _n	= sampling nozzle cross-sectional area (ft ²)
A _r	= acetone residue - result of blank evaporation
A _s	= stack cross sectional area (ft ²)
B _{wo}	= moisture content of stack gas; expressed as a decimal
C	= final emissions data reported by CEMs, adjusted for calibration drift
C'	= raw emissions data reported by the CEMs, uncorrected for calibration drift.
C _m	= average CEM response to initial and final span gas system calibration
C _o	= average CEM response to initial and final zero gas system calibration
C _p	= pitot tube coefficient
C _s	= concentration in stack gas in pounds per standard cubic foot
C _{s'}	= concentration in stack gas in grains per standard cubic foot
C _{s12}	= concentration corrected to 12 percent CO ₂
D _e	= equivalent diameter of rectangular stack
D _n	= nozzle diameter in inches
D _s	= stack inside diameter in feet
Delta H(abs)	= the meter orifice differential, absolute conditions in inches of mercury
Delta H	= the meter orifice differential
dgm	= dry gas meter
Dry Gas In	= temperature of the dgm inlet in degrees Fahrenheit
Dry Gas Out	= temperature of the dgm outlet in degrees Fahrenheit
F factor	= a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted
F _c	= a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted
F _w	= a F factor on a wet basis
dscf	= dry standard cubic foot
dscfh	= dry standard cubic foot per hour
dscfm	= dry standard cubic foot per minute
E	= emission rate in pounds per million Btu

NOMENCLATURE (cont.)

End Meter	= the dgm reading in cubic feet at the end of the sampling period
F_d	= F-factor dry standard cubic feet per million Btu at zero percent oxygen and at 68
FID	= flame ionization detection
F_o	= EPA method 3 fuel factor
fps	= feet per second
GC	= gas chromatograph
GC/MS	= gas chromatograph/mass spectrograph
gr	= grain of particulate; 1 lb. = 7000 grains
gr/dscf	= grains per dry standard cubic foot
gr@12%	= grains per dry standard cubic foot corrected to 12 percent oxygen
gr@7%	= grains per dry standard cubic foot corrected to 7 percent oxygen
Hg	= mercury
int/i	= initial
IN	= inches
Int Meter	= the dgm reading in cubic feet at the beginning of the test period
K	= degrees Kelvin
PIT Coeff	= pitot tube coefficient
lb/SCF	= pounds per standard cubic foot
lb/hr	= pounds per hour
lb/MMBtu	= pounds per million Btu
Cma	= concentration of the calibration gases
M_d	= dry molecular weight of flue gas
mg	= milligrams
mg/DSCM	= milligrams per dry standard cubic meter
ml	= milliliters
MM5	= modified EPA method 5
MMBtu/hr	= million Btu per hour
M_s	= molecular weight of flue gas, wet basis
M_d	= molecular weight of flue gas, dry basis
ng	= nanograms
NMHC	= non-methane hydrocarbons
Θ	= net run time in minutes
$^{\circ}\text{C}$	= degrees Celsius
$^{\circ}\text{F}$	= degrees Fahrenheit
$^{\circ}\text{R}$	= degrees Rankine
P bar	= barometric pressure in inches of mercury
P stk	= pressure of the stack in inches of water
P_{abs}	= absolute pressure

NOMENCLATURE (cont.)

ppm _{vd}	= parts per million by volume, dry
P _s	= flue gas static pressure in absolute pressure
P _{std}	= standard absolute pressure at 29.92 inches of mercury
Q _a	= volumetric air flow rate actual cubic feet per minute
Q _s	= volumetric air flow rate dry standard cubic feet per minute
rh	= relative humidity
scf	= standard cubic feet
scfm	= standard cubic feet per minute
T _m	= dry gas meter temperature in degrees Fahrenheit
T _s	= flue gas temperature in degrees Fahrenheit
t _{std}	= standard temperature in degrees Fahrenheit
T _{std}	= standard absolute temperature
THC	= total hydrocarbons
V	= volume
V _I	= total volume of liquid collected in impingers and silica gel
V _m	= volume of metered gas sampled in cubic feet
V _{m std}	= volume of metered gas sample at dry standard conditions in dry standard cubic feet
VOC	= volatile organic compounds
VS	= average flue gas velocity in feet per second
V _{w std}	= volume of water vapor in cubic feet
wscfm	= wet standard cubic feet per minute
Y	= dry gas meter calibration factor

APPENDIX G
FACILITY OPERATING DATA

12-15-97
16-97 T.P.

12-15-97
16-97 T.P.

Revised 12-16-97 T.P.



FLORIDA KEYS ELECTRIC COOPERATIVE ASSOCIATION, INC. - FKEC

91605 OVERSEAS HIGHWAY P.O. BOX 700377, TAVERNIER, FL 33070-0377 PHONE (305) 852-2431 FAX: (305) 852-4794

Mr. Clair Fancy
Chief
Bureau of Air Regulation
Dept. of Environmental Protection
Mail Station 5505
2600 Blairstone Rd.
Tallahassee, FL 32399-2400

RECEIVED

JAN 28 1998

**BUREAU OF
AIR REGULATION**

Re: PSD-FL-237. NO_x emissions test result.

26 January 1998

Dear Mr. Fancy:

Enclosed are the results of the emissions compliance testing conducted on Florida Keys Electric Cooperative's Marathon Generating Plant Unit # 8 by South Florida Environmental Services. The engine passed all test parameters except for NO_x, which was emitted at an average rate of 65.71 lbs/hr. FKEC's permitted limit for NO_x is 62 lbs/hr. The 62 lbs/hr limit was based on theoretical calculations that I made over one year ago based on EPA emissions data (AP-42, which EPA acknowledges has limited value based on small sample sizes and variable operating conditions) and on manufacturer's estimates on fuel consumption and emissions rates (there were no units of this type and model running then so no real emissions data were available). Based on the data available to me at the time, I calculated that the uncontrolled NO_x emissions of the EMD 20-710G4B would be 96.6 lbs/hr. Based on the manufacturer's claim of a 40% reduction in NO_x emissions with the emissions reduction package that FKEC had ordered, I further reduced my emissions calculation by 36% (taking what I thought was a conservative approach) resulting in the projected 62 lbs/hr NO_x emission rate.

In August 1997, FKEC's vendor informed us that the lowest feasible NO_x emission rate would be 71 lbs/hr. I immediately contacted your office for guidance on how to change the hourly limit proposed in our draft permit which was at that time undergoing the public notice period. During August 1997, I had several conversations with David Knowles, Syed Arif and Al Linero of your Ft. Myers and Tallahassee offices. We were advised that we could write a "comment letter" on the draft permit and ask that the NO_x hourly limit be increased to 71 lbs/hr. Doing that would have required further review by your office and another 30-day public notice period. FKEC did write a comment letter (copy enclosed for your reference), but elected not to send it because our construction schedule had no slack left for further delays. Instead, FKEC asked the vendor to strive for the best NO_x emission rate possible under FKEC's specifications. The fact that the engine tested at an average NO_x rate of 65.71 lbs/hr (significantly better than the

Fancy, C., p. 2

vendor thought feasible) demonstrates that our efforts to reduce NO_x were successful, but we were striving for an unrealistic goal. The technician conducting the emissions tests commented that he had never tested a cleaner running engine.

Where does this leave us? FKEC has already accepted a 50% reduction in operating hours for Units 1-7 at the Marathon Generating Plant. FKEC is reluctant to accept further limits on operating hours. It should be noted that while Unit # 8 is currently allowed unlimited operating hours, in reality, no unit can operate 8760 hours per year. So while Unit # 8 cannot meet the hourly NO_x limit of 62 lbs/hr, it will never exceed the current 271 tons/yr annual limit. Therefore, FKEC requests an increase in the hourly NO_x limit to 68 lbs/hr for our operating permit for Unit # 8 and for our Title V air operating permit.

Thank you for your consideration and assistance.

Sincerely,



Deborah A. Shaw, Ph.D.
Environmental Affairs Coordinator

Enc:

- 1) Draft comment letter.
- 2) Final Test Report - So. Fla. Environmental Services

PC: without test report.

C.A. Russell, CEO/GM, FKEC

T.E. Planer, Supt. Transmission, FKEC

D.M. Knowles, Air Program Administrator, FDEP



FLORIDA KEYS ELECTRIC COOPERATIVE ASSOCIATION, INC. - FKEC

91605 OVERSEAS HIGHWAY P.O. BOX 700377, TAVERNIER, FL 33070-0377 PHONE (305) 852-2431 FAX: (305) 852-4794

Mr. Clair Fancy
Chief
Bureau of Air Regulation
Dept. of Environmental Protection
Mail Station 5505
2600 Blairstone Rd.
Tallahassee, FL 32399-2400

RECEIVED

Re: PSD-FL-237. NO_x emissions test result.

JAN 28 1998

26 January 1998

BUREAU OF
AIR REGULATION

Dear Mr. Fancy:

Enclosed are the results of the emissions compliance testing conducted on Florida Keys Electric Cooperative's Marathon Generating Plant Unit # 8 by South Florida Environmental Services. The engine passed all test parameters except for NO_x, which was emitted at an average rate of 65.71 lbs/hr. FKEC's permitted limit for NO_x is 62 lbs/hr. The 62 lbs/hr limit was based on theoretical calculations that I made over one year ago based on EPA emissions data (AP-42, which EPA acknowledges has limited value based on small sample sizes and variable operating conditions) and on manufacturer's estimates on fuel consumption and emissions rates (there were no units of this type and model running then so no real emissions data were available). Based on the data available to me at the time, I calculated that the uncontrolled NO_x emissions of the EMD 20-710G4B would be 96.6 lbs/hr. Based on the manufacturer's claim of a 40% reduction in NO_x emissions with the emissions reduction package that FKEC had ordered, I further reduced my emissions calculation by 36% (taking what I thought was a conservative approach) resulting in the projected 62 lbs/hr NO_x emission rate.


In August 1997, FKEC's vendor informed us that the lowest feasible NO_x emission rate would be 71 lbs/hr. I immediately contacted your office for guidance on how to change the hourly limit proposed in our draft permit which was at that time undergoing the public notice period. During August 1997, I had several conversations with David Knowles, Syed Arif and Al Linero of your Ft. Myers and Tallahassee offices. We were advised that we could write a "comment letter" on the draft permit and ask that the NO_x hourly limit be increased to 71 lbs/hr. Doing that would have required further review by your office and another 30-day public notice period. FKEC did write a comment letter (copy enclosed for your reference), but elected not to send it because our construction schedule had no slack left for further delays. Instead, FKEC asked the vendor to strive for the best NO_x emission rate possible under FKEC's specifications. The fact that the engine tested at an average NO_x rate of 65.71 lbs/hr (significantly better than the

vendor thought feasible) demonstrates that our efforts to reduce NO_x were successful, but we were striving for an unrealistic goal. The technician conducting the emissions tests commented that he had never tested a cleaner running engine.

Where does this leave us? FKEC has already accepted a 50% reduction in operating hours for Units 1-7 at the Marathon Generating Plant. FKEC is reluctant to accept further limits on operating hours. It should be noted that while Unit # 8 is currently allowed unlimited operating hours, in reality, no unit can operate 8760 hours per year. So while Unit # 8 cannot meet the hourly NO_x limit of 62 lbs/hr, it will never exceed the current 271 tons/yr annual limit. Therefore, FKEC requests an increase in the hourly NO_x limit to 68 lbs/hr for our operating permit for Unit # 8 and for our Title V air operating permit.

Thank you for your consideration and assistance.

Sincerely,



Deborah A. Shaw, Ph.D.
Environmental Affairs Coordinator

Enc:

- 1) Draft comment letter.
- 2) Final Test Report - So. Fla. Environmental Services

PC: without test report.

C.A. Russell, CEO/GM, FKEC

T.E. Planer, Supt. Transmission, FKEC

D.M. Knowles, Air Program Administrator, FDEP

ENGINE SYSTEMS, INC.

P.O. Box 1928

1220 South Washington St.

Rocky Mount, NC 27802-1928

Telephone: 919/977-2720

Fax: 919/446-1136 or 919/446-3830

Page 1 of 1**DOCUMENT TRANSMITTAL RECORD**

To: Florida Keys Electric Cooperative
91605 Overseas Highway
Tavernier, FL 33070

Date: January 20, 1998

Ref. S/N: 51229C-O-0050

Attn: Tim Planer

Subject: Marathon Generating
Plant - Diesel Generating Set
P.O. 961588
ESI Job No. 51229

Enclosed are the following:

<u>Copies</u>	<u>Code</u>	<u>Drawing/Document No.</u>	<u>Sheet</u>	<u>Rev.</u>	<u>Title/Description</u>
3	B	N/A	All	--	Final Test Report - Emissions Compliance Test Program - Florida Keys Electric Cooperative Marathon Facility

Code:	<u>A</u>	Submitted For Approval	<u>F</u>	Approved
	<u>B</u>	Submitted For Information	<u>G</u>	Approved As Noted
	<u>C</u>	Submitted For Comments	<u>H</u>	Revise and Resubmit
	<u>D</u>	Final Drawings/Documents Enclosed	<u>I</u>	Not Approved
	<u>E</u>	Issued For Construction	<u>J</u>	Return _____ Signed Copies

Remarks: _____

Signed: Wanda D. Davis
Wanda D. Davis - Contract Administrator

Copy To: R. Weeks
Doc. Control

South Florida Environmental Services

FINAL TEST REPORT

EMISSIONS COMPLIANCE TEST PROGRAM

FLORIDA KEYS ELECTRIC COOPERATIVE

MARATHON FACILITY

PREPARED FOR:

Engine Systems, Inc.
1220 Washington Street
Rocky Mount, NC 27802-1928

CONCERNING:

NO_x, CO, VOC and Opacity Compliance Testing
Emission Unit #8 3.58 MW Diesel Electric Generator
Florida Keys Electric Cooperative Association, Inc.
Marathon Facility
December 17, 1997

PREPARED BY:

South Florida Environmental Services
6821 Vista Parkway North
West Palm Beach, Florida 33411
SFES #97-581


Ron C. Cook Jr.

Senior Project Director


Date

RECEIVED

JAN 28 1998

BUREAU OF
AIR REGULATION

TABLE OF CONTENTS

1.	COMPENDIUM	p. 1
2.	REFERENCE METHOD SAMPLING LOCATION	p. 3
3.	SAMPLE POINT LOCATIONS	p. 4
4.	SAMPLING TRAIN AND ANALYTICAL PROCEDURES	p. 5
5.	QUALITY CONTROL PROCEDURES	p. 11

APPENDICES

A	CEMS/VOC EMISSION CALCULATIONS
B	OPACITY OBSERVATIONS
C	CALIBRATION GAS CERTIFICATIONS
D	FIELD DATA SHEETS
E	STRIP CHARTS
F	NOMENCLATURE
G	FACILITY OPERATING DATA

1.0 COMPENDIUM

South Florida Environmental Services conducted an emissions compliance test program on behalf of Engine Systems, Inc. at Florida Keys Electric Cooperative Association, Inc. located in Marathon, Florida. The testing was conducted on the newly installed EMD generator set rated at 3.58 MW and took place on December 17, 1997.

The objective of the testing program was to determine the Compliance/Performance status of EMD diesel generator #8 with respect to oxides of nitrogen, carbon monoxide, total hydrocarbons and opacity limits. Set forth by the Florida, Department of Environmental Protection (FDEP) and Florida Keys Electric Cooperative.

All test methods and procedures were conducted in strict accordance with EPA Methods 3A, 7E, 9, 10 and 25A as found in the Federal Register (40CFR60), Appendix A. The approved test plan was adhered to throughout the program. All lb/MMBtu emission rates are based on the F-factor for oil in accordance with EPA Method 19.

The gaseous (CEM/VOC) sampling consisted of three 1-hour runs during the test program while the unit was operating at 100% of rated capacity. Final results can be found in Table 1-1.

The opacity determination was an hour visible emissions run consisting of 240 readings, 4 readings per minute, from which the highest 6-minute average and maximum opacity values were obtained and reported as percent opacity. Final results can be found in Table 1-2.

Ron C. Cook Jr. Senior Project Director, was responsible for all phases of the test program he was assisted by a team of qualified environmental professionals. Robin L. Weeks of Engine Systems, Inc. coordinated unit operation with testing. Tim Planner of Florida Keys Electric Cooperative was the company's representative.

1.0 COMPENDIUM (cont.)

The following tables summarize the results of the emissions testing program.

Table 1-1
Summary of Results
FKEC Emission Unit # 8
EMD Diesel Electric Generator
NO_x

Run #	Time	BHP	NO _x Gms/bhp-hr	NO _x lb/hr	NO _x Tons/yr
1	1500-1600	4981	6.01	65.95	288.86
2	1635-1735	4988	6.01	66.09	289.47
3	1800-1900	4983	5.93	65.10	285.14
Average			5.98	65.71	287.82

CO

Run #	Time	BHP	CO Gms/bhp-hr	CO lb/hr	CO Tons/yr
1	1500-1600	4981	.49	5.40	23.65
2	1635-1735	4988	.49	5.38	23.56
3	1800-1900	4983	.49	5.38	23.56
Average			.49	5.39	23.59

THC

Run #	Time	BHP	THC Gms/bhp-hr	THC lb/hr	THC Tons/yr
1	1500-1600	4981	.15	1.70	7.45
2	1635-1735	4988	.16	1.72	7.53
3	1800-1900	4983	.15	1.69	7.40
Average			.15	1.70	7.46

Note: Tons/yr were calculated using 8760 hours or continuous operation

Table 1-2
Visible Emission Results

Unit #	Length of Test	Highest 6 min. Average	Readings above 20%
EMD #8	60	5.0%	NONE