



# FLORIDA KEYS ELECTRIC COOPERATIVE ASSOCIATION, INC. - FKEC

91605 OVERSEAS HIGHWAY P.O. BOX 700377, TAVERNIER, FL 33070-0377 PHONE (305) 852-2431 FAX: (305) 852-4794

Mr. Al A. Linero  
Department of Environmental Protection  
Bureau of Air Resources, Mail Station 5505  
2600 Blairstone Road  
Tallahassee, FL 32399

**RECEIVED**  
FEB 17 2000  
BUREAU OF AIR REGULATION

February 14, 2000

Re: Application for new diesel generator (Unit 9) for Marathon Generation Plant.

Dear Mr. Linero:

DB70004-004-AC  
PSD-FI-285

Florida Keys Electric Cooperative Association, Inc. (FKEC) is submitting the enclosed application for the construction of a new 3.58 MW diesel generator (the Project) at the Marathon Generation Plant. As part of the Project, the stack height of the existing 3.58 MW diesel generator (Unit #8) will be increased from 38.7 feet to 45 feet. Also enclosed with the application is a check in the amount of seven thousand five hundred dollars to cover the application processing fee for a PSD New Source Review.

FKEC purchases its electricity from Florida Power & Light (FP&L) to distribute to Florida Keys residents. The Marathon Plant is maintained in a standby generating capacity, ready to generate power in the event that FP&L cannot supply power to the Keys. In May 1992, FKEC entered into a long-term contract with FP&L which requires that FKEC maintain the capability of generating electricity in the event that the mainland power supply fails. Due to this contractual obligation to FP&L, FKEC cannot accept operating limitations on the proposed source.

However, the proposed unit, like all other Marathon Plant's units, will operate only during emergencies and during peak power demand periods. Since 1992, annual operation at Marathon has averaged only 640 hours per year during non-hurricane and other 'typical' operating years. Due to these limited operating hours, emissions of various pollutants from the new source will be minimized.

Three copies of the application have been included for your review and distribution. Please contact either Deborah Shaw or Tim Planer at (305) 852-2431 if you have any questions or should require additional information.

Very truly yours,

*Charles A. Russell*

Charles A. Russell

Chief Executive Officer and General Manager

cc: C. Holladay, BAR  
SD  
EPA  
NPS

c: T. Planer, Assistant General Manager  
C. Pankow, Supv. of Generation  
D. Shaw, Environmental Affairs Coordinator



**Florida Keys Electric Cooperative**  
 Association, Inc.  
 P.O. Box 377  
 Tavernier, FL 33070  
 (305) 852-2431 www.fkec.com

First State Bank of the Florida Keys  
 97670 Overseas Highway  
 Key Largo, FL 33037  
 63-43670

Check Number

00005473

Check Date

02/15/2000

Net Amount

\$ \*\*\*\*\*7,500.00

Accounts Payable

Void After: 120 Days

**PAY \*\*\*Seven Thousand Five Hundred and 00/100 Dollars\*\*\***

TO THE ORDER OF

FL DEPT OF ENVIRON PROTECTION  
 BUREAU OF AIR RESOURCES  
 MAIL STATION 5505  
 2600 BLAIR STONE RD  
 TALLAHASSEE FL 32399-2400



*Charles A. Russell*  
 SIGNATURE HAS A COLORED BACKGROUND • BORDER CONTAINS MICROPRINTING

⑈0000005473⑈ ⑆067000438⑆ 0300023404⑈

FL DEPT OF ENVIRON PROTECTION

02/15/00

CHECK NO. 00005473

## SUMMARY OF INVOICES

INVOICES #	INV. DATE	AMOUNT	INVOICES #	INV. DATE	AMOUNT
APP FEE	02/15/00	7500.00			
			TOTAL		7500.00

## SUMMARY OF EXPENSE DISTRIBUTION

EXP. ACCT.	DEPT.	AMOUNT	EXP. ACCT.	DEPT.	AMOUNT	EXP. ACCT.	DEPT.	AMOUNT
107.20	00	7500.00						
			TOTAL		7500.00			

Florida Keys Electric Cooperative

STUB 01 OF 01

**FLORIDA KEYS ELECTRIC COOPERATIVE, INC.**

**AIR CONSTRUCTION PERMIT APPLICATION FOR**

**MARATHON GENERATION PLANT**

**TABLE OF CONTENTS**

**RECEIVED**

**FEB 17 2000**

**SECTION 1 DESCRIPTION OF PROJECT**

**SECTION 2 FLDEP FORMS (ELSA)**

**BUREAU OF AIR REGULATION**

**FIGURE 1: AREA MAP SHOWING FACILITY LOCATION**

**FIGURE 2: FACILITY PLOT PLAN**

**FIGURE 3A: PROCESS FLOW DIAGRAM – UNIT #8**

**FIGURE 3B: PROCESS FLOW DIAGRAM – UNIT #9**

**ATTACHMENT A: CURRENT OPERATION PERMIT  
(#0870004-001-AV)**

**ATTACHMENT B: MARATHON GENERATION PLANT ACTUAL  
OPERATING HOURS AND FUEL CONSUMPTION  
1992-1999**

**ATTACHMENT C: PRECAUTIONS TO PREVENT EMISSIONS OF  
UNCONFINED PARTICULATE MATTER**

**ATTACHMENT D: FUEL ANALYSIS**

**ATTACHMENT E: DETAILED DESCRIPTION OF CONTROL  
EQUIPMENT FOR UNIT #8**

**ATTACHMENT F: PROCEDURES FOR STARTUP AND SHUTDOWN**

**ATTACHMENT G: EMISSIONS TESTING RESULTS**

**SECTION 3 BEST AVAILABLE CONTROL TECHNOLOGY ANALYSIS**

**SECTION 4 AIR QUALITY ANALYSIS**

**FIGURE 1: EVERGLADES CLASS I AREA**

**ATTACHMENT 1: AIR DISPERSION MODELING RUNS**

**ATTACHMENT 2: SUPPLEMENT C TO  
*GUIDELINE ON AIR QUALITY MODELS***

This report has been prepared for the use of the client for the specific purposes identified in the report. The conclusions, observations, and recommendations contained herein attributed to R. W. Beck, Inc. ("R. W. Beck") constitute the opinions of R. W. Beck. To the extent that statements, information, and opinions provided by the client or others have been used in the preparation of this report, R. W. Beck has relied upon the same to be accurate, and for which no assurances are intended and no representations or warranties are made. R. W. Beck makes no certification and gives no assurances except as explicitly set forth in this report.

Copyright 2000, R. W. Beck, Inc.  
All rights reserved.

## SECTION 1

# DESCRIPTION OF PROJECT

---

This Prevention of Significant Deterioration (PSD) permit application is submitted by Florida Keys Electric Cooperative Association, Inc. (FKEC) for the construction and operation of one nominally rated 3,580 kW high-speed diesel engine electric generator at FKEC's existing Marathon Generation Plant. This unit will be fired exclusively on No. 2 low sulfur (less than or equal to 0.05 percent sulfur, by weight) fuel. The proposed addition is being referred to as Unit 9.

The two pollutants for which Unit 9 is subject to PSD review are  $\text{NO}_x$  and  $\text{PM}_{10}$ . Emissions of  $\text{NO}_x$  from the proposed unit will exceed the PSD threshold for a major modification (40 tpy).  $\text{PM}_{10}$  emissions, when combined with  $\text{PM}_{10}$  emissions from the existing PSD source (Unit 8), will slightly exceed the PSD threshold (15 tpy). However, with a combination of good combustion practices and low sulfur fuel, it is likely that  $\text{PM}_{10}$  emissions will actually be reduced to below the threshold concentration. Additionally, the engines at the Marathon Generation Facility are 'peaking' units and total, annual operation has averaged 640 hours per year, during non-hurricane and other typical years, since 1992. Therefore, emissions of all pollutants will be minimized through the infrequent operation of the units at Marathon.

Currently, two 2,000 kW (Units 1 and 2), three 3,000 kW (Units 3, 4 and 5), two 2,500 kW (Units 6 and 7) and one 3,580 kW (Unit 8) diesel electric generators are operating at the Marathon Plant. Unit 8 was permitted for unlimited operation with maximum allowable  $\text{NO}_x$  emissions of 68 lbs/hr or 298 tpy. Additionally, the operating permit limits Units 1 through 7 to either 4,380 hrs/yr per unit or to a total fuel oil consumption of 6,200,000 gal/yr, whichever is more restrictive. As part of the proposed Project, the stack height for Unit 8 will be increased from 38.7 feet to 45 feet.

Further details and information on the Marathon Generation Facility and the proposed Project, including the addition of Unit 9 and the stack height increase for Unit 8, can be found in Section 2 which contains the Florida Department of Environmental Protection (FL DEP) forms. These forms were completed with FLDEP's Electronic Submission of Application (ELSA) program.

FKEC buys its electricity from Florida Power & Light (FP&L) to distribute to Florida Keys consumers. The Marathon Generation Plant is maintained in a standby generating capacity, ready to generate power in the event that FP&L cannot supply power to the Keys. FKEC entered into a 20-year extendable contract with FP&L which requires that FKEC maintain the capability of generating electricity in the event the mainland power supply fails and can no longer continue to deliver alternate economic energy. Due to this contractual

obligation to FP&L, FKEC cannot accept operating limitations on the proposed Unit 9. Therefore, it is anticipated that Unit 9 will operate under conditions comparable to those for the similar Unit 8, including maximum allowable NO<sub>x</sub> emissions of 68 lbs/hr or 298 tpy. The proposed engine will operate below these NO<sub>x</sub> levels through a combination of ignition timing retardation and a 4-pass aftercooler with a separately cooled aftercooler circuit. Additionally, due to good combustion controls and low sulfur fuel, PM<sub>10</sub> emissions will be reduced. These control methods are determined to be Best Available Control Technology (BACT) for the engine (Section 3).

An air dispersion modeling analysis was performed to compare the predicted impacts of the Project to the National Ambient Air Quality Standards (NAAQS) and Prevention of Significant Deterioration (PSD) Class II Increments. It was determined that the proposed Unit 9 will not cause or contribute to adverse impacts on the air quality in the region of the Marathon Plant. Additionally, impacts were modeled on the closest PSD Class I Area, Everglades National Park. Due to the distance of the Project to the Everglades, impacts were found to be small enough to eliminate the need for further evaluations. The Air Quality Analysis discussion is found in Section 4.

**Department of  
Environmental Protection**

**DIVISION OF AIR RESOURCES MANAGEMENT  
APPLICATION FOR AIR PERMIT - LONG FORM**

**I. APPLICATION INFORMATION**

**Identification of Facility Addressed in This Application**

1. Facility Owner/Company Name : Flroida Keys Electric Coop. Assoc., Inc.		
2. Site Name : Marathon Generation Plant		
3. Facility Identification Number :      0870004      [   ] Unknown		
4. Facility Location : Marathon Generation Plant  Street Address or Other Locator :      3421 Overseas Highway City : Marathon      County : Monroe      Zip Code : 33050		
5. Relocatable Facility? [   ] Yes    [X] No		6. Existing Permitted Facility? [X] Yes    [   ] No

0870004-004-AC  
PSD-FI-285

I. Part 1 - 1

**Owner/Authorized Representative or Responsible Official**

1. Name and Title of Owner/Authorized Representative or Responsible Official :

Name : Charles A. Russell  
Title : CEO and General Manager

2. Owner or Authorized Representative or Responsible Official Mailing Address :


Organization/Firm : Florida Keys Electric Coop. Assoc., Inc.  
Street Address : 91605 Overseas Highway  
City : Tavernier  
State : FL Zip Code : 33070


3. Owner/Authorized Representative or Responsible Official Telephone Numbers :

Telephone : (305)852-2431 Fax : (305)853-5381

4. Owner/Authorized Representative or Responsible Official Statement :

*I, the undersigned, am the owner or authorized representative\* of the non-Title V source addressed in this Application for Air Permit or the responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions units.*

  
Signature

  
Date

\* Attach letter of authorization if not currently on file.

I. Part 2 - 1



Scope of Application

Emissions Unit ID	Description of Emissions Unit	Permit Type
008	3.58 MW EMD Diesel Generator #8	AFMM
009	3.58 MW EMD Diesel Generator #9	ACIA

**Purpose of Application and Category**

Category I: All Air Operation Permit Applications Subject to Processing Under Chapter 62-213, F.A.C.

This Application for Air Permit is submitted to obtain :

- ☐ Initial air operation permit under Chapter 62-213, F.A.C., for an existing facility which is classified as a Title V source.
- ☐ Initial air operation permit under Chapter 62-213, F.A.C., for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number :

- ☐ Air operation permit renewal under Chapter 62-213, F.A.C., for a Title V source.

Operation permit to be renewed :

- ☒ Air operation permit revision for a Title V source to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number :  
0870004-001-AV (Attachment A)

Operation permit to be revised :  
0870004-001-AV

- ☐ Air operation permit revision or administrative correction for a Title V source to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application.

Operation permit to be revised/corrected :

I. Part 4 - 1

- ☐ Air operation permit revision for a Title V source for reasons other than construction or modification of an emissions unit.

Operation permit to be revised :

Reason for revision :

Category II : All Air Operation Permit Applications Subject to Processing Under Rule 62-210.300(2)(b), F.A.C.

This Application for Air Permit is submitted to obtain :

- ☐ Initial air operation permit under Rule 62-210.300(2)(b), F.A.C., for an existing facility seeking classification as a synthetic non-Title V source.

Current operation/construction permit number(s) :

- ☐ Renewal air operation permit under Rule 62-210.300(2)(b), F.A.C., for a synthetic non-Title V source.

Operation permit to be renewed :

- ☐ Air operation permit revision for a synthetic non-Title V source.

Operation permit to be revised :

Reason for revision :

Category III : All Air Construction Permit Applications for All Facilities and Emissions Units

This Application for Air Permit is submitted to obtain :

I. Part 4 - 2

DEP Form No. 62-210.900(1) - Form  
Effective : 3-21-96

- ☒ Air construction permit to construct or modify one or more emissions units within a facility (including any facility classified as a Title V source).

Current operation permit number(s), if any :  
0870004-001-AV (Attachment A)

- ☐ Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.

Current operation permit number(s) :

- ☐ Air construction permit for one or more existing, but unpermitted, emissions units.

### Application Processing Fee

Check one :

☒ Attached - Amount : \$7500.00      ☐ Not Applicable.

### Construction/Modification Information

1. Description of Proposed Project or Alterations :	
Proposed construction of one new 3.58 MW EMD Diesel Generator at Florida Keys Electric Cooperative Association, Inc.'s Marathon Stand-By Generation Plant. As part of the proposed project, the stack height for the existing 3.58 MW EMD Diesel Generator Unit #8 at the Marathon Generation Plant will be increased from 38.7 feet to 45 feet.	
2. Projected or Actual Date of Commencement of Construction :	01-Sep-2000
3. Projected Date of Completion of Construction :	31-Dec-2000

### Professional Engineer Certification

1. Professional Engineer Name : Ivan L. Clark Registration Number : 0049777	
2. Professional Engineer Mailing Address :  Organization/Firm : R.W. Beck Street Address : 1125 17th Street, Suite 1900 City : Denver      State : CO   Zip Code : 80202-2615	
3. Professional Engineer Telephone Numbers : Telephone : (303)299-5247      Fax : (303)297-2811	

I. Part 5 - 1

4. Professional Engineer Statement :

*I, the undersigned, hereby certify, except as particularly noted herein\*, that :*

*(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollutant control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and*

*(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.*

*If the purpose of this application is to obtain a Title V source air operation permit (check here [ ] if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.*

*If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [X] if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.*

*If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [ ] if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.*

Signature  
(seal)



Date

2/11/00

\* Attach any exception to certification statement.

I. Part 6 - 2

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96

## Application Contact

### 1. Name and Title of Application Contact :

Name : Deborah A. Shaw

Title : Environmental Affairs Coordinator

### 2. Application Contact Mailing Address :

Organization/Firm : FKEC Assoc., Inc.

Street Address : 91605 Overseas Highway

City : Tavernier

State : FL Zip Code : 33070

### 3. Application Contact Telephone Numbers :

Telephone : (305)852-2431

Fax : (305)852-9129

## Application Comment

Florida Keys Electric Cooperative Association, Inc. (FKEC) supplies electric power to the Middle and Upper Florida Keys. FKEC buys its electricity from Florida Power & Light (FP&L) to distribute to Florida Keys consumers. The Marathon Generation Plant is maintained in a standby generating capacity, ready to generate power in the event that FP&L cannot supply power to the Keys. FKEC entered into a 20-year extendable contract with FP&L that became effective May 1, 1992 and which requires that FKEC maintain the capability of generating electricity in the event the mainland power supply fails and can no longer continue to deliver alternate economic energy above the effective base demand.

Since the implementation of that contract agreement, the Marathon Generation Plant's total, annual operating hours have averaged 640 hours during 'non-hurricane' and other typical operating years. (Attachment B)

Because FKEC must be able to generate electricity for the Keys during emergencies, operating limitations on the Marathon Generation Plant cannot be accepted. Therefore, even though the Plant's annual emissions are far below the levels which define a major air pollution source, FKEC is applying for this permit as a major source.



## II. FACILITY INFORMATION

### A. GENERAL FACILITY INFORMATION

#### Facility, Location, and Type

1. Facility UTM Coordinates : Zone : 17 East (km) : 490.70 North (km) : 2732.70			
2. Facility Latitude/Longitude : Latitude (DD/MM/SS) : 24 42 38 Longitude (DD/MM/SS) : 81 5 30			
3. Governmental Facility Code : 0	4. Facility Status Code : A	5. Facility Major Group SIC Code : 49	6. Facility SIC(s) : 4911
7. Facility Comment :  This facility is a standby electric generating plant consisting of eight (8) diesel engines driving electric generators.  A ninth (9th) unit is being added. Total capacity of the facility with nine (9) units will be 25.2 MW. This facility generates power only during emergencies or during peak power demand periods when Florida Power & Light cannot provide sufficient power to supply Florida Keys Electric Cooperative Association, Inc.'s customers.			

## II. FACILITY INFORMATION

### A. GENERAL FACILITY INFORMATION

#### Facility Contact

1. Name and Title of Facility Contact :	
Charles A. Russell CEO and General Manager	
2. Facility Contact Mailing Address :	
Organization/Firm :	FKEC Assoc., Inc
Street Address :	91605 Overseas Highway
City :	Tavernier
State :	FL
Zip Code :	33070
3. Facility Contact Telephone Numbers :	
Telephone :	(305)852-2431
Fax :	(305)853-5381

### Facility Regulatory Classifications

1. Small Business Stationary Source?	N
2. Title V Source?	Y
3. Synthetic Non-Title V Source?	N
4. Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)?	Y
5. Synthetic Minor Source of Pollutants Other than HAPs?	N
6. Major Source of Hazardous Air Pollutants (HAPs)?	N
7. Synthetic Minor Source of HAPs?	N
8. One or More Emissions Units Subject to NSPS?	N
9. One or More Emission Units Subject to NESHAP?	N
10. Title V Source by EPA Designation?	Y
11. Facility Regulatory Classifications Comment :  The facility is classified as a major Title V source only because it has the potential to emit 250 tons of air pollutants, however, the plant typically operates less than 10% of the time.	

II. Part 2 - 1

## B. FACILITY REGULATIONS

### Rule Applicability Analysis

--

## **B. FACILITY REGULATIONS**

### **List of Applicable Regulations**

40 CFR 70 - State Operating Permits

62-4.001 through 62-4.160, FAC - Permits Part I General

62-4.210, FAC - Construction Permits

62-4.220, FAC - Operating Permits

62-103.150, FAC - Public Notice of Application and Proposed Agency Action

62-204.240, FAC - Ambient Air Quality Standards

62-210, FAC - Stationary Sources

62-212.300, FAC - General Preconstruction Review Requirements

62-212.400, FAC - Prevention of Significant Deterioration

62-213, FAC - Operation Permits for Major Sources of Air Pollution (Title V)

62-296.320(2), FAC - General Pollutant Emission Limiting Standards, Objectionable Odor

62-296.320(4)(b), FAC - General Visible Emission Standards

62-296.320(4)(c), FAC - Unconfined Emissions of Particulate Matter

62-297.310, FAC - General Test Requirements

II. Part 3b - 1

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96

## B. FACILITY REGULATIONS

### List of Applicable Regulations

62-297.401, FAC - EPA Test Procedures

62-297.620, FAC - Exceptions and Approvals of Alternative Procedures and Requirements

62-204.800, FAC - Federal Regulations Adopted by Reference

62-297.400, FAC - EPA Methods Adopted by Reference

62-297.440, FAC - Supplementary Test Procedures

## C. FACILITY POLLUTANTS

### Facility Pollutant Information

1. Pollutant Emitted	2. Pollutant Classification
SO2	A
CO	A
NOX	A
PM	A
PM10	A
VOC	B

## D. FACILITY POLLUTANT DETAIL INFORMATION

### Facility Pollutant Information

Pollutant 1

1. Pollutant Emitted :	SO2	
2. Requested Emissions Cap :	(lbs/hour)	(tons/year)
3. Basis for Emissions Cap Code :	AMBIENT	
4. Facility Pollutant Comment :	<p>Diesel generator units #1 through #7 at Marathon Generation Plant are limited to either 4,380 hrs/yr per unit or to a total fuel oil consumption of 6,200,000 gal/yr, whichever limit is more restrictive. SO2 emissions will be restricted as a result of these operating limits.</p>	

II. Part 4b - 1

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96



## D. FACILITY POLLUTANT DETAIL INFORMATION

### Facility Pollutant Information

Pollutant 2

1. Pollutant Emitted :	CO	
2. Requested Emissions Cap :	(lbs/hour)	(tons/year)
3. Basis for Emissions Cap Code :	AMBIENT	
4. Facility Pollutant Comment :	Diesel generator units #1 through #7 at Marathon Generation Plant are limited to either 4,380 hrs/yr per unit or to a total fuel oil consumption of 6,200,000 gal/yr, whichever limit is more restrictive. CO emissions will be restricted as a result of these operating limits.	

II. Part 4b - 2

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96

## D. FACILITY POLLUTANT DETAIL INFORMATION

### Facility Pollutant Information

Pollutant 3

1. Pollutant Emitted :	NOX	
2. Requested Emissions Cap :	(lbs/hour)	(tons/year)
3. Basis for Emissions Cap Code :	AMBIENT	
4. Facility Pollutant Comment :	<p>Diesel generator units #1 through #7 at Marathon Generation Plant are limited to either 4,380 hrs/yr per unit or to a total fuel oil consumption of 6,200,000 gal/yr, whichever limit is more restrictive. thus restricting NOx emissions. The maximum NOx emission rate for Unit #8 is 68 lbs/hr (298 tpy). It is anticipated that Unit #9 will also operate under the NOx limit of 68 lb/hr (298 tpy).</p>	

II. Part 4b - 3

## D. FACILITY POLLUTANT DETAIL INFORMATION

### Facility Pollutant Information

Pollutant 4

1. Pollutant Emitted :	PM	
2. Requested Emissions Cap :	(lbs/hour)	(tons/year)
3. Basis for Emissions Cap Code :	AMBIENT	
4. Facility Pollutant Comment :	Diesel generator units #1 through #7 at Marathon Generation Plant are limited to either 4,380 hrs/yr per unit or to a total fuel oil consumption of 6,200,000 gal/yr, whichever limit is more restrictive. PM emissions will be restricted as a result of these operating limits.	

II. Part 4b - 4

## D. FACILITY POLLUTANT DETAIL INFORMATION

### Facility Pollutant Information

Pollutant 5

1. Pollutant Emitted :	PM10
2. Requested Emissions Cap :	(lbs/hour) (tons/year)
3. Basis for Emissions Cap Code :	AMBIENT
4. Facility Pollutant Comment :	Diesel generator units #1 through #7 at Marathon Generation Plant are limited to either 4,380 hrs/yr per unit or to a total fuel oil consumption of 6,200,000 gal/yr, whichever limit is more restrictive. PM10 emissions will be restricted as a result of these operating limits.

II. Part 4b - 5

## D. FACILITY POLLUTANT DETAIL INFORMATION

### Facility Pollutant Information

Pollutant 6

1. Pollutant Emitted :	VOC	
2. Requested Emissions Cap :	(lbs/hour)	(tons/year)
3. Basis for Emissions Cap Code :	AMBIENT	
4. Facility Pollutant Comment :	<p>Diesel generator units #1 through #7 at Marathon Generation Plant are limited to either 4,380 hrs/yr per unit or to a total fuel oil consumption of 6,200,000 gal/yr, whichever limit is more restrictive. VOC emissions will be restricted as a result of these operating limits.</p>	

II. Part 4b - 6

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96

## D. FACILITY SUPPLEMENTAL INFORMATION

### Supplemental Requirements for All Applications

1. Area Map Showing Facility Location :	Figure 1
2. Facility Plot Plan :	Figure 2
3. Process Flow Diagram(s) :	Figures 3a & 3b
4. Precautions to Prevent Emissions of Unconfined Particulate Matter :	Attachment C
5. Fugitive Emissions Identification :	NA
6. Supplemental Information for Construction Permit Applica	NA

### Additional Supplemental Requirements for Category I Applications Only

7. List of Proposed Exempt Activities :	NA
8. List of Equipment/Activities Regulated under Title VI :	NA
9. Alternative Methods of Operation :	NA
10. Alternative Modes of Operation (Emissions Trading) :	NA
11. Identification of Additional Applicable Requirements :	NA
12. Compliance Assurance Monitoring Plan :	NA
13. Risk Management Plan Verification :	NA
14. Compliance Report and Plan :	NA
15. Compliance Certification (Hard-copy Require	NA

### III. EMISSIONS UNIT INFORMATION

#### A. TYPE OF EMISSIONS UNIT (Regulated and Unregulated Emissions Units)

Emissions Unit Information Section     1    

3.58 MW EMD Diesel Generator #8

#### Type of Emissions Unit Addressed in This Section

1. Regulated or Unregulated Emissions Unit? Check one :

- ☒ The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.
- ☐ The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

2. Single Process, Group of Processes, or Fugitive Only? Check one :

- ☒ This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
- ☐ This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.
- ☐ This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

Emissions Unit Information Section 1

**B. GENERAL EMISSIONS UNIT INFORMATION**  
(Regulated and Unregulated Emissions Units)

Emissions Unit Description and Status

1. Description of Emissions Unit Addressed in This Section :  3.58 MW EMD Diesel Generator #8		
2. Emissions Unit Identification Number : 008 [ ] No Corresponding ID [ ] Unknown		
3. Emissions Unit Status Code : A	4. Acid Rain Unit? [ ] Yes [X] No	5. Emissions Unit Major Group SIC Code : 49
6. Emissions Unit Comment :  As part of the proposed project, the stack height for the existing 3.58 MW EMD diesel generator unit (#8) is being increased from 38.7 feet to 45 feet.		



**Emissions Unit Information Section**      1

3.58 MW EMD Diesel Generator #8

**Emissions Unit Control Equipment**      1

1. Description :

Retarded injection timing - Reduces firing pressure and combustion temperature.

2. Control Device or Method Code :      99

III. Part 3 -      1

**Emissions Unit Information Section**

1

3.58 MW EMD Diesel Generator #8

**Emissions Unit Control Equipment**

2

1. Description :

Increased flow capacity aftercoolers (4-pass,4-flange,Counterflow) with low temperature separate aftercooling circuit - Increases combustion air density thereby increasing the ratio of air to fuel.

2. Control Device or Method Code :

99

**C. EMISSIONS UNIT DETAIL INFORMATION**  
**(Regulated Emissions Units Only)**

**Emissions Unit Information Section**

1

3.58 MW EMD Diesel Generator #8

**Emissions Unit Details**

1. Initial Startup Date :	01-Jan-1998	
2. Long-term Reserve Shutdown Date :		
3. Package Unit :		
Manufacturer :	Electro-Motive Diesel (EMD)	Model Number : 20-710G4B
4. Generator Nameplate Rating :		
4	MW	
5. Incinerator Information :		
Dwell Temperature :		Degrees Fahrenheit
Dwell Time :		Seconds
Incinerator Afterburner Temperature :		Degrees Fahrenheit

**Emissions Unit Operating Capacity**

1. Maximum Heat Input Rate :	30	mmBtu/hr
2. Maximum Incinerator Rate :	lb/hr	tons/day
3. Maximum Process or Throughput Rate :		
4. Maximum Production Rate :		
5. Operating Capacity Comment :		
This unit, like all other Florida Keys Electric Cooperative Association, Inc.'s units, will operate only during emergencies and during peak power demand periods.		

**Emissions Unit Operating Schedule**

Requested Maximum Operating Schedule :		
24 hours/day		7 days/week
52 weeks/year		8,760 hours/year

**D. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

**Emissions Unit Information Section**          1    

3.58 MW EMD Diesel Generator #8

**Rule Applicability Analysis**

--

III. Part 6a - 1

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96

**Emissions Unit Information Section**      1  
3.58 MW EMD Diesel Generator #8

**List of Applicable Regulations**

40 CFR 70 - State Operating Permits

62-4.001 through 62-4.160, FAC - Permits Part I General

62-4.210, FAC - Construction Permits

62-4.220, FAC - Operating Permits

62-103.150, FAC - Public Notice of Application and Proposed Agency Action

62-204.240, FAC - Ambient Air Quality Standards

62-210, FAC - Stationary Sources

62-212.300, FAC - General Preconstruction Review Requirements

62-212.400, FAC - Prevention of Significant Deterioration

62-213, FAC - Operation Permits for Major Sources of Air Pollution (Title V)

62-296.320(2), FAC - General Pollutant Emission Limiting Standards, Objectionable Odor

62-296.320(4)(b), FAC - General Visible Emission Standards

62-297.310, FAC - General Test Requirements

III. Part 6b - 3

DEP Form No. 62-210.900(1) - Form  
Effective : 3-21-96

**Emissions Unit Information Section**      1  
3.58 MW EMD Diesel Generator #8

**List of Applicable Regulations**

62-297.401, FAC - EPA Test Procedures

62-297.620, FAC - Exceptions and Approvals of Alternative Procedures and Requirements

62-204.800, FAC - Federal Regulations Adopted by Reference

62-297.400, FAC - EPA Methods Adopted by Reference

62-297.440, FAC - Supplementary Test Procedures

## F. SEGMENT (PROCESS/FUEL) INFORMATION

Emissions Unit Information Section 1

3.58 MW EMD Diesel Generator #8

Segment Description and Rate : Segment 1

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) :

No. 2 Fuel Oil Burned in Diesel Engine.

2. Source Classification Code (SCC) : 20100102

3. SCC Units : Thousand Gallons Burned (all liquid fuels)

4. Maximum Hourly Rate : 0.23

5. Maximum Annual Rate : 2,015.00

6. Estimated Annual Activity Factor :

7. Maximum Percent Sulfur : 0.05

8. Maximum Percent Ash :

9. Million Btu per SCC Unit : 132

10. Segment Comment :

III. Part 8 - 2

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96

## E. EMISSION POINT (STACK/VENT) INFORMATION

Emissions Unit Information Section 1

3.58 MW EMD Diesel Generator #8

Emission Point Description and Type :

1. Identification of Point on Plot Plan or Flow Diagram :	Figure 2, #8
2. Emission Point Type Code :	1
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking : (limit to 100 characters per point)	
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common :	
5. Discharge Type Code :	W
6. Stack Height :	45 feet
7. Exit Diameter :	2.3 feet
8. Exit Temperature :	666 °F
9. Actual Volumetric Flow Rate :	29008 acfm
10. Percent Water Vapor :	0.00 %
11. Maximum Dry Standard Flow Rate :	0 dscfm
12. Nonstack Emission Point Height :	0 feet
13. Emission Point UTM Coordinates :	
Zone : 17	East (km) : 490.700 North (km) : 2732.700
14. Emission Point Comment :	
The stack height for the existing 3.58 MW EMD diesel unit will be increased from 38.7 feet to 45 feet. The UTM coordinates for this emission point are approximate (see Figures 1 and 2).	

III. Part 7a - 1



**G. EMISSIONS UNIT POLLUTANTS**  
**(Regulated and Unregulated Emissions Units)**

**Emissions Unit Information Section**     1

3.58 MW EMD Diesel Generator #8

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
1 - SO <sub>2</sub>			NS
2 - CO			NS
3 - NO <sub>X</sub>	099		EL
4 - PM			NS
5 - PM <sub>10</sub>			NS
6 - VOC			NS

III. Part 9a - 1

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**      1

3.58 MW EMD Diesel Generator #8

**Pollutant Potential/Estimated Emissions :**      Pollutant      1

1. Pollutant Emitted : <b>SO2</b>	
2. Total Percent Efficiency of Control :	%
3. Potential Emissions :	1.6500000 lb/hour                      7.2000000 tons/year
4. Synthetically Limited? [   ] Yes                      [X ] No	
5. Range of Estimated Fugitive/Other Emissions:	to                      tons/year
6. Emissions Factor Reference : Mass Balance	Units :
7. Emissions Method Code :      2	
8. Calculations of Emissions :  1000 gal/132 MMBtu x 7.2 lbs/gal x 0.05% S x 2 = 0.0545 lbs/MMBtu 0.0545 lbs/MMBtu x 30.2 MMBtu/hr = 1.65 lbs/hr 1.65 lbs/hr x 8760 hrs/yr x ton/2000 lbs = 7.2 tpy	
9. Pollutant Potential/Estimated Emissions Comment :  SO2 emissions will be minimized through the use of low sulfur fuel (less than or equal to 0.05% sulfur, by weight).	

III. Part 9b - 1

## Emissions Unit Information Section 1

Pollutant Potential/Estimated Emissions : Pollutant . 2



**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**     1  
3.58 MW EMD Diesel Generator #8

**Pollutant Potential/Estimated Emissions :**     Pollutant     4

1. Pollutant Emitted : <b>PM</b>		
2. Total Percent Efficiency of Control :		%
3. Potential Emissions :		
2.1000000 lb/hour	9.2200000 tons/year	
4. Synthetically Limited? [   ] Yes            [X ] No		
5. Range of Estimated Fugitive/Other Emissions:		
	to	tons/year
6. Emissions Factor            0	Units : lbs/MMBtu	
Reference : AP-42		
7. Emissions Method Code :     3		
8. Calculations of Emissions :  0.0697 lbs/MMBtu x 30.2 MMBtu/hr = 2.10 lbs/hr 2.10 lbs/hr x 8760 hrs/yr x ton/2000 lbs = 9.22 tpy		
9. Pollutant Potential/Estimated Emissions Comment :  The use of low sulfur fuel (less than or equal to 0.05% sulfur, by weight) and good combustion practices will reduce PM emissions.		

III. Part 9b - 4

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**     1

3.58 MW EMD Diesel Generator #8

**Pollutant Potential/Estimated Emissions :**     Pollutant     5

1. Pollutant Emitted : <b>PM10</b>		
2. Total Percent Efficiency of Control :		%
3. Potential Emissions :		
1.7300000 lb/hour		7.5800000 tons/year
4. Synthetically Limited? [   ] Yes                    [X ] No		
5. Range of Estimated Fugitive/Other Emissions:		
	to	tons/year
6. Emissions Factor                    0 Reference : AP-42		Units : lbs/MMBtu
7. Emissions Method Code :     3		
8. Calculations of Emissions :  0.0573 lbs/MMBtu x 30.2 MMBtu/hr = 1.73 lbs/hr 1.73 lbs/hr x 8760 hrs/yr x ton/2000 lbs = 7.58 tpy		
9. Pollutant Potential/Estimated Emissions Comment :  The use of low sulfur fuel (<= 0.05% sulfur, by weight) and good combustion practices will reduce PM10 emissions. Based on ave. actual operation of 640 hrs/yr, PM10 emissions will also be minimized.		

**Emissions Unit Information Section** 1  
3.58 MW EMD Diesel Generator #8

1. Pollutant Emitted :	VOC		
2. Total Percent Efficiency of Control :	%		
3. Potential Emissions :	3.0200000 lb/hour	13.2300000 tons/year	
4. Synthetically Limited?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		to	tons/year
6. Emissions Factor	0	Units : lbs/MMBtu	
Reference :	AP-42		
7. Emissions Method Code :	3		
8. Calculations of Emissions :	$0.1 \text{ lbs/MMBtu} \times 30.2 \text{ MMBtu/hr} = 3.02 \text{ lbs/hr}$ $3.02 \text{ lbs/hr} \times 8760 \text{ hrs/yr} \times \text{ton}/2000 \text{ lbs} = 13.23 \text{ tpy}$		
9. Pollutant Potential/Estimated Emissions Comment :			

**Emissions Unit Information Section**      1  
3.58 MW EMD Diesel Generator #8

**Pollutant Information Section**      3

**Allowable Emissions**      1

1. Basis for Allowable Emissions Code :				OTHER
2. Future Effective Date of Allowable Emissions :				
3. Requested Allowable Emissions and Units :				
4. Equivalent Allowable Emissions :				
	68.00	lb/hour	298.00	tons/year
5. Method of Compliance :				
Emission controls determined as BACT (Attachment E).				
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) :				
Maximum allowable emission rates during normal operation based on current permit conditions (Attachment A).				

III. Part 9c - 2



**I. VISIBLE EMISSIONS INFORMATION**  
**(Regulated Emissions Units Only)**

**Emissions Unit Information Section**       1  

3.58 MW EMD Diesel Generator #8

**Visible Emissions Limitation :** Visible Emissions Limitation       1  

1. Visible Emissions Subtype :	20									
2. Basis for Allowable Opacity :	RULE									
3. Requested Allowable Opacity :	<table style="width: 100%;"><tr><td style="text-align: right;">Normal Conditions :</td><td style="text-align: center;">20</td><td style="text-align: right;">%</td></tr><tr><td style="text-align: right;">Exceptional Conditions :</td><td style="text-align: center;">100</td><td style="text-align: right;">%</td></tr><tr><td style="text-align: right;">Maximum Period of Excess Opacity Allowed :</td><td style="text-align: center;">10</td><td style="text-align: right;">min/hour</td></tr></table>	Normal Conditions :	20	%	Exceptional Conditions :	100	%	Maximum Period of Excess Opacity Allowed :	10	min/hour
Normal Conditions :	20	%								
Exceptional Conditions :	100	%								
Maximum Period of Excess Opacity Allowed :	10	min/hour								
4. Method of Compliance :	EPA Method 9 or state approved equivalent method.									
5. Visible Emissions Comment :	General emission standard 62-296.320, FAC. As per 62-210.700(1), FAC, excess emissions during startup, shutdown or malfunction shall be permitted but in no case exceed 2 hours in any 24 hour period.									

**I. VISIBLE EMISSIONS INFORMATION**  
**(Regulated Emissions Units Only)**

**Emissions Unit Information Section**     1

3.58 MW EMD Diesel Generator #8

**Visible Emissions Limitation :** Visible Emissions Limitation     2

1. Visible Emissions Subtype :            X		
2. Basis for Allowable Opacity :        RULE		
3. Requested Allowable Opacity :		
Normal Conditions :	100	%
Exceptional Conditions :	100	%
Maximum Period of Excess Opacity Allowed :	60	min/hour
4. Method of Compliance :		
Emissions monitored to not exceed 2 hrs in any 24 hr period.		
5. Visible Emissions Comment :		
As per 62-210.700(1), FAC, excess emissions during startup, shutdown, malfunction or annual low load testing requirements shall be permitted but in no case exceed 2 hours in any 24 hour period.		

## K. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT TRACKING INFORMATION

Emissions Unit Information Section 1

3.58 MW EMD Diesel Generator #8

### PSD Increment Consumption Determination

#### 1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

- ☐ The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. If so, emissions unit consumes increment.
- ☒ The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

- ☒ The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. If so, emissions unit consumes increment.
- ☐ The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ None of the above apply. If so, baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3. Increment Consuming/Expanding Code :

PM : C

SO2 : C

NO2 : C

4. Baseline Emissions :

PM :

lb/hour

tons/year

SO2 :

lb/hour

tons/year

NO2 :

tons/year

5. PSD Comment :

## L. EMISSIONS UNIT SUPPLEMENTAL INFORMATION

Emissions Unit Information Section 1

3.58 MW EMD Diesel Generator #8

### Supplemental Requirements for All Applications

1. Process Flow Diagram :	Figure 3a
2. Fuel Analysis or Specification :	Attachment D
3. Detailed Description of Control Equipment :	Attachment E
4. Description of Stack Sampling Facilities :	NA
5. Compliance Test Report :	NA
6. Procedures for Startup and Shutdown :	Attachment F
7. Operation and Maintenance Plan :	NA
8. Supplemental Information for Construction Permit Application :	NA
9. Other Information Required by Rule or Statue :	NA

### Additional Supplemental Requirements for Category I Applications Only

10. Alternative Methods of Operations :	NA
11. Alternative Modes of Operation (Emissions Trading) :	NA

III. Part 13 - 1

12. Identification of Additional Applicable Requirements :		NA
13. Compliance Assurance Monitoring Plan :		NA
14. Acid Rain Application (Hard-copy Required) :		
NA	Acid Rain Part - Phase II (Form No. 62-210.900(1)(a))	
NA	Repowering Extension Plan (Form No. 62-210.900(1)(a)1.)	
NA	New Unit Exemption (Form No. 62-210.900(1)(a)2.)	
NA	Retired Unit Exemption (Form No. 62-210.900(1)(a)3.)	

### III. EMISSIONS UNIT INFORMATION

#### A. TYPE OF EMISSIONS UNIT (Regulated and Unregulated Emissions Units)

Emissions Unit Information Section 2

3.58 MW EMD Diesel Generator #9

#### Type of Emissions Unit Addressed in This Section

1. Regulated or Unregulated Emissions Unit? Check one :

- ☒ The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.
- ☐ The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

2. Single Process, Group of Processes, or Fugitive Only? Check one :

- ☒ This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
- ☐ This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.
- ☐ This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

Emissions Unit Information Section 2

**B. GENERAL EMISSIONS UNIT INFORMATION**  
(Regulated and Unregulated Emissions Units)

Emissions Unit Description and Status

1. Description of Emissions Unit Addressed in This Section :  3.58 MW EMD Diesel Generator #9		
2. Emissions Unit Identification Number : 009 [ ] No Corresponding ID [ ] Unknown		
3. Emissions Unit Status Code : C	4. Acid Rain Unit? [ ] Yes [X] No	5. Emissions Unit Major Group SIC Code : 49
6. Emissions Unit Comment :  This is a new unit necessary for Florida Keys Electric Cooperative Association, Inc. to maintain contractual generating capacity for use during emergency and peak power demand periods.		



**Emissions Unit Information Section**      2

3.58 MW EMD Diesel Generator #9

**Emissions Unit Control Equipment**      1

1. Description :

Retarded injection timing - Reduces firing pressure and combustion temperature.

2. Control Device or Method Code :      99

**Emissions Unit Information Section**      2

3.58 MW EMD Diesel Generator #9

**Emissions Unit Control Equipment**      2

1. Description :

Increased flow capacity aftercoolers (4-pass,4-flange,Counterflow) with low temperature separate aftercooling circuit - Increases combustion air density thereby increasing the ratio of air to fuel.

2. Control Device or Method Code :      99

### C. EMISSIONS UNIT DETAIL INFORMATION (Regulated Emissions Units Only)

**Emissions Unit Information Section**      2

3.58 MW EMD Diesel Generator #9

#### Emissions Unit Details

1. Initial Startup Date :	31-Dec-2000	
2. Long-term Reserve Shutdown Date :		
3. Package Unit :		
Manufacturer : Electro-Motive Diesel (EMD)	Model Number : 20-710G4B	
4. Generator Nameplate Rating :	4	MW
5. Incinerator Information :		
Dwell Temperature :	Degrees Fahrenheit	
Dwell Time :	Seconds	
Incinerator Afterburner Temperature :	Degrees Fahrenheit	

#### Emissions Unit Operating Capacity

1. Maximum Heat Input Rate :	30	mmBtu/hr
2. Maximum Incinerator Rate :	lb/hr	tons/day
3. Maximum Process or Throughput Rate :		
4. Maximum Production Rate :		
5. Operating Capacity Comment :		
While unlimited operating capacity is requested, this unit, like all other FKEC's units, will operate only during emergencies and during peak power demand periods.		

#### Emissions Unit Operating Schedule

Requested Maximum Operating Schedule :		
24 hours/day	7 days/week	
52 weeks/year	8,760 hours/year	

III. Part 4 - I

DEP Form No. 62-210.900(1) - Form

Effective : 3-21-96

**D. EMISSIONS UNIT REGULATIONS**  
**(Regulated Emissions Units Only)**

**Emissions Unit Information Section**      2  
3.58 MW EMD Diesel Generator #9

**Rule Applicability Analysis**

--

III. Part 6a - 2

**List of Applicable Regulations**

40 CFR 70 - State Operating Permits

62-4.001 through 62-4.160, FAC - Permits Part I General

62-4.210, FAC - Construction Permits

62-4.220, FAC - Operating Permits

62-103.150, FAC - Public Notice of Application and Proposed Agency Action

62-204.240, FAC - Ambient Air Quality Standards

62-210, FAC - Stationary Source

62-212.300, FAC - General Preconstruction Review Requirements

62-212.400, FAC - Prevention of Significant Deterioration

62-213, FAC - Operation Permits for Major Sources of Air Pollution (Title V)

62-296.320(2), FAC - General Pollutant Emission Limiting Standards, Objectionable Odor

62-296.320(4)(b), FAC - General Visible Emission Standards

62-297.310, FAC - General Test Requirements

III. Part 6b - 1

DEP Form No. 62-210.900(1) - Form  
Effective : 3-21-96

**Emissions Unit Information Section**      2  
3.58 MW EMD Diesel Generator #9

**List of Applicable Regulations**

62-297.401, FAC - EPA Test Procedures

62-297.620, FAC - Exceptions and Approvals of Alternative Procedures and Requirements

62-204.800, FAC - Federal Regulations Adopted by Reference

62-297.400, FAC - EPA Methods Adopted by Reference

62-297.440, FAC - Supplementary Test Procedures

III. Part 6b - 2

DEP Form No. 62-210.900(1) - Form  
Effective : 3-21-96

### E. EMISSION POINT (STACK/VENT) INFORMATION

Emissions Unit Information Section 2

3.58 MW EMD Diesel Generator #9

Emission Point Description and Type :

1. Identification of Point on Plot Plan or Flow Diagram :	Figure 2, #9		
2. Emission Point Type Code :	1		
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking : (limit to 100 characters per point)			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common :			
5. Discharge Type Code :	W		
6. Stack Height :	45	feet	
7. Exit Diameter :	2.3	feet	
8. Exit Temperature :	666	°F	
9. Actual Volumetric Flow Rate :	29008	acfm	
10. Percent Water Vapor :	0.00	%	
11. Maximum Dry Standard Flow Rate :	0	dscfm	
12. Nonstack Emission Point Height :	0	feet	
13. Emission Point UTM Coordinates :			
Zone :	17	East (km) :	490.698 North (km) : 2732.707
14. Emission Point Comment :			
The UTM coordinates for this emission point are approximate (see Figures 1 and 2).			

III. Part 7a - 1

## F. SEGMENT (PROCESS/FUEL) INFORMATION

Emissions Unit Information Section 2

3.58 MW EMD Diesel Generator #9

Segment Description and Rate : Segment 1

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) :

No. 2 Fuel Oil Burned in Diesel Engine.

2. Source Classification Code (SCC) : 20100102

3. SCC Units : Thousand Gallons Burned (all liquid fuels)

4. Maximum Hourly Rate : 0.23

5. Maximum Annual Rate : 2,015.00

6. Estimated Annual Activity Factor :

7. Maximum Percent Sulfur : 0.05

8. Maximum Percent Ash :

9. Million Btu per SCC Unit : 132

10. Segment Comment :

III. Part 8 - 1



**G. EMISSIONS UNIT POLLUTANTS**  
**(Regulated and Unregulated Emissions Units)**

**Emissions Unit Information Section**      2

3.58 MW EMD Diesel Generator #9

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
1 - SO <sub>2</sub>			NS
2 - CO			NS
3 - NO <sub>X</sub>	099		EL
4 - PM			NS
5 - PM <sub>10</sub>			NS
6 - VOC			NS

III. Part 9a - 2

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**        2  

3.58 MW EMD Diesel Generator #9

**Pollutant Potential/Estimated Emissions :**      Pollutant        1  

1. Pollutant Emitted : <b>SO2</b>		
2. Total Percent Efficiency of Control :		%
3. Potential Emissions :		
1.6500000    lb/hour		7.2000000 tons/year
4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
	to	tons/year
6. Emissions Factor Reference : Mass Balance		Units :
7. Emissions Method Code :      2		
8. Calculations of Emissions :  $1000 \text{ gal/132 MMBtu} \times 7.2 \text{ lbs/gal} \times 0.05\% \text{ S} \times 2 = 0.0545 \text{ lbs/MMBtu}$ $0.0545 \text{ lbs/MMBtu} \times 30.2 \text{ MMBtu/hr} = 1.65 \text{ lbs/hr}$ $1.65 \text{ lbs/hr} \times 8760 \text{ hrs/yr} \times \text{ton}/2000 \text{ lbs} = 7.2 \text{ tpy}$		
9. Pollutant Potential/Estimated Emissions Comment :  SO2 emissions will be minimized through the use of low sulfur fuel (less than or equal to 0.05% sulfur, by weight).		

III. Part 9b - 1

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**      2  

3.58 MW EMD Diesel Generator #9

**Pollutant Potential/Estimated Emissions :**    Pollutant      2  

1. Pollutant Emitted : <b>CO</b>		
2. Total Percent Efficiency of Control :		%
3. Potential Emissions :		
5.4000000    lb/hour		23.7000000 tons/year
4. Synthetically Limited? [   ] Yes                    [X ] No		
5. Range of Estimated Fugitive/Other Emissions:		
	to	tons/year
6. Emissions Factor Reference : Emissions Testing		Units :
7. Emissions Method Code :            1		
8. Calculations of Emissions :  4988 bhp x 0.49 g/bhp-hr x lb/453.6 g = 5.4 lbs/hr 5.4 lbs/hr x 8760 hrs/yr x ton/2000 lbs = 23.7 tpy		
9. Pollutant Potential/Estimated Emissions Comment :  Emission testing results for the identical Unit #8 can be found in Attachment G.		

III. Part 9b - 2

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**        2  

3.58 MW EMD Diesel Generator #9

**Pollutant Potential/Estimated Emissions :**      Pollutant        3  

1. Pollutant Emitted : <b>NOX</b>		
2. Total Percent Efficiency of Control :	32.00	%
3. Potential Emissions :	66.0900000 lb/hour	289.5000000 tons/year
4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <div style="text-align: right; margin-right: 100px;">to</div> <div style="text-align: right;">tons/year</div>		
6. Emissions Factor Reference : Emissions Testing		Units :
7. Emissions Method Code :      1		
8. Calculations of Emissions :  4988 bhp x 6.01 g/bhp-hr x lb/453.6 g = 66.09 lbs/hr 66.09 lbs/hr x 8760 hrs/yr x ton/2000 lbs = 289.5 tpy		
9. Pollutant Potential/Estimated Emissions Comment :  Emission testing results for the identical Unit #8 can be found in Attachment G. The permitted maximum allowable emission rates for Unit #8 are 68 lbs/hr and 298 tpy.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**      2

3.58 MW EMD Diesel Generator #9

**Pollutant Potential/Estimated Emissions :**      Pollutant      4

1. Pollutant Emitted : <b>PM</b>		
2. Total Percent Efficiency of Control :		%
3. Potential Emissions :		9.2200000 tons/year
2.1000000 lb/hour		
4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		to              tons/year
6. Emissions Factor	0	Units : lbs/MMBtu
Reference : AP-42		
7. Emissions Method Code :      3		
8. Calculations of Emissions :  0.0697 lbs/MMBtu x 30.2 MMBtu/hr = 2.10 lbs/hr 2.10 lbs/hr x 8760 hrs/yr x ton/2000 lbs = 9.22 tpy		
9. Pollutant Potential/Estimated Emissions Comment :  The use of low sulfur fuel (less than or equal to 0.05% sulfur, by weight) and good combustion practices will reduce PM emissions.		

III. Part 9b - 4

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**      2

3.58 MW EMD Diesel Generator #9

**Pollutant Potential/Estimated Emissions :**      Pollutant      5

1. Pollutant Emitted : <b>PM10</b>		
2. Total Percent Efficiency of Control :		%
3. Potential Emissions :		
1.7300000 lb/hour		7.5800000 tons/year
4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
	to	tons/year
6. Emissions Factor              0		Units : lbs/MMBtu
Reference : AP-42		
7. Emissions Method Code :      3		
8. Calculations of Emissions :  0.0573 lbs/MMBtu x 30.2 MMBtu/hr = 1.73 lbs/hr 1.73 lbs/hr x 8760 hrs/yr x ton/2000 lbs = 7.58 tpy		
9. Pollutant Potential/Estimated Emissions Comment :  The use of low sulfur fuel (<= 0.05% sulfur, by weight) and good combustion practices will reduce PM10 emissions. Based on ave. actual operation of 640 hrs/yr, PM10 emissions will also be minimized.		

III. Part 9b - 5

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

**Emissions Unit Information Section**      2

3.58 MW EMD Diesel Generator #9

**Pollutant Potential/Estimated Emissions :**      Pollutant      6

1. Pollutant Emitted : <b>VOC</b>		
2. Total Percent Efficiency of Control :		%
3. Potential Emissions :		
3.0200000    lb/hour		13.2300000 tons/year
4. Synthetically Limited? [   ] Yes                [X ] No		
5. Range of Estimated Fugitive/Other Emissions:		
	to	tons/year
6. Emissions Factor                0	Units : lbs/MMBtu	
Reference : AP-42		
7. Emissions Method Code :      3		
8. Calculations of Emissions :  0.1 lbs/MMBtu x 30.2 MMBtu/hr = 3.02 lbs/hr 3.02 lbs/hr x 8760 hrs/yr x ton/2000 lbs = 13.23 tpy		
9. Pollutant Potential/Estimated Emissions Comment :		

**Emissions Unit Information Section**      2  
3.58 MW EMD Diesel Generator #9

**Pollutant Information Section**      3

**Allowable Emissions**      1

1. Basis for Allowable Emissions Code :	OTHER
2. Future Effective Date of Allowable Emissions :	
3. Requested Allowable Emissions and Units :	
4. Equivalent Allowable Emissions :	
	68.00      lb/hour      298.00      tons/year
5. Method of Compliance :	Emission controls determined as BACT (Section 3).
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) :	Maximum allowable emission rates during normal operation based on current permit conditions for Unit #8 (Attachment A).

III. Part 9c - 1



**I. VISIBLE EMISSIONS INFORMATION**  
**(Regulated Emissions Units Only)**

**Emissions Unit Information Section**      2    
3.58 MW EMD Diesel Generator #9

**Visible Emissions Limitation :** Visible Emissions Limitation      1  

1. Visible Emissions Subtype :	20
2. Basis for Allowable Opacity :	RULE
3. Requested Allowable Opacity :	
Normal Conditions :	20            %
Exceptional Conditions :	100           %
Maximum Period of Excess Opacity Allowed :	10            min/hour
4. Method of Compliance :	
EPA Method 9 or state approved equivalent method.	
5. Visible Emissions Comment :	
General emission standard 62-296.320, FAC. As per 62-210.700(1), FAC, excess emissions during startup, shutdown or malfunction shall be permitted but in no case exceed 2 hours in any 24 hour period.	

**I. VISIBLE EMISSIONS INFORMATION**  
**(Regulated Emissions Units Only)**

**Emissions Unit Information Section**     2  
3.58 MW EMD Diesel Generator #9

**Visible Emissions Limitation :** Visible Emissions Limitation     2

1. Visible Emissions Subtype :             X			
2. Basis for Allowable Opacity :             RULE			
3. Requested Allowable Opacity :			
Normal Conditions :	100	%	
Exceptional Conditions :	100	%	
Maximum Period of Excess Opacity Allowed :	60	min/hour	
4. Method of Compliance :			
Emissions monitored to not exceed 2 hrs in any 24 hr period.			
5. Visible Emissions Comment :			
As per 62-210.700(1), FAC, excess emissions during startup, shutdown, malfunction or annual low load testing requirements shall be permitted but in no case exceed 2 hours in any 24 hour period.			

III. Part 10 - 2

## K. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT TRACKING INFORMATION

Emissions Unit Information Section 2

3.58 MW EMD Diesel Generator #9

### PSD Increment Consumption Determination

#### 1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

- ☒ [ X ] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. If so, emissions unit consumes increment.
- ☐ [ ] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ [ ] The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ [ ] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ [ ] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

- ☒ The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. If so, emissions unit consumes increment.
- ☐ The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ The facility addressed in this application is classified as an EPA major source, and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. If so, baseline emissions are zero, and emissions unit consumes increment.
- ☐ None of the above apply. If so, baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3. Increment Consuming/Expanding Code :

PM : C

SO2 : C

NO2 : C

4. Baseline Emissions :

PM :

lb/hour

tons/year

SO2 :

lb/hour

tons/year

NO2 :

tons/year

5. PSD Comment :

## L. EMISSIONS UNIT SUPPLEMENTAL INFORMATION

Emissions Unit Information Section 2

3.58 MW EMD Diesel Generator #9

### Supplemental Requirements for All Applications


1. Process Flow Diagram :	Figure 3b
2. Fuel Analysis or Specification :	Attachment D
3. Detailed Description of Control Equipment :	Section 3
4. Description of Stack Sampling Facilities :	NA
5. Compliance Test Report :	NA
6. Procedures for Startup and Shutdown :	Attachment F
7. Operation and Maintenance Plan :	NA
8. Supplemental Information for Construction Permit Application :	NA
9. Other Information Required by Rule or Statue :	NA

### Additional Supplemental Requirements for Category I Applications Only

10. Alternative Methods of Operations :	NA
11. Alternative Modes of Operation (Emissions Trading) :	NA

III. Part 13 - 1


12. Identification of Additional Applicable Requirements :	NA
13. Compliance Assurance Monitoring Plan :	NA
14. Acid Rain Application (Hard-copy Required) :	
NA	Acid Rain Part - Phase II (Form No. 62-210.900(1)(a))
NA	Repowering Extension Plan (Form No. 62-210.900(1)(a)1.)
NA	New Unit Exemption (Form No. 62-210.900(1)(a)2.)
NA	Retired Unit Exemption (Form No. 62-210.900(1)(a)3.)



1" = 40'0"



FIGURE 2  
FACILITY PLOT PLAN  
MARATHON GENERATING PLANT  
FLORIDA KE S ELECTRIC COOPERATIVE  
HESSELMAN, INC.



COPYRIGHT 2000 R. W. BECK ALL RIGHTS RESERVED

DES	CIVIL REV	ELEC REV
OWN	MECH REV	STRUC REV
CK'D	APP'D	DATE


**RWBECK**

FLORIDA KEYS ELECTRIC COOPERATIVE ASSOCIATION, INC.  
MARATHON GENERATING PLANT

**FIGURE 3a**  
**UNIT No. 8 PROCESS FLOW DIAGRAM**

FILE NO	002557
W/O	0200811010001000
DWG NO	8110-SK-1.





DL 1-002557-0000110-0110-01-2.dwg 1-13-00 10:15


COPYRIGHT 2000 R. W. BECK ALL RIGHTS RESERVED

DES	CIVIL REV	ELEC REV
DWN	MECH REV	STRUC REV
CK'D	APP'D	DATE

**R-W-BECK**

FLORIDA KEYS ELECTRIC COOPERATIVE ASSOCIATION, INC.  
MARATHON GENERATING PLANT  
**FIGURE 3b**  
**UNIT No. 9 PROCESS FLOW DIAGRAM**

FILE NO	002557
W/D	0200811010001000
DWG NO	8110-SK-2.



# Department of Environmental Protection

Jeb Bush  
Governor

South District  
P.O. Box 2549  
Fort Myers, Florida 33902-2549

David B. Struhs  
Secretary

## NOTICE OF FINAL PERMIT

March 17, 1999

CERTIFIED MAIL #Z 252 620 678  
RETURN RECEIPT REQUESTED

In the Matter of an  
Application for Permit by:

Mr. Charles A. Russell  
General Manager  
Florida Keys Electric Cooperative  
Post Office Box 700377  
Tavernier, Florida 33070-0377

Re: Monroe County - AP  
FINAL Permit No.: 0870004-001-AV  
Marathon Generation Plant  
EMA - Florida Keys

Enclosed is FINAL Permit Number 0870004-001-AV for the operation of the Marathon Generation Plant located at 3421 Overseas Highway, Marathon, Monroe County, issued pursuant to Chapter 403, Florida Statutes (F.S.).

Any party to this order (permit) has the right to seek judicial review of it under Section 120.68 of the Florida Statutes, by the filing of a Notice of Appeal under Rule 9.110 of the Florida Rules of Appellate Procedure, with the clerk of the Department of Environmental Protection in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within thirty days from the date this notice is filed with the clerk of the permitting authority.

Executed in Fort Myers, Florida.

Sincerely,

Margaret F. Highsmith  
Director of  
District Management

MFH/JRS/jw

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF FINAL PERMIT (including the FINAL permit) was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on March 17, 1999 to the person(s) listed or as otherwise noted:

Charles A. Russell  
Ivan Clark, P.E.


Mary Fillingim, Air Resources Management

Ms. Carla E. Pierce, USEPA, Region 4 (INTERNET E-mail Memorandum)

Ms. Gracy Danois, U.S. EPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED,**  
on this date, pursuant to Section 120.52(7), Florida  
Statutes, with the designated agency Clerk, receipt  
of which is hereby acknowledged.

  
(Clerk)

3-17-99  
(Date)

Florida Keys Electric Cooperative Association  
Marathon Generation Plant  
Facility ID No.: 0870004  
Monroe County

Initial Title V Air Operation Permit  
FINAL Permit No.: 0870004-001-AV

Permitting Authority:  
State of Florida Department of Environmental Protection  
Post Office Box 2549  
Fort Myers, Florida 33902-2549  
Telephone: (941) 332-6975  
Fax: (941) 332-6969

Initial Title V Air Operation Permit  
FINAL Permit No.: 0870004-001-AV

Table of Contents

Section	Page Number
Placard Page .....	1
I. Facility Information .....	2
A. Facility Description.	
B. Summary of Emissions Unit ID No(s). and Brief Description(s).	
C. Relevant Documents.	
II. Facility-wide Conditions .....	3
III. Emissions Unit(s) and Conditions	
[A.] Emissions Unit(s) Brief Description(s) .....	6

Florida Keys Electric Cooperative  
Association, Inc.  
Marathon Generation Plant

FINAL Permit No.: 0870004-001-AV  
Facility ID No.: 0870004  
SIC Nos.: 4911  
Project: Initial Title V Air Operation Permit

This permit is for the operation of the eight diesel electric generators, fired with low sulfur (0.5% or less) No. 2 fuel oil. This facility is located at 3421 Overseas Highway, Marathon, Monroe County; UTM Coordinates: Zone 17, 490.7 km East; and 2732.70 km North; Latitude: 24° 42' 38" North and Longitude: 81° 05' 30" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, and 62-213. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:  
APPENDIX TV-1, TITLE V CONDITIONS

Effective Date: [March 16, 1999]

Renewal Application Due Date: [September 19, 2004]

Expiration Date: [March 16, 2004]

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION



Margaret F. Highsmith  
Director of  
District Management

MFH/JRS/jw

**Section I. Facility Information.**

**Subsection A. Facility Description.**

This facility consists of eight diesel electric generators, fired with low sulfur (0.5% or less) No. 2 fuel oil.

Based on the initial Title V permit application received June 12, 1996 this facility is a major source of air pollutants.

**Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).**

<u>E.U. ID No.</u>	<u>Brief Description</u>
001	2.0 MW Diesel Electric Generator
002	2.0 MW Diesel Electric Generator
003	3.0 MW Diesel Electric Generator
004	3.0 MW Diesel Electric Generator
005	3.0 MW Diesel Electric Generator
006	2.5 MW Diesel Electric Generator
007	2.5 MW Diesel Electric Generator
008	3.58 MW Diesel Electric Generator

Eight Diesel electric generators, fired with low sulfur (0.5% or less) No. 2 fuel oil.

*Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.*

**Subsection C. Relevant Documents.**

The documents listed below are not a part of this permit, however, are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History/ID Number Changes

These documents are on file with permitting authority:

Initial Title V Permit Application received June 12, 1996.

Construction permit for Unit 8, Issued September 12, 1997

Modification of Construction Permit, Issued April 29, 1998.

## Section II. Facility-wide Conditions.

The following conditions apply facility-wide.

1. APPENDIX TV-1, TITLE V CONDITIONS, version dated 12/02/97 is a part of this permit. {Permitting note: APPENDIX TV-1, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}
2. Not federally enforceable.] General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.  
[Rule 62-296.320(2), F.A.C.]
3. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. [Rule 62-296.320(4)(b)1., F.A.C.]
4. Prevention of Accidental Releases (Section 112® of CAA). If required by 40 CFR 68, the permittee shall submit to the implementing agency:
  - a. a risk management plan (RMP) when, and if, such requirement becomes applicable; and
  - b. certification forms and/or RMP's according to the promulgated rule schedule.[40 CFR 68]
5. [Not federally enforceable.] General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1)(a), F.A.C.]
6. The hours of operation of this facility are not limited. [Reference Construction Permit Application dated December 22, 1972 and Permit PSD-FL-237, 0870004-002-AC, Issued September 12, 1997.]
7. All equipment, pipes, hoses, lids, fittings, etc. shall be operated/maintained in such a manner as to minimize leaks, fugitive emissions, and spills of solvent materials.  
[Rule 62-296.320, F.A.C.]



8. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.  
[Rule 62-213.440, F.A.C.]

9. The permittee shall submit all compliance related notifications and reports required of this permit to the Department's South District office and to the Department's Marathon office:

Department of Environmental Protection  
South District  
Post Office Box 2549  
Fort Myers, Florida 33902-2549  
Telephone: 941/332-6975  
Fax: 941/332-6969

Department of Environmental Protection  
South District Branch Office  
2796 Overseas Highway, Suite 221  
Marathon, Florida 33050  
Telephone: 305/289-2310  
Fax: 305/289-2314

10. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency  
Region 4  
Air, Pesticide & Toxics Management Division  
Operating Permit Section  
61 Forsyth Street  
Atlanta, Georgia 30303  
Telephone: 404/562-9099  
Fax: 404/562-9095

### Construction Requirements

11. Applicable Regulations: Unless otherwise indicated in this permit, the construction and operation of the subject emission unit(s) shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of Chapter 403, F.S. and Florida Administrative Code Chapter 62-4, 62-103, 62-204, 62-210, 62-212, 62-213, 62-296, 62-297; and the applicable requirements of the Code of Federal Regulations Section 40, Part 60, adopted by reference in the Florida Administrative Code regulation [Rule 62-204.800, F.A.C.]. Issuance of this permit does not relieve the facility owner or operator from compliance with any applicable federal, state, or local permitting requirements or regulations.  
[Rule 62-210.300, F.A.C.]

Reports and Records

12. Duration: All reports and records required by this permit shall be kept for at least (5) years from the date the information was recorded. [Rule 62-4.160(14)(b), F.A.C.]

13. Emission Compliance Stack Test Reports:

- (a) A *test report* indicating the results of the required compliance tests shall be filed with the Permitting Authority as soon as practical, but no later than 45 days after the last sampling run is completed. [Rule 62-297.310(8), F.A.C.]
- (b) The *test report* shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8), F.A.C.

14. Excess Emissions Report: If excess emissions occur, the owner or operator shall notify the Permitting Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition the Department may request a written summary report of the incident. Pursuant to the New Source Performance Standards, excess emissions shall also be reported in accordance with 40 CFR 60.7, Subpart A. [Rules 62-4.130 and 62-210.700(6), F.A.C.]

### Section III. Emissions Unit(s) and Conditions.

#### Subsection A. Listing of Emissions Units

The following specific conditions apply to the emissions unit(s) listed above:

#### Essential Potential to Emit (PTE) Parameters

EMISSION UNIT NO.	SYSTEM	EMISSIONS UNITS DESCRIPTION
001#	Power	2.0 MW Diesel Electric Generator
002#	Power	2.0 MW Diesel Electric Generator
003#	Power	3.0 MW Diesel Electric Generator
004#	Power	3.0 MW Diesel Electric Generator
005#	Power	3.0 MW Diesel Electric Generator
006#	Power	2.5 MW Diesel Electric Generator
007#	Power	2.5 MW Diesel Electric Generator
008*	Power	3.58 MW Diesel Electric Generator

# Existing Emissions Unit

• New Emission Unit

#### Subsection B. Specific Conditions (Unit 008):

EMISSION UNIT NO.	SYSTEM	EMISSION UNIT DESCRIPTION
008	Power	3.58 MW Diesel Electric Generator

#### Emissions Limitations

B.1 The maximum allowable emission rates for NO<sub>x</sub> for Unit No. 008 shall not exceed 68 pounds per hour (lb/hr) and 298 tons per year (TPY) pursuant to the Best Available Control Technology (BACT) Determination. [Rule 62-212.410, F.A.C.]

B.2 In order to minimize excess emissions during startup/shutdown/malfunction this emission unit shall adhere to best operation practices. [Rule 62-210.700, F.A.C.]

#### Operational Limitations

B.3 The emission unit is allowed to operate continuously (8760 hours/year) [Rule 62-210.200, F.A.C., Definitions; Potential-to-Emit].

B.4 ~~Only No. 2 fuel oil~~ can be fired in the diesel generator. The maximum sulfur content of the No. 2 fuel oil shall ~~not exceed 0.05 percent~~ by weight.  
[Rule 62-210.200, F.A.C., Definitions: Potential-to-Emit].

B.5 The ~~maximum heat input rate to Unit No. 008 shall not exceed 30.2 million Btu per hour~~ (MMBtu/hr) [Rule 62-210.200, F.A.C., Definitions: Potential-to-Emit].

B.6 The maximum No. 2 fuel oil consumption allowed to be burned in Unit No. 008 is 2,015,000 gallons per year, which is equivalent to 8760 hours per year of operation at full load.  
[Rule 62-210.200, F.A.C., Definitions: Potential-to-Emit].

#### Test Methods and Procedures

B.7 Compliance with the allowable emission limiting standards for NO<sub>x</sub> in B.1 shall be determined by using EPA Reference Method 7E (or equivalent) as described in 40 CFR 60, Appendix A (1996, version) adopted by reference in Rule 62-204.800, F.A.C. An annual compliance test shall be performed on the unit if operated for more than 400 hours in the preceding 12 month period. [Rule 62-297.310, F.A.C.]

B.8 The fuel shall be monitored initially and annually for the sulfur content using ASTM D4294 Method (or equivalent). [Rule 62-297.440, F.A.C.]

B.9 The permittee shall maintain daily records of fuel oil consumption for the emission unit.  
[Rule 62-210.200, F.A.C.]

B.10 Compliance with the visible emission standards shall be demonstrated with EPA Reference Method 9 as described in 40 CFR 60, Appendix A (1996, version) adopted by reference in Rule 62-204.800, F.A.C. [Rule 62-297.401, F.A.C.]

#### Recordkeeping and Reporting Requirements

B.11 Two copies of the results of the emission tests for the pollutant listed in Condition B.1 for Unit No. 8 shall be submitted with forty-five days of the last sampling run to the South District office in Fort Myers. All reports shall be in a format consistent with and shall include the information in accordance with Rule 62-297.310(8), F.A.C.  
[Rule 62-297.310(8) F.A.C.]

**Test Requirements:**

B.12 Visible emissions tests are required to show continuing compliance with the standards of the Department. The test results must provide reasonable assurance that the unit is capable of compliance at the permitted maximum operating rate. Test shall be conducted in accordance with EPA Method 9 as published in 40 CFR 60, Appendix A, or State approved equivalent method. Such tests shall be conducted once per year. Results shall be submitted to the Department within 45 days after testing. The Department shall be notified at least 15 days prior to testing to allow witnessing. [Reference Rule 62-297.340(1), F.A.C.]

B.13 Test Performance Within 60 days after achieving the maximum production rate at which these emission units will be operated, but not later than 180 days after initial startup and annually thereafter, the owner or operator of this facility shall conduct performance test(s) pursuant to 40 CFR 60.8, Subpart A, General Provisions and 40 CFR 60, Appendix A. No other test method shall be used unless approval from the Department has been received in writing. Unless otherwise stated in the applicable emission limiting standard rule, testing of emissions shall be conducted with the emission unit(s) operating at permitted capacity pursuant to Rule 62-297.310(2), F.A.C. [Rules 62-204.800, 62-297.310, 62-297.400, 62-297.401, F.A.C.]

B.14 Test Procedures shall meet all applicable requirements of the Florida Administrative Code Chapter 62-297. [Rule 62-297.310, F.A.C.]

B.15 Test Notification: The owner or operator shall notify the Permitting Authority in writing at least *(30) days* (initial) and *15 days* (annual) prior to each scheduled compliance test to allow witnessing. The notification shall include the compliance test date, place of such test, the expected test time, the facility contact person for the test, and the person or company conducting the test. The (3) or (15) day notification requirement may be waived at the discretion of the Department. Likewise, if circumstances prevent testing during the test window specified for the emission unit, the owner or operator may request an alternate test date before the expiration of this window. [Rule 62-297.310 and 40 CFR 60.8, F.A.C.]

B.16 Special Compliance Tests: When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained In Rule 62-204, 62-210, 62-212, 62-296, and 62-297, F.A.C. or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the facility to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions units and to provide a report on the results of said tests to the Permitting Authority. [Rule 62-297.310(7)(b), F.A.C.]

B.17 Stack Testing Facilities: The owner or operator shall install stack testing facilities in accordance with Rule 62-297.310(6), F.A.C.

B.18 Exceptions and Approval of Alternate Procedures and Requirements: An Alternate Sampling Procedure (ASP) may be requested from the Bureau of Air Monitoring and Mobil Sources of the Florida Department of Environmental Protection in accordance with the procedures specified in Rule 62-297.620 F.A.C.

B.19 Operating Rate During Testing: Unless otherwise stated in the applicable emission limiting standard rule, testing of emission shall be conducted with the emission unit operation at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emission unit operation is limited to 110 percent of the test load until a new test is conducted. Once the unit is so limited, operation at high capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rule 62-297.310(2) and (3), F.A.C.]

**Subsection C. Specific Conditions (Units 001-007)**

The following Specific Conditions apply to the following emission units:

EMISSION UNIT NO.	SYSTEM	EMISSIONS UNITS DESCRIPTION
001#	Power	2.0 MW Diesel Electric Generator
002#	Power	2.0 MW Diesel Electric Generator
003#	Power	3.0 MW Diesel Electric Generator
004#	Power	3.0 MW Diesel Electric Generator
005#	Power	3.0 MW Diesel Electric Generator
006#	Power	2.5 MW Diesel Electric Generator
007#	Power	2.5 MW Diesel Electric Generator

**Emission Limitation**

C.1 In order to minimize excess emissions during startup/shutdown/malfunction this emission unit shall adhere to best operating practices. [Rule 62-210.700, F.A.C.]

**Operation Limitations**

C.2 The combined maximum heat input to Units No. 001-007 shall not exceed 187 MMBtu/hr while firing No. 2 fuel oil. [Rule 62-210.200, F.A.C., Definitions: Potential-to-Emit]

C.3 The existing Units No. 001-007 operations shall be limited to either 4380 hours per year per unit or to a total fuel oil consumption of 6,200,000 gallons per year for all seven units, whichever limit is more restrictive. [Rule 62-210.200, F.A.C., Definitions: Potential-to-Emit]

C.4 No. 2 fuel oil can be fired in the diesel generators 001-007. The maximum sulfur content of the No. 2 fuel oil shall not exceed 0.50 percent, by weight. [Rule 62.210. F.A.C., Definitions: Potential-to-Emit]

**Test Methods and Compliance Procedures**

C.5 The No. 2 fuel oil shall be monitored initially and annually for the sulfur content using ASTM D4294 Method (or equivalent). [Rule 62-297.440, F.A.C.]

C.6 The permittee shall maintain daily records of the fuel oil consumption for the emission units. [Rule 62-210.200, F.A.C., Definitions: Potential-to-Emit]

C.7 Compliance with the visible emission standard shall be demonstrated once per year with EPA Reference Method 9 as described in 40 CFR 60, Appendix A (1996, version) adopted by reference in 62-204.800, F.A.C. [Rule 62-297.3310, F.A.C.]

## Appendix H-1, Permit History/ID Number Changes

Mr. Charles A. Russell, General Manager  
Florida Keys Electric Cooperative Association, Inc.  
Page 11

FINAL Permit No.: 0870004-001-AV  
Facility I D No. 0870004

### Permit History (for tracking purposes):

<u>E.U. ID No.</u>	<u>Description</u> <u>Expiration Date</u>	<u>Extended Date</u> <sup>1, 2</sup>	<u>Permit No.</u> <u>Revised Date(s)</u>	<u>Issue Date</u>
1 - 5	01-29-78		AO44-1140	01-29-73
1 - 5	06-19-83		AO44-5072	06-19-78
1	07-08-88		AO44-69510	07-08-83
2	07-08-88		AO44-69511	07-08-83
3	07-08-88		AO44-69512	07-08-83
4	07-08-88		AO44-69513	07-08-83
5	07-08-88		AO44-69514	07-08-83
3	04-25-93		AO44-147446	04-25-88
4	04-25-93		AO44-147447	04-25-88
5	04-25-93		AO44-147448	04-25-88
3 - 5	05-27-98		AO44-227958	05-27-93
6 - 7	12-01-73		AC532	12-22-72
6 - 7	09-13-78		AO44-2158	09-13-73
6 - 7	01-11-84		AO44-5516	01-11-79
6 - 7	03-07-89		AO44-82705	03-07-84
1 - 2	11-22-89		AC44-147170	11-22-88
6 - 7	03-30-94		AO44-161577	03-30-89
1, 2, 6, 7	08-14-94		AO44-167945	08-14-89
1, 2, 6, 7	08-15-99		AO44-252749	08-15-94
8	01-31-99		0870004-002-AC PSD-FL-237	09-12-97

### Notes:

Unit 1 Retired 01-88  
Unit 2 Retired 02-88

1 - AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

2 - AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96.  
{Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}



**ATTACHMENT B**  
**MARATHON GENERATION PLANT ACTUAL OPERATING**  
**HOURS AND FUEL CONSUMPTION**  
**1992-1999**

---

**MARATHON GENERATION PLANT**

**OPERATING HOURS AND FUEL CONSUMPTION**

**1992 - 1999**

<b>YEAR<sup>1</sup></b>	<b>TOTAL RUNNING HOURS</b>	<b>FUEL CONSUMPTION GALLONS</b>
1992	2,155.0	344,527
1993	681.0	105,090
1994	496.0	74,277
1995	611.0	80,673
1996	415.2	66,936
1997	1,801.9	287,925
1998	757.0	116,600
1999	894.2	145,099
<b>AVERAGE<sup>2</sup></b>	642.4	

<sup>1</sup> Abnormal conditions, which caused increased annual operation at the Marathon Plant, occurred during the following years:

- 1992 - Hurricane Andrew
- 1997 - Power Transformer Failed
- 1998 - Various storms
- 1999 - Various storms

<sup>2</sup> The average annual operating hours were calculated for 1992 through 1999, with the exception of 1992 and 1997, due to the extremely high usage and abnormal conditions during these two years.

ATTACHMENT C  
PRECAUTIONS TO PREVENT EMISSIONS OF  
UNCONFINED PARTICULATE MATTER

---

## MARATHON GENERATION PLANT

### PRECAUTIONS TO PREVENT EMISSIONS OF UNCONFINED PARTICULATE MATTER

The only potential source of unconfined particulate matter emissions associated with the operation of the facility are fugitive emissions from vehicular traffic providing fuel deliveries. Paved fuel delivery areas and roads are used as precautions taken to prevent and control unconfined emissions of particulate matter.



Florida Keys Electric Cooperative Assoc. Inc.  
3421 Overseas Highway  
Generating Plant  
Marathon, FL 33050

1/11/00

Reference: We show the following data for diesel fuel samples received on 1/7/00.

TOTAL P.03

Lab No.	Source	Date sampled	Sulfur content % MASS (D1266)
36087T	Tank 2	Not stated	0.04
36088T	Tank 3	Not stated	0.05

*Carl E. Johnson*  
Carl E. Johnson, President

ATTACHMENT E  
DETAILED DESCRIPTION OF CONTROL  
EQUIPMENT FOR UNIT #8

---

## MARATHON GENERATION PLANT

### DETAILED DESCRIPTION OF CONTROL EQUIPMENT FOR UNIT #8

The air pollution control considered as Best Available Control Technology (BACT) for Unit #8 consists of a combination of fuel injection timing retardation and 4-pass aftercooler with a separately cooled aftercooler circuit. Retarding the fuel injector timing reduces the firing pressure, which results in a 20 percent reduction of NO<sub>x</sub> emissions. Additionally, through separately cooling the 4-pass aftercooler circuit, the combustion air density increases thus improving the ratio of air to fuel and reducing the output of NO<sub>x</sub> by an additional 10 to 20 percent.

**ATTACHMENT F**  
**PROCEDURES FOR STARTUP AND SHUTDOWN**

---



MARATHON GENERATION PLANT  
PROCEDURES FOR STARTUP AND SHUTDOWN

Each of the eight existing diesel engines, as well as the proposed Unit #9, used for generation will be constantly kept at operating temperatures through the use of immersion heaters and electrically heated oil filter units. This practice allows each engine to come on line with an absolute minimum of idle, or warm-up time. Further, engines will be shut down completely when the requirements for electrical generation are no longer present.

Regularly scheduled inspection and maintenance of each engine provides both economical and efficient operation.

ATTACHMENT G  
EMISSIONS TESTING RESULTS

---

**BEST AVAILABLE CONTROL TECHNOLOGIES ANALYSIS**

---

**3.1 INTRODUCTION AND BACT APPROACH**

Among the requirements of New Source Review under Prevention of Significant Deterioration (PSD) regulations is a Best Available Control Technology (BACT) analysis to demonstrate that the control of air contaminant emissions from a proposed source will represent BACT. BACT is specifically determined for each PSD affected proposed source on a case-by-case basis. USEPA policy requires that the BACT analysis utilize a "top-down" procedure which requires identifying and implementing the most stringent, technically feasible control for each applicable PSD regulated pollutant unless economic, energy or environmental impacts are shown to be excessive. For example, if the costs associated with the most stringent, technically feasible control for a pollutant are shown to be excessive, the next most stringent level of control must be analyzed to determine economic, energy and environmental impacts. This progression is continued until the most effective, technically feasible control is identified for which the impacts are not excessive (USEPA, 1990). Therefore, in conformance with USEPA policy requiring a top-down analysis, the basic approach of the analysis presented herein is to: 1) determine the applicability of each PSD regulated pollutant; 2) identify available pollution control technologies for pollutants which BACT is required and review specific BACT determinations for similar recent projects; 3) eliminate pollution control technologies which are shown to be not technically feasible; and 4) evaluate the effectiveness of feasible technologies.

The Project consists of the addition of one EMD 20-710G4B high-speed diesel engine to the existing Marathon Power Plant. The diesel engine, which will be used for electric generation, is rated at 3,580 (gross) kW output with a HHV heat input of 30.2 million Btu per hour (MMBtu/hr) and fueled on No. 2 low sulfur (less than or equal to 0.05 percent sulfur, by weight) fuel oil. The annual emission rates for the Project at 100 percent base load with and without pollution control are presented in Table 3-1.

Unit 9's emissions indicate that the Project is significant with respect to PSD thresholds for one regulated pollutant ( $\text{NO}_x$ ) which, therefore, requires a BACT determination. A BACT analysis is also required for  $\text{PM}_{10}$ , due to emissions from the proposed Project slightly exceeding the PSD threshold when combined with emissions from the existing PSD source (Unit 8), as shown in Table 3-1. However, through the use of good combustion controls and the exclusive use of low sulfur fuel (less than or equal to 0.05 percent sulfur, by weight), total  $\text{PM}_{10}$  emissions from Units 8 and 9 will most likely be less than the PSD threshold of 15 tpy.

---

Additionally, these Units are 'peakers' and total operation at Marathon has averaged only 640 hrs/yr during non-hurricane or otherwise typical years.

A brief introduction explaining the mechanisms of emissions formation is provided for a pollutant requiring a BACT determination. Applicable technologies are then identified for that pollutant and individually reviewed for their feasibility for application to the Project. Once a particular pollution control is determined feasible for the Project, an analysis is conducted to evaluate the economic, energy, and environmental impacts associated with its use. Annual potential emissions are used to determine the cost effectiveness of a given control. The most effective, technically feasible control option for which the impacts are not excessive is then identified as BACT for that significant pollutant.

Specifics on the various evaluation factors used in the BACT analysis are presented below.

### **3.1.1 TECHNOLOGY IDENTIFICATION**

Review of the USEPA's RACT/BACT/LAER Clearinghouse (RBLC) is used as part of the analysis to determine appropriate pollution control technologies. The RBLC gives access to some of the latest pollution control technologies employed and their control levels for previously permitted similar projects. These specific determinations for similar recent projects were analyzed for applicability and comparison to the Project.

### **3.1.2 TECHNOLOGY FEASIBILITY**

Control methods and devices are listed in descending order from most stringent to least stringent and, starting with the most stringent, are reviewed for their technical feasibility. Those that are found to be technically infeasible are identified and the basis for the finding is discussed. Technically infeasible controls are then excluded from further analysis and the remaining control options are evaluated. From this analysis, the most stringent, technically feasible control option is identified.

### **3.1.3 IMPACT ANALYSIS**

Each option is evaluated with respect to its economic, energy and environmental impacts, starting with the most stringent feasible control. The first acceptable option is then determined as BACT.

#### **3.1.3.1 ECONOMIC ANALYSIS**

The economic impact analyses presented herein compare the total capital and operating costs of feasible pollution control technologies in terms of their cost effectiveness (dollars per ton of pollutant removed). Also, in accordance with the USEPA top-down procedure, in addition to calculating the top-down overall cost effectiveness of a given control option, incremental cost effectiveness can be

calculated in comparing two technically feasible control options. As such, the incremental cost effectiveness of a pollution control alternative is examined in combination with the total cost effectiveness in order to justify elimination of a control option. Finally, note that the analyses presented utilize the cost estimating methodology outlined in the most recent USEPA guidance document on this subject (USEPA, 1990).

Capital costs include purchase, installation costs, engineering fees, and other expenses of all required components, which comprise the pollution control system. The purchased equipment costs represent the delivered costs of the basic control equipment, auxiliary equipment, and instrumentation. Auxiliary equipment consists of all structural, mechanical, and electrical components required for the operation of the control device. Auxiliary equipment costs reflect vendor data provided for this project. Instrumentation and controls are usually not included in the basic equipment cost. The purchased equipment costs which include the FOB equipment cost, auxiliaries, instrumentation and controls, and freight, are then the basis for determining the direct and indirect installation costs.

Installation costs consist of both direct and indirect expenditures. Direct expenditures include materials and labor for site preparation, foundation, structural steel erection, piping, electrical, painting, and ancillary facilities. Indirect costs include contractor's engineering and supervision, construction and field expenses, construction fees, contingencies, and start-up and performance tests. Direct installation costs are expressed as a function of the basic equipment cost, based on average installation requirements of typical systems. Indirect costs are designated as a percentage of the direct costs (purchased equipment costs plus the direct installation costs) of the system. The factors are based on the assumption that the installation is performed by an outside contractor and not by plant personnel.

The capital cost estimation factors utilized in this analysis are shown in Table 3-2. These costs are comprised of the delivered equipment cost for the basic control equipment and all auxiliary equipment, plus direct and indirect installation costs. The capital cost estimates are based on information obtained from vendors, USEPA Office of Air Quality Planning and Standards (OAQPS) guidance, and experience with similar systems.

Annual operating costs consist of the financial requirements to operate the control system including overhead, maintenance, labor, raw materials, utilities, and other expenses incurred over the life of the project as a result of the application of the control technology. Table 3-3 depicts the annualized cost factors, which are comprised of the direct costs of materials and labor for maintenance and operation, utilities and waste disposal, as well as the indirect charges including plant overhead, general administration, insurance and capital recovery.

The cost effectiveness of a given pollution control system is based on an annualized cost of the system and its annual pollutant reduction. It is

determined by dividing the total annualized cost of the alternative by the tons of pollutant removed by that alternative per year. The basis for determining the uncontrolled tons, control effectiveness, and controlled tons of each pollutant are presented within each respective section of this BACT analysis. Table 3-1 presents estimated "realistic upper-bound" annual emissions for the Project with uncontrolled emissions and with emissions controlled using the proposed BACT. Realistic upper-bound annual emissions for the Project were calculated based on 8,760 hours of operation at 100 percent baseload and actual site conditions.

### 3.1.3.2 ENERGY ANALYSIS

Energy impacts associated with pollution control can generally be translated into economic costs. For example, an energy impact associated with a particular pollution control system may consist of a fuel penalty due to an increased heat rate. Consequently, the cost of the requirement for increased fuel consumption can be calculated and added to the economic analysis as an associated operating cost. Therefore, the energy impact analysis for each pollution control alternative presented herein is included as part of the economic analysis and, consequently, included in the operating cost component of each control system evaluated.

### 3.1.3.3 ENVIRONMENTAL ANALYSIS

An environmental analysis is performed for each feasible pollution control alternative to evaluate adverse environmental impacts resulting from application of the technology. As such, the environmental impacts associated with each feasible pollution control alternative for each pollutant are presented to determine whether the impacts are excessive and should preclude use of the control technology.

### 3.1.4 CONCLUSION

The pollution control technology chosen as representing BACT for the Project is provided for each PSD regulated pollutant which exceeds its respective PSD threshold, accompanied by a summary of supporting reasons. Additionally, should there be a more stringent pollution control technology that was not chosen as BACT for the evaluated pollutant, a summary of the findings eliminating it from consideration as BACT is provided.

## 3.2 BACT FOR NITROGEN OXIDES

### 3.2.1 INTRODUCTION

NO<sub>x</sub> is formed in combustion sources by the thermal oxidation of nitrogen in the combustion air and the reduction and subsequent oxidation of fuel bound nitrogen. The predominant mechanism for NO<sub>x</sub> formation in the diesel engine is through thermal oxidation of nitrogen in the combustion air. The rate of formation of the thermal NO<sub>x</sub> is a function of the residence time, free oxygen,

turbulence, and peak flame temperature. Primary control techniques for thermal NO<sub>x</sub> are aimed at minimizing one or more of these variables. Other secondary control methods, involving post-combustion techniques, remove the NO<sub>x</sub> from the exhaust gas stream.

### 3.2.2 TECHNOLOGY IDENTIFICATION

NO<sub>x</sub> limits for diesel engines range from approximately 50 ppm to 1500 ppm, with the majority being between 500 ppm and 1000 ppm. The low end of the range (50-ppm) corresponds to medium or high speed diesels fired on gas and equipped with SCR, while the high end of the range (1,500 ppm) corresponds to uncontrolled, low-speed diesels. The mid-range corresponds to medium-speed diesels with primary NO<sub>x</sub> control techniques such as timing retardation, water emulsion (or injection), or a combination thereof.

Review of the RBLC database covering the past eight years resulted in the identification of over 30 stationary diesel engines fired on liquid fuel for which BACT determinations have been made and PSD applications approved. Control techniques identified in the RBLC included fuel injection timing retardation, water injection, lean combustion, intake air cooling, turbocharger with intercooling or aftercooling, and selective catalytic reduction (SCR). The engines that were identified and reviewed in the RBLC database, and are fired primarily on diesel fuel, range from 0.3 MW to 7.86 MW.

It should be noted that when identifying BACT determinations in the RBLC or elsewhere, care must be exercised in comparing emissions limits among the various projects. Emissions from the various types of diesels (low, medium, and high speed) vary widely. Therefore, small, high-speed diesels fired on low sulfur fuel oil should be compared to other small, high-speed diesels fired on low sulfur fuel oil, medium-speed diesels to other medium-speed diesels, and so on. It would not be prudent to use limits given for one diesel type to set limits for another.

### 3.2.3 TECHNOLOGY FEASIBILITY

NO<sub>x</sub> control technologies available for diesel engines, from the most stringent to the least stringent level of control, are identified as follows:

1. Selective Catalytic Reduction (SCR)
2. Ignition Timing Retardation
3. Water Injection
4. Engine Performance Improvements (Inlet Air Cooling, Turbocharger with Intercooling or Aftercooling)

These alternatives are described and evaluated below for their respective feasibility as BACT.

### 3.2.3.1 SELECTIVE CATALYTIC REDUCTION

The SCR technology has been applied primarily to natural gas-fired combined-cycle combustion turbine systems. In SCR systems, ammonia is injected into the flue gas upstream of the catalyst bed where  $\text{NO}_x$  and ammonia react on the catalyst surface, forming elemental nitrogen and water. There are several types of commercially available SCR catalysts, including platinum-based, vanadium-based, and zeolite and ceramic molecular sieve-based catalysts. Each catalyst exhibits advantages and disadvantages in terms of operating temperature, ammonia/ $\text{NO}_x$  ratio, and optimum oxygen concentration. The function of the catalyst is to effectively lower the activation energy of the  $\text{NO}_x$  reduction reaction. Thus, the reaction is allowed to proceed under cooler conditions than normally required.

The rate at which the reactions proceed that reduce  $\text{NO}_x$  to molecular nitrogen and water are, even on the catalyst surface, a function of reactant concentration and temperature. A characteristic common to all types of SCR is the narrow "window" of temperatures in which the reactions are optimized. The optimum temperature range for operating an SCR system is between 500°F - 850°F. Operation above the optimum temperature could result in the formation of  $\text{NO}_x$  from ammonia as well as damage to the SCR system. Operation below the minimum temperature results in no substantial reduction of  $\text{NO}_x$ .

The SCR process typically employs a relatively low ammonia to  $\text{NO}_x$  stoichiometric ratio (a molar ratio of between 1.0 to 1.2). In order for this system to be effective as a pollution control technique, the injected ammonia must be carefully balanced with the  $\text{NO}_x$  concentration in the exhaust gas stream. Too much ammonia results in unreacted ammonia being discharged. This phenomenon is referred to as "ammonia slip." As the  $\text{NO}_x$  reduction is a complex function of both the temperature and reactant concentration, the proper control of an SCR unit is complex because of the precarious balance that must be achieved and maintained.

The SCR process is subject to loss of catalyst activity over time. Since the catalyst itself is the most costly part of the process, steps to prevent catalyst deactivation must be taken to improve economical operation of the process. There is no simple method of monitoring catalyst activity, rather ammonia use and corresponding  $\text{NO}_x$  emissions must both be monitored. Catalyst deactivation occurs through either physical masking or chemical poisoning. Physical masking is generally the result of either prolonged exposure to excess temperature or masking of the catalyst due to entrainment of particulate matter, whereas chemical poisoning is caused by the irreversible reaction of the catalyst with a contaminant of the gas stream and is a permanent condition. The presence of heavy metals in a gas stream is often responsible for the permanent deactivation of a catalyst through poisoning. It is typical for catalyst suppliers to assign a two to three year lifetime to catalyst systems employed on gas turbines when natural gas is the fuel. It is expected that the catalyst life with diesel operation on fuel oil



firing will be reduced due to particulate, sulfur and trace metals in the fuel. Thus, catalyst replacement cost would be prohibitive.

Virtually all of the recent experience with the application of SCR to combustion sources has been associated with natural gas-fired combined-cycle installations with the SCR system installed in the Heat Recovery Steam Generator (HRSG). Review of the RBLC database indicates that only one facility has installed SCR on small diesel engines. SCR was determined as BACT for the Philadelphia Northeast Water Treatment Plant due to a local ordinance that set strict emission limits without regard to cost.

In conclusion, SCR is not a technically feasible option for the Project due to the high costs and limited application on small, high-speed diesel engines. SCR evaluations for combined-cycle, gas-fired installations typically have cost effectiveness values of approximately \$1,500/ton. Significantly higher cost effectiveness would be expected on high-speed diesel engines due to lack of economies of scale for relatively low flue gas flow rates and expected higher frequency of catalyst replacement. Additionally, there are significant potential negative environmental impacts associated with SCR catalyst materials and reagents (as described in Section 3.2.4.1).

### 3.2.3.2 IGNITION TIMING RETARDATION

Ignition Timing Retardation (ITR) is accomplished in a diesel engine by delaying the injection of the fuel into the compressed air in the cylinder. The result is that combustion occurs at lower peak pressures and temperatures. In addition, the duration of the peak pressure and temperatures is shorter than for standard timing of the fuel injection. The lower peak flame temperature and the shorter exposure reduces the formation of  $\text{NO}_x$ . However, as a result of the reduction in peak pressures and temperatures, timing retardation reduces maximum power output and engine efficiency while increasing particulate emissions and fuel consumption. Vendor data indicates reduction of  $\text{NO}_x$  concentrations by approximately 20 percent with four degrees of injection retard on small, high-speed, oil-fired diesels with a concomitant 1.5 percent increase in fuel consumption.

### 3.2.3.3 WATER INJECTION

This  $\text{NO}_x$  control method sprays water into the mixing chamber. As the water evaporates, considerable heat from the air stream is absorbed. Through decreasing inlet air temperature, the conversion of  $\text{N}_2$  and  $\text{O}_2$  into  $\text{NO}_x$  during the combustion process is affected. However, this control method appears to have limited applicability in Florida due to climate constraints. Relative humidity on Vaca Key is typically between 75 percent and 85 percent. At these high levels of humidity, significant evaporative cooling is not physically possible. Additionally, water injection is found to be the most effective on peaking units during cold ambient temperatures. The annual minimum temperature on Vaca

Key is approximately 65°F. Therefore, water injection is not considered further in this BACT analysis due to limited effectiveness.

### 3.2.3.4 ENGINE PERFORMANCE IMPROVEMENTS

Various engine performance improvements, such as inlet air cooling or a combination of a turbocharger and intercooling or aftercooling, reduce the temperature of the charge air entering the cylinder, thereby also reducing the maximum compressed air temperature. This reduces the peak combustion temperature and thus reduces the rate of NO<sub>x</sub> formation. Vendor data suggests NO<sub>x</sub> reductions of 10 percent with a decrease of 20°F to 25°F in the charge air temperature. Additionally, reductions in PM emissions (approximately 10 percent) and fuel consumption (approximately 0.5 percent) are typical of this control method. The reduced charge air temperature also allows for an increase in power, as more air enters the cylinder due to its increased density.

### 3.2.4 IMPACT ANALYSIS

The most stringent technically feasible control technologies were found to be:

- 4° ignition timing retardation; and
- 4-pass aftercooler with a separate aftercooler circuit.

These controls were then evaluated with respect to their economic, energy, and environmental impacts. Additionally, it was determined that a combination of these two technologies will significantly reduce NO<sub>x</sub> emissions while maintaining PM emissions and fuel consumption at an acceptable level. Although SCR has been shown to be technically infeasible for the Project and has been removed from further consideration for BACT, the adverse environmental impacts associated with the use of SCR were considered noteworthy and are, therefore, also described below.

#### 3.2.4.1 SELECTIVE CATALYTIC REDUCTION

##### 3.2.4.1.1 ENVIRONMENTAL ANALYSIS

In addition to being technically infeasible for the Project, there are significant adverse environmental impacts associated with the use of SCR including disposal of spent catalyst, transportation, storage and handling of ammonia, and emissions of unreacted ammonia, referred to as ammonia slip.

The SCR catalyst material will be subject to loss of activity and poisoning and must be periodically replaced. The disposal of catalyst is complicated by the fact that many SCR catalysts contain various heavy metals including titanium and vanadium, which are hazardous wastes. Thus, use of SCR entails hazardous waste handling and disposal, which is an environmental burden and potential liability. It is expected that if SCR were applied to the Project, the catalyst would require frequent replacement.

An additional adverse environmental impact associated with SCR is the transportation of the ammonia ( $\text{NH}_3$ ) to the site, and the subsequent on-site storage. Ammonia is a designated "Extremely Hazardous Substance" (EHS). Under federal regulations, the facility would most likely exceed certain thresholds for on-site storage of ammonia, thus requiring the preparation of risk assessments and management plans for the prevention of accidental releases.

Additionally, as with any chemical process, not all of the reactants will be consumed in the  $\text{NO}_x$  reduction reactions. Emissions of unreacted ammonia (ammonia slip) are thus another adverse environmental consideration in the application of SCR.

### **3.2.4.2 IGNITION TIMING RETARDATION AND AFTERCOOLER WITH SEPARATELY COOLED AFTERCOOLER CIRCUIT**

#### **3.2.4.2.1 ECONOMIC AND ENERGY ANALYSIS**

Tables 3-4 and 3-5, respectively, present the capital and annualized cost for the combined timing retard and aftercoolers control option. The costs are itemized to include capital cost of equipment required such as installation, structural support and instrumentation. Direct and indirect operation costs include operating personnel, maintenance, replacement parts, energy penalties and utilities. The total capital cost is estimated at \$351,300 and the total annualized cost is estimated at \$218,100. The top-down cost effectiveness ratio for this control option is estimated at \$1,600 per ton of  $\text{NO}_x$  removed. This ratio is considered high, but cost effective, when considered against other proposed controls.

#### **3.2.4.2.2 ENVIRONMENTAL ANALYSIS**

Ignition timing retardation ( $4^\circ$ ) will decrease  $\text{NO}_x$  emissions by approximately 20 percent. However, other environmental impacts associated with timing retard include increased PM emissions and fuel consumption. A 20 to 25 percent increase of PM emissions is caused both by cooler combustion conditions and by decreased engine efficiency. The decrease in efficiency means that fuel must be burned at a higher rate to obtain the same amount of power, thus causing an approximate 1.5-percent increase in fuel consumption. In turn, the rate of certain pollutant emissions increases.

However, with the addition of a 4-pass aftercooler with a separate aftercooler circuit, PM emissions will be reduced along with fuel consumption. According to vendor data, the 4-pass aftercooler will reduce PM emissions by about 10 percent and fuel consumption by about 0.7 percent. Additionally,  $\text{NO}_x$  emissions will decrease by 10 percent with the 4-pass aftercooler. The separate aftercooling circuit will decrease PM by approximately another 10 percent and fuel consumption by 0.5 percent, while also reducing  $\text{NO}_x$  emissions by 10 percent.

The combination of these two technologies will work together to effectively minimize environmental impacts. However, emission reductions due to the

chosen controls are not cumulative, and must be considered 'step-by-step'. With the combination of control technologies, NO<sub>x</sub> emissions will be reduced by approximately 35 percent. An increase or decrease of PM emissions due to the control devices is considered negligible when combined with additional combustion controls, such as low sulfur fuel (less than or equal to 0.05 percent sulfur, by weight) and good combustion practices.

### 3.2.5 CONCLUSION

The most stringent control technology option for NO<sub>x</sub> associated with combustion source operation is the SCR system. SCR should not be considered BACT for the Project because it is currently not technically feasible, as:

1. No. 2 fuel oil contains sulfur and trace elements that will likely mask and/or poison the catalyst, resulting in prohibitive replacement cost.
2. The only SCR on a small, high-speed diesel engine in the United States that we are aware of is found at the Philadelphia Southwest Water Treatment Plant. This facility was required to implement stringent controls, due to strict emissions limits, without regard to cost.
3. In addition to being technically infeasible due to high cost and limited application for the Project, SCR includes adverse environmental impacts associated with ammonia slip, ammonia transportation, handling and storage, and disposal, which are greater than for other control alternatives.

The next most stringent control technology after SCR is a combination of timing retard and aftercoolers. This technology should be viewed as representing BACT for NO<sub>x</sub> control because:

1. Its cost effectiveness ratio of \$1,600 per ton is within high, but reasonable, limits when compared to similar units and similar applications.
2. The 66 lb/hr emission level has been demonstrated in similar applications and is consistent with similarly designed and operated units that have been recently permitted.
3. Timing retard combined with an aftercooler and separate aftercooler circuit has minimal adverse environmental impacts. NO<sub>x</sub> control to 66 lb/hr gives adequate reduction without increasing other pollutant emissions to unacceptable levels.

## 3.3 BACT FOR PARTICULATE MATTER

### 3.3.1 INTRODUCTION

Emissions of particulate matter are primarily the result of fuel impurities and byproducts of incomplete combustion. Primary particulate matter control consists of burning clean fuel oil in combination with proper engine design,

operation and maintenance. Post-combustion controls for particulate matter include cyclones, electrostatic precipitators, baghouses, and scrubbers.

### 3.3.2 CONCLUSION

A review of the RBLC and other projects with which we are familiar indicates that no post-combustion particulate control systems such as electrostatic precipitators or baghouses have been employed on diesel engines. The high gas velocities and volumetric flow rates, along with the high combustion efficiency, associated with diesel engines make the application of post-combustion particulate control devices technically infeasible. Rather, particulate emissions from diesel engines are controlled through combustion controls via proper engine design, operation and maintenance. With respect to combustion controls, there are no significant economic, energy, or environmental impacts. Therefore, BACT for particulate matter should be determined to be the minimum emission rate achievable through proper engine design, operation and maintenance. Additionally, the Project will exclusively burn low sulfur fuel oil (less than or equal to 0.05 percent sulfur, by weight). This fuel restriction will contribute to limiting the emissions of particulates.

**TABLE 3-1  
POLLUTANT SUMMARY  
BASELINE ANNUAL EMISSIONS<sup>(1)</sup>**

<b>Pollutant</b>	<b>Unit 9 Uncontrolled (TPY)</b>	<b>Unit 9 Controlled (TPY)</b>	<b>Combined Emissions For Units 8 and 9 (TPY)</b>	<b>PSD Significance Level<sup>(2)</sup> (TPY)</b>
NO <sub>x</sub> (as NO <sub>2</sub> )	423	289.5 <sup>(3)</sup>	579.0	40
CO	23.7 <sup>(4)</sup>		47.4	100
SO <sub>2</sub>	7.2		14.4	40
PM	9.22		18.44	25
PM <sub>10</sub> <sup>(5)</sup>	7.58	<7.58	15.2	15

(1) All emissions based on Units 8 and 9 operating at 100 percent load and 8,760 hours per year.

(2) From 40 CFR 52.21(b)(23).

(3) The controlled NO<sub>x</sub> emissions are based on emissions tests for the identical Unit 8. These results indicate a 32 percent efficiency of control.

(4) CO emissions are based on emissions tests for the identical Unit 8.

(5) The use of low sulfur fuel (less than or equal to 0.05% sulfur, by weight) and good combustion practices will decrease PM<sub>10</sub> emissions. Additionally, based on average operating hours of 640 hours per year, actual PM<sub>10</sub> emissions for each unit (8 and 9) will be further reduced.

TABLE 3-2 CAPITAL COST ESTIMATION FACTORS	
DIRECT COSTS	FACTOR
1) Purchased Equipment	
a) Basic Equipment	Vendor Data
b) Auxiliaries	Vendor Data
c) Instrumentation	$0.10(1a + 1b)$
d) Structural Support	$0.10(1a + 1b)$
e) Freight	$0.05(\text{sum } 1a \dots 1d)$
2) Direct Installation	$(0.25 \text{ to } 0.30)(\text{sum } 1a \dots 1e)$
Total Direct Cost (TDC)	(1) + (2)
INDIRECT COSTS	FACTOR
3) Indirect Installation	
a) Engineering	$(0.05 \text{ to } 0.1)(\text{TDC})$
b) Construction and Field Expenses	$0.1(\text{TDC})$
c) Construction Fee	$0.05(\text{TDC})$
d) Contingencies	$0.2(\text{TDC})$
4) Other Indirect Costs	
a) Start-up and Testing	$0.01(\text{TDC})$
Total Indirect Costs (TIC)	(3) + (4)
TOTAL CAPITAL COSTS	TDC + TIC

**TABLE 3-3**  
**ANNUALIZED COST ESTIMATION FACTORS**

<b>DIRECT OPERATING COSTS</b>	<b>FACTOR</b>
1) Operating Labor and Supervisor	Labor: \$40.00/man-hour Supervisor: 15% of Operating Labor
2) Maintenance	5% of Direct Costs
3) Replacement Parts	3% of Direct Costs
4) Utilities	
a) Electricity	\$0.07/kW-hr
c) Fuel Penalty	
<b>INDIRECT OPERATING COSTS</b>	<b>FACTOR</b>
6) Overhead	30% of Labor + 12% Maintenance
7) Property Tax	1% Total Capital Cost
8) Insurance	1% Total Capital Cost
9) Administration	2% Total Capital Cost
10) Capital Recovery	Capital Recovery x TDC
Total Annualized Cost	Sum ( 1 . . . 10)
<b>COST EFFECTIVENESS</b>	<b>ANNUAL COST/TONS REMOVED</b>
Source: EPA OAQPS, 1990	



**TABLE 3-4**  
**CAPITAL COSTS FOR PRIMARY NO<sub>x</sub> CONTROLS**  
**EMD 20-210G4B ENGINE**  
**(\$1,000)**

<b>DIRECT COSTS</b>	
<b>Item</b>	<b>Cost<sup>(1)</sup></b>
1) Purchased Equipment	
a) Timing Retardation 4°	5.7
b) Separately Cooled Aftercooler	26.1
c) Aftercooler	107.5
d) Instrumentation	13.9
e) Structural Support	13.9
f) Freight	8.4
2) Direct Installation	52.7
<b>Total Direct Costs</b>	<b>228.2</b>
<b>INDIRECT COSTS</b>	
<b>Item</b>	<b>Cost</b>
3) Indirect Installation	
a) Engineering	22.8
b) Construction and Field Expenses	22.8
c) Construction Fee	11.4
d) Contingencies	45.6
4) Other Indirect Costs	
a) Start-up and Testing	20.4
<b>Total Indirect Costs</b>	<b>123.1</b>
<b>TOTAL CAPITAL COSTS</b>	<b>351.3</b>
(1) An explanation for the basis of cost can be found in Table 3-2.	

**TABLE 3-5**  
**ANNUALIZED COSTS FOR NO<sub>x</sub> CONTROLS**  
**EMD 20-210G4B ENGINE**  
**(\$1000) <sup>(1)</sup>**

<b>DIRECT OPERATING COSTS</b>	<b>FACTOR<sup>(2)</sup></b>
1) Personnel	
a) Labor at \$40/man-hr	41.6
b) Supervisor at 15% of Labor	6.2
2) Maintenance at 5% of Direct Costs	11.4
3) Replacement Parts	
a) Parts at 3% of Direct Costs	68.5
4) Utilities	
a) Electricity	34.3
c) Fuel Penalty	3.5
<b>INDIRECT OPERATING COSTS</b>	
6) Overhead at 30% of Labor and 12% of Maintenance	15.7
7) Property Tax at 1% of Total Capital Costs	3.5
8) Insurance at 1% of Total Capital Costs	3.5
9) Administration at 2% of Total Capital Costs	7.0
10) Capital Recovery at 10% x TDC	22.8
<b>TOTAL ANNUALIZED COSTS</b>	<b>218.1</b>
<b>TONS REMOVED</b>	<b>133.5</b>
<b>DOLLARS PER TON REMOVAL</b>	<b>1,600</b>
(1) Except for "TONS REMOVED" and "DOLLARS PER TON REMOVAL".	
(2) An explanation for the basis of cost can be found in Table 3-3.	

## 4.1 INTRODUCTION

The addition of Unit 9 (a 3.58 MW diesel generating unit) at Florida Key Electric Cooperative's Marathon Generation Plant will constitute an addition of a major source. Under the provisions of the regulations for Prevention of Significant Deterioration (PSD) of air quality, an air quality compliance assessment is required as technical support for the PSD permit application. The primary objective of this air quality assessment is to demonstrate compliance with applicable PSD Class I and Class II increments and National Ambient Air Quality Standards (NAAQS) for those pollutants emitted from the source in quantities defined by the regulations as significant (40 CFR 52.21 (b)(23)(i) and Table 17-212.400-2, F.A.C.).

Dispersion modeling has been conducted to determine the significance of the impacts from Unit 9 and the existing Units 1 through 8 on the regional ambient air quality due to the emissions of  $\text{NO}_x$  and  $\text{PM}_{10}$ . This assessment presents the results of the comprehensive air quality analysis that indicates that the addition of the source will not cause or contribute to a violation of the NAAQS. The analysis also demonstrates that Class I and Class II PSD increments will not be exceeded.

## 4.2 MODELING METHOD

### 4.2.1 MODEL SELECTION

The model used for this air dispersion analysis was USEPA's Industrial Source Complex Short Term, Version 3 (ISCST3) model. This steady-state Gaussian plume model contains algorithms for predicting area and volume source impacts, modified downwash algorithms for non-buoyant plumes, and an Huber-Snyder algorithm which incorporates wind-direction specific building heights and widths similar to the Schulman-Scire algorithm. This software also allows each model run to include several averaging intervals and multiple receptors.

### 4.2.2 TOPOGRAPHICAL FEATURES

Vaca Key, on which Marathon is located, and the surrounding islands are essentially flat. The Marathon Plant site is at an elevation of approximately 2.5-m above mean sea level (msl), with the surrounding area dropping to an elevation of about 2-m msl. Since the variation in terrain is minimal and less than the

height of the Unit 9 exhaust stack (13.72 m), the use of a flat terrain dispersion model is appropriate for the analysis.

#### 4.2.3 METEOROLOGICAL LAND USE CLASSIFICATION

The meteorological land use classification is used to determine the profile of the vertical wind speed and associated mechanical turbulence due to surface roughness. The wind speed profile is then used to extrapolate wind speeds at various heights for use in the estimates of atmospheric pollutant dispersion. USEPA's *Guideline on Air Quality Models* stipulates that the land use within the total area circumscribed by a 3-km radius around the source can be classified using Auer's scheme of meteorological land use typing proposed in the *Journal of Applied Meteorology* (1976). Auer's classifications are as follows:

Type	Description
I1	Heavy Industrial
I2	Light/Moderate Industrial
C1	Commercial
R1	Common Residential
R2/R3	Compact Residential
R4	Estate Residential
A1	Metropolitan Natural
A2	Agricultural Rural
A3/A4	Undeveloped
A5	Water Surfaces

According to the *Guideline*, if more than 50 percent of the total area in the circle is classified by land use as I1, I2, C1, R2, or R3, urban dispersion coefficients should be used in the modeling, otherwise, appropriate rural dispersion coefficients should be used. After reviewing various maps of the region surrounding the Marathon Plant, it was estimated that more than half of this area is classified as type A5 (Water Surfaces). Therefore, default rural dispersion coefficients were used in the analysis.

#### 4.2.4 BACKGROUND AMBIENT AIR QUALITY

Marathon is designated attainment or unclassified for all criteria pollutants. This designation is consistent with several features of the area. First, there are no large sources of air pollution nearby. Second, there is no significant terrain that could trap pollution and cause exceedances of the NAAQS. Third, the prevailing winds are east and southeast bringing clean air off of the Atlantic Ocean.

#### 4.2.5 SOURCE DATA

The existing diesel stacks and their emissions at the Marathon Plant are described in Table 4-1. The installation of Unit 9, one nominal 3.58-MW diesel

generator, is the proposed addition to the site. Emissions of  $\text{NO}_x$  from the new unit will be controlled using a combination of retarded injection timing and 4-pass increased flow capacity aftercoolers with a low temperature separate aftercooling circuit. Through the use of good combustion control practices and low sulfur fuel (less than or equal to 0.05% sulfur, by weight),  $\text{PM}_{10}$  emissions from Unit 9 will be reduced. The modeling parameters presented in Table 4-1 represent Unit 9 operating at 100% of capacity with these controls in place.

Additionally, as part of the proposed project, the stack height of the existing 3.58 MW EMD Diesel Generator Unit 8 will be increased from 38.7 feet to 45 feet. This stack height adjustment is included in Table 4-1.

#### 4.2.6 METEOROLOGICAL DATA

The refined analysis presented herein used five complete years (1987 through 1991) of wind and stability data consisting of actual surface observations in Key West and twice-per-day upper air soundings concurrently recorded at a station in Miami. Default wind speed profile exponents (indicative of increasing wind speed with increasing distance from the surface) and vertical potential temperature gradients (indicative of decreasing temperature with increasing distance above the surface) were used in the modeling. Five years of meteorology were processed using the source parameters found in Table 4-1.

#### 4.2.7 STACK HEIGHT CONSIDERATIONS

According to 40 CFR 51.100(hh), a good engineering practice (GEP) stack height is the greater of:

65 meters

or  $H_g = H_b + 1.5L$

where:  $H_g$  = the GEP stack height  
 $H_b$  = the height of the dominant nearby building, and  
 $L$  = the lesser dimension of the height or projected width of the dominant nearby building.

As shown in Table 4-1, the Unit 9 stack and the stacks of the existing units are less than 65 m. This in combination with the building dimensions indicate the potential for building downwash. For this reason, a building downwash analysis was included in the dispersion modeling.

Structures tend to disrupt airflow across a region and create turbulence around the structure. This disruption is referred to as the building wake effect or building downwash effect. This effect can result in high local ground-level pollutant concentrations if the emission point of the source is not far enough above or away from the structure to avoid the effect. A stack constructed at a height approximately 2.5 times the height of a nearby building is not likely to be affected by structural turbulence. If a stack is located within  $5L$  of a building,

and the building height is greater than approximately 40 percent of the stack height, then the stack is considered to be affected by building downwash.

The ISCST3 model used in the ambient air quality assessment uses a combination of two algorithms for predicting building wake effects. The Schulman-Scire algorithm is applicable when the stack height is less than  $1.5 H_b$  and takes into account wind-direction-specific building heights and widths when determining wake effects. The Huber-Snyder algorithm is applicable when the stack height is between  $1.5 H_b$  and  $2.5 H_b$  and uses the actual building height and maximum projected width for all wind directions. Software packages are available to determine the values of the building heights and widths that can influence each stack. One such package, Building Profile Input Program (BPIP), has been used for this analysis to estimate the wake effects caused by the structures at the Marathon Plant. The only structure at the Marathon Plant site with the potential to affect airflow is the Power Plant Building, with a height of 30 feet. The site layout can be found in Section 2 (Figure 2).

After BPIP was run, it was found that the Units 6 and 7 were located at a distance greater than  $5L$  from the building and were therefore not included in the building downwash analysis. All other units were included, and the results of BPIP can be found in the input for the modeling runs (Attachment 1).

### 4.2.8 RECEPTOR NETWORKS

The receptor grid used for the refined air quality analysis consists of a polar coordinate system centered on the Unit 8 stack. The grid network is made up of 36 direction radials separated by 10-degree increments. Receptors were placed at ground level at 50, 100, 200, 300, 400, 500, 750 and 1000m intervals. The polar grid is rotated so that  $0^\circ$  is located  $104^\circ$  off True North to accommodate for the orientation of the site (Section 2, Figure 2). This grid network provided sufficient resolution and downwind coverage to identify the areas of expected maximum concentrations.

## 4.3 RESULTS OF MODELING ANALYSIS

### 4.3.1 REFINED ANALYSIS

ISCST3 was used with real-time meteorological data to account for the consistency of the meteorology from the east and southeast. Further, the influence of structural downwash on the exhaust plumes was included in the refined modeling calculations.

The parameters found in Table 4-1, which include Unit 9 and the increased stack height for Unit 8, were modeled over five years of meteorology. The results can be seen in Tables 4-2 and 4-3.

A first-high concentration of  $117.0 \mu\text{g}/\text{m}^3$  for NAAQS and  $17.4 \mu\text{g}/\text{m}^3$  for PSD - Class II Increment (Attachment 1) was produced when  $\text{NO}_x$  emissions were

modeled. In accordance with USEPA-approved practices and consistent with modeling protocol, these concentrations can be reduced by 25 percent for  $\text{NO}_x$  due to the ratio of  $\text{NO}_2$  to  $\text{NO}_x$ , as outlined in Supplement C to the *Guideline on Air Quality Models* (revised) (Appendix W of 40 CFR Part 51), EPA, August 1995 (Attachment 2). Therefore, the first-high concentrations for NAAQS and PSD - Class II are  $87.75 \mu\text{g}/\text{m}^3$  and  $13.05 \mu\text{g}/\text{m}^3$ , respectively. Both these concentrations fall below the annual  $\text{NO}_x$  NAAQS of  $100 \mu\text{g}/\text{m}^3$  and the annual  $\text{NO}_x$  PSD - Class II Increment of  $25 \mu\text{g}/\text{m}^3$ .

Additionally,  $\text{PM}_{10}$  emissions were modeled for the facility, which included the addition of Unit 9 and the stack height increase for Unit 8. The first-high annual concentration was predicted to be  $6.5 \mu\text{g}/\text{m}^3$  for NAAQS and  $0.44 \mu\text{g}/\text{m}^3$  for PSD - Class II Increments. Second-high twenty-four hour concentrations were found to be  $65.56 \mu\text{g}/\text{m}^3$  and  $7.37 \mu\text{g}/\text{m}^3$  for the NAAQS and PSD - Class II Increments, respectively. These predicted impacts do not exceed the  $\text{PM}_{10}$  annual standards of  $50 \mu\text{g}/\text{m}^3$  (NAAQS) and  $17 \mu\text{g}/\text{m}^3$  (PSD - Class II Increment) or twenty-four hour standards of  $150 \mu\text{g}/\text{m}^3$  (NAAQS) and  $30 \mu\text{g}/\text{m}^3$  (PSD - Class II Increments). It is appropriate to consider the second-high concentration for the twenty-four hour averaging interval when modeling and reviewing five complete years of meteorological data. The modeled concentrations of  $\text{NO}_x$  and  $\text{PM}_{10}$  are compared to the appropriate standards in Tables 4-2 and 4-3.

#### 4.3.2 CLASS I INCREMENT ANALYSIS

The National Park Service (NPS) has developed a guidance document for assessing source impacts on Class I areas (*Permit Application Guidance for New Air Pollution Sources*, March 1993). Modeling procedures, similar to those applicable in Class II areas, have been developed by the NPS for Class I areas. Those guidelines were used in this application to show that the net effect of adding Unit 9 will be insignificant on regional Class I areas.

The receptors used in this analysis were similar to those used in the PSD Class II and NAAQS analysis except the distance was increased. The receptors were limited to represent only the intersection of the direction radials from  $10^\circ$  to  $60^\circ$  and the nearest boundary of the Everglades Class I area (see Figure 1). The receptors are identified in Table 4-4. Table 4-5 sets forth the  $\text{NO}_x$  annual maximum impact concentrations of Marathon's Units 8 and 9 on the Everglades over five years (1987 through 1991). Maximum predicted annual and twenty-four hour  $\text{PM}_{10}$  impacts are also found in Table 4-5.

The distance between Marathon and the Everglades is approximately 30 km. At this distance, as demonstrated when the modeled values are compared with the corresponding PSD - Class I Increment concentrations (Table 4-5), the addition of Unit 9 and the stack height increase for Unit 8 will have an insignificant impact on the Class I area.

### 4.3.3 AIR QUALITY RELATED ISSUES

Due to the small size of the proposed new diesel unit and the nature of operation (peaking operation), the air quality impacts on growth, visibility, soils, vegetation, and aquatic life are considered insignificant.



**TABLE 4-1**  
**SOURCE PARAMETERS**

Source	Stack Height (m)	NO <sub>x</sub> Emission Rate <sup>(2)</sup> (g/s)	PM <sub>10</sub> Emission Rate <sup>(3)</sup> (g/s)	Stack Temperature (K)	Stack Velocity (m/s)	Stack Diameter (m)
Unit 1	6.15	2.96	0.218	669	27.3	0.71
Unit 2	6.15	3.85	0.218	669	27.3	0.71
Unit 3	11.43	4.64	0.218	677	38.9	0.66
Unit 4	11.43	4.44	0.218	677	38.9	0.66
Unit 5	11.43	5.11	0.218	677	38.9	0.66
Unit 6	7.2	4.72	0.218	664	23.8	0.76
Unit 7	7.2	4.40	0.218	664	23.8	0.76
Unit 8	13.72 <sup>(1)</sup>	8.57	0.218	625	34.6	0.71
Unit 9	13.72	8.57	0.218	625	34.6	0.71

<sup>(1)</sup> The stack height for the existing Unit 8 is being increased from 11.79 m to 13.72 m as part of this permit application.

<sup>(2)</sup> The NO<sub>x</sub> rates included in this table are the maximum allowable emissions for Units 1 through 8 as stated in the Plant's Operation Permit (#0870004-001-AV). It is anticipated that the proposed Unit 9 will have NO<sub>x</sub> emissions restrictions similar to those for the existing and identical Unit 8.

<sup>(3)</sup> The PM<sub>10</sub> emission rates for Units 8 and 9 were calculated from emission factors found in AP-42. To be conservative, these calculated rates were also used for Units 1 through 7 (all seven units are smaller, and therefore would have lower actual emission rates, than Units 8 and 9).

**TABLE 4-2**  
**NAAQS AND PSD-CLASS II AIR QUALITY ANALYSIS**  
**ANNUAL NO<sub>x</sub>**  
**MAXIMUM PREDICTED CONCENTRATIONS**

Year	NAAQS <sup>(1)</sup>			PSD <sup>(2)</sup>		
	Maximum Concentration (ug/m <sup>3</sup> )	Revised Concentration <sup>(3)</sup> (ug/m <sup>3</sup> )	Annual Standard (ug/m <sup>3</sup> )	Maximum Concentration (ug/m <sup>3</sup> )	Revised Concentration <sup>(3)</sup> (ug/m <sup>3</sup> )	Annual standard (ug/m <sup>3</sup> )
1987	91.8	68.9		15.5	11.6	
1988	112.1	84.1		12.9	9.7	
1989	111.3	83.5	100.0	16.2	12.2	25.0
1990	102.7	77.0		16.6	12.5	
1991	117.0	87.8		17.4	13.1	

<sup>(1)</sup> The NAAQS analysis results include Units 1 through 9.

<sup>(2)</sup> The PSD-Class II analysis results include Units 8 and 9.

<sup>(3)</sup> The NO<sub>x</sub> concentrations can be reduced by 25% due to the ratio of NO<sub>2</sub> to NO<sub>x</sub> as outlined in Supplement C to EPA's *Guideline on Air Quality Models*, August 1995 (Attachment 2)

**TABLE 4-3**  
**NAAQS AND PSD-CLASS II AIR QUALITY ANALYSIS**  
**ANNUAL AND 24-HOUR PM<sub>10</sub>**  
**MAXIMUM PREDICTED CONCENTRATIONS**

Year	NAAQS <sup>(1,2)</sup>				PSD <sup>(3)</sup>			
	Annual		24-Hour		Annual		24-Hour	
	Maximum Concentration (ug/m <sup>3</sup> )	Standard (ug/m <sup>3</sup> )	Second-High Concentration (ug/m <sup>3</sup> )	Standard (ug/m <sup>3</sup> )	Maximum Concentration (ug/m <sup>3</sup> )	Standard (ug/m <sup>3</sup> )	Second-High Concentration (ug/m <sup>3</sup> )	Standard (ug/m <sup>3</sup> )
1987	4.84		55.20		0.39		6.56	
1988	6.46		65.56		0.33		7.37	
1989	6.50	50.0	53.35	150.0	0.41	17.0	4.64	30.0
1990	5.23		63.07		0.42		7.00	
1991	6.17		53.79		0.44		5.79	

<sup>(1)</sup> The NAAQS analysis results include Units 1 through 9. PM<sub>10</sub> emission rates for Units 8 and 9 were calculated from emission factors found in AP-42. To be conservative, these calculated rates were also used for Units 1 through 7 (all seven units are smaller, and therefore would have lower actual emission rates, than Units 8 and 9). If actual emission rates were used for Units 1 through 7, the maximum impact concentrations would be lower than what is shown here.

<sup>(2)</sup> The PSD-Class II analysis results include Units 8 and 9.

**TABLE 4-4**  
**PSD - CLASS I**  
**RECEPTOR LOCATIONS**

Receptor	Distance (m) <sup>(1)</sup>	Radials (°) <sup>(2)</sup>
1	41000	108
2	33500	118
3	31150	128
4	30000	138
5	30000	148
6	30000	158
7	31150	168

<sup>(1)</sup> Distance from the Unit 8 stack.

<sup>(2)</sup> The radials are based on the polar grid rotated 104° from True North.

**TABLE 4-5**  
**PSD - CLASS I**  
**MAXIMUM CUMULATIVE IMPACT CONCENTRATIONS<sup>(1,2)</sup>**


Year	NO <sub>x</sub>		PM <sub>10</sub>			
	Annual		Annual		24-Hour	
	Maximum Modeled Concentration (ug/m <sup>3</sup> )	PSD Class I Increment Concentration (ug/m <sup>3</sup> )	Maximum Modeled Concentration (ug/m <sup>3</sup> )	PSD Class I Increment Concentration (ug/m <sup>3</sup> )	Maximum Modeled Concentration (ug/m <sup>3</sup> )	PSD Class I Increment Concentration (ug/m <sup>3</sup> )
1987	0.074	SI 0.1	0.0019	0.1	0.071	0.3
1988	0.075		0.0019		0.043	
1989	0.062	2.5	0.0016	5.0	0.056	10.0
1990	0.041		0.0010		0.073	
1991	0.038		0.0010		0.056	

<sup>(1)</sup> The impacts are the highest concentrations predicted at the border of the nearest Class I area (the Everglades).

<sup>(2)</sup> The predicted impacts are made up of contributions from both PSD sources (Units 8 and 9).

FIGURE 1  
EVERGLADES CLASS I AREA

---



ATTACHMENT 1  
AIR DISPERSION MODELING RUNS

---

CO STARTING  
 CO TITLEONE 1991 FLORIDA KEYS ELECTRIC COOP - NO2 - AAQS & PSD 1/12/00 R.W.BECK  
 CO TITLETWO ANN 24-All ex 8&9@50%(8&9 @ permit rate,45m)-RE894591.IN  
 CO MODELOPT DFAULT CONC RURAL  
 CO AVERTIME PERIOD  
 CO POLLUTID OTHER  
 CO DCAYCOEF .000000  
 CO RUNORNOT RUN  
 CO FINISHED

SO STARTING  
 SO LOCATION unit1 POINT -71.1 -34.8 0.0  
 SO LOCATION unit2 POINT -71.1 -28.2 0.0  
 SO LOCATION unit3 POINT -6.7 0.0 0.0  
 SO LOCATION unit4 POINT -14.8 0.0 0.0  
 SO LOCATION unit5 POINT -20.4 0.0 0.0  
 SO LOCATION unit6 POINT -74.0 -48.9 0.0  
 SO LOCATION unit7 POINT -74.0 -43.0 0.0  
 SO LOCATION unit8 POINT 0.0 0.0 0.0  
 SO LOCATION unit9 POINT 6.7 0.0 0.0

\*\* POINT: SRCID QS HS TS VS DS  
 SO SRCPARAM unit1 2.96 6.15 669 27.3 0.71  
 SO SRCPARAM unit2 3.85 6.15 669 27.3 0.71  
 SO SRCPARAM unit3 4.64 11.43 677 38.9 0.66  
 SO SRCPARAM unit4 4.44 11.43 677 38.9 0.66  
 SO SRCPARAM unit5 5.11 11.43 677 38.9 0.66  
 SO SRCPARAM unit6 4.72 7.20 664 23.8 0.76  
 SO SRCPARAM unit7 4.40 7.20 664 23.8 0.76  
 SO SRCPARAM unit8 8.57 13.72 625 34.6 0.71  
 SO SRCPARAM unit9 8.57 13.72 625 34.6 0.71

SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 10.00 10.00 10.00 10.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 46.65 43.61 39.24 33.69

SO BUILDHGT unit2 10.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 10.00 10.00 10.00  
 SO BUILDWID unit2 27.11 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 43.61 39.24 33.69

SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00

SO BUILDHGT unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit4	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit4	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit4	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit4	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit4	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit4	48.43	48.27	46.65	43.61	39.24	33.69

SO BUILDHGT unit5	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit5	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit5	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit5	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit5	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit5	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit5	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit5	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit5	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit5	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit5	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit5	48.43	48.27	46.65	43.61	39.24	33.69

[illegible][illegible]

SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
-------------------	-------	-------	-------	-------	-------	-------



SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit8	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit8	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit8	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit8	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit8	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit8	48.43	48.27	46.65	43.61	39.24	33.69

SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit9	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit9	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit9	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit9	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit9	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit9	48.43	48.27	46.65	43.61	39.24	33.69

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)  
 SO SRCGROUP NAAQS unit1-unit9  
 SO SRCGROUP PSD unit8-unit9  
 SO FINISHED

RE STARTING  
 RE GRIDPOLR POL STA  
 \*\*GRID ORIGIN CENTERED ON unit 8  
 RE GRIDPOLR POL ORIG 0.0 0.0  
 RE GRIDPOLR POL DIST 50.0 100 200 300 400 500 750 1000  
 RE GRIDPOLR POL GDIR 36 10.0 10.0  
 RE GRIDPOLR POL END  
 RE FINISHED

ME STARTING  
 ME INPUTFIL KYWPRE91.ASC  
 ME ANEMHGT 6 700 METERS  
 ME SURFDATA 12836 1991 key west  
 ME UAIRDATA 12844 1991 miami  
 ME FINISHED

OU STARTING  
 OU RECTABLE ALLAVE FIRST SECOND  
 OU FINISHED

\*\*\*\*\*  
 \*\*\* SETUP Finishes Successfully \*\*\*  
 \*\*\*\*\*

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1991 FLORIDA KEYS ELECTRIC COOP - NO2 - AAQS & PSD 1/12/00 R.W.BECK \*\*\*  
02/11/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ permit rate,45m)-RE894591.IN \*\*\* 14:01:47

PAGE 12

\*\*MODELOPTs: CONC RURAL FLAT DFAULT

\*\*\* THE SUMMARY OF MAXIMUM PERIOD ( 8760 HRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN (MICROGRAMS/CUBIC-METER) \*\*

GROUP ID	AVERAGE CONC	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE	GRID-ID
----------	--------------	--	---------	---------

NAAQS	1ST HIGHEST VALUE IS	116.96910 AT (	-86.60,	50.00,	0.00,	0.00)	GP	POL
	2ND HIGHEST VALUE IS	106.60316 AT (	-93.97,	34.20,	0.00,	0.00)	GP	POL
	3RD HIGHEST VALUE IS	94.60606 AT (	-76.60,	64.28,	0.00,	0.00)	GP	POL
	4TH HIGHEST VALUE IS	75.43366 AT (	-98.48,	17.36,	0.00,	0.00)	GP	POL
	5TH HIGHEST VALUE IS	56.69728 AT (	-64.28,	76.60,	0.00,	0.00)	GP	POL
	6TH HIGHEST VALUE IS	54.03368 AT (	-153.21,	128.56,	0.00,	0.00)	GP	POL

PSD	1ST HIGHEST VALUE IS	17.41699 AT (	-383.02,	321.39,	0.00,	0.00)	GP	POL
	2ND HIGHEST VALUE IS	16.56292 AT (	-574.53,	482.09,	0.00,	0.00)	GP	POL
	3RD HIGHEST VALUE IS	16.19117 AT (	-153.21,	128.56,	0.00,	0.00)	GP	POL
	4TH HIGHEST VALUE IS	15.84502 AT (	-433.01,	250.00,	0.00,	0.00)	GP	POL
	5TH HIGHEST VALUE IS	15.61868 AT (	-649.52,	375.00,	0.00,	0.00)	GP	POL
	6TH HIGHEST VALUE IS	15.17626 AT (	-306.42,	257.11,	0.00,	0.00)	GP	POL

\*\*\* RECEPTOR TYPES: GC = GRIDCART

GP = GRIDPOLR

DC = DISCCART

DP = DISCPOLR

BD = BOUNDARY

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1991 FLORIDA KEYS ELECTRIC COOP - NO2 - AAQS & PSD 1/12/00 R.W.BECK \*\*\*  
02/11/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ permit rate,45m)-RE894591.IN

\*\*\* 14:01.47

PAGE 13

\*\*MODELOPTs. CONC

RURAL FLAT

DFAULT

\*\*\* Message Summary : ISCST3 Model Execution \*\*\*

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)  
A Total of 0 Warning Message(s)  
A Total of 180 Informational Message(s)  
  
A Total of 180 Calm Hours Identified

\*\*\*\*\* FATAL ERROR MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\* WARNING MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\*  
\*\*\* ISCST3 Finishes Successfully \*\*\*  
\*\*\*\*\*

CO STARTING  
 CO TITLEONE 1988 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/28/00 R.W.BECK  
 CO TITLETWO ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894588.IN  
 CO MODELOPT DFAULT CONC RURAL  
 CO AVERTIME PERIOD 24  
 CO POLLUTID OTHER  
 CO DCAYCOEF .000000  
 CO RUNORNOT RUN  
 CO FINISHED

SO STARTING  
 SO LOCATION unit1 POINT -71.1 -34.8 0.0  
 SO LOCATION unit2 POINT -71.1 -28.2 0.0  
 SO LOCATION unit3 POINT -6.7 0.0 0.0  
 SO LOCATION unit4 POINT -14.8 0.0 0.0  
 SO LOCATION unit5 POINT -20.4 0.0 0.0  
 SO LOCATION unit6 POINT -74.0 -48.9 0.0  
 SO LOCATION unit7 POINT -74.0 -43.0 0.0  
 SO LOCATION unit8 POINT 0.0 0.0 0.0  
 SO LOCATION unit9 POINT 6.7 0.0 0.0

\*\* POINT: SRCID QS HS TS VS DS  
 SO SRCPARAM unit1 0.218 6.15 669 27.3 0.71  
 SO SRCPARAM unit2 0.218 6.15 669 27.3 0.71  
 SO SRCPARAM unit3 0.218 11.43 677 38.9 0.66  
 SO SRCPARAM unit4 0.218 11.43 677 38.9 0.66  
 SO SRCPARAM unit5 0.218 11.43 677 38.9 0.66  
 SO SRCPARAM unit6 0.218 7.20 664 23.8 0.76  
 SO SRCPARAM unit7 0.218 7.20 664 23.8 0.76  
 SO SRCPARAM unit8 0.218 13.72 625 34.6 0.71  
 SO SRCPARAM unit9 0.218 13.72 625 34.6 0.71

SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 10.00 10.00 10.00 10.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 46.65 43.61 39.24 33.69

SO BUILDHGT unit2 10.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 10.00 10.00 10.00  
 SO BUILDWID unit2 27.11 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 43.61 39.24 33.69

SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00

10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
27.11	28.50	34.89	40.22	44.33	47.09
48.42	48.28	46.68	43.65	44.36	47.11
48.43	48.27	46.65	43.61	39.24	33.69
27.11	28.50	34.89	40.22	44.33	47.09
48.42	48.28	46.68	43.65	44.36	47.11
48.43	48.27	46.65	43.61	39.24	33.69

10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
27.11	28.50	34.89	40.22	44.33	47.09
48.42	48.28	46.68	43.65	44.36	47.11
48.43	48.27	46.65	43.61	39.24	33.69
27.11	28.50	34.89	40.22	44.33	47.09
48.42	48.28	46.68	43.65	44.36	47.11
48.43	48.27	46.65	43.61	39.24	33.69

10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
10.00	10.00	10.00	10.00	10.00	10.00
27.11	28.50	34.89	40.22	44.33	47.09
48.42	48.28	46.68	43.65	44.36	47.11
48.43	48.27	46.65	43.61	39.24	33.69
27.11	28.50	34.89	40.22	44.33	47.09
48.42	48.28	46.68	43.65	44.36	47.11
48.43	48.27	46.65	43.61	39.24	33.69

[illegible][illegible]

10.00 10.00 10.00 10.00 10.00 10.0

SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit8	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit8	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit8	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit8	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit8	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit8	48.43	48.27	46.65	43.61	39.24	33.69

SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit9	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit9	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit9	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit9	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit9	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit9	48.43	48.27	46.65	43.61	39.24	33.69

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)  
 SO SRCGROUP NAAQS unit1-unit9  
 SO SRCGROUP PSD unit8-unit9  
 SO FINISHED

RE STARTING  
 RE GRIDPOLR POL STA  
 \*\*GRID ORIGIN CENTERED ON unit 8  
 RE GRIDPOLR POL ORIG 0.0 0.0  
 RE GRIDPOLR POL DIST 50.0 100. 200. 300. 400. 500. 750. 1000.  
 RE GRIDPOLR POL GDIR 36 10.0 10 0  
 RE GRIDPOLR POL END  
 RE FINISHED

ME STARTING  
 ME INPUTFIL KYWPRE88.ASC  
 ME ANEMHGHT 6.700 METERS  
 ME SURFDATA 12836 1988 key west  
 ME UAIRDATA 12844 1988 miami  
 ME FINISHED

OU STARTING  
 OU RECTABLE ALLAVE FIRST SECOND  
 OU FINISHED

\*\*\*\*\*  
 \*\*\* SETUP Finishes Successfully \*\*\*  
 \*\*\*\*\*

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1988 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/28/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894588.IN

\*\*\* 16:08:01

PAGE 20

\*\*MODELOPTs: CONC

RURAL FLAT

DFAULT

\*\*\* THE SUMMARY OF MAXIMUM PERIOD ( 8784 HRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN (MICROGRAMS/CUBIC-METER) \*\*

GROUP ID	AVERAGE CONC	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG) OF TYPE GRID-ID
----------	--------------	--

NAAQS 1ST HIGHEST VALUE IS	6.45579 AT (	-93.97, 34.20, 0.00, 0.00) GP POL
2ND HIGHEST VALUE IS	5.53912 AT (	-86.60, 50.00, 0.00, 0.00) GP POL
3RD HIGHEST VALUE IS	5.37443 AT (	-98.48, 17.36, 0.00, 0.00) GP POL
4TH HIGHEST VALUE IS	4.49316 AT (	-76.60, 64.28, 0.00, 0.00) GP POL
5TH HIGHEST VALUE IS	3.06799 AT (	-64.28, 76.60, 0.00, 0.00) GP POL
6TH HIGHEST VALUE IS	2.70619 AT (	-100.00, 0.00, 0.00, 0.00) GP POL

PSD 1ST HIGHEST VALUE IS	0.32842 AT (	-433.01, 250.00, 0.00, 0.00) GP POL
2ND HIGHEST VALUE IS	0.32102 AT (	-173.21, 100.00, 0.00, 0.00) GP POL
3RD HIGHEST VALUE IS	0.31694 AT (	-153.21, 128.56, 0.00, 0.00) GP POL
4TH HIGHEST VALUE IS	0.31391 AT (	-383.02, 321.39, 0.00, 0.00) GP POL
5TH HIGHEST VALUE IS	0.31082 AT (	-649.52, 375.00, 0.00, 0.00) GP POL
6TH HIGHEST VALUE IS	0.28993 AT (	-346.41, 200.00, 0.00, 0.00) GP POL

\*\*\* RECEPTOR TYPES: GC = GRIDCART

GP = GRIDPOLR

DC = DISCCART

DP = DISCPOLR

BD = BOUNDARY

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1988 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/28/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894588.IN

\*\*\* 16:08:01

PAGE 21

\*\*MODELOPTs: CONC

RURAL FLAT

DFAULT

\*\*\* THE SUMMARY OF HIGHEST 24-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN (MICROGRAMS/CUBIC-METER) \*\*

GROUP ID	DATE AVERAGE CONC (YYMMDDHH)	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE GRID-ID
----------	---------------------------------	--	-----------------

NAAQS HIGH 1ST HIGH VALUE IS 72.39799 ON 88082024: AT ( -93.97, 34.20, 0.00, 0.00) GP POL  
HIGH 2ND HIGH VALUE IS 65.55708 ON 88012024: AT ( -93.97, 34.20, 0.00, 0.00) GP POL

PSD HIGH 1ST HIGH VALUE IS 11.48685 ON 88091424: AT ( -86.60, 50.00, 0.00, 0.00) GP POL  
HIGH 2ND HIGH VALUE IS 7.37324 ON 88040124: AT ( -86.60, 50.00, 0.00, 0.00) GP POL

\*\*\* RECEPTOR TYPES: GC = GRIDCART

GP = GRIDPOLR

DC = DISCCART

DP = DISCPOLR

BD = BOUNDARY



\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1988 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/28/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894588.IN

\*\*\* 16:08.01

PAGE 22

\*\*MODELOPTs: CONC RURAL FLAT DFAULT

\*\*\* Message Summary : ISCST3 Model Execution \*\*\*

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)  
A Total of 0 Warning Message(s)  
A Total of 111 Informational Message(s)  
  
A Total of 111 Calm Hours Identified

\*\*\*\*\* FATAL ERROR MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\* WARNING MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\*  
\*\*\* ISCST3 Finishes Successfully \*\*\*  
\*\*\*\*\*

CO STARTING  
 CO TITLEONE 1989 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/28/00 R.W.BECK  
 CO TITLETWO ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894589.IN  
 CO MODELOPT DFAULT CONC RURAL  
 CO AVERTIME PERIOD 24  
 CO POLLUTID OTHER  
 CO DCAYCOEF .000000  
 CO RUNORNOT RUN  
 CO FINISHED

SO STARTING  
 SO LOCATION unit1 POINT -71.1 -34.8 0.0  
 SO LOCATION unit2 POINT -71.1 -28.2 0.0  
 SO LOCATION unit3 POINT -6.7 0.0 0.0  
 SO LOCATION unit4 POINT -14.8 0.0 0.0  
 SO LOCATION unit5 POINT -20.4 0.0 0.0  
 SO LOCATION unit6 POINT -74.0 -48.9 0.0  
 SO LOCATION unit7 POINT -74.0 -43.0 0.0  
 SO LOCATION unit8 POINT 0.0 0.0 0.0  
 SO LOCATION unit9 POINT 6.7 0.0 0.0

\*\* POINT: SRCID QS HS TS VS DS  
 SO SRCPARAM unit1 0.218 6.15 669 27.3 0.71  
 SO SRCPARAM unit2 0.218 6.15 669 27.3 0.71  
 SO SRCPARAM unit3 0.218 11.43 677 38.9 0.66  
 SO SRCPARAM unit4 0.218 11.43 677 38.9 0.66  
 SO SRCPARAM unit5 0.218 11.43 677 38.9 0.66  
 SO SRCPARAM unit6 0.218 7.20 664 23.8 0.76  
 SO SRCPARAM unit7 0.218 7.20 664 23.8 0.76  
 SO SRCPARAM unit8 0.218 13.72 625 34.6 0.71  
 SO SRCPARAM unit9 0.218 13.72 625 34.6 0.71

SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit1 0.00 0.00 10.00 10.00 10.00 10.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit1 0.00 0.00 46.65 43.61 39.24 33.69

SO BUILDHGT unit2 10.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDHGT unit2 0.00 0.00 0.00 10.00 10.00 10.00  
 SO BUILDWID unit2 27.11 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 0.00 0.00 0.00  
 SO BUILDWID unit2 0.00 0.00 0.00 43.61 39.24 33.69

SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00  
 SO BUILDHGT unit3 10.00 10.00 10.00 10.00 10.00 10.00

SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
-------------------	-------	-------	-------	-------	-------	-------

SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit8	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit8	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit8	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit8	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit8	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit8	48.43	48.27	46.65	43.61	39.24	33.69

SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit9	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit9	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit9	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit9	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit9	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit9	48.43	48.27	46.65	43.61	39.24	33.69

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)  
 SO SRCGROUP NAAQS unit1-unit9  
 SO SRCGROUP PSD unit8-unit9  
 SO FINISHED

RE STARTING  
 RE GRIDPOLR POL STA  
 \*\*GRID ORIGIN CENTERED ON unit 8  
 RE GRIDPOLR POL ORIG 0.0 0.0  
 RE GRIDPOLR POL DIST 50.0 100. 200. 300. 400. 500. 750. 1000.  
 RE GRIDPOLR POL GDIR 36 10.0 10.0  
 RE GRIDPOLR POL END  
 RE FINISHED

ME STARTING  
 ME INPUTFIL KYWPRE89.ASC  
 ME ANEMHGT 6.700 METERS  
 ME SURFDATA 12836 1989 key west  
 ME UAIRDATA 12844 1989 miami  
 ME FINISHED

OU STARTING  
 OU RECTABLE ALLAVE FIRST SECOND  
 OU FINISHED

\*\*\*\*\*  
 \*\*\* SETUP Finishes Successfully \*\*\*  
 \*\*\*\*\*

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1989 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/28/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894589 IN

\*\*\* 16:09:30

PAGE 20

\*\*MODELOPTs: CONC

RURAL FLAT

DEFAULT

\*\*\* THE SUMMARY OF MAXIMUM PERIOD ( 8760 HRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN (MICROGRAMS/CUBIC-METER) \*\*

GROUP ID	AVERAGE CONC	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG) OF TYPE GRID-ID
----------	--------------	--

NAAQS	1ST HIGHEST VALUE IS 6.49994 AT ( -93.97, 34.20, 0.00, 0.00)	GP POL
	2ND HIGHEST VALUE IS 5.91234 AT ( -98.48, 17.36, 0.00, 0.00)	GP POL
	3RD HIGHEST VALUE IS 5.57096 AT ( -86.60, 50.00, 0.00, 0.00)	GP POL
	4TH HIGHEST VALUE IS 4.34003 AT ( -76.60, 64.28, 0.00, 0.00)	GP POL
	5TH HIGHEST VALUE IS 2.90637 AT ( -64.28, 76.60, 0.00, 0.00)	GP POL
	6TH HIGHEST VALUE IS 2.66756 AT ( -100.00, 0.00, 0.00, 0.00)	GP POL

PSD	1ST HIGHEST VALUE IS 0.41119 AT ( -649.52, 375.00, 0.00, 0.00)	GP POL
	2ND HIGHEST VALUE IS 0.40706 AT ( -433.01, 250.00, 0.00, 0.00)	GP POL
	3RD HIGHEST VALUE IS 0.39597 AT ( -383.02, 321.39, 0.00, 0.00)	GP POL
	4TH HIGHEST VALUE IS 0.38153 AT ( -574.53, 482.09, 0.00, 0.00)	GP POL
	5TH HIGHEST VALUE IS 0.35053 AT ( -866.03, 500.00, 0.00, 0.00)	GP POL
	6TH HIGHEST VALUE IS 0.34337 AT ( -321.39, 383.02, 0.00, 0.00)	GP POL

\*\*\* RECEPTOR TYPES. GC = GRIDCART

GP = GRIDPOLR

DC = DISCCART

DP = DISCPOLR

BD = BOUNDARY

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1989 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/28/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-Air ex 8&9@50%(8&9 @ 45m)-PM894589.IN \*\*\* 16:09:30

PAGE 21

\*\*MODELOPTs: CONC RURAL FLAT DFAULT

\*\*\* THE SUMMARY OF HIGHEST 24-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN (MICROGRAMS/CUBIC-METER) \*\*

GROUP ID	DATE AVERAGE CONC (YYMMDDHH)	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE GRID-ID
----------	---------------------------------	--	-----------------

NAAQS HIGH 1ST HIGH VALUE IS 59.84761 ON 89022124: AT ( -98.48, 17.36, 0.00, 0.00) GP POL  
HIGH 2ND HIGH VALUE IS 53.34970 ON 89071824: AT ( -93.97, 34.20, 0.00, 0.00) GP POL

PSD HIGH 1ST HIGH VALUE IS 9.30202 ON 89022324: AT ( 64.28, -76.60, 0.00, 0.00) GP POL  
HIGH 2ND HIGH VALUE IS 4.63773 ON 89120324: AT ( 0.00, -100.00, 0.00, 0.00) GP POL

\*\*\* RECEPTOR TYPES: GC = GRIDCART

GP = GRIDPOLR

DC = DISCCART

DP = DISCPOLR

BD = BOUNDARY

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1989 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/28/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894589.IN

\*\*\* 16:09:30

PAGE 22

\*\*MODELOPTs: CONC                   RURAL FLAT       DFAULT

\*\*\* Message Summary : ISCST3 Model Execution \*\*\*

----- Summary of Total Messages -----

A Total of       0 Fatal Error Message(s)  
A Total of       0 Warning Message(s)  
A Total of       223 Informational Message(s)  
  
A Total of       223 Calm Hours Identified

\*\*\*\*\* FATAL ERROR MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\* WARNING MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\*  
\*\*\* ISCST3 Finishes Successfully \*\*\*  
\*\*\*\*\*

CO STARTING  
 CO TITLEONE 1991 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/27/00 R.W.BECK  
 CO TITLETWO ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894591.IN  
 CO MODELOPT DFAULT CONC RURAL  
 CO AVERTIME PERIOD 24  
 CO POLLUTID OTHER  
 CO DCAYCOEF .000000  
 CO RUNORNOT RUN  
 CO FINISHED

SO STARTING  
 SO LOCATION unit1 POINT -71.1 -34.8 0.0  
 SO LOCATION unit2 POINT -71.1 -28.2 0.0  
 SO LOCATION unit3 POINT -6.7 0.0 0.0  
 SO LOCATION unit4 POINT -14.8 0.0 0.0  
 SO LOCATION unit5 POINT -20.4 0.0 0.0  
 SO LOCATION unit6 POINT -74.0 -48.9 0.0  
 SO LOCATION unit7 POINT -74.0 -43.0 0.0  
 SO LOCATION unit8 POINT 0.0 0.0 0.0  
 SO LOCATION unit9 POINT 6.7 0.0 0.0

** POINT: SRCID	QS	HS	TS	VS	DS
SO SRCPARAM unit1	0.218	6.15	669	27.3	0.71
SO SRCPARAM unit2	0.218	6.15	669	27.3	0.71
SO SRCPARAM unit3	0.218	11.43	677	38.9	0.66
SO SRCPARAM unit4	0.218	11.43	677	38.9	0.66
SO SRCPARAM unit5	0.218	11.43	677	38.9	0.66
SO SRCPARAM unit6	0.218	7.20	664	23.8	0.76
SO SRCPARAM unit7	0.218	7.20	664	23.8	0.76
SO SRCPARAM unit8	0.218	13.72	625	34.6	0.71
SO SRCPARAM unit9	0.218	13.72	625	34.6	0.71
SO BUILDHGT unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit1	0.00	0.00	10.00	10.00	10.00
SO BUILDWID unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit1	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit1	0.00	0.00	46.65	43.61	39.24

SO BUILDHGT unit2	10.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit2	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit2	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit2	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit2	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT unit2	0.00	0.00	0.00	10.00	10.00
SO BUILDWID unit2	27.11	0.00	0.00	0.00	0.00
SO BUILDWID unit2	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit2	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit2	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit2	0.00	0.00	0.00	0.00	0.00
SO BUILDWID unit2	0.00	0.00	0.00	43.61	39.24

SO BUILDHGT unit3	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit3	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit3	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit3	10.00	10.00	10.00	10.00	10.00



SO BUILDHGT	unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT	unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT	unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT	unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT	unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT	unit4	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID	unit4	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID	unit4	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID	unit4	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID	unit4	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID	unit4	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID	unit4	48.43	48.27	46.65	43.61	39.24	33.69

[illegible][illegible]

SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
-------------------	-------	-------	-------	-------	-------	-------

SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit8	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit8	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit8	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit8	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit8	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit8	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit8	48.43	48.27	46.65	43.61	39.24	33.69

SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDHGT unit9	10.00	10.00	10.00	10.00	10.00	10.00
SO BUILDWID unit9	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit9	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit9	48.43	48.27	46.65	43.61	39.24	33.69
SO BUILDWID unit9	27.11	28.50	34.89	40.22	44.33	47.09
SO BUILDWID unit9	48.42	48.28	46.68	43.65	44.36	47.11
SO BUILDWID unit9	48.43	48.27	46.65	43.61	39.24	33.69

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)  
 SO SRCGROUP NAAQS unit1-unit9  
 SO SRCGROUP PSD unit8-unit9  
 SO FINISHED

RE STARTING  
 RE GRIDPOLR POL STA  
 \*\*GRID ORIGIN CENTERED ON unit 8  
 RE GRIDPOLR POL ORIG 0.0 0.0  
 RE GRIDPOLR POL DIST 50.0 100. 200. 300. 400. 500. 750. 1000.  
 RE GRIDPOLR POL GDIR 36 10.0 10.0  
 RE GRIDPOLR POL END  
 RE FINISHED

ME STARTING  
 ME INPUTFIL KYWPRE91.ASC  
 ME ANEMHGHT 6.700 METERS  
 ME SURFDATA 12836 1991 key west  
 ME UAIRDATA 12844 1991 miami  
 ME FINISHED

OU STARTING  
 OU RECTABLE ALLAVE FIRST SECOND  
 OU FINISHED

\*\*\*\*\*  
 \*\*\* SETUP Finishes Successfully \*\*\*  
 \*\*\*\*\*

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1991 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/27/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894591.IN

\*\*\* 16:27:06

PAGE 20

\*\*MODELOPTs: CONC

RURAL FLAT DFAULT

\*\*\* THE SUMMARY OF MAXIMUM PERIOD ( 8760 HRS) RESULTS \*\*\*

\*\* CONC OF OTHER IN (MICROGRAMS/CUBIC-METER) \*\*

GROUP ID	AVERAGE CONC	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG) OF TYPE GRID-ID
----------	--------------	--

NAAQS	1ST HIGHEST VALUE IS	6.17000 AT ( -86.60, 50.00, 0.00, 0.00) GP POL
	2ND HIGHEST VALUE IS	6.15450 AT ( -93.97, 34.20, 0.00, 0.00) GP POL
	3RD HIGHEST VALUE IS	4.94235 AT ( -98.48, 17.36, 0.00, 0.00) GP POL
	4TH HIGHEST VALUE IS	4.86929 AT ( -76.60, 64.28, 0.00, 0.00) GP POL
	5TH HIGHEST VALUE IS	2.94968 AT ( -64.28, 76.60, 0.00, 0.00) GP POL
	6TH HIGHEST VALUE IS	2.39710 AT ( -153.21, 128.56, 0.00, 0.00) GP POL

PSD	1ST HIGHEST VALUE IS	0.44305 AT ( -383.02, 321.39, 0.00, 0.00) GP POL
	2ND HIGHEST VALUE IS	0.42132 AT ( -574.53, 482.09, 0.00, 0.00) GP POL
	3RD HIGHEST VALUE IS	0.41186 AT ( -153.21, 128.56, 0.00, 0.00) GP POL
	4TH HIGHEST VALUE IS	0.40306 AT ( -433.01, 250.00, 0.00, 0.00) GP POL
	5TH HIGHEST VALUE IS	0.39730 AT ( -649.52, 375.00, 0.00, 0.00) GP POL
	6TH HIGHEST VALUE IS	0.38605 AT ( -306.42, 257.11, 0.00, 0.00) GP POL

\*\*\* RECEPTOR TYPES: GC = GRIDCART

GP = GRIDPOLR

DC = DISCCART

DP = DISCPOLR

BD = BOUNDARY

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1991 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/27/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894591.IN

\*\*\* 16.27.06

PAGE 21

\*\*MODELOPTs: CONC

RURAL FLAT DFAULT

\*\*\* THE SUMMARY OF HIGHEST 24-HR RESULTS \*\*\*

\*\* CONC OF OTHER IN (MICROGRAMS/CUBIC-METER) \*\*

GROUP ID	DATE AVERAGE CONC (YYMMDDHH)	NETWORK RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE	GRID-ID
----------	---------------------------------	--	---------	---------

NAAQS HIGH 1ST HIGH VALUE IS 59.45385 ON 91051524: AT ( -93.97, 34.20, 0.00, 0.00) GP POL  
HIGH 2ND HIGH VALUE IS 53.78853 ON 91032924: AT ( -98.48, 17.36, 0.00, 0.00) GP POL

PSD HIGH 1ST HIGH VALUE IS 11.69194 ON 91052124: AT ( -76.60, 64.28, 0.00, 0.00) GP POL  
HIGH 2ND HIGH VALUE IS 5.78601 ON 91031024: AT ( 0.00, -100.00, 0.00, 0.00) GP POL

\*\*\* RECEPTOR TYPES: GC = GRIDCART

GP = GRIDPOLR

DC = DISCCART

DP = DISCPOLR

BD = BOUNDARY

\*\*\* ISCST3 - VERSION 97363 \*\*\* \*\*\* 1991 FLORIDA KEYS ELECTRIC COOP - PM10 - AAQS & PSD 1/27/00 R.W.BECK \*\*\*  
01/28/00

\*\*\* ANN 24-All ex 8&9@50%(8&9 @ 45m)-PM894591.IN

\*\*\* 16:27:06

PAGE 22

\*\*MODELOPTs: CONC                   RURAL FLAT       DFAULT

\*\*\* Message Summary : ISCST3 Model Execution \*\*\*

----- Summary of Total Messages -----

A Total of       0 Fatal Error Message(s)  
A Total of       0 Warning Message(s)  
A Total of       180 Informational Message(s)  
  
A Total of       180 Calm Hours Identified

\*\*\*\*\* FATAL ERROR MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\* WARNING MESSAGES \*\*\*\*\*  
\*\*\* NONE \*\*\*

\*\*\*\*\*  
\*\*\* ISCST3 Finishes Successfully \*\*\*  
\*\*\*\*\*

**DRAFT**



**SUPPLEMENT C**  
**TO THE**  
**GUIDELINE ON**  
**AIR QUALITY MODELS (REVISED)**  
(Appendix W of 40 CFR Part 51)

June 1994


U.S. ENVIRONMENTAL PROTECTION AGENCY  
Office of Air and Radiation  
Office of Air Quality Planning and Standards  
Research Triangle Park, North Carolina 27711

### 6.2.3 Models for Nitrogen Dioxide (Annual Average)

A tiered screening approach is recommended to obtain annual average estimates of  $\text{NO}_2$  from point sources for New Source Review analysis, including PSD, and for SIP planning purposes. This multi-tiered approach is conceptually shown in Figure 6-1 below:

FIGURE 6-1

Multi-tiered Screening Approach for Estimating Annual  $\text{NO}_2$   
Concentrations from Point Sources



a) For Tier 1 (the initial screen), use an appropriate Gaussian model from Appendix A to estimate the maximum annual average concentration and assume a total conversion of NO to  $\text{NO}_2$ . If the concentration exceeds the NAAQS and/or PSD increments for  $\text{NO}_2$ , proceed to the 2nd level screen.

b) For Tier 2 (2nd level) screening analysis, multiply the Tier 1 estimate(s) by an empirically derived  $\text{NO}_2 / \text{NO}_x$  value of 0.75 (annual national default).<sup>36</sup> An annual  $\text{NO}_2 / \text{NO}_x$  ratio differing from 0.75 may be used if it can be shown that such a ratio is based on data likely to be representative of the location(s) where maximum annual impact from the individual source under review occurs. In the case where several sources contribute to consumption of a PSD increment, a locally derived annual  $\text{NO}_2 / \text{NO}_x$  ratio should also be shown to be representative of the location where the maximum collective impact from the new plus existing sources occurs.

In urban areas, a proportional model may be used as a preliminary assessment to evaluate control strategies to meet the NAAQS for multiple minor sources, i.e. minor point, area and mobile sources of  $\text{NO}_x$ ; concentrations resulting from major point sources should be estimated separately as discussed above, then added to the impact of the minor sources. An acceptable screening technique for urban complexes is to assume that all  $\text{NO}_x$  is emitted in the form of  $\text{NO}_2$  and to use a model from Appendix A for nonreactive pollutants to estimate  $\text{NO}_2$  concentrations. A more accurate estimate can be obtained by: (1) calculating the annual average concentrations of  $\text{NO}_x$  with an urban model, and (2) converting these estimates to  $\text{NO}_2$  concentrations using an empirically derived annual  $\text{NO}_2 / \text{NO}_x$  ratio. A value of 0.75 is recommended for

this ratio. However, a spatially averaged annual  $\text{NO}_2$  /  $\text{NO}_x$  ratio may be determined from an existing air quality monitoring network and used in lieu of the 0.75 value if it is determined to be representative of prevailing ratios in the urban area by the reviewing agency. To ensure use of appropriate locally derived annual  $\text{NO}_2$  /  $\text{NO}_x$  ratios, monitoring data under consideration should be limited to those collected at monitors meeting siting criteria defined in 40 CFR 58, Appendix D as representative of "neighborhood", "urban", or "regional" scales. Furthermore, the highest annual spatially averaged  $\text{NO}_2$  /  $\text{NO}_x$  ratio from the most recent 3 years of complete data should be used to foster conservatism in estimated impacts.

To demonstrate compliance with  $\text{NO}_2$  PSD increments in urban areas, emissions from major and minor sources should be included in the modeling analysis. Point and area source emissions should be modeled as discussed above. If mobile source emissions do not contribute to localized areas of high ambient  $\text{NO}_2$  concentrations, they should be modeled as area sources. When modeled as area sources, mobile source emissions should be assumed uniform over the entire highway link and allocated to each area source grid square based on the portion of highway link within each grid square. If localized areas of high concentrations are likely, then mobile sources should be modeled as line sources with the preferred model ISCLT2.

More refined techniques to handle special circumstances may be considered on a case-by-case basis and agreement with the reviewing authority should be obtained. Such techniques should consider individual quantities of  $\text{NO}$  and  $\text{NO}_2$  emissions, atmospheric transport and dispersion, and atmospheric transformation of  $\text{NO}$  to  $\text{NO}_2$ . Where they are available, site-specific data on the conversion of  $\text{NO}$  to  $\text{NO}_2$  may be used. Photochemical dispersion models, if used for other pollutants in the area, may also be applied to the  $\text{NO}_2$  problem.