

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

OFFICIAL USE

7000 2870 0000 7028 2713

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To
R. B. Havens

Street, Apt. No.; or PO Box No.
PO Box 1409

City, State, ZIP+ 4
Key West, FL 33041-1409
PS Form 3800, May 2000 See Reverse for Instructions


SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1 Article Addressed to:
Mr. R. B. Havens, Plant Manager
Southernmost Waste to Energy Facility
The City of Key West
PO Box 1409
Key West, FL 33041-1409

COMPLETE THIS SECTION ON DELIVERY

A. Received by (Please Print Clearly) **Robert Mesa** B. Date of Delivery **10-15-01**

C. Signature  Agent
 Addressee

D. Is delivery address different from item 1? Yes
If YES, enter delivery address below: No

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

2. Article Number (Copy from service label)
7000 2870 0000 7028 2713

UNITED STATES POSTAL SERVICE



First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •


Dept. of Environmental Protection
Division of Air Resources Mgt.
Bureau of Air Regulation, NSR
2600 Blair Stone Rd., MS 5505
Tallahassee, FL 32399-2400

BUREAU OF AIR REGULATION

OCT 17 2001

RECEIVED





Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

October 12, 2001

Mr. R. B. Havens
Plant Manager
Southernmost Waste to Energy Facility
The City of Key West
P.O. Box 1409
Key West, Florida 33041-1409

Re: Proposed Super Heater Installation

Dear Mr. Havens:

Your letter on this subject to Ron Blackburn of our Department was forwarded to this office for review and reply. Please be advised that because the proposed change involves a *physical modification*, you will need to submit an Air Construction (AC) permit application to us. However, since your letter indicates that the modification is minor, no application fee is required at this time. The proper form, DEP 62-210.900(1), can be downloaded from the Department's web site at www.dep.state.fl.us/air/forms.

The application must include the justification from a Florida licensed P.E. verifying that there will be no actual emissions increases due to the proposed change. We will also require that you perform both a pre and post-test to validate that PSD pollutant emissions limits (significant emission rates) are not exceeded due to the change. Please refer to Rule 62-212.400(5), F.A.C. The battery of tests should be conducted for all PSD regulated pollutants, and using the correct test methods as required by the facility's Title V permit. If the results of the tests reveal that a PSD significant emissions rate has indeed been triggered, then the proper fee must be tendered, and a full PSD application will then be required. The results of the tests should be sent to this office.

Sincerely,

A handwritten signature in black ink, appearing to read "C. H. Fancy".

C. H. Fancy, P.E.

Chief

Bureau of Air Regulation

cc: Ron Blackburn, South District Office

"More Protection, Less Process"

Printed on recycled paper.