


STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

NORTHEAST DISTRICT

3426 BILLS ROAD  
JACKSONVILLE, FLORIDA 32207  
(904) 396-6959



BOB GRAHAM  
GOVERNOR  
VICTORIA J. TSCHINKEL  
SECRETARY  
G. DOUG DUTTON  
DISTRICT MANAGER

December 14, 1984

Mr. Paul J. Magnell  
Vice President and Resident Manager  
Container Corporation of America  
North Eighth Street  
Fernandina Beach, Florida 32034

DER

Dear Mr. Magnell:

DEC 17 1984

Nassau County - AP  
Container Corporation of America  
No. 7 Power Boiler

BAQM

EPA Specific Condition 7, Final Determination, PSD-FL-062 requires a continuous monitor for SO<sub>2</sub> emissions. It is noted that a request for an alternate procedure for compliance monitoring of SO<sub>2</sub> was submitted to EPA on October 15, 1984.

No action on that request has been received by this office. Therefore, when Permit No. AO45-71885 was issued, the Department had no alternative except to require the CEMS until the alternate procedure has been approved.

Please advise of the action taken within 14 days of receipt of this letter. Technically, you are not in compliance with EPA Condition #7 and DER Condition #4. If you can facilitate early action on your request of October 15, 1984, it may preclude the necessity for a CEMS.

If there are any questions, please contact me.

Sincerely,

  
John Brown, P.E.  
Supervisor Air Section

 JB:vk

cc: Mr. James T. Wilburn, EPA  
Mr. Bruce Mitchell, BAQM  
Ms. Cynthia Sawyer, CCA