


STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

NORTHEAST DISTRICT

3426 BILLS ROAD
JACKSONVILLE, FLORIDA 32207
(904) 396-6959



BOB GRAHAM
GOVERNOR
VICTORIA J. TSCHINKEL
SECRETARY
G. DOUG DUTTON
DISTRICT MANAGER

September 14, 1984

Ms. Cynthia Sawyer
Environmental Group Leader
Container Corporation of America
North Eighth Street
Fernandina Beach, Florida 32034

Dear Ms. Sawyer:

Nassau County - AP
Container Corporation of America
No. 7 Power Boiler
Nitrogen Oxides and SO₂ Monitoring Requirement

The following information is provided to document the conversations with Mr. Bruce Mitchell and me on September 13, 1984.

Mr. Mitchell has indicated that he is willing to modify the construction permit for No. 7 power boiler to require an emissions limiting standard of 0.70 lb/10⁶ BTU per CFR 40, Section 60.44(a)(3) subject to the following:

1. Certification that you have not used, are not using, and will not utilize lignite or a solid fossil fuel containing 25 percent by weight, or more of coal refuse.
2. That the permit condition be changed to limit future use of No. 7 power boiler to the fuel input specified by 40 CFR, Section 60.44(a)(3).

Please note that we have not received the additional information required for completion of the operating permit review for No. 7 power boiler. Also, please expedite the request for approval of your alternate method for monitoring sulfur dioxide.


Ms. Cynthia Sawyer
September 14, 1984
page two

Failure to complete the action required to obtain the operating permit for No. 7 power boiler most expeditiously will necessitate enforcement action by the Department.

Please send me copies of all letters to the Bureau of Air Quality Management and EPA.

Your cooperation is appreciated.

Sincerely,


John Brown, P.E.
Supervisor Air Section

BPL

JB:vk

 cc: Bruce Mitchell
Enforcement

Container
Corporation
of America

Paper Mill Division

North Eighth Street
Fernandina Beach, Florida 32034

Phone: 904 261-5551

September 13, 1984

Mr. Bruce Mitchell
DER - Bureau of Air Quality Management
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, FL 32301-8241

Dear Mr. Mitchell:

As discussed in our phone conversation this morning, this letter is written verification that we do not plan to burn lignite or 25% by weight of coal refuse in No. 7 Coal Fired Power Boiler. No. 7 Power Boiler only burns washed bituminous coal. My understanding from our conversation is this verification will allow the NO_x limit to be changed from .6 lb/mmBTU to .7 lb/mmBTU, because the .6 lb/mmBTU only applies to boilers burning lignite or coal refuse [as stated in 40 CFR 60.44(a)(4)] and will also add a specific condition stating we cannot burn lignite or coal refuse.

If you have any additional questions or comments, please do not hesitate to call.

Sincerely yours,

CONTAINER CORPORATION OF AMERICA

Cynthia L. Sawyer
Environmental Group Leader

jrb

DER

SEP 21 1984

BAQM