


TWIN TOWERS OFFICE BUILDING
2600 BLAIR STONE ROAD
TALLAHASSEE, FLORIDA 32301



BOB GRAHAM
GOVERNOR

JACOB D. VARN
SECRETARY

STATE OF FLORIDA

DEPARTMENT OF ENVIRONMENTAL REGULATION

January 14, 1981

Mr. R.W. Galphin
General Manager
Container Corporation of America
Fernandina Beach Mill Division
North Eight Street
Fernandina Beach, Florida 32034

Dear Mr. Galphin:

This is to confirm that the Department has received the supplemental material to your application for construction of power boiler No. 7, #AC 45-35532.

As of December 12, 1980, your application is considered complete and we have begun to process it.

Preliminary determination and draft permit will be completed around February 5, 1981.


Sincerely,

Willard Hanks

Willard Hanks
Engineer,
Bureau of Air Quality Management

WH:dav

AN EYEBOLT AND ANGLE SHALL BE ATTACHED DIRECTLY ABOVE EACH PORT OF VERTICAL STACKS AND ABOVE EACH VERTICAL SET OF PORTS FOUND ON THE SIDES OF HORIZONTAL DUCTWORK 1.8 WORKING PLATFORMS. THE DIMENSIONS AND PLACEMENT OF THESE FIXTURES ARE SHOWN IN FIGURE 1-1.



IF EYEBOLT IS MORE THAN 120 INCHES ABOVE THE PLATFORM A PIECE OF CHAIN SHOULD BE ATTACHED TO IT TO BRING THE POINT OF ATTACHMENT WITHIN SAFE REACH. THE EYEBOLT SHOULD BE CAPABLE OF SUPPORTING A 500 POUND WORKING LOAD.

INTEROFFICE MEMORANDUM

For Routing To District Offices And/Or To Other Than The Addressee		
To: _____	Loctn.: _____	
To: _____	Loctn.: _____	
To: _____	Loctn.: _____	
From: _____	Date: _____	
Reply Optional []	Reply Required []	Info. Only []
Date Due: _____	Date Due: _____	

TO: Ed Palagyi
FROM: Teresa Heron *T.H.*
DATE: November 24, 1980
SUBJ: BACT Recommendation Container Corporation

This project is the construction of a 1021 MMBTU/hr power boiler (No. 7) to replace the existing power boiler No. 3, power boiler No. 6 and recovery boiler No. 3 at the applicant's mill located on Fernandina Beach.

I concur with the applicants NSPS emission limits and their proposed control technology as BACT.
The BACT are as follows:

SO₂
1.2¹lb/MMBTU

and low sulfur content
(0.75%_s) bituminous coal

Particulate Matter
0.1 lb/MMBTU

and the use of mechanical dust
collectors, followed by an
electrostatic precipitator.

NO
0.7^x1b/MMBTU

This will be accomplished by
minimizing excess air and staging
combustion via overfire and under-
fire air ratios.


Coal preparation and Handling

Enclose the coal unloading area

Employ baghouses on conveyor transfer points.

TH:dav

TWIN TOWERS OFFICE BUILDING
2600 BLAIR STONE ROAD
TALLAHASSEE, FLORIDA 32301



*Container
Permit file
(Bob King)*

file

BOB GRAHAM
GOVERNOR
JACOB D. VARN
SECRETARY

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

November 6, 1980

Mr. R.W. Galphin
General Manager
Container Corporation of
America
Fernandina Beach Mill Division
North Eight Street
Fernandina Beach, Florida 32034

Dear Mr. Galphin:

The Department has received your application for a permit to construct a new coal/wood waste boiler in Nassau County, Florida. Based on the initial review of your proposal, it has been determined that additional information is needed before we can process the application. The information required to complete the application is described below.

1. If the application includes coal preparation and handling facilities what are the potential and actual emission rates from the coal preparation and handling facilities?
2. What kind of fuel oil will be used for start ups and emergencies? Give analysis information for the fuel oil.

As soon as we receive the requested information, we will begin processing your application. If you have any questions on the data requested, please call Bob King at (904) 488-1344.


Sincerely,

Steve Smallwood

for

Steve Smallwood, Chief
Bureau of Air Quality Management

SS:dav



Lid
Sheet & cover paper

DER PERMIT APPLICATION TRACKING SYSTEM MASTER RECORD

FILE#00000000000000000000 DER PROCESSOR:HARKS DER OFFICE:TI
FILE NAME:CONTAINER CORR APPROVA DATE FIRST REC: 10/09/80 APPLICATION TYPE:
APPL NAME:RALPHIN, R.W. APPL PHONE:(904)241-5554 PROJECT COUNTY:
ADDR:N. 9TH ST. CITY:FERNANDINA BEACH ST:FLZIP:
AGNT NAME: GUSON, J.P. AGNT PHONE:(404)294-7575
ADDR:4329 MEMORIAL DRIVE CITY:DECATUR ST:GAZIP:300:

ADDITIONAL INFO REQ: / / / / / / / / / / / /
APPL COMPLETE DATE: / / COMMENTS REQ:Y DATE REC: / / DATE REC: / /
LETTER OF INTENT REQ: / DATE WHEN INTENT ISSUED: / / WAIVER DATE: / /

HEARING REQUEST DATES: / / / / / / / / / / / /
HEARING WITHDRAWN/REVOKED ORDER --- DATES: / / / / / / / / / / / /
HEARING ORDER OR FINAL ACTION DATE: / / / / / / / / / / / /

THIS RECORD HAS BEEN REFILED. ADDED 10/09/80 14:06:02
FEE PD DATE:10/09/80 RECEIPT#000033554 REFUND DATE: / / REFUND \$
FEE PD DATE: / / REFUND DATE: / / REFUND \$
APPL ACTION: TRANSFERRED TO 10/09/80 TRANSFERRED EXEMPT/ISSUED:AC DATE: 10/09/80
REMARKS: SEE EARL PERMIT # 8407136 / 8094.186H.

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

Nº 33554

RECEIPT FOR APPLICATION FEES AND MISCELLANEOUS REVENUE

Received from CONTAINER CORP Date 10/09/80
Address N. 9TH ST. FERNANDINA BEACH FL Dollars \$ 25.00
Applicant Name & Address STATE OF FLORIDA
Source of Revenue _____
Revenue Code 101 Application Number 10 45 - 1000
By M. K. H. H.