From: Bumar, Rich
To: Costello, Martin
Subject: RE: Public Notice of Intent to Issue Draft/Proposed Permits 0950111-032-AV and 0950111-033-AC/PSD-FL-109(A)
Date: Monday, November 26, 2012 3:18:11 PM

Marty,

I hope you had a great Thanksgiving holiday.

I noticed a few typos in the appendices on page 56. Here's what it says:

APPENDIX NESHAP – SUBPART YYYY

NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS FOR STATIONARY

COMBUSTIO N TURBINE S

Walt Disney Parks and Resorts U.S. Inc. Permit No. 0950111-032-AV

Walt Disney World Resort Complex Title V Air Operation Permit Renewal

Page NESHA P YYYY - 1 of 1

FEDERAL REGULATIONS ADOPTED BY REFERENCE

In accordance with Rule 62-204.800, F.A.C., the following federal regulation in Title 40 of the Code of Federal Regulations

(CFR) was adopted by reference.

40 CFR 63, Subpart YYYY - National Emissions Standards for Hazardous Air Pollutants for Stationary Combustion

Turbines

Applicability of NESHAP Subpart YYYY

The West County Energy Center is a major source of hazardous air pollutant emissions. As such, the new combustion turbines, Unit 1 and Unit 2, are subject to NESHAP 40 CFR 63, Subpart YYYY, which became final on March 5, 2004. According to the final rule, each unit is considered a —new lean premix gas-fired stationary combustion turbine. Therefore, each new combustion turbine is subject to an emissions standard for formaldehyde of no more than 91 parts per billion by volume, dry (ppbvd @ 15% O_2). Compliance must be demonstrated by initial and annual performance tests. In addition, acceptable operating parameters must be specified that show continuous compliance with the standard. These operating parameters must be continuously monitored that ensure continuous compliance.

Staying of the Rule

On August 18, 2004, the U.S. EPA stayed the effectiveness of 40 CFR 63, Subpart YYYY for lean premix gas turbines

such as Unit 1 and Unit 2 at the West County Energy Center. The following is the federal regulation amendment that stays the effectiveness of 40 CFR 63, Subpart YYYY:

§ 63.6095(d) Stay of standards for gas-fired subcategories.

If you start up a new or reconstructed stationary combustion turbine that is a lean premix gas-fired stationary combustion turbine or diffusion flame gas-fired stationary combustion turbine as defined by this subpart, you must comply with the Initial Notification requirements set forth in Sec. 63.6145 but need not comply with any other requirement of this subpart until EPA takes final action to require compliance and publishes a document in the

Federal Register.

I think maybe there was a cut and paste error here. Can we fix this so it references our facility?

Thanks,

Rich

Rich Bumar, P.E.
Environmental Engineer
Walt Disney World Resort • Environmental Control Dept. • Maingate Office Complex #2235

Phone: 407-390-5003 (tie line 8+298) • Fax: 407-938-7322/7325 and **407-390-5227** *• Mobile:321-278-6125 • DC:162*134*1071*