

# Memorandum

# Florida Department of Environmental Protection

---

TO: Trina Vielhauer, Bureau of Air Regulation  
THROUGH: Jon Holtom, Title V Section *JH*  
FROM: Tom Cascio *TC*  
DATE: February 3, 2010  
SUBJECT: Draft Air Construction Permit No. 0950137-030-AC  
Draft/Proposed Permit Revision No. 0950137-029-AV  
Orlando Utilities Commission, Stanton Energy Center

Attached for your review are the following items:

- Written Notice of Intent to Issue Air Permits;
- Public Notice of Intent to Issue Air Permits;
- Statement of Basis;
- Technical Evaluation and Preliminary Determination;
- Draft air construction permit and draft/proposed Title V air operation permit revision; and,
- P.E. Certification.

The air construction permit authorizes the removal of the monthly carbon monoxide continuous emissions monitoring system (CO-CEMS) reporting requirement for Units 1 and 2 for the Stanton Energy Center, which is located in Orange County, Florida. The draft/proposed Title V air operation permit revises the Title V permit for the Stanton Energy Center by incorporating applicable specific conditions from previously issued air construction permits No. 0950137-011-AC and No. 0950137-015-AC. The Statement of Basis provides a summary of the project and the rationale for issuance. The P.E. certification briefly summarizes the proposed project.

The application was received on November 24, 2009, and was deemed complete. Day 90 is February 22, 2010. According to the Central District Office, there is a Consent Order involving OUC currently under OGC review dealing with the company's missed compliance dates to apply for a Title V permit revision to incorporate the permit conditions from the two earlier AC permits mentioned above.

I recommend your approval of the attached draft construction permit and draft/proposed Title V air operation permit revision.

Attachments

**P.E. CERTIFICATION STATEMENT**

**PERMITTEE**

Orlando Utilities Commission  
P. O. Box 3193  
Orlando, FL 32802


Permit No. 0950137-030-AC  
Permit No. 0950137-029-AV  
Facility ID No. 0950137  
Stanton Energy Center  
Air Construction Permit  
Title V Air Operation Permit Revision  
Orange County, Florida


**PROJECT DESCRIPTION**

The purpose of this project is to issue an air construction permit and to revise the Title V air operation permit No. 0950137-027-AV. The air construction permit authorizes the removal of the monthly carbon monoxide continuous emissions monitoring system (CO-CEMS) reporting requirement for Units 1 and 2. The Title V air operation permit revision incorporates applicable specific conditions from previously issued air construction permits No. 0950137-011-AC and No. 0950137-015-AC.

***I HEREBY CERTIFY** that the air pollution control engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including, but not limited to, the electrical, mechanical, structural, hydrological, geological, and meteorological features).*

This review was conducted by Tom Cascio under my responsible supervision.

  
Jonathan K. Holtom, P.E.      Date: 2/2/10  
Registration Number: 0052664



# Florida Department of Environmental Protection

Bob Martinez Center  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Charlie Crist  
Governor

Jeff Kottkamp  
Lt. Governor

Michael W. Sole  
Secretary

*Electronic Mail – Received Receipt Requested*

Mr. Jan C. Aspuru, Vice President of Power Resources  
Orlando Utilities Commission  
P. O. Box 3193  
Orlando, Florida 32802

Re: Air Construction Permit No. 0950137-030-AC and  
Title V Air Operation Permit Revision No. 0950137-029-AV  
Stanton Energy Center

Dear Mr. Aspuru:

Enclosed is the draft/proposed permit package to issue an air construction permit and to revise the Title V air operation permit for the Stanton Energy Center. This facility is located in Orange County at 5100 South Alafaya Trail, Orlando, Florida. The permit package includes the following documents:

- The Technical Evaluation and Preliminary Determination, which establishes the basis for approving the requested changes made in the construction permit.
- The Statement of Basis, which summarizes the facility, the equipment, the primary rule applicability, and the changes included in this Title V permit revision.
- The draft construction permit and the draft/proposed Title V air operation permit revision, which includes the specific permit conditions that regulate the emissions units covered by the proposed project.
- The Written Notice of Intent to Issue Air Permits provides important information regarding: the Permitting Authority's intent to issue air permits for the proposed project; the requirements for publishing a Public Notice of the Permitting Authority's intent to issue air permits; the procedures for submitting comments on the draft/proposed permit; the process for filing a petition for an administrative hearing; and the availability of mediation.
- The Public Notice of Intent to Issue Air Permits is the actual notice that you must have published in the legal advertisement section of a newspaper of general circulation in the area affected by this project. The Public Notice of Intent to Issue Title V Air Permits must be published as soon as possible and the original proof of publication affidavit must be provided to the Department within seven days of the date of publication.

If you have any questions, please contact the Project Engineer, Tom Cascio by telephone at (850) 921-9526 or by email at [tom.cascio@dep.state.fl.us](mailto:tom.cascio@dep.state.fl.us).

Sincerely,

Trina L. Vielhauer, Chief  
Bureau of Air Regulation

2/4/10  
Date

Enclosures  
TLV/jkh/tbc

**WRITTEN NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT AND TITLE V AIR  
OPERATION PERMIT REVISION**

---

*In the Matter of an*

*Application for Air Construction Permit and Title V Air Operation Permit Revision by:*

Orlando Utilities Commission  
P. O. Box 3193, Orlando, FL 32802

Permit No. 0950137-029-AV  
Permit No. 0950137-030-AC  
Facility ID No. 0950137  
Stanton Energy Center  
Air Construction Permit  
Title V Air Operation Permit Revision  
Orange County, Florida

*Responsible Official:*

Mr. Jan C. Aspuru, Vice President of Power  
Resources

**Facility Location:** Orlando Utilities Commission operates the existing Stanton Energy Center, which is located in Orange County at 5100 South Alafaya Trail, Orlando, Florida.

**Project:** The purpose of this project is to issue an air construction permit and to revise the Title V air operation permit No. 0950137-027-AV. The air construction permit authorizes the removal of the monthly carbon monoxide continuous emissions monitoring system (CO-CEMS) reporting requirement for Units 1 and 2. The Title V air operation permit revision incorporates applicable specific conditions from previously issued air construction permits No. 0950137-011-AC and No. 0950137-015-AC. Details of the project are provided in the application and the enclosed Statement of Basis.

**Permitting Authority:** Applications for air construction permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210 and 62-212 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and an air permit is required to perform the proposed work.

Applications for Title V air operation permits for facilities that contain Acid Rain units are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, 62-213 and 62-214 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and a Title V air operation permit is required to operate the facility. The Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination for this project. The Permitting Authority's physical address is: 111 South Magnolia Drive, Suite #4, Tallahassee, Florida. The Permitting Authority's mailing address is: 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Permitting Authority's telephone number is 850/488-0114.

**Project File:** A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at the address indicated above for the Permitting Authority. The complete project file includes the Technical Evaluation And Preliminary Determination, the draft/proposed permits, the Statement of Basis, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may view the draft permits by visiting the following website: <http://www.dep.state.fl.us/air/emission/apds/default.asp> and entering the permit number shown above. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address or phone number listed above.

**Notice of Intent to Issue Permits:** The Permitting Authority gives notice of its intent to issue an air construction permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of the proposed equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a final permit in accordance with the conditions of the proposed draft air construction permit unless a timely petition for an administrative hearing is filed under Sections 120.569 and

**WRITTEN NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT AND TITLE V AIR  
OPERATION PERMIT REVISION**

---

120.57, F.S. or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.

The Permitting Authority gives notice of its intent to issue a revised Title V air operation permit to the applicant for the project described above. The applicant has provided reasonable assurance that continued operation of the existing equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a final permit revision in accordance with the conditions of the draft/proposed permit revision unless a response received in accordance with the following procedures results in a different decision or a significant change of terms or conditions.

**Public Notice:** Pursuant to Section 403.815, F.S. and Rules 62-110.106 and 62-210.350, F.A.C., you (the applicant) are required to publish at your own expense the enclosed Public Notice of Intent to Issue Air Permits (Public Notice). The Public Notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected by this project. The newspaper used must meet the requirements of Sections 50.011 and 50.031, F.S. in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the Permitting Authority at the above address or phone number. Pursuant to Rule 62-110.106(5) and (9), F.A.C., the applicant shall provide proof of publication to the Permitting Authority at the above address within 7 days of publication. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rule 62-110.106(11), F.A.C.

**Comments:** The Permitting Authority will accept written comments concerning the draft air construction permit for a period of 14 days from the date of publication of the Public Notice. Written comments must be received by the Permitting Authority by close of business (5:00 p.m.) on or before the end of this 14-day period. If written comments received result in a significant change to the draft air construction permit modification, the Permitting Authority shall revise the draft air construction permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.

The Permitting Authority will accept written comments concerning the draft/proposed Title V air operation permit revision for a period of 30 days from the date of publication of the Public Notice. Written comments must be received by the close of business (5:00 p.m.), on or before the end of this 30-day period by the Permitting Authority at the above address. As part of his or her comments, any person may also request that the Permitting Authority hold a public meeting on this permitting action. If the Permitting Authority determines there is sufficient interest for a public meeting, it will publish notice of the time, date, and location in the Florida Administrative Weekly (FAW). If a public meeting is requested within the 30-day comment period and conducted by the Permitting Authority, any oral and written comments received during the public meeting will also be considered by the Permitting Authority. If timely received written comments or comments received at a public meeting result in a significant change to the draft/proposed permit, the Permitting Authority shall issue a revised draft/proposed permit revision and require, if applicable, another Public Notice. All comments filed will be made available for public inspection. For additional information, contact the Permitting Authority at the above address or phone number.

**Petitions:** A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by the applicant or any of the parties listed below must be filed within 14 days of receipt of this Written Notice of Intent to Issue Air Permit. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within 14 days of publication of the attached Public Notice or within 14 days of receipt of this Written Notice of Intent to Issue Air

**WRITTEN NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT AND TITLE V AIR  
OPERATION PERMIT REVISION**

---

Permit, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of when and how each petitioner received notice of the agency action or proposed decision; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Written Notice of Intent to Issue Air Permit. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

**Mediation:** Mediation is not available in this proceeding.

**EPA Review:** EPA has agreed to treat the draft/proposed Title V air operation permit revision as a proposed Title V air operation permit revision and to perform its 45-day review provided by the law and regulations concurrently with the public comment period. Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day review period is performed after the public comment period has ended. The final Title V air operation permit will be issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that result in a different decision or significant change of terms or conditions. The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following website address:  
<http://www.epa.gov/region4/air/permits/Florida.htm>.


**Objections:** Finally, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 days of the expiration of the Administrator's 45-day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to the issuance of any Title V air operation permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30-day public comment period provided in the Public Notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not

**WRITTEN NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT AND TITLE V AIR  
OPERATION PERMIT REVISION**

---

stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460. For more information regarding EPA review and objections, visit EPA's Region 4 web site at <http://www.epa.gov/region4/air/permits/Florida.htm> .

Executed in Tallahassee, Florida.



---

Trina L. Vielhauer, Chief  
Bureau of Air Regulation





**PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT AND TITLE V AIR  
OPERATION PERMIT REVISION**

---

Florida Department of Environmental Protection  
Division of Air Resource Management, Bureau of Air Regulation  
Draft Air Construction Permit No. 0950137-030-AC  
Draft/Proposed Air Operation Permit Revision No. 0950137-029-AV  
Orlando Utilities Commission, Stanton Energy Center  
Orange County, Florida

**Applicant:** The applicant for this project is the Orlando Utilities Commission. The applicant's responsible official and mailing address are: Mr. Jan C. Aspuru, Vice President of Power Resources, Orlando Utilities Commission, Stanton Energy Center, P. O. Box 3193, Orlando, FL 32802.

**Facility Location:** The applicant operates the existing Stanton Energy Center, which is located in Orange County at 5100 South Alafaya Trail in Orlando, Florida.

**Project:** The applicant applied on November 24, 2009, to the Department for an air construction permit and a revision of Title V air operation permit No. 0950137-027-AV. The air construction permit authorizes the removal of the monthly carbon monoxide continuous emissions monitoring system (CO-CEMS) reporting requirement for Units 1 and 2. The Title V air operation permit revision incorporates applicable specific conditions from previously issued air construction permits No. 0950137-011-AC and No. 0950137-015-AC. The existing facility consists of two fossil fuel fired steam electric generating stations, an auxiliary boiler, two combined-cycle combustion turbines, and solid fuels, fly ash, limestone, gypsum, slag, and bottom ash storage and handling facilities.

**Permitting Authority:** Applications for air construction permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210 and 62-212 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and an air permit is required to perform the proposed work. The Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination for this project.

Applications for Title V air operation permits for facilities that contain Acid Rain units are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, 62-213 and 62-214 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and a Title V air operation permit is required to operate the facility. The Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination for this project. The Permitting Authority's physical address is: 111 South Magnolia Drive, Suite #4, Tallahassee, Florida. The Permitting Authority's mailing address is: 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Permitting Authority's telephone number is 850/488-0114.

**Project File:** A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at the address indicated above for the Permitting Authority. The complete project file includes the draft air construction permit, the draft/proposed air operation permit revision, the Statement of Basis, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may view the draft air construction permit and draft/proposed air operation permit revision by visiting the following website: <http://www.dep.state.fl.us/air/emission/apds/default.asp> and entering the permit numbers shown above. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address or phone number listed above.

**Notice of Intent to Issue Permits:** The Permitting Authority gives notice of its intent to issue an air construction permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of proposed equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a final permit in accordance with the conditions of the draft air construction

**(Public Notice to be Published in the Newspaper)**

**PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT AND TITLE V AIR  
OPERATION PERMIT REVISION**

---

permit unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, F.S. or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.

The Permitting Authority gives notice of its intent to issue a revised Title V air operation permit to the applicant for the project described above. The applicant has provided reasonable assurance that continued operation of the existing equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a final permit in accordance with the conditions of the draft/proposed permit revision unless a response received in accordance with the following procedures results in a different decision or a significant change of terms or conditions.

**Comments:** The Permitting Authority will accept written comments concerning the draft air construction permit for a period of 14 days from the date of publication of the Public Notice. Written comments must be received by the Permitting Authority by close of business (5:00 p.m.) on or before the end of this 14-day period. If written comments received result in a significant change to the draft air construction permit, the Permitting Authority shall revise the draft air construction permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.

The Permitting Authority will accept written comments concerning the draft/proposed Title V air operation permit revision for a period of 30 days from the date of publication of the Public Notice. Written comments must be received by the close of business (5:00 p.m.), on or before the end of this 30-day period by the Permitting Authority at the above address. As part of his or her comments, any person may also request that the Permitting Authority hold a public meeting on this permitting action. If the Permitting Authority determines there is sufficient interest for a public meeting, it will publish notice of the time, date, and location in the Florida Administrative Weekly (FAW). If a public meeting is requested within the 30-day comment period and conducted by the Permitting Authority, any oral and written comments received during the public meeting will also be considered by the Permitting Authority. If timely received written comments or comments received at a public meeting result in a significant change to the draft/proposed permit revision, the Permitting Authority shall issue a revised draft/proposed permit revision and require, if applicable, another Public Notice. All comments filed will be made available for public inspection. For additional information, contact the Permitting Authority at the above address or phone number.

**Petitions:** A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S. must be filed within 14 days of publication of the Public Notice or receipt of a written notice, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address and telephone number of the petitioner; the name address and telephone number of the petitioner's representative, if any, which shall be the address for service

**(Public Notice to be Published in the Newspaper)**

**PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT AND TITLE V AIR  
OPERATION PERMIT REVISION**

---

purposes during the course of the proceeding; and an explanation of how the petitioner's substantial rights will be affected by the agency determination; (c) A statement of when and how the petitioner received notice of the agency action or proposed decision; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Public Notice of Intent to Issue Air Permit. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

**Mediation:** Mediation is not available for this proceeding.

**EPA Review:** EPA has agreed to treat the draft/proposed Title V air operation permit revision as a proposed Title V air operation permit revision and to perform its 45-day review provided by the law and regulations concurrently with the public comment period. Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day review period is performed after the public comment period has ended. The final Title V air operation permit will be issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that results in a different decision or significant change of terms or conditions. The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following website address:  
<http://www.epa.gov/region4/air/permits/Florida.htm>.

**Objections:** Finally, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 days of the expiration of the Administrator's 45-day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to the issuance of any Title V air operation permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30-day public comment period provided in the Public Notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460. For more information regarding EPA review and objections, visit EPA's Region 4 web site at <http://www.epa.gov/region4/air/permits/Florida.htm>.

**TECHNICAL EVALUATION  
AND  
PRELIMINARY DETERMINATION**

Orlando Utilities Commission  
Curtis H. Stanton Energy Center Units 1 & 2

**Removal of Monthly CO-CEMS Report Requirement**  
Orange County

DEP File No. 0950137-030-AC



Florida Department of Environmental Protection  
Division of Air Resource Management  
Bureau of Air Regulation  
Title V Section

February 3, 2010

**1. GENERAL PROJECT INFORMATION**

**Air Pollution Regulations**

Projects at stationary sources with the potential to emit air pollution are subject to the applicable environmental laws specified in Section 403 of the Florida Statutes (F.S.). The statutes authorize the Department of Environmental Protection (Department) to establish regulations regarding air quality as part of the Florida Administrative Code (F.A.C.), which includes the following applicable chapters: 62-4 (Permits); 62-204 (Air Pollution Control – General Provisions); 62-210 (Stationary Sources – General Requirements); 62-212 (Stationary Sources – Preconstruction Review); 62-213 (Operation Permits for Major Sources of Air Pollution); 62-296 (Stationary Sources - Emission Standards); and 62-297 (Stationary Sources – Emissions Monitoring). Specifically, air construction permits are required pursuant to Rules 62-4, 62-210 and 62-212, F.A.C.

In addition, the U. S. Environmental Protection Agency (EPA) establishes air quality regulations in Title 40 of the Code of Federal Regulations (CFR). Part 60 specifies New Source Performance Standards (NSPS) for numerous industrial categories. Part 61 specifies National Emission Standards for Hazardous Air Pollutants (NESHAP) based on specific pollutants. Part 63 specifies NESHAP based on the Maximum Achievable Control Technology (MACT) for numerous industrial categories. The Department adopts these federal regulations on a quarterly basis in Rule 62-204.800, F.A.C.

**Facility Description and Location**

The Orlando Utilities Commission (OUC) operates the Curtis H. Stanton Energy Center (OUC Stanton), which is categorized under Standard Industrial Classification Code No. 4911, Electrical Services. OUC Stanton is located in Orange County at 5100 South Alafaya Trail. The UTM coordinates of the existing facility are 483.50 km East and 3150.60 North. The location of the OUC Stanton Energy Center is shown in Figure 1.



**Figure 1 - OUC Stanton Location.**



**Figure 2 - OUC Stanton Units 1 and 2.**

This site is in an area that is in attainment (or designated as unclassifiable) for all air pollutants subject to state and federal Ambient Air Quality Standards (AAQS).

**Facility Regulatory Categories**

- The facility is not a potential major source of hazardous air pollutants (HAP).
- The facility operates existing units subject to the acid rain provisions of the Clean Air Act.
- The facility is a Title V major source of air pollution in accordance with Chapter 213, F.A.C.

---

## TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

---

- The facility is a major stationary source in accordance with Rule 62-212.400, F.A.C. for the Prevention of Significant Deterioration (PSD) of Air Quality.
- The facility is subject to the Clean Air Interstate Rule (CAIR) set forth in Rule 62-296.470, Florida Administrative Code (F.A.C.).
- The facility operates units subject to the Standards of Performance for New Stationary Sources (NSPS) pursuant to 40 CFR Part 60.
- The facility was originally certified pursuant to the power plant siting provisions of Chapter 62-17, F.A.C.

### Project Description

OUC Stanton consists of two bottom fired, fossil fuel steam electrical generating units (Stanton 1 and 2) and two combined cycle units. Stanton 1 and 2 (shown in Figure 2 above) began operation in 1987 and 1996 respectively and each is rated at 468 megawatts (MW). Coal is the primary fuel used in Stanton 1 and 2.

The project under this permit is for the removal of the monthly carbon monoxide continuous emissions monitoring system (CO-CEMS) reporting requirement for Units 1 and 2 that was previously established by air construction permit No. 0950137-015-AC.

Any further heat input data can be obtained independently. Therefore, the above mentioned CO-CEMS report is no longer needed.

## 2. PSD APPLICABILITY

### General PSD Applicability

For areas currently in attainment with the state and federal AAQS or areas otherwise designated as unclassifiable, the Department regulates major stationary sources of air pollution in accordance with Florida's PSD preconstruction review program as defined in Rule 62-212.400, F.A.C. Under preconstruction review, the Department first must determine if a project is subject to the PSD requirements ("PSD applicability review") and, if so, must conduct a PSD preconstruction review. A PSD applicability review is required for projects at new and existing major stationary sources. In addition, proposed projects at existing minor sources are subject to a PSD applicability review to determine whether potential emissions *from the proposed project itself* will exceed the PSD major stationary source thresholds. A facility is considered a major stationary source with respect to PSD if it emits or has the potential to emit:

- 5 tons per year or more of lead;
- 250 tons per year or more of any regulated air pollutant; or
- 100 tons per year or more of any regulated air pollutant and the facility belongs to one of the following 28 PSD-major facility categories: fossil fuel-fired steam electric plants of more than 250 million British thermal units per hour heat input, coal cleaning plants (with thermal dryers), Kraft pulp mills, Portland cement plants, primary zinc smelters, iron and steel mill plants, primary aluminum ore reduction plants, primary copper smelters, municipal incinerators capable of charging more than 250 tons of refuse per day, hydrofluoric, sulfuric, and nitric acid plants, petroleum refineries, lime plants, phosphate rock processing plants, coke oven batteries, sulfur recovery plants, carbon black plants (furnace process), primary lead smelters, fuel conversion plants, sintering plants, secondary metal production plants, chemical process plants, fossil fuel boilers (or combinations thereof) totaling more than 250 million British thermal units per hour heat input, petroleum storage and transfer units with a total storage capacity exceeding 300,000 barrels, taconite ore processing plants, glass fiber processing plants and charcoal production plants.

## TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

---

Once it is determined that a project is subject to PSD preconstruction review, the project emissions are compared to the "significant emission rates" defined in Rule 62-210.200, F.A.C. for the following pollutants: carbon monoxide (CO); nitrogen oxides (NO<sub>x</sub>); sulfur dioxide (SO<sub>2</sub>); particulate matter (PM); particulate matter with a mean particle diameter of 10 microns or less (PM<sub>10</sub>); volatile organic compounds (VOC); lead (Pb); fluorides (F); sulfuric acid mist (SAM); hydrogen sulfide (H<sub>2</sub>S); total reduced sulfur (TRS), including H<sub>2</sub>S; reduced sulfur compounds, including H<sub>2</sub>S; municipal waste combustor organics measured as total tetra- through octa-chlorinated dibenzo-p-dioxins and dibenzofurans; municipal waste combustor metals measured as particulate matter; municipal waste combustor acid gases measured as SO<sub>2</sub> and hydrogen chloride (HCl); municipal solid waste landfills emissions measured as non-methane organic compounds (NMOC); and mercury (Hg). In addition, significant emissions rate also means any emissions rate or any net emissions increase associated with a major stationary source or major modification which would construct within 10 kilometers of a Class I area and have an impact on such area equal to or greater than 1 µg/m<sup>3</sup>, 24-hour average.

If the potential emission exceeds the defined significant emissions rate of a PSD pollutant, the project is considered "significant" for the pollutant and the applicant must employ the Best Available Control Technology (BACT) to minimize the emissions and evaluate the air quality impacts. Although a facility or project may be *major* with respect to PSD for only one regulated pollutant, it may be required to install BACT controls for several "significant" regulated pollutants.

### **PSD Applicability for Project and Conclusion**

This project has no affect on actual or potential pollutant emissions levels from the Stanton Energy Center. Therefore, the Department agrees to make the requested change, and the permittee is relieved of the responsibility of submitting the report referenced above. As a corollary action, the original implementing specific condition is deleted from previously issued air construction permit 0950137-015-AC.

# DRAFT

**PERMITTEE:**

Orlando Utilities Commission (OUC)  
500 South Orange Avenue  
Orlando, Florida 32802

*Authorized Representative:*

Mr. Jan C. Aspuru, Vice President  
Power Resources

DEP File No. 0950137-030-AC  
Curtis H. Stanton Energy Center  
Stanton Units 1 and 2  
SIC No. 4911

Removal of Monthly CO-CEMS Report Requirement  
Orange County, Florida

Permit Expires: July 1, 2010

**PROJECT AND LOCATION**

This permit authorizes the removal of the monthly carbon monoxide continuous emissions monitoring system (CO-CEMS) reporting requirement for Units 1 and 2 at the OUC Curtis H. Stanton Energy Center. The facility is located at 5100 South Alafaya Trail, Orlando, Orange County. Universal Transverse Mercator (UTM) Coordinates are: Zone 17, 483.50 km East and 3150.60 km North.

This final permit is organized into the following sections: Section 1 (General Information); Section 2 (Administrative Requirements); Section 3 (Emissions Unit Specific Conditions); Section 4 (Appendix CG – General Conditions).

**STATEMENT OF BASIS**

This air pollution construction permit is issued under the provisions of: Chapter 403 of the Florida Statutes (F.S.) and Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297 of the Florida Administrative Code (F.A.C.). The permittee is authorized to conduct the proposed work in accordance with the conditions of this permit. This project is subject to the general preconstruction review requirements in Rule 62-212.300, F.A.C. and is not subject to the preconstruction review requirements for major stationary sources in Rule 62-212.400, F.A.C. for the Prevention of Significant Deterioration (PSD) of Air Quality.

Upon issuance of this final permit, any party to this order has the right to seek judicial review of it under Section 120.68 of the Florida Statutes by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within 30 days after this order is filed with the clerk of the Department.

(DRAFT)

\_\_\_\_\_  
Joseph Kahn, Director  
Division of Air Resource Management

\_\_\_\_\_  
(Date)



## SECTION 1. GENERAL INFORMATION

### FACILITY AND PROJECT DESCRIPTION

The existing facility consists of two 468 megawatt (MW) fossil fuel fired steam electric generating units (Units 1 and 2), and one 640 MW combined cycle unit. There are storage and handling facilities for solid fuels, fly ash, limestone, gypsum, slag, and bottom ash. A recently permitted nominal 285 MW integrated gasification and combined cycle unit (Unit B) is under construction and will be operational by 2012.

As noted above, the project under this permit is for the removal of the monthly carbon monoxide continuous emissions monitoring system (CO-CEMS) reporting requirement for Units 1 and 2 that was previously established by air construction permit No. 0950137-015-AC. The Project Administrator of the Special Projects Section of the Bureau of Air Regulation has indicated that evaluation of the permittee's CO/NO<sub>x</sub> data has been completed, and that we will rely on our Emissions Monitoring Section to provide heat input data if needed. Therefore, the above mentioned CO-CEMS report is no longer needed.

EU ID	Emissions Unit Description
001	Fossil Fuel Fired Steam Electric Generator No. 1
002	Fossil Fuel Fired Steam Electric Generator No. 2

### REGULATORY CLASSIFICATION

The facility is not a major source of hazardous air pollutants (HAP).

The facility operates existing units subject to the Acid Rain provisions of Title IV of the Clean Air Act (CAA).

The facility is a Title V major source of air pollution in accordance with Chapter 213, Florida Administrative Code (F.A.C.).

The facility is a major Prevention of Significant Deterioration (PSD) stationary source in accordance with Rule 62-212.400, F.A.C.

The facility operates units subject to the Standards of Performance for New Stationary Sources pursuant to 40 CFR Part 60.

The facility does not operate electrical generating units subject to National Emissions Standards for Hazardous Air Pollutants pursuant to 40 Code of Federal Regulations (CFR) Part 63.

The facility is subject to the Federal Clean Air Interstate Rule (CAIR) in accordance with the Final Department Rules issued pursuant to CAIR as implemented by the Department in Rule 62-296.470, F.A.C.

The facility operates units that were certified under the Florida Power Plant Siting Act, 403.501-518, F.S.

### RELEVANT DOCUMENTS

The following relevant documents are not a part of this permit, but helped form the basis for this permitting action: the permit application and additional information received to make it complete; and the Department's Technical Evaluation and Preliminary Determination.

## SECTION 2. ADMINISTRATIVE REQUIREMENTS

---

1. Permitting Authority: The Permitting Authority for this project is the Bureau of Air Regulation in the Division of Air Resource Management of the Department. The mailing address for the Bureau of Air Regulation is 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400.
2. Compliance Authority: All documents related to compliance activities such as reports, tests, and notifications shall be submitted to the Central District Office. The mailing address and phone number of the Central District Office are: Department of Environmental Protection, Central District Office, 3319 Maguire Boulevard, Suite 232, Orlando Florida 32803-3767. Telephone: (407)894-7555. Fax: (407)897-5963.
3. Appendix: The following Appendix is attached as part of this permit: Appendix GC (General Conditions).
4. Applicable Regulations, Forms and Application Procedures: Unless otherwise specified in this permit, the construction and operation of the subject emissions units shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of: Chapter 403, F.S.; and Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296, and 62-297, F.A.C. Issuance of this permit does not relieve the permittee from compliance with any applicable federal, state, or local permitting or regulations.
5. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
6. Modifications: No emissions unit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification. [Rules 62-210.300(1) and 62-212.300(1)(a), F.A.C.]

### SECTION 3. EMISSIONS UNITS SPECIFIC CONDITIONS

This section of the permit addresses the following existing emissions units.

#### Emissions Units 001 and 002

Fossil Fuel Fired Steam Generators 1 and 2 are wall-fired, dry bottom boilers, firing pulverized coal as the primary fuel and No. 6 fuel oil for purposes of startup and flame stabilization. Each unit has a maximum heat input rate of 4,286 million British thermal units (MMBtu) per hour with a nominal generating capacity of 468 megawatts (MW). Each unit is equipped with an electrostatic precipitator (ESP) for control of particulate matter (PM/PM<sub>10</sub>), a wet flue gas desulfurization (WFGD) system for sulfur dioxide (SO<sub>2</sub>) control, and low-NO<sub>x</sub> burners for nitrogen oxides (NO<sub>x</sub>) control. Unit 2 is also equipped with a selective catalytic reduction (SCR) system for further control of NO<sub>x</sub> emissions. The following parameters are continuously monitored on both units: NO<sub>x</sub>, opacity, SO<sub>2</sub>, carbon dioxide (CO<sub>2</sub>), and stack gas flow rate.

#### APPLICABLE STANDARDS AND REGULATIONS

1. Issuance of this permit does not relieve the facility owner or operator from compliance with any applicable federal, state, or local permitting requirements or regulations. [Rule 62-210.300, F.A.C.]
2. Except as specified below, the facility remains subject to all of the requirements contained in all previously issued air construction permits for this facility. These requirements are reflected in Title V Air Operation Permit Renewal No. 0950137-027-AV.

#### REPORTING AND RECORD KEEPING REQUIREMENTS

3. The following specific condition from permit No. 0950137-015-AC is deleted:

~~21. Monthly CO-CEMS Report: Upon certification of the CO-CEMS the permittee shall submit, on a monthly basis, a report in electronic file format which includes Unit 1 and Unit 2 CO, NO<sub>x</sub>, and heat input data. The report shall be submitted by the 15<sup>th</sup> of each month by mailing a compact disc to the Department's Bureau of Air Regulation Permitting South Section and shall include all hourly readings from the previous month. Alternatively, upon contacting the Bureau's project engineer, the file may be emailed to the appropriate Bureau personnel.~~

## APPENDIX GC – GENERAL CONDITIONS

---

The permittee shall comply with the following general conditions from Rule 62-4.160, F.A.C.

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
  - a. Have access to and copy and records that must be kept under the conditions of the permit;
  - b. Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
  - c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
  - a. A description of and cause of non-compliance; and

## APPENDIX GC – GENERAL CONDITIONS

---

- b. The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
12. This permit or a copy thereof shall be kept at the work site of the permitted activity.
13. This permit also constitutes:
  - a. Determination of Best Available Control Technology (Not Applicable);
  - b. Determination of Prevention of Significant Deterioration (Not Applicable);
  - c. Compliance with National Emission Standards for Hazardous Air Pollutants (Not Applicable); and
  - d. Compliance with New Source Performance Standards (Not Applicable).
14. The permittee shall comply with the following:
  - a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
  - b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
  - c. Records of monitoring information shall include:
    - 1) The date, exact place, and time of sampling or measurements;
    - 2) The person responsible for performing the sampling or measurements;
    - 3) The dates analyses were performed;
    - 4) The person responsible for performing the analyses;
    - 5) The analytical techniques or methods used; and
    - 6) The results of such analyses.

When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

## STATEMENT OF BASIS

---

Orlando Utilities Commission, Stanton Energy Center  
Title V Air Operation Permit Revision  
Permit Revision No. 0950137-029-AV

### APPLICANT

The applicant for this project is the Orlando Utilities Commission. The applicant's responsible official and mailing address are: Mr. Jan C. Aspuru, Vice President of Power Resources, Orlando Utilities Commission, Stanton Energy Center, P. O. Box 3193, Orlando, FL 32802.

### FACILITY DESCRIPTION

The applicant operates the existing Stanton Energy Center, which is located in Orange County at 5100 South Alafaya Trail, Orlando, Florida 32193.

This facility consists primarily of two fossil fuel fired steam electric generating stations, an auxiliary boiler, two combined-cycle combustion turbines, and solid fuels, fly ash, limestone, gypsum, slag, and bottom ash storage and handling facilities.

Fossil fuel fired steam generator #1 (Unit No. 1) consists of a Babcock and Wilcox boiler/steam generator (Model RB 611) and steam turbine which drives a generator with a nameplate rating of 468 megawatts. Unit No. 1 is fired primarily on bituminous coal and secondarily on No. 6 fuel oil for startup and flame stabilization, as permitted herein, with a maximum heat input of 4286 MMBtu per hour. Pipeline quality natural gas as well as landfill gas is also approved for combustion, although petroleum coke is not approved. Fossil fuel fired steam generator #2 (Unit No. 2) consists of a Babcock and Wilcox boiler/steam generator (Model RB 621) and steam turbine which drives a generator with a nameplate rating of 468 megawatts. Unit No. 2 is fired primarily on bituminous coal and secondarily on No. 6 fuel oil and on-specification used oil for startup and flame stabilization, as permitted herein, with a maximum heat input of 4286 MMBtu per hour. Pipeline quality natural gas as well as landfill gas is also approved for combustion, although petroleum coke is not approved. Each boiler/steam generator is a wall fired dry bottom unit. An auxiliary boiler, which serves both boilers and has a maximum heat input of 83 MMBtu/hour, is located at the facility. The auxiliary boiler is fired with No. 2 distillate fuel oil.

Each boiler/steam generator (units #1 and #2) drives a turbine generator and each unit has an individual 550-foot exhaust stack. Particulate matter emissions generated during the operation of the unit are controlled by a dry electrostatic precipitator (ESP) manufactured by Wheelabrator-Frye Inc. The control efficiency of the ESP is 99.7%. Sulfur dioxide emissions are controlled by flue gas desulfurization equipment manufactured by Combustion Engineering.

Both boiler/steam generators (units #1 and #2) are regulated under the federal Acid Rain Program, Phase II, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; and NSPS-40 CFR 60, Subpart Da, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After September 18, 1978, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT). Fossil fuel fired steam generator # 1 began commercial operation on May 12, 1987; and, fossil fuel fired steam generator # 2 began commercial operation on March 29, 1996. Due to the many (nearly 9) years of time which elapsed between the startup of these units, the PSD requirements are different, reflecting improvements in available control technology. Generally speaking, the emission limits for unit #2 are more stringent than those for unit #1, as can be seen from the permitted SO<sub>2</sub> and NO<sub>x</sub> emission rates.

The auxiliary boiler is designated as Unit No. 3. The unit is a Babcock & Wilcox Model No. FM-2919 boiler. It is fired primarily with "new oil", which means oil which has been refined from crude oil and has not been used. Only No. 2 fuel oil can be burned in the auxiliary boiler. This auxiliary boiler serves both Unit No. 1 and 2 boiler/steam generators. The emission unit is regulated under Rule 62-210.300, F.A.C., Permits Required.

Fly Ash Silos No. 1 and No. 2 handle fly ash from Steam Generators No. 1 and No. 2 respectively. Fly ash is pneumatically conveyed from the individual electrostatic precipitators to Silos No. 1 and No. 2 and then is gravity

## STATEMENT OF BASIS

---

fed by tubing into totally enclosed tanker trucks. Particulate matter emissions generated by silo loading and unloading to a tanker truck is controlled by baghouses in addition to reasonable precautions. The emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required.

Emission units 025 and 026 are nominal 170 MW, General Electric "F" Class (PG7241FA) combined-cycle combustion turbine-electrical generators, fired with pipeline natural gas or diesel and equipped with evaporative coolers on the inlet air system, two supplementary fired heat recovery steam generators (HRSG), each with a 160 ft. stack, and one steam turbine-electrical generator rated at approximately 300 MW. The combustion turbines are equipped with Dry Low NO<sub>x</sub> combustors as well as a selective catalytic reduction (SCR) system in order to control NO<sub>x</sub> emissions to 3.5 ppmvd at 15% O<sub>2</sub> while firing natural gas. During fuel oil firing, emissions shall be held to 10 ppmvd at 15% O<sub>2</sub> using SCR plus water injection. Pipeline quality natural gas, 0.05% sulfur oil, and good combustion practices shall be employed to control all pollutants. Units 25 and 26 have a total nominal capacity of 640 MW and will achieve approximately 700 megawatts during extreme winter peaking conditions.

Also included in this permit are miscellaneous unregulated/insignificant emissions units and/or activities.

### PROJECT DESCRIPTION

The purpose of this permitting project is to revise the existing Title V permit for the above referenced facility. See Project Review discussion below.

### PROCESSING SCHEDULE AND RELATED DOCUMENTS

Application for a Title V Air Operation Permit Revision received November 24, 2009.

### PRIMARY REGULATORY REQUIREMENTS

Title III: The facility is not identified as a major source of hazardous air pollutants (HAP).

Title IV: The facility operates units subject to the acid rain provisions of the Clean Air Act.

Title V: The facility is a Title V major source of air pollution in accordance with Chapter 62-213, Florida Administrative Code (F.A.C.).

PSD: The facility is a Prevention of Significant Deterioration (PSD)-major source of air pollution in accordance with Rule 62-212.400, F.A.C.

NSPS: The facility operates units subject to the New Source Performance Standards (NSPS) of 40 Code of Federal Regulations (CFR) 60.

CAIR: The facility is subject to the Clean Air Interstate Rule (CAIR) set forth in Rule 62-296.470, F.A.C.

Siting: Units 001, 002 and 003 were originally certified pursuant to the power plant siting provisions of Chapter 62-17, F.A.C.

CAM: Compliance Assurance Monitoring (CAM) does apply to units at the facility. Emission Units 1 and 2 are subject to CAM for particulate matter (PM) emissions controlled by an ESP. Because the continuous opacity monitoring system (COMS) is required to be used at the facility (for Phase II Acid Rain Program purposes), it must also be used as part of the CAM plan. A CAM plan is included for the ESP. The combustion turbines are not subject to CAM because the NO<sub>x</sub> CEMS is used for continuous compliance determination. Thus no CAM plan is included for these units in this permit.

### PROJECT REVIEW

This Title V air operation permit revision incorporates the applicable specific conditions from previously issued air construction permits No. 0950137-011-AC and No. 0950137-015-AC.

Changes made to the permit document are as follows (deletions are noted in ~~striketrough~~ and additions are noted in double underline).

Changes to Emissions Unit 1 and Unit 2 Description.

## STATEMENT OF BASIS

Fossil fuel fired steam generator # 1 is a nominal 468 megawatt steam generator designated as Unit # 1. The emission unit is fired primarily on bituminous coal and secondarily on No. 6 fuel oil for startup and flame stabilization, as permitted herein, with a maximum heat input of 4286 MMBtu per hour. Stack height is 550 feet, stack exit diameter is 19.0 feet, flow rate is 1,420,000 actual cubic feet per minute (acfm) at 127 degrees Fahrenheit, stack exit velocity is 83.5 feet per second.

Fossil fuel fired steam generator # 2 is a nominal 468 megawatt steam generator designated as Unit # 2. The emission unit is fired primarily on bituminous coal and secondarily on No. 6 fuel oil and on-specification used oil for startup and flame stabilization, as permitted herein, with a maximum heat input of 4286 MMBtu per hour. Stack height is 550 feet, stack exit diameter is 19.0 feet, flow rate is 1,310,120 acfm at 124 degrees Fahrenheit, stack exit velocity is 77.0 feet per second.

Each boiler/steam generator, units #1 and #2, drives a turbine generator and both units have an individual 550 foot exhaust stack. Particulate matter emissions generated during the operation of the unit are controlled by a dry electrostatic precipitator (ESP) manufactured by Wheelabrator-Frye Inc. The control efficiency of the ESP is 99.7%. Sulfur dioxide emissions are controlled by wet scrubber flue gas desulfurization (WFGD) equipment manufactured by Combustion Engineering.

Units 1 and 2 are each equipped with low NO<sub>x</sub> burners and overfire air equipment. The burner design provides accurate fuel-air ratio control and thorough mixing of fuel and air at all ratings. Both an air and coal flow monitoring system are provided at each burner.

The WFGD systems for Units 1 and 2 include a dibasic acid (DBA) delivery system, and a neural network-based combustion optimization system that interfaces with the existing plant distributed control system for the purpose of optimizing boiler operations. The DBA system includes three metering pumps, one DBA storage tank, associated piping, valves, components, instrumentation and controls.

Each boiler/steam generator (i.e., units #1 and #2) are regulated under the federal Acid Rain Program, Phase II, adopted and incorporated by reference in Rule 62-204.800, F.A.C. These units hold ORIS code 0564.

Emission Units 1 and 2 are subject to compliance assurance monitoring (CAM) for particulate matter (PM) emissions controlled by an ESP. Because the continuous opacity monitoring system (COMS) is required to be used at the facility (for Phase II Acid Rain Program purposes), it must also be used as part of the CAM plan. *A CAM plan is included for the ESP. See Appendix CAM.*

### Changes to Specific Condition A.10.

**A.10. Carbon Monoxide.** Emissions of CO from Unit 1 shall not exceed 0.18 lb/MMBtu heat input on a 30-operating day rolling average as demonstrated by the required continuous emissions monitoring system (CO-CEMS). Carbon monoxide (CO) emissions from Unit No. 2 shall not exceed 0.15 lb/million Btu heat input on a 30-operating day rolling average as demonstrated by the required CO-CEMS. Based upon a heat input of 4286 million Btu/hr, CO emissions shall not exceed 643 lb/hr (2,816 TPY). [PSD-FL-084; 0950137-015-AC, Specific Condition 9.]

### New Specific Conditions Added.

**A.25. Continuous Compliance with CO limits.** The permittee shall calibrate, maintain and operate a carbon monoxide (CO) continuous emissions monitor system (CO-CEMS) and record the output of the system for measuring CO emissions discharged to the atmosphere. Compliance with the 30-operating day rolling average shall be demonstrated using data collected from the required CO-CEMS. [Rule 62-4.070(3), F.A.C.; 0950137-015-AC, Specific Condition 10.]

**A.26. Performance Specifications and Quality Assurance.** The acceptability of the CO-CEMS shall be evaluated by conducting the appropriate performance specification, as follows.

The CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F. The required



## STATEMENT OF BASIS

RATA tests shall be performed using EPA Method 10 in Appendix A of 40 CFR 60 and shall be based on a continuous sampling train. The CO monitor span values shall be set appropriately, considering the expected range of emissions and corresponding emission standards.

[Rules 62-4.070(3), 62-210.200(BACT), F.A.C.; 0950137-015-AC, Specific Condition 15.]

### A.27. CEMS Data Requirements for CO BACT Standard.

- a. Data Collection: The CO-CEMS shall monitor and record emissions during all operations and whenever emissions are being generated, including during episodes of startups, shutdowns, and malfunctions. All data shall be used, except for invalid measurements taken during monitor system breakdowns, repairs, calibration checks, zero adjustments, and span adjustments.
- b. Operating Hours and Operating Days: An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Any day with at least one operating hour for an emissions unit is an operating day for that emission unit.
- c. Valid Hourly Averages: The CO-CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
  - 1) Hours that are not operating hours are not valid hours.
  - 2) For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data, the 1-hour block average is not valid, and the hour is considered as "monitor unavailable."
- d. Rolling 30-day average: Compliance shall be determined after each operating day by calculating the arithmetic average of all the valid hourly averages from that operating day and the prior 29 operating days.
- e. Monitor Availability: The quarterly excess emissions report shall identify monitor availability for each quarter in which the unit operated. Monitor availability for the CO-CEMS shall be 95% or greater in any calendar quarter in which the unit operated for more than 760 hours. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit.

[Rules 62-4.070(3) and 62-210.200(BACT), F.A.C. ; 0950137-015-AC, Specific Condition 16.]

The old Specific Conditions **A.25-A.31** are renumbered to **A.28-A.34**.

**A.35. CO-CEMS Annual Emissions Requirement.** The owner or operator shall use data from the CO-CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rule 62-210.370(3), F.A.C. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit.

[Rules 62-210.200, and 62-210.370(3), F.A.C.; 0950137-015-AC, Specific Condition 17.]

## STATEMENT OF BASIS

---

### A.36. Excess Emissions Reporting.

- a. Malfunction Notification: If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. The Department may request a written summary report of the incident.
- b. SIP Quarterly Report: Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of CO emissions in excess of the BACT permit standard following the NSPS format in 40 CFR 60.7(c), Subpart A. In addition, the report shall summarize the CO-CEMS system monitor availability for the previous quarter.
- c. NSPS Reporting: Within 30 days following the calendar quarter, the permittee shall submit the written reports required by 40 CFR 60 Subpart Da (Standards of Performance for Fossil-Fuel Fired Steam Generators) for the previous semi-annual period to the Compliance Authority.

*{Note: If there are no periods of excess emissions as defined in 40 CFR, Part 60, Subpart Da, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}*

[Rules 62-4.130, 62-204.800, 62-210.700(6) and 62-212.400(BACT), F.A.C., and 40 CFR 60.7; 0950137-015-AC, Specific Condition 19.]


### **CONCLUSION**

This project revises Title V air operation permit No. 0950137-027-AV, which was effective on January 1, 2010. This Title V air operation permit revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4, 62-210, 62-213 and 62-214, F.A.C.

Orlando Utilities Commission  
Stanton Energy Center  
Facility ID No. 0950137  
Orange County

Title V Air Operation Permit Revision

**Draft/Proposed Permit Revision No. 0950137-029-AV**  
(First Revision of Title V Air Operation Permit No. 0950137-027-AV)



**Permitting Authority:**

State of Florida  
Department of Environmental Protection  
Division of Air Resource Management  
Bureau of Air Regulation  
Title V Section  
2600 Blair Stone Road  
Mail Station #5505  
Tallahassee, Florida 32399-2400  
Telephone: (850) 488-0114  
Fax: (850) 921-9533

**Compliance Authority:**

Central District Office  
3319 Maguire Boulevard, Suite 232  
Orlando, FL 32803-3767  
Telephone: (407) 894-7555  
Fax: (407) 897-5963

## Title V Air Operation Permit Revision

Permit No. 0950137-029-AV

### Table of Contents

<u>Section</u>	<u>Page Number</u>
I. Facility Information.	
A. Facility Description. ....	2
B. Summary of Emissions Units. ....	2
C. Applicable Regulations. ....	2
II. Facility-wide Conditions. ....	5
III. Emissions Units and Conditions.	
A. Coal Fired Steam Generators. ....	7
B. Auxiliary Boiler. ....	17
C. Fly Ash Silos. ....	19
D. Combined-Cycle Combustion Turbines. ....	22
E. Distillate Fuel Oil Storage Tank. ....	31
IV. Acid Rain Part. ....	32
Phase II Acid Rain Application/Compliance Plan.	
Phase II Acid Rain NO <sub>x</sub> Compliance Plan.	
V. Clean Air Interstate Rule Part. ....	44
VI. Appendices. ....	55
Appendix A, Glossary.	
Appendix CAM, Compliance Assurance Monitoring Plan.	
Appendix I, List of Insignificant Emissions Units and/or Activities.	
Appendix ICE	
Appendix NESHAP, Subpart A – General Provisions.	
Appendix NESHAP, Subpart ZZZZ.	
Appendix NSPS, Subpart A – General Provisions.	
Appendix NSPS, Subpart Da.	
Appendix NSPS, Subpart GG.	
Appendix NSPS, Subpart IIII.	
Appendix NSPS Subpart Kb.	
Appendix NSPS, Subpart Y.	
Appendix RR, Facility-wide Reporting Requirements.	
Appendix TR, Facility-wide Testing Requirements.	
Appendix TV, Title V General Conditions.	
Appendix U, List of Unregulated Emissions Units and/or Activities.	
Referenced Attachments. ....	At End
Figure 1, Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance (40 CFR 60, July, 1996).	
Table H, Permit History.	
Table 1, Summary of Air Pollutant Standards.	
Table 2, Compliance Requirements.	

## ***Draft/Proposed Permit***

**PERMITTEE:**  
Orlando Utilities Commission  
P. O. Box 3193  
Orlando, Florida 32802

Permit No. 0950137-029-AV  
Stanton Energy Center  
Facility ID No. 0950137  
Title V Air Operation Permit Revision

The purpose of this permit is to revise the Title V Air Operation Permit for the above referenced facility. The existing Stanton Energy Center is located at 5100 South Alafaya Trail, Orlando, in Orange County. Universal Transverse Mercator (UTM) Coordinates are: Zone 17, 483.50 km East and 3150.60 km North. Latitude is: 28° 29' 1" North; and, Longitude is: 81° 10' 7" West.

The Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to operate the facility in accordance with the terms and conditions of this permit.

Effective Date: January 1, 2010  
Revision Effective Date:  
Renewal Application Due Date: May 20, 2014  
Expiration Date: December 31, 2014

*(Draft)*

---

Joseph Kahn, Director  
Division of Air Resource Management

JK/tlv/jkh/tbc

**SECTION I. FACILITY INFORMATION.**

---

**Subsection A. Facility Description.**

This facility consists of two fossil fuel fired steam electric generating stations, emissions unit (E.U.) identification (ID) No. 001 (Unit No. 1) and 002 (Unit No. 2); also, there are storage and handling facilities for solid fuels, fly ash, limestone, gypsum, slag, and bottom ash. Unit No. 1 consists of a Babcock and Wilcox boiler/steam generator (Model RB 611) and steam turbine, which drives a generator with a nameplate rating of 468 megawatts (MW). Unit No. 2 consists of a Babcock and Wilcox boiler/steam generator (Model RB 621) and steam turbine, which drives a generator with a nameplate rating of 468 MW. Each boiler/steam generator is a wall fired dry bottom unit. Unit Nos. 1 and 2 are fired with coal, with No. 6 fuel oil used for startup and flame stabilization. Each unit has their individual stacks. Particulate matter emissions generated during the operation of the unit are controlled by a dry electrostatic precipitator (ESP) manufactured by Wheelabrator-Frye Inc. The control efficiency of the ESP is 99.7%. An auxiliary boiler is located at the facility that serves both boilers and has a maximum heat input of 83 million British thermal units (MMBtu)/hour. The auxiliary boiler is fired with No. 2 distillate fuel oil. Units 1 and 2 are each equipped with low NO<sub>x</sub> burners and overfire air equipment. The burner design provides accurate fuel-air ratio control and thorough mixing of fuel and air at all ratings.

Emission Units 1 and 2 are subject to compliance assurance monitoring (CAM) for particulate matter (PM) emissions controlled by an ESP. Because the continuous opacity monitoring system (COMS) is required to be used at the facility (for Phase II Acid Rain Program purposes), it must also be used as part of the CAM plan. A CAM plan is included for the ESP. See Appendix CAM.

Emission units 025 and 026 are nominal 170 MW, General Electric "F" Class (PG7241FA) combustion turbine-electrical generators, fired with pipeline natural gas or diesel and equipped with evaporative coolers on the inlet air system, two supplementary fired heat recovery steam generators (HRSG), each with a 160 ft. stack, and one steam turbine-electrical generator rated at approximately 300 MW. Units 25 and 26 have a total nominal capacity of 640 MW and will achieve approximately 700 MW during extreme winter peaking conditions.

The combustion turbines are equipped with dry low nitrogen oxides (NO<sub>x</sub>) combustors as well as selective catalytic reduction (SCR) in order to control NO<sub>x</sub> emissions to 3.5 parts per million by volume dry (ppmvd) at 15% oxygen (O<sub>2</sub>) while firing natural gas. During fuel oil firing, emissions shall be held to 10 ppmvd at 15% O<sub>2</sub> using SCR plus water injection. Pipeline quality natural gas, 0.05% sulfur, by weight, fuel oil, and good combustion practices shall be employed to control all pollutants.

These emissions units (the combustion turbines) are not subject to continuous assurance monitoring (CAM) because the NO<sub>x</sub> continuous emissions monitoring system (CEMS) is used for continuance compliance determination. Thus no CAM plan is included for these units in this permit.

Also included in this permit are miscellaneous unregulated emissions units and insignificant emissions units and/or activities.

**Subsection B. Summary of Emissions Units.**

<b>EU No.</b>	<b>Brief Description</b>
<i>Regulated Emissions Units</i>	
001	Fossil Fuel Fired Steam Electric Generator No. 1
002	Fossil Fuel Fired Steam Electric Generator No. 2
003	Auxiliary Boiler
004	Coal Transfer Baghouse
005	Coal Crusher Building Baghouse

**SECTION I. FACILITY INFORMATION.**

006	Coal Plant Transfer and Silo Fill Area #1 Baghouse
007	Coal Plant Transfer and Silo Fill Area #2 Baghouse
008	Limestone Day Bin Baghouse
009	Pebble Lime Receiving Hopper Baghouse
010	Coal Reclaim Hopper Baghouse
011	Flyash Exhauster Filter #1 Baghouse
012	Flyash Exhauster Filter #2 Baghouse
013	Flyash Exhauster Filter #3 Baghouse
014	Flyash Exhauster Filter #4 Baghouse
015	Flyash Silo Bin Vent Filter Baghouse
016	Adipic Acid Storage Baghouse
025	Combined-Cycle Combustion Turbine
026	Combined-Cycle Combustion Turbine
028	Distillate Fuel Oil Storage Tank
029	Flyash Silo Bin Vent Filter Baghouse
041	500 kW Emergency Generator at the Stanton A Plant Site
<i>Unregulated Emissions Units and Activities</i>	
017	Material Handling
018	Fuel Storage Tanks
019	Water Treatment
020	Unconfined Emissions
021	Surface Coating and Solvent Cleaning
022	General Purpose Engines
023	Helper Cooling Towers
024	Emergency Generators
027	Mechanical Draft Cooling Tower
036	Inline Insertable Dust Collector
040	Natural Draft Cooling Towers

**Subsection C. Applicable Regulations.**

Based on the Title V Air Operation Renewal application received on May 21, 2009, this facility is not a major source of hazardous air pollutants (HAP). Because this facility operates stationary reciprocating internal combustion engines, it is subject to regulation under 40 CFR 63, Subpart ZZZZ – National Emissions Standards For hazardous Air Pollutants For Stationary Reciprocating Internal Combustion Engines. However, since the engines being operated meet the Subpart ZZZZ definition of “existing units”, there are no unit specific applicable requirements that must be met pursuant to this rule at this time. The existing facility is a PSD major source of air pollutants in accordance with Rule 62-212.400, F.A.C. A summary of applicable regulations is shown in the following table.

**SECTION I. FACILITY INFORMATION.**

<b>Regulation</b>	<b>EU No(s).</b>
<i>Federal Rule Citations</i>	
40 CFR 60, Subpart A, NSPS General Provisions	001, 002, 025, 026
40 CFR 60, Subpart Da, Standards of Performance for Fossil-Fuel Fired Steam Generators	001, 002
NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800	025, 026
40 CFR 60, Subpart Kb, Standards of Performance for Volatile Organic Liquid Storage Vessels	028
40 CFR 60, Subpart Y, Standards of Performance for Coal Preparation Plants	004 through 016 and 029
Federal Acid Rain Program, Phase II	001, 002, 025, 026
40 CFR 75 Acid Rain Monitoring Provisions	
<i>State Rule Citations</i>	
Rule 62-4, F.A.C. (Permitting Requirements)	001, 002, 003, 025, 026. 004 through 016 and 029 028
Rule 62-204, F.A.C. (Ambient Air Quality Requirements, PSD Increments, and Federal Regulations Adopted by Reference)	
Rule 62-210, F.A.C. (Permits Required, Public Notice, Reports, Stack Height Policy, Circumvention, Excess Emissions, and Forms)	
Rule 62-212, F.A.C. (Preconstruction Review, PSD Review and BACT)	
Rule 62-213, F.A.C. (Title V Air Operation Permits for Major Sources of Air Pollution)	
Rule 62-214, F.A.C. (Requirements For Sources Subject To The Federal Acid Rain Program)	001, 002, 025, 026
Rule 62-296, F.A.C. (Emission Limiting Standards)	001, 002, 003, 025, 026 004 through 016 and 029 028
Rule 62-297, F.A.C. (Test Methods and Procedures, Continuous Monitoring Specifications, and Alternate Sampling Procedures)	
PSD-FL-084	001, 002, 003
PPS PA 81-14/SA2	01, 002, 003, 025, 026
PSD-FL-313, 0950137-002-AC	025, 026, 028



## SECTION II. FACILITY-WIDE CONDITIONS.

---

### **The following conditions apply facility-wide to all emission units and activities:**

**FW1. Appendices.** The permittee shall comply with all documents identified in Section VI, Appendices, listed in the Table of Contents. Each document is an enforceable part of this permit unless otherwise indicated. [Rule 62-213.440, F.A.C.]

### **Emissions and Controls**

**FW2. Not federally Enforceable. Objectionable Odor Prohibited.** No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rule 62-296.320(2) and 62-210.200(Definitions), F.A.C.]

**FW3. General Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions.** The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed-necessary and ordered by the Department. Nothing is deemed necessary and ordered at this time. [Rule 62-296.320(1), F.A.C.]

**FW4. General Visible Emissions.** No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b), F.A.C.]

**FW5. Unconfined Particulate Matter.** No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include:

- Paving and maintenance of roads, parking areas, and yards.
- Chemical (dust suppressants) or water application to unpaved roads, and unpaved yard areas.
- Removal of particulate matter (PM) from roads and other paved areas to prevent re-entrainment, and from buildings or work areas to prevent airborne PM.
- Landscaping or planting of vegetation.
- Confining abrasive blasting where possible.
- Other techniques as necessary.

[Rule 62-296.320(4)(c), F.A.C.; and, proposed by applicant in Title V air operation permit renewal application received May 21, 2009]

### **Annual Reports and Fees**

See Appendix RR, Facility-wide Reporting Requirements for additional details.

**FW6. Annual Operating Report.** The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by April 1<sup>st</sup> of each year. [Rule 62-210.370(3), F.A.C.]

**FW7. Annual Emissions Fee Form and Fee.** The annual Title V emissions fees are due (postmarked) by March 1<sup>st</sup> of each year. The completed form and calculated fee shall be submitted to: Major Air Pollution Source Annual Emissions Fee, P.O. Box 3070, Tallahassee, Florida 32315-3070. The forms are available for download by accessing the Title V Annual Emissions Fee On-line Information Center at the following Internet web site: <http://www.dep.state.fl.us/air/emission/tvfee.htm>. [Rule 62-213.205, F.A.C.]

## SECTION II. FACILITY-WIDE CONDITIONS.

---

**FW8. Annual Statement of Compliance.** The permittee shall submit an annual statement of compliance to the compliance authority at the address shown on the cover of this permit within 60 days after the end of each calendar year during which the Title V permit was effective. [Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

**FW9. Prevention of Accidental Releases (Section 112(r) of CAA).**

- a. As required by Section 112(r)(7)(B)(iii) of the CAA and 40 CFR 68, the owner or operator shall submit an updated Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center.
- b. As required under Section 252.941(1)(c), F.S., the owner or operator shall report to the appropriate representative of the Department of Community Affairs (DCA), as established by department rule, within one working day of discovery of an accidental release of a regulated substance from the stationary source, if the owner or operator is required to report the release to the United States Environmental Protection Agency under Section 112(r)(6) of the CAA.
- c. The owner or operator shall submit the required annual registration fee to the DCA on or before April 1, in accordance with Part IV, Chapter 252, F.S., and Rule 9G-21, F.A.C.
- d. Any required written reports, notifications, certifications, and data required to be sent to the DCA, should be sent to: Department of Community Affairs, Division of Emergency Management, 2555 Shumard Oak Boulevard, Tallahassee, FL 32399-2100, Telephone: (850) 413-9921, Fax: (850) 488-1739.
- e. Any Risk Management Plans, original submittals, revisions, or updates to submittals, should be sent to: RMP Reporting Center, Post Office Box 10162, Fairfax, VA 22038, Telephone: (703) 227-7650.

Any required reports to be sent to the National Response Center, should be sent to: National Response Center, EPA Office of Solid Waste and Emergency Response, USEPA (5305 W), 401 M Street SW, Washington, D.C. 20460, Telephone: (800) 424-8802.

Send the required annual registration fee using approved forms made payable to: Cashier, Department of Community Affairs, State Emergency Response Commission, 2555 Shumard Oak Boulevard, Tallahassee, FL 32399-2149

[Part IV, Chapter 252, F.S.; and, Rule 9G-21, F.A.C.]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection A. Emissions Units 001 and 002**

**The specific conditions in this section apply to the following emissions unit(s):**

<b>EU No.</b>	<b>Brief Description</b>
001	Fossil Fuel Fired Steam Generator No. 1
002	Fossil Fuel Fired Steam Generator No. 2

Fossil fuel fired steam generator # 1 is a nominal 468 megawatt steam generator designated as Unit # 1. The emission unit is fired primarily on bituminous coal and secondarily on No. 6 fuel oil for startup and flame stabilization, as permitted herein, with a maximum heat input of 4286 MMBtu per hour. Stack height is 550 feet, stack exit diameter is 19.0 feet, flow rate is 1,420,000 actual cubic feet per minute (acfm) at 127 degrees Fahrenheit, stack exit velocity is 83.5 feet per second.

Fossil fuel fired steam generator # 2 is a nominal 468 megawatt steam generator designated as Unit # 2. The emission unit is fired primarily on bituminous coal and secondarily on No. 6 fuel oil and on-specification used oil for startup and flame stabilization, as permitted herein, with a maximum heat input of 4286 MMBtu per hour. Stack height is 550 feet, stack exit diameter is 19.0 feet, flow rate is 1,310,120 acfm at 124 degrees Fahrenheit, stack exit velocity is 77.0 feet per second.

Each boiler/steam generator, units #1 and #2, drives a turbine generator and both units have an individual 550 foot exhaust stack. Particulate matter emissions generated during the operation of the unit are controlled by a dry electrostatic precipitator (ESP) manufactured by Wheelabrator-Frye Inc. The control efficiency of the ESP is 99.7%. Sulfur dioxide emissions are controlled by wet scrubber flue gas desulfurization (WFGD) equipment manufactured by Combustion Engineering.

Units 1 and 2 are each equipped with low NO<sub>x</sub> burners and overfire air equipment. The burner design provides accurate fuel-air ratio control and thorough mixing of fuel and air at all ratings. Both an air and coal flow monitoring system are provided at each burner.

The WFGD systems for Units 1 and 2 include a dibasic acid (DBA) delivery system, and a neural network-based combustion optimization system that interfaces with the existing plant distributed control system for the purpose of optimizing boiler operations. The DBA system includes three metering pumps, one DBA storage tank, associated piping, valves, components, instrumentation and controls.

Each boiler/steam generator (i.e., units #1 and #2) are regulated under the federal Acid Rain Program, Phase II, adopted and incorporated by reference in Rule 62-204.800, F.A.C. These units hold ORIS code 0564.

Emission Units 1 and 2 are subject to compliance assurance monitoring (CAM) for particulate matter (PM) emissions controlled by an ESP. Because the continuous opacity monitoring system (COMS) is required to be used at the facility (for Phase II Acid Rain Program purposes), it must also be used as part of the CAM plan. A CAM plan is included for the ESP. See Appendix CAM.

*{Permitting note(s): The emissions units are regulated under Acid Rain, Phase II; NSPS-40 CFR 60, Subpart Da, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After September 18, 1978, adopted and incorporated by reference in Rule 62-204.800(7)(b)2, F.A.C.; Rule 62-212.400, F.A.C., Prevention of Significant Deterioration (PSD); and Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT), and Compliance Assurance Monitoring (CAM). Fossil fuel fired steam generator # 1 began commercial operation on May 12, 1987; and fossil fuel fired steam generator # 2 began commercial operation on June 1, 1996.}*

**Essential Potential to Emit (PTE) Parameters**

**A.1. Permitted Capacity.** The maximum allowable heat input rate is as follows:

<u>Unit Nos.</u>	<u>MMBtu/hr Heat Input</u>	<u>Fuel Type</u>
------------------	----------------------------	------------------

## SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

### Subsection A. Emissions Units 001 and 002

001	4,286	Coal, No. 6 fuel oil, on-site generated lubricating oil and used fuel oil which meets the requirements of 40 CFR 266.40, landfill gas from the Orange
002	4,286	County Landfill and natural gas as supplied by commercial pipeline.

[Rules 62-4.160(2), 62-204.800 and 62-210.200(PTE), F.A.C.; PSD-FL-084; and Department Order Modifying Conditions of Power Plant Certification dated December 24, 1997]

*{Permitting Note: The heat input limitations have been placed in the permit to identify the capacity of each emissions unit for purposes of confirming that emissions testing is conducted within 90-100 percent of the emissions unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate limits and to aid in determining future rule applicability. To address OUC's concerns related to the heat input limitations, OUC will submit an application for an air construction permit revision no later than April 1, 2010. A change in the heat input limitation and/or a change in the method of determining compliance with the heat input limitations will be established through the issuance of an air construction permit in the near future. As such, this permitting note will not be valid after a final air construction permit has been issued by the Department or December 31, 2010, whichever occurs sooner.}*

**A.2. Emissions Unit Operating Rate Limitation After Testing.** See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

**A.3. Methods of Operation.**

a. *Fuels.* The fuels that are allowed to be burned in this unit/these units are:

- (1) Coal, primary fuel,
- (2) Natural gas,
- (3) New No. 6 fuel oil,
- (4) On-site generated lubricating oil,
- (5) On-specification used oil (see Specific Condition A.42.), and
- (6) Landfill gas from the Orange County Landfill.

b. *Flue Gas Desulfurization System (FGD).* No fraction of flue gas shall be allowed to bypass the FGD system to reheat the gases exiting from the FGD system, if the bypass will cause overall SO<sub>2</sub> removal efficiency less than 90 percent (or 70 percent for mass SO<sub>2</sub> emission rates less than or equal to 0.6 lb/million Btu 30 day rolling average). The percentage and amount of flue gas bypassing the FGD system shall be documented and records kept for a minimum of two years available for Department's inspection. The flue gas scrubber shall be put into service during normal operational startup, and shutdown, when No. 6 fuel oil is being burned. The flue-gas desulfurization system and mist eliminators for Unit 2 will be maintained and operated in a manner consistent with good air pollution practice for minimizing emissions pursuant to the requirements of 40 C.F.R. 60.11(d).

[Rules 62-4.070(3) and 62-213.410, F.A.C.; 40 CFR 60.40Da, and PSD-FL-084]

**A.4. Hours of Operation.** These emissions units may operate continuously (8,760 hours/year). [Rule 62-210.200(PTE), F.A.C.]

### **Emission Limitations and Standards**

*{Permitting Note: The attached Table 1, Summary of Air Pollutant Standards, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}*

Unless otherwise specified, the averaging times for Specific Conditions A.5. – A.16. are based on the specified averaging time of the applicable test method.

**A.5. Particulate Matter.** Particulate matter emissions shall not exceed any of the following:

a. *Unit 1.*

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection A. Emissions Units 001 and 002

- (1) 0.03 lb/million Btu heat input and 1 percent of the potential combustion concentration (99 percent reduction) when combusting solid fuel;
- (2) 0.03 lb/million Btu and 30 percent of potential combustion concentration (70 percent reduction) when combusting liquid fuel (No. 6 fuel oil); or,
- (3) 124.1 lbs/hour and 543.5 tons/year, based on the heat input rate listed in Specific Condition A.1.

b. *Unit 2.*

- (1) 0.02 lb/million Btu heat input and 1 percent of the potential combustion concentration (99 percent reduction) when combusting solid fuel. This standard applies at all times except during periods of startup, shutdown, or malfunction.
- (2) 0.03 lb/million Btu and 30 percent of potential combustion concentration (70 percent reduction) when combusting liquid fuel (No. 6 fuel oil); or,
- (2) 85.7 lbs/hr and 375.4 tons/year, based on the heat input rate listed in Specific Condition A.1.

[Rules 62-204.800(8) and 62-296.700(4)(b)1., F.A.C.; 40 CFR 60.42Da; and PSD-FL-084]

**A.6. Visible Emissions.** Visible emissions from Units No. 1 and 2 shall not exceed 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity. [Rule 62-204.800(8), F.A.C. and 40 CFR 60.42Da]

**A.7. Sulfur Dioxide.** Sulfur dioxide emissions shall not exceed any of the following:

a. *Unit No. 1.*

(1) When Combusting solid fuel:

- (a) 1.2 lb/million Btu (30 day rolling average) heat input, or
- (b) 1.2 lb/million Btu (2 hour emission rate) heat input, or.
- (c) 1.14 lb/million Btu (3-hr average) heat input (4886 lbs/hr and 21,400 tons/year) and
  - i. 10 percent of the potential combustion concentration (90 percent reduction) or
  - ii. 30 percent of the potential combustion concentration (70 percent reduction) when emissions are less than 0.60 lb/million Btu heat input.

(2) When combusting liquid fuel (No. 6 fuel oil):

- (a) 0.80 lb/million Btu heat input, and
- (b) 10 percent of the potential combustion concentration (90 percent reduction).

(3) When different fuels are combusted simultaneously in Unit No. 1, the applicable standard for sulfur dioxide is determined by proration using the following formulas:

(a) If emissions of sulfur dioxide to the atmosphere are greater than 0.60 lb/million Btu heat input:  
 $Es = \text{the lesser of } (0.80x + 1.20y)/100 \text{ or } 1.14 \text{ and } \%Ps = 10$

(b) If emissions of sulfur dioxide to the atmosphere are equal to or less than 0.60 lb/million Btu heat input:

$Es = \text{the lesser of } (0.80x + 1.20y)/100 \text{ or } 1.14 \text{ and } \%Ps = (10x + 30y)/100$

where:

$Es$  = the sulfur dioxide emission limit (lb/million Btu heat input).

$\%Ps$  = the percentage of potential sulfur dioxide emission allowed.

$x$  = the percentage of total heat input derived from the combustion of liquid fuel.

$y$  = the percentage of total heat input derived from the combustion of solid fuel.

b. *Unit No. 2.*

(1) When Combusting solid fuel:

- (a) 0.25 lb/million Btu (30 day rolling average) heat input;
- (b) 0.67 lb/million Btu (24 hour emission rate) heat input or
- (c) 0.85 lb/million Btu (3 hour emission rate) heat input. This corresponds to 3643 lbs/hr and 4,693 tons/year emission rate.

(2) When combusting liquid fuel (No. 6 fuel oil):

- (a) 0.80 lb/million Btu heat input, and
- (b) 10 percent of the potential combustion concentration (90 percent reduction).

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection A. Emissions Units 001 and 002**

(3) When different fuels are combusted simultaneously in Unit No. 2, the applicable standard of sulfur dioxide is determined by proration using the following formulas:

(a) If emissions of sulfur dioxide to the atmosphere are greater than 0.60 lb/million Btu heat input:

$$Es = \text{the lesser of } (0.80x + 1.20y)/100 \text{ or } 0.85 \text{ and } \%Ps = 10$$

(b) If emissions of sulfur dioxide to the atmosphere are equal to or less than 0.60 lb/million heat input:

$$Es = \text{the lesser of } (0.80x + 1.20y)/100 \text{ or } 0.85 \text{ and } \%Ps = (10x + 30y)/100$$

where:

Es = the sulfur dioxide emission limit (lb/million Btu heat input),

%Ps = the percentage of potential sulfur dioxide emission allowed.

x = the percentage of total heat input derived from the combustion of liquid fuel

y = the percentage of total heat input derived from the combustion of solid fuel

c. *Unit 1 and 2 Averaging Time.* Compliance with the NSPS sulfur dioxide emission limitations and percent reduction requirements are both determined on a 30-day rolling average basis.

[Rule 62-204.800(8), F.A.C.; 40 CFR 60.43Da; and PSD-FL-084]

**A.8. Nitrogen Oxides.** Nitrogen oxide emissions shall not exceed any of the following:

a. *Unit 1.*

(1) When combusting bituminous coal:

(a) 0.60 lb./million Btu heat input (30 day rolling average), nor

(b) 0.46 lb./million Btu heat input on an annual average.

(2) When combusting liquid fuel, nitrogen oxide emissions shall not exceed shall not exceed 0.30 lb/million Btu heat input (30-day rolling average).

(3) When liquid and solid fuels are combusted simultaneously in Unit No. 1, the applicable standard for nitrogen oxides is determined by proration using the following formula:

$$En = [0.30 x + 0.60 y]/100$$

where:

En = the applicable standard for nitrogen oxides when multiple fuels are combusted simultaneously (lb/million Btu heat input).

x = the percentage of total heat input derived from the combustion of liquid fuels.

y = the percentage of total heat input derived from the combustion of solid fuels.

b. *Unit 2.*

(1) When combusting bituminous coal, nitrogen oxide emissions shall not exceed 0.17 lb./million Btu heat input (30-day rolling average).

(2) When combusting liquid fuel, nitrogen oxide emissions shall not exceed shall not exceed 0.30 lb/million Btu heat input (30-day rolling average).

(3) When liquid and solid fuels are combusted simultaneously in Unit No. 2, the applicable standard for nitrogen oxides is determined by proration using the following formula:

$$En = [0.30 x + 0.17 y]/100$$

where:

En = the applicable standard for nitrogen oxides when multiple fuels are combusted simultaneously (lb/million Btu heat input).

X = the percentage of total heat input derived from the combustion of liquid fuels.

Y = the percentage of total heat input derived from the combustion of solid fuels.

c. *Units 1 and 2.* The above standards apply at all times except during periods of startup, shutdown, or malfunction.

[Rule 62-204.800(8) and 42-214, F.A.C.; and 40 CFR 60.44Da]

**A.9. Ammonia Slip.** Ammonia slip from the NO<sub>x</sub> control system shall be limited to less than 30 ppmv, uncorrected. [Rule 62-204.800(8) and 42-214, F.A.C.; and 40 CFR 60.44Da]

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection A. Emissions Units 001 and 002

- A.10. Carbon Monoxide.** Emissions of CO from Unit 1 shall not exceed 0.18 lb/mmBtu heat input on a 30-operating day rolling average as demonstrated by the required continuous emissions monitoring system (CO-CEMS). Carbon monoxide (CO) emissions from Unit No. 2 shall not exceed 0.15 lb/million Btu heat input on a 30-operating day rolling average as demonstrated by the required CO-CEMS. Based upon a heat input of 4286 million Btu/hr, CO emissions shall not exceed 643 lb/hr (2,816 TPY). [PSD-FL-084; 0950137-015-AC, Specific Condition 9.]
- A.11. Volatile Organic Compounds.** Volatile Organic Compounds (VOC) emissions from Unit No. 2 shall not exceed 0.015 lb/million Btu heat input. Based upon a heat input of 4,286 million Btu/hr, VOC emissions shall not exceed 64 lb/hr (282 TPY). [PSD-FL-084]
- A.12. Sulfuric Acid Mist.** Sulfuric acid mist (H<sub>2</sub>SO<sub>4</sub>) emissions from Unit No. 2 shall not exceed 0.033 lb/million Btu heat input. Based upon a heat input of 4,286 million Btu/hr, H<sub>2</sub>SO<sub>4</sub> emissions shall not exceed 140 lb/hr (613 TPY). [PPS PA 81-14/SA1]
- A.13. Beryllium.** Beryllium (Be) emissions from Unit No. 2 shall not exceed  $5.2 \times 10^{-6}$  lb./million Btu heat input. Based upon a heat input of 4286 million Btu/hr, Be emissions shall not exceed 0.022 lb./hr (0.1 TPY). [PPS PA 81-14/SA1]
- A.14. Mercury.** Mercury (Hg) emissions from Unit No. 2 shall not exceed  $1.1 \times 10^{-5}$  lb/million Btu heat input. Based upon a heat input of 4,286 million Btu/hr, Hg emissions shall not exceed 0.046 lb/hr (0.2 TPY). [PPS PA 81-14/SA1]
- A.15. Lead.** Lead (Pb) emissions from Unit No. 2 shall not exceed  $1.5 \times 10^{-4}$  lb/million Btu heat input. Based upon a heat input of 4,286 million Btu/hr, Pb emissions shall not exceed 0.64 lb/hr (2.8 TPY). [PPS PA 81-14/SA1]
- A.16. Fluorides.** Fluorides (Fl) emissions from Unit No. 2 shall not exceed  $4.2 \times 10^{-4}$  lb/million Btu heat input. Based upon a heat input of 4,286 million Btu/hr, Fl emissions shall not exceed 1.8 lb/hr (7.9 TPY). [PPS PA 81-14/SA1]

#### Excess Emissions

Rule 62-210.700 (Excess Emissions), F.A.C., cannot vary any requirement of an NSPS, NESHAP or Acid Rain program provision.

- A.17. Excess Emissions Allowed.** Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
- A.18. Excess Emissions Allowed.** Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized. [Rule 62-210.700(2), F.A.C.]
- A.19. Excess Emissions Prohibited.** Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

#### Monitoring of Operations

- A.20. CAM Plan.** These emissions units are subject to the Compliance Assurance Monitoring (CAM) requirements contained in the attached Appendix CAM. Failure to adhere to the monitoring requirements specified does not necessarily indicate an exceedance of a specific emissions limitation; however, it may constitute good reason to require compliance testing pursuant to Rule 62-297.310(7)(b), F.A.C. [40 CFR 64; Rules 62-204.800 and 62-213.440(1)(b)1.a., F.A.C.]

## SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

### Subsection A. Emissions Units 001 and 002

#### Continuous Monitoring Requirements

- A.21. Opacity Monitor.** The permittee shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring the opacity of emissions discharged to the atmosphere. Opacity interference exists due to water droplets in the stack from the use of an FGD system, therefore the opacity is monitored upstream of the interference (at the inlet to the FGD system). This monitoring method has been approved by the Department through permitting actions. [Rule 62-204.800(8), F.A.C.; 40 CFR 60.49Da; and PSD-FL-084]
- A.22. Sulfur Dioxide Monitor.** The permittee shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring sulfur dioxide emissions as follows:
- Sulfur dioxide emissions are monitored at both the inlet and outlet of the sulfur dioxide control device.
  - An "as fired" fuel monitoring system (upstream of coal pulverizers) meeting the requirements of Method 19, Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates, may be used to determine potential sulfur dioxide emissions in place of a continuous sulfur dioxide emission monitor at the inlet to the sulfur dioxide control device as required in the preceding Specific Condition **A.22.a.**
  - Within 90 days of commencement of operations, the applicant will determine and submit to EPA and FDER the pH level in the scrubber effluent that correlates with 90% removal of the SO<sub>2</sub> in the flue gas (or 70% for mass SO<sub>2</sub> emission rates less than or equal to 0.6 lb./MMBtu). Moreover, the applicant is required to operate a continuous pH meter equipped with and upset alarm to ensure that the operator becomes aware when pH value of the scrubber effluent rises above certain limited value. The value of the scrubber pH may be revised at a later date provided notification to EPA and FDER is made demonstrating that the minimum removal will be achieved on a continuous basis. Further, if compliance data show that higher FGD performance is necessary to maintain the minimum removal efficiency limit, a different pH value will be determined and maintained.  
[PSD-FL-084, Rule 62-204.800(8), F.A.C.; 40 CFR 60.49Da; and 40 CFR 60, Appendix A, Method 19]
- A.23. Nitrogen Oxides.** The permittee shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxide emissions discharged to the atmosphere. [Rule 62-204.800(8), F.A.C.; 40 CFR 60.49Da]
- A.24. Oxygen or Carbon Dioxide.** The permittee shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring the oxygen or carbon dioxide content of the flue gases at each location where sulfur dioxide or nitrogen oxide emissions are monitored. The oxygen monitor shall be used with automatic feedback or manual controls to continuously maintain optimum air/fuel ratio parameters. [PSD-FL-084, Rule 62-204.800(8), F.A.C.; 40 CFR 60.49Da]
- A.25. Continuous Compliance with CO limits.** The permittee shall calibrate, maintain and operate a carbon monoxide (CO) continuous emissions monitor system (CO-CEMS) and record the output of the system for measuring CO emissions discharged to the atmosphere. Compliance with the 30-operating day rolling average shall be demonstrated using data collected from the required CO-CEMS. [Rule 62-4.070(3), F.A.C.; 0950137-015-AC, Specific Condition 10.]
- A.26. Performance Specifications and Quality Assurance.** The acceptability of the CO-CEMS shall be evaluated by conducting the appropriate performance specification, as follows.  
The CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F. The required RATA tests shall be performed using EPA Method 10 in Appendix A of 40 CFR 60 and shall be based on a continuous sampling train. The CO monitor span values shall be set appropriately, considering the expected range of emissions and corresponding emission standards.  
[Rules 62-4.070(3), 62-210.200(BACT), F.A.C.; 0950137-015-AC, Specific Condition 15.]



**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection A. Emissions Units 001 and 002**

**A.27. CEMS Data Requirements for CO BACT Standard.**

- a. Data Collection: The CO-CEMS shall monitor and record emissions during all operations and whenever emissions are being generated, including during episodes of startups, shutdowns, and malfunctions. All data shall be used, except for invalid measurements taken during monitor system breakdowns, repairs, calibration checks, zero adjustments, and span adjustments.
- b. Operating Hours and Operating Days: An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Any day with at least one operating hour for an emissions unit is an operating day for that emission unit.
- c. Valid Hourly Averages: The CO-CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
  - 1) Hours that are not operating hours are not valid hours.
  - 2) For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data, the 1-hour block average is not valid, and the hour is considered as "monitor unavailable."
- d. Rolling 30-day average: Compliance shall be determined after each operating day by calculating the arithmetic average of all the valid hourly averages from that operating day and the prior 29 operating days.
- e. Monitor Availability: The quarterly excess emissions report shall identify monitor availability for each quarter in which the unit operated. Monitor availability for the CO-CEMS shall be 95% or greater in any calendar quarter in which the unit operated for more than 760 hours. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit.

[Rules 62-4.070(3) and 62-210.200(BACT), F.A.C. ; 0950137-015-AC, Specific Condition 16.]

**Test Methods and Procedures**

*{Permitting Note: The attached Table 2, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}*

**A.28. ~~A.25.~~ Test Methods.** Required tests shall be performed in accordance with the following reference methods:

<b>Method</b>	<b>Description of Method and Comments</b>
1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
3B	Gas Analysis for the Determination of Emission Rate Correction Factor or Excess Air
5, 5B	Method for Determining Particulate Matter Emissions (All PM is assumed to be PM <sub>10</sub> .)
6, 6A, 6B	Determination of Sulfur Dioxide Emissions from Stationary Sources

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection A. Emissions Units 001 and 002**

<b>Method</b>	<b>Description of Method and Comments</b>
or 6C	
7, 7A, 7C, 7D or 7E	Determination of Nitrogen Oxides Emissions from Stationary Sources
8	Determination of Sulfuric Acid Mist Emissions
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources {Note: The method shall be based on a continuous sampling train.}
12	Determination of Lead Emissions
13A, 13B	Determination of Fluoride Emissions
17	Determination of In-Stack Particulate Matter (PM) Emissions
18	Determination of VOC Emissions
19	Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates (Optional F-factor method may be used to determine flow rate and gas analysis to calculate mass emissions in lieu of Methods 1-4.)
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines
25, 25A, 25B	Method for Determining Gaseous Organic Concentrations (Flame Ionization)
101A	Determination of Hg Emissions
104	Determination of Be Emissions
108	Determination of Hg Emissions

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [62-297.401, F.A.C.; PPS PA 81-14/SA1; PSD-FL-084; and 40 CFR 60.49Da]

- A.29. ~~A.26.~~ Common Testing Requirements.** Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]
- A.30. ~~A.27.~~ Annual Compliance Tests Required.** During each federal fiscal year (October 1<sup>st</sup> to September 30<sup>th</sup>), each EU shall be tested to demonstrate compliance with the emissions standards for particulate matter, NO<sub>x</sub>, SO<sub>2</sub> and visible emissions. [Rule 62-297.310(7), F.A.C.; and PPS PA 81-14/SA1]
- A.31. ~~A.28.~~ Compliance Tests Prior To Renewal.** Compliance tests shall be performed for both Unit 1 and Unit 2 for particulate matter, NO<sub>x</sub>, SO<sub>2</sub>, visible emissions and carbon monoxide once every 5 years. Compliance tests shall be performed for Unit 2 for volatile organic compounds, sulfuric acid mist, mercury, beryllium, lead and fluoride once every 5 years. The tests shall occur prior to obtaining a renewed operating permit to demonstrate compliance with the emission limits in Specific Conditions A.5. – A.16. [Rules 62-210.300(2)(a) and 62-297.310(7)(a), F.A.C.]

**Recordkeeping and Reporting Requirements**

- A.32. ~~A.29.~~ Reporting Requirements.** See Appendix RR, Facility-Wide Reporting Requirements, for reporting requirements.

## SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

### Subsection A. Emissions Units 001 and 002

**A.33. ~~A.30.~~ Fuel Sampling Record.** Samples of all fuel oil and coal fired in the boilers shall be taken and analyzed for sulfur content, ash content, and heating value. Accordingly, samples shall be taken of each fuel oil shipment received. Coal sulfur content shall be determined and recorded on a daily basis in accordance with EPA Reference Method 19. Records of all the analyses shall be kept for public inspection for a minimum of five years. [Rule 62-213.440, F.A.C. and PSD-FL-084]

#### **Other Requirements**

- A.34. ~~A.31.~~ Used Oil.** Burning of on-specification used oil is allowed at this facility in accordance with all other conditions of this permit and the following conditions:
- a. *On-specification Used Oil Allowed as Fuel.* This permit allows the burning of used fuel oil meeting EPA "on-specification" used oil specifications, with a maximum sulfur content of 1.5 percent by weight for Units 1 and 2 and 0.5 percent by weight for the auxiliary boiler. The PCB concentration of used oil shall be less than 50 ppm. Used oil that does not meet the specifications for on-specification used oil shall not be burned at this facility. On-specification used oil shall meet the following specifications: [40 CFR 279, Subpart B.]
    - Arsenic shall not exceed 5.0 ppm;
    - Cadmium shall not exceed 2.0 ppm;
    - Chromium shall not exceed 10.0 ppm;
    - Lead shall not exceed 100.0 ppm;
    - Total halogens shall not exceed 1000 ppm;
    - Flash point shall not be less than 100 degrees F.
  - b. *Quantity Limited.* The maximum amount of on-specification used oil that can be burned at this facility shall be limited to 1.5 million gallons during each calendar year.
  - c. *Used Oil Containing PCBs Not Allowed.* Used oil containing a PCB concentration of 50 or more ppm shall not be burned at this facility. Used oil shall not be blended to meet this requirement.
  - d. *PCB Concentration of 2 to less than 50 ppm.* On-specification used oil with a PCB concentration of 2 to less than 50 ppm shall be burned only at normal source operating temperatures. On-specification used oil with a PCB concentration of 2 to less than 50 ppm shall not be burned during periods of startup or shutdown.
  - e. *Testing Required.* The owner or operator shall sample and analyze each batch of used oil to be burned for the following parameters: Arsenic, cadmium, chromium, lead, total halogens, flash point, PCBs, and percent sulfur content by weight, ash, and BTU value (BTU per gallon). Testing (sampling, extraction and analysis) shall be performed using approved methods specified in EPA Publication SW-846 (Test Methods for Evaluating Solid Waste, Physical/Chemical Methods), latest edition. If the analytical results show that the used oil does not meet the specification for on-specification used oil, or that it contains a PCB concentration of 50 ppm or greater, the owner or operator shall:
    - (1) immediately notify the Central District Office in Orlando;
    - (2) provide the analytical results for the above parameters; and
    - (3) indicate the proposed means of disposal of the used oil.
  - f. *Record Keeping Required.* The owner or operator shall obtain, make, and keep the following records related to the use of used oil in a form suitable for inspection at the facility by the Department: [40 CFR 279.61 and 761.20(e)]
    - (1) The gallons of on-specification used oil generated and burned each month. (This record shall be completed no later than the fifteenth day of the succeeding month.)
    - (2) The total gallons of on-specification used oil burned in the preceding consecutive 12-month period. (This record shall be completed no later than the fifteenth day of the succeeding month.)
    - (3) Results of the analyses required above.
    - (4) The total amount of lead emitted from burning used oil each month (calculated from the amount burned, the specific gravity of the used oil and the concentration of lead in the

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection A. Emissions Units 001 and 002

used oil), and the total amount of lead emitted in the preceding consecutive 12-month period. (This record shall be completed no later than the fifteenth day of the succeeding month.)

- g. *Reporting Required.* The owner or operator shall submit to Central District Office in Orlando, within thirty days of the end of each calendar quarter, the analytical results and the total amount of on-specification used oil generated and burned during the quarter. Also, the owner or operator shall submit, with the Annual Operation Report form, the analytical results and the total amount of on-specification used oil burned during the previous calendar year. [Rules 62-4.070(3) and 62-213.440, F.A.C., 40 CFR 279 and 40 CFR 761]

**A.35. CO-CEMS Annual Emissions Requirement.** The owner or operator shall use data from the CO-CEMS when calculating annual emissions for purposes of computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for purposes of computing emissions pursuant to the reporting requirements of Rule 62-210.370(3), F.A.C. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit.  
[Rules 62-210.200, and 62-210.370(3), F.A.C.; 0950137-015-AC, Specific Condition 17.]

**A.36. Excess Emissions Reporting.**

- a. *Malfunction Notification:* If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. The Department may request a written summary report of the incident.
- b. *SIP Quarterly Report:* Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of CO emissions in excess of the BACT permit standard following the NSPS format in 40 CFR 60.7(c), Subpart A. In addition, the report shall summarize the CO-CEMS system monitor availability for the previous quarter.
- c. *NSPS Reporting:* Within 30 days following the calendar quarter, the permittee shall submit the written reports required by 40 CFR 60 Subpart Da (Standards of Performance for Fossil-Fuel Fired Steam Generators) for the previous semi-annual period to the Compliance Authority.

{Note: If there are no periods of excess emissions as defined in 40 CFR, Part 60, Subpart Da, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}

[Rules 62-4.130, 62-204.800, 62-210.700(6) and 62-212.400(BACT), F.A.C., and 40 CFR 60.7; 0950137-015-AC, Specific Condition 19.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection B. Emissions Unit 003

The specific conditions in this section apply to the following emissions unit:

EU No.	Brief Description
003	Auxiliary Boiler

The auxiliary boiler is designated as Unit No. 3. The unit is a Babcock & Wilcox Model No. FM-2919 boiler. It is fired only with "new oil", which means an oil product which has been refined from crude oil and has not been used. Only No. 2 fuel oil can be burned in the auxiliary boiler. This auxiliary boiler serves both Unit No. 1 and 2 boiler/steam generators. Stack height is 50 feet; stack diameter is 3.5 feet. Initial startup date was July 1, 1985.

{Permitting notes: This emission unit is regulated under Rule 62-210.300, F.A.C., Permits Required. Because this emissions unit has no add-on control devices, it is not subject to CAM.}

Essential Potential to Emit (PTE) Parameters

- B.1. Capacity. The maximum permitted heat input rate for Unit No. 3 is 83 MMBtu/hour. [Rule 62-210.200(PTE), F.A.C.; and PSD-FL-084, Technical Evaluation and Preliminary Determination]
- B.2. Methods of Operation - Fuel. The auxiliary boiler shall be fired on No. 2 fuel oil having a sulfur content of less than 0.5 percent, by weight. [Rule 62-4.160(2), F.A.C.; construction permit application request]
- B.3. Hours of Operation. The emission unit may operate up to 150 hours/year. [Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting Note: The attached Table 1, Summary of Air Pollutant Standards, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

Unless otherwise specified, the averaging times for Specific Condition B.4. are based on the specified averaging times of the applicable test methods.

- B.4. Emissions from the auxiliary boiler for burning No. 2 fuel oil shall not exceed the allowable emission limits listed in the following table:

Allowable Emission Limits

<u>Pollutant</u>	<u>lb/MMBtu</u>
PM	0.015
SO <sub>2</sub>	0.51
NO <sub>x</sub>	0.16
Visible Emissions	20% Opacity

[Rule 62-4.160(2), F.A.C. and PSD-FL-084]

Excess Emissions

Rule 62-210.700 (Excess Emissions), F.A.C., cannot vary any requirement of an NSPS, NESHAP or Acid Rain program provision.

- B.5. Excess Emissions Allowed. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
- B.6. Excess Emissions Allowed. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized. [Rule 62-210.700(2), F.A.C.]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection B. Emissions Unit 003**

**B.7. Excess Emissions Prohibited.** Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

**Test Methods and Procedures**

*{Permitting Note: The attached Table 2, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}*

**B.8. Test Methods.** Required tests shall be performed in accordance with the following reference methods:

<b>Method</b>	<b>Description of Method and Comments</b>
1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
5	Method for Determining Particulate Matter Emissions (All PM is assumed to be PM <sub>10</sub> .)
6	Determination of Sulfur Dioxide Emissions from Stationary Sources
7	Determination of Nitrogen Oxides Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [62-297.401, F.A.C.; PPS PA 81-14/SA1; and PSD-FL-084]

**B.9. Common Testing Requirements.** Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

**B.10. Annual Compliance Tests Required.** During each federal fiscal year (October 1<sup>st</sup> to September 30<sup>th</sup>), the auxiliary boiler shall be tested to demonstrate compliance with the emissions standards for visible emissions. [Rule 62-297.310(7), F.A.C.]

**B.11. Compliance Tests Prior To Renewal.** Except as specified in Specific Condition **TR7.a.(3)**, compliance tests shall be performed for visible emissions prior to obtaining a renewed operating permit to demonstrate compliance with the emission limits in Specific Condition **B.4**. [Rules 62-210.300(2)(a) and 62-297.310(7)(a), F.A.C.]

**B.12. Annual PM Compliance Testing Not Required.** Compliance testing for PM emissions is not required if the unit operates for less than 400 hours annually. [Rule 62-297.310(7)(a)(5), F.A.C.]

**B.13. Visible Emissions.** The test method for visible emissions shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C. [PSD-FL-084]

**Recordkeeping and Reporting Requirements**

**B.14. Reporting Requirements.** See Appendix RR, Facility-Wide Reporting Requirements, for reporting requirements.

**B.15. Fuel Records.** Documentation of the type, quantity, and analysis of the fuel oil used/received is required. [PSD-FL-084]

**B.16. Operating Hours.** Documentation on operating hours shall be kept in order to ensure that the source is operating less than 150 hours per year. [PSD-FL-084, Technical Evaluation and Preliminary Determination, dated April 6, 1982.]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection C. Fly Ash Silos**

The specific conditions in this section apply to the following emissions units:

<b>EU No.</b>	<b>Brief Description</b>
004	Coal Transfer Baghouse
005	Coal Crusher Building Baghouse
006	Coal Plant Transfer and Silo Fill Area #1 Baghouse
007	Coal Plant Transfer and Silo Fill Area #2 Baghouse
008	Limestone Day Bin Baghouse
009	Pebble Lime Receiving Hopper Baghouse
010	Coal Reclaim Hopper Baghouse
011	Flyash Exhauster Filter #1 Baghouse
012	Flyash Exhauster Filter #2 Baghouse
013	Flyash Exhauster Filter #3 Baghouse
014	Flyash Exhauster Filter #4 Baghouse
015	Flyash Silo Bin Vent Filter Baghouse
016	Adipic Acid Storage Baghouse
029	Flyash Silo Bin Vent Filter Baghouse

Fly ash silos handle fly ash from Steam Generators No. 1 and No. 2 respectively. Fly ash is pneumatically conveyed from the individual electrostatic precipitators to Silos and then is gravity fed by tubing into totally enclosed tanker trucks. Particulate matter (PM) emissions generated by silo loading and unloading to a tanker truck are controlled by baghouses in addition to reasonable precautions. These units are subject to the applicable requirements under 40 CFR 60 Subpart Y - Standards of Performance for Coal Preparation Plants, since the facility has coal processing and conveying equipment (including breakers and crushers) and the facility commenced construction after October 24, 1974, per 40 CFR 60.250.

*{Permitting notes: The emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required. Because the potential to emit PM is below the major source threshold, these emissions units are not subject to CAM.}*

**Essential Potential to Emit (PTE) Parameters**

**C.1. Hours of Operation.** Fly ash silos are each allowed to operate continuously (i.e., 8,760 hrs./yr.). [Rule 62-210.200, F.A.C., Definition (PTE)]

**Emission Limitations and Standards**

*{Permitting Note: The attached Table 1, Summary of Air Pollutant Standards, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}*

Unless otherwise specified, the averaging times for Specific Conditions C.2 – C.3. are based on the specified averaging times of the applicable test method.

**C.2. Particulate Matter and Visible Emissions.** Particulate emissions from fly ash handling system shall be limited to 0.02 gr./acf. A visible emission reading of 5% opacity or less may be used to establish compliance with this emission limit. A visible emission reading greater than 5% opacity will not create a presumption that the 0.02 gr./acf emission limit is being violated. However, a visible emission reading greater than 5% opacity will require the permittee to perform a stack test for particulate emissions. [PPS PA 81-14/SA1]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection C. Fly Ash Silos**

- C.3. Fugitive Emissions.** The following requirements shall be met to minimize fugitive dust emissions from the coal storage and handling facilities, the limestone storage and handling facilities, haul roads and general plant operations:
- a. All conveyors and conveyor transfer points will be enclosed to preclude PM emissions (except those directly associated with the coal stacker/reclaimer and the emergency stockout facilities for which enclosure is operationally infeasible). All coal and limestone conveyors not underground or within buildings will be enclosed (roof and sides) with steel grating or concrete floors (except the stacker/reclaimer which will have windscreen protection);
  - b. Inactive coal storage piles will be shaped, compacted and oriented to minimize wind erosion.
  - c. Water sprays or chemical wetting agents and stabilizers will be applied to storage piles, handling equipment, etc. during dry periods and as necessary to all facilities to maintain an opacity of less than or equal to 5 percent except when adding, transferring and/or removing coal from the coal pile during which the opacity allowed shall be 20%.
  - d. The limestone handling receiver hopper will be equipped with water spray dust control facilities. Limestone conveyors not underground or within buildings will be enclosed with open grating floors (except where concrete floors are provided over roads or other facilities). Limestone day silos and associated transfer points will be maintained at negative pressures during filling operations with the exhaust vented to a control system. Lime will be handled with a totally enclosed pneumatic system. Exhaust from the lime silos during filling will be vented to a collector system.
  - e. The fly ash handling system (including transfer and silo storage) will be totally enclosed and vented (including pneumatic system exhaust) through fabric filters. Particulate emissions from fly ash handling system shall be limited to 0.02 gr./acf. A visible emission reading of 5% opacity or less may be used to establish compliance with this emission limit. A visible emission reading greater than 5% opacity will not create a presumption that the 0.02 gr./acf emission limit is being violated. However, a visible emission reading greater than 5% opacity will require the permittee to perform a stack test for particulate emissions.

[PSD-FL-084]

**Test Methods and Procedures**

*{Permitting Note: The attached Table 2, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}*

- C.4. Test Methods.** Required tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
5	Method for Determining Particulate Matter Emissions (All PM is assumed to be PM <sub>10</sub> )
9	Visual Determination of the Opacity of Emissions from Stationary Sources

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [62-297.401, F.A.C.; PPS PA 81-14/SA1; and PSD-FL-084]

- C.5. Visible Emissions.** During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the permittee shall have formal compliance test conducted on each silo baghouse for opacity. Additionally, each baghouse shall be visually inspected on a daily basis to ensure that emissions are not visible. Records shall be maintained documenting that such inspections took place. Should emissions from a baghouse be visible, corrective action should be undertaken as well as conducting a Method 9 V.E. Records should include color, duration, and density of the plume of any abnormal visible emissions detected, as well as the cause and corrective action taken for any abnormal visible emissions. [Rule 62-297.310(7)(a)4., F.A.C., Rule 62-213.440, F.A.C.]

*{Permitting note: It is presumed that the threshold of visibility for opacity is equal to 5%.}*



**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

---

**Subsection C. Fly Ash Silos**

**C.6. Visible Emissions.** Compliance with the opacity limit listed in C.2. will be determined by EPA Reference Method 9. [PPS PA 81-14/SA1]

**Recordkeeping and Reporting Requirements**

**C.7. Reporting Requirements.** See Appendix RR, Facility-Wide Reporting Requirements, for reporting requirements.

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection D. Combined-Cycle Combustion Turbines**

The specific conditions in this section apply to the following emissions units:

EU No.	Brief Description
025	Combined-Cycle Combustion Turbine
026	Combined-Cycle Combustion Turbine

These emissions units include two nominal 170 MW, General Electric "F" Class (PG7241FA) combustion turbine-electrical generators, fired with pipeline natural gas or diesel fuel oil and equipped with evaporative coolers on the inlet air system, two supplementary fired heat recovery steam generators (HRSG), each with a 160 ft. stack, and one steam turbine-electrical generator rated at approximately 300 MW. Units 25 and 26 have a total nominal capacity of 640 MW and will achieve approximately 700 megawatts during extreme winter peaking conditions.

The combustion turbines are equipped with dry low NO<sub>x</sub> combustors and a selective catalytic reduction (SCR) system in order to control NO<sub>x</sub> emissions to 3.5 ppmvd at 15% O<sub>2</sub> while firing natural gas. During fuel oil firing, emissions shall be held to 10 ppmvd at 15% O<sub>2</sub> using SCR plus water injection. Pipeline quality natural gas, 0.05% sulfur fuel oil, by weight, and good combustion practices shall be used to control all pollutants.

The combustion turbines are subject to the requirements of Phase II of the federal Acid Rain Program. These units hold ORIS code 55821. Unit 025 commercial start date was April 28, 2003, and Unit 026 commercial start date was April 28, 2003. Stack parameters are the same for both units: stack height is 160 feet, exit diameter is 19 feet, exit temperature is 287 degrees Fahrenheit (F) and volumetric flow rate is 1,280,130 actual cubic feet per minute (acfm).

These emissions units are not subject to compliance assurance monitoring (CAM) because the NO<sub>x</sub> CEMS is used for continuance compliance determination. Thus, no CAM plan is included in this permit.

**General**

- D.1. NSPS Requirements.** Each combustion turbine (CT) shall comply with all applicable requirements of 40 CFR 60, adopted by reference in Rule 62-204.800(7)(b), F.A.C.
- a. Subpart A, General Provisions (see Specific Condition D.2.)
  - b. Subpart GG, Standards of Performance for Stationary Gas Turbines. [See attached Appendix GG.] [0950137-002-AC, Specific Condition 2.]
- D.2. General Provisions.** These emission units shall comply with all applicable requirements of 40 CFR 60, Subpart A, General Provisions, including:
- 40 CFR 60.7, Notification and Recordkeeping
  - 40 CFR 60.8, Performance Tests
  - 40 CFR 60.11, Compliance with Standards and Maintenance Requirements
  - 40 CFR 60.12, Circumvention
  - 40 CFR 60.13, Monitoring Requirements
  - 40 CFR 60.19, General Notification and Reporting Requirements
- [0950137-002-AC, Specific Condition 4.]
- D.3. Subpart GG.** Each emissions unit shall comply with all applicable provisions of 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted by reference in Rule 62-204.800(8), F.A.C. The Subpart GG requirement to correct test data to International Organization for Standardization (ISO) conditions applies. However, such correction is not used for compliance determinations with the BACT standard(s). Compliance determination for BACT standards shall comply with all applicable provisions of 40 CFR 60, Subpart Da, Standards of Performance for Electric Utility Steam Generating Units Which Construction is Commenced After September 18, 1978, adopted by reference in Rule 62-204.800(8), F.A.C. [0950137-002-AC, Specific Condition 5.]

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection D. Combined-Cycle Combustion Turbines

- D.4. Operating Procedures.** Operating procedures shall include good operating practices and proper training of all operators and supervisors. The good operating practices of pollution control equipment shall meet the guidelines and procedures as established by the equipment manufacturers. All operators (including supervisors) of air pollution control devices shall be properly trained in plant specific equipment. [Rule 62-4.070(3), F.A.C. and 0950137-002-AC, Specific Condition 14.]
- D.5. Circumvention.** The owner or operator shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C. and 0950137-002-AC, Specific Condition 15.]

#### **Control Technology**

- D.6. Equipment.** Dry low NO<sub>x</sub> (DLN) combustors and water injection capability are installed on each stationary combustion turbine. The permittee has installed a selective catalytic reduction system to comply with the NO<sub>x</sub> and ammonia limits listed in Specific Condition **D.13**. Additionally, space is provided for the installation of oxidation catalysts. [Rules 62-4.070 and 62-212.400, F.A.C.; and 0950137-002-AC, Specific Condition 18.]
- D.7. Testing Locations.** The permittee shall design these units to accommodate adequate testing and sampling locations for compliance with the applicable emission limits (per each unit) listed in Specific Conditions **D.13**. - **D.17**. [Rules 62-4.070 and 62-204.800, F.A.C.; 40 CFR 60.40Da; and 0950137-002-AC, Specific Condition 19.]
- D.8. Drift Eliminators.** Drift eliminators are installed on the cooling tower to reduce PM/PM<sub>10</sub> emissions. A certification letter, following installation (and prior to startup) shall be submitted that the drift eliminators were installed and that the installation is capable of meeting 0.002-gallons/100 gallons recirculation water flowrate. [0950137-002-AC, Specific Condition 20.]

#### **Essential Potential to Emit (PTE) Parameters**

- D.9. Permitted Capacity.**
- a. **Combustion Turbine.** The maximum heat input rates to each CT/HRSG shall not exceed 2,402 million Btu (HHV) per hour (MMBtu/hr) when firing natural gas with duct burner firing and power augmentation. The maximum heat input rates to each CT/HRSG shall not exceed 2,068 MMBtu/hr (HHV) when firing fuel oil. Manufacturer's curves corrected for ISO conditions were provided to the Department of Environmental Protection (DEP) within 45 days prior to the completion of the initial compliance testing.
- b. **Heat Recovery Steam Generator equipped with Duct Burner.** The maximum heat input rate of the natural gas fired duct burner shall not exceed 533 MMBtu/hour (LHV) at any temperature or under any scenario. [Rule 62-210.200, F.A.C. (Definitions - Potential Emissions); and 0950137-002-AC, Specific Conditions 10 and 11.]
- {Permitting note: Heat input capacity shall be determined by CEMS database used for the acid rain program. CEMS data availability shall meet 40 CFR Part 75 requirements at greater than 95% of the time. Only valid hourly data shall be used to determine compliance with this provision. The source shall maintain this database for up to 5 years and make the information available upon request by the Department.}*
- D.10. Emissions Unit Operating Rate Limitation After Testing.** See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]
- D.11. Hours of Operation.** Maximum allowable hours of operation for each CT/HRSG Emissions Unit are 8,760 hours per year while firing natural gas. Fuel oil firing is permitted for 1,000 hours during any consecutive 12-month period in each CT. [Rule 62-210.200, F.A.C. (Definitions - Potential Emissions); and 0950137-002-AC, Specific Condition 16.]

## SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

### Subsection D. Combined-Cycle Combustion Turbines

#### D.12. Methods of Operation.

- a. Fuels. Only pipeline natural gas or (up to) 1000 hours per year of 0.05%, by weight, distillate fuel oil shall be fired in each CT emissions unit. Only natural gas shall be fired in each duct burner.
- b. Simple Cycle Operation. The plant may not be operated without the use of the SCR system except during periods of startup and shutdown.

[Rule 62-210.200, F.A.C. (Definitions - Potential Emissions); and 0950137-002-AC, Specific Conditions 9 and 17.]

#### Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions D.13. through D17. are based on the specified averaging time of the applicable test method.

#### D.13. Nitrogen Oxides (NO<sub>x</sub>) and Ammonia Emissions.

- a. The concentration of NO<sub>x</sub> in the stack exhaust gas, with the combustion turbine operating on natural gas, shall not exceed 3.5 ppmvd @15% O<sub>2</sub> on a 3-hour block average. This limit shall apply whether or not the unit is operating with duct burner on and/or in power augmentation mode. Compliance shall be determined by the continuous emission monitor (CEMS).
- b. The emissions of NO<sub>x</sub> in the stack exhaust gas, with the combustion turbine operating on fuel oil shall not exceed 10.0 ppmvd @15% O<sub>2</sub> on a 3-hour block average. Compliance shall be determined by the continuous emission monitor (CEMS).
- c. Emissions of NO<sub>x</sub> from the duct burner shall not exceed 0.1 lb/MMBtu, which is more stringent than the NSPS.
- d. The concentration of ammonia in the exhaust gas from each CT/HRSG shall not exceed 5.0 ppmvd @15% O<sub>2</sub>.

[BACT Determination; Rules 62-4.070, 62-204.800(8), 62-212.400, and 62-4.070, F.A.C.; and 0950137-002-AC, Specific Condition 21.]

D.14. Carbon Monoxide (CO) Emissions. Emissions of CO in the stack exhaust gas (at ISO conditions) with the combustion turbine operating on natural gas shall not exceed 17 ppmvd @15% O<sub>2</sub> on a 24-hour block average to be demonstrated by CEMS; or 14 ppmvd @15% O<sub>2</sub> with the CT operating on fuel oil on a 24-hr block average to be demonstrated by CEMS. These limits shall also be demonstrated by annual stack test using EPA Method 10 or through annual relative accuracy test audit (RATA) testing. [BACT Determination; Rule 62-212.400, F.A.C.; and 0950137-002-AC, Specific Condition 22.]

D.15. Volatile Organic Compounds (VOC) Emissions. Emissions of VOC in the stack exhaust gas (baseload at ISO conditions) shall not exceed 2.7 ppmvd @15% O<sub>2</sub> with the CT firing fuel oil or 6.3 ppmvd @15% O<sub>2</sub> with the CT firing natural gas (with maximum duct burner firing and operating in power augmentation mode). [BACT Determination; Rule 62-212.400, F.A.C.; and 0950137-002-AC, Specific Condition 23.]

D.16. Sulfur Dioxide (SO<sub>2</sub>) Emissions. SO<sub>2</sub> emissions shall be limited by firing pipeline natural gas (sulfur content not greater than 1.5 grains per 100 standard cubic feet) and up to 1,000 hours per consecutive 12-month period of 0.05% sulfur, by weight, fuel oil. Compliance with these fuel limits in conjunction with implementation of the attached Appendix GG will demonstrate compliance with the applicable NSPS SO<sub>2</sub> emissions limitations from the duct burner and the combustion turbine. Note: This will effectively limit the combined SO<sub>2</sub> emissions for EU-025 and EU-026 to approximately 134 tons per year. [BACT Determination; 40 CFR 60 Subpart GG; Rules 62-4.070, 62-212.400, and 62-204.800(8), F.A.C.; and 0950137-002-AC, Specific Condition 24.]

D.17. PM/PM<sub>10</sub> and Visible Emissions (VE). Visible emissions shall not exceed 10 percent opacity from the stack in use. [BACT Determination; Rules 62-4.070, 62-212.400 and 62-204.800(8), F.A.C.; and, 0950137-002-AC, Specific Condition 25.]

## SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

### Subsection D. Combined-Cycle Combustion Turbines

#### Excess Emissions

The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS or NESHAP provision.

**D.18. Excess Emissions Allowed.** Excess emissions resulting from startup, shutdown, fuel switching, or malfunction shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized. Excess emissions occurrences shall in no case exceed two hours in any 24-hour period. During any 24-hour period in which an hour of start-up or shutdown occurs, the following alternative emission limits shall apply on the basis of a 24-hour rolling average:

- a. An alternative NO<sub>x</sub> limit of 127 lb/hr shall apply if natural gas is the exclusively fired fuel;
- b. An alternative NO<sub>x</sub> limit of 370 lb/hr shall apply if any fuel oil is fired; and,
- c. An alternative CO limit of 155 lb/hr firing either natural gas or fuel oil.

The 24-hour averages shall be based on all available data excluding calibration data. Operation below 50% output per turbine shall otherwise be limited to 2 hours in any 24-hour period.

[BACT Determination; Rule 62-210.700, F.A.C.; and 0950137-002-AC, Specific Condition 26., modified on May 16, 2003.].

**D.19. Excess Emissions Prohibited.** Excess emissions entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction, shall be prohibited pursuant to Rule 62-210.700, F.A.C. These emissions shall be included in the 3-hr average for NO<sub>x</sub> and the 24-hr average for CO. [0950137-002-AC, Specific Condition 27.]

#### Monitoring of Operations

**D.20. Subpart Da Monitoring and Recordkeeping Requirements.** The permittee shall comply with all applicable requirements of 40 CFR 60 Subpart Da. [40 CFR 60, Subpart Da; and 0950137-002-AC, Specific Condition 44.].

**D.21. Selective Catalytic Reduction System (SCR) Compliance Procedures.**

- a. An annual stack emission test for nitrogen oxides and ammonia from the CT/HRSRG pair shall be simultaneously conducted while operating in the power augmentation mode with the duct burner. The ammonia injection rate necessary to comply with the NO<sub>x</sub> standard shall be established and reported during the each performance test.
- b. The SCR shall operate at all times that the turbine is operating, except during turbine start-up and shutdown periods, as dictated by manufacturer's guidelines and in accordance with this permit.
- c. The permittee shall install and operate an ammonia flow meter to measure and record the ammonia injection rate to the SCR system of the CT/HRSRG set. It shall be maintained and calibrated according to the manufacturer's specifications.
- d. During the stack test, the permittee (at each tested load condition) shall determine and report the ammonia flow rate required to meet the emissions limitations. During NO<sub>x</sub> CEM downtimes or malfunctions, the permittee shall operate at the ammonia flow rate, which was established during the last stack test.
- e. In the event of a complaint or concern by an inspector, the permittee shall be capable of making an instantaneous measurement using inlet and outlet NO<sub>x</sub> concentrations from the SCR system and ammonia flow supplied to the SCR system to determine ammonia slip. This determination shall not be used as a compliance method but only as an indicator to determine if a special compliance test is needed to demonstrate NO<sub>x</sub> and ammonia slip requirements of the permit. The calculation procedure shall be provided with the CEM monitoring plan required by 40 CFR Part 75. The following calculation represents one means by which the permittee may demonstrate compliance with this condition:

$$\text{Ammonia slip @ 15\%O}_2 = \frac{(A - (B \times C / 1,000,000)) \times (1,000,000 / B) \times D}{17}$$

where: A= ammonia injection rate (lb/hr) / 17 (lb/lb.mol)

$$B = \text{dry gas exhaust flow rate (lb/hr) / 29 (lb/lb.mol)}$$

## SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

### Subsection D. Combined-Cycle Combustion Turbines

C = change in measured NO<sub>x</sub> (ppmv@15%O<sub>2</sub>) across catalyst

D = correction factor, derived annually during compliance testing by comparing actual to tested ammonia slip

[Note: exhaust gas flow rate may be back calculated using heat input and F factor.]

- f. The calculation along with each newly determined correction factor shall be submitted with each annual compliance test. Calibration data (“as found” and “as left”) shall be provided for each measurement device utilized to make the ammonia emission measurement and submitted with each annual compliance test.
- g. Upon specific request by the Department, a special re-test shall occur as described in the previous conditions concerning annual test requirements, in order to demonstrate that all NO<sub>x</sub> and ammonia slip related permit limits can be complied with.

[0950137-002-AC, Specific Condition 45.]

#### **Continuous Monitoring Requirements**

**D.22. Continuous Monitoring Systems.** The permittee shall calibrate, maintain, and operate a continuous emission monitor in the stack to measure and record the emissions of NO<sub>x</sub> and CO from these emissions units, and the Carbon Dioxide (CO<sub>2</sub>) content of the flue gas at the location where NO<sub>x</sub> and CO are monitored, in a manner sufficient to demonstrate compliance with the emission limits of this permit. The CEM system shall be used to demonstrate compliance with the emission limits for NO<sub>x</sub> and CO established in this permit. Compliance with the emission limits for NO<sub>x</sub> shall be based on a 3-hour block average. The 3-hour block average shall be calculated from 3 consecutive hourly average emission rate values. Compliance with the emission limits for CO shall be based on a 24-hour block average starting at midnight of each operating day. The 24-hour block average shall be calculated from 24 consecutive hourly average emission rate values. Each hourly value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). The owner or operator shall use all valid measurements or data points collected during an hour to calculate the hourly averages. All data points collected during an hour shall be, to the extent practicable, evenly spaced over the hour. The permittee may use the inlet SCR NO<sub>x</sub> monitor as a backup analyzer in determining excess emissions during startup. If the CEM system measures concentration on a wet basis, the CEM system shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the owner or operator may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load for each allowable fuel, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Final results of the CEM system shall be expressed as ppmvd, corrected to 15% oxygen.

- a. *NO<sub>x</sub> Monitor.* The NO<sub>x</sub> monitor shall be certified and operated in accordance with the following requirements. The NO<sub>x</sub> monitor shall be certified pursuant to 40 CFR Part 75 and shall be operated and maintained in accordance with the applicable requirements of 40 CFR Part 75, Subparts B and C. For purposes of determining compliance with the emission limits specified within this permit, missing data shall not be substituted. Instead the block average shall be determined using the remaining hourly data in the 3-hour block. However, in the event that the permittee maintains 95% or greater availability of the continuous emission monitoring systems used for determining NO<sub>x</sub> emissions compliance for the previous quarter, then compliance with the emission limits for NO<sub>x</sub> shall be based on 3 valid consecutive hours of data for a 3-hour block average. Record keeping and reporting shall be conducted pursuant to 40 CFR Part 75, Subparts F and G. The RATA tests required for the NO<sub>x</sub> monitor shall be performed using EPA Method 20 or 7E, of Appendix A of 40 CFR 60. The NO<sub>x</sub> monitor shall be a dual range monitor. The span for the lower range shall be between or inclusive of the values of 10 and 20 ppm, and the span for the upper range shall be between or inclusive of the values of 200 and 250 ppm, as corrected to 15% O<sub>2</sub>.
- b. *CO Monitor.* The CO monitor and CO<sub>2</sub> monitor shall be certified and operated in accordance with the following requirements. The CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection D. Combined-Cycle Combustion Turbines

Specification 4. The CO<sub>2</sub> monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 3. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of section 7 shall be made each calendar quarter, and reported semi-annually to the Department's Central District Office. The RATA tests required for the CO monitor shall be performed using EPA Method 10, of Appendix A of 40 CFR 60. The Method 10 analysis shall be based on a continuous sampling train, and the ascarite trap may be omitted or the interference trap of section 10.1 may be used in lieu of the silica gel and ascarite traps. The CO monitor shall be a dual range monitor. The span for the lower range shall be between or inclusive of the values of 20 and 30 ppm, and the span for the upper range shall be between or inclusive of the values of 500 and 1000 ppm, as corrected to 15% O<sub>2</sub>. The RATA tests required for the CO<sub>2</sub> monitor shall be performed using EPA Method 3B, of Appendix A of 40 CFR 60.

- c. NO<sub>x</sub>, CO and CO<sub>2</sub> emissions data shall be recorded by the CEM system during episodes of startup, shutdown and malfunction. NO<sub>x</sub> and CO emissions data recorded during malfunctions may be excluded from the block average calculated to demonstrate compliance with the emission limits specified within this permit.
- d. Best operational practices shall be used to minimize hourly emissions that occur during episodes of startup, shutdown and malfunction. Emissions of any quantity or duration that occur entirely or in part from poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented, shall be prohibited.
- e. A summary report of duration of data excluded from the block average calculation, and all instances of missing data from monitor downtime, shall be reported to the Department's Central District office semi-annually, and shall be consolidated with the report required pursuant to 40 CFR 60.7. For purposes of reporting "excess emissions" pursuant to the requirements of 40 CFR 60.7, excess emissions shall be defined as the hourly emissions which are recorded by the CEM system during periods of data excluded for episodes of startup, shutdown and malfunction, allowed above. The duration of excess emissions shall be the duration of the periods of data excluded for such episodes. Reports required by this paragraph and by 40 CFR 60.7 shall be submitted no less than semi-annually, including semi-annual periods in which no data is excluded or no instances of missing data occur. Upon request from the Department, the CEMS emission rates shall be corrected to ISO conditions to demonstrate compliance with the applicable standards of 40 CFR 60.332.

[Note: Compliance with these requirements will ensure compliance with the other CEM system requirements of this permit to comply with Subpart GG requirements, as well as the applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.7(a)(5) and 40 CFR 60.13, and with 40 CFR Part 51, Appendix P, 40 CFR 60, Appendix B, Performance Specifications and 40 CFR 60, Appendix F, Quality Assurance Procedures].

[Rules 62-4.070(3) and 62-212.400., F.A.C.; BACT Determination; and 0950137-004-AC, Specific Condition 41., modified on May 16, 2003.]

- D.23. Continuous Monitoring System Requirements.** The monitoring devices shall comply with the certification and quality assurance, and any other applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.13, including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications and 40 CFR 60.7(a)(5) or 40 CFR Part 75. Quality assurance procedures must conform to all applicable sections of 40 CFR 60, Appendix F or 40 CFR 75. [0950137-002-AC, Specific Condition 42.]

### SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

#### Subsection D. Combined-Cycle Combustion Turbines

##### Test Methods and Procedures

*{Permitting Note: The attached Table 2, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}*

**D.24. Test Methods.** Required tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources {Note: The method shall be based on a continuous sampling train.}
18	Measurement of Gaseous Organic Compound Emissions by Gas Chromatography
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines
25, 25A	Method for Determining Gaseous Organic Concentrations (Flame Ionization)
CTM-027, 320	Conditional EPA Test Method 027, Measurement of Ammonia Slip (or equivalent method)

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rule 62-297.401, F.A.C.; 0950137-002-AC]

**D.25. Common Testing Requirements.** Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

**D.26. Annual Compliance Tests Required.** During each federal fiscal year (October 1<sup>st</sup> to September 30<sup>th</sup>), each EU shall be tested to demonstrate compliance with the emissions standards for visible emissions, carbon monoxide, nitrogen oxides and ammonia slip. [Rule 62-297.310(7), F.A.C.; and Permit No. 0950137-002-AC]

**D.27. Compliance Tests Prior To Renewal.** Compliance tests shall be performed for visible emissions, carbon monoxide, nitrogen oxides, ammonia slip and volatile organic compounds once every 5 years. The tests shall occur prior to obtaining a renewed operating permit to demonstrate compliance with the emission limits in Specific Conditions **D.13 - D.17**. [Rules 62-210.300(2)(a) and 62-297.310(7)(a), F.A.C.]

**D.28. Performance Tests.** Performance tests shall be conducted after any replacement of the major components of the air pollution control equipment (and shake down period not to exceed 100 days after re-starting the CT), such as replacement of SCR catalyst or addition of oxidation catalyst (or change of combustors, if specifically requested by the DEP on a case-by-case basis). Annual compliance tests shall be performed during every federal fiscal year (October 1 - September 30) pursuant to Rule 62-297.310(7), F.A.C. The reference methods listed in Specific Condition **D.24** shall be used. No other test methods may be used for compliance testing unless prior DEP approval is received in writing. The applicant shall calculate and report the ppmvd ammonia slip (@ 15% O<sub>2</sub>) at the measured lb/hr NO<sub>x</sub> emission rate as a means of compliance with the BACT standard. The applicant shall also be capable of calculating ammonia slip at the Department's request. [0950137-002-AC, Specific Condition 30.; and Applicant request in an e-mail memorandum received on October 7, 2004.]



**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection D. Combined-Cycle Combustion Turbines**

- D.29. Continuous Compliance with the CO and NO<sub>x</sub> Emission Limits.** Continuous compliance with the CO and NO<sub>x</sub> emission limits shall be demonstrated by the CEMS equipment on the specified hourly average basis. Based on CEMS data, a separate compliance determination is conducted at the end of each period and a new average emission rate is calculated from the arithmetic average of all valid hourly emission rates from the previous period. [Rules 62-4.070 F.A.C., 62-210.700, F.A.C., 40 CFR 75 and BACT; and 0950137-002-AC, Specific Condition 31.]
- D.30. Compliance with the SO<sub>2</sub> and PM/PM<sub>10</sub> Emission Limits.** For the purposes of demonstrating compliance with the 40 CFR 60.333 SO<sub>2</sub> standard, the applicant is responsible for ensuring that the procedures outlined in attached Appendix GG are complied with. [0950137-002-AC, Specific Condition 32.]
- D.31. Compliance with CO Emission Limit.** An annual test for CO shall be conducted at 100% capacity with the duct burners off. The NO<sub>x</sub> and CO test results shall be the average of three valid one-hour runs. Annual RATA testing for the CO and NO<sub>x</sub> CEMS shall be required pursuant to 40 CFR 75 and may substitute for the annual CO stack testing requirement. [0950137-002-AC, Specific Condition 33.]
- D.32. Compliance with the VOC Emission Limit.** An *initial* test was required to demonstrate compliance with the VOC emission limit. Thereafter, the CO emission limit shall be employed as a surrogate and no annual testing is required. [0950137-002-AC, Specific Condition 34.]
- D.33. Testing Procedures.** Unless otherwise specified, testing of emissions shall be conducted with the combustion turbine operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the maximum heat input rate allowed by the permit, corrected for the average inlet air temperature during the test (with 100 percent represented by a curve depicting heat input vs. inlet temperature). Procedures for these tests shall meet all applicable requirements (i.e., testing time frequency, minimum compliance duration, etc.) of Chapters 62-204 and 62-297, F.A.C. [0950137-002-AC, Specific Condition 35.]

**Recordkeeping and Reporting Requirements**

- D.34. Reporting Schedule.** The following reports and notifications shall be submitted to the Compliance Authority:

Report	Reporting Deadline	Related Condition(s)
Notice of Excess Emissions	Quarterly	D.37.

- D.35. Other Reporting Requirements.** See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements.
- D.36. Records.** All measurements, records, and other data required to be maintained by the applicant shall be recorded in a permanent form and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. These records shall be made available to Department representatives upon request.
- The applicant will be required to maintain records indicating the daily hours of operation of each CT/HRSG unit. These records shall specify which type of fuel is being combusted and the records shall be available for review at the site. Each calendar month, a compilation of the hours of operation for each CT/HRSG unit combusting fuel oil shall be made and totalized for the most recent consecutive 12-month period. Each annual operating report (AOR) submitted by the applicant shall include a compilation of each consecutive 12-month period during the preceding calendar year. [0950137-002-AC, Specific Condition 39.]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

---

**Subsection D. Combined-Cycle Combustion Turbines**

- D.37. Excess Emissions Report.** If excess emissions occur for more than two hours due to malfunction, the owner or operator shall notify the Department's Central District Office within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident. Pursuant to the New Source Performance Standards, all excess emissions shall also be reported in accordance with 40 CFR 60.7, Subpart A. Following this format, 40 CFR 60.7, and using the monitoring methods listed in this permit, periods of startup, shutdown, malfunction, shall be monitored, recorded, and reported as excess emissions when emission levels exceed the permitted standards listed in Specific Conditions **D.14.** through **D.17.** [Rules 62-4.130, 62-204.800, 62-210.700(6), F.A.C.; 40 CFR 60.7; and 0950137-002-AC, Specific Condition 28.]
- D.38. Quarterly Reports.** Quarterly excess emission reports, in accordance with 40 CFR 60.7, shall be submitted to the Department's Central District Office. [0950137-002-AC, Specific Condition 14., Section II.]

**SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.**

**Subsection E. Distillate Fuel Oil Storage Tank**

**The specific conditions in this section apply to the following emissions unit(s):**

<b>EU No.</b>	<b>Brief Description</b>
028	Distillate Fuel Oil Storage Tank

This fuel storage unit, consisting of a 1.86 million gallon distillate fuel oil storage tank (Unit 028), shall comply with all applicable provisions of 40 CFR 60, Subpart Kb, Standards of Performance for Volatile Organic Liquid Storage Vessels, adopted by reference in Rule 62-204.800, F.A.C. [0950137-002-AC, Specific Condition 7.]

**Essential Potential to Emit (PTE) Parameters**

**E.1. Hours of Operation.** This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year. [Rules 62-4.160(2) and 62-210.200, F.A.C., Definitions - (PTE).]

**Recordkeeping and Reporting Requirements**

**E.2. Record Maintenance.** The permittee shall maintain records on site for storage vessel identification number 028 to include the date of construction, the material storage capacity, and type of material stored for the life of this storage vessel. [40 CFR 60.116b(b).]

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

Operated by: Orlando Utilities Commission  
 ORIS Codes: 0564 and 55821

The emissions units listed below are regulated under Acid Rain, Phase II.

<b><u>E.U. ID No.</u></b>	<b><u>EPA ID</u></b>	<b><u>Brief Description</u></b>
001	1	Fossil Fuel Fired Steam Generator No. 1
002	2	Fossil Fuel Fired Steam Generator No. 2
025	25	Combined-Cycle Combustion Turbine
026	26	Combined-Cycle Combustion Turbine
030	B	300 megawatt (MW) Gas-Fueled Combined Cycle Project

**A.1.** The Phase II Acid Rain Part application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain units must comply with the standard requirements and special provisions set forth in the application(s) listed below:

- a. DEP Form No. 62-210.900(1)(a), dated 04/29/09, received 05/21/09.
- b. DEP Form No. 62-210.900(1)(a), dated 05/13/09, received 05/21/09.  
 [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

**A.2.** Nitrogen oxide (NO<sub>x</sub>) requirements for each Acid Rain Phase II unit are as follows:

<b><u>E.U. ID #</u></b>	<b><u>EPA ID</u></b>	<b><u>NO<sub>x</sub> Limit</u></b>
<b>001</b>	<b>1</b>	<p>The Florida Department of Environmental Protection approves a NO<sub>x</sub> compliance plan for this unit. The compliance plan is effective for calendar year 2010 through calendar year 2014.</p> <p>This unit's applicable emission limitation for each year of the plan, is 0.46 lb/MMBtu from 40 CFR 76.7(a)(2) for dry bottom wall-fired boilers.</p> <p>In addition to the described NO<sub>x</sub> compliance plan, this unit shall comply with all other applicable requirements of 40 CFR Part 76, including the duty to reapply for a NO<sub>x</sub> compliance plan and the requirements covering excess emissions.</p>
<b>002</b>	<b>2</b>	<p>The Florida Department of Environmental Protection approves a NO<sub>x</sub> compliance plan for this unit. The compliance plan is effective for calendar year 2010 through calendar year 2014.</p> <p>This unit's applicable emission limitation for each year of the plan, is 0.46 lb/MMBtu from 40 CFR 76.7(a)(2) for dry bottom wall-fired boilers.</p> <p>In addition to the described NO<sub>x</sub> compliance plan, this unit shall comply with all other applicable requirements of 40 CFR Part 76, including the duty to reapply for a NO<sub>x</sub> compliance plan and the requirements covering excess emissions.</p>

**A.3.** Sulfur Dioxide (SO<sub>2</sub>) Emission Allowances. SO<sub>2</sub> emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
- b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

---

c. Allowances shall be accounted for under the Federal Acid Rain Program.  
[Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]

**A.4.** Comments, notes, and justifications: None.

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**



United States  
 Environmental Protection Agency  
 Acid Rain Program

OMB No. 2060-0254  
 Expires 1-31-89

## Phase II NO<sub>x</sub> Compliance Plan

Page 1 of 2

For more information, see instructions and refer to 40 CFR 76.6

This submission is:  New  Revised

**STEP 1**  
 Indicate plant name,  
 State, and ORIS code  
 from NADES, if applicable

<b>Stanton Energy Center</b>	<b>FL</b>	<b>564</b>
Plant Name	State	ORIS Code

**STEP 2**

Identify each affected Group 1 and Group 2 boiler using the boiler ID# from NADES, if applicable. Indicate boiler type: "CB" for cell burner, "CY" for cyclone, "DWB" for dry bottom wall-fired, "T" for tangentially fired, "V" for vertically fired, and "WB" for wet bottom. Indicate the compliance option selected for each unit.

ID#	ID#	ID#	ID#	ID#	ID#
1	2				
Type	Type	Type	Type	Type	Type
DWB	DWB				

- (a) Standard annual average emission limitation of 0.50 lb/mmBtu (for Phase I dry bottom wall-fired boilers)
- (b) Standard annual average emission limitation of 0.46 lb/mmBtu (for Phase I tangentially fired boilers)
- (c) EPA-approved early abatement plan under 40 CFR 76.6 through 76.1777 (also indicate above emission limit specified in plan)
- (d) Standard annual average emission limitation of 0.46 lb/mmBtu (for Phase II dry bottom wall-fired boilers)
- (e) Standard annual average emission limitation of 0.40 lb/mmBtu (for Phase II tangentially fired boilers)
- (f) Standard annual average emission limitation of 0.38 lb/mmBtu (for cell burner boilers)
- (g) Standard annual average emission limitation of 0.36 lb/mmBtu (for cyclone boilers)
- (h) Standard annual average emission limitation of 0.34 lb/mmBtu (for vertically fired boilers)
- (i) Standard annual average emission limitation of 0.34 lb/mmBtu (for wet bottom boilers)
- (j) NO<sub>x</sub> Averaging Plan (include NO<sub>x</sub> Averaging form)
- (k) Common stack pursuant to 40 CFR 76.17(a)(1)(ii)(A) (check the standard emission limitation box above for most stringent limitation applicable to any unit utilizing stack)
- (l) Common stack pursuant to 40 CFR 76.17(a)(2)(ii)(B) with NO<sub>x</sub> Averaging (check the NO<sub>x</sub> Averaging Plan box and include NO<sub>x</sub> Averaging form)

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

EPA Form 7810-26 (3-97)

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

**Stanton Energy Center**  
 Plant Name (from Step 1)

NO<sub>x</sub> Compliance - Page 2  
 Page 2 of 2

**STEP 2, cont'd.**

1	2				
ID#	ID#	ID#	ID#	ID#	ID#
Type	Type	Type	Type	Type	Type
DWB	DWB				

(m) EPA-approved common stack apportionment method pursuant to 40 CFR 75.17 (a)(2)(i)(C), (a)(2)(ii)(D), or (b)(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(n) AEL (include Phase II AEL Demonstration Period, Final AEL Petition, or AEL Renewal Form as appropriate)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(o) Petition for AEL Demonstration period or final AEL under review by U.S. EPA or demonstration period ongoing	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(p) Repowering extension plan approved or under review	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**STEP 3**  
 Read the standard requirements and certification, enter the name of the designated representative, sign &

**Standard Requirements**

**General.** This source is subject to the standard requirements in 40 CFR 72.9 (consistent with 40 CFR 76.6(e)(1)(i)). These requirements are listed in this source's Acid Rain Permit.

**Special Provisions for Early Election Units**

**Nitrogen Oxides.** A unit that is governed by an approved early election plan shall be subject to an emissions limitation for NO<sub>x</sub> as provided under 40 CFR 76.6(a)(2) except as provided under 40 CFR 76.6(e)(3)(ii).

**Liability.** The owners and operators of a unit governed by an approved early election plan shall be liable for any violation of the plan or 40 CFR 76.6 at that unit. The owners and operators shall be liable, beginning January 1, 2000, for fulfilling the obligations specified in 40 CFR Part 77.

**Termination.** An approved early election plan shall be in effect only until the earlier of January 1, 2008 or January 1 of the calendar year for which a termination of the plan takes effect. If the designated representative of the unit under an approved early election plan fails to demonstrate compliance with the applicable emissions limitation under 40 CFR 76.6 for any year during the period beginning January 1 of the first year the early election takes effect and ending December 31, 2007, the permitting authority will terminate the plan. The termination will take effect beginning January 1 of the year after the year for which there is a failure to demonstrate compliance, and the designated representative may not submit a new early election plan. The designated representative of the unit under an approved early election plan may terminate the plan any year prior to 2008 but may not submit a new early election plan. In order to terminate the plan, the designated representative must submit a notice under 40 CFR 72.60(d) by January 1 of the year for which the termination is to take effect. If an early election plan is terminated any year prior to 2000, the unit shall meet, beginning January 1, 2000, the applicable emissions limitation for NO<sub>x</sub> for Phase II units with Group 1 boilers under 40 CFR 76.7. If an early election plan is terminated on or after 2000, the unit shall meet, beginning on the effective date of the termination, the applicable emissions limitation for NO<sub>x</sub> for Phase II units with Group 1 boilers under 40 CFR 76.7.

**Certification**

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

<b>Denise M. Stalls, ADR</b>	
Name	
Signature	<i>Denise M Stalls</i>
Date	10/09/2009

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

## Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is:  New     Revised     Renewal

**STEP 1**

Identify the source by plant name, state, and ORIS or plant code.

<b>Stanton A</b>	<b>FL</b>	<b>55821</b>
Plant name	State	ORIS/Plant Code

**STEP 2**

Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO<sub>2</sub> Opt-in unit, enter "yes" in column "b".

For new units or SO<sub>2</sub> Opt-in units, enter the requested information in columns "d" and "e."

a	b	c	d	e
Unit ID#	SO <sub>2</sub> Opt-in Unit? (Yes or No)	Unit will hold allowances in accordance with 40 CFR 72.9(c)(1)	New or SO <sub>2</sub> Opt-in Units Commence Operation Date	New or SO <sub>2</sub> Opt-in Units Monitor Certification Deadline
25		Yes		
26		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		



**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

**Stanton A**  
Plant Name (from STEP 1)

**STEP 3**

**Read the  
standard  
requirements.**

Acid Rain Part Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
  - (ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
  - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
- (4) For applications including a SO<sub>2</sub> Opt-in unit, a monitoring plan for each SO<sub>2</sub> Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO<sub>2</sub> Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
  - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

<p><b>Stanton A</b>  Plant Name (from STEP 1)</p>
---

**STEP 3,**  
**Continued.**

**Recordkeeping and Reporting Requirements (cont)**

- (iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

**Liability.**

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO<sub>x</sub> averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

**Effect on Other Authorities.**

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or
- (5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

**STEP 4**  
**For SO<sub>2</sub> Opt-In**  
**units only.**

**In column "f" enter**  
**the unit ID# for**  
**every SO<sub>2</sub> Opt-In**  
**unit identified in**  
**column "a" of**  
**STEP 2.**

**For column "g"**  
**describe the**  
**combustion unit**  
**and attach**  
**information and**  
**diagrams on the**  
**combustion unit's**  
**configuration.**

**In column "h"**  
**enter the hours.**

F	g	h (not required for renewal application)
Unit ID#	Description of the combustion unit	Number of hours unit operated in the six months preceding initial application

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

**Stanton A**  
 Plant Name (from STEP 1)

**STEP 5**

For SO<sub>2</sub> Opt-in units only. (Not required for SO<sub>2</sub> Opt-in renewal applications.)

In column "i" enter the unit ID# for every SO<sub>2</sub> Opt-in unit identified in column "a" (and in column "f").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.

i	j	k	l	m	n
Unit ID#	Baseline or Alternative Baseline under 40 CFR 74.20 (mmBtu)	Actual SO <sub>2</sub> Emissions Rate under 40 CFR 74.22 (lbs/mmBtu)	Allowable 1985 SO <sub>2</sub> Emissions Rate under 40 CFR 74.23 (lbs/mmBtu)	Current Allowable SO <sub>2</sub> Emissions Rate under 40 CFR 74.24 (lbs/mmBtu)	Current Promulgated SO <sub>2</sub> Emissions Rate under 40 CFR 74.25 (lbs/mmBtu)

**STEP 6**

For SO<sub>2</sub> Opt-in units only. Attach additional requirements, certify and sign.

- A. If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
- B. A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
- C. A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
- D. Attach a complete compliance plan for SO<sub>2</sub> under 40 CFR 72.40.
- E. The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
- F. The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."

Signature	Date
-----------	------

**STEP 7**

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

**Certification (for designated representative or alternate designated representative only)**

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name <b>Robert A. Schaffeld</b>	Title <b>General Manager, E&amp;CS Design</b>
Owner Company Name <b>Southern Power - Florida, LLC</b>	
Phone <b>(205) 257-6311</b>	E-mail address <b>raschaff@southernco.com</b>
Signature <i>Robert A. Schaffeld</i>	Date <b>07.29.09</b>

DEP Form No. 62-210.900(1)(a) - Form Effective: 3/16/08

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

## Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is:  New     Revised     Renewal

**STEP 1**

Identify the source by plant name, state, and ORIS or plant code.

STANTON ENERGY CENTER	FL	564
Plant name	State	ORIS/Plant Code

**STEP 2**

Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO<sub>2</sub> Opt-in unit, enter "yes" in column "b".

For new units or SO<sub>2</sub> Opt-in units, enter the requested information in columns "d" and "e."

a	b	c	d	e
Unit ID#	SO <sub>2</sub> Opt-in Unit? (Yes or No)	Unit will hold allowances in accordance with 40 CFR 72.9(c)(1)	New or SO <sub>2</sub> Opt-in Units Commence Operation Date	New or SO <sub>2</sub> Opt-in Units Monitor Certification Deadline
1	NO	Yes		
2	NO	Yes		
B	NO	Yes	3-1-2010	6-1-2010
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

Plant Name (from STEP 1) **STANTON ENERGY CENTER**

**STEP 3**

**Read the  
standard  
requirements.**

Acid Rain Part Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
  - (ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part.
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
  - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
- (4) For applications including a SO<sub>2</sub> Opt-in unit, a monitoring plan for each SO<sub>2</sub> Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO<sub>2</sub> Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
  - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.330, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and

**SECTION IV. ACID RAIN PART.  
Federal Acid Rain Program Provisions**

Plant Name (from STEP 1) **STANTON ENERGY CENTER**

**STEP 3,  
Continued.**

**Recordkeeping and Reporting Requirements (cont)**

(iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

**Liability.**

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 75.11 (NO<sub>x</sub> averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

**Effect on Other Authorities.**

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

**STEP 4  
For SO<sub>2</sub> Opt-in  
units only.**

In column "f" enter the unit ID# for every SO<sub>2</sub> Opt-in unit identified in column "a" of STEP 2.

For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.

In column "h" enter the hours.

f	g	h (not required for renewal application)
Unit ID#	Description of the combustion unit	Number of hours unit operated in the six months preceding initial application

**SECTION IV. ACID RAIN PART.**  
**Federal Acid Rain Program Provisions**

<b>STANTON ENERGY CENTER</b> Plant Name (from STEP 1)
--

**STEP 5**

For SO<sub>2</sub> Opt-in units only.  
(Not required for SO<sub>2</sub> Opt-in renewal applications.)

In column "i" enter the unit ID# for every SO<sub>2</sub> Opt-in unit identified in column "a" (and in column "f").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.

i	j	k	l	m	n
Unit ID#	Baseline or Alternative Baseline under 40 CFR 74.20 (mmBtu)	Actual SO <sub>2</sub> Emissions Rate under 40 CFR 74.22 (lbs/mmBtu)	Allowable 1985 SO <sub>2</sub> Emissions Rate under 40 CFR 74.23 (lbs/mmBtu)	Current Allowable SO <sub>2</sub> Emissions Rate under 40 CFR 74.24 (lbs/mmBtu)	Current Promulgated SO <sub>2</sub> Emissions Rate under 40 CFR 74.25 (lbs/mmBtu)

**STEP 6**

For SO<sub>2</sub> Opt-in units only.

Attach additional requirements, certify and sign.

- A. If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
- B. A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
- C. A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
- D. Attach a complete compliance plan for SO<sub>2</sub> under 40 CFR 72.40.
- E. The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
- F. The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."

Signature	Date
<b>Certification (for designated representative or alternate designated representative only)</b>	
<small>I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.</small>	
Name	Title
DENISE M. STALLS	VICE PRESIDENT, ENVIRONMENTAL AFFAIRS
Owner Company Name ORLANDO UTILITIES COMMISSION	
Phone (407) 737-4236	E-mail address dstalls@ouc.com
Signature <i>Denise M. Stalls</i>	Date 5/13/09

DEP Form No. 62-210.900(1)(a) - Form  
Effective: 3/16/08

**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

---

**Clean Air Interstate Rule (CAIR).**

**Operated by:** Orlando Utilities Commission

**Plant:** Stanton Energy Center

**ORIS Code:** 0564

The emissions units below are regulated under the Clean Air Interstate Rule.

<b>EU No.</b>	<b>EPA Unit ID#</b>	<b>Brief Description</b>
001	1	Fossil Fuel Fired Steam Generator # 1
002	2	Fossil Fuel Fired Steam Generator # 2
030	B	300 megawatt (MW) Gas-Fueled Combined Cycle Project

**Operated by:** Southern Power – Florida, LLC

**Plant:** Stanton Energy Center

**ORIS Code:** 55821

The emissions units below are regulated under the Clean Air Interstate Rule.

<b>EU No.</b>	<b>EPA Unit ID#</b>	<b>Brief Description</b>
025	25	Combined-Cycle Combustion Turbine
026	26	Combined-Cycle Combustion Turbine

1. Clean Air Interstate Rule Application. The Clean Air Interstate Rule Part Form submitted for this facility is a part of this permit. The owners and operators of these CAIR units as identified in this form must comply with the standard requirements and special provisions set forth in the CAIR Part Form (DEP Form No. 62-210.900(1)(b)) dated March 16, 2008, which is attached at the end of this section. [Chapter 62-213, F.A.C. and Rule 62-210.200, F.A.C.]



**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

## Clean Air Interstate Rule (CAIR) Part

For more information, see instructions and refer to 40 CFR 96.121, 96.122, 96.221, 96.222, 96.321 and 96.322; and Rule 62-296.470, F.A.C.

This submission is:  New     Revised     Renewal

**STEP 1**

**Identify the source by plant name and ORIS or EIA plant code**

Plant Name: <b>Stanton A Combined Cycle</b>	State: <b>Florida</b>	ORIS or EIA Plant Code: <b>055821</b>
--	--------------------------	--

**STEP 2**

**In column "a" enter the unit ID# for every CAIR unit at the CAIR source.**

**In columns "b," "c," and "d," indicate to which CAIR program(s) each unit is subject by placing an "X" in the column(s).**

**For new units, enter the requested information in columns "e" and "f."**

a	b	c	d	e	f
Unit ID#	Unit will hold nitrogen oxides (NO <sub>x</sub> ) allowances in accordance with 40 CFR 96.106(c)(1)	Unit will hold sulfur dioxide (SO <sub>2</sub> ) allowances in accordance with 40 CFR 96.206(c)(1)	Unit will hold NO <sub>x</sub> Ozone Season allowances in accordance with 40 CFR 96.306(c)(1)	New Units Expected Commence Commercial Operation Date	New Units Expected Monitor Certification Deadline
25	X	X	X		
26	X	X	X		

DEP Form No. 62-210.900(1)(b) – Form 3/15/00

**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

Plant Name (from STEP 1)	Stanton A Combined Cycle
--------------------------	--------------------------

**STEP 3**

**Read the  
standard  
requirements.**

**CAIR NO<sub>x</sub> ANNUAL TRADING PROGRAM**

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-286.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NO<sub>x</sub> source with the following CAIR NO<sub>x</sub> Emissions Requirements.

NO<sub>x</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
- (2) A CAIR NO<sub>x</sub> unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR NO<sub>x</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> allowance was allocated.
- (4) CAIR NO<sub>x</sub> allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
- (5) A CAIR NO<sub>x</sub> allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Annual Trading Program. No provision of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO<sub>x</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> allowance to or from a CAIR NO<sub>x</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> unit.

Excess Emissions Requirements.

If a CAIR NO<sub>x</sub> source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> emissions limitation, then:

- (1) The owners and operators of the source and each CAIR NO<sub>x</sub> unit at the source shall surrender the CAIR NO<sub>x</sub> allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law, and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
  - (i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Annual Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) The CAIR designated representative of a CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

Stanton A Combined Cycle Plant Name (from STEP 1)
--

**STEP 3,  
Continued**

Liability.

- (1) Each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit shall meet the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> source or the CAIR designated representative of a CAIR NO<sub>x</sub> source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> units at the source.
- (3) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> unit or the CAIR designated representative of a CAIR NO<sub>x</sub> unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO<sub>x</sub> Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> source or CAIR NO<sub>x</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**CAIR SO<sub>2</sub> TRADING PROGRAM**

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR SO<sub>2</sub> source and each SO<sub>2</sub> CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO<sub>2</sub> source with the following CAIR SO<sub>2</sub> Emission Requirements.

SO<sub>2</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO<sub>2</sub> allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO<sub>2</sub> units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
- (2) A CAIR SO<sub>2</sub> unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR SO<sub>2</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO<sub>2</sub> Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO<sub>2</sub> allowance was allocated.
- (4) CAIR SO<sub>2</sub> allowances shall be held in, deducted from, or transferred into or among CAIR SO<sub>2</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
- (5) A CAIR SO<sub>2</sub> allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO<sub>2</sub> Trading Program. No provision of the CAIR SO<sub>2</sub> Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR SO<sub>2</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO<sub>2</sub> allowance to or from a CAIR SO<sub>2</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO<sub>2</sub> unit.

Excess Emissions Requirements.

If a CAIR SO<sub>2</sub> source emits SO<sub>2</sub> during any control period in excess of the CAIR SO<sub>2</sub> emissions limitation, then:

- (1) The owners and operators of the source and each CAIR SO<sub>2</sub> unit at the source shall surrender the CAIR SO<sub>2</sub> allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

Stanton A Combined Cycle Plant Name (from STEP 1)
--

**STEP 3,  
Continued**

**Recordkeeping and Reporting Requirements.**

- (1) Unless otherwise provided, the owners and operators of the CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.
  - (i) The certificate of representation under 40 CFR 96.213 for the CAIR designated representative for the source and each CAIR SO<sub>2</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.213 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO<sub>2</sub> Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO<sub>2</sub> Trading Program or to demonstrate compliance with the requirements of the CAIR SO<sub>2</sub> Trading Program.
- (2) The CAIR designated representative of a CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall submit the reports required under the CAIR SO<sub>2</sub> Trading Program, including those under 40 CFR Part 96, Subpart HHH.

**Liability.**

- (1) Each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit shall meet the requirements of the CAIR SO<sub>2</sub> Trading Program.
- (2) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> source or the CAIR designated representative of a CAIR SO<sub>2</sub> source shall also apply to the owners and operators of such source and of the CAIR SO<sub>2</sub> units at the source.
- (3) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> unit or the CAIR designated representative of a CAIR SO<sub>2</sub> unit shall also apply to the owners and operators of such unit.

**Effect on Other Authorities.**

No provision of the CAIR SO<sub>2</sub> Trading Program, a CAIR Part, or an exemption under 40 CFR 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO<sub>2</sub> source or CAIR SO<sub>2</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**CAIR NO<sub>x</sub> OZONE SEASON TRADING PROGRAM**

**CAIR Part Requirements.**

- (1) The CAIR designated representative of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO<sub>x</sub> Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO<sub>x</sub> Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

**Monitoring, Reporting, and Recordkeeping Requirements.**

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO<sub>x</sub> Ozone Season source with the following CAIR NO<sub>x</sub> Ozone Season Emissions Requirements.

**NO<sub>x</sub> Ozone Season Emission Requirements.**

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.
- (2) A CAIR NO<sub>x</sub> Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1),(2), or (3) and for each control period thereafter.
- (3) A CAIR NO<sub>x</sub> Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> Ozone Season allowance was allocated.
- (4) CAIR NO<sub>x</sub> Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.
- (5) A CAIR NO<sub>x</sub> Ozone Season allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Ozone Season Trading Program. No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO<sub>x</sub> Ozone Season allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Ozone Season allowance to or from a CAIR NO<sub>x</sub> Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> Ozone Season unit.

DEP Form No. 62-210.900(1)(b) - Form  
Effective: 01/01/09

**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

Stanton A Combined Cycle Plant Name (from STEP 1)
--

**STEP 3,  
Continued**

Excess Emissions Requirements.

If a CAIR NO<sub>x</sub> Ozone Season source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> Ozone Season emissions limitation, then:  
 (1) The owners and operators of the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall surrender the CAIR NO<sub>x</sub> Ozone Season allowances required for deduction under 40 CFR 96.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and  
 (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.  
 (i) The certificate of representation under 40 CFR 96.313 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.  
 (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.  
 (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (2) The CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Ozone Season Trading Program, including those under 40 CFR Part 96, Subpart HHHH.

Liability.

(1) Each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit shall meet the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (2) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season source or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> Ozone Season units at the source.  
 (3) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season unit or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.


No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> Ozone Season source or CAIR NO<sub>x</sub> Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**STEP 4**

**Certification (for designated representative or alternate designated representative only)**

**Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.**

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Robert A. Schaffeld Name	General Manger E&CS Design Title
Southern Power - Florida, LLC Company Owner Name	
(205) 257-6311 Phone	raschaff@southernco.com E-mail Address
Signature 	Date 06/29/09

**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

## Clean Air Interstate Rule (CAIR) Part

For more information, see instructions and refer to 40 CFR 96.121, 96.122, 96.221, 96.222, 96.321 and 96.322; and Rule 62-296.470, F.A.C.

This submission is:  New  Revised  Renewal

**STEP 1**

Identify the source by plant name and ORIS or EIA plant code

Plant Name: <b>STANTON ENERGY CENTER</b>	State: Florida <b>FL</b>	ORIS or EIA Plant Code: <b>564</b>
---	-----------------------------	---------------------------------------

**STEP 2**

In column "a" enter the unit ID# for every CAIR unit at the CAIR source.

In columns "b," "c," and "d," indicate to which CAIR program(s) each unit is subject by placing an "X" in the column(s).

For new units, enter the requested information in columns "e" and "f."

a	b	c	d	e	f
Unit ID#	Unit will hold nitrogen oxides (NO <sub>x</sub> ) allowances in accordance with 40 CFR 96.106(c)(1)	Unit will hold sulfur dioxide (SO <sub>2</sub> ) allowances in accordance with 40 CFR 96.206(c)(1)	Unit will hold NO <sub>x</sub> Ozone Season allowances in accordance with 40 CFR 96.306(c)(1)	New Units Expected Commence Commercial Operation Date	New Units Expected Monitor Certification Deadline
1	X	X	X		
2	X	X	X		
B	X	X	X	3-1-2010	6-1-2010

**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

Plant Name (from STEP 1) **STANTON ENERGY CENTER**

**STEP 3**

**Read the  
standard  
requirements.**

**CAIR NO<sub>x</sub> ANNUAL TRADING PROGRAM**

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 62-299.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-299.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NO<sub>x</sub> source with the following CAIR NO<sub>x</sub> Emissions Requirements.

NO<sub>x</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
- (2) A CAIR NO<sub>x</sub> unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR NO<sub>x</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> allowance was allocated.
- (4) CAIR NO<sub>x</sub> allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
- (5) A CAIR NO<sub>x</sub> allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Annual Trading Program. No provision of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO<sub>x</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> allowance to or from a CAIR NO<sub>x</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> unit.

Excess Emissions Requirements.

If a CAIR NO<sub>x</sub> source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> emissions limitation, then:

- (1) The owners and operators of the source and each CAIR NO<sub>x</sub> unit at the source shall surrender the CAIR NO<sub>x</sub> allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
  - (i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Annual Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) The CAIR designated representative of a CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

Plant Name (from STEP 1) STANTON ENERGY CENTER

**STEP 3,**  
**Continued**

Liability.

- (1) Each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit shall meet the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> source or the CAIR designated representative of a CAIR NO<sub>x</sub> source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> units at the source.
- (3) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> unit or the CAIR designated representative of a CAIR NO<sub>x</sub> unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO<sub>x</sub> Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> source or CAIR NO<sub>x</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**CAIR SO<sub>2</sub> TRADING PROGRAM**

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-298.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCG, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR SO<sub>2</sub> source and each SO<sub>2</sub> CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHH, and Rule 62-298.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO<sub>2</sub> source with the following CAIR SO<sub>2</sub> Emission Requirements.

SO<sub>2</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO<sub>2</sub> allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO<sub>2</sub> units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
- (2) A CAIR SO<sub>2</sub> unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR SO<sub>2</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO<sub>2</sub> Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO<sub>2</sub> allowance was allocated.
- (4) CAIR SO<sub>2</sub> allowances shall be held in, deducted from, or transferred into or among CAIR SO<sub>2</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
- (5) A CAIR SO<sub>2</sub> allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO<sub>2</sub> Trading Program. No provision of the CAIR SO<sub>2</sub> Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR SO<sub>2</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO<sub>2</sub> allowance to or from a CAIR SO<sub>2</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO<sub>2</sub> unit.

Excess Emissions Requirements.

- If a CAIR SO<sub>2</sub> source emits SO<sub>2</sub> during any control period in excess of the CAIR SO<sub>2</sub> emissions limitation, then:
- (1) The owners and operators of the source and each CAIR SO<sub>2</sub> unit at the source shall surrender the CAIR SO<sub>2</sub> allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
  - (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.



**SECTION V. CAIR PART.**  
**Clean Air Interstate Rule Provisions**

Plant Name (from STEP 1) **STANTON ENERGY CENTER**

**STEP 3,  
Continued**

**Recordkeeping and Reporting Requirements.**

- (1) Unless otherwise provided, the owners and operators of the CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.
- (i) The certificate of representation under 40 CFR 98.213 for the CAIR designated representative for the source and each CAIR SO<sub>2</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 98.213 changing the CAIR designated representative.
- (ii) All emissions monitoring information, in accordance with 40 CFR Part 98, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 98, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
- (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO<sub>2</sub> Trading Program.
- (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO<sub>2</sub> Trading Program or to demonstrate compliance with the requirements of the CAIR SO<sub>2</sub> Trading Program.
- (2) The CAIR designated representative of a CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall submit the reports required under the CAIR SO<sub>2</sub> Trading Program, including those under 40 CFR Part 98, Subpart HHH.

**Liability.**

- (1) Each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit shall meet the requirements of the CAIR SO<sub>2</sub> Trading Program.
- (2) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> source or the CAIR designated representative of a CAIR SO<sub>2</sub> source shall also apply to the owners and operators of such source and of the CAIR SO<sub>2</sub> units at the source.
- (3) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> unit or the CAIR designated representative of a CAIR SO<sub>2</sub> unit shall also apply to the owners and operators of such unit.

**Effect on Other Authorities.**

No provision of the CAIR SO<sub>2</sub> Trading Program, a CAIR Part, or an exemption under 40 CFR 98.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO<sub>2</sub> source or CAIR SO<sub>2</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**CAIR NO<sub>x</sub> OZONE SEASON TRADING PROGRAM**

**CAIR Part Requirements.**

- (1) The CAIR designated representative of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall:
- (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
- (ii) [Reserved]
- (2) The owners and operators of each CAIR NO<sub>x</sub> Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO<sub>x</sub> Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

**Monitoring, Reporting, and Recordkeeping Requirements.**

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO<sub>x</sub> Ozone Season source with the following CAIR NO<sub>x</sub> Ozone Season Emissions Requirements.

**NO<sub>x</sub> Ozone Season Emission Requirements.**

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.
- (2) A CAIR NO<sub>x</sub> Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1), (2), or (3) and for each control period thereafter.
- (3) A CAIR NO<sub>x</sub> Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> Ozone Season allowance was allocated.
- (4) CAIR NO<sub>x</sub> Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.
- (5) A CAIR NO<sub>x</sub> Ozone Season allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Ozone Season Trading Program. No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO<sub>x</sub> Ozone Season allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Ozone Season allowance to or from a CAIR NO<sub>x</sub> Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> Ozone Season unit.

DEP Form No. 62-210.900(1)(b) - Form  
Effective: 3/16/08

4

**SECTION V. CAIR PART.  
Clean Air Interstate Rule Provisions**

Plant Name (from STEP 1) **STANTON ENERGY CENTER**

**STEP 3,  
Continued**

Excess Emissions Requirements.

If a CAIR NO<sub>x</sub> Ozone Season source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> Ozone Season emissions limitation, then:  
 (1) The owners and operators of the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall surrender the CAIR NO<sub>x</sub> Ozone Season allowances required for deduction under 40 CFR 96.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and  
 (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.  
 (i) The certificate of representation under 40 CFR 96.313 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.  
 (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.  
 (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (2) The CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Ozone Season Trading Program, including those under 40 CFR Part 96, Subpart HHHH.

Liability.

(1) Each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit shall meet the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.  
 (2) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season source or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> Ozone Season units at the source.  
 (3) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season unit or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> Ozone Season source or CAIR NO<sub>x</sub> Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**STEP 4**

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

**Certification (for designated representative or alternate designated representative only)**

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	DENISE M. STALLS	VICE PRESIDENT, ENVIRONMENTAL AFFAIRS	Title
Owner Name	ORLANDO UTILITIES COMMISSION		
Phone	(407) 737-4236	E-mail Address	dstalls@ouc.com
Signature	<i>Denise M. Stalls</i>		Date
			5-13-09

**SECTION VI. APPENDICES.**

**The Following Appendices Are Enforceable Parts of This Permit:**

- Appendix A, Glossary.
- Appendix CAM, Compliance Assurance Monitoring Plan.
- Appendix I, List of Insignificant Emissions Units and/or Activities.
- Appendix ICE, Requirements for Internal Combustion Engines.
- Appendix NESHAP, Subpart A – General Provisions.
- Appendix NESHAP, Subpart ZZZZ.
- Appendix NSPS, Subpart A – General Provisions.
- Appendix NSPS, Subpart Da
- Appendix NSPS, Subpart GG.
- Appendix NSPS, Subpart IIII.
- Appendix NSPS Subpart Kb.
- Appendix NSPS, Subpart Y.
- Appendix RR, Facility-wide Reporting Requirements.
- Appendix TR, Facility-wide Testing Requirements.
- Appendix TV, Title V General Conditions.
- Appendix U, List of Unregulated Emissions Units and/or Activities.

## Friday, Barbara

---

**To:** jaspuru@ouc.com  
**Cc:** Stalls, Denise M.; dbaez@ouc.com; sosbourn@golder.com; Shine, Caroline; 'Forney.Kathleen@epamail.epa.gov'; Oquendo.Ana@epamail.epa.gov; Gibson, Victoria; Cascio, Tom; Holtom, Jonathan; Koerner, Jeff; Walker, Elizabeth (AIR); Livingston, Sylvia  
**Subject:** ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV  
**Attachments:** 0950137029AV030ACWrittenNoticeofIntent.pdf

Dear Sir/ Madam:

Attached is the official **Written Notice of Intent to Issue Air Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

*Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).*

Attention: Tom Cascio

Owner/Company Name: ORLANDO UTILITIES COMMISSION  
Facility Name: STANTON ENERGY CENTER  
Project Number: 0950137-029-AV/0950137-030-AC  
Permit Status: DRAFT/PROPOSED  
Permit Activity: PERMIT REVISION/DRAFT AIR CONSTRUCTION  
Facility County: ORANGE

“The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the “*Air Permit Documents Search*” website at <http://www.dep.state.fl.us/air/emission/apds/default.asp> . “

Permit project documents that are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation.

Barbara Friday  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
(850)921-9524

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0950137.029.AV.D\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0950137.029.AV.D_pdf.zip)

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0950137.030.AC.D\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0950137.030.AC.D_pdf.zip)

**Friday, Barbara**

---

**From:** Microsoft Exchange  
**To:** jaspuru@ouc.com; 'Stalls, Denise M.'; dbaez@ouc.com  
**Sent:** Friday, February 05, 2010 1:07 PM  
**Subject:** Relayed: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER;  
0950137-029-AV

**Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:**

[jaspuru@ouc.com](mailto:jaspuru@ouc.com)

'Stalls, Denise M.'

[dbaez@ouc.com](mailto:dbaez@ouc.com)

Subject: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

---

Sent by Microsoft Exchange Server 2007

## Friday, Barbara

---

**From:** Stalls, Denise M. [DStalls@ouc.com]  
**Sent:** Friday, February 05, 2010 1:37 PM  
**To:** Friday, Barbara  
**Subject:** RE: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Barbara

We are able to retrieve documents. Thank you,

### DISCLAIMER:

Florida has a very broad public records law. As a result, any written communication created or received by Orlando Utilities Commission officials and employees will be made available to the public and media, upon request, unless otherwise exempt. Under Florida law, email addresses are public records. If you do not want your email address released in response to a public records request, do not send electronic mail to this office. Instead, contact our office by phone or in writing.

---

**From:** Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]  
**Sent:** Friday, February 05, 2010 1:07 PM  
**To:** Aspuru, Jan  
**Cc:** Stalls, Denise M.; Baez, David R.; sosbourn@golder.com; Shine, Caroline; Forney.Kathleen@epamail.epa.gov; Oquendo.Ana@epamail.epa.gov; Gibson, Victoria; Cascio, Tom; Holtom, Jonathan; Koerner, Jeff; Walker, Elizabeth (AIR); Livingston, Sylvia  
**Subject:** ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Dear Sir/ Madam:

Attached is the official **Written Notice of Intent to Issue Air Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

*Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).*

Attention: Tom Cascio

Owner/Company Name: ORLANDO UTILITIES COMMISSION  
Facility Name: STANTON ENERGY CENTER  
Project Number: 0950137-029-AV/0950137-030-AC  
Permit Status: DRAFT/PROPOSED  
Permit Activity: PERMIT REVISION/DRAFT AIR CONSTRUCTION  
Facility County: ORANGE

"The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other

project documents using the “*Air Permit Documents Search*” website at <http://www.dep.state.fl.us/air/emission/apds/default.asp> . “

Permit project documents that are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation.

Barbara Friday  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
(850)921-9524

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0950137.029.AV.D\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0950137.029.AV.D_pdf.zip)

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0950137.030.AC.D\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0950137.030.AC.D_pdf.zip)

*The Department of Environmental Protection values your feedback as a customer. DEP Secretary Michael W. Sole is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.*



## Friday, Barbara

---

**From:** Baez, David R. [DBaez@ouc.com]  
**Sent:** Friday, February 05, 2010 1:37 PM  
**Subject:** Read: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Your message was read on Friday, February 05, 2010 1:36:54 PM (GMT-05:00) Eastern Time (US & Canada).

## Friday, Barbara

---

**From:** Baez, David R. [DBaez@ouc.com]  
**Sent:** Friday, February 05, 2010 1:38 PM  
**To:** Friday, Barbara  
**Subject:** RE: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

David R. Báez  
Project Engineer, Environmental Affairs  
Orlando Utilities Commission  
407-658-6444 x.3691(office)  
407-719-6515 (cell)  
407-244-8794 (fax)  
[dbaez@ouc.com](mailto:dbaez@ouc.com)

### DISCLAIMER:

Florida has a very broad public records law. As a result, any written communication created or received by Orlando Utilities Commission officials and employees will be made available to the public and media, upon request, unless otherwise exempt. Under Florida law, email addresses are public records. If you do not want your email address released in response to a public records request, do not send electronic mail to this office. Instead, contact our office by phone or in writing.

---

**From:** Friday, Barbara [<mailto:Barbara.Friday@dep.state.fl.us>]  
**Sent:** Friday, February 05, 2010 1:07 PM  
**To:** Aspuru, Jan  
**Cc:** Stalls, Denise M.; Baez, David R.; [sosbourn@golder.com](mailto:sosbourn@golder.com); Shine, Caroline; [Forney.Kathleen@epamail.epa.gov](mailto:Forney.Kathleen@epamail.epa.gov); [Oquendo.Ana@epamail.epa.gov](mailto:Oquendo.Ana@epamail.epa.gov); Gibson, Victoria; Cascio, Tom; Holtom, Jonathan; Koerner, Jeff; Walker, Elizabeth (AIR); Livingston, Sylvia  
**Subject:** ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Dear Sir/ Madam:

Attached is the official **Written Notice of Intent to Issue Air Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

*Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).*

Attention: Tom Cascio

Owner/Company Name: ORLANDO UTILITIES COMMISSION  
Facility Name: STANTON ENERGY CENTER  
Project Number: 0950137-029-AV/0950137-030-AC  
Permit Status: DRAFT/PROPOSED

Permit Activity: PERMIT REVISION/DRAFT AIR CONSTRUCTION  
Facility County: ORANGE

“The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the “*Air Permit Documents Search*” website at <http://www.dep.state.fl.us/air/emission/apds/default.asp> . “

Permit project documents that are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation.

Barbara Friday  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
(850)921-9524

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0950137.029.AV.D\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0950137.029.AV.D_pdf.zip)

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0950137.030.AC.D\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0950137.030.AC.D_pdf.zip)

*The Department of Environmental Protection values your feedback as a customer. DEP Secretary Michael W. Sole is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.*

**Friday, Barbara**

---

**From:** Mail Delivery System [MAILER-DAEMON@mx3.golder.com]  
**To:** sosbourn@golder.com  
**Sent:** Friday, February 05, 2010 1:08 PM  
**Subject:** Relayed: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER;  
0950137-029-AV

**Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:**

[sosbourn@golder.com](mailto:sosbourn@golder.com)

Subject: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

## Friday, Barbara

---

**From:** Osbourn, Scott [Scott\_Osbourn@golder.com]  
**To:** Friday, Barbara  
**Sent:** Friday, February 05, 2010 2:00 PM  
**Subject:** Read: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Your message was read on Friday, February 05, 2010 1:59:33 PM (GMT-05:00) Eastern Time (US & Canada).

**Friday, Barbara**

---

**From:** Microsoft Exchange  
**To:** Cascio, Tom; Livingston, Sylvia; Holtom, Jonathan; Gibson, Victoria  
**Sent:** Friday, February 05, 2010 1:07 PM  
**Subject:** Delivered: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER;  
0950137-029-AV

**Your message has been delivered to the following recipients:**

Cascio, Tom

Livingston, Sylvia

Holtom, Jonathan

Gibson, Victoria

Subject: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

---

Sent by Microsoft Exchange Server 2007

## Friday, Barbara

---

**From:** Cascio, Tom  
**To:** Friday, Barbara  
**Sent:** Friday, February 05, 2010 2:47 PM  
**Subject:** Read: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Your message was read on Friday, February 05, 2010 2:47:28 PM (GMT-05:00) Eastern Time (US & Canada).

## Friday, Barbara

---

**From:** Livingston, Sylvia  
**To:** Friday, Barbara  
**Sent:** Friday, February 05, 2010 1:07 PM  
**Subject:** Read: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Your message was read on Friday, February 05, 2010 1:07:12 PM (GMT-05:00) Eastern Time (US & Canada).



## Friday, Barbara

---

**From:** Gibson, Victoria  
**To:** Friday, Barbara  
**Sent:** Friday, February 05, 2010 1:11 PM  
**Subject:** Read: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Your message was read on Friday, February 05, 2010 1:10:44 PM (GMT-05:00) Eastern Time (US & Canada).

## Friday, Barbara

---

**From:** Holtom, Jonathan  
**To:** Friday, Barbara  
**Sent:** Friday, February 05, 2010 1:07 PM  
**Subject:** Read: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Your message was read on Friday, February 05, 2010 1:07:13 PM (GMT-05:00) Eastern Time (US & Canada).

**Friday, Barbara**

---

**From:** Microsoft Exchange  
**To:** Walker, Elizabeth (AIR); Shine, Caroline; Koerner, Jeff  
**Sent:** Friday, February 05, 2010 1:07 PM  
**Subject:** Delivered: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER;  
0950137-029-AV

**Your message has been delivered to the following recipients:**

Walker, Elizabeth (AIR)

Shine, Caroline

Koerner, Jeff

Subject: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

---

Sent by Microsoft Exchange Server 2007

**Friday, Barbara**

---

**From:** Koerner, Jeff  
**To:** Friday, Barbara  
**Sent:** Friday, February 05, 2010 1:09 PM  
**Subject:** Read: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV

Your message was read on Friday, February 05, 2010 1:08:53 PM (GMT-05:00) Eastern Time (US & Canada).

**Friday, Barbara**

---

**From:** Mail Delivery System [MAILER-DAEMON@mseive02.rtp.epa.gov]  
**To:** Forney.Kathleen@epamail.epa.gov; Oquendo.Ana@epamail.epa.gov  
**Sent:** Friday, February 05, 2010 1:07 PM  
**Subject:** Relayed: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER;  
0950137-029-AV

**Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:**

[Forney.Kathleen@epamail.epa.gov](mailto:Forney.Kathleen@epamail.epa.gov)

[Oquendo.Ana@epamail.epa.gov](mailto:Oquendo.Ana@epamail.epa.gov)

Subject: ORLANDO UTILITIES COMMISSION - STANTON ENERGY CENTER; 0950137-029-AV