

DEPARTMENT OF ENVIRONMENTAL REGULATION

ROUTING AND TRANSMITTAL SLIP		ACTION NO.
		ACTION DUE DATE
1. TO: (NAME, OFFICE, LOCATION)	INITIAL	DATE
<i>Bob King</i>		
2.	INITIAL	DATE
3.	INITIAL	DATE
4.	INITIAL	DATE
REMARKS:		INFORMATION
DER APR 23 1982 BAQM		REVIEW & RETURN
		REVIEW & FILE
		INITIAL & FORWARD
		DISPOSITION
		REVIEW & RESPOND
		PREPARE RESPONSE
		FOR MY SIGNATURE
		FOR YOUR SIGNATURE
		LET'S DISCUSS
		SET UP MEETING
		INVESTIGATE & REPLY
		INITIAL & FORWARD
		DISTRIBUTE
		CONCURRENCE
		FOR PROCESSING
FROM:		DATE <i>4-21</i>
<i>C. Collins</i>		PHONE

DEPARTMENT OF ENVIRONMENTAL REGULATION

INTEROFFICE MEMORANDUM

For Routing To District Offices And/Or To Other Than The Addressee	
To: _____	Loctn.: _____
To: _____	Loctn.: _____
To: _____	Loctn.: _____
From: _____	Date: _____

ST. JOHNS RIVER DISTRICT

TO: Bob King° OSJ-82-0954

THROUGH: A. Senkevich

THROUGH: T. Hunnicutt *JH*

FROM: C. Collins *CMC*

DATE: April 19, 1982

SUBJECT: Preliminary Determination - Orlando Utilities
Commission Stanton Energy Center Units I and 2
(PSD-FL-084)

DER
APR 23 1982
BAQM

As you requested, we are setting forth our verbal comments to Clair Fancy on the above referenced subject.

1. Page 30 - the Coal Stacking Spray is to be operating at all times. The proposed operation limit was 10%. OUC expressed doubts that they could meet 10% and wanted 20%. We finally agreed that under the condition that the spray was operating at its rated efficiency, the limit would be no greater than 20%.

We alerted OUC of the real world situation when their men would turn the scrubbers off or let it fall into a state of dispair and quote the fact that they have a 20% limit. Mr. Bill Shoup agrees that the up to 20% capacity limit would be based on the spray operating and doing its best.

2. Page 30 - the pH alarm should sound when the level rises above not falls below the scrubber water standard. If the water became more basic than the SO₂ it is not being removed if the water is becoming more acidic. The SO₂ is becoming H₂SO₄ and everything is O.K.

3. Under General Conditions - The District Manager must be notified at once by telephone, then notified in writing, no later than four (4) days after the beginning of any non-compliance. We must know this to visit the site and we may choose to run air monitoring equipment and it is imperative that we are fully informed to handle calls from the public and the news media.

Should we be of further assistance, please let us know.

CMC:es

cc: Clair Fancy
Buck Oven