



Florida Gas Transmission Company  
 Tallahassee Region  
 1987 Commonwealth Lane  
 Tallahassee, FL 32303

Main Telephone: 850-350-5000 FAX: 850-350-5000

Date: 8/26/04

**FAX**

7151

To

James Fleak

From

Jake Krautsch

*90 day response*

*Remove Heat Input from permit condition  
 Central District*

*Jeff Koerner at Tallahassee discussed*

*1806 turbine application to change heat input  
 should get construction permit within 90 days from Jeff K.  
 Tallahassee*

*Phase I & VI - FDEP district*

*all construction permits went thru Tallahassee Jeff Koerner  
 within 12 mo. Title V application to modify*

Aug 18 04 04:04p

Air Program

407-897-5963

p.2



Jeb Bush  
Governor

# Department of Environmental Protection

Central District  
3319 Maguire Boulevard, Suite 232  
Orlando, Florida 32803-3767

*due within  
90 days  
Aug 18, 2004  
30 days  
60 days  
Nov 17, 2004*

## AIR RESOURCES COMPLETENESS REVIEW

**SOURCE NAME:** Compressor Station #18  
**APPLICANT:** Richard Craig, VP Southeast Operations      **DATE RECEIVED:** 03/04/04  
**LOCATION:** Florida Gas Transmission      **FILE:** 0950190-C05-AV  
 7990 Stear Lake Road      **FAX:** 850.350.3001  
 Orlando, FL 32861

Mr. Krausch's response to my completeness letter for this project was received on July 20, 2004 and reviewed by this office. The following is needed to complete the application.

1. From permit 0950190-004-AC, Performance Restrictions, 3. Permitted Capacities: The maximum heat input rate to the gas turbine shall not exceed 63 MMBtu per hour... From permit 0950190-003-AV, Specific Condition 1. Capacity. The maximum... shall not exceed 15 MMBtu/hr per engine.

To remove the hourly rates, my supervisor has advised that a construction permit is needed for the other units (001-004) and that application should go to Tallahassee. Until both construction permits are issued, this application will be labeled incomplete. Please provide a copy of construction permit(s) when issued.

2. A staff member of Orange Co. Pollution Control has stated that Engine 1806 and perhaps another engine is out of compliance with the hourly heat input rate. Please provide a statement about the compliance status of each engine and a compliance plan (application page A-12, number 3) so that the hourly heat input limitations are maintained.

Please provide a compliance plan or evidence of construction permit(s) from Tallahassee removing the hourly limit.

Pursuant to Rule 62-4.055, the applicant (Mr. Craig) shall have ninety days after the Department mails a timely request for additional information to submit that information to the Department. If an applicant requires more than ninety days in which to respond to a request for additional information, the applicant may notify the Department in writing of the circumstances, at which time the application shall be held in active status for one additional period of up to ninety days. Additional extensions shall be granted for good cause shown by the applicant. A showing that the applicant is making a diligent effort to obtain the requested additional information shall constitute good cause. Failure of an applicant to provide the timely requested information by the applicable deadline shall result in denial of the application.

"More Protection, Less Process"

Printed on recycled paper.

Aug 18 04 04:05p

Air Program

407-897-5963

p.3

Florida Gas Transmission, Station #18  
0950190-005-AV  
page two  
1

Please provide future responses from Mr. Craig to complete the application process. If you have any questions regarding this letter, please fax me at 407.897.5963 or write to me at the above address.

Sincerely,



Alan Zahn, P.E.  
Permitting Supervisor

18 Aug '04  
date

cc: Jacob Krautsch, FL Gas Transmission, fax 8503505001  
John Kapser, PE, OCEPD, fax 4078361498  
Al Linaro, PE, DARM, fax 2926979