



Lawton Chiles  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

**RECEIVED**  
JAN 23 1997  
PERIGEE TECHNICAL  
SERVICES, INC.

Virginia B. Wetherell  
Secretary

January 21, 1997

Mr. Jerome J. Guidry, P.E.  
President  
Perigee Technical Services, Inc.  
6658 The Landings Drive  
Orlando, Florida 32812-3528

RE: Kissimmee Utility Authority

Dear Mr. Guidry:

The Emissions Monitoring Section has reviewed your November 29 letter concerning Kissimmee Utility Authority's request to use nitrogen oxide emissions data collected during its annual RATA to demonstrate compliance with its emission standard. Pursuant to the conditions stated in the letter, it does not appear that the proposed procedure would substantially depart from the requirements of either 40 CFR 60 or 40 CFR 75. Therefore, we do not believe that approval of an alternate sampling procedure would be required in this specific case.

If you have any questions, please contact Amy Hulbert at 904/488-6140, or write to me.

Sincerely,

FOR

M. D. Harley, P.E., DEE  
P.E. Administrator  
Emissions Monitoring Section  
Bureau of Air Monitoring and Mobile Sources

MDH:adh

cc: Len Kozlov, Central District