

PALMETTO POWER L.L.C.

1000 Louisiana, Suite 5800
Houston, Texas 77002-5050
(713) 507-6400

RECEIVED

OCT 15 1999

BUREAU OF AIR REGULATION

October 13, 1999

Administrator, New Source Review Section
Florida Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Attention: Mr. A.A. Linero, P.E.

0970073-001-AC
PSD-F1-277

RE: DYNEGY, INC.
AIR PERMIT APPLICATION AND PREVENTION OF SIGNIFICANT
DETERIORATION ANALYSIS
PALMETTO POWER PROJECT, OSCEOLA COUNTY, FLORIDA

Dear Mr. Linero:

Palmetto Power L.L.C. is pleased to submit this application for a permit to license, construct, and operate an independent power production facility in Osceola County, Florida. The enclosed application includes supportive information that the project is required to provide under the regulations for Prevention of Significant Deterioration (PSD) of air quality. As you may know, the associated fee of \$7,500 for processing the application was previously forwarded to the DEP ahead of this application.

We appreciate your timely review of this application and look forward toward working with you. If you have any questions, please contact me at (713) 767-8961.

Sincerely,



Starla Lacy
Environmental Specialist


CC: J. Koerner, BAR
Central District
EPA
NPS
C. Carlson, BAR

VOUCHER	VENDOR INVOICE #	INVOICE DATE	TOTAL AMOUNT	PRIOR PAYMENTS	NET AMOUNT
00006233 081099		19990810		\$	7,500.00

Page 1 of 1

DYN-6005 (8/98)

Dynegy Inc.
1000 Louisiana Street, Suite 5800
Houston, Texas 77002

RECEIVED
POST OFFICE

EGY

32333-6316 01





Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

October 20, 1999

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. John Bunyak, Chief
Policy, Planning & Permit Review Branch
NPS - Air Quality Division
P.O. Box 25287
Denver, CO 80225

Re: Palmetto Power LLC
New Facility, Three Westinghouse Frame 501F Combustion Turbines
PSD-FL-277 (File No. 0970073-001-AC)
Facility ID No. 0970073

Dear Mr. Bunyak:

Enclosed for your review and comment is an application for the above referenced project. The applicant proposes to construct a new electrical power generating facility consisting of three new Westinghouse Frame 501F Combustion Turbines. Each gas turbine is fired only with natural gas and will produce a nominal 180 MW per hour of peaking power for up to 3750 hours per year. The applicant has proposed the following BACT limits:

- NOx: 15.0 ppmvd @ 15% oxygen with natural gas only firing and dry low-NOx combustion controls, and
- CO: 25.0 ppmvd @ 15% oxygen with natural gas only firing, combustor design, and good combustion practices.


Your comments may be forwarded to my attention at the letterhead address or faxed to the Bureau of Air Regulation at 850/922-6979. If you have any questions, please contact the project engineer, Jeff Koerner, at 850/414-7268.

Sincerely,

Al Linero, P.E.
Administrator
New Source Review Section

AAL/jfk/kt

Enclosures



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

October 20, 1999

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Gregg Worley, Chief
Air, Radiation Technology Branch
Preconstruction/HAP Section
U.S. EPA - Region 4
61 Forsyth Street
Atlanta, GA 30303

Re: Palmetto Power LLC
New Facility, Three Westinghouse Frame 501F Combustion Turbines
PSD-FL-277 (File No. 0970073-001-AC)
Facility ID No. 0970073

Dear Mr. Worley:

Enclosed for your review and comment is an application for the above referenced project. The applicant proposes to construct a new electrical power generating facility consisting of three new Westinghouse Frame 501F Combustion Turbines. Each gas turbine is fired only with natural gas and will produce a nominal 180 MW per hour of peaking power for up to 3750 hours per year. The applicant has proposed the following BACT limits:

- NOx: 15.0 ppmvd @ 15% oxygen with natural gas only firing and dry low-NOx combustion controls, and
- CO: 25.0 ppmvd @ 15% oxygen with natural gas only firing, combustor design, and good combustion practices.

Your comments may be forwarded to my attention at the letterhead address or faxed to the Bureau of Air Regulation at 850/922-6979. If you have any questions, please contact the project engineer, Jeff Koerner, at 850/414-7268.

Sincerely,

Al Linero, P.E.
Administrator
New Source Review Section

AAL/jfk/kt

Enclosures

RECEIVED

OCT 15 1999

BUREAU OF AIR REGULATION

**AIR PERMIT APPLICATION
AND PREVENTION OF SIGNIFICANT
DETERIORATION ANALYSIS
FOR THE PALMETTO POWER L.L.C. FACILITY**

Submitted by:

**Palmetto Power L.L.C.
1000 Louisiana, Suite 5800
Houston, Texas 77002-5050**

Prepared By:

**Golder Associates Inc.
6241 NW 23rd Street, Suite 500
Gainesville, Florida 32653-1500**

**October 1999
9937575Y/F1**

DISTRIBUTION:

**4 Copies - FDEP
3 Copies - Palmetto Power L.L.C.
3 Copies - Golder Associates**

TABLE OF CONTENTS

AIR PERMIT APPLICATION

PSD ANALYSIS

1.0	INTRODUCTION AND EXECUTIVE SUMMARY	1-1
1.1	<u>PROJECT APPROACH</u>	1-1
1.2	<u>PREVENTION OF SIGNIFICANT DETERIORATION (PSD)</u> <u>REQUIREMENTS</u>	1-2
1.3	<u>BEST AVAILABLE CONTROL TECHNOLOGY (BACT) ANALYSIS</u>	1-3
1.4	<u>AIR QUALITY ANALYSIS</u>	1-3
1.5	<u>SUMMARY OF RESULTS</u>	1-4
1.6	<u>AIR PERMIT APPLICATION ORGANIZATION</u>	1-4
2.0	PROJECT DESCRIPTION	2-1
2.1	<u>SITE DESCRIPTION</u>	2-1
2.2	<u>POWER PLANT</u>	2-1
2.3	<u>PROPOSED SOURCE EMISSIONS AND STACK PARAMETERS</u>	2-4
2.4	<u>SITE LAYOUT, STRUCTURES, AND STACK SAMPLING FACILITIES</u>	2-5
3.0	AIR QUALITY REVIEW REQUIREMENTS AND APPLICABILITY	3-1
3.1	<u>NATIONAL AND STATE AAQS</u>	3-1
3.2	<u>PREVENTION OF SIGNIFICANT DETERIORATION (PSD)</u> <u>REQUIREMENTS</u>	3-1
3.3	<u>EMISSION STANDARDS</u>	3-10
3.4	<u>PSD APPLICABILITY TO OSCEOLA COUNTY</u>	3-12
4.0	CONTROL TECHNOLOGY REVIEW	4-1
4.1	<u>APPLICABILITY</u>	4-1
4.2	<u>NEW SOURCE PERFORMANCE STANDARDS</u>	4-2
4.3	<u>BEST AVAILABLE CONTROL TECHNOLOGY FOR</u> <u>SIMPLE CYCLE OPERATION</u>	4-2
5.0	AMBIENT MONITORING ANALYSIS	5-1
6.0	AIR QUALITY IMPACT ANALYSIS	6-1
6.1	<u>AIR MODELING PROTOCOL</u>	6-1

TABLE OF CONTENTS

6.2	<u>SIGNIFICANT IMPACT ANALYSIS APPROACH</u>	6-1
6.3	<u>PRECONSTRUCTION MONITORING ANALYSIS APPROACH</u>	6-2
6.4	<u>AIR MODELING ANALYSIS APPROACH</u>	6-2
6.5	<u>AIR MODELING RESULTS</u>	6-7
7.0	ADDITIONAL IMPACT ANALYSIS	7-1
7.1	<u>IMPACTS DUE TO DIRECT GROWTH</u>	7-1
7.2	<u>IMPACTS ON SOILS, VEGETATION AND WILDLIFE</u>	7-1
7.3	<u>IMPACTS UPON PSD CLASS I AREAS</u>	7-1

APPENDICES

- A - VENDOR INFORMATION ON "F" CLASS COMBUSTION TURBINE
- B - BEST AVAILABLE CONTROL TECHNOLOGY FOR THE PROPOSED COMBUSTION TURBINES
- C - AIR QUALITY MODELING PROTOCOL DOCUMENTS
- D - BUILDING DOWNWASH INFORMATION FROM BPIP
- E - DETAILED SUMMARY OF ISCST MODEL RESULTS

LIST OF TABLES

- 1-1 Summary of Maximum "Annual" Pollutant Emissions for the Palmetto Power L.L.C. Project
- 2-1 Stack, Operating, and Emission Data for the Palmetto Power L.L.C. Project with Dry Low-NO_x Combustors Firing Natural Gas
- 2-2 Summary of Maximum Potential Annual Emissions for the Palmetto Power L.L.C. Project Simple Cycle Operation
- 3-1 National and State AAQS, Allowable PSD Increments, and Significant Impact Levels
- 3-2 PSD Significant Emission Rates and *De Minimis* Monitoring Concentrations
- 3-3 Net Increase in Emissions Due to the Proposed Palmetto Power L.L.C. Facility Compared to the PSD Significant Emission Rates
- 3-4 Predicted Net Increase in Impacts Due to the Proposed Palmetto Power L.L.C. Facility Compared to PSD *De Minimis* Monitoring Concentrations
- 4-1 NO_x Emission Estimates (TPY) of BACT Alternative Technologies for Simple Cycle Operation per Combustion Turbine
- 4-2 Comparison of Alternative BACT Control Technologies for NO_x - Simple Cycle Mode (per CT)
- 4-3 Maximum Potential Incremental Emissions (TPY) with Selective Catalytic Reduction
- 6-1 Major Features of the ISCST3 Model
- 6-2 Maximum Predicted Pollutant Concentrations For One Simple-Cycle Combustion Turbine Screening Analysis, 501D Combustion Turbine, Natural Gas-Fired
- 6-3 Maximum Pollutant Concentrations Predicted For Three Simple-Cycle Combustion Turbines (Natural Gas-Fired) Compared to EPA Significant Impact and *De Minimis* Monitoring Levels - Screening Analysis
- 6-4 Summary of Maximum Pollutant Concentrations Predicted for Three Simple-Cycle Combustion Turbines Compared to EPA Significant Impact and *De Minimis* Monitoring Levels

LIST OF FIGURES

- 1-1 Location of Proposed Palmetto Power L.L.C. Facility
- 2-1 Simplified Flow Diagram of Proposed Combustion Turbine, Simple Cycle Operation
- 2-2 Site Location Plan of Proposed Palmetto Power L.L.C. Facility
- 2-3 Plot Plan of Proposed Palmetto Power Project

AIR PERMIT APPLICATION



Department of Environmental Protection

Division of Air Resources Management

RECEIVED

APPLICATION FOR AIR PERMIT - TITLE V SOURCE

See Instructions for Form No. 62-210.900(1)

OCT 15 1999

BUREAU OF AIR REGULATION

I. APPLICATION INFORMATION

Identification of Facility

1. Facility Owner/Company Name: Palmetto Power LLC Project	
2. Site Name: Palmetto Power LLC Project (PPP)	
3. Facility Identification Number: <input checked="" type="checkbox"/> Unknown	
4. Facility Location: Street Address or Other Locator: State Road 532 City: _____ County: Osceola Zip Code: _____	
5. Relocatable Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6. Existing Permitted Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Application Contact

1. Name and Title of Application Contact: Starla Lacy	
2. Application Contact Mailing Address: Organization/Firm: Palmetto Power, L. L. C. Street Address: 1000 Louisiana St., Suite 5800 City: Houston State: TX Zip Code: 77002	
3. Application Contact Telephone Numbers: Telephone: (713) 767 - 8961 Fax: (713) 767 - 8764	

Application Processing Information (DEP Use)

1. Date of Receipt of Application:	October 15, 1999
2. Permit Number:	0970073-001-AC
3. PSD Number (if applicable):	PSD-FI-277
4. Siting Number (if applicable):	

Purpose of Application

Air Operation Permit Application

This Application for Air Permit is submitted to obtain: (Check one)


- ☐ Initial Title V air operation permit for an existing facility which is classified as a Title V source.
- ☐ Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.
- Current construction permit number: _____
- ☐ Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application.
- Current construction permit number: _____
- Operation permit number to be revised: _____
- ☐ Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.)
- Operation permit number to be revised/corrected: _____
- ☐ Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.
- Operation permit number to be revised: _____
- Reason for revision: _____

Air Construction Permit Application

This Application for Air Permit is submitted to obtain: (Check one)

- ☒ Air construction permit to construct or modify one or more emissions units.
- ☐ Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.
- ☐ Air construction permit for one or more existing, but unpermitted, emissions units.

Owner/Authorized Representative or Responsible Official

1. Name and Title of Owner/Authorized Representative or Responsible Official: Rick A. Bowen, Executive Vice President
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: Palmetto Power, L. L. C. Street Address: 1000 Louisiana St., Suite 5800 City: Houston State: TX Zip Code: 77002
3. Owner/Authorized Representative or Responsible Official Telephone Numbers: Telephone: (713) 767 - 8532 Fax: (713) 767 - 8511
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative*(check here [], if so) or the responsible official (check here [], if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i>  _____ Signature Date

* Attach letter of authorization if not currently on file.

Professional Engineer Certification

1. Professional Engineer Name: Kennard F. Kosky Registration Number: 14996
2. Professional Engineer Mailing Address: Organization/Firm: Golder Associates Inc. Street Address: 6241 NW 23rd Street, Suite 500 City: Gainesville State: FL Zip Code: 32653-1500
3. Professional Engineer Telephone Numbers: Telephone: (352) 336 - 5600 Fax: (352) 336 - 6603

4. Professional Engineer Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.


If the purpose of this application is to obtain a Title V source air operation permit (check here [], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [X], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

[Signature]

10/14/99
Date



Attach any exception to certification statement.

Scope of Application

Emissions Unit ID	Description of Emissions Unit	Permit Type	Processing Fee
1R	S/W Frame 501F Combustion Turbine	AC1A	
2R	S/W Frame 501F Combustion Turbine	AC1A	
3R	S/W Frame 501F Combustion Turbine	AC1A	

Application Processing Fee

Check one: ☒ Attached - Amount: \$: 7,500 ☐ Not Applicable

Construction/Modification Information

1. Description of Proposed Project or Alterations:

Construction of 3 170-MW 'F' Class combustion turbines. See Attachment PSD-PPP.

2. Projected or Actual Date of Commencement of Construction: **1 Jul 2000**

3. Projected Date of Completion of Construction: **1 Mar 2002**

Application Comment

See Attachment PSD-PPP

II. FACILITY INFORMATION

A. GENERAL FACILITY INFORMATION

Facility Location and Type

1. Facility UTM Coordinates: Zone: 17 East (km): 508.3 North (km): 3135.2			
2. Facility Latitude/Longitude: Latitude (DD/MM/SS): / / Longitude (DD/MM/SS): / /			
3. Governmental Facility Code: 0	4. Facility Status Code: C	5. Facility Major Group SIC Code: 49	6. Facility SIC(s): 4911
7. Facility Comment (limit to 500 characters): Project consists of three 170-MW Siemens/Westinghouse (S/W) Frame 501F combustion turbines that will use dry low-nitrogen oxide combustion technology when firing natural gas. Each CT will operate up to 3,750 hours per year.			

Facility Contact

1. Name and Title of Facility Contact: Ms. Starla Lacy			
2. Facility Contact Mailing Address: Organization/Firm: Palmetto Power, L. L. C. Street Address: 1000 Louisiana St., Suite 5800 City: Houston State: TX Zip Code: 77002			
3. Facility Contact Telephone Numbers: Telephone: (713) 767 - 8961 Fax: (713) 767 - 8764			

Facility Regulatory Classifications**Check all that apply:**

1. <input type="checkbox"/> Small Business Stationary Source?	<input type="checkbox"/> Unknown
2. <input checked="" type="checkbox"/> Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)?	
3. <input type="checkbox"/> Synthetic Minor Source of Pollutants Other than HAPs?	
4. <input type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)?	
5. <input type="checkbox"/> Synthetic Minor Source of HAPs?	
6. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS?	
7. <input type="checkbox"/> One or More Emission Units Subject to NESHAP?	
8. <input type="checkbox"/> Title V Source by EPA Designation?	
9. Facility Regulatory Classifications Comment (limit to 200 characters): CT is subject to NSPS Subpart GG.	

List of Applicable Regulations

Not Applicable	

B. FACILITY POLLUTANTS

List of Pollutants Emitted

[illegible]

C. FACILITY SUPPLEMENTAL INFORMATION

Supplemental Requirements

1. Area Map Showing Facility Location: [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
2. Facility Plot Plan: [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
3. Process Flow Diagram(s): [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
4. Precautions to Prevent Emissions of Unconfined Particulate Matter: [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
5. Fugitive Emissions Identification: [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
6. Supplemental Information for Construction Permit Application: [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable
7. Supplemental Requirements Comment:

Additional Supplemental Requirements for Title V Air Operation Permit Applications

8. List of Proposed Insignificant Activities: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
9. List of Equipment/Activities Regulated under Title VI: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Equipment/Activities On site but Not Required to be Individually Listed <input type="checkbox"/> Not Applicable
10. Alternative Methods of Operation: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
13. Risk Management Plan Verification: <input type="checkbox"/> Plan previously submitted to Chemical Emergency Preparedness and Prevention Office (CEPPO). Verification of submittal attached (Document ID: _____) or previously submitted to DEP (Date and DEP Office: _____) <input type="checkbox"/> Plan to be submitted to CEPPO (Date required: _____) <input type="checkbox"/> Not Applicable
14. Compliance Report and Plan: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
15. Compliance Certification (Hard-copy Required): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)**Emissions Unit Description and Status**

1. Type of Emissions Unit Addressed in This Section: (Check one)			
<input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
<input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
<input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Siemens/Westinghouse Frame 501F Simple Cycle			
4. Emissions Unit Identification Number:		[] No ID	
ID:		[X] ID Unknown	
5. Emissions Unit Status Code: C	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit? [X]
9. Emissions Unit Comment: (Limit to 500 Characters) This emission unit is a S/W Frame 501F combustion turbine operating in simple cycle mode. See Attachment PSD-PPP.			

Emissions Unit Control Equipment

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

Dry Low NO_x combustion - Natural gas firing2. Control Device or Method Code(s): **25****Emissions Unit Details**

1. Package Unit:

Manufacturer: **Siemens/Westinghouse**Model Number: **W501FD**

2. Generator Nameplate Rating:

182.5 MW

3. Incinerator Information:

Dwell Temperature:

°F

Dwell Time:

seconds

Incinerator Afterburner Temperature:

°F

B. EMISSIONS UNIT CAPACITY INFORMATION
(Regulated Emissions Units Only)**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	1,681	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	hours/day	days/week
	weeks/year	3,750 hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters): Maximum heat input at ISO conditions and natural gas firing (LHV) and 182.5 MW with evaporative coolers off.		

C. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)**List of Applicable Regulations**

See Attachment IPS-EU1-D for operational requirements	
See Attachment PSD-PPP for permitting requirements	

ATTACHMENT PPP-EU1-D

Applicable Requirements Listing

EMISSION UNIT ID: EU1

FDEP Rules:

Air Pollution Control-General Provisions:

- 62-204.800(7)(b)37. (State Only) - NSPS Subpart GG
- 62-204.800(7)(c) (State Only) - NSPS authority
- 62-204.800(7)(d)(State Only) - NSPS General Provisions
- 62-204.800(12) (State Only) - Acid Rain Program
- 62-204.800(13) (State Only) - Allowances
- 62-204.800(14) (State Only) - Acid Rain Program Monitoring
- 62-204.800(16) (State Only) - Excess Emissions (Potentially applicable over term of permit)

Stationary Sources-General:

- 62-210.650 - Circumvention; EUs with control device
- 62-210.700(1) - Excess Emissions;
- 62-210.700(4) - Excess Emissions; poor maintenance
- 62-210.700(6) - Excess Emissions; notification

Acid Rain:

- 62-214.300 - All Acid Rain Units (Applicability)
- 62-214.320(1)(a),(2) - All Acid Rain Units (Application Shield)
- 62-214.330(1)(a)1. - Compliance Options (if 214.430)
- 62-214.340 - Exemptions (new units, retired units)
- 62-214.350(2);(3);(6) - All Acid Rain Units (Certification)
- 62-214.370 - All Acid Rain Units (Revisions; correction; potentially applicable if a need arises)
- 62-214.430 - All Acid Rain Units (Compliance Options-if required)

Stationary Sources-Emission Standards:

- 62-296.320(4)(b)(State Only) - CTs/Diesel Units

Stationary Sources-Emission Monitoring (where stack test is required):

- 62-297.310(1) - All Units (Test Runs-Mass Emission)
- 62-297.310(2)(b) - All Units (Operating Rate; other than CTs;no CT)
- 62-297.310(3) - All Units (Calculation of Emission)
- 62-297.310(4)(a) - All Units (Applicable Test Procedures;Sampling time)
- 62-297.310(4)(b) - All Units (Sample Volume)
- 62-297.310(4)(c) - All Units (Required Flow Rate Range-PM/H2SO4/F)
- 62-297.310(4)(d) - All Units (Calibration)
- 62-297.310(4)(e) - All Units (EPA Method 5-only)

62-297.310(5)
62-297.310(6)(a)
62-297.310(6)(c)
62-297.310(6)(d)
62-297.310(6)(e)
62-297.310(6)(f)
62-297.310(6)(g)
62-297.310(7)(a)1.
62-297.310(7)(a)2.
62-297.310(7)(a)3.
62-297.310(7)(a)4.a
62-297.310(7)(a)5.
62-297.310(7)(a)6.
62-297.310(7)(a)7.
62-297.310(7)(a)9.
62-297.310(7)(c)
62-297.310(8)

- All Units (Determination of Process Variables)
- All Units (Permanent Test Facilities-general)
- All Units (Sampling Ports)
- All Units (Work Platforms)
- All Units (Access)
- All Units (Electrical Power)
- All Units (Equipment Support)
- Applies mainly to CTs/Diesels
- FFSG excess emissions
- Permit Renewal Test Required
- Annual Test
- PM exemption if <400 hrs/yr
- PM FFSG semi annual test required if >200 hrs/yr
- PM quarterly monitoring if >100 hrs/yr
- FDEP Notification - 15 days
- Waiver of Compliance Tests (Fuel Sampling)
- Test Reports

Federal Rules:

NSPS Subpart GG:
40 CFR 60.332(a)(1)
40 CFR 60.332(a)(3)
40 CFR 60.333
40 CFR 60.334
40 CFR 60.335

- NOx for Electric Utility CTs
- NOx for Electric Utility CTs
- SO2 limits
- Monitoring of Operations (Custom Monitoring for Gas)
- Test Methods

NSPS General Requirements:

40 CFR 60.7(a)(1)
40 CFR 60.7(a)(2)
40 CFR 60.7(a)(3)
40 CFR 60.7(a)(4)
Cycle)
40 CFR 60.7(a)(5)
40 CFR 60.7(b)
(startup/shutdown/malfunction)
40 CFR 60.7(c)
(startup/shutdown/malfunction)
40 CFR 60.7(d)
(startup/shutdown/malfunction)
40 CFR 60.7(f)
40 CFR 60.8(a)
40 CFR 60.8(b)
40 CFR 60.8(c)
40 CFR 60.8(e)

- Notification of Construction
- Notification of Initial Start-Up
- Notification of Actual Start-Up
- Notification and Recordkeeping (Physical/Operational
- Notification of CEM Demonstration
- Notification and Recordkeeping
- Notification and Recordkeeping
- Notification and Recordkeeping
- Notification and Recordkeeping (maintain records-2 yrs)
- Performance Test Requirements
- Performance Test Notification
- Performance Tests (representative conditions)
- Provide Stack Sampling Facilities

40 CFR 60.8(f)

- Test Runs

40 CFR 60.11(a)	- Compliance (ref. S. 60.8 or Subpart; other than opacity)
40 CFR 60.11(b)	- Compliance (opacity determined EPA Method 9)
40 CFR 60.11(c)	- Compliance (opacity; excludes
startup/shutdown/malfunction)	
40 CFR 60.11(d)	- Compliance (maintain air pollution control equip.)
40 CFR 60.11(e)(2)	- Compliance (opacity; ref. S. 60.8)
40 CFR 60.12	- Circumvention
40 CFR 60.13(a)	- Monitoring (Appendix B; Appendix F)
40 CFR 60.13(c)	- Monitoring (Opacity COMS)
40 CFR 60.13(d)(1)	- Monitoring (CEMS; span, drift, etc.)
40 CFR 60.13(d)(2)	- Monitoring (COMS; span, system check)
40 CFR 60.13(e)	- Monitoring (frequency of operation)
40 CFR 60.13(f)	- Monitoring (frequency of operation)
40 CFR 60.13(h)	- Monitoring (COMS; data requirements)
Acid Rain-Permits:	
40 CFR 72.9(a)	- Permit Requirements
40 CFR 72.9(b)	- Monitoring Requirements
40 CFR 72.9(c)(1)	- SO2 Allowances-hold allowances
40 CFR 72.9(c)(2)	- SO2 Allowances-violation
40 CFR 72.9(c)(3)(iii)	- SO2 Allowances-Phase II Units (listed)
40 CFR 72.9(c)(4)	- SO2 Allowances-allowances held in ATS
40 CFR 72.9(c)(5)	- SO2 Allowances-no deduction for 72.9(c)(1)(i)
40 CFR 72.9(d)	- NOx Requirements
40 CFR 72.9(e)	- Excess Emission Requirements
40 CFR 72.9(f)	- Recordkeeping and Reporting
40 CFR 72.9(g)	- Liability
40 CFR 72.20(a)	- Designated Representative; required
40 CFR 72.20(b)	- Designated Representative; legally binding
40 CFR 72.20(c)	- Designated Representative; certification requirements
40 CFR 72.21	- Submissions
40 CFR 72.22	- Alternate Designated Representative
40 CFR 72.23	- Changing representatives; owners
40 CFR 72.24	- Certificate of representation
40 CFR 72.30(a)	- Requirements to Apply (operate)
40 CFR 72.30(b)(2)	- Requirements to Apply (Phase II-Complete)
40 CFR 72.30(c)	- Requirements to Apply (reapply before expiration)
40 CFR 72.30(d)	- Requirements to Apply (submittal requirements)
40 CFR 72.31	- Information Requirements; Acid Rain Applications
40 CFR 72.32	- Permit Application Shield
40 CFR 72.33(b)	- Dispatch System ID;unit/system ID
40 CFR 72.33(c)	- Dispatch System ID;ID requirements
40 CFR 72.33(d)	- Dispatch System ID;ID change
40 CFR 72.40(a)	- General; compliance plan
40 CFR 72.40(b)	- General; multi-unit compliance options
40 CFR 72.40(c)	- General; conditional approval

40 CFR 72.40(d)
40 CFR 72.51
40 CFR 72.90

- General; termination of compliance options
- Permit Shield
- Annual Compliance Certification

Allowances:

40 CFR 73.33(a),(c)
40 CFR 73.35(c)(1)

- Authorized account representative
- Compliance: ID of allowances by serial number

Monitoring Part 75:

40 CFR 75.4
40 CFR 75.5
40 CFR 75.10(a)(1)
40 CFR 75.10(a)(2)
40 CFR 75.10(a)(3)(iii)
40 CFR 75.10(b)
40 CFR 75.10(c)
40 CFR 75.10(e)
40 CFR 75.10(f)
40 CFR 75.10(g)
40 CFR 75.11(d)
40 CFR 75.11(e)
40 CFR 75.12(a)
40 CFR 75.12(b)

- Compliance Dates;
- Prohibitions
- Primary Measurement; SO₂;
- Primary Measurement; NO_x;
- Primary Measurement; CO₂; O₂ monitor
- Primary Measurement; Performance Requirements
- Primary Measurement; Heat Input; Appendix F
- Primary Measurement; Optional Backup Monitor
- Primary Measurement; Minimum Measurement
- Primary Measurement; Minimum Recording
- SO₂ Monitoring; Gas- and Oil-fired units
- SO₂ Monitoring; Gaseous firing
- NO_x Monitoring; Coal; Non-peaking oil/gas units
- NO_x Monitoring; Determination of NO_x emission rate; Appendix F
- CO₂ Monitoring; Appendix G
- CO₂ Monitoring; Appendix F
- Opacity Monitoring; Gas units; exemption
- Initial Certification Approval Process; Loss of

40 CFR 75.13(b)
40 CFR 75.13(c)
40 CFR 75.14(c)
40 CFR 75.20(a)
Certification

- Recertification Procedures (if recertification necessary)
- Certification Procedures (if recertification necessary)
- Recertification Backup/portable monitor
- Alternate Monitoring system
- QA/QC; CEMS; Appendix B (Suspended 7/17/95-

12/31/96)
40 CFR 75.21(c)
40 CFR 75.21(d)
40 CFR 75.21(e)
40 CFR 75.21(f)
40 CFR 75.22
40 CFR 75.24
40 CFR 75.30(a)(3)
40 CFR 75.30(a)(4)
40 CFR 75.30(b)
monitor
40 CFR 75.30(c)
monitor

- QA/QC; Calibration Gases
- QA/QC; Notification of RATA
- QA/QC; Audits
- QA/QC; CEMS (Effective 7/17/96-12/31/96)
- Reference Methods
- Out-of-Control Periods; CEMS
- General Missing Data Procedures; NO_x
- General Missing Data Procedures; SO₂
- General Missing Data Procedures; certified backup
- General Missing Data Procedures; certified backup

40 CFR 75.30(d)	- General Missing Data Procedures; SO ₂ (optional before 1/1/97)
40 CFR 75.30(e) stacks	- General Missing Data Procedures; bypass/multiple
40 CFR 75.31	- Initial Missing Data Procedures (new/re-certified CMS)
40 CFR 75.32	- Monitoring Data Availability for Missing Data
40 CFR 75.33	- Standard Missing Data Procedures
40 CFR 75.36	- Missing Data for Heat Input
40 CFR 75.40	- Alternate Monitoring Systems-General
40 CFR 75.41	- Alternate Monitoring Systems-Precision Criteria
40 CFR 75.42	- Alternate Monitoring Systems-Reliability Criteria
40 CFR 75.43	- Alternate Monitoring Systems-Accessability Criteria
40 CFR 75.44	- Alternate Monitoring Systems-Timeliness Criteria
40 CFR 75.45	- Alternate Monitoring Systems-Daily QA
40 CFR 75.46	- Alternate Monitoring Systems-Missing data
40 CFR 75.47	- Alternate Monitoring Systems-Criteria for Class
40 CFR 75.48	- Alternate Monitoring Systems-Petition
40 CFR 75.53	- Monitoring Plan ; revisions
40 CFR 75.54(a)	- Recordkeeping-general
40 CFR 75.54(b)	- Recordkeeping-operating parameter
40 CFR 75.54(c)	- Recordkeeping-SO ₂
40 CFR 75.54(d)	- Recordkeeping-NO _x
40 CFR 75.54(e)	- Recordkeeping-CO ₂
40 CFR 75.54(f)	- Recordkeeping-Opacity
40 CFR 75.55(c)	- General Recordkeeping (Specific Situations)
40 CFR 75.55(e)	- General Recordkeeping (Specific Situations)
40 CFR 75.56	- Certification; QA/QC Provisions
40 CFR 75.60	- Reporting Requirements-General
40 CFR 75.61	- Reporting Requirements-Notification cert/recertification
40 CFR 75.62	- Reporting Requirements-Monitoring Plan
40 CFR 75.63	- Reporting Requirements-Certification/Recertification
40 CFR 75.64(a)	- Reporting Requirements-Quarterly reports; submission
40 CFR 75.64(b) statement	- Reporting Requirements-Quarterly reports; DR
40 CFR 75.64(c)	- Rep. Req.; Quarterly reports; Compliance Certification
40 CFR 75.64(d)	- Rep. Req.; Quarterly reports; Electronic format
40 CFR 75.66	- Petitions to the Administrator (if required)
Appendix A-1	- Installation and Measurement Locations
Appendix A-2.	- Equipment Specifications
Appendix A-3.	- Performance Specifications
Appendix A-4.	- Data Handling and Acquisition Systems
Appendix A-5.	- Calibration Gases
Appendix A-6.	- Certification Tests and Procedures
Appendix A-7.	- Calculations
Appendix B	- QA/QC Procedures
Appendix C-1.	- Missing Data; SO ₂ /NO _x for controlled sources
Appendix C-2.	- Missing Data; Load-Based Procedure; NO _x & flow

Appendix D
Appendix F
Appendix H

- Optional SO₂; Oil-/gas-fired units
- Conversion Procedures
- Traceability Protocol

Acid Rain Program-Excess Emissions (these are future requirements):

40 CFR 77.3

40 CFR 77.5(b)

40 CFR 77.6

- Offset Plans (future)
- Deductions of Allowances (future)
- Excess Emissions Penalties (SO₂ and NO_x;future)

D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? See Att. PSD-PPP		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): Exhausts through a single stack.			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 50 feet	7. Exit Diameter: 19 feet	
8. Exit Temperature: 1,099 °F	9. Actual Volumetric Flow Rate: 2,429,695 acfm	10. Water Vapor: 8.5 %	
11. Maximum Dry Standard Flow Rate: 750,000 dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: 17 East (km): North (km):			
14. Emission Point Comment (limit to 200 characters): Stack parameters for ISO operating condition firing natural gas with evaporative coolers off.			

E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)**Segment Description and Rate:** Segment 1 of 1

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Natural Gas		
2. Source Classification Code (SCC): 20100201		3. SCC Units: Million Cubic Feet
4. Maximum Hourly Rate: 1.83	5. Maximum Annual Rate: 6,853	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: 920
10. Segment Comment (limit to 200 characters): Based on 920 Btu/cf(LHV); ISO conditions and 3,750 hrs/yr operation with evaporative coolers off.		

Segment Description and Rate: Segment ____ of ____

1. Segment Description (Process/Fuel Type) (limit to 500 characters):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

F. EMISSIONS UNIT POLLUTANTS
(All Emissions Units)

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM			EL
SO ₂			EL
NO _x	026		EL
CO			EL
VOC			EL
PM ₁₀			EL

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**(Regulated Emissions Units -****Emissions-Limited and Preconstruction Review Pollutants Only)****Potential/Fugitive Emissions**

1. Pollutant Emitted: PM		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 8.6 lb/hour 15.3 tons/year		4. Synthetically Limited? [X]	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: Reference: S/W, 1999; Golder		7. Emissions Method Code: 2	
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 32°F. Tons/yr based on 3,750 hrs/yr gas firing; ISO conditions.			

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <10% opacity		4. Equivalent Allowable Emissions: 8.6 lb/hour 15.3 tons/year	
5. Method of Compliance (limit to 60 characters): Annual VE test; EPA Method 9			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Lb/hr based on 32°F; Tons/year at ISO and 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.			

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: SO₂	2. Total Percent Efficiency of Control:
3. Potential Emissions: 5.5 lb/hour 9.8 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Emission Factor: 1 grain S per 100 CF gas; Lb/hr at 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing; ISO conditions.	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: Pipeline Natural Gas	4. Equivalent Allowable Emissions: 5.5 lb/hour 9.8 tons/year
5. Method of Compliance (limit to 60 characters): Fuel Sampling	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Lb/hr at 32°F and 100% load; Tons/year at 3,750 hrs/yr ISO conditions. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: NO_x	2. Total Percent Efficiency of Control:
3. Potential Emissions: 111.2 lb/hour 196.5 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on gas firing at 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions.	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 15 ppmvd	4. Equivalent Allowable Emissions: 111.2 lb/hour 196.5 tons/year
5. Method of Compliance (limit to 60 characters): CEM - 30 Day Rolling Average	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Requested Allowable Emissions is at 15% O₂-100% load. Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: CO	2. Total Percent Efficiency of Control:
3. Potential Emissions: 113.0 lb/hour 200.6 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 25 ppmvd @ 15% O₂	4. Equivalent Allowable Emissions: 113.0 lb/hour 200.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10; high and low load	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: VOC	2. Total Percent Efficiency of Control:
3. Potential Emissions: 3.7 lb/hour 6.6 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load; 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 1.8 ppmvd	4. Equivalent Allowable Emissions: 3.7 lb/hour 6.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 25A; high and low load	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: PM₁₀		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 8.6 lb/hour 15.3 tons/year		4. Synthetically Limited? [X]	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: Reference: S/W, 1999; Golder		7. Emissions Method Code: 2	
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load; 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions			

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: 8.6 lb/hr		4. Equivalent Allowable Emissions: 8.6 lb/hour 15.3 tons/year	
5. Method of Compliance (limit to 60 characters): Annual VE test; EPA Method 9			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Dry Filterable PM - excludes H₂SO₄. See Attachment PSD-PPP; Section 2.0; Appendix A.			

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissions Limitation 1 of 2

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: [] Rule [<input checked="" type="checkbox"/>] Other
3. Requested Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: Annual VE Test EPA Method 9	
5. Visible Emissions Comment (limit to 200 characters): Maximum for gas firing.	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)

Continuous Monitoring System: Continuous Monitor 1 of 2

1. Parameter Code: EM	2. Pollutant(s): NO_x
3. CMS Requirement:	[<input checked="" type="checkbox"/>] Rule [] Other
4. Monitor Information: Not yet determined Manufacturer: Model Number: Serial Number:	
5. Installation Date: 01 Mar 2002	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters): NO_x CEM proposed to meet requirements of 40 CFR Part 75.	

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)**Visible Emissions Limitation:** Visible Emissions Limitation 2 of 2

1. Visible Emissions Subtype: VE99	2. Basis for Allowable Opacity: [<input checked="" type="checkbox"/>] Rule [<input type="checkbox"/>] Other
3. Requested Allowable Opacity: Normal Conditions: % Exceptional Conditions: 100 % Maximum Period of Excess Opacity Allowed: 6 min/hour	
4. Method of Compliance: None	
5. Visible Emissions Comment (limit to 200 characters): FDEP Rule 62-201.700(1), Allowed for 2 hours (120 minutes) per 24 hours for start up, shutdown and malfunction.	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)**Continuous Monitoring System:** Continuous Monitor 2 of 2

1. Parameter Code: O₂	2. Pollutant(s): Oxygen
3. CMS Requirement:	[<input checked="" type="checkbox"/>] Rule [<input type="checkbox"/>] Other
4. Monitor Information: Not yet determined Manufacturer: Model Number: Serial Number:	
5. Installation Date: 01 Mar 2002	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters): Dilution monitor required by 40 CFR Part 75; may be CO₂ in lieu of O₂ monitor.	

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**Supplemental Requirements**

1. Process Flow Diagram [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
2. Fuel Analysis or Specification [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
3. Detailed Description of Control Equipment [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
4. Description of Stack Sampling Facilities [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
5. Compliance Test Report [] Attached, Document ID: _____ [] Previously submitted, Date: _____ [X] Not Applicable
6. Procedures for Startup and Shutdown [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
7. Operation and Maintenance Plan [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
8. Supplemental Information for Construction Permit Application [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable
9. Other Information Required by Rule or Statute [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable
10. Supplemental Requirements Comment:

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID:_____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID:_____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID:_____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID:_____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID:_____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID:_____ <input type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)

Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in This Section: (Check one)			
<input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
<input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
<input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Siemens/Westinghouse Frame 501F Simple Cycle			
4. Emissions Unit Identification Number:		<input type="checkbox"/> No ID <input checked="" type="checkbox"/> ID Unknown	
5. Emissions Unit Status Code: C	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit? <input checked="" type="checkbox"/>
9. Emissions Unit Comment: (Limit to 500 Characters) This emission unit is a S/W Frame 501F combustion turbine operating in simple cycle mode. See Attachment PSD-PPP.			

Emissions Unit Control Equipment

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

Dry Low NO_x combustion - Natural gas firing

2. Control Device or Method Code(s): **25**

Emissions Unit Details

1. Package Unit:	
Manufacturer: Siemens/Westinghouse	Model Number: W501FD
2. Generator Nameplate Rating: 182.5 MW	
3. Incinerator Information:	
Dwell Temperature:	°F
Dwell Time:	seconds
Incinerator Afterburner Temperature:	°F

B. EMISSIONS UNIT CAPACITY INFORMATION
(Regulated Emissions Units Only)**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	1,681	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	hours/day	days/week
	weeks/year	3,750 hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):		
Maximum heat input at ISO conditions and natural gas firing (LHV) and 182.5 MW with evaporative coolers off.		

C. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)**List of Applicable Regulations**

See Attachment IPS-EU1-D for operational requirements	
See Attachment PSD-PPP for permitting requirements	

D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? See Att. PSD-PPP		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): Exhausts through a single stack.			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V		6. Stack Height: 50 feet	
		7. Exit Diameter: 19 feet	
8. Exit Temperature: 1,099 °F		9. Actual Volumetric Flow Rate: 2,429,695 acfm	
		10. Water Vapor: 8.5 %	
11. Maximum Dry Standard Flow Rate: 750,000 dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: 17 East (km): North (km):			
14. Emission Point Comment (limit to 200 characters): Stack parameters for ISO operating condition firing natural gas with evaporative coolers off.			

E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)**Segment Description and Rate:** Segment 1 of 1

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Natural Gas		
2. Source Classification Code (SCC): 20100201		3. SCC Units: Million Cubic Feet
4. Maximum Hourly Rate: 1.83	5. Maximum Annual Rate: 6,853	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: 920
10. Segment Comment (limit to 200 characters): Based on 920 Btu/cf(LHV); ISO conditions and 3,750 hrs/yr operation with evaporative coolers off.		

Segment Description and Rate: Segment _____ of _____

1. Segment Description (Process/Fuel Type) (limit to 500 characters):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

F. EMISSIONS UNIT POLLUTANTS
(All Emissions Units)

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM			EL
SO ₂			EL
NO _x	026		EL
CO			EL
VOC			EL
PM ₁₀			EL

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**(Regulated Emissions Units -****Emissions-Limited and Preconstruction Review Pollutants Only)****Potential/Fugitive Emissions**

1. Pollutant Emitted: PM	2. Total Percent Efficiency of Control:
3. Potential Emissions: 8.6 lb/hour 15.3 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 32°F. Tons/yr based on 3,750 hrs/yr gas firing; ISO conditions.	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <10% opacity	4. Equivalent Allowable Emissions: 8.6 lb/hour 15.3 tons/year
5. Method of Compliance (limit to 60 characters): Annual VE test; EPA Method 9	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Lb/hr based on 32°F; Tons/year at ISO and 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**(Regulated Emissions Units -****Emissions-Limited and Preconstruction Review Pollutants Only)****Potential/Fugitive Emissions**

1. Pollutant Emitted: SO₂	2. Total Percent Efficiency of Control:
3. Potential Emissions: 5.5 lb/hour 9.8 tons/year	4. Synthetically Limited? [<input checked="" type="checkbox"/>]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Emission Factor: 1 grain S per 100 CF gas; Lb/hr at 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing; ISO conditions.	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: Pipeline Natural Gas	4. Equivalent Allowable Emissions: 5.5 lb/hour 9.8 tons/year
5. Method of Compliance (limit to 60 characters): Fuel Sampling	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Lb/hr at 32°F and 100% load; Tons/year at 3,750 hrs/yr ISO conditions. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**(Regulated Emissions Units -****Emissions-Limited and Preconstruction Review Pollutants Only)****Potential/Fugitive Emissions**

1. Pollutant Emitted: NO_x	2. Total Percent Efficiency of Control:
3. Potential Emissions: 111.2 lb/hour 196.5 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on gas firing at 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions.	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 15 ppmvd	4. Equivalent Allowable Emissions: 111.2 lb/hour 196.5 tons/year
5. Method of Compliance (limit to 60 characters): CEM - 30 Day Rolling Average	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Requested Allowable Emissions is at 15% O₂-100% load. Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**(Regulated Emissions Units -****Emissions-Limited and Preconstruction Review Pollutants Only)****Potential/Fugitive Emissions**

1. Pollutant Emitted: CO	2. Total Percent Efficiency of Control:
3. Potential Emissions: 113.0 lb/hour 200.6 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 25 ppmvd @ 15% O₂	4. Equivalent Allowable Emissions: 113.0 lb/hour 200.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10; high and low load	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**(Regulated Emissions Units -****Emissions-Limited and Preconstruction Review Pollutants Only)****Potential/Fugitive Emissions**

1. Pollutant Emitted: VOC	2. Total Percent Efficiency of Control:
3. Potential Emissions: 3.7 lb/hour 6.6 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load; 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 1.8 ppmvd	4. Equivalent Allowable Emissions: 3.7 lb/hour 6.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 25A; high and low load	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: PM₁₀	2. Total Percent Efficiency of Control:
3. Potential Emissions: 8.6 lb/hour 15.3 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load; 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 8.6 lb/hr	4. Equivalent Allowable Emissions: 8.6 lb/hour 15.3 tons/year
5. Method of Compliance (limit to 60 characters): Annual VE test; EPA Method 9	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Dry Filterable PM - excludes H₂SO₄. See Attachment PSD-PPP; Section 2.0; Appendix A.	

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)**Visible Emissions Limitation:** Visible Emissions Limitation 1 of 2

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: [] Rule [X] Other
3. Requested Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: Annual VE Test EPA Method 9	
5. Visible Emissions Comment (limit to 200 characters): Maximum for gas firing.	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)**Continuous Monitoring System:** Continuous Monitor 1 of 2

1. Parameter Code: EM	2. Pollutant(s): NO_x
3. CMS Requirement:	[X] Rule [] Other
4. Monitor Information: Not yet determined Manufacturer: Model Number: Serial Number:	
5. Installation Date: 01 Mar 2002	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters): NO_x CEM proposed to meet requirements of 40 CFR Part 75.	

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)**Visible Emissions Limitation:** Visible Emissions Limitation 2 of 2

1. Visible Emissions Subtype: VE99	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Requested Allowable Opacity: Normal Conditions: % Exceptional Conditions: 100 % Maximum Period of Excess Opacity Allowed: 6 min/hour	
4. Method of Compliance: None	
5. Visible Emissions Comment (limit to 200 characters): FDEP Rule 62-201.700(1), Allowed for 2 hours (120 minutes) per 24 hours for start up, shutdown and malfunction.	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)**Continuous Monitoring System:** Continuous Monitor 2 of 2

1. Parameter Code: O₂	2. Pollutant(s): Oxygen
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information: Not yet determined Manufacturer: Model Number: Serial Number:	
5. Installation Date: 01 Mar 2002	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters): Dilution monitor required by 40 CFR Part 75; may be CO₂ in lieu of O₂ monitor.	

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**Supplemental Requirements**

1. Process Flow Diagram [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
2. Fuel Analysis or Specification [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
3. Detailed Description of Control Equipment [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
4. Description of Stack Sampling Facilities [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
5. Compliance Test Report [] Attached, Document ID: _____ [] Previously submitted, Date: _____ [X] Not Applicable
6. Procedures for Startup and Shutdown [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
7. Operation and Maintenance Plan [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
8. Supplemental Information for Construction Permit Application [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable
9. Other Information Required by Rule or Statute [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable
10. Supplemental Requirements Comment:

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in This Section: (Check one)			
<input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
<input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
<input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Siemens/Westinghouse Frame 501F Simple Cycle			
4. Emissions Unit Identification Number:		<input type="checkbox"/> No ID	
ID:		<input checked="" type="checkbox"/> ID Unknown	
5. Emissions Unit Status Code: C	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit? <input checked="" type="checkbox"/>
9. Emissions Unit Comment: (Limit to 500 Characters) This emission unit is a S/W Frame 501F combustion turbine operating in simple cycle mode. See Attachment PSD-PPP.			

Emissions Unit Control Equipment

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

Dry Low NO_x combustion - Natural gas firing

2. Control Device or Method Code(s): 25

Emissions Unit Details

1. Package Unit:	
Manufacturer: Siemens/Westinghouse	Model Number: W501FD
2. Generator Nameplate Rating: 182.5 MW	
3. Incinerator Information:	
Dwell Temperature:	°F
Dwell Time:	seconds
Incinerator Afterburner Temperature:	°F

B. EMISSIONS UNIT CAPACITY INFORMATION
(Regulated Emissions Units Only)**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	1,681	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	hours/day	days/week
	weeks/year	3,750 hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):		
Maximum heat input at ISO conditions and natural gas firing (LHV) and 182.5 MW with evaporative coolers off.		

C. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)**List of Applicable Regulations**

See Attachment IPS-EU1-D for operational requirements	
See Attachment PSD-PPP for permitting requirements	

D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? See Att. PSD-PPP		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): Exhausts through a single stack.			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 50 feet	7. Exit Diameter: 19 feet	
8. Exit Temperature: 1,099 °F	9. Actual Volumetric Flow Rate: 2,429,695 acfm	10. Water Vapor: 8.5 %	
11. Maximum Dry Standard Flow Rate: 750,000 dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: 17 East (km): North (km):			
14. Emission Point Comment (limit to 200 characters): Stack parameters for ISO operating condition firing natural gas with evaporative coolers off.			

E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)**Segment Description and Rate:** Segment 1 of 1

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Natural Gas		
2. Source Classification Code (SCC): 20100201		3. SCC Units: Million Cubic Feet
4. Maximum Hourly Rate: 1.83	5. Maximum Annual Rate: 6,853	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: 920
10. Segment Comment (limit to 200 characters): Based on 920 Btu/cf(LHV); ISO conditions and 3,750 hrs/yr operation with evaporative coolers off.		

Segment Description and Rate: Segment of

1. Segment Description (Process/Fuel Type) (limit to 500 characters):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

F. EMISSIONS UNIT POLLUTANTS
(All Emissions Units)

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM			EL
SO ₂			EL
NO _x	026		EL
CO			EL
VOC			EL
PM ₁₀			EL

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**(Regulated Emissions Units -****Emissions-Limited and Preconstruction Review Pollutants Only)****Potential/Fugitive Emissions**

1. Pollutant Emitted: PM		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 8.6 lb/hour 15.3 tons/year		4. Synthetically Limited? [X]	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: Reference: S/W, 1999; Golder		7. Emissions Method Code: 2	
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 32°F. Tons/yr based on 3,750 hrs/yr gas firing; ISO conditions.			

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <10% opacity		4. Equivalent Allowable Emissions: 8.6 lb/hour 15.3 tons/year	
5. Method of Compliance (limit to 60 characters): Annual VE test; EPA Method 9			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Lb/hr based on 32°F; Tons/year at ISO and 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.			

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: SO₂	2. Total Percent Efficiency of Control:
3. Potential Emissions: 5.5 lb/hour 9.8 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Emission Factor: 1 grain S per 100 CF gas; Lb/hr at 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing; ISO conditions.	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: Pipeline Natural Gas	4. Equivalent Allowable Emissions: 5.5 lb/hour 9.8 tons/year
5. Method of Compliance (limit to 60 characters): Fuel Sampling	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Lb/hr at 32°F and 100% load; Tons/year at 3,750 hrs/yr ISO conditions. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: NO_x	2. Total Percent Efficiency of Control:
3. Potential Emissions: 111.2 lb/hour 196.5 tons/year	4. Synthetically Limited? <input checked="" type="checkbox"/> [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on gas firing at 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions.	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 15 ppmvd	4. Equivalent Allowable Emissions: 111.2 lb/hour 196.5 tons/year
5. Method of Compliance (limit to 60 characters): CEM - 30 Day Rolling Average	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Requested Allowable Emissions is at 15% O₂-100% load. Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: CO	2. Total Percent Efficiency of Control:
3. Potential Emissions: 113.0 lb/hour 200.6 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load and 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 25 ppmvd @ 15% O₂	4. Equivalent Allowable Emissions: 113.0 lb/hour 200.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10; high and low load	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: VOC	2. Total Percent Efficiency of Control:
3. Potential Emissions: 3.7 lb/hour 6.6 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load; 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 1.8 ppmvd	4. Equivalent Allowable Emissions: 3.7 lb/hour 6.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 25A; high and low load	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Max @ 32°F; 100% load; TPY @ 59°F, 3,750 hrs/yr. See Attachment PSD-PPP; Section 2.0; Appendix A.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: PM₁₀	2. Total Percent Efficiency of Control:
3. Potential Emissions: 8.6 lb/hour 15.3 tons/year	4. Synthetically Limited? [X]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: S/W, 1999; Golder	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): See Attachment PSD-PPP; Section 2.0; Appendix A.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Lb/hr based on 100% load; 32°F. Tons/yr based on 3,750 hrs/yr gas firing and ISO conditions	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 8.6 lb/hr	4. Equivalent Allowable Emissions: 8.6 lb/hour 15.3 tons/year
5. Method of Compliance (limit to 60 characters): Annual VE test; EPA Method 9	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Dry Filterable PM - excludes H₂SO₄. See Attachment PSD-PPP; Section 2.0; Appendix A.	

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissions Limitation 1 of 2

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: [] Rule [X] Other
3. Requested Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: Annual VE Test EPA Method 9	
5. Visible Emissions Comment (limit to 200 characters): Maximum for gas firing.	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)

Continuous Monitoring System: Continuous Monitor 1 of 2

1. Parameter Code: EM	2. Pollutant(s): NO_x
3. CMS Requirement:	[X] Rule [] Other
4. Monitor Information: Not yet determined Manufacturer: Model Number: Serial Number:	
5. Installation Date: 01 Mar 2002	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters): NO_x CEM proposed to meet requirements of 40 CFR Part 75.	

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissions Limitation 2 of 2

1. Visible Emissions Subtype: VE99	2. Basis for Allowable Opacity: [X] Rule [] Other
3. Requested Allowable Opacity: Normal Conditions: % Exceptional Conditions: 100 % Maximum Period of Excess Opacity Allowed: 6 min/hour	
4. Method of Compliance: None	
5. Visible Emissions Comment (limit to 200 characters): FDEP Rule 62-201.700(1), Allowed for 2 hours (120 minutes) per 24 hours for start up, shutdown and malfunction.	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)

Continuous Monitoring System: Continuous Monitor 2 of 2

1. Parameter Code: O₂	2. Pollutant(s): Oxygen
3. CMS Requirement:	[X] Rule [] Other
4. Monitor Information: Not yet determined Manufacturer: Model Number: Serial Number:	
5. Installation Date: 01 Mar 2002	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters): Dilution monitor required by 40 CFR Part 75; may be CO₂ in lieu of O₂ monitor.	

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**Supplemental Requirements**

1. Process Flow Diagram [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
2. Fuel Analysis or Specification [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
3. Detailed Description of Control Equipment [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
4. Description of Stack Sampling Facilities [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable [] Waiver Requested
5. Compliance Test Report [] Attached, Document ID: _____ [] Previously submitted, Date: _____ [X] Not Applicable
6. Procedures for Startup and Shutdown [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
7. Operation and Maintenance Plan [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
8. Supplemental Information for Construction Permit Application [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable
9. Other Information Required by Rule or Statute [X] Attached, Document ID: <u>PSD-PPP</u> [] Not Applicable
10. Supplemental Requirements Comment:

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation
☐ Attached, Document ID: _____ ☐ Not Applicable

12. Alternative Modes of Operation (Emissions Trading)
☐ Attached, Document ID: _____ ☐ Not Applicable

13. Identification of Additional Applicable Requirements
☐ Attached, Document ID: _____ ☐ Not Applicable

14. Compliance Assurance Monitoring Plan
☐ Attached, Document ID: _____ ☐ Not Applicable

15. Acid Rain Part Application (Hard-copy Required)

☐ Acid Rain Part - Phase II (Form No. 62-210.900(1)(a))
Attached, Document ID: _____

☐ Repowering Extension Plan (Form No. 62-210.900(1)(a)1.)
Attached, Document ID: _____

☐ New Unit Exemption (Form No. 62-210.900(1)(a)2.)
Attached, Document ID: _____

☐ Retired Unit Exemption (Form No. 62-210.900(1)(a)3.)
Attached, Document ID: _____

☐ Phase II NO_x Compliance Plan (Form No. 62-210.900(1)(a)4.)
Attached, Document ID: _____

☐ Phase NO_x Averaging Plan (Form No. 62-210.900(1)(a)5.)
Attached, Document ID: _____

☐ Not Applicable

ATTACHMENT PPP-EU1-D
APPLICABLE REQUIREMENTS LISTING

EMISSION UNIT ID: EU1

FDEP Rules:

Air Pollution Control-General Provisions:

62-204.800(7)(b)37. (State Only)	NSPS Subpart GG
62-204.800(7)(c) (State Only)	NSPS authority
62-204.800(7)(d) (State Only)	NSPS General Provisions
62-204.800(12) (State Only)	Acid Rain Program
62-204.800(13)(State Only)	Allowances
62-204.800(14) (State Only)	Acid Rain Program Monitoring
62-204.800(16) (State Only)	Excess Emissions (Potentially applicable over term of permit)

Stationary Sources-General:

62-210.650	Circumvention; EUs with control device
62-210.700(1)	Excess Emissions;
62-210.700(4)	Excess Emissions; poor maintenance
62-210.700(6)	Excess Emissions; notification

Acid Rain:

62-214.300	All Acid Rain Units (Applicability)
62-214.320(1)(a),(2)	All Acid Rain Units (Application Shield)
62-214.330(1)(a)1.	Compliance Options (if 214.430)
62-214.340	Exemptions (new units, retired units)
62-214.350(2);(3);(6)	All Acid Rain Units (Certification)
62-214.370	All Acid Rain Units (Revisions; correction; potentially applicable if a need arises)
62-214.430	All Acid Rain Units (Compliance Options-if required)

Stationary Sources-Emission Standards:

62-296.320(4)(b)(State Only)	CTs/Diesel Units
------------------------------	------------------

Stationary Sources-Emission Monitoring:

62-297.310(1)	All Units (Test Runs-Mass Emission)
62-297.310(2)(b)	All Units (Operating Rate; other than CTs; no CT);
62-297.310(3)	All Units (Calculation of Emission)
62-297.310(4)(a)	All Units (Applicable Test Procedures; Sampling time)
62-297.310(4)(b)	All Units (Sample Volume)
62-297.310(4)(c)	All Units (Required Flow Rate Range-PM/H2SO4/F)
62-297.310(4)(d)	All Units (Calibration)
62-297.310(4)(e)	All Units (EPA Method 5 only)
62-297.310(5)	All Units (Determination of Process Variables)
62-297.310(6)(a)	All Units (Permanent Test Facilities-general)
62-297.310(6)(c)	All Units (Sampling Ports)
62-297.310(6)(d)	All Units (Work Platforms)
62-297.310(6)(e)	All Units (Access)
62-297.310(6)(f)	All Units (Electrical Power)
62-297.310(6)(g)	All Units (Equipment Support)
62-297.310(7)(a)1.	Applies mainly to CTs/Diesels
62-297.310(7)(a)2	FFSG excession emissions
62-297.310(7)(a)3.	Permit Renewal Test Required

62.297-310(7)(a)4.a
62.297.310(7)(a)5.
62.297.310(7)(a)6.
62-297.310(7)(a)7.
62-297.310(7)(a)9.
62-297.310(7)(c)
62-297.310(8)

Annual Test
PM exemption if <400 hrs/yr
PM FFSG semi annual test required if >200 hrs/yr
PM quarterly monitoring if >100 hrs/yr
FDEP Notification - 15 days
Waiver of Compliance Tests (Fuel Samplings)
Test Reports

Federal Rules:

NPS Subpart GG:
40 CFR 60.332(a)(1)
40 CFR 60.332(a)(3)
40 CFR 60.333
40 CFR 60.334

NOx for Electric Utility CTs
NOx for Electric Utility CTs
SO2 limits
Monitoring of Operations (Custom Monitoring for Gas)
Test Methods

40 CFR 560.335

NPS General Requirements

40CFR 60.7(a)(1)
40 CFR 60.7(a)(2)
40 CFR 60.7(a)(3)
40 CFR 60.7(a)(4)

40 40 CFR 60.7(a)(5)
40 CFR 60.7(b)

40 CFR 60.7(c)

40 CFR 60.7(d)

40 CFR 60.7(f)

40 CFR 60.8(a)
40 CFR 60.8(b)
40 CFR 60.8(c)
40 CFR 60.8(e)
40 CFR 60.8(f)
40 CFR 60.11(a)

40 CFR 60.11(b)
40 CFR 60.11(c)

40 CFR 60.11(d)
40 CFR 60.11(e)(2)
40 CFR 60.12
40 CFR 60.13(a)
40 CFR 60.13(c)
40 CFR 60.13(d)(1)
40 CFR 60.13(d)(2)
40 CFR 60.13(e)
40 CFR 60.13(f)
40 CFR 60.13(h)

Notification of Construction
Notification of Initial Start-Up
Notification of Actual Start-Up
Notification and Recordkeeping (Physical/Operational Cycle)
Notification of CEM Demonstration
Notification and Recordkeeping (startup/shutdown/malfunction)
Notification and Recordkeeping (startup/shutdown/malfunction)
Notification and Recordkeeping (startup/shutdown/malfunction)
Notification and Recordkeeping (maintain records - 2 yrs)
Performance Test Requirements
Performance Test Notification
Performance Tests (representative conditions)
Provide Stack Sampling Facilities
Test Runs
Compliance (ref S. 60.8 or Subpart; other than opacity)
Compliance (opacity determined EPA Method 9)
Compliance (opacity; excludes startup/shutdown/malfunction)
Compliance (maintain air pollution control equip.)
Compliance (opacity; ref.S.60.8)
Circumvention
Monitoring (Appendix B; Appendix F)
Monitoring (Opacity COMS)
Monitoring (CEMSS; span, drift, etc.)
Monitoring (COMS; span, system check)
Monitoring (frequency of operation)
Monitoring (frequency of operation)
Monitoring (COMS; data requirements)

Acid Rain-Permits:
40 CFR 72.9(a)

Permit Requirements

40 CFR 72.9(b)
40 CFR 72.9(c)(1)
40 CFR 72.9(c)(2)
40 CFR 72.9(c)(3)(iii)
40 CFR 72.9(c)(4)
40 CFR 72.9(c)(5)
40 CFR 72.9(d)
40 CFR 72.9(e)
40 CFR 72.9(f)
40 CFR 72.9(g)
40 CFR 72.20(a)
40 CFR 72.20(b)
40 CFR 72.20(c)

40 CFR 72.21
40 CFR 72.22
40 CFR 72.23
40 CFR 72.24
40 CFR 72.30(a)
40 CFR 72.20(b)(2)
40 CFR 72.30(c)
40 CFR 72.30(d)
40 CFR 72.31
40 CFR 72.32
40 CFR 72.33(b)
40 CFR 72.33(c)
40 CFR 72.33(d)
40 CFR 72.40(a)
40 CFR 72.40(b)
40 CFR 72.40(c)
40 CFR 72.40(d)
40 CFR 72.51
40 CFR 72.90

Allowances:

40 CFR 73.33(a),(c)
40 CFR 73.35(c)(c)

Monitoring Part 75:

40 CFR 75.4
40 CFR 75.5
40 CFR 75.10(a)(1)
40 CFR 75.10(a)(2)
40 CFR 75.10(a)(3)(iii)
40 CFR 75.10(b)
40 CFR 75.10(c)
40 CFR 75.10(e)
40 CFR 75.10(f)
40 CFR 75.10(g)
40 CFR 75.11(d)
40 CFR 75.11(e)
40 CFR 75.12(a)
40 CFR 75.12(b)

40 CFR 75.13(b)
40 CFR 75.13(c)

Monitoring Requirements
SO2 Allowances-hold allowances
SO2 Allowances violation
SO2 Allowances-Phase II Units (listed)
SO2 Allowances-allowances held in ATS
SO2 Allowances-no deduction for 72.9(c)(1)(i)
NOx Requirements
Excess Emission Requirements;
Recordkeeping and Reporting
Liability
Designated Representative required
Designated Representative; legally binding
Designated Representative; certification
requirements
Submissions
Alternate Designated Representative
Changing representatives; owners
Certificate of representation
Requirements to Apply (operate)
Requirements to Apply (Phase II-Complete)
Requirements to Apply (reapply before expiration)
Requirements to Apply (submittal requirements)
Information Requirements; Acid Rain Applications
Permit Application Shield
Dispatch System ID; unit/system ID
Dispatch System ID; ID requirements
Dispatch System ID; ID change
General; compliance plan
General; multi-unit compliance options
General; conditional approval
General; termination of compliance options
Permit Shield
Annual Compliance Certification

Authorized account representative
Compliance: ID of allowances by serial number

Compliance Dates;
Prohibitions
Primary Measurement; SO2;
Primary Measurement; NOx;
Primary Measurement; CO2, O2 monitor
Primary Measurement: Performance Requirements
Primary Measurement; Heat Input; Appendix F
Primary Measurement; Optional Backup Monitor
Primary Measurement; Minimum Measurement
Primary Measurement; Minimum Recording
SO2 Monitoring; Gas- and Oil-fired units
SO2 Monitoring; Gaseous firing
NOx Monitoring; Coal; Non-peaking oil/gas units
NOx Monitoring; Determination of NOx emission
rate; Appendix F
CO2 Monitoring; Appendix G
CO2 Monitoring; Appendix F

40 CFR 75.14(c)	Opacity Monitoring; Gas units; exemption
40 CFR 75.20(a)	Initial Certification Approval Process; Loss of Certification
40 CFR 75.20(b)	Recertification Procedures (if recertification necessary)
40 CFR 75.20(c)	Certification Procedures (if recertification necessary)
40 CFR 75.20(d)	Recertification Backup/portable monitor
40 CFR 75.20(f)	Alternate Monitoring system
40 CFR 75.21(a)	QA/QC; CEMS; Appendix B (Suspended 7/17/95-12/31/96)
40 CFR 75.21(c)	QA/QC; Calibration Gases
40 CFR 75.21(d)	QA/QC; Notification of RATA
40 CFR 75.21(e)	QA/QC; Audits
40 CFR 75.21(f)	QA/QC CEMS (Effective 7/17/96-12/31/96)
40 CFR 75.22	Reference Methods
40 CFR 75.24	Out-of-Control Periods; CEMS
40 CFR 75.30(a)(3)	General Missing Data Procedures; NOx
40 CFR 75.30(a)(4)	General Missing Data Procedures; SO2
40 CFR 75.30(b)	General Missing Data Procedures; certified backup monitor
40 CFR 75.30(c)	General Missing Data Procedures; certified backup monitor
40 CFR 75.30(d)	General Missing Data Procedures; SO2 (optional before 1/1/97)
40 CFR 75.30(e)	General Missing Data Procedures; bypass/multiple stacks
40 CFR 75.31	Initial Missing Data Procedures (new/re-certified CMS)
40 CFR 75.32	Monitoring Data Availability for Missing Data
40 CFR 75.33	Standard Missing Data Procedures
40 CFR 75.36	Missing Data for Heat Input
40 CFR 75.40	Alternate Monitoring Systems-General
40 CFR 75.41	Alternate Monitoring Systems-Precision Criteria
40 CFR 75.42	Alternate Monitoring Systems-Reliability Criteria
40 CFR 75.43	Alternate Monitoring Systems-Accessibility Criteria
40 CFR 75.44	Alternate monitoring Systems-Timeliness Criteria
40 CFR 75.45	Alternate Monitoring Systems-Daily Qa
40 CFR 75.46	Alternate Monitoring Systems-Missing data
40 CFR 75.47	Alternate Monitoring Systems-Criteria for Class
40 CFR 75.48	Alternate Monitoring Systems-Petition
40 CFR 75.53	Monitoring Plan; revisions
40 CFR 75.54(a)	Recordkeeping-general
40 CFR 75.54(b)	Recordkeeping-operating parameter
40 CFR 75.54(c)	Recordkeeping-SO2
40 CFR 75.54(d)	Recordkeeping-NOx
40 CFR 75.54(e)	Recordkeeping-CO2
40 CFR 75.54(f)	Recordkeeping-Opacity
40 CFR 75.55(c)	General Recordkeeping (Specific Situations)
40 CFR 75.55(e)	General Recordkeeping (Specific Situations)
40 CFR 75.56	Certification; QA/QC Provisions
40 CFR 75.60	Reporting Requirements-General
40 CFR 75.61	Reporting Requirements-Notification cert/recertification
40 CFR 75.62	Reporting Requirements-Monitoring Plan
40 CFR 75.63	Reporting Requirements-Certification/Recertification
40 CFR 75.64(a)	Reporting Requirements-Quarterly reports; submission

40 CFR 75.64(b)	Reporting Requirements-Quarterly reports; DR statement
40 CFR 75.64(c)	Rep. Req.; Quarterly reports; Compliance Certification
40 CFR 75.64(d)	Rep.Req.; Quarterly reports; Electronic format
40 CFR 75.66	Petitions to the Administrator (if required)
Appendix A-1	Installation and Measurement Locations
Appendix A-2	Equipment Specifications
Appendix A-3	Performance Specifications
Appendix A-4	Data Handling and Acquisition Systems
Appendix A-5	Calibration Gases
Appendix A-6	Certification Tests and Procedures
Appendix A-7	Calculations
Appendix B	QA/QC Procedures
Appendix C-1	Missing Data; SO ₂ /NO _x for controlled sources
Appendix C-2	Missing Data; Load-Based Procedure; NO _x & flow
Appendix D	Optional SO ₂ ; Oil/gas-fired units
Appendix F	Conversion Procedures
Appendix H	Traceability Protocol
Acid Rain Program-Excess Emissions (these are future requirements):	
40 CFR 77.3	Offset Plans (future)
40 CFR 77.5(b)	Deductions of Allowances (future)
40 CFR 77.6	Excess Emissions Penalties (SO ₂ and NO _x future)

PSD ANALYSIS

1.0 INTRODUCTION AND EXECUTIVE SUMMARY

Palmetto Power L.L.C. proposes to construct and operate a simple cycle independent power production facility in Osceola County, Florida (Figure 1-1). The facility will be located on a 150-acre tract approximately 12 kilometers (km) west of Cocoa, Florida, and is referred to as the Palmetto Power L.L.C. Project ("the Project"). The facility will be capable of generating a nominal net electrical output of 540 megawatts (MW).

This application contains the technical information developed in accordance with Prevention of Significant Deterioration (PSD) regulations as promulgated by the U.S. Environmental Protection Agency (EPA) and implemented through delegation to the Florida Department of Environmental Protection (DEP). It presents an evaluation of regulated pollutants subject to PSD review, a demonstration of Best Available Control Technology (BACT), a demonstration that pollutant emission rates comply with New Source Performance Standards (NSPS) regulation, and an assessment of potential air quality impacts associated with the Project. Through this application, Palmetto Power L.L.C. requests that the Florida DEP issue an Air Construction Permit for the Project.

1.1 PROJECT APPROACH

The Project will consist of three 180-MW combustion turbines (CTs) that will operate in simple cycle mode. The total electric power capacity will be nominally 540 MW. The CTs will be Siemens-Westinghouse 501FD models or equivalent with dry low-nitrogen oxide (NO_x) burners fired by natural gas only. Operation of the CTs in simple cycle mode provides a fast response time to meet the high electrical demands during peak hours. Additionally, the proposed CTs provide electric energy at heat rates that are much lower and more efficient than previous turbine technology. Palmetto Power L.L.C. expects that the Project may be required to operate in simple cycle mode for up to 3,750 hours each year, responding to system peak demands and market opportunities. This corresponds to an approximate 43 percent annual capacity factor.

1.2 PREVENTION OF SIGNIFICANT DETERIORATION (PSD) REQUIREMENTS

The permitting of the Project in Florida requires an air construction permit and PSD review approval. The Project will be a new air emission source in Osceola County. The U.S. EPA has implemented regulations requiring a PSD review for new or modified sources that increase air emissions above certain threshold amounts. Because the threshold amounts will be exceeded by the proposed project, the project is subject to PSD review. The total predicted emissions in tons per year associated with this project are presented as Table 1-1. PSD regulations are promulgated under 40 Code of Federal Regulations (CFR) Part 52.21 and implemented through delegation to the Florida DEP. Florida's PSD regulations are codified in Rules 62-212.400, F.A.C. These regulations incorporate the EPA PSD regulations.

Based on the emissions from the proposed project, a PSD review is required for each of the following regulated pollutants:

- Particulate matter (PM) as total suspended particulate matter (TSP),
- Particulate matter with aerodynamic diameter of 10 microns or less (PM₁₀),
- Nitrogen dioxide (NO₂), and
- Carbon monoxide (CO)

Osceola County has been designated as an attainment or unclassifiable area for all criteria pollutants. The county is also classified as a PSD Class II area for PM₁₀, SO₂, and NO₂; therefore, the new source review will follow PSD regulations pertaining to such designations.

Table 1-1. Summary of Maximum "Annual" Pollutant Emissions for the Palmetto Power L.L.C. Project (see Section 2.0 for Details)^a

Pollutant	3 CTs in SC Mode (tons per year)	EPA Significant Emission Rate Threshold (tons per year)
SO ₂	29.9	40
PM	46.4	25
PM ₁₀	46.4	15
NO _x	601	40
CO	613	100
VOC	20.2	40
Sulfuric Acid Mist	4.6	7
Mercury	0.000008	0.1

^a Based on 3 CTs operating at 100 percent load for 3,750 hours per year.

Note: CT = combustion turbine
SC = simple cycle

Other regulated pollutants will be emitted in negligible amounts.

1.3 BEST AVAILABLE CONTROL TECHNOLOGY (BACT) ANALYSIS

A BACT analysis was conducted for each pollutant which was greater than the EPA significance threshold and, therefore, subject to BACT review. The proposed BACT to control NO_x emissions from the Project's three CTs operating in simple cycle mode is the use of dry low NO_x (DLN) combustors. The NO_x concentration will be 15 parts per million, volume dry (ppmvd), corrected to 15 percent oxygen (O₂). The proposed BACT for PM, PM-10, and CO are good combustion practices utilizing the DLN combustor and firing natural gas fuel.

1.4 AIR QUALITY ANALYSIS

An air quality impact analysis was conducted to determine if the proposed operation of the Project would cause or contribute to a violation of any National Ambient Air Quality Standard (NAAQS) or allowable PSD increment concentration. It was demonstrated that emissions from the Project would not result in ambient concentrations above the PSD Class

II significant impact levels. As a result, the Project will not cause or contribute to any adverse impacts on air quality.

Additional impacts of the Project, such as soils, vegetation, and growth impacts, were analyzed and found to be negligible (see analysis in Section 7.0).

1.5 SUMMARY OF RESULTS

Results from the analyses presented in this PSD Air Permit application lead to the following conclusions.

- The proposed BACT for each applicable pollutant provides the maximum degree of emissions reduction based on energy, environmental, and economic impacts and technical feasibility.
- National and State Ambient Air Quality Standards will not be exceeded as a result of the operation of the Project.
- Applicable PSD increments will not be exceeded as a result of the operation of the Project.
- Non-criteria pollutants emitted from the Project will not adversely affect the public.
- Visibility impacts from the Project's plume on Class II areas are insignificant.
- No effects on soils and vegetation are expected as a result of the operation of the Project.
- The operation of the Project is not expected to adversely affect population or economic growth in the area; thus, no additional secondary emissions or impacts are anticipated.

As substantiated in this application, the Project will be constructed and operated in compliance with all applicable state and federal rules, regulations and laws.

1.6 AIR PERMIT APPLICATION ORGANIZATION

The air permit application is divided into seven major sections.

- Section 2.0 presents a description of the facility, including air emissions and stack parameters.

- Section 3.0 provides a review of the PSD and nonattainment requirements applicable to the proposed project.
- Section 4.0 includes the control technology review with discussions on BACT.
- Section 5.0 discusses the ambient air monitoring analysis (pre-construction monitoring) required by PSD regulations.
- Section 6.0 presents a summary of the air modeling approach and results used in assessing compliance of the proposed project with ambient air quality standards (AAQS), PSD increments, and good engineering practice (GEP) stack height regulations.
- Section 7.0 provides the additional impact analyses for soils, vegetation, and visibility.




Figure 1-1. Location of Proposed Palmetto Power LLC Facility

Source: USGS, 1980.



2.0 PROJECT DESCRIPTION

2.1 SITE DESCRIPTION

The project site consists of 150 acres that are undeveloped and have been historically utilized as agriculture/ranchland. This site is zoned for agricultural use. The Project will apply for a Conditional Use Permit for power plant development through the Osceola County Board of County Commissioners. The plant elevation will be approximately 20 feet above sea level.

Natural gas will be supplied by a lateral pipeline connected to the Florida Gas Transmission (FGT) natural gas pipeline located about 7 miles north of the site. The site has access to transmission facilities from a 230 kV transmission line owned by Florida Power & Light Company and Florida Power Corporation that is located approximately one mile south of the site. Water for the evaporative cooler, potable uses, other service and fire protection supply will be supplied by East Central Florida Services.

2.2 POWER PLANT

The Project will consist of three "F" Class CTs operating in simple cycle mode. A CT is an internal combustion engine that operates with rotary motion to drive an electric generator to produce electricity. CTs are essentially composed of three major components: compressor, combustor, and power turbine. In the compressor section, ambient air is drawn in, compressed and directed to the combustor section where fuel is introduced, ignited, and burned. The rotary power is achieved by the expansion of the combustion gases through the power turbine. For this project, the combustion process is based on lean premix staged combustion. For lean premix combustors, fuel and air are thoroughly mixed in an initial stage resulting in a uniform, lean, unburned fuel/air mixture which is delivered to a secondary stage where the combustion reaction takes place. Manufacturers use different types of fuel/air staging, including fuel staging, air staging, or both; however, the same staged, lean premix principle is applied. CTs using staged combustion are also referred to as dry, low NO_x combustors.

Hot gases from the combustion section are diluted with additional air from the compressor section and directed to the power turbine section at very high temperatures. Energy from the hot exhaust gases, which expand in the power turbine section, is recovered in the form of shaft horsepower. More than 50 percent of the shaft horsepower is needed to drive the internal compressor and the balance of recovered shaft horsepower is available to drive an external load. The heat content of the exhaust gases exiting the turbine can be exhausted to the atmosphere without heat recovery (referred to as simple cycle mode) or recovered in a heat recovery steam generator (HRSG) to raise steam for a steam turbine (referred to as combined cycle mode). In combined cycle mode, the gas turbine drives an electric generator and the steam from the HRSG drives a steam turbine, which also drives an electric generator.

The Project will consist of three 180-MW CTs that will operate in simple cycle mode. The Project will also have administration, maintenance, and water treatment buildings; water storage tanks; emergency diesel generator; fuel gas heater; and various pumps, including an emergency firewater pump.

The total electric power capacity will be nominally 540 MW. The CTs will be Siemens-Westinghouse 501FD models or equivalent with dry low-nitrogen oxide (NO_x) burners fired by natural gas. The facility will not use backup fuel oil. Although the CTs operating in simple cycle mode have relatively high heat rates, this operating mode provides a faster response time to meet electrical demands in the market during peak hours. The Project may be required to operate in simple cycle mode for up to 3,750 hours each year. This corresponds to an approximate 43 percent annual capacity factor. This capacity factor is based on current market forecasts that indicate the Project would be competitive on a cost basis by operating in simple cycle mode.

A process flow diagram of the facility operating in simple cycle mode is presented in Figure 2-1.

The anticipated schedule for the Project is as follows:

- Obtain air permit and begin construction by third quarter, 2000; and
- Startup by the first quarter, 2002.

The Siemens-Westinghouse 501FD CTs are up to 10 percent more fuel-efficient than the previous generation of CT (501D5). Each CT will have an evaporative cooler at the turbine air inlet that reduces the inlet air temperature and increases the efficiency, mass flow and power output. These coolers add water vapor to the exhaust from the CTs but do not affect emissions of regulated pollutants.

The CTs typically will operate between 70 and 100 percent of load. The efficiency of the CTs decreases at part load. As a result, the economic incentive is to dispatch the plant as near to 100 percent load, whenever possible. The facility will be dispatched to meet peak electrical demand. The turbines may be operated individually or in any combination of one, two, or three.

Natural gas will be transported to the site via pipeline. No backup fuel will be used.

Air emissions control will consist of using state-of-the-art dry low-NO_x burners. The dry low-NO_x combustors for the Siemens-Westinghouse 501FD CT have premixed fuel zones plus a standard diffusion flame pilot burner for startup. Low NO_x levels are achieved by introducing fuel primarily to the pre-mix zones to create a very uniform temperature in the combustion zone. The proposed NO_x emission levels are 15 parts per million volume dry (ppmvd), corrected to 15 percent oxygen (O₂) for simple cycle operation.

The SO₂ emissions will be controlled by the use of natural gas, the cleanest-burning fossil fuel commercially available. Good combustion practices and the use of natural gas fuel will also minimize potential emissions of PM, PM₁₀, CO, VOC, and other pollutants (e.g., trace metals). The engineering and environmental design of the Project will maximize control of air emissions while minimizing economic, environmental, and energy impacts (see Section 4.0 for the BACT evaluation).

The project will have one 250-kW emergency diesel generator and 310-hp emergency fire water pump. These exempt units will use low sulfur content distillate oil. Each of these units will be operated for up to 1 hour per week for readiness testing and maintenance and up to 500 hours per year as required during emergencies.

The project will also have one fuel gas heater with a maximum heat input rate of 4.9 mmBtu/hr fired. This heater will be fired by natural gas only and will be operated for up to 800 hours per year.

2.3 PROPOSED SOURCE EMISSIONS AND STACK PARAMETERS

As discussed previously, the CTs will operate in simple cycle mode and will typically operate from 70 to 100 percent of full load. At CT operating loads below 100 percent, the mass emissions of all criteria pollutants decrease as load decreases to approximately 70 percent of full load. When the CTs are operated at less than about 70 percent load, the mass emissions (lb/hr) of certain pollutants (NO_x, VOC, and CO) may begin to increase above the mass emission levels in the operating loads between 70 to 100 percent. As a result, minimum load will be limited to 70 percent of full load except for startup, shutdown, and malfunction.

The estimated maximum hourly emissions and exhaust information representative of the advanced CT design operating at 100- and 70- percent load conditions for simple cycle mode are presented in Table 2-1. The information in these tables is presented for one CT unit operation based on natural gas combustion for air inlet ambient temperatures of 32, 59, and 95°F. These temperatures represent the range of ambient temperatures that the CTs are most likely to experience. The data in these tables were derived from the data provided on the vendor's data sheets found in Appendix A. The vendor data sheets also include operating scenarios with and without evaporative coolers in operation. The evaporative coolers will be used at full load operations when ambient temperatures are about 59°F or higher. When the evaporative coolers are operating, the CTs combust more natural gas and generate more mass emissions of pollutants than when the coolers are not operating. To provide a conservative estimate of maximum pollutant emissions, the maximum emissions

presented in this section assume that the evaporative coolers would operate for all available hours, where appropriate (i.e., full load operations at 59 and 95°F).

The maximum potential annual emissions for the Project for regulated air pollutants are presented in Table 2-2 for one and three CTs operating in simple cycle mode based on an ambient temperature of 59°F. The potential annual emissions are based on the 59°F ambient air condition since it represents the temperature referenced in the new source performance standards (NSPS) for stationary gas turbines (40 CFR Part 60, Subpart GG). It also represents a nominal average between the higher emission levels at the 32°F ambient condition (winter) and the 95°F ambient condition (summer). Although the annual average temperature for the project site is slightly higher than 59°F, higher annual emissions are estimated assuming an ambient temperature of 59°F.

2.4 SITE LAYOUT, STRUCTURES, AND STACK SAMPLING FACILITIES

Plot plans of the proposed facility are presented in Figures 2-2 and 2-3. The dimensions of the buildings and structures are presented in Section 6.0. Stack sampling facilities will be constructed in accordance to Florida's Rule 62-297.310(6) F.A.C. for stack sampling. Stack sampling performed at the facility as required by FDEP will follow the methods specified in 40 CFR Part 60 Appendix B and adopted by reference in Rule 62-204.800 F.A.C.

Table 2-1. Stack, Operating, and Emission Data for the Palmetto Power L.L.C. Project
with Dry Low-NO_x Combustors firing Natural Gas

Parameter	Operating and Emission Data ^a for Ambient Temperature		
	32 °F	59 °F	95 °F
<u>Stack Data (ft)</u>			
Height	50	50	50
Diameter	19	19	19
<u>100 Percent Load</u>			
Operating Data			
Temperature (°F)	1,085	1,096	1,123
Velocity (ft/sec)	147	144	136
Maximum Hourly Emissions per Unit ^b			
PM/PM10 lb/hr	8.6	8.2	7.5
SO ₂ lb/hr	5.5	5.3	4.9
NO _x lb/hr	111.2	106.8	98.4
CO lb/hr	113.0	109.0	100.0
VOC (as methane) lb/hr	3.7	3.6	3.3
Sulfuric Acid Mist lb/hr	0.85	0.81	0.75
Mercury lb/hr	1.48E-06	1.42E-06	1.31E-06
<u>70 Percent Load</u>			
Operating Data			
Temperature (°F)	1,026	1,041	1,064
Velocity (ft/sec)	117	114	110
Maximum Hourly Emissions per Unit ^b			
PM/PM10 lb/hr	7.1	6.9	6.4
SO ₂ lb/hr	4.1	3.9	3.6
NO _x lb/hr	83.0	78.8	72.9
CO lb/hr	85.0	80.0	74.0
VOC (as methane) lb/hr	2.8	2.6	2.5
Sulfuric Acid Mist lb/hr	0.63	0.60	0.55
Mercury lb/hr	1.10E-06	1.04E-06	9.67E-07

^a Refer to Appendix A for detailed information. Data at 100% load for 59 and 95°F are based on evaporative cooler on and operating at 85 percent efficiency. With evaporative cooler not operating, emissions (lb/hr) are slightly lower.

^b Other regulated pollutants are assumed to have negligible emissions. These pollutants include lead, reduced sulfur compounds, hydrogen sulfide, fluorides, beryllium, arsenic, asbestos, vinyl chloride, and radionuclides.

Basis for pollutant emission rates at 59 °F ambient temperature are:

SO₂ = 1.0 grain sulfur/ 100 cubic feet

PM/PM10 = dry filterables

NO_x = 15 ppmvd at 15% O₂

CO = 25 ppmvd at 15% O₂

VOC = 1.5 ppmvd at 15% O₂ (as methane)


Sulfuric acid mist = 10% SO₂ emissions

Mercury = 0.000748 lb/10¹² Btu

Table 2-2 Summary of Maximum Potential Annual Emissions for the Palmetto Power L.L.C. Project
Simple Cycle Operation

Pollutant	Annual Emissions (tons/year) ^a		
	Load:	100%	70%
	Hours:	3,750	3,750
<hr/>			
<u>One Combustion Turbine- Simple Cycle</u>			
PM/PM10		15.5	12.8
SO ₂		10.0	7.31
NO _x		200	148
CO		204	150
VOC (as methane)		6.7	5.0
Sulfuric Acid Mist		1.53	1.12
Mercury		2.67E-06	1.95E-06
<hr/>			
<u>Three Combustion Turbines- Simple Cycle</u>			
PM/PM10		46.4	38.5
SO ₂		29.9	21.9
NO _x		601	443
CO		613	450
VOC (as methane)		20.2	14.9
Sulfuric Acid Mist		4.6	3.36
Mercury		8.00E-06	5.86E-06

^a Based on 59 °F ambient inlet air temperature. At 100% load, evaporative cooler is on and operating at 85% efficiency. With evaporative cooler not operating, emissions (lb/hr) are slightly lower.



2-8

Figure 2-1. Simplified Flow Diagram of Proposed Combustion Turbine
Simple Cycle Operation, 100 Percent Load, Annual Design Conditions
Palmetto Power LLC Project




Figure 2-2. Site Location Plan of Proposed Palmetto Power LLC Facility

3.0 AIR QUALITY REVIEW REQUIREMENTS AND APPLICABILITY

Federal and state air regulatory requirements for a new source of air pollution are discussed in Sections 3.1 to 3.3. The applicability of these regulations to the proposed Palmetto Power L.L.C. Project is presented in Section 3.4. These regulations must be satisfied before the proposed project can begin construction.

3.1 NATIONAL AND STATE AAQS

The existing applicable National and Florida Ambient Air Quality Standard (AAQS) are presented in Table 3-1. Primary national AAQS were promulgated to protect the public health, and secondary national AAQS were promulgated to protect the public welfare from any known or anticipated adverse effects associated with the presence of pollutants in the ambient air. Areas of the country in violation of AAQS are designated as nonattainment areas, and new sources to be located in or near these areas may be subject to more stringent air permitting requirements.

3.2 PREVENTION OF SIGNIFICANT DETERIORATION (PSD) REQUIREMENTS

3.2.1 General Requirements

Under federal and State of Florida PSD review requirements, all major new or modified sources of air pollutants regulated under the Clean Air Act (CAA) must be reviewed and a pre-construction permit issued. EPA has approved Florida's State Implementation Plan (SIP), which contains PSD regulations; therefore, PSD approval authority has been granted to DEP.

A "major facility" is defined as any one of 28 named source categories that have the potential to emit 100 tons per year (TPY) or more or any other stationary facility that has the potential to emit 250 TPY or more of any pollutant regulated under CAA. "Potential to emit" means the capability, at maximum design capacity, to emit a pollutant after the application of control equipment. Once a new source is determined to be a "major facility" for a particular pollutant, any pollutant emitted in amounts greater than the PSD significant emission rates is subject to PSD review. The PSD significant emission rates are presented in Table 3-2.

EPA has promulgated as regulations certain increases above an air quality baseline concentration level of SO₂, PM₁₀, and NO₂ concentrations that would constitute significant deterioration. The EPA class designations and allowable PSD increments are presented in Table 3-1. The magnitude of the allowable increment depends on the classification of the area in which a new source (or modification) will be located or have an impact. Three classifications are designated based on criteria established in the Clean Air Act Amendments. Congress promulgated areas as Class I (international parks, national wilderness areas, and memorial parks larger than 5,000 acres and national parks larger than 6,000 acres) or as Class II (all areas not designated as Class I). No Class III areas, which would be allowed greater deterioration than Class II areas, were designated. The State of Florida has adopted the EPA class designations and allowable PSD increments for SO₂, PM₁₀, and NO₂ increments.

PSD review is used to determine whether significant air quality deterioration will result from the new or modified facility. Federal PSD requirements are contained in 40 CFR 52.21, Prevention of Significant Deterioration of Air Quality. The State of Florida has adopted PSD regulations that have been approved by EPA [Rule 62-212.400 F.A.C.]. Major facilities are required to undergo the following analysis related to PSD for each pollutant emitted in significant amounts:

1. Control technology review,
2. Source impact analysis,
3. Air quality analysis (monitoring),
4. Source information, and
5. Additional impact analyses.

In addition to these analyses, a new facility also must be reviewed with respect to Good Engineering Practice (GEP) stack height regulations. Discussions concerning each of these requirements are presented in the following sections.

3.2.2 Control Technology Review

The control technology review requirements of the federal and state PSD regulations require that all applicable federal and state emission-limiting standards be met, and that Best Available Control Technology (BACT) be applied to control emissions from the source. The

BACT requirements are applicable to all regulated pollutants for which the increase in emissions from the facility exceeds the significant emission rate (see Table 3-2).

BACT is defined in 40 CFR 52.21 (b)(12), as:

An emissions limitation (including a visible emission standard) based on the maximum degree of reduction of each pollutant subject to regulation under the Act which would be emitted by any proposed major stationary source or major modification which the Administrator, on a case-by-case basis, taking into account energy, environmental, and economic impacts, and other costs, determines is achievable through application of production processes and available methods, systems, and techniques (including fuel cleaning or treatment or innovative fuel combustion techniques) for control of such pollutant. In no event shall application of best available control technology result in emissions of any pollutant, which would exceed the emissions allowed by any applicable standard under 40 CFR Parts 60 and 61. If the Administrator determines that technological or economic limitations on the application of measurement methodology to a particular part of a source or facility would make the imposition of an emission standard infeasible, a design, equipment, work practice, operational standard or combination thereof, may be prescribed instead to satisfy the requirement for the application of BACT. Such standard shall, to the degree possible, set forth the emissions reductions achievable by implementation of such design, equipment, work practice, or operation and shall provide for compliance by means, which achieve equivalent results.

BACT was promulgated within the framework of the PSD requirements in the 1977 amendments of the CAA [Public Law 95-95; Part C, Section 165(a)(4)]. The primary purpose of BACT is to optimize consumption of PSD air quality increments and thereby enlarge the potential for future economic growth without significantly degrading air quality (EPA, 1978; 1980). Guidelines for the evaluation of BACT can be found in EPA's *Guidelines for Determining Best Available Control Technology (BACT)* (EPA, 1978) and in the *PSD Workshop Manual* (EPA, 1980). These guidelines were promulgated by EPA to provide a consistent approach to BACT and to ensure that the impacts of alternative emission control systems are measured by the same set of parameters. In addition, through implementation of these guidelines, BACT in one area may not be identical to BACT in another area. According to EPA (1980), "BACT analyses for the same types of emissions unit and the same pollutants in different locations or situations may determine that different control strategies should be

applied to the different sites, depending on site-specific factors. Therefore, BACT analyses must be conducted on a case-by-case basis."

The BACT requirements are intended to ensure that the control systems incorporated in the design of a proposed facility reflect the latest in control technologies used in a particular industry and take into consideration existing and future air quality in the vicinity of the proposed facility. BACT must, as a minimum, demonstrate compliance with new source performance standards (NSPS) for a source (if applicable). An evaluation of the air pollution control techniques and systems, including a cost-benefit analysis of alternative control technologies capable of achieving a higher degree of emission reduction than the proposed control technology, is required. The cost-benefit analysis requires the documentation of the materials, energy, and economic penalties associated with the proposed and alternative control systems, as well as the environmental benefits derived from these systems. A decision on BACT is to be based on sound judgment, balancing environmental benefits with energy, economic, and other impacts (EPA, 1978).

Historically, a "bottom-up" approach consistent with the BACT Guidelines and PSD Workshop Manual has been used. With this approach, an initial control level, which is usually NSPS, is evaluated against successively more stringent controls until a BACT level is selected. However, EPA developed a concern that the bottom-up approach was not providing the level of BACT decisions originally intended. As a result, in December 1987, the EPA Assistant Administrator for Air and Radiation mandated changes in the implementation of the PSD program, including the adoption of a new "top-down" approach to BACT decision making.

The top-down BACT approach essentially starts with the most stringent (or top) technology and emissions limit that have been applied elsewhere to the same or a similar source category. The applicant must next provide a basis for rejecting this technology in favor of the next most stringent technology or propose to use it. Rejection of control alternatives may be based on technical or economic infeasibility. Such decisions are made on the basis of physical differences (e.g., fuel type), locational differences (e.g., availability of water), or

significant differences that may exist in the environmental, economic, or energy impacts. The differences between the proposed facility and the facility on which the control technique was applied previously must be justified. EPA has issued a draft guidance document on the top-down approach entitled *Top-Down Best Available Control Technology Guidance Document* (EPA, 1990).

3.2.3 Source Impact Analysis

A source impact analysis must be performed for a proposed major source subject to PSD review for each pollutant for which the increase in emissions exceeds the significant emission rate (Table 3-2). The PSD regulations specifically provide for the use of atmospheric dispersion models in performing impact analyses, estimating baseline and future air quality levels, and determining compliance with AAQS and allowable PSD increments. Designated EPA models normally must be used in performing the impact analysis. Specific applications for other than EPA-approved models require EPA's consultation and prior approval. Guidance for the use and application of dispersion models is presented in the EPA publication *Guideline on Air Quality Models* (Revised).

The source impact analysis for criteria pollutants to address compliance with AAQS and PSD Class II increments may be limited to the new source if the net increase in impacts as a result of the new source is above significant impact levels, as presented in Table 3-1. To address compliance with AAQS and PSD Class II increments, a source impact analysis must be performed for the criteria pollutants. This analysis may be limited to the new source alone if the new source's impacts are less than the EPA significant impact levels presented in Table 3-1. The significant impact levels are threshold levels that are used to determine the level of air impact analyses needed for the project. If the new source's impacts are predicted to be less than significant, then the source's impacts are assumed not to have a significant adverse affect on air quality and additional modeling with other sources is not required. However, if the source's impacts are predicted to be greater than the significant impact levels, additional modeling with other sources is required to demonstrate compliance ambient standards.

The EPA has proposed significant impact levels for Class I areas as follows:

- SO₂ 3-hour - 1 $\mu\text{g}/\text{m}^3$
 24-hour - 0.2 $\mu\text{g}/\text{m}^3$
 Annual - 0.1 $\mu\text{g}/\text{m}^3$
- PM₁₀ 24-hour - 0.3 $\mu\text{g}/\text{m}^3$
 Annual - 0.2 $\mu\text{g}/\text{m}^3$
- NO₂ Annual - 0.1 $\mu\text{g}/\text{m}^3$

Although these levels have not been officially promulgated as part of the PSD review process and may not be binding for states in performing PSD review, the proposed levels serve as a guideline in assessing a source's impact in a Class I area. The EPA action to incorporate Class I significant impact levels in the PSD process is part of implementing NSR provisions of the 1990 CAA Amendments. Because the process of developing the regulations will be lengthy, EPA believes that the proposed rules concerning the significant impact levels is appropriate in order to assist states in implementing the PSD permit process.

Various lengths of record for meteorological data can be used for impact analysis. A 5-year period is normally used with corresponding evaluation of highest, second-highest short-term concentrations for comparison to AAQS or PSD increments. The meteorological data are selected based on an evaluation of measured weather data from a nearby weather station that represents weather conditions at the project site. The criteria used in this evaluation include determining the distance of the project site to the weather station; comparing topographical and land use features between the locations; and determining availability of necessary weather parameters. The selection of the weather data is normally discussed with and approved by the regulatory agency reviewing the air permit application prior to initiating air modeling.

The term "highest, second-highest" (HSH) refers to the highest of the second-highest concentrations at all receptors (i.e., the highest concentration at each receptor is discarded). The second-highest concentration is important because short-term AAQS specify that the

standard should not be exceeded at any location more than once a year. If fewer than 5 years of meteorological data are used in the modeling analysis, the highest concentration at each receptor normally must be used for comparison to air quality standards.

The term "baseline concentration" evolves from federal and state PSD regulations and refers to a concentration level corresponding to a specified baseline date and certain additional baseline sources. By definition, in the PSD regulations as amended August 7, 1980, baseline concentration means the ambient concentration level that exists in the baseline area at the time of the applicable baseline date. A baseline concentration is determined for each pollutant for which a baseline date is established and includes:

1. The actual emissions representative of facilities in existence on the applicable baseline date; and
2. The allowable emissions of major stationary facilities that commenced construction before January 6, 1975, for SO₂ and PM (TSP) concentrations, or February 8, 1988, for NO₂ concentrations, but that were not in operation by the applicable baseline date.

The following emissions are not included in the baseline concentration and therefore affect PSD increment consumption:

1. Actual emissions from any major stationary facility on which construction commenced after January 6, 1975, for SO₂ and PM(TSP) concentrations, and after February 8, 1988, for NO₂ concentrations; and
2. Actual emission increases and decreases at any stationary facility occurring after the baseline date.

In reference to the baseline concentration, the term "baseline date" actually includes three different dates:

1. The major facility baseline date, which is January 6, 1975, in the cases of SO₂ and PM (TSP), and February 8, 1988, in the case of NO₂.

2. The minor facility baseline date, which is the earliest date after the trigger date on which a major stationary facility or major modification subject to PSD regulations submits a complete PSD application.
3. The trigger date, which is August 7, 1977, for SO₂ and PM (TSP), and February 8, 1988, for NO₂.

The minor source baseline date for SO₂ and PM (TSP) has been set as December 27, 1977, for the entire State of Florida (Rule 62-204.360(1) and (2), F.A.C.). The minor source baseline for NO₂ has been set as March 28, 1988 (Rule 62-204.360(3), F.A.C.). It should be noted that references to PM (TSP) are also applicable to PM₁₀.

3.2.4 Air Quality Monitoring Requirements

In accordance with requirements of 40 CFR 52.21(m), any application for a PSD permit must contain an analysis of continuous ambient air quality data in the area affected by the proposed major stationary facility or major modification. For a new major facility, the affected pollutants are those that the facility potentially would emit in significant amounts. For a major modification, the pollutants are those for which the net emissions increase exceeds the significant emission rate (see Table 3-2).

Ambient air monitoring for a period of up to 1 year generally is appropriate to satisfy the PSD monitoring requirements. A minimum of 4 months of data is required. Existing data from the vicinity of the proposed source may be used if the data meet certain quality assurance requirements; otherwise, additional data may need to be gathered. Guidance in designing a PSD monitoring network is provided in EPA's *Ambient Monitoring Guidelines for Prevention of Significant Deterioration* (EPA, 1987a).

The regulations include an exemption that excludes or limits the pollutants for which an air quality analysis must be conducted. This exemption states that the Florida DEP may exempt a proposed major stationary facility or major modification from the monitoring requirements with respect to a particular pollutant if the emissions increase of the pollutant

from the facility or modification would cause, in any area, air quality impacts less than the *de minimis* levels presented in Table 3-2 (adopted by Florida in Rule 62-212.400-3, F.A.C.).

3.2.5 Source Information/Good Engineering Practice Stack Height

Source information must be provided to adequately describe the proposed project. The general type of information required for this project is presented in Section 2.0.

The 1977 CAA Amendments require that the degree of emission limitation required for control of any pollutant not be affected by a stack height that exceeds GEP or any other dispersion technique. On July 8, 1985, EPA promulgated final stack height regulations (EPA, 1985a). The Florida DEP (Rule 62-210.550, F.A.C.) has adopted identical regulations. GEP stack height is defined as the highest of:

1. 65 meters (m); or
2. A height established by applying the formula:

$$H_g = H + 1.5L$$

where: H_g = GEP stack height,

H = Height of the structure or nearby structure, and

L = Lesser dimension (height or projected width) of nearby structure(s); or

3. A height demonstrated by a fluid model or field study.

"Nearby" is defined as a distance up to five times the lesser of the height or width dimensions of a structure or terrain feature, but not greater than 0.8 km. Although GEP stack height regulations require that the stack height used in modeling for determining compliance with AAQS and PSD increments not exceed the GEP stack height, the actual stack height may be greater.

The stack height regulations also allow increased GEP stack height beyond that resulting from the above formula in cases where plume impaction occurs. Plume impaction is defined as concentrations measured or predicted to occur when the plume interacts with

elevated terrain. Elevated terrain is defined as terrain that exceeds the height calculated by the GEP stack height formula.

3.2.6 Additional Impact Analysis

In addition to air quality impact analyses, federal and State of Florida PSD regulations require analyses of the impairment to visibility and the impacts on soils and vegetation that would occur as a result of the proposed source [40 CFR 52.21(o); Florida Rule 62-212.400(5)(e), F.A.C.]. These analyses are to be conducted primarily for PSD Class I areas. Impacts as a result of general commercial, residential, industrial, and other growth associated with the source also must be addressed. These analyses are required for each pollutant emitted in significant amounts (Table 3-2).

3.3 EMISSION STANDARDS

3.3.1 New Source Performance Standards

The NSPS are a set of national emission standards that apply to specific categories of new sources. As stated in the CAA Amendments of 1977, these standards "shall reflect the degree of emission limitation and the percentage reduction achievable through application of the best technological system of continuous emission reduction the Administrator determines has been adequately demonstrated."

The proposed project will be subject to one or more NSPS.

Combustion Turbine

The CT is subject to emission limitations covered under Subpart GG, which limits NO_x and SO₂ emissions from all stationary CTs with a heat input at peak load equal to 10.7 gigajoules per hour (10 mmBtu/hr), based on the lower heating value of the fuel fired.

NO_x emissions are limited to 75 ppmvd corrected to 15 percent oxygen and heat rate while sulfur dioxide emissions are limited to using a fuel with a sulfur content of 0.8 percent. In addition to emission limitations, these are requirements for notification, record keeping, reporting, performance testing and monitoring. These are summarized below:

40 CFR 60.7 Notification and Record Keeping

- (a)(1) Notification of the date of construction - within 30 days after such date.
- (a)(2) Notification of the date of initial start-up - no more than 60 days or less than 30 days prior to date.
- (a)(3) Notification of actual date of initial start-up - within 15 days after such date.
- (a)(5) Notification of date which demonstrates CEM - not less than 30 days prior to date.

60.7 (b) Maintain records of the start-up, shutdown, and malfunction quarterly.

- (c) Excess emissions reports - by the 30th day following end of quarter.
(required even if no excess emissions occur)
- (d) Maintain file of all measurements for two years.

60.8 Performance Tests

- (a) Must be performed within 60 days after achieving maximum production rate but no later than 180 days after initial start-up.
- (d) Notification of Performance tests at least 30 days prior to them occurring.

40 CFR Subpart GG**60.334 Monitoring of Operations**

- (b) Monitor sulfur and nitrogen content of fuel.
Gas - (2): daily monitoring required

3.3.2 Florida Rules

The Florida DEP regulations for new stationary sources are covered in the F.A.C. The Florida DEP has adopted the EPA NSPS by reference in Rule 62-204.800(7); subsection (b)39 for stationary gas turbines. Therefore, the project is required to meet the same emissions, performance testings, monitoring, reporting, and record keeping as those described in Section 3.4.1. DEP has authority for implementing NSPS requirements in Florida.

3.3.3 Florida Air Permitting Requirements

The Florida DEP regulations require any new source to obtain an air permit prior to construction. Major new sources must meet the appropriate PSD and nonattainment requirements as discussed previously. Required permits and approvals for air pollution sources include NSR for nonattainment areas, PSD, NSPS, National Emission Standards for Hazardous Air Pollutants (NESHAP), Permit to Construct, and Permit to Operate. The requirements for construction permits and approvals are contained in Rules 62-4.030, 62-4.050, 62-4.052, 62-4.210, and 62-210.300(1), F.A.C. Specific emission standards are set forth in Chapter 62-296, F.A.C.

3.4 PSD APPLICABILITY TO OSCEOLA COUNTY

3.4.1 Area Classification

The project site is located in Osceola County, which has been designated by EPA and Florida DEP as an attainment area for all criteria pollutants. Osceola County and surrounding counties are designated as PSD Class II areas for SO₂, PM (TSP), and NO₂. The nearest Class I areas to the site are the Chassahowitzka National Wilderness Area (NWA) and the Everglades National Park which are located about 170 and >250 km, respectively, from the site. Other PSD Class I areas are located more than 250 km from the site.

3.4.2 PSD Review

Pollutant Applicability

The proposed project is considered to be a "major facility" because the annual emissions of several regulated pollutants from the three simple cycle CTs are estimated to exceed 250 TPY; therefore, PSD review is required for any pollutant for which the emissions are considered major or exceed the PSD significant emission rates. The proposed project is not one of the named major sources and, therefore, the major source threshold is 250 TPY. As shown in Table 3-3, potential emissions from the proposed project will be major for NO_x and CO, and greater than the significant emission rate levels for PM and PM₁₀. Because the proposed project impacts for these pollutants are predicted to be below the significant impact levels, a modeling analysis incorporating the impacts from other sources is not required.

The nearest Class I area, the Chassahowitzka NWA, to the plant site is greater than 150 km from the site. Based on the discussions with the Florida DEP, a PSD Class I increment-consumption analysis was not required because of the large distance between the facility and the Class I areas.

Emission Standards

The applicable NSPS for the CTs is 40 CFR Part 60, Subpart GG. The proposed emissions for the turbines will be well below the specified limits (see Section 4.0).

Ambient Monitoring

Based on the estimated pollutant emissions from the proposed plant (see Table 3-3), a pre-construction ambient monitoring analysis is required for PM₁₀, NO₂, and CO and monitoring data would be required to be submitted as part of the application. However, if the net increase in impact of these pollutants is less than the applicable *de minimis* monitoring concentration, then an exemption from submittal of pre-construction ambient monitoring data may be obtained [40 CFR 52.21(i)(8)]. In addition, if EPA has not established an acceptable ambient monitoring method for the pollutant, monitoring is not required.

Pre-construction monitoring data are not required to be submitted for this project because, as shown in Table 3-4, the proposed plant's impacts are predicted to be below the applicable *de minimis* monitoring concentration (see Table 3-2) levels for all pollutants.

GEP Stack Height Impact Analysis

The GEP stack height regulations allow any stack to be at least 65 m [213 feet (ft)] high. The proposed CT stacks will be 50 ft. These stack heights do not exceed the applicable GEP stack heights. However, as discussed in Section 6.0, Air Quality Modeling Approach, since the stack heights are less than GEP, building downwash effects must be considered in the modeling analysis. As a result, the potential for downwash of the CTs' emissions caused by nearby structures is included in the modeling analysis.

Emergency Diesel Generator and Emergency Diesel Fire Water Pump

The diesel generator and fire water pump are defined as "emergency" generators or units in Florida Rules, Chapter 62-210.200. Each of these units will be operated for up to 1 hour per week for readiness testing and maintenance and up to 500 hours per year as required during emergencies when the primary power source for that facility has been rendered inoperable by an emergency situation. They are exempt from permitting in Florida Rules, Chapter 62-210.300(3)(a) since they are not subject to the Federal Acid Rain Program and total fuel consumption will be limited to 32,000 gallons per year of diesel fuel.

Fuel Gas Heater

This heater will operate during the startup conditions for the CTs at up to 800 hours per year. The fuel gas heater is exempt from permitting in Florida Rules, Chapter 62-210.300(3)(a) since it is not subject to the Federal Acid Rain Program and total fuel consumption will be limited to 4.4 million standard cubic feet per year of natural gas.

3.4.3 NONATTAINMENT REVIEW

The project site is located in Osceola County, which is classified as an attainment area for all criteria pollutants. Therefore, nonattainment requirements are not applicable.

3.4.4 OTHER CLEAN AIR ACT REQUIREMENTS

The 1990 CAA Amendments established a program to reduce potential precursors of acidic deposition. The Acid Rain Program was delineated in Title IV of the CAA Amendments and required EPA to develop the program. EPA's final regulations were promulgated on January 11, 1993, and included permit provisions (40 CFR Part 72), allowance system (Part 73), continuous emission monitoring (Part 75), excess emission procedures (Part 77), and appeal procedures (Part 78).

EPA's Acid Rain Program applies to all existing and new utility units except those serving a generator less than 25 MW, existing simple cycle CTs, and certain non-utility facilities; units which fall under the program are referred to as affected units. The EPA regulations are applicable to the proposed project for the purposes for obtaining a permit and allowances,

as well as emission monitoring. New units are required to obtain permits under the program by submitting a complete application 24 months before the later of January 1, 2000, or the date on which the unit begins serving an electric generator (greater than 25 MW). An Acid Rain Permit application will be submitted.

The Acid Rain (Title IV) permit will provide SO₂ and NO_x emission limitations and the requirement to hold SO₂ emission allowances. Emission limitations established in the Acid Rain Program are presumed to be less stringent than BACT for new units. An allowance is a market-based financial instrument that is equivalent to 1 ton of SO₂ emissions. Allowances can be sold, purchased, or traded. For the proposed project, SO₂ allowances will be obtained from the market. There is currently no NO_x allowance trading program in place (but there may be in the future).

Continuous emission monitoring (CEM) for SO₂ and NO_x is required for gas-fired and oil-fired affected units. SO₂ emissions for natural gas may be determined using procedures established in Appendix D, 40 CFR Part. CO₂ emissions must also be determined either through a CEM (e.g., as a diluent for NO_x monitoring) or calculation. Alternate procedures, test methods, and quality assurance/quality control (QA/QC) procedures for CEM are specified (Part 75 Appendices A through I). The CEM requirements including QA/QC procedures are, in general, more stringent than those specified in the NSPS for Subpart GG. New units are required to meet the requirements by the later of January 1, 1995, or not later than 90 days after the unit commences commercial operation. Peaking units, which are affected units with an average capacity of no more than 10 percent during 3 consecutive calendar years with no one year having a capacity factor of no more than 20 percent, can utilize an optional NO_x emission estimating procedure [i.e., predictive emission monitoring (PEM)]. The Palmetto project will be required to either install CEMs for NO_x or PEMs to meet the Part 75 requirements.

The 1990 CAAA also established a federally mandated air operating permitting program. The program requires the states to adopt regulations consistent with the CAA and the implementing regulations promulgated by EPA in 40 CFR 70. The program applies to

"Title V or Part 70" sources that include major stationary sources of air pollutants. The State of Florida has adopted the requirements of 40 CFR 70 in Florida Rules, Chapter 62-213 which specify that all applicable sources, such as those proposed for this project, have a Title V permit to operate. The Palmetto project must file an application for a Title V permit 90 days before expiration of the air construction/PSD permit, but no later than 180 days after commencing operation.

The US Environmental Protection Agency has, and is currently developing, emissions standards for hazardous air pollutants (HAPs) for various industrial categories. These new National Emission Standards for Hazardous Air Pollutants (NESHAPs) that result from the 1990 CAAA are referred to as Maximum Achievable Control Technology (MACT) standards. The adopted standards regulations are promulgated under 40 CFR Part 63. New sources that emit more than 10 tons/year of a single HAP or 25 tons/year of total HAPs are required to apply MACT for the promulgated industrial category or to obtain a case-by-case MACT from the regulatory authority after submitting a MACT analysis. For the Palmetto Project, emissions of HAPs will be less than 10 tons/year of a single HAP and 25 tons/year of all HAPs. There are no current or planned MACT standards for simple cycle power plants.

Table 3-1. National and State AAQS, Allowable PSD Increments, and Significant Impact Levels

Pollutant	Averaging Time	AAQS ($\mu\text{g}/\text{m}^3$)			PSD Increments ($\mu\text{g}/\text{m}^3$)		Significant Impact Levels ($\mu\text{g}/\text{m}^3$) ^b
		National Primary Standard ^a	National Secondary Standard ^a	Florida ^a	Class I ^a	Class II ^a	
Sulfur Dioxide	Annual Arithmetic Mean	365	NA	60	2	20	1
	24-Hour Maximum	80	NA	260	5	91	5
	3-Hour Maximum	NA	1,300	1,300	25	512	25
Particulate Matter ^c (PM ₁₀)	Annual Arithmetic Mean	50	50	50	4	17	1
	24-Hour Maximum	150	150	150	8	30	5
Nitrogen Dioxide	Annual Arithmetic Mean	100	100	100	2.5	25	1
Carbon Monoxide	8-Hour Maximum	10,000	10,000	10,000	NA	NA	500
	1-Hour Maximum	40,000	40,000	40,000	NA	NA	2,000
Ozone ^c	8-Hour Maximum ^d	157	157	157	NA	NA	NA
Lead	Calendar Quarter Arithmetic Mean	1.5	1.5	1.5	NA	NA	NA

Note: Particulate matter (PM₁₀) = particulate matter with aerodynamic diameter less than or equal to 10 micrometers.

NA = Not applicable, i.e., no standard exists.

^a Short-term maximum concentrations are not to be exceeded more than once per year, except for PM₁₀ AAQS which is based on 6th highest over five years.

^b Maximum concentrations are not to be exceeded.

^c On July 18, 1997, EPA promulgated revised AAQS for particulate matter and ozone. For particulate matter, PM_{2.5} standards were introduced with a 24-hour standard of 65 $\mu\text{g}/\text{m}^3$ (3-year average of 98th percentile) and an annual standard of 15 $\mu\text{g}/\text{m}^3$ (3-year average at community monitors). These standards have been stayed by a court case against EPA and implementation of these standards are many years away pending EPA appeal.

^d 0.08 ppm; achieved when 3-year average of 99th percentile is 0.08 ppm or less. These have been stayed by a court case against EPA. The 1-hour standard of 0.12 ppm is still applicable. FDEP has not yet adopted the revised standards.

Sources: Federal Register, Vol. 43, No. 118, June 19, 1978.
40 CFR 50; 40 CFR 52.21. Florida Chapter 62-204, F.A.C.

Table 3-2. PSD Significant Emission Rates and *De Minimis* Monitoring Concentrations

Pollutant	Regulated Under	Significant Emission Rate (TPY)	<i>De Minimis</i> Monitoring Concentration ^a ($\mu\text{g}/\text{m}^3$)
Sulfur Dioxide	NAAQS, NSPS	40	13, 24-hour
Particulate Matter [PM(TSP)]	NSPS	25	10, 24-hour
Particulate Matter (PM ₁₀)	NAAQS	15	10, 24-hour
Nitrogen Dioxide	NAAQS, NSPS	40	14, annual
Carbon Monoxide	NAAQS, NSPS	100	575, 8-hour
Volatile Organic Compounds (Ozone)	NAAQS, NSPS	40	100 TPY ^b
Lead	NAAQS	0.6	0.1, 3-month
Sulfuric Acid Mist	NSPS	7	NM
Total Fluorides	NSPS	3	0.25, 24-hour
Total Reduced Sulfur	NSPS	10	10, 1-hour
Reduced Sulfur Compounds	NSPS	10	10, 1-hour
Hydrogen Sulfide	NSPS	10	0.2, 1-hour
Mercury	NESHAP	0.1	0.25, 24-hour
MWC Organics	NSPS	3.5×10^{-6}	NM
MWC Metals	NSPS	15	NM
MWC Acid Gases	NSPS	40	NM
MSW Landfill Gases	NSPS	50	NM

Note: Ambient monitoring requirements for any pollutant may be exempted if the impact of the increase in emissions is below *de minimis* monitoring concentrations.

NAAQS = National Ambient Air Quality Standards.

NM = No ambient measurement method established; therefore, no *de minimis* concentration has been established.

NSPS = New Source Performance Standards.

NESHAP = National Emission Standards for Hazardous Air Pollutants.

g/m^3 = micrograms per cubic meter.

MWC = Municipal waste combustor

MSW = Municipal solid waste

^a Short-term concentrations are not to be exceeded.

^b No *de minimis* concentration; an increase in VOC emissions of 100 TPY or more will require monitoring analysis for ozone.

^c Any emission rate of these pollutants.

Sources: 40 CFR 52.21.

Florida Rule 62-212.400

Table 3-3. Net Increase in Emissions Due to the Proposed Palmetto Power L.L.C. Facility Compared to the PSD Significant Emission Rates

Pollutant	Emissions (TPY)		
	Potential Emissions from Proposed Project ^a	Significant Emission Rate	PSD Review Required?
Sulfur Dioxide	29.9	40	No
Particulate Matter [PM(TSP)]	46.4	25	Yes
Particulate Matter (PM ₁₀)	46.4	15	Yes
Nitrogen Dioxide	601	40	Yes
Carbon Monoxide	613	100	Yes
Volatile Organic Compounds	20.2	40	No
Lead	NEG	0.6	No
Sulfuric Acid Mist	4.6	7	No
Total Fluorides	NEG	3	No
Total Reduced Sulfur	NEG	10	No
Reduced Sulfur Compounds	NEG	10	No
Hydrogen Sulfide	NEG	10	No
Mercury	0.000008	0.1	No

Note: NEG = Negligible.

- ^a Emissions are based on three CTs operating in simple cycle mode at 100% load conditions for 3,750 hours at 59°F firing natural gas only (refer to Table 2-2). NO_x emission levels are 15 parts per million, volume dry (ppmvd), corrected to 15 percent oxygen (O₂).

Table 3-4. Predicted Net Increase in Impacts Due To the Proposed Palmetto Power L.L.C. Facility Compared to PSD *De Minimis* Monitoring Concentrations

Pollutant	Concentration ($\mu\text{g}/\text{m}^3$)		PSD Monitoring Required?
	Predicted Net Increase in Impacts ^a	<i>De Minimis</i> Monitoring Concentration	
Particulate Matter [PM (TSP)]	0.076	10, 24-hour	No
Particulate Matter (PM ₁₀)	0.076	10, 24-hour	No
Nitrogen Dioxide	0.061	14, annual	No
Carbon Monoxide	2.1	575, 8-hour	No

^a See Section 6.0 for air dispersion modeling results. Predicted impacts for other pollutants are not required because PSD review is not required for those pollutants.

4.0 CONTROL TECHNOLOGY REVIEW

4.1 APPLICABILITY

The PSD regulations require new major stationary sources to undergo a control technology review for each pollutant that may potentially be emitted above significant emission rates. The maximum potential "worst-case" annual emissions of these pollutants from the proposed project are summarized below (see Table 2-3):

Total Facility Annual Emissions (TPY) ^a		PSD Review
Pollutant	Westinghouse 501F or Equivalent	Required?
SO ₂	29.9	No
PM/PM ₁₀	46.4	Yes
NO _x	601	Yes
CO	613	Yes
VOC	20.2	No
Sulfuric Acid Mist	4.6	No
Mercury	0.000008	No

^a Based on 3 CTs operating at 100 percent load for 3,750 hours per year.

The control technology review requirements of the PSD regulations are applicable to emissions of NO_x, CO, and PM/PM₁₀ (see Section 3.0). Maximum emissions are based on three CTs in simple cycle configuration each operating for 3,750 hours at 59°F using natural gas fuel. A turbine inlet air temperature of 59°F represents the manufacturer's rated load condition at ISO and provides a conservative estimate of annual emissions.

The emissions will be controlled by the use of natural gas and the latest combustion technology. Natural gas is the cleanest-burning fossil fuel, and, when combined with dry low NO_x combustion technology, thereby minimizing potential emissions of PM, PM₁₀, SO₂, NO_x, CO, VOC, and other pollutants (e.g., trace metals). The Project's engineering and environmental designs will maximize control of air emissions while minimizing economic, environmental, and energy impacts.

This section presents the applicable NSPS and the proposed BACT for these pollutants. The approach to the BACT analysis is based on the regulatory definitions of BACT, as well as EPA's current policy guidelines requiring a top-down approach. A BACT determination requires an analysis of the economic, environmental, and energy impacts of the proposed and alternative control technologies [see 40 CFR 52.21(b)(12)]. The analysis must, by definition, be specific to the project (i.e., case-by-case).

4.2 NEW SOURCE PERFORMANCE STANDARDS

The applicable NSPS for CTs are codified in 40 CFR 60, Subpart GG and summarized in Appendix B. The applicable NSPS emission limit for NO_x is 75 parts per million by volume dry (ppmvd) corrected for heat rate and 15 percent oxygen. For the CTs being considered for the project, the NSPS emission limit for NO_x with the NSPS heat rate correction about 111 ppm on natural gas (corrected to 15 percent oxygen at a fuel-bound nitrogen content of 0.015 percent). The proposed NO_x emission limits for the project will be much lower than the NSPS.

4.3 BEST AVAILABLE CONTROL TECHNOLOGY FOR SIMPLE CYCLE OPERATION

The control technology review requirements of PSD regulations require a determination of BACT. As described in Section 3.2.2, BACT is determined on a case-by-case basis after taking into account the specific energy, environmental and economic impacts and other costs of the project. The EPA top-down approach is the recommended evaluation method that must consider technically feasible and available control technologies that achieve the maximum degree of emission reduction. These technologies must then be evaluated against the energy, environmental and economic impacts. The rejection of the "top" technically feasible and available technologies must be justified as "inappropriate" based on this case-by-case evaluation.

A BACT analysis has been performed for a Westinghouse 501F CT operating in simple cycle mode. The results of the analysis have concluded the following controls will be BACT for the project. The CTs will utilize dry low-NO_x (DLN) for NO_x control that will achieve, at 59°F ambient conditions:

- NO_x emission levels of up to 15 ppmvd corrected to 15 percent O₂ at 70 to 100 percent load (baseload) conditions; and
- CO emissions will be limited to 25 ppmvd corrected to 15 percent O₂ at 70 to 100 percent load.
- PM/PM₁₀ emissions (dry filterables) will be limited to 6.9 to 8.2 lb/hr at 70 to 100 percent load, respectively, at ambient temperature of 59 °F.

4.3.1 Nitrogen Oxides

The BACT analysis was performed for simple cycle operation for the following alternatives:

- DLN with selective catalytic reduction (SCR) at an emission rate of 4.5 ppmvd corrected to 15 percent O₂ for 3,750 hours.
- Westinghouse 501F CT with DLN at an emissions rate of 15 ppmvd corrected to 15 percent O₂ for 3,750 hours.

The evaluated technologies are those that are technically feasible and potentially available for the project using the EPA top-down approach (see Appendix B). For the proposed project, the technologies evaluated included DLN in combination with "hot" SCR and DLN alone.

NO_x Control Technologies

Dry low-NO_x combustor technology has recently been offered and installed by manufacturers to reduce NO_x emissions by inhibiting thermal NO_x formation through premixing fuel and air prior to combustion and providing staged combustion to reduce flame temperatures. NO_x emission rates from 25 ppmvd (corrected to 15-percent O₂) and less have been demonstrated with DLN technology. The NO_x emission level proposed for the project when only firing natural gas at baseload conditions is 15 ppmvd (corrected to 15-percent O₂), which is guaranteed by the selected vendor (Westinghouse).

SCR is a post-combustion process where NO_x in the gas stream is reacted with ammonia in the presence of a catalyst to form nitrogen and water (refer to Appendix B). The reaction occurs typically between 600°F and 750°F, which is appropriate for combined cycle units where such temperatures occur in the heat recovery steam generator (HRSG). Exhausts

from simple cycle operation are in the range of 1,100°F and greater, thus precluding the application of combined cycle SCR systems for this mode of operation due to damage to the catalyst. With the higher cost ceramic catalyst, SCR at temperatures up to 1,100°F is theoretically possible. However, flue gas cooling would still be required to maintain temperatures at or below 1,050°F to insure the catalyst is not damaged during the range of operation. There have been only a few applications of SCR on simple cycle gas turbines primarily associated with much smaller turbines with low exhaust temperatures, i.e., less than 1,000°F operating on a continuous basis. Experience with these SCR has not been entirely successful with catalyst damage occurring on several of the projects. The exhaust temperatures associated with the Westinghouse 501F exceed 1,100°F and would require a temperature reduction to less than 1,050°F for high temperature SCR to be technically feasible. This can be accomplished with dilution air or heat exchange mechanism (referred to as attemperation) but has not been commercially demonstrated on an "F" Class turbine. Even with the proper design, the uncertainty of maintaining such temperatures throughout the peaking service cycle has not been demonstrated. Such a system has not been determined or demonstrated as BACT on an "F" Class CT (i.e., 180 MW) operating in peaking mode.

As discussed in Section 2.1, the proposed CTs will be fired only with natural gas. No backup fuel will be used. Table 4-1 presents a summary of NO_x emissions with DLN and DLN with SCR assuming 3,750 hours of operation at an ambient (turbine inlet) temperature of 59°F. This temperature represents an average expected condition over an annual period. The NO_x removed is based on 3,750 hours per year per CT at baseload.

Proposed NO_x BACT and Rationale

The proposed BACT for the project is DLN for simple-cycle "F" Class CTs. The proposed NO_x emissions level using this technology is 15 ppmvd (corrected to 15 percent oxygen) when firing natural gas. Control of NO_x emissions using DLN is proposed for the following reasons:

1. The proposed BACT (i.e., DLN) provides the most cost effective and pollution preventing control alternative, and results in low environmental impacts. DLN at the proposed emissions levels has been adopted previously in Florida as BACT in a

recent determination. Indeed, the definition of BACT specifically includes "innovative fuel combustion techniques" as being appropriate in determining BACT.

2. SCR was rejected based on technical, economic, environmental, and energy grounds. Table 4-2 summarizes these considerations which favor DLN technology. A specific cost breakdown for SCR use is detailed in Table B-3 and B-4 of Appendix B.
3. The estimated incremental cost of SCR is approximately \$11,850 per ton of NO_x removed. The excessive costs are even more apparent if additional pollutant emissions due to SCR are considered. The cost effectiveness is more than \$18,000 per ton of pollutant removed when the net emissions of all pollutants (exclusive of CO₂) are considered.
4. Additional environmental impacts would result from SCR operation (see Table 4-3), including emissions of ammonia; from secondary emissions (to replace the lost generation); and from the generation of hazardous waste (i.e., spent catalyst replacement). While NO_x emissions would be reduced by about 140 TPY/CT with SCR, the net emissions reduction would not be as great. There are three additional factors that must be considered:
 - a. Ammonia slip would occur, and it may be as high as 41.7 TPY/CT.
 - b. Additional particulate matter may be formed through the reaction of ammonia and sulfur oxides forming ammonium salts. As much as 3.1 TPY/CT of additional particulate matter may be formed.
 - c. SCR will require energy for system operation and reduce the efficiency of the CT. This lost energy would have to be replaced since the proposed project would be an efficient baseload plant while operating. Any power plants replacing this lost energy would be lower on the dispatch list and inevitably more polluting. Additional emissions of carbon dioxide would also result.
5. The energy impacts of SCR will reduce potential electrical power generation by more than 4.55 million kilowatt-hours (kWh) per year per CT. This amount of energy is sufficient to provide the annual electrical needs of 379 residential customers/CT.

6. DLN technology has been demonstrated to meet NO_x emission levels proposed for the project. In contrast, application of SCR on a simple cycle "F" Class turbine has not been demonstrated or not yet commercially available for this type of CT. There are considerable technical uncertainties, which would likely affect the reliability of the SCR system and its ultimate economic impacts to the project.

A description of the proposed technology and feasibility and the BACT analyses of economic, environmental and energy impacts follow.

Technology Demonstration and Feasibility

The project will use a heavy-duty industrial CT with advanced dry low-NO_x combustors. Appendix B describes in detail a technology comparison of combustion process modifications (i.e. water/steam injection, DLN) and post-combustion exhaust gas treatment systems (i.e. SCR, SCONO_x, NO_xOUT process, Thermal DeNO_x, and NSCR)

A heavy-duty industrial CT is unique from an engineering perspective in two ways. First, the machine is larger and has higher initial firing (i.e., combustion) temperatures than previous turbines. This results in a larger, more thermally efficient machine. For example, the electrical generating capability of the "F" Class machine is about 180 MW compared to the 70 MW to 120 MW size of the conventional machines. The higher initial firing temperature (i.e., 2,400 F) results in about 10 percent more electrical energy produced for the same amount of fossil fuel used in conventional machines. This has the added advantage of producing lower air pollutant emissions (e.g., NO_x, PM, and CO) for each MW generated. While the increased firing temperature increases the thermal NO_x generated, this NO_x increase is controlled through combustor design.

The second unique attribute of this machine is the use of dry low-NO_x combustors that will reduce NO_x emissions to 15 ppmvd when firing natural gas. Thermal NO_x formation is inhibited by using staged combustion techniques where the natural gas and combustion air are premixed prior to ignition. This level of control will result in NO_x emissions of about 0.06 lb/10⁶ Btu, which is less than half of the new NSPS emissions limits for conventional fossil fuel-fired steam generators (i.e., 1.6 lb/net MWh in 40 CFR Part 60, Subpart Da). While

the new NSPS for fossil-fuel steam generators is not applicable to the proposed project, it does establish an output-based emission limit for the production of electric power from this type of technology. The electric power produced by the proposed project will already have much lower NO_x emission rates from power produced by even the lowest NSPS limits for steam technology.

Since the purpose of the project is to produce electrical energy, and CT technology is rapidly advancing, it is appropriate to compare the proposed emissions on an equivalent generation basis to that of a conventional CT. The heat rate of the "F" Class machines in simple-cycle operation will be about 9,200 Btu/kWh (LHV) at 59°F. In contrast, the heat rate for a new conventional CT, is about 11,000 Btu/kWh (LHV). Older existing peaking turbines have heat rates typically greater than 13,000 Btu/kWh (LHV). Therefore, the amount of total NO_x from the CT will be at least 10 percent lower than that of a new conventional turbine for the same amount of generation.

Also, the amount of NO_x control achieved by the dry low-NO_x combustor on the proposed CT is considerably higher than that achieved by a conventional CT. Because of the higher firing initial temperatures, this CT results in greater NO_x emission formation. Since the advanced machine has higher firing temperatures, the NO_x emissions without the use of dry low-NO_x combustion technology are much higher than a conventional CT (greater than 180 ppmvd vs. 150 ppmvd). This results in an overall greater NO_x reduction on the advanced CT.

NO_x BACT Impacts Analysis

Economic Impacts for NO_x

The total capital cost of selective catalytic reduction on a per CT basis is \$5,290,700. The total annualized cost of applying SCR with water injection is \$1,661,000. The capital cost is about 12 percent of the total cost of a simple cycle unit which is a significant percent of the overall cost. Detailed cost estimates for the capital and annualized costs are provided in Tables B-3 and B-4 of Appendix B. The incremental cost effectiveness of adding SCR to the water injection is estimated to be \$11,850 per ton of NO_x removed. This cost effectiveness accounts only for the reduction of NO_x with SCR use and not the potential emissions from ammonia

slip or other criteria pollutants that may result. The net cost effectiveness will be much higher.

Environmental Impact for NO_x

The maximum predicted NO_x impacts using the dry low-NO_x technology with SCR are considerably below the PSD Class II increment for NO_x of 25 ug/m³, annual average, and the AAQS for NO_x, 100 ug/m³. Indeed, the maximum annual impact is predicted to be 0.5 ug/m³, which is about 50 percent of the significant impact level.

The use of SCR on the proposed project will cause emissions of ammonia and ammonium salts, such as ammonium sulfate and bisulfate. Ammonia emissions associated with SCR are typically guaranteed by SCR vendors at 10 ppm and previous permit conditions have specified this level. Indeed, ammonia emissions could be as high as 41.7 TPY for a CT at 10 ppm. Potential emissions of ammonium sulfate and bisulfate will increase emissions of PM₁₀; up to 3.1 TPY/CT could be emitted.

The electrical energy required to run the SCR system and the back pressure from the turbine will reduce the available power from the project. This power, which would otherwise be available to the electrical system, will have to be replaced by other less efficient CTs. The replacement power will cause air pollutant emissions that would not have occurred without SCR.

The replacement of the SCR catalyst will create additional economic and environmental impacts since certain catalysts contain materials that are listed as hazardous chemical wastes under Resource Conservation and Recovery Act (RCRA) regulations (40 CFR 261). In addition, SCR will require the construction and maintenance of storage vessels of anhydrous or aqueous ammonia for use in the reaction. Ammonia has a number of potential health effects, and the construction of ammonia storage facilities triggers the application of at least three major standards: Clean Air Act (section 112), Occupational Safety and Health Administration (OSHA) 29 CFR 1910.1000, and OSHA 29 CFR 1910.119.

Energy Impacts for NO_x

Significant energy penalties occur with SCR. With SCR, the output of the CT may be reduced by about 0.50 percent over that of DLN for NO_x control. This penalty is the result of the SCR pressure drop, which would be about 2.5 inches of water and would amount to about 3.5 million kWh per year per CT in potential lost generation. The energy required by the SCR equipment would be about 1.05 million kWh per year per CT. Taken together, the total lost generation and energy requirements of SCR of 4.55 million kWh per year per CT could supply the annual electrical needs of about 379 residential customers. To replace this lost energy, an additional 44.03×10^9 British thermal CTs per year (Btu/yr) or about 44 million cubic feet per year (ft³/yr) of natural gas would be required.

4.3.2 Carbon Monoxide

Emissions of CO are dependent upon the combustion design, which is a result of the manufacturer's design and operating performance. The CTs proposed for the project have designs to optimize combustion efficiency and minimize CO as well as NO_x emissions.

The following alternatives were evaluated as BACT for CO for the project:

1. Combustion controls at 25 ppmvd at 15 percent O₂ when firing natural gas (at 70 to 100 percent load); with emissions of 204 TPY assuming operation of 3,750 hours per year per turbine at baseload; and
2. Oxidation catalyst at 10 ppmvd; maximum annual CO emissions are 66 TPY based on 3,750 hours per year per turbine operation.

Proposed CO BACT and Rationale

Combustion design is proposed as BACT as a result of the technical and economic consequences of using catalytic oxidation on CTs. The proposed BACT emission rates for CO will not exceed 25 ppmvd when firing natural gas at baseload conditions. Catalytic oxidation is considered inappropriate for the following reasons:

1. Catalytic oxidation will not produce measurable reduction in the air quality impacts, based on air modeling results;
2. The economic impacts are significant (i.e., the capital cost is about \$1.75 million per CT, with an annualized cost of \$575,529 per year per CT) (see Tables B-6 and B-7).

Combustion design is proposed as BACT as a result of the technical and economic consequences of using catalytic oxidation on CTs. Catalytic oxidation is considered inappropriate since it will not produce a measurable reduction in the air quality impacts. Indeed, recent BACT decisions for similar advanced CTs have set limits in the 30 ppmvd range and higher. Even the Northeast States for Coordinated Air Use Management (NESCAUM) has recognized a BACT level of 50 ppmvd for CO emissions.

CO Technology Demonstration and Feasibility

The DLN combustor technology has been demonstrated and is technically feasible. High temperature oxidation catalyst can be used to reduce CO emissions. Temperatures greater than 1,200°F may cause catalyst damage. While the data provided by Westinghouse suggest exhaust temperatures less than 1,200°F, the thermal stress for peaking operation, would likely result in temperature variations that may require an attenuation system to assure no catalyst damage. Such a system including high temperature has not been determined or demonstrated as BACT for CO on an "F" class combustion turbine in peaking service.

BACT Impact Analysis

Economic Impact for CO

The estimated annualized cost of a CO oxidation catalyst is \$575,529/CT, resulting in a cost effectiveness of approximately \$4,150 per ton of CO removed (see Tables B-6 and B-7). The cost effectiveness is based on 3,750 hours per year per with the maximum emissions controlled to 10 ppmvd. No costs are associated with combustion techniques since they are inherent in the design.

The CO emissions estimate for the "F" Class machines is a result of uncertainty associated with maintaining low NO_x emissions while keeping emissions of CO as low as possible over the load range for the machine. Experience has shown, however, that actual CO emissions are much lower. Recent tests on a Westinghouse "F" class turbine with DLN found CO concentrations less than 10 ppmvd. By maintaining an emission rate of 20 ppmvd or less for 3,750 hours per year the cost effectiveness of an oxidation catalyst is \$8,770 per ton of CO removed, or about 110 percent higher.

Environmental Impacts for CO

The air quality impacts based on air dispersion modeling of both oxidation catalyst control and combustion design control techniques are below the significant impact levels for CO. Therefore, no significant environmental benefit would be realized by the installation of a CO catalyst. Indeed, additional particulate and secondary emissions as a result of an oxidation catalyst. The particulate would result from the conversion of SO₂ to sulfates, and the secondary emissions would result from worsening the heat rate. Moreover, the air quality impacts at the proposed BACT emission rate of 25 ppmvd at 15 percent O₂ are predicted to be much less than the PSD significant impact levels. There would also be no secondary benefits, such as reduction of acidic deposition, to reducing CO emissions.

Energy Impact for CO

An energy penalty would result from the pressure drop across the catalyst bed. A pressure drop of about 2 inches of water would be expected. At a catalyst backpressure of about 2 inches, an energy penalty of about 1,398,450 kWh/yr per CT would result at peak load. This energy penalty is sufficient to supply the electrical needs of about 117 residential customers for a year. To replace this lost energy, about 13.5×10^9 Btu/yr or about 14 million ft³/yr of natural gas would be required.

4.3.3 PM₁₀ and Other Regulated and Nonregulated Pollutant Emissions

The emission of particulates from the CTs is a result of incomplete combustion, trace elements in the fuel, and particulates in the filtered incoming air. The design of the CT ensures that combustion controls and the use of clean fuels will minimize particulate emissions. A review of EPA's BACT/LAER Clearinghouse Documents did not reveal any post-combustion particulate control technologies being used on natural gas fired CTs.

The maximum particulate emissions from the CT will be lower in concentration than that normally specified for fabric filter designs {i.e., the grain loading associated with the maximum particulate emissions [about 6 pounds per hour (lb/hr) when firing natural gas]} is less than 0.01 grain per standard cubic foot (gr/scf), which is a typical design specification

for a baghouse. This further demonstrates that no further particulate controls are necessary for the proposed project.

There are no technically feasible methods for controlling the emissions of these pollutants from CTs, other than the inherent quality of the fuel. Clean fuels such as natural gas represents BACT for PM/ PM₁₀. The use of SCR for controlling NO_x would result in an increase in PM/PM₁₀ emissions due to the reaction of ammonia and sulfur oxides. Ammonium sulfates (e.g., ammonium sulfate) are formed by the unreacted ammonia (i.e., ammonia slip) and SO₃ downstream of the SCR system.

None of the control technologies evaluated above for other pollutants (i.e., SCR) would reduce emissions of nonregulated pollutants such as trace organic compounds (e.g., formaldehyde). Natural gas, and good combustion practices represent BACT because of the inherently low contaminant content found in the fuel.

Table 4-1. NO_x Emission Estimates (TPY) of BACT Alternative Technologies for Simple Cycle Operation Per Combustion Turbine

Alternative BACT Control Technologies	Operating Mode ^a	
	lb/hr	TPY
<u>NO_x Emission</u>		
Dry Low-NO _x (DLN) only	106.8	200.3
DLN with SCR ^b	32.0	60.1
Reduction	(74.8)	(140.2)
<u>Basis of Emissions (ppmvd)</u>		
DLN only		15
DLN with SCR		4.5
Hours of Operation		3,750

Note: DLN = Dry low-NO_x.

SCR = selective catalytic reduction.

TPY = tons per year.

^a Emission rates were based on a Westinghouse 501FD CT or equivalent firing natural gas for 3,750 hours at base load with an ambient temperature of 59°F.

^b Based on primary emissions with SCR; no account is made for additional emissions (secondary) due to lost energy from heat rate penalty and electrical usage for SCR operation.

Table 4-2. Comparison of Alternative BACT Control Technologies for NO_x - Simple Cycle Mode (per CT)

Impact Analysis	Alternative BACT Control Technologies	
	DLN Only	SCR
Technical Feasibility Demonstration	Feasible	Not Demonstrated on "F" Simple Cycle
Economic Impact ^a		
Capital Costs	Included	\$5,290,745
Annualized Costs	Included	\$1,661,050
Cost Effectiveness		
NO _x Removed (TPY)	NA	\$11,850
Environmental Impact ^b		
Total NO _x (TPY)	200.3	60.1
NO _x Reduction (TPY)	NA	(140.2)
Ammonia Emissions (TPY)	0	41.4
PM Emissions (TPY)	0	3.1
Secondary Emissions (TPY)	0	5.1
Net Emission Reduction (TPY)	NA	(60)
Energy Impacts ^c		
Energy Use (kWh/yr)	0	4,546,125
Energy Use (mmBtu/yr)	0	44,029
At 10,000 Btu/kWh		
Energy Use (mmcf/yr)	0	44
at 1,000 Btu/cf for natural gas		

^a See Appendix B for detailed development of capital costs (including recurring costs) and annualized costs.

^b See data presented in Table 4-3.

^c Energy impacts are estimated due to the lost energy from heat rate penalty and electrical usage for the SCR operation at 3,750 hours per year. Lost energy is based on 0.5 percent of 186.46 MW. SCR electrical usage is based on 0.080 MWh per SCR system.

Table 4-3. Maximum Potential Incremental Emissions (TPY) with Selective Catalytic Reduction

Pollutants	Incremental Emissions (tons/year) of SCR		Total
	Primary	Secondary	
Particulate	3.09	0.16	3.25
Sulfur Dioxide		0.06	0.06
Nitrogen Oxides	-140.18	2.94	-137.24
Carbon Monoxide		1.76	1.76
Volatile Organic Compounds		0.12	0.12
Ammonia	41.68		
Total:	-95.40	5.03	-90.37
Carbon Dioxide (additonal from gas firing)		2,788.52	2,788.52

Basis:

Lost Energy (mmBtu/year) 44,029

Secondary Emissions (lb/mmBtu): Assumes natural gas firing in NO_x controlled steam unit.

Particulate	0.0072
Sulfur Dioxide	0.0027
Nitrogen Oxides w/LNB	0.1333
Carbon Monoxide	0.0800
Volatile Organic Compounds	0.0052

Reference: Table 1.4-1 and 1.4-2, AP-42, Version 2/98

5.0 AMBIENT MONITORING ANALYSIS

The CAA requires that an air quality analysis be conducted for each criteria and noncriteria pollutant subject to regulation under the act before a major stationary source is constructed. Criteria pollutants are those pollutants for which AAQS have been established. Noncriteria pollutants are those pollutants that may be regulated by emission standards, but no AAQS have been established. This analysis may be performed by the use of modeling and/or by monitoring the air quality.

A major source may waive the ambient monitoring analysis requirement if it can be demonstrated that the proposed source's maximum air quality impacts will not exceed the PSD *de minimis* concentration levels. The maximum impacts of the proposed source are compared with the PSD *de minimis* concentrations in Table 3-5. As can be seen from Table 3-5, the proposed plant's maximum air quality impacts will be well below the *de minimis* concentrations for all applicable pollutants. As a result, preconstruction monitoring data are not required to be submitted as part of this application.

6.0 AIR QUALITY IMPACT ANALYSIS

6.1 AIR MODELING PROTOCOL

Prior to performing air modeling for this project, an air modeling protocol was prepared and sent to the Florida DEP for review and approval. The Florida DEP provided comments to the protocol which are incorporated into the modeling approach described in the following sections. As a result, the proposed modeling approach conforms to procedures and guidelines used by the Florida DEP to assess air modeling projects that undergo PSD review.

Copies of the letters that present the air modeling protocol and comments provided by the Florida DEP are presented in Appendix C.

6.2 SIGNIFICANT IMPACT ANALYSIS APPROACH

The general modeling approach followed EPA and Florida DEP modeling guidelines for determining compliance with AAQS and PSD increments. For all applicable pollutants that have emission increases that will exceed the PSD significant emission rate due to a proposed project, a significant impact analysis is performed. This analysis determines whether the project alone will result in predicted impacts that will exceed the EPA significant impact levels at any off-plant property areas in the vicinity of the plant.

If the project's impacts are above the significant impact levels, then a more detailed air modeling analysis that includes background sources is performed. If the project's impacts are below the significant impact levels, more detailed air modeling analysis is not required. The project is assumed to have an insignificant impact on surrounding air quality.

For this project, the significant impact levels were estimated in the vicinity of the plant following Florida DEP policies.

Generally, if a new project also is within 150 kilometers of a PSD Class I area, then a significant impact analysis is also performed for the PSD Class I area. EPA has proposed PSD Class I significant impact levels that have not been finalized as of this report (see Section 3.2.3).

Based on comments provided by the Florida DEP, a PSD Class I modeling analysis was not required since the project is more than 150 km from the nearest Class I area.

6.3 PRECONSTRUCTION MONITORING ANALYSIS APPROACH

The general modeling approach followed EPA and Florida DEP modeling guidelines for evaluating a project's impacts relative to the *de minimis* monitoring levels to determine the need to submit continuous monitoring data prior to construction. For all applicable pollutants that have emission increases that will exceed the PSD significant emission rate due to a proposed project, a *de minimis* impact analysis is performed. This analysis determines whether the project alone will result in predicted impacts that will exceed the EPA *de minimis* levels at any off-plant property areas in the vicinity of the plant. Current Florida DEP policies stipulate that the highest annual average and highest short-term concentrations are to be compared to the applicable *de minimis* monitoring levels.

A proposed major stationary facility or major modification may be exempt from the monitoring requirements with respect to a particular pollutant if the emissions increase of the pollutant from the facility or modification would cause, in any area, air quality impacts less than the *de minimis* levels.

For this project, the project's impacts were estimated in the vicinity of the plant for comparison to *de minimis* levels following Florida DEP policies.

6.4 AIR MODELING ANALYSIS APPROACH

6.4.1 General Procedures

As stated in the previous sections, for each pollutant which is emitted above the significant emission rate, air modeling analyses are required to determine if the project's impacts are predicted to be greater than the significant impact levels and *de minimis* monitoring levels. These analyses consider the project's impacts alone. Air quality impacts are predicted using 5 years of meteorological data and selecting the highest annual and the highest short-term concentrations for comparison are compared to the significant impact levels and *de minimis* levels.

If the project's impacts are greater than the significant impact levels, the air modeling analyses must consider other nearby sources and background concentrations, and predict concentration for comparison to ambient standards. In general, when 5 years of meteorological data are used in the analysis, the highest annual and the highest, second-highest (HSH) short-term concentrations are compared to the applicable AAQS and allowable PSD increments. The HSH concentration is calculated for a receptor field by:

1. Eliminating the highest concentration predicted at each receptor,

2. Identifying the second-highest concentration at each receptor, and
3. Selecting the highest concentration among these second-highest concentrations.

This approach is consistent with air quality standards and allowable PSD increments, which permit a short-term average concentration to be exceeded once per year at each receptor.

To develop the maximum short-term concentrations for the proposed project, the modeling approach was divided into screening and refined phases to reduce the computation time required to perform the modeling analysis. For this study, the only difference between the two modeling phases is the density of the receptor grid spacing employed when predicting concentrations. Concentrations are predicted for the screening phase using a coarse receptor grid and a 5-year meteorological data record.

Refinements of the maximum predicted concentrations are typically performed for the receptors of the screening receptor grid at which the highest and/or HSH concentrations occurred over the 5-year period. Generally, if the maximum concentrations from other years in the screening analysis are within 10 percent of the overall maximum concentration, then those other concentrations are refined as well. Typically, if the highest and HSH concentrations are in different locations, concentrations in both areas are refined.

Modeling refinements are performed for short-term averaging times by using a denser receptor grid, centered on the screening receptor at which the maximum concentration was predicted. The angular spacing between radials is 2 degrees and the radial distance interval between receptors is 100 m. Annual modeling refinements employ an angular spacing between radials of 2 degrees and a distance interval from 100 to 300 m, depending on the concentration gradient in the vicinity of the screening receptor to be refined. If the maximum screening concentration is located on the plant property boundary, additional plant boundary receptors are input, spaced at a 2-degree angular interval and centered on the screening receptor. The domain of the refinement grid will extend to all adjacent screening receptors. The air dispersion model is then executed with the refined grid for the entire year of meteorology during which the screening concentration occurred. This approach is used to ensure that a valid highest concentration is obtained. A more detailed description of the model, along with the emission inventory, meteorological data, and screening receptor grids are presented in the following sections.

6.4.2 Model Selection

The Industrial Source Complex Short-term (ISCST3, Version 99155) dispersion model (EPA, 1999) was used to evaluate the pollutant impacts due to the proposed CTs. This model is maintained by the EPA on its Internet website, Support Center for Regulatory Air Models (SCRAM), within the Technical Transfer Network (TTN). A listing of ISCST3 model features is presented in Table 6-1. The ISCST3 model is designed to calculate hourly concentrations based on hourly meteorological data (i.e., wind direction, wind speed, atmospheric stability, ambient temperature, and mixing heights). The ISCST3 model is applicable to sources located in either flat or rolling terrain where terrain heights do not exceed stack heights. These areas are referred to as simple terrain. The model can also be applied in areas where the terrain exceeds the stack heights. These areas are referred to as complex terrain.

In this analysis, the EPA regulatory default options were used to predict all maximum impacts. The ISCST3 model can run in the rural or urban land use mode that affects stability dispersion coefficients, wind speed profiles, and mixing heights. Land use can be characterized based on a scheme recommended by EPA (Auer, 1978). If more than 50 percent land use within a 3-km radius around a project is classified as industrial or commercial, or high-density residential, then the urban option should be selected. Otherwise, the rural option is appropriate. Based on the land-use within a 3-km radius of the proposed plant site (see Figure 1-1), the rural dispersion coefficients were used in the modeling analysis.

The ISCST3 model was used to provide maximum concentrations for the annual and 24-, 8-, 3-, and 1-hour averaging times. A generic emission rate of 10 grams per second (g/s) was used as emissions for the proposed source. Maximum pollutant-specific air impacts were determined by multiplying the maximum pollutant-specific emission rate in pounds per hour (lb/hr) to the maximum predicted generic impact divided by 79.365 lb/hr (10 g/s).

6.4.3 Meteorological Data

Meteorological data used in the ISCST3 model to determine air quality impacts consisted of a concurrent 5-year period of hourly surface weather observations and twice-daily upper air soundings from the National Weather Service (NWS) stations at Orlando, Florida, and West Palm Beach, Florida, respectively. The 5-year period of meteorological data was from 1987 through 1991, which is the latest readily available data for this station that is acceptable to the Florida DEP (see Appendix C). The NWS station at Orlando is located approximately 40 km (24 miles) west of the proposed plant site while the NWS station at West Palm Beach

is located approximately 200 km (120 miles) south-southeast of the proposed plant site. The surface meteorological data from Orlando are assumed to be representative of the project site because both the project site and the weather station are located in areas to experience similar weather conditions, such as frontal passages. In addition, these data have been accepted for use by the Florida DEP in other PSD permit applications to address air quality impacts for other proposed sources locating in Osceola County and adjacent counties.

6.4.4 Emission Inventory

A summary of the criteria pollutant emission rates, physical stack and stack operating parameters for the proposed CTs used in the air modeling analysis is presented in Table 2-1. Emission and stack operating parameters are presented for 32°F, 59°F, and 95°F ambient temperatures. In an effort to obtain the maximum air quality impacts for a range of possible operating conditions, the air modeling analysis used a range of emission rates and stack parameter data to predict air quality impacts.

Six modeling scenarios were considered:

1. 100 percent operating load for the ambient temperature of 32°F;
2. 100 percent operating load for the ambient temperature of 59°F;
3. 100 percent operating load for the ambient temperature of 95°F;
4. 70 percent operating load for the ambient temperature of 32°F;
5. 70 percent operating load for the ambient temperature of 59°F; and
6. 70 percent operating load for the ambient temperature of 95°F.

The proposed CTs will have a stack height of 50 feet and an inside stack diameter of 19 ft.

The relative locations of the stacks used in the modeling were:

Emission source	Relative Location (ft)	
	<u>X</u>	<u>Y</u>
CT No. 1 (simple-cycle)	-130	0
CT No. 2 (simple-cycle)	0	0
CT No. 3 (simple-cycle)	130	0

6.4.5 Receptor Locations

For predicting maximum concentrations in the vicinity of the plant, a polar receptor grid comprised of 1,0691 grid receptors was used. These receptors included 36 receptors located on radials extending out from the proposed CTs' stack locations. Along each radial, receptors were at distances of 0.2, 0.4, 0.6, 0.8, 1.0, 1.2, 1.4, 1.6, 1.8, 2.0, 2.25, 2.5, 2.75, 3.0, 3.5, 4.0, 4.5, 5.0, 6.0, 7.0, 8.0, 9.0, 10.0, 12.0, 13.0, 15.0, 17.0, 20.0, 22.5, and 25.0 km from the center of the proposed stack locations. The distance of 0.2 km was selected as the minimum receptor distance since this distance represents the minimum distance in any direction from the stack for CT No. 2 (used as the modeling origin) to the plant boundary. The proposed plant property extends out from a minimum distance of about 0.2 km to more than 0.4 km for other directions. However, since the proposed CTs will only operate in simple cycle mode, the maximum impacts are expected to occur well beyond the plant property. Minimal, if any, impacts due to the proposed CTs are expected at receptors located on the plant property or at the plant boundary.

Modeling refinements were performed, as needed, by employing a polar receptor grid with a maximum spacing of 100 m along each radial and an angular spacing between radials of 2 degrees.

For each receptor location, terrain elevations were assumed equal to the stack base elevation since the terrain is flat surrounding the project site. The stackbase elevation was assumed to be 20 ft above mean sea level (MSL).

6.4.6 Building Downwash Effects

The only significant structures in the vicinity of the proposed CT stacks are the proposed CT air inlet filters and CT enclosure/air inlet ducts. The height and widths of these structures are as follows:

<u>Structure</u>	<u>Height (ft)</u>	<u>Width (ft)</u>	<u>Length (ft)</u>
CT air inlet filter	40	40	40
CT enclosure/air inlet duct	28	20	60

Building dimensions for the project's structures were entered into the EPA's Building Profile Input Program (BPIP, Version 95086) for the purpose of obtaining direction-specific building heights and widths for all downwash-affected sources. The direction-specific building dimensions were then input to the ISCST3 model as the building height and width for each

of 36 ten-degree wind sectors. A summary of the direction-specific building dimensions used in the modeling is presented in Appendix D.

6.5 AIR MODELING RESULTS

The modeling analysis results for the proposed CTs operating are summarized in Tables 6-2 through 6-4. The maximum pollutant concentrations predicted in the screening analysis for one CT and three CTs are given in Tables 6-2 and 6-3, respectively. The results from the refined analyses are given in Table 6-4. Although, SO₂ emissions are not subject to PSD review in this phase, the maximum SO₂ concentrations are also provided for completeness and comparison to significant impact levels.

As shown in Table 6-4, the maximum predicted PM, SO₂, NO₂, and CO impacts due to the proposed CTs are all below the significant impact levels. Because the Project will not have a significant impact upon the air quality in the vicinity of the plant site, more detailed modeling analyses for determining compliance with the AAQS and PSD Class II increments are not required.

The maximum predicted PM, SO₂, NO₂, and CO impacts due to the proposed CTs are also below the *de minimis* monitoring levels. Because the proposed source will not have predicted impacts greater than *de minimis* levels, preconstruction monitoring data are not required to be submitted as part of the PSD review.

A summary of the model results for each year is presented in Appendix E. The locations of the maximum predicted concentrations are also given in the summary. An example of the model input file is also provided in Appendix E.

Table 6-1. Major Features of the ISCST3 Model

ISCST3 Model Features	
<hr/>	
<ul style="list-style-type: none">• Polar or Cartesian coordinate systems for receptor locations• Rural or one of three urban options which affect wind speed profile exponent, dispersion rates, and mixing height calculations• Plume rise due to momentum and buoyancy as a function of downwind distance for stack emissions (Briggs, 1969, 1971, 1972, and 1975; Bowers, et al., 1979).• Procedures suggested by Huber and Snyder (1976); Huber (1977); and Schulman and Scire (1980) for evaluating building wake effects• Procedures suggested by Briggs (1974) for evaluating stack-tip downwash• Separation of multiple emission sources• Consideration of the effects of gravitational settling and dry deposition on ambient particulate concentrations• Capability of simulating point, line, volume, area, and open pit sources• Capability to calculate dry and wet deposition, including both gaseous and particulate precipitation scavenging for wet deposition• Variation of wind speed with height (wind speed-profile exponent law)• Concentration estimates for 1-hour to annual average times• Terrain-adjustment procedures for elevated terrain including a terrain truncation algorithm for ISCST3; a built-in algorithm for predicting concentrations in complex terrain• Consideration of time-dependent exponential decay of pollutants• The method of Pasquill (1976) to account for buoyancy-induced dispersion• A regulatory default option to set various model options and parameters to EPA recommended values (see text for regulatory options used)• Procedure for calm-wind processing including setting wind speeds less than 1 m/s to 1 m/s.	

Note: ISCST3 = Industrial Source Complex Short-Term.

Source: EPA, 1999.

Table 6-2. Maximum Predicted Pollutant Concentrations For One Simple-Cycle Combustion Turbine
Screening Analysis, 501D Combustion Turbine, Natural Gas- Fired
Palmetto Power LLC Project

Pollutant	Maximum Emission Rates (lb/hr) by Operating Load and Air Inlet Temperature						Averaging Time	Maximum Predicted Concentrations (ug/m ³) by Operating Load and Air Inlet Temperature (1)					
	Base Load			70% Load				Base Load			70% Load		
	32 °F	59 °F	95 °F	32 °F	59 °F	95 °F		32 °F	59 °F	95 °F	32 °F	59 °F	95 °F
Generic (10 g/s)	79.37	79.37	79.37	79.37	79.37	79.37	Annual	0.015	0.015	0.015	0.017	0.018	0.018
							24-Hour	0.184	0.188	0.197	0.236	0.240	0.246
							8-Hour	0.484	0.494	0.516	0.608	0.618	0.632
							3-Hour	0.871	0.891	0.937	1.241	1.334	1.339
							1-Hour	1.970	2.007	2.097	2.460	2.552	2.596
PM10	8.6	8.2	7.5	7.1	6.9	6.4	Annual	0.0016	0.0015	0.0014	0.0015	0.0015	0.0015
							24-Hour	0.020	0.020	0.018	0.021	0.021	0.020
NO _x	111.2	106.8	98.4	83.0	78.8	72.9	Annual	0.020	0.020	0.018	0.018	0.018	0.017
CO	113.0	109.0	100.0	85.0	80.0	74.0	8-Hour	0.69	0.68	0.65	0.65	0.62	0.59
							1-Hour	2.8	2.8	2.6	2.6	2.6	2.4

(1) Concentrations are based on highest predicted concentrations using five years of meteorological for 1987 to 1991
of surface and upper air data from the National Weather Service stations in Orlando and West Palm Beach, Florida, respectively.

Pollutant concentrations were based on a modeled or generic concentration predicted using a modeled emission rate of 79.37 lb/hr [10(g/s)]. Specific pollutant concentrations were estimated by multiplying the modeled concentration (at 10 g/s) by the ratio of the specific pollutant emission rate to the modeled emission rate of 10 g/s.

Table 6-3. Maximum Pollutant Concentrations Predicted for Three Simple Cycle Combustion Turbines Compared to EPA Significant Impact and De minimis Monitoring Levels- Screening Analysis
Palmetto Power LLC Project

Pollutant	Averaging Time	Maximum Predicted Concentrations (ug/m³) by Operating Load and Air Inlet Temperature (1)						EPA Significant Impact Levels (ug/m³)	EPA Deminimis Levels (ug/m³)
		Base Load			70% Load				
		32 °F	59 °F	95 °F	32 °F	59 °F	95 °F		
PM10	Annual	0.5513	0.5630	0.5898	0.7065	0.7203	0.7374	1	NA
	24-Hour	1.451	1.481	1.549	1.823	1.855	1.895	5	10
NO₂	Annual	0.061	0.059	0.055	0.054	0.053	0.050	1	14
CO	8-Hour	2.1	2.0	2.0	2.0	1.9	1.8	500	575
	1-Hour	8.4	8.3	7.9	7.9	7.7	7.3	2,000	NA

(1) Concentrations are based on highest predicted concentrations using five years of meteorological for 1987 to 1991 of surface and upper air data from the National Weather Service stations in Orlando and West Palm Beach, Florida, respectively.

Table 6-4. Summary of Maximum Pollutant Concentrations Predicted for Three SimpleCycle Combustion Turbines Compared to EPA Significant Impact and De minimis Monitoring Levels
Palmetto Power LLC Project

Pollutant	Averaging Time	Maximum Predicted Concentrations ($\mu\text{g}/\text{m}^3$)	EPA Significant Impact Levels ($\mu\text{g}/\text{m}^3$)	EPA De minimis Levels ($\mu\text{g}/\text{m}^3$)
PM ₁₀	Annual	0.0047 (1)	1	NA
	24-Hour	0.076 (2)	5	10
NO ₂	Annual	0.061 (1)	1	14
CO	8-Hour	2.1 (1)	500	575
	1-Hour	8.4 (1)	2,000	NA

(1) Based on operating conditions at 100 percent load and ambient inlet temperature of 32 °F.

(2) Based on operating conditions at 70 percent load and ambient inlet temperature of 32 °F.

7.0 ADDITIONAL IMPACT ANALYSIS

7.1 IMPACTS DUE TO DIRECT GROWTH

The Project is being constructed to meet current and projected electric demands. Additional growth as a direct result of the additional electric power provided by the project is not expected. The project will be constructed and operated with minimum labor and associated facilities and is not expected to significantly affect growth in the area. As a result, air pollution impacts from additional growth are not anticipated.

7.2 IMPACT ON SOILS, VEGETATION AND WILDLIFE

Because the Project's impacts on the local air quality are predicted to be less than the significant impact levels for PSD Class II areas, the project's impacts on soils, vegetation, and wildlife are also not expected to be significant.

7.3 IMPACTS UPON PSD CLASS I AREAS

The proposed project is located more than 150 km from any PSD Class I area. The nearest Class I areas to the site are the Chassahowitzka NWA and the Everglades National Park which are located about 170 and 220 km, respectively, from the site. Other PSD Class I areas are located more than 250 km from the site. Based on discussions with the Florida DEP, an air quality impact evaluation was not required for this project since the project's impacts are not expected to be significant at the distances of the Class I areas. Because the proposed CTs will be fired with natural gas, a clean fuel, it is expected that the project's impacts for SO₂, NO₂, and PM₁₀ will be minimal and not significantly affect or impair visibility or soils and vegetation at the Class I areas.

APPENDIX A

VENDOR INFORMATION ON "F" CLASS COMBUSTION TURBINE

Table A-1. Design Information and Stack Parameters for the Palmetto Power L.L.C. Project- Simple Cycle Operation
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 100 % Load

Parameter	Ambient/Compressor Inlet Temperature				
	32 °F Case 1	59 °F Case 2	59 °F Case 3	95 °F Case 4	95 °F Case 5
Combustion Turbine Performance					
Evaporative cooler status/ efficiency (%)	Off	85	Off	85	Off
Ambient Relative Humidity (%)	50	60	60	60	60
Gross power output (MW)	196.20	186.46	182.47	167.59	160.93
Gross heat rate (Btu/kWh, LHV)	9,095	9,190	9,215	9,415	9,495
(Btu/kWh, HHV)	10,100	10,200	10,230	10,455	10,540
Heat Input (MMBtu/hr, LHV)- calculated	1,784	1,714	1,681	1,578	1,528
- provided	1,784	1,713	1,681	1,578	1,528
(MMBtu/hr, HHV) - provided	1,981	1,902	1,867	1,752	1,696
(HHV/LHV)	1.110	1.110	1.110	1.110	1.110
Fuel heating value (Btu/lb, LHV)	20,981	20,981	20,981	20,981	20,981
(Btu/lb, HHV)	23,299	23,299	23,299	23,299	23,299
(HHV/LHV)	1.110	1.110	1.110	1.110	1.110
CT Exhaust Flow					
Mass Flow (lb/hr)	3,793,672	3,661,592	3,612,916	3,368,437	3,291,632
Temperature (°F)	1,085	1,096	1,099	1,123	1,129
Moisture (% Vol.)	7.90	8.74	8.49	11.07	10.66
Oxygen (% Vol.)	12.50	12.38	12.46	11.94	12.08
Molecular Weight - calculated	28.44	28.35	28.38	28.09	28.13
- provided					
Volume Flow (acfm) = [(Mass Flow (lb/hr) x 1,545 x (Temp. (°F) + 460°F)] / [Molecular weight x 2116.8] / 60 min/hr					
Mass flow (lb/hr)	3,793,672	3,661,592	3,612,916	3,368,437	3,291,632
Temperature (°F)	1,085	1,096	1,099	1,123	1,129
Molecular weight	28.44	28.35	28.38	28.09	28.13
Volume flow (acfm)- calculated	2,506,572	2,445,344	2,414,762	2,309,422	2,261,718
- provided	2,522,120	2,460,472	2,429,695	2,323,628	2,275,619
	1.006	1.006	1.006	1.006	1.006
Fuel Usage					
Fuel usage (lb/hr) = Heat Input (MMBtu/hr) x 1,000,000 Btu/MMBtu (Fuel Heat Content, Btu/lb (LHV))					
Heat input (MMBtu/hr, LHV)	1,784	1,713	1,681	1,578	1,528
Heat content (Btu/lb, LHV)	20,981	20,981	20,981	20,981	20,981
Fuel usage (lb/hr)- calculated	85,048	81,641	80,129	75,192	72,815
- provided	85,050	81,640	80,130	75,190	72,810
Heat content (Btu/cf, LHV)- assumed	920	920	920	920	920
Fuel density (lb/ft³)	0.0438	0.0438	0.0438	0.0438	0.0438
Fuel usage (cf/hr)- calculated	1,939,563	1,861,858	1,827,375	1,714,785	1,660,584
Stack and Exit Gas Conditions- Simple Cycle					
Stack height (ft)	50	50	50	50	50
Diameter (ft)	19.0	19.0	19.0	19.0	19.0
Temperature (°F)	1,085	1,096	1,099	1,123	1,129
Velocity (ft/sec) = Volume flow (acfm) / [(diameter)² / 4] x 3.14159 / 60 sec/min					
Volume flow (acfm)	2,506,572	2,445,344	2,414,762	2,309,422	2,261,718
Diameter (ft)	19.0	19.0	19.0	19.0	19.0
Velocity (ft/sec)- calculated	147.3	143.7	141.9	135.8	133.0
Velocity (m/sec)- calculated	44.91	43.81	43.27	41.38	40.52

Source: Siemens-Westinghouse, 1999 (CTT-1914, Revision 1, 8/19/99).

Note: Universal gas constant = 1,545 ft-lb(force)/°R; atmospheric pressure = 2,116.8 lb(force)/ft²

Table A-2. Maximum Emissions for Criteria and Other Regulated Pollutants for the Palmetto Power L.L.C. Project- Simple Cycle Operation
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 100 % Load

Parameter	Ambient/Compressor Inlet Temperature				
	32 °F Case 1	59 °F Case 2	59 °F Case 3	95 °F Case 4	95 °F Case 5
Hours of Operation	3,750	3,750	3,750	3,750	3,750
Particulate (lb/hr) = Emission rate (lb/hr) from manufacturer (front-half)					
Basis, lb/hr (a)	8.6	8.2	8.2	7.5	7.3
Emission rate (lb/hr)- provided	8.6	8.2	8.2	7.5	7.3
(TPY)	16.1	15.5	15.3	14.0	13.7
Sulfur Dioxide (lb/hr) = Natural gas (cf/hr) x sulfur content(gr/100 cf) x 1 lb/7000 gr x (lb SO ₂ /lb S) /100					
Fuel use (cf/hr)	1,939,563	1,861,858	1,827,375	1,714,785	1,660,584
Sulfur content (grains/ 100 cf) - assumed (b)	1	1	1	1	1
lb SO ₂ /lb S (64/32)	2	2	2	2	2
Emission rate (lb/hr)- calculated	5.5	5.3	5.2	4.9	4.7
(lb/hr)- provided none	5.5	5.3	5.2	4.9	4.7
(TPY)	10.4	10.0	9.8	9.2	8.9
Nitrogen Oxides (lb/hr) = NOx(ppm) x ([20.9 x (1 - Moisture(%)/100)] - Oxygen(%)) x 2116.8 x Volume flow (acfm) x 46 (mole. wgt NOx) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 5.9 x 1,000,000 (adj. for ppm)]					
Basis, ppmvd @15% O ₂ (a)	15	15	15	15	15
Moisture (%)	7.90	8.74	8.49	11.07	10.66
Oxygen (%)	12.50	12.38	12.46	11.94	12.08
Volume Flow (acfm)	2,506,572	2,445,344	2,414,762	2,309,422	2,261,718
Temperature (°F)	1,085	1,096	1,099	1,123	1,129
Emission rate (lb/hr)- calculated	105.3	101.1	99.2	93.2	90.2
(lb/hr)- provided	111.2	106.8	104.8	98.4	95.3
(TPY)	208.6	200.2	196.5	184.5	178.6
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056	1.056	1.056
Carbon Monoxide (lb/hr) = CO(ppm) x ([20.9 x (1 - Moisture(%)/100)] - Oxygen(%)) x 2116.8 lb/ft ² x Volume flow (acfm) x 28 (mole. wgt CO) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 1,000,000 (adj. for ppm)]					
Basis, ppmvd (a)	31.1	31.1	30.9	31.7	31.3
Basis, ppmvd @ 15% O ₂ - calculated	22	22	22	21	21
- provided	25	25	25	25	25
Moisture (%)	7.90	8.74	8.49	11.07	10.66
Oxygen (%)	12.50	12.38	12.46	11.94	12.08
Volume Flow (acfm)	2,506,572	2,445,344	2,414,762	2,309,422	2,261,718
Temperature (°F)	1,085	1,096	1,099	1,123	1,129
Emission rate (lb/hr)- calculated from given ppmv	106.9	102.6	100.7	94.5	91.5
(lb/hr)- provided	113.0	109.0	107.0	100.0	97.0
(TPY)	211.9	204.4	200.6	187.5	181.9
[Ratio lb/hr provided/calculated]	1.057	1.063	1.063	1.058	1.060
VOCs (lb/hr) = VOC(ppm) x [1 - Moisture(%)/100] x 2116.8 lb/ft ² x Volume flow (acfm) x 16 (mole. wgt as methane) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 1,000,000 (adj. for ppm)]					
Basis, ppmvd (as CH ₄) (a)	1.8	1.8	1.8	1.8	1.8
Basis, ppmvd @ 15% O ₂ - calculated	1.3	1.2	1.3	1.2	1.2
- provided	1.5	1.5	1.5	1.5	1.5
Moisture (%)	7.90	8.74	8.49	11.07	10.66
Oxygen (%)	12.50	12.38	12.46	11.94	12.08
Volume Flow (acfm)	2,506,572	2,445,344	2,414,762	2,309,422	2,261,718
Temperature (°F)	1,085	1,096	1,099	1,123	1,129
Emission rate (lb/hr)- calculated	3.5	3.4	3.3	3.1	3.0
(lb/hr)- provided	3.7	3.6	3.5	3.3	3.2
(TPY)	7.0	6.7	6.6	6.2	6.0
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056	1.056	1.056
Lead (lb/hr) = NA					
Emission Rate Basis	NA	NA	NA	NA	NA
Emission rate (lb/hr)	NA	NA	NA	NA	NA
(TPY)	NA	NA	NA	NA	NA
Mercury (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu					
Basis, lb/10 ¹² Btu (c)	7.48E-04	7.48E-04	7.48E-04	7.48E-04	7.48E-04
Heat Input Rate (MMBtu/hr)	1.981	1.902	1.867	1.752	1.696
Emission Rate (lb/hr)	1.48E-06	1.42E-06	1.40E-06	1.31E-06	1.27E-06
(TPY)	2.78E-06	2.67E-06	2.62E-06	2.46E-06	2.38E-06
Sulfuric Acid Mist = Fuel Use (lb/hr) x sulfur (S) content (fraction) x conversion of S to H ₂ SO ₄ (%) x MW H ₂ SO ₄ /MW S (98/32)					
SO ₂ emission rate (lb/hr)	5.5	5.3	5.2	4.9	4.7
lb H ₂ SO ₄ /lb SO ₂ (98/64)	1.53	1.53	1.53	1.53	1.53
Conversion to H ₂ SO ₄ (%) (b)	10	10	10	10	10
Emission Rate (lb/hr)	0.85	0.81	0.80	0.75	0.73
(TPY)	1.59	1.53	1.50	1.41	1.36

Source: (a) Siemens-Westinghouse 1999; (b) Golder Associates, 1999; (c) EPA, 1996

Note: ppmvd = parts per million, volume dry; ppmvw = parts per million, volume wet; O₂ = oxygen.

Table A-3. Maximum Emissions for Other Regulated PSD Pollutants for the Palmetto Power L.L.C. Project- Simple Cycle Operation
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 100 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 1	59 °F Case 3	95 °F Case 5
Hours of Operation	3,750	3,750	3,750
$2,3,7,8 \text{ TCDD Equivalents (lb/hr)} = \text{Basis (lb/10}^{12} \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^{12} \text{ Btu}$			
Basis (a) , lb/10 ¹² Btu	1.20E-06	1.20E-06	1.20E-06
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	2.38E-09	2.24E-09	2.04E-09
(TPY)	4.46E-09	4.20E-09	3.82E-09
$\text{Beryllium (lb/hr)} = \text{Basis (lb/10}^{12} \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^{12} \text{ Btu}$			
Basis (a) , lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
$\text{Fluoride (lb/hr)} = \text{Basis (lb/10}^{12} \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^{12} \text{ Btu}$			
Basis, lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00

Sources: (a) Golder Associates, 1998

Note: No emission factors for hydrogen chloride (HCl) from natural gas-firing.

Table A-4. Maximum Emissions for Hazardous Air Pollutants for the Palmetto Power L.L.C. Project- Simple Cycle Operation
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 100 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 1	59 °F Case 3	95 °F Case 5
Hours of Operation	3,750	3,750	3,750
Antimony (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Benzene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0.8	0.8	0.8
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	1.59E-03	1.49E-03	1.36E-03
(TPY)	2.97E-03	2.80E-03	2.54E-03
Cadmium (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Chromium (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Formaldehyde (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	34	34	34
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	6.74E-02	6.35E-02	5.77E-02
(TPY)	1.26E-01	1.19E-01	1.08E-01
Cobalt (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Manganese (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Nickel (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Phosphorous (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (b), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Selenium (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Toluene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	10	10	10
Heat Input Rate (MMBtu/hr)	1,981	1,867	1,696
Emission Rate (lb/hr)	1.98E-02	1.87E-02	1.70E-02
(TPY)	3.72E-02	3.50E-02	3.18E-02

Sources: (a) Golder Associates, 1998; (b) EPA, 1996 (AP-42, Table 3.1-4)

Table A-5. Design Information and Stack Parameters for the Palmetto Power L.L.C. Project- Simple Cycle Operation
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 70 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 6	59 °F Case 7	95 °F Case 8
Combustion Turbine Performance			
Evaporative cooler status/ efficiency (%)	Off	Off	Off
Ambient Relative Humidity (%)	50	60	60
Gross power output (MW)	137.01	127.37	112.26
Gross heat rate (Btu/kWh, LHV)	9,650	9,855	10,370
(Btu/kWh, HHV)	10,715	10,940	11,510
Heat Input (MMBtu/hr, LHV)- calculated	1,322	1,255	1,164
- provided	1,322	1,255	1,164
(MMBtu/hr, HHV) - provided	1,468	1,394	1,292
(HHV/LHV)	1.110	1.110	1.110
Fuel heating value (Btu/lb, LHV)	20,981	20,981	20,981
(Btu/lb, HHV)	23,299	23,299	23,299
(HHV/LHV)	1.110	1.110	1.110
CT Exhaust Flow			
Mass Flow (lb/hr)	3,133,033	3,017,700	2,849,774
Temperature (°F)	1,026	1,041	1,064
Moisture (% Vol.)	7.19	7.76	9.84
Oxygen (% Vol.)	13.29	13.27	13.00
Molecular Weight - calculated	28.49	28.42	28.19
- provided			
Volume Flow (acfm) = [(Mass Flow (lb/hr) x 1,545 x (Temp. (°F) + 460°F)] / [Molecular weight x 2116.8] / 60 min/hr			
Mass flow (lb/hr)	3,133,033	3,017,700	2,849,774
Temperature (°F)	1,026	1,041	1,064
Molecular weight	28.49	28.42	28.19
Volume flow (acfm)- calculated	1,987,413	1,938,564	1,874,889
- provided	1,999,900	1,950,697	1,886,565
	1.006	1.006	1.006
Fuel Usage			
Fuel usage (lb/hr) = Heat Input (MMBtu/hr) x 1,000,000 Btu/MMBtu (Fuel Heat Content, Btu/lb (LHV))			
Heat input (MMBtu/hr, LHV)	1,322	1,255	1,164
Heat content (Btu/lb, LHV)	20,981	20,981	20,981
Fuel usage (lb/hr)- calculated	63,002	59,813	55,463
- provided	63,000	59,810	55,460
Heat content (Btu/cf, LHV)	920	920	920
Fuel density (lb/ft³)	0.0438	0.0438	0.0438
Fuel usage (cf/hr)- calculated	1,436,787	1,364,066	1,264,859
Stack and Exit Gas Conditions- Simple Cycle			
Stack height (ft)	50	50	50
Diameter (ft)	19.0	19.0	19.0
Temperature (°F)	1,026	1,041	1,064
Velocity (ft/sec) = Volume flow (acfm) / [((diameter)² / 4) x 3.14159] / 60 sec/min			
Volume flow (acfm)	1,987,413	1,938,564	1,874,889
Diameter (ft)	19.0	19.0	19.0
Velocity (ft/sec)- calculated	116.8	114.0	110.2
Velocity (m/sec)- calculated	35.61	34.73	33.59

Source: Siemens-Westinghouse, 1999 (CTT-1914, Revision 1, 8/19/99).

Note: Universal gas constant = 1,545 ft-lb(force)/°R; atmospheric pressure = 2,116.8 lb(force)/ft²

Table A-6. Maximum Emissions for Criteria and Other Regulated Pollutants for the Palmetto Power L.L.C. Project- Simple Cycle Operation
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 70 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 6	59 °F Case 7	95 °F Case 8
Hours of Operation	3,750	3,750	3,750
Particulate (lb/hr) = Emission rate (lb/hr) from manufacturer (front-half)			
Basis, lb/hr (a)	7.1	6.9	6.4
Emission rate (lb/hr)- provided	7.1	6.9	6.4
(TPY)	13.4	12.8	12.0
Sulfur Dioxide (lb/hr) = Natural gas (cf/hr) x sulfur content (gr/100 cf) x 1 lb/7000 gr x (lb SO ₂ /lb S) /100			
Fuel use (cf/hr)	1,436,787	1,364,066	1,264,859
Sulfur content (grains/ 100 cf) - assumed (b)	1	1	1
lb SO ₂ /lb S (64/32)	2	2	2
Emission rate (lb/hr)- calculated	4.1	3.9	3.6
(lb/hr)- none provided	4.1	3.9	3.6
(TPY)	7.7	7.3	6.8
Nitrogen Oxides (lb/hr) = NOx(ppm) x {[20.9 x (1 - Moisture(%)/100)] - Oxygen(%)} x 2116.8 x Volume flow (acfm) x 46 (mole. wgt NOx) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 1,000,000 (adj. for ppm)]			
Basis, ppmvd @15% O ₂ (a)	15	15	15
Moisture (%)	7.19	7.76	9.84
Oxygen (%)	13.29	13.27	13.00
Volume Flow (acfm)	1,987,413	1,938,564	1,874,889
Temperature (°F)	1,026	1,041	1,064
Emission rate (lb/hr)- calculated	78.6	74.6	69.1
(lb/hr)- provided	83.0	78.8	72.9
(TPY)	155.6	147.7	136.8
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056
Carbon Monoxide (lb/hr) = CO(ppm) x {[20.9 x (1 - Moisture(%)/100)] - Oxygen(%)} x 2116.8 lb/ft ² x Volume flow (acfm) x 28 (mole. wgt CO) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 1,000,000 (adj. for ppm)]			
Basis, ppmvd (a)	27.9	27.6	27.5
Basis, ppmvd @ 15% O ₂ - calculated	22	21	21
- provided	25	25	25
Moisture (%)	7.19	7.76	9.84
Oxygen (%)	13.29	13.27	13.00
Volume Flow (acfm)	1,987,413	1,938,564	1,874,889
Temperature (°F)	1,026	1,041	1,064
Emission rate (lb/hr)- calculated from given ppmv	79.7	75.7	70.1
(lb/hr)- provided	85.0	80.0	74.0
(TPY)	159.4	150.0	138.8
[Ratio lb/hr provided/calculated]	1.066	1.057	1.056
VOCs (lb/hr) = VOC(ppm) x [1 - Moisture(%)/100] x 2116.8 lb/ft ² x Volume flow (acfm) x 16 (mole. wgt as methane) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 1,000,000 (adj. for ppm)]			
Basis, ppmvd (as CH ₄) (a)	1.6	1.6	1.6
Basis, ppmvd @ 15% O ₂ - calculated	1.3	1.2	1.2
- provided	1.5	1.5	1.5
Moisture (%)	7.19	7.76	9.84
Oxygen (%)	13.29	13.27	13.00
Volume Flow (acfm)	1,987,413	1,938,564	1,874,889
Temperature (°F)	1,026	1,041	1,064
Emission rate (lb/hr)- calculated	2.6	2.5	2.3
(lb/hr)- provided	2.8	2.6	2.5
(TPY)	5.2	5.0	4.6
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056
Lead (lb/hr) = NA			
Emission Rate Basis	NA	NA	NA
Emission rate (lb/hr)	NA	NA	NA
(TPY)	NA	NA	NA
Mercury (lb/hr) = Basis (lb/10 ¹³ Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹³ Btu			
Basis, lb/10 ¹³ Btu (c)	7.48E-04	7.48E-04	7.48E-04
Heat Input Rate (MMBtu/hr)	1.468	1.394	1.292
Emission Rate (lb/hr)	1.10E-06	1.04E-06	9.67E-07
(TPY)	2.06E-06	1.95E-06	1.81E-06
Sulfuric Acid Mist = Fuel Use (lb/hr) x sulfur (S) content (fraction) x conversion of S to H ₂ SO ₄ (%) x MW H ₂ SO ₄ /MW S (98/32)			
SO ₂ emission rate (lb/hr)	4.1	3.9	3.6
lb H ₂ SO ₄ /lb SO ₂ (98/64)	1.53	1.53	1.53
Conversion to H ₂ SO ₄ (%) (b)	10	10	10
Emission Rate (lb/hr)	0.63	0.60	0.55
(TPY)	1.18	1.12	1.04

Source: (a) Siemens-Westinghouse 1999; (b) Golder Associates, 1999; (c) EPA, 1996

Note: ppmvd = parts per million, volume dry; ppmvw = parts per million, volume wet; O₂ = oxygen.

Table A-7. Maximum Emissions for Other Regulated PSD Pollutants for the Palmetto Power L.L.C. Project- Simple Cycle Operation
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 70 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 6	59 °F Case 7	95 °F Case 8
Hours of Operation	3,750	3,750	3,750
$2,3,7,8 \text{ TCDD Equivalents (lb/hr)} = \text{Basis (lb/10}^{12} \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^{12} \text{ Btu}$			
Basis (a) , lb/10 ¹² Btu	1.20E-06	1.20E-06	1.20E-06
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	1.76E-09	1.67E-09	1.55E-09
(TPY)	3.30E-09	3.14E-09	2.91E-09
$\text{Beryllium (lb/hr)} = \text{Basis (lb/10}^{12} \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^{12} \text{ Btu}$			
Basis (a) , lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
$\text{Fluoride (lb/hr)} = \text{Basis (lb/10}^{12} \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^{12} \text{ Btu}$			
Basis, lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00

Sources: (a) Golder Associates, 1998

Note: No emission factors for hydrogen chloride (HCl) from natural gas-firing.

Table A-8. Maximum Emissions for Hazardous Air Pollutants for the Palmetto Power L.L.C. Project- Simple Cycle Operation
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 70 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 6	59 °F Case 7	95 °F Case 8
Hours of Operation	3,750	3,750	3,750
Antimony (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Benzene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0.8	0.8	0.8
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	1.17E-03	1.11E-03	1.03E-03
(TPY)	2.20E-03	2.09E-03	1.94E-03
Cadmium (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Chromium (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Formaldehyde (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	34	34	34
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	4.99E-02	4.74E-02	4.39E-02
(TPY)	9.36E-02	8.88E-02	8.24E-02
Cobalt (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Manganese (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Nickel (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Phosphorous (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (b), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Selenium (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	0	0	0
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	0.00E+00	0.00E+00	0.00E+00
(TPY)	0.00E+00	0.00E+00	0.00E+00
Toluene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis (a), lb/10 ¹² Btu	10	10	10
Heat Input Rate (MMBtu/hr)	1,468	1,394	1,292
Emission Rate (lb/hr)	1.47E-02	1.39E-02	1.29E-02
(TPY)	2.75E-02	2.61E-02	2.42E-02

Sources: (a) Golder Associates, 1998; (b) EPA, 1996 (AP-42, Table 3.1-4)

APPENDIX B

**BEST AVAILABLE CONTROL TECHNOLOGY FOR
THE PROPOSED COMBUSTION TURBINES**

B.1 NEW SOURCE PERFORMANCE STANDARDS

The NSPS regulations (40 CFR, Subpart GG) applicable to gas turbines apply to:

1. Electric utility stationary gas turbines with a heat input at peak load of greater than 100×10^6 Btu/hr [40 CFR 60.332 (b)];
2. Stationary gas turbines with a heat input at peak load between 10 and 100×10^6 Btu/hr [40 CFR 60.332 (c)]; or
3. Stationary gas turbines with a manufacturer's rate base load at ISO conditions of 30 MW or less [40 CFR 60.332 (d)] except as provided in Section 60.322(b) shall comply with paragraph (a)(2) of this section.

The electric utility stationary gas turbine provisions apply to stationary gas turbines constructed for the purpose of supplying more than one-third of their potential electric output capacity for sale to any utility power distribution system [40 CFR 60.331 (q)]. The requirements for electric utility stationary gas turbines are applicable to the 501F class turbines proposed for the project and are the most stringent provision of the NSPS. These requirements are summarized in Table B-1 and were considered in the BACT analysis.

As noted from Table B-1, the NSPS NO_x emission limit can be adjusted upward to allow for fuel-bound nitrogen (FBN). For a fuel-bound nitrogen concentration of 0.015 percent or less, no increase in the NSPS is provided; for a fuel-bound nitrogen concentration of 0.03 percent, the NSPS is increased by 0.0012 percent or 12 parts per million (ppm). The NSPS NO_x emission limit adjustment is not affected by natural gas combustion.

B.2 BEST AVAILABLE CONTROL TECHNOLOGY

B.2.1 NITROGEN OXIDES

Advanced dry low- NO_x combustion alone has increasingly been approved by regulatory agencies as BACT and is technically feasible for the proposed project. Available information suggests that "hot" SCR with dry low- NO_x combustor technology or with wet injection is also available for some smaller size turbines. However, this technology has not been commercially demonstrated or made available for the F Class turbine.

Identification of NO_x Control Technologies

NO_x emissions from combustion of fossil fuels consist of thermal NO_x and fuel-bound NO_x. Thermal NO_x is formed from the reaction of oxygen and nitrogen in the combustion air at combustion temperatures. Formation of thermal NO_x depends on the flame temperature, residence time, combustion pressure, and air-to-fuel ratios in the primary combustion zone. The design and operation of the combustion chamber dictates these conditions. Fuel-bound NO_x is created by the oxidation of volatilized nitrogen in the fuel. Nitrogen content in the fuel is the primary factor in its formation.

Table B-2 presents a listing of the lowest achievable emission rates/best available control technology (LAER/BACT) decisions made by state environmental agencies and EPA regional offices for gas turbines. This table was developed from the information obtained from BACT/LAER Information System (BLIS) database maintained at EPA's National Computer Center located at Research Triangle Park, North Carolina.

Historically, the most stringent NO_x controls for CTs established as LAER/BACT by state agencies were selective catalytic reduction (SCR) with wet injection and wet injection alone. When SCR has been employed, wet injection is used initially to reduce NO_x emissions. However, advanced dry low-NO_x technology has only recently been developed and made available for gas turbines. SCR is a post-combustion control, while advanced dry low-NO_x combustors minimize the formation of NO_x in the combustion process.

SCR has been installed or permitted in over 100 projects. The majority of these projects (more than 90 percent) are cogeneration facilities with capacities of 50 MW or less. About 80 percent of the projects have been in California. A majority of projects are for SCR installed in the heat-recovery steam generator (HRSG). Only 3 simple cycle projects with SCR have been constructed. Of these projects that have either installed SCR or have been permitted with SCR, many have been in the Southern California NO₂ nonattainment area where SCR was required not as BACT but as LAER, a more stringent requirement. LAER is distinctly different from BACT in that there is no consideration of economic, energy, or

environmental impacts; if a control technology has previously been installed, it must be required as LAER. LAER is defined as follows:

Lowest achievable emission rate means, for any source, the more stringent rate of emissions based on the following: (i) The most stringent emissions limitation which is contained in the implementation plan of any State of such class or category of stationary source, unless the owner or operator of the proposed stationary source demonstrates that such limitations are not achievable; or (ii) The most stringent emissions limitation which is achieved in practice by such class or category of stationary source. This limitation, when applied to a modification, means the lowest achievable emissions rate for the new or modified emissions units within the stationary source. In no event shall the application of this term permit a proposed new modified stationary source to emit any pollutant in excess of the amount allowable under applicable new source standards of performance (40 CFR 51, Appendix S.II, A.18).

As noted previously, there are distinct regulatory and policy differences between LAER and BACT.

As discussed in Section 3.0, BACT involves an evaluation of the economic, environmental, and energy impacts of alternative control technologies. In contrast, LAER only considers the technical aspects of control.

All the projects in California have natural gas as the primary fuel, and less than 15 percent of the SCR applications in California have distillate fuel as backup.

The other group of projects with SCR are located in the eastern United States. These projects are located in Vermont, Massachusetts, Connecticut, New Jersey, New York, Rhode Island, and Virginia. A majority of these projects are cogenerators or independent power producers. The size of these projects ranges from 22 MW to 450 MW, with nearly 90 percent less than 100 MW in size. While almost all of the facilities have distillate oil as backup fuel, distillate oil generally is restricted by permit to 1,000 hours or less per CT. Also, none of these projects included SCR for CTs with simple cycle operations.

Reported and permitted NO_x removal efficiencies of SCR range from 40 to 80 percent of NO_x in the exhaust gas stream. The most common emission limiting standards associated with SCR are approximately 9 ppm for natural gas firing. However, a few facilities have reported emission limits of about 3.5 ppm.

Wet injection historically has been the primary method of reducing NO_x emissions from CTs. Indeed, this method of control was first mandated by the NSPS to reduce NO_x levels to 75 parts per million by volume, dry (ppmvd) (corrected to 15 percent O₂ and heat rate). Development of improved wet injection combustors reduced NO_x concentrations to 25 ppmvd (corrected to 15 percent O₂) when burning natural gas. More recently, however, CT manufacturers have developed dry low-NO_x combustors that can reduce NO_x concentrations to 15 ppmvd (corrected to 15 percent O₂) or less when firing natural gas.

Technology Description and Feasibility

Wet Injection

The injection of water or steam in the combustion zone of CTs reduces the flame temperature with a corresponding decrease of NO_x emissions. The amount of NO_x reduction possible depends on the combustor design and the water-to-fuel ratio employed. An increase in the water-to-fuel ratio will cause a concomitant decrease in NO_x emissions until flame instability occurs. At this point, operation of the CT becomes inefficient and unreliable, and significant increases in products of incomplete combustion results (i.e., CO and VOC emissions). In "F" Class turbines using wet injection with gas firing, the NO_x emission rates in the 30 ppm range have been demonstrated. However, wet injection is no longer offered for gas firing in "F" Class turbine. Wet injection is the only current feasible means of reducing NO_x emissions in the combustion process when firing oil.



Dry Low-NO_x Combustor

In the past several years, CT manufacturers have offered and installed machines with dry low-NO_x combustors. These combustors, which are offered on conventional machines manufactured by Westinghouse, GE, Kraftwerk Union, and ABB, can achieve NO_x concentrations of 25 ppmvd or less when firing natural gas. Westinghouse and GE have offered dry low-NO_x combustors on advanced heavy-duty industrial machines. Thermal

NO_x formation is inhibited by using combustion techniques where the natural gas and combustion air are premixed before ignition. For the CT being considered for the project, the combustion chamber design includes the use of dry low-NO_x combustor technology. The NO_x emission level when firing natural gas at baseload conditions is 15 ppmvd (corrected to 15 percent O₂), a level which is guaranteed by the selected vendor (Westinghouse or equivalent) for the project.

Selective Catalytic Reduction

Selective Catalytic Reduction (SCR) uses ammonia (NH₃) to react with NO_x in the gas stream in the presence of a catalyst. NH₃, which is diluted with air to about 5 percent by volume, is introduced into the gas stream at reaction temperatures between 600°F and 750°F. The reactions are as follows:



SCR operating experience, as applied to gas turbines, consists primarily of baseload natural-gas-fired installations either of cogeneration or combined cycle configuration; no simple cycle facilities have SCR. Exhaust gas temperatures of simple cycle CTs generally are in the range of 1,000°F, which exceeds the optimum range for SCR with base metal catalysts. All current SCR applications have the catalyst placed in the HRSG to achieve proper reaction conditions. This allows a relatively constant temperature for the reaction of NH₃ and NO_x on the catalyst surface.

The use of SCR has been primarily limited to combined-cycle facilities that burn natural gas with small amounts of fuel oil, since SCR catalysts are contaminated by sulfur-containing fuels. For most fuel-oil-burning facilities, catalyst operation is discontinued, or the exhaust bypasses the SCR system. While the operating experience with SCR has not been extensive, certain cost, technical, and environmental considerations have surfaced for units firing both natural gas and oil while using SCR.

Ammonium salts (ammonium sulfate and bisulfate) are formed by the reaction of NH₃ and sulfur combustion products. Ammonium bisulfate can be corrosive and could cause damage to the HRSG surfaces that follow the catalyst, as well as to the stack. Corrosion protection

for these areas would be required with concomitant cost and technical requirements. Ammonium sulfate is emitted as particulate matter. While the formation of ammonium salts is primarily associated with oil firing, sulfur combustion products from natural gas also could form small amounts of ammonium salts.

Zeolite and specially designed high temperature catalysts, which are reported to be capable of withstanding temperature ranges up to 1,100°F, have become available commercially only recently in smaller size units. Their application with SCR primarily has been limited to internal combustion engines. Optimum performance of an SCR system using a zeolite catalyst is reported to range from about 800°F to 900°F. At temperatures of 1,100°F and above, the high-temperature catalyst will be irreparably damaged.

In the 1990s there are four simple cycle combustion turbine projects that have installed SCR with operating experience. These projects are:

- Redding Municipal Power – 3 GE Frame 5 CTs fired with natural gas. The CTs are operated as a peaking facility.
- SoCal Gas Company – 4 Solar Centaur CTs (4MW equivalent each) fired with natural gas. The CTs are operated in intermediate cycling duty.
- UnoCal Brea Research Center – a single 4 MW CT firing natural gas. The CT operates in intermediate to base load duty.
- Puerto Rico Electric Power Authority (Cambalache Facility) – 3 ABB Type 11 N (83 MW each) firing No. 2 distillate oil.

The SCRs for all these CTs were designed to operate at temperatures less than 1,000°F. Many of the smaller CTs have exhaust temperatures less than 1,000°F. The Cambalache Facility had a once through steam generator in the ductwork leading to SCR used for power augmentation that reduced the catalyst temperature to less than 1,000°F. Experience on these systems has shown significant catalyst deactivation occurs with peaking and intermediate cycling duty while firing natural gas. Under these conditions catalyst deactivation has occurred after operating from 350 to 4,000 hours. For intermediate-base load duty and firing natural gas, catalyst deactivation improved but still occurred after 8,000 hour of operation and well less the catalyst guarantee. When firing distillate oil,

catalyst deactivation occurred after 600 hours. Due to the problems with oil firing, the SCR system for the Cambalache Facility has been removed. This experience suggests that SCR for simple cycle CTs while available from vendors has not been demonstrated as feasible.

SCONO_xTM Process

SCONO_xTM is a NO_x and CO control system exclusively offered by Goal Line Environmental Technologies (GLET). GLET is a partnership formed by Sunlaw Energy Corporation and Advanced Catalyst Systems, Inc.

The SCONO_xTM system employs a single catalyst to simultaneously oxidize CO to CO₂ and NO to NO₂. NO₂ formed by the oxidation of NO is subsequently absorbed onto the catalyst surface through the use of a potassium carbonate absorber coating. The SCONO_xTM oxidation/absorption cycle reactions are:



CO₂ produced by reaction (1) and (2) is released to the atmosphere as part of the CT/HRSG exhaust gas stream.



As shown in Reaction (3), the potassium carbonate catalyst coating reacts with NO₂ to form potassium nitrites and nitrates. Prior to saturation of the potassium carbonate coating, the catalyst must be regenerated. This regeneration is accomplished by passing a dilute hydrogen-reducing gas across the surface of the catalyst in the absence of O₂. Hydrogen in the reducing gas reacts with the nitrites and nitrates to form water and elemental nitrogen. CO₂ in the regeneration gas reacts with potassium nitrites and nitrates to form potassium carbonate; this compound is the catalyst absorber coating present on the surface of the catalyst at the start of the oxidation/absorption cycle. The SCONO_xTM regeneration cycle reaction is:



Water vapor and elemental nitrogen are released to the atmosphere as part of the CT/HRSG exhaust stream. Following regeneration, the $\text{SCONO}_x^{\text{TM}}$ catalyst has a fresh coating of potassium carbonate, allowing the oxidation/absorption cycle to begin again. There is no net gain or loss of potassium carbonate after both the oxidation/absorption and regeneration cycles have been completed.

Since the regeneration cycle must take place in an oxygen-free environment, the section of catalyst undergoing regeneration is isolated from the exhaust gas stream using a set of louvers. Each catalyst section is equipped with a set of upstream and downstream louvers. During the regeneration cycle, these louvers close and valves open allowing fresh regeneration gas to enter and spent regeneration gas to exit the catalyst section being regenerated. At any given time, 75 percent of the catalyst sections will be in the oxidation/absorption cycle, while 25 percent will be in regeneration mode. A regeneration cycle is typically set to last for 3 to 5 minutes.



Regeneration gas is produced by reacting natural gas with O_2 present in ambient air. The $\text{SCONO}_x^{\text{TM}}$ system uses a gas generator produced by Surface Combustion. This unit uses a two-stage process to produce hydrogen and carbon dioxide. In the first stage, natural gas and ambient air are reacted across a partial oxidation catalyst at $1,900^\circ\text{F}$ to form CO and hydrogen. Steam is added and the gas mixture is then passed across a low temperature shift catalyst, forming CO_2 and additional hydrogen. The resulting gas stream is diluted to less than 4 percent hydrogen using steam or another inert gas. The regeneration gas reactions are:



The $\text{SCONO}_x^{\text{TM}}$ operates at a temperature range of 300 to 700°F and, therefore, must be installed in the appropriate temperature section of a HRSG. For $\text{SCONO}_x^{\text{TM}}$ systems installed in locations of the HRSG above 500°F , a separate regeneration gas generator is not required.

Instead, regeneration gas is produced by introducing natural gas directly across the $\text{SCONO}_x^{\text{TM}}$ catalyst that reforms the natural gas.

The $\text{SCONO}_x^{\text{TM}}$ system catalyst is subject to reduced performance and deactivation due to exposure to sulfur oxides. For this reason, an additional catalytic oxidation/absorption system ($\text{SCONO}_x^{\text{TM}}$) to remove sulfur compounds is installed upstream of the $\text{SCONO}_x^{\text{TM}}$ catalyst. During regeneration of the $\text{SCONO}_x^{\text{TM}}$ catalyst, either hydrogen sulfide or SO_2 is released to the atmosphere as part of the CT/HRSG exhaust gas stream. The absorption portion of the $\text{SCONO}_x^{\text{TM}}$ process is proprietary. $\text{SCONO}_x^{\text{TM}}$ oxidation/absorption and regeneration reactions are:



Utility materials needed for the operation of the $\text{SCONO}_x^{\text{TM}}$ control system include ambient air, natural gas, water, steam, and electricity. The primary utility material is natural gas used for regeneration gas production. Steam is used as the carrier/dilution gas for the regeneration gas. Electricity is required to operate the computer control system, control valves, and louver actuators.


Commercial experience to date with the $\text{SCONO}_x^{\text{TM}}$ control system is limited to one small combined cycle (CC) power plant located in Los Angeles. This power plant, owned by GLET partner Sunlaw Energy Corporation, utilizes a GE LM2500 turbine (30 MW size) equipped with water injection to control NO_x emissions to approximately 25 ppmvd. The $\text{SCONO}_x^{\text{TM}}$ control system was installed at the Sunlaw Energy facility in December 1996 and has achieved a NO_x exhaust concentration of 3.5 ppmv resulting in an approximate 85 percent NO_x removal efficiency.

The $\text{SCONO}_x^{\text{TM}}$ control technology is not considered to be technically feasible because it has not been commercially demonstrated on large CTs. The CTs planned for the project,

Westinghouse 501 F units, each have a nominal generating capacity of 180 MW which are approximately six times larger than the nominal 25-MW GE LM2500 utilized at the Sunlaw Energy Corporation Los Angeles facility. Technical problems associated with scale-up of the SCONO_xTM technology given the large differences in machine flow rates are unknown. Additional concerns with the SCONO_xTM control technology include process complexity (multiple catalytic oxidation / absorption / regeneration systems), reliance on only one supplier, and the relatively brief (approximately 18 months) operating history of the technology.

NO_xOUT Process

The NO_xOUT process originated from the initial research by the Electric Power Research Institute (EPRI) in 1976 on the use of urea to reduce NO_x. EPRI licensed the proprietary process to Fuel Tech, Inc., for commercialization. In the NO_xOUT process, aqueous urea is injected into the flue gas stream ideally within a temperature range of 1,600°F to 1,900°F. In the presence of oxygen, the following reaction results:



The amount of urea required is most cost-effective when the treatment rate is 0.5 to 2 moles of urea per mole of NO_x. In addition to the original EPRI urea patents, Fuel Tech claims to have a number of proprietary catalysts capable of expanding the effective temperature range of the reaction to between 1,600°F and 1,950°F. Advantages of the system are as follows:

1. Low capital and operating costs as a result of use of urea injection, and
2. The proprietary catalysts used are nontoxic and nonhazardous, thus eliminating potential disposal problems.

Disadvantages of the system are as follows:

1. Formation of ammonia from excess urea treatment rates and/or improper use of reagent catalysts, and
2. Sulfur trioxide (SO₃), if present, will react with ammonia created from the urea to form ammonium bisulfate, potentially plugging the cold end equipment downstream.

Commercial application of the NO_xOUT system is limited and the NO_xOUT system has not been demonstrated on any combustion turbine/HRSG unit.

The NO_xOUT process is not technically feasible for the proposed project because of the high application temperature of 1,600°F to 1,950°F. The maximum exhaust gas temperature of the 501F CT is about 1,000°F. Raising the exhaust temperature the required amount essentially would require installation of a heater. This would be economically prohibitive and would result in an increase in fuel consumption, an increase in the volume of gases that must be treated by the control system, and an increase in uncontrolled air emissions, including NO_x.

Thermal DeNO_x

Thermal DeNO_x is Exxon Research and Engineering Company's patented process for NO_x reduction. The process is a high temperature selective noncatalytic reduction (SNCR) of NO_x using ammonia as the reducing agent. Thermal DeNO_x requires the exhaust gas temperature to be above 1,800°F. However, use of ammonia plus hydrogen lowers the temperature requirement to about 1,000°F. For some applications, this must be achieved by additional firing in the exhaust stream before ammonia injection.

The only known commercial applications of Thermal DeNO_x are on heavy industrial boilers, large furnaces, and incinerators that consistently produce exhaust gas temperatures above 1,800°F. There are no known applications on or experience with CTs. Temperatures of 1,800°F require alloy materials constructed with very large piping and components since the exhaust gas volume would be increased by several times. As with the NO_xOUT process, high capital, operating, and maintenance costs are expected because of material requirements, an additional duct burner system, and fuel consumption. Uncontrolled emissions would increase because of the additional fuel burning.

Thus, the Thermal DeNO_x process will not be considered for the proposed project since its high application temperature makes it technically infeasible. The maximum exhaust gas temperature of a 501 F combustion turbine is typically 1,100°F; the cost to raise the exhaust gas to such a high temperature is prohibitively expensive.

Nonselective Catalytic Reduction

Certain manufacturers, such as Engelhard, market a nonselective catalytic reduction system (NSCR) for NO_x control on reciprocating engines. The NSCR process requires a low oxygen content in the exhaust gas stream and high temperature (700°F to 1,400°F) in order to be effective. CTs have the required temperature but also have high oxygen levels (greater than 12 percent) and, therefore, cannot use the NSCR process. As a result, NSCR is not a technically feasible add-on NO_x control device for CTs.

Technology Demonstration and Feasibility

The technical evaluation of post-combustion gas controls that include NO_xOUT, Thermal DeNO_x, NSCR, and SCONO™ indicate that these processes have not been applied to simple-cycle turbines and are technically infeasible for the project because of process constraints (e.g., temperature). While high-temperature SCR is feasible, it has not been demonstrated on simple-cycle "F" class turbines in peaking service. Wet injection cannot achieve emission rates lower than 25 ppm when firing natural gas in an "F" Class machine and is not offered by the preferred vendor.

For the BACT analysis, dry low-NO_x combustion technology is technically feasible when firing natural gas and SCR in combination with combustion controls is a potentially feasible alternative that can achieve a maximum degree of emission reduction. The advanced dry low-NO_x combustor alone can achieve 15 ppm (corrected) and the SCR with dry low-NO_x combustor is capable of achieving a NO_x emission level of 9 ppm when firing natural gas (corrected to 15 percent O₂ dry conditions).

Below is a summary of the technical demonstration and feasibility for the proposed Palmetto Power project.

Technology

Dry Low-NO_x Combustors
 Wet Injection
 Selective Catalytic Reduction

Thermal De NO_x
 NO_x Out
 SCO NO_x
 NSCR

Simple Cycle

Demonstrated and Feasible – Gas Firing
 Not Feasible/Available – Gas Firing
 Not Demonstrated on "F" Class turbines in
 peaking service
 Not Feasible
 Not Feasible
 Not Feasible
 Not Feasible

SCR Cost Estimates

Tables B-3 and B-4 present the total capital and annualized cost for SCR applied to simple cycle operation, respectively. The costs were developed using EPA Cost Control Manual (EPA, 1990 & 1993). Vendor based estimates were used for the SCR system. Standard EPA recommended cost factors were used. A capital recovery period of 15 years was used for the capital costs and 3 years for the reoccurring capital costs (i.e., catalyst). SCR system in simple-cycle operation would be subjected to temperatures exceeding 1,000°F where considerable wear can take place resulting in lower life of equipment. Capital recovery periods in this case may be much lower.

B.2.2 Carbon Monoxide**Identification of CO Control Technologies**

CO emissions are a result of incomplete or partial combustion of fossil fuel. Combustion design and catalytic oxidation are the control alternatives that are viable for the project. Table B-5 presents a listing of LAER/BACT decisions for CO emissions from combustion turbines. Combustion design is the more common control technique used in CTs. Sufficient time, temperature, and turbulence is required within the combustion zone to maximize combustion efficiency and minimize the emissions of CO. Combustion efficiency is dependent upon combustor design. For the CTs being evaluated, CO emissions will not exceed 25 ppmvd, corrected to 15 percent O₂, dry conditions when firing natural gas under full load conditions.

Catalytic oxidation is a post-combustion control that has been employed in CO nonattainment areas where regulations have required CO emission levels to be less than

those associated with wet injection. These installations have been required to use LAER technology and typically have CO limits in the 10 ppm range (corrected to dry conditions).

Technology Description

In an oxidation catalyst control system, CO emissions are reduced by allowing unburned CO to react with oxygen at the surface of a precious metal catalyst, such as platinum. Combustion of CO starts at about 300°F, with efficiencies above 90 percent occurring at temperatures above 600°F. Catalytic oxidation occurs at temperatures 50 percent lower than that of thermal oxidation, which reduces the amount of thermal energy required.

For CTs, the oxidation catalyst can be located directly after the CT. Catalyst size depends upon the exhaust flow, temperature, and desired efficiency. The existing oxidation catalyst applications primarily have been limited to smaller cogeneration facilities burning natural gas. Oxidation catalysts have not been used on fuel-oil-fired CTs or combined cycle facilities. The use of sulfur-containing fuels in an oxidation catalyst system would result in an increase of SO₃ emissions and concomitant corrosive effects to the stack. In addition, trace metals in the fuel could result in catalyst poisoning during prolonged periods of operation.

Since the units likely will require numerous startups, during simple-cycle operation, variations in exhaust conditions will influence catalyst life and performance. Very little technical data exist to demonstrate the effect of such cycling.

Oxidation Catalyst Costs

Tables B-6 and B-7 present the capital and annualized cost for an oxidation catalyst applied to simple cycle operation. The maximum CO impacts are less than 0.1 percent of the applicable ambient air quality standards. There would also be no secondary benefits, such as reducing acidic deposition, to reducing CO.

Table B-1. Federal NSPS for Electric Utility Stationary Gas Turbines

Pollutant	Emission Limitation ^a
Nitrogen Oxides ^b	0.0075 percent by volume (75 ppm) at 15 percent O ₂ on a dry basis adjusted for heat rate and fuel nitrogen
^a Applicable to electric utility gas turbines with a heat input at peak load of greater than 100 x 10 ⁶ Btu/hr. ^b Standard is multiplied by 14.4/Y; where Y is the manufacturer's rated heat rate in kilojoules per watt at rated load or actual measured heat rate based on the lower heating value of fuel measured at actual peak load; Y cannot be greater than 14.4. Standard is adjusted upward (additive) by the percent of nitrogen in the fuel:	
Fuel-Bound Nitrogen (percent by weight)	Allowed Increase NO _x Percent by Volume
N ≤ 0.015	0
0.015 < N ≤ 0.1	0.04(N)
0.1 < N ≤ 0.25	0.004 + 0.0067(N - 0.1)
N > 0.25	0.005

where: N = the nitrogen content of the fuel (percent by weight).

Source: 40 CFR 60 Subpart GG.

Table B-2. Summary of Best Available Control Technology (BACT) Determinations for Nitrogen Oxide (NOx) Emissions

Facility Name	State	Permit Issue Date	Unit/Process Description	Capacity (size)	NOx Emission Limit	Control Method	Efficiency (%)	Type
WYANDOTTE ENERGY	MI	Feb-99	TURBINE, COMBINED CYCLE, POWER PLANT	500 MW	4.5 PPM	SCR & DLN COMBUSTORS DURING GAS FIRING. STEAMWATER INJECTION DURING OIL FIRING	70	BACT
MOBILE ENERGY LLC	AL	Jan-99	TURBINE, GAS, COMBINED CYCLE	188 MW	0.019 LB/MMBTU	15 PPMV ABOVE 70% LOAD	0	BACT-PSD
CLARKSPRING UTILITIES	CO	Jan-99	TURBINE, COMBINE, NATURAL GAS FIRED	30 MW EACH	15 PPMV @ 15% O2	POLLUTION PREVENTION DUCT INTO EQUIPMENT.	0	BACT-PSD
TENUSKA GEORGIA PARTNERS, L.P.	GA	Dec-98	TURBINE, COMBUSTION, SIMPLE CYCLE, 8	180 MW EA	15 PPMV @ 15% O2	USING 15% EXCESS AIR, NOX EMISSION IS BECAUSE OF NAT. GAS.	0	BACT-PSD
TENUSKA GEORGIA PARTNERS, L.P.	GA	Dec-98	TURBINE, COMBUSTION, SIMPLE CYCLE, 8	180 MW EA	42 PPMV @ 15% O2	USING 15% EXCESS AIR, NOX EMISSION IS BECAUSE OF FUEL OIL.	0	BACT-PSD
SANTA ROSA ENERGY LLC	FL	Dec-98	TURBINE, COMBUSTION, NATURAL GAS	241 MW	9.8 PPM @ 15%O2 DE OX	DRY LOW NOX BURNER	0	BACT-PSD
CITY OF LOMPOC (PORTABLE TURBINDER IC ENGINE)	CA	Dec-98	IC ENGINE, DIESEL-FIRED, PORTABLE 480 BHP, CATERP	480 BHP	580 PPMV @ 15% O2	DIRECT INJECTION, TURBOCHARGED, INTAKE INTERCOOLER	0	BACT-OTHER
LSP - COTTAGE GROVE, L.P.	MN	Nov-98	ENGINE, DIESEL, EMERGENCY FIRE PUMP	2.7 MMBTU/H	1.85 LB/MMBTU	LIMITED TO BURN DIESEL 150 MYR/L	0	BACT-PSD
LSP - COTTAGE GROVE, L.P.	MN	Nov-98	GENERATOR, COMBUSTION TURBINE & DUCT BURNER	1865 MMBTU/H (CTG)	4.5 PPMV @ 15%O2 (NG)	SELECTIVE CATALYTIC REDUCTION (SCR) WITH A NOX CEM AND PEM.	0	BACT-PSD
WESTERN GAS RESOURCES - HILIGHT GAS PLANT	WY	Oct-98	ENGINES, COMPRESSOR, 2 EA	1650 HP	1 G4P-H	3-WAY CATALYST SYSTEM AND AIR/FUEL RATIO CONTROLLER.	0	BACT-PSD
SABA PETROLEUM, INC. (BELL COMPRESSOR PLANT)	CA	Oct-98	IC ENGINE, COMPRESSOR, NATURAL GAS-FIRED	747 BHP	0.15 G4P-H-P	3-WAY CATALYTIC CONVERTER. MFOR. DCL, INC; MODEL:DC87/77-10 WITH ELECTRONIC AIR/FUEL RATIO CONTROLLER	0	BACT-OTHER
CHAMPAIGN INTERNATIONAL CORP. & CHAMP. CLEAN ENERGY	ME	Sep-98	TURBINE, COMBINED CYCLE, NATURAL GAS	175 MW	9 PPMV @ 15% O2 GAS	DRY LOW NOX BURNER-1 OPTION IS CONSIDERED FOR OIL AND IS SELECTED.	0	BACT-OTHER
TWP TECHNOLOGY LLC (FORMERLY TX-AM POWER CO.)	NM	Aug-98	GAS TURBINES	375 MMBTU/H	15 PPM	WATER INJECTION FOLLOWED BY SELECTIVE CATALYTIC REDUCTION	95	BACT-PSD
CASCO RAY ENERGY CO	ME	Jul-98	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170 MW EACH	3.5 PPM @ 15% O2	SELECTIVE CATALYTIC REDUCTION	0	BACT-PSD
CITY OF LAKELAND ELECTRIC AND WATER UTILITIES	FL	Jul-98	TURBINE, COMBUSTION, GAS FIRED W/ FUEL OIL ALSO	2174 MMBTU/H	25 PPM @ 15% O2	DRY LOW NOX COMBUSTION	0	BACT-PSD
COLORADO SPRINGS UTILITIES-NIXON POWER PLANT	CO	Jun-98	SIMPLE CYCLE TURBINE, NATURAL GAS	1122 MM BTU/H	25 PPM @ 15% O2	DRY LOW NOX BURNER WITH SCR	0	BACT-PSD
BRIDGEMOUNT ENERGY, LLC	CT	May-98	TURBINES, COMBUSTION, MODEL V84.3A, 2 SIEMES	260 BURNERS PER TURBINE	8 PPM NAT. GAS	ULTRA LOW NOX LEAN BURN TECHNOLOGY	0	BACT-PSD
UNION PACIFIC RESOURCES - PATRICK DRAW GAS PLANT	WY	May-98	ENGINES, COMPRESSOR, 8 EA	3200 HP	0.5 G4P-H	ULTRA LOW NOX LEAN BURN TECHNOLOGY	0	BACT-PSD
UNION PACIFIC RESOURCES - PATRICK DRAW GAS PLANT	WY	May-98	ENGINES, COMPRESSOR, 2 EA	1200 HP	0.9 G4P-H-P	ULTRA LOW NOX LEAN BURN TECHNOLOGY.	0	BACT-PSD
UNION PACIFIC RESOURCES - PATRICK DRAW GAS PLANT	WY	May-98	ENGINES, COMPRESSOR, 8 EA	3200 HP	0.9 G4P-H-P	ULTRA LOW NOX LEAN BURN TECHNOLOGY.	0	BACT-PSD
UNION PACIFIC RESOURCES - PATRICK DRAW GAS PLANT	WY	May-98	COMPRESSOR, ENGINES, 2 EA	1200 HP	0.9 G4P-H	ULTRA LOW NOX LEAN BURN TECHNOLOGY.	0	BACT-PSD
RUMFORD POWER ASSOCIATES	ME	May-98	TURBINE GENERATOR, COMBUSTION, NATURAL GAS	1908 MMBTU/H	3.5 PPM @ 15% O2	SCR AMMONIA INJECTION SYSTEM AND CATALYTIC REACTORTO REDUCE NOX.	85	BACT-PSD
ANDROSOGOGAN ENERGY LIMITED	ME	Mar-98	GAS TURBINES, COGEN, WDUCT BURNERS	875 MMBTU/H TURBINE	8 PPM @ 15% O2 NG	LOW NOX BURNERS, LOW NOX COMBUSTORS, SCR DURING GAS FIRING ONLY.	85	BACT-PSD
ANDROSOGOGAN ENERGY LIMITED	ME	Mar-98	GAS TURBINES, COGEN, WDUCT BURNERS	875 MMBTU/H TURBINE	42 PPM @ 15% O2 NO OIL	LOW NOX COMBUSTORS, LOW NOX BURNERS, WATER INJECTION DURING OIL FIRING.	85	BACT-PSD
TWO ELX GENERATION PARTNERS, LIMITED PARTNERSHIP	WY	2/27/98	TURBINE, STATIONARY	33.3 MW	25 PPM @ 15% O2	DRY LOW NOX BURNERS	40	BACT-PSD
AIR LIQUIDE AMERICA CORPORATION	LA	2/13/98	TURBINE GAS, GE, 7ME 7	908 MMBTU/H	9 PPMV	DRY LOW NOX TO LIMIT NOX EMISSION TO 8PPMV	0	BACT-PSD
MILLENNIUM POWER PARTNER, LP	MA	2/2/98	TURBINE, COMBUSTION, WESTINGHOUSE MODEL 5010	2534 MMBTU/H	0.013 LB/MMBTU	DRY LOW-NOX COMBUSTION TECHNOLOGY IN CONJUNCTION WITH SCR ADD-ON NOX CONTROLS.	0	BACT-PSD
MINNESOTA METHANE TAJILUS CORPORATION	CA	1/9/98	EQUIPMENT, LANDFILL GAS TO ENERGY PRODUCTION	43.88 MMBTU/H	0.59 G4P-H-P	LEAN BURN, EXHAUST ROUTED THROUGH AFTERBURNER TO FURTHER COMBUST ENGINE CO AND UNBURNED HYDROCARBONS.	0	BACT
BASF CORPORATION	LA	12/30/97	TURBINE, COGEN UNIT 2, GE FRAME 8	42.4 MW	8 PPMV NAT. GAS	STEAM INJECTION AND SCR TO LIMIT NOX TO 8 PPM FOR NATURAL GAS AND 25 PPM FOR WASTE GAS (80% H2)	0	BACT-PSD
ARCHIE CRIPPEN	CA	12/8/97	IC ENGINE, DETROIT DIESEL, MODEL 8V-92TA	500 BHP	0.2 G4P-H-P	NO CONTROL	0	BACT
WILLIAMS FIELD SERVICES-MIDDLE MESA COP	NM	12/3/97	NATURAL GAS COMPRESSION STATION, 14 ENGINES	1478 HP, EACH	4.51 LB/Hr EACH ENGINE	CLEAN/LEAN BURN COMBUSTION	0	BACT-PSD
SOUTHERN NATURAL GAS	AL	Mar-98	2-9150 HP GE MODEL M5300X2 NATURAL GAS TURBINES	9,150 HP	53 LB/Hr		0	BACT-PSD
SOUTHERN NATURAL GAS	AL	Mar-98	9150 HP GE MODEL M5300X2 NATURAL GAS FIRED TURBINE	9,150 HP	53 LB/Hr		0	BACT-PSD
ALABAMA POWER COMPANY	AL	Dec-97	COMBUSTION TURBINE W/ DUCT BURNER (COMBINED CYCLE)	100 MW	15 PPM	DRY LOW NOX BURNERS	0	BACT-PSD
BUCKNELL UNIVERSITY	PA	Nov-97	NG FIRED TURBINE, SOLAR TAJILUS T-7300S	5.0 MW	25 PPMV @ 15%O2	SOLARNOX BURNER, LOW NOX BURNER	0	BACT-OTHER
NORTHERN CALIFORNIA POWER AGENCY	CA	Oct-97	GE FRAME 5 GAS TURBINE	325 MMBTU/Hr	25 PPMV @ 15% O2	DRY LOW NOX BURNERS	0	LAER
LORDSBURG L.P.	NM	Jun-97	TURBINE, NATURAL GAS-FIRED, ELEC. GEN.	100 MW	74.4 LB/SHR	DRY LOW-NOX TECHNOLOGY WHICH ADOPTS STAGED OR SCHEDULED COMBUSTION.	80	BACT-PSD
SOUTHERN CALIFORNIA GAS COMPANY	CA	May-97	VARIABLE LOAD NATURAL GAS FIRED TURBINE COMPRESSOR	60 MMBTU/Hr	25 PPMV @ 15% O2	DRY LOW NOX COMBUSTOR	0	LAER
MEAD COATED BOARD, INC.	AL	Mar-97	COMBINED CYCLE TURBINE (25 MW)	568 MMBTU/Hr	25 PPMV @ 15% O2 (GAS)	FUEL OIL SULFUR CONTENT <=0.05% BY WEIGHT, DRY LOW NOX COMBUSTOR DESIGN FIRING GAS AND DRY LOW NOX COMBUSTOR WITH WATER INJECTION FIRING OIL	0	BACT-PSD
FORMOSA PLASTICS CORPORATION, BATON ROUGE PLANT	LA	Mar-97	TURBINE/HSPQ, GAS COGENERATION	450 MM BTU/Hr	9 PPMV	DRY LOW NOX BURNER/COMBUSTION DESIGN AND CONSTRUCTION.	0	BACT-PSD
SOUTHWESTERN PUBLIC SERVICE COMPANY/CUNNINGHAM STA	NM	Feb-97	COMBUSTION TURBINE, NATURAL GAS	100 MW	0 SEE FACILITY NOTES	DRY LOW NOX COMBUSTION	0	BACT-PSD
CALREOURCES LLC	CA	Jan-97	SOLAR MODEL 1100 SATURN GAS TURBINE	14 MMBTU/H	89 PPMV @ 15% O2	NO CONTROL	0	LAER
TEMPO PLASTICS	CA	Dec-96	GAS TURBINE COGENERATION UNIT	0.0	0.09 LB/MMBTU	LOW-NOX COMBUSTOR	0	LAER
SOUTHERN NATURAL GAS COMPANY	MS	Dec-96	TURBINE, NATURAL GAS-FIRED	9,180 HORSEPOWER	110 PPMV @ 15% O2, DRY	PROPER TURBINE DESIGN AND OPERATION	0	BACT-PSD
SOUTHERN NATURAL GAS COMPANY-SELMA COMPRESSOR STAT	AL	Dec-96	9180 HP GE M5300X2 NATURAL GAS FIRED TURBINE	0.0	53 LB/Hr		0	BACT-PSD
SOUTHWESTERN PUBLIC SERVICE CO/CUNNINGHAM STATION	NM	Nov-96	COMBUSTION TURBINE, NATURAL GAS	100 MW	15 PPM; SEE FAC. NOTES	DRY LOW NOX COMBUSTION	0	BACT-PSD
ECOELECTRICA, L.P.	PR	Oct-96	TURBINES, COMBINED-CYCLE COGENERATION	461 MW	60 LB/Hr (GAS)	STEAM/WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION (SCR).	72	BACT-PSD
ECOELECTRICA, L.P.	PR	Oct-96	TURBINES, COMBINED-CYCLE COGENERATION	461 MW	73 LB/Hr (OIL)	STEAM/WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION (SCR).	72	BACT-PSD
BLUE MOUNTAIN POWER, LP	PA	Jul-96	COMBUSTION TURBINE WITH HEAT RECOVERY BOILER	153 MW	4 PPM @ 15% O2	DRY LNB WITH SCR WATER INJECTION IN PLACE WHEN FIRING OIL. OIL FIRING LIMITS SET TO 8.4 PPM @ 15% O2	84	LAER
CITY OF ST. PAUL, POWER PLANT	AK	Jun-96	INTERNAL COMBUSTION	3.4 MW	427 TPY	AFTERCOOLERS	0	BACT-PSD
CITY OF UNALASKA	AK	Jun-96	INTERNAL COMBUSTION	8.5 MW	833 TPY	LIMIT OF OPERATION HOURS AND AFTERCOOLERS	0	BACT-PSD
GENERAL ELECTRIC GAS TURBINES	SC	Apr-96	I.C. TURBINE	2,700 MMBTU/Hr	865 LB/Hr	GOOD COMBUSTION PRACTICES TO MINIMIZE EMISSIONS	0	BACT-PSD
CAROLINA POWER & LIGHT	NC	Apr-96	COMBUSTION TURBINE, 4 EACH	1,908 MMBTU/Hr	512 LB/Hr (OIL)	WATER INJECTION; FUEL SPEC: 0.04% N FUEL OIL	0	BACT-PSD
CAROLINA POWER & LIGHT	NC	Apr-96	COMBUSTION TURBINE, 4 EACH	1,908 MMBTU/Hr	158 LB/Hr (GAS)	WATER INJECTION	0	BACT-PSD
MID-GEORGIA COGEN.	GA	Apr-96	COMBUSTION TURBINE (2), FUEL OIL	118 MW	20 PPMV/D	WATER INJECTION WITH SCR	0	BACT-PSD
MID-GEORGIA COGEN.	GA	Apr-96	COMBUSTION TURBINE (2), NATURAL GAS	118 MW	9 PPMV/D	DRY LOW NOX BURNER WITH SCR	0	BACT-PSD
GEORGIA GULF CORPORATION	LA	Apr-96	GENERATOR, NATURAL GAS FIRED TURBINE	1,123 MM BTU/Hr	25 PPMV-CORR. TO 15%O2	CONTROL NOX USING STEAM INJECTION	0	BACT-PSD
SEMINOLE HARDEE UNIT 3	FL	Jan-96	COMBINED CYCLE COMBUSTION TURBINE	140 MW	15 PPM @ 15% O2	DRY LNB STAGED COMBUSTION	0	BACT-PSD
KEY WEST CITY ELECTRIC SYSTEM	FL	Sep-95	TURBINE, EXISTING CT RELOCATION TO A NEW PLANT	23 MW	75 PPM @ 15% O2	WATER INJECTION	0	BACT-PSD
UNION CARBIDE CORPORATION	LA	Sep-95	GENERATOR, GAS TURBINE	1,313 MM BTU/Hr	25 PPMV CORR. TO 15% O2	DRY LOW NOX COMBUSTOR	0	BACT-PSD
PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	PR	Jul-96	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EACH	248 MW	35 LB/Hr AS NO2	STEAM INJECTION PLUS SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM, USE OF NO. 2 FUEL OIL WITH-NITROGEN CONTENT NOT TO EXCEED 0.10% BY WEIGHT.	0	BACT-PSD
HOOVERVILLE MUNICIPAL POWER FACILITY	MO	Jul-95	ADD OF A DUAL FUEL FIRED TWIN-PAC TURBINE	48 MW	42 PPM BY VOL. 1 HR AVG (G) WATER TO FUEL BEING FIRED IN THE TURBINES	CONTROLS TO REGULATE THE FUEL CONSUMPTION AND THE RATIO OF FUEL TO FUEL BEING FIRED IN THE TURBINES	0	BACT-PSD
HOOVERVILLE MUNICIPAL POWER FACILITY	MO	Jul-95	ADD OF A DUAL FUEL FIRED TWIN-PAC TURBINE	48 MW	75 PPM BY VOL. 1 HR AVG (NC) WATER TO FUEL BEING FIRED IN THE TURBINES	CONTROLS TO REGULATE THE FUEL CONSUMPTION AND THE RATIO OF FUEL TO FUEL BEING FIRED IN THE TURBINES	0	BACT-PSD
BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.	NY	Jun-95	TURBINE, NATURAL GAS FIRED	240 MW	3.5 PPM @ 15% O2	SCR	0	LAER
PANDA-KATHLEEN, L.P.	FL	Jun-95	COMBINED CYCLE COMBUSTION TURBINE (TOTAL 115MW)	75 MW	15 PPM @ 15% O2	DRY LOW NOX BURNER	0	BACT-PSD
PROCTOR AND GAMBLE PAPER PRODUCTS CO (CHARMIN)	PA	May-95	TURBINE, NATURAL GAS	580 MMBTU/Hr	55 PPM @ 15% O2	STEAM INJECTION	75	RACT
MILAGO, WILLIAMS FIELD SERVICE	NM	May-95	TURBINE/COGEN, NATURAL GAS (2)	900 MMCF/DAY	9 PPM @ 15% O2	DRY LOW NOX (GENERAL ELECTRIC MODEL P08541B)	84	BACT-PSD
GAINESVILLE REGIONAL UTILITIES	FL	Apr-95	SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL B-U-P	74 MW	18 PPM AT 15% OXYGEN	DRY LOW NOX BURNERS GE FRAME UNIT, CAN ANNUAL COMBUSTORS	0	BACT-PSD
GAINESVILLE REGIONAL UTILITIES	FL	Apr-95	OIL FIRED COMBUSTION TURBINE	74 MW	42 PPM AT 15% OXYGEN	WATER INJECTION	0	BACT-PSD

Table B-2. Summary of Best Available Control Technology (BACT) Determinations for Nitrogen Oxide (NOx) Emissions

Facility Name	State	Permit Issue Date	Unit/Process Description	Capacity (size)	NOx Emission Limit	Control Method	Efficiency (%)	Type
LEDERLE LABORATORIES	NY	Apr-93	(2) GAS TURBINES (EP #5 001014102)	110 MMBTUHR	42 PPM, 18 LB/HR	STEAM INJECTION	0	BACT-PSD
PILGRIM ENERGY CENTER	NY	Apr-93	(2) WESTINGHOUSE W50105 TURBINES (EP #5 0000182)	1,400 MMBTUHR	4.5 PPM, 23.8 LB/HR	STEAM INJECTION FOLLOWED BY SCR	0	BACT
BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT	MD	Mar-95	TURBINE, 140 MW NATURAL GAS FIRED ELECTRIC	140 MW	15 PPM @ 15% O2	DRY LOW NOX BURNERS	81	BACT-PSD
FORMOSA PLASTICS CORPORATION, LOUISIANA	LA	Mar-95	TURBINE#R50, GAS COGENERATION	450 MM BTUHR	9 PPMV	DRY LOW NOX BURNER/COMBUSTION DESIGN AND CONTROL	0	LAER
LSP-COTTAGE GROVE, L.P.	MI	Mar-95	COMBUSTION TURBINE/GENERATOR	1,870 MMBTUHR	4.5 PPM @ 15% O2 GAS	SELECTIVE CATALYTIC REDUCTION (SCR)	70	BACT-PSD
SUPRIE DISTRICT ELECTRIC CO.	MO	Feb-95	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	80 MW	360 TYP	WATER INJECTION	0	BACT-PSD
MARATHON OIL CO. - INDIAN BASIN N.O. PLAN	NM	Jun-95	TURBINES, NATURAL GAS (2)	5,500 HP	7.4 LB/HR	LEAN-PREHEATED COMBUSTION TECHNOLOGY, DRY/LOW NOX	66	BACT-PSD
KAMINE/BESICORP SYRACUSE LP	NY	Dec-94	SIEMENS V64.3 GAS TURBINE (EP #00001)	650 MMBTUHR	25 PPM	WATER INJECTION	70	BACT
INDECK-OSWEGO ENERGY CENTER	NY	Oct-94	GE FRAME 6 GAS TURBINE	533 LB/MMBTU	42 PPM, 75.00 LB/HR	STEAM INJECTION	53	BACT
FULTON COGEN PLANT	NY	Sep-94	GE LM5000 GAS TURBINE	500 MMBTUHR	38 PPM, 65 LB/HR	WATER INJECTION	56	BACT
CAROLINA POWER AND LIGHT	SC	Aug-94	STATIONARY GAS TURBINE	1,520 MMBTUHR	25 PPMV @ 15% O2 (GAS)	WATER INJECTION	0	BACT-PSD
CAROLINA POWER AND LIGHT	SC	Aug-94	STATIONARY GAS TURBINE	1,520 MMBTUHR	42 PPMV @ 15% O2 (OIL)	WATER INJECTION	30	BACT-PSD
BRUSH COGENERATION PARTNERSHIP	CO	Jul-94	TURBINE	350 MMBTUHR	25 PPM @ 15% O2	DRY LOW NOX BURNER	74	BACT-PSD
COLORADO POWER PARTNERSHIP	CO	Jul-94	TURBINES, 2 NAT GAS & 2 DUCT BURNERS	365 MMBTUHR EACH TURBINE	42 PPM @ 15% O2	WATER INJECTION	66	BACT-PSD
MUDDY RIVER L.P.	NV	Jun-94	COMBUSTION TURBINE, DIESEL & NATURAL GAS	140 MEGAWATT	303 LB/HR	LOW NOX BURNER	0	BACT-PSD
CSW NEVADA, INC.	NV	Jun-94	COMBUSTION TURBINE, DIESEL & NATURAL GAS	140 MEGAWATT	273 LB/HR	DRY LOW NOX COMBUSTOR	0	BACT-PSD
PORTLAND GENERAL ELECTRIC CO.	OR	May-94	TURBINES, NATURAL GAS (2)	1,720 MMBTUHR	4.5 PPM @ 15% O2	SCR	82	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	MO	May-94	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	1,345 MMBTUHR	25 PPM BY VOL. 1 HR AVG (90	LOW NOX BURNERS, AND WATER INJECTION	0	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	MO	May-94	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	1,345 MMBTUHR	1,135 TYP (NO. 2 OIL)	LOW NOX BURNERS, AND WATER INJECTION	0	BACT-PSD
GEORGIA POWER COMPANY, ROBINS TURBINE PROJECT	GA	May-94	TURBINE, COMBUSTION, NATURAL GAS	80 MW	25 PPM	WATER INJECTION, FUEL SPEC: NATURAL GAS	0	BACT-PSD
WEST CAMPUS COGENERATION COMPANY	TX	May-94	GAS TURBINES	75 MW (TOTAL POWER)	200 TYP	INTERNAL COMBUSTION CONTROLS	0	BACT-PSD
FLEETWOOD COGENERATION ASSOCIATES	PA	Apr-94	NO TURBINE (GE LM5000) WITH WASTE HEAT BOILER	360 MMBTUHR	31 LB/HR	SCR WITH LOW NOX COMBUSTORS	47	BACT-OTHER
HERNSTON GENERATING CO.	OR	Apr-94	TURBINES, NATURAL GAS (2)	1,696 MMBTUHR	4.5 PPM @ 15% O2	SCR	62	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	FL	Feb-94	TURBINE, NATURAL GAS (2)	1,510 MMBTUHR	12 PPMV @ 15% O2	DRY LOW NOX COMBUSTOR	0	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	FL	Feb-94	TURBINE, FUEL OIL (2)	1,730 MMBTUHR	42 PPMV @ 15% O2	WATER INJECTION	0	BACT-PSD
TECO POLK POWER STATION	FL	Feb-94	TURBINE, SYNGAS (COAL GASIFICATION)	1,755 MMBTUHR	25 PPMV @ 15% O2	DRY LOW NOX COMBUSTOR	0	BACT-PSD
TECO POLK POWER STATION	FL	Feb-94	TURBINE, FUEL OIL	1,765 MMBTUHR	42 PPMV @ 15% O2	WET INJECTION	0	BACT-PSD
INTERNATIONAL PAPER	LA	Jan-94	TURBINE#R400, GAS COGEN	338 MM BTUHR TURBINE	25 PPMV 15% O2 TURBINE	DRY LOW NOX COMBUSTOR/COMBUSTION CONTROL	0	BACT
KAMINE/BESICORP CARTHAGE L.P.	NY	Jan-94	GE FRAME 6 GAS TURBINE	491 BTUHR	42 PPM, 76.8 LB/HR	STEAM INJECTION	63	BACT
ORANGE COGENERATION LP	FL	Dec-93	TURBINE, NATURAL GAS, 2	366 MMBTUHR	15 PPM @ 15% O2	DRY LOW NOX COMBUSTOR	0	BACT-PSD
PROJECT ORANGE ASSOCIATES	NY	Dec-93	GE LM-5000 GAS TURBINE	550 MMBTUHR	25 PPM, 47 LB/HR	STEAM INJECTION, FUEL SPEC: NATURAL GAS ONLY	80	BACT
WILLIAMS FIELD SERVICES CO. - EL CEDRO COMPRESSOR	NM	Oct-93	TURBINE, GAS-FIRED	11,287 HP	42 PPM @ 15% O2	SOLONOX COMBUSTOR, DRY LOW NOX TECHNOLOGY	86	BACT-PSD
FLORIDA GAS TRANSMISSION	FL	Sep-93	TURBINE, GAS	132 MMBTUHR	25 PPM @ 15% O2	DRY LOW NOX COMBUSTOR	0	BACT
PATCHMACK POWER PARTNERS, LIMITED PARTNERSHIP	VA	Sep-93	TURBINE, COMBUSTION, SIEMENS MODEL V64.2, 3	19.2 X109 SCF/YR NAT GAS	131 LB/HR(GAS); 338 OIL	DRY LOW NOX COMBUSTOR, DESIGN, WATER INJECTION	0	BACT-PSD
FLORIDA GAS TRANSMISSION COMPANY	AL	Aug-93	TURBINE, NATURAL GAS	12,600 BHP	0.58 GHP/HR	AIR-TO-FUEL RATIO CONTROL, DRY LOW NOX COMBUSTION	71	BACT-PSD
LOCKPORT COGEN FACILITY	NY	Jul-93	(6) GE FRAME 6 TURBINES (EP #5 00001-00006)	424 MMBTUHR	42 PPM	STEAM INJECTION	78	BACT
AMITEC COGEN PLANT	NY	Jul-93	GE LM5000 COMBINED CYCLE GAS TURBINE EP #00001	451 MMBTUHR	25 PPM, 41 LB/HR	NO CONTROLS	0	BACT-OTHER
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NJ	Jun-93	TURBINES, COMBUSTION, KEROSENE-FIRED (2)	640 MMBTUHR (EACH)	16 PPMV	SCR	0	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NJ	Jun-93	TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)	617 MMBTUHR (EACH)	8.3 PPMV	SCR	0	BACT-PSD
TIGER BAY LP	FL	May-93	TURBINE, OIL	1,850 MMBTUHR	42 PPM @ 15% O2	WATER INJECTION	0	BACT-PSD
TIGER BAY LP	FL	May-93	TURBINE, GAS	1,815 MMBTUHR	15 PPM @ 15% O2	DRY LOW NOX COMBUSTOR	0	BACT-PSD
INDECK ENERGY COMPANY	NY	May-93	GE FRAME 6 GAS TURBINE EP #00001	481 MMBTUHR	32 PPM	STEAM INJECTION	58	BACT
PHOENIX POWER PARTNERS	CO	May-93	TURBINE (NATURAL GAS)	311 MMBTUHR	22 PPM @ 15% O2	DRY LOW NOX COMBUSTION	0	BACT-OTHER
TROKEN MITCHELL FIELD	NY	Apr-93	GE FRAME 6 GAS TURBINE	425 MMBTUHR	40 PPM, 80 LB/HR	STEAM INJECTION	20	BACT
KISSIMMEE UTILITY AUTHORITY	FL	Apr-93	TURBINE, FUEL OIL	928 MMBTUHR	42 PPM @ 15% O2	WATER INJECTION	0	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	FL	Apr-93	TURBINE, FUEL OIL	371 MMBTUHR	42 PPM @ 15% O2	WATER INJECTION	0	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	FL	Apr-93	TURBINE, NATURAL GAS	869 MMBTUHR	15 PPM @ 15% O2	DRY LOW NOX COMBUSTOR	0	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	FL	Apr-93	TURBINE, NATURAL GAS	367 MMBTUHR	15 PPM @ 15% O2	DRY LOW NOX COMBUSTOR	0	BACT-PSD
EAST KENTUCKY POWER COOPERATIVE	KY	Mar-93	TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED	1,492 MMBTUHR (EACH)	42 PPM @ 15% O2 (OIL)	WATER INJECTION	46	SEE NOTES
INTERNATIONAL PAPER CO. - RIVERDALE MILL	AL	Jan-93	TURBINE, STATIONARY (GAS-FIRED) WITH DUCT BURNER	40 MW	0.06 LB/MMBTU (GAS)	TURBINE	0	BACT-PSD
OKLAHOMA MUNICIPAL POWER AUTHORITY	OK	Dec-92	TURBINE, COMBUSTION	58 MW	65 PPM @ 15% O2 (OIL)	COMBUSTION CONTROLS	83	BACT-OTHER
OKLAHOMA MUNICIPAL POWER AUTHORITY	OK	Dec-92	TURBINE, COMBUSTION	58 MW	25 PPM @ 15% O2 (GAS)	COMBUSTION CONTROLS	63	BACT-OTHER
AUBURNDALE POWER PARTNERS, LP	FL	Dec-92	TURBINE, OIL	1,170 MMBTUHR	42 PPMV @ 15% O2	STEAM INJECTION	0	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	FL	Dec-92	TURBINE, GAS	1,214 MMBTUHR	12 PPMV @ 15% O2	DRY LOW NOX COMBUSTOR	0	BACT-PSD
SITH/INDEPENDENCE POWER PARTNERS	NY	Nov-92	TURBINES, COMBUSTION (4) (NATURAL GAS) (1012 MW)	2,133 MMBTUHR (EACH)	4.5 PPM	SCR AND DRY LOW NOX	0	BACT-OTHER
KAMINE/BESICORP BEAVER FALLS COGENERATION FACILITY	NY	Nov-92	TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MM)	650 MMBTUHR	9 PPM (GAS)	DRY LOW NOX OR SCR	0	BACT-OTHER
KAMINE/BESICORP BEAVER FALLS COGENERATION FACILITY	NY	Nov-92	TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MM)	650 MMBTUHR	55 PPM (OIL)	DRY LOW NOX OR SCR	0	BACT-OTHER
KAMINE/BESICORP CORNING L.P.	NY	Nov-92	TURBINE, COMBUSTION (79 MM)	653 MMBTUHR	9 PPM	DRY LOW NOX OR SCR	0	BACT-OTHER
GRAYS FERRY CO. GENERATION PARTNERSHIP	PA	Nov-92	TURBINE (NATURAL GAS & OIL)	1,150 MMBTUHR	9 PPMV @ 15% O2	DRY LOW NOX BURNER, COMBUSTION CONTROL	0	BACT-OTHER
OAL LINE, LP ICF/JOE	CA	Nov-92	TURBINE, COMBUSTION (NATURAL GAS) (42.4 MW)	306 MMBTUHR	5 PPMV @ 15% OXYGEN	WATER INJECTION & SCR W/ AUTOMATIC AMMONIA INJECT.	84	BACT-OTHER
BEAR ISLAND PAPER COMPANY, L.P.	VA	Oct-92	TURBINE, COMBUSTION GAS	468 X10(8) BTUHR #2 OIL	15 PPM	SCR	81	BACT-PSD
BEAR ISLAND PAPER COMPANY, L.P.	VA	Oct-92	TURBINE, COMBUSTION GAS (TOTAL)	0.0	69.7 TYP	SCR	0	BACT-PSD
BEAR ISLAND PAPER COMPANY, L.P.	VA	Oct-92	TURBINE, COMBUSTION GAS	474 X10(8) BTUHR N. GAS	9 PPM	SELECTIVE CATALYTIC REDUCTION (SCR)	75	BACT-PSD
GORDONSVILLE ENERGY L.P.	VA	Sep-92	TURBINE FACILITY, GAS	7.4 X10(7) QPY FUEL OIL	245 TOTAL TYP	SELECTIVE CATALYTIC REDUCTION (SCR)	80	BACT-PSD
GORDONSVILLE ENERGY L.P.	VA	Sep-92	TURBINES (2) (EACH WITH A SF)	1.4 X10(9) BTUHR #2 OIL	86 LB/HR/UNIT	WATER INJECTION AND SCR	80	BACT-PSD
GORDONSVILLE ENERGY L.P.	VA	Sep-92	TURBINE FACILITY, GAS	1,331 X10(7) SCF/YR NAT GAS	245 TOTAL TYP	SELECTIVE CATALYTIC REDUCTION (SCR) W/ WATER INJECT	80	BACT-PSD
GORDONSVILLE ENERGY L.P.	VA	Sep-92	TURBINES (2) (EACH WITH A SF)	1.5 X10(9) BTUHR N GAS	9 PPMV/UNIT @ 15% O2	SCR WITH WATER INJECTION	80	BACT-PSD
NEVADA POWER COMPANY, HARRY ALLEN PEAKING PLANT	NV	Sep-92	COMBUSTION TURBINE ELECTRIC POWER GENERATION	600 MW (5 UNITS 75 EACH)	68.6 TYP (EACH TURBINE)	LOW NOX COMBUSTOR	0	BACT-PSD
KAMINE SOUTH GLENS FALLS COGEN CO	NY	Sep-92	GE FRAME 6 GAS TURBINE	488 MMBTUHR	42 PPM, 76.8 LB/HR	WATER INJECTION	50	BACT
NORTHERN STATES POWER COMPANY	SD	Sep-92	TURBINE, SIMPLE CYCLE, 4 EACH	129 MW	24 PPM @ 15% O2 GAS	WATER INJECTION FOR GAS & DISTILLATION	0	BACT-PSD
PASNYHOLTSVILLE COMBINED CYCLE PLANT	NY	Sep-92	TURBINE, COMBUSTION GAS (150 MM)	1,146 MMBTUHR (GAS)*	9 PPM (GAS)	DRY LOW NOX	0	BACT-OTHER
PASNYHOLTSVILLE COMBINED CYCLE PLANT	NY	Sep-92	TURBINE, COMBUSTION GAS (150 MM)	1,146 MMBTUHR (GAS)*	42 PPM (OIL)	WATER INJECTOR	0	BACT-OTHER
WEPOL, PARIS SITE	WI	Aug-92	TURBINES, COMBUSTION (4)	0.0	65 PPM @ 15% O2 (OIL)	GOOD COMBUSTION PRACTICES	0	BACT-PSD
WEPOL, PARIS SITE	WI	Aug-92	TURBINES, COMBUSTION (4)	0.0	25 PPM @ 15% O2 (GAS)	GOOD COMBUSTION PRACTICES	0	BACT-PSD
FLORIDA POWER CORPORATION	FL	Aug-92	TURBINE, OIL	1,028 MMBTUHR	42 PPMV @ 15% O2	WET INJECTION	0	BACT-PSD
FLORIDA POWER CORPORATION	FL	Aug-92	TURBINE, GAS-FIRED	12,100 HP	42 PPMV @ 15% O2	WET INJECTION	0	BACT-PSD
NORTHWEST PIPELINE COMPANY	WA	Aug-92	TURBINE (NATURAL GAS) (3)	5,500 HP (EACH)	186 PPM @ 15% O2	ADVANCED DRY LOW NOX COMBUSTOR (BY 07/01/95)	76	BACT-PSD
CNG TRANSMISSION	OH	Aug-92	TURBINE, COMBUSTION (2) (NATURAL GAS)	1,123 MMBTUHR (EACH)	1.6 GHP/HR	LOW NOX COMBUSTION	0	BACT-OTHER
SARANAC ENERGY COMPANY	NY	Jul-92	TURBINE, OIL FIRED (2 EACH)	1,840 M BTUHR	9 PPM	SCR	0	BACT-OTHER
HARTWELL ENERGY LIMITED PARTNERSHIP	GA	Jul-92	TURBINE, COMBINED-CYCLE COMBUSTION	28 MW	25 PPMV, FUEL N AFLOW	MAXIMUM WATER INJECTION	0	BACT-PSD
MAIA ELECTRIC COMPANY, LTD./MAALAEA GENERATING STA	HI	Jul-92	TURBINE, GAS FIRED (2 EACH)	18.17 M BTUHR	42 PPM, 74 LB/HR	WATER INJECTION	89	BACT-OTHER
HARTWELL ENERGY LIMITED PARTNERSHIP	GA	Jul-92	TURBINE, GAS FIRED (2 EACH)	432 MMBTUHR	25 PPM, 41 LB/HR	MAXIMUM WATER INJECTION	0	BACT-OTHER
INDECK-YERKES ENERGY SERVICES	NY	Jun-92	GE FRAME 6 GAS TURBINE (EP #00001)	1,173 MMBTUHR (EACH)	25 PPM GAS	STEAM INJECTION	35	BACT
SELKIRK COGENERATION PARTNERS, L.P.	NY	Jun-92	COMBUSTION TURBINES (2) (252 MW)	1,173 MMBTUHR (EACH)	25 PPM GAS	STEAM INJECTION AND SCR	0	BACT-OTHER
SELKIRK COGENERATION PARTNERS, L.P.	NY	Jun-92	COMBUSTION TURBINE (79 MW)	1,173 MMBTUHR	25 PPM GAS	STEAM INJECTION	0	BACT-OTHER
NORTHWEST PIPELINE CORPORATION	CO	May-92	TURBINE, SOLAR TAURUS	45 MMBTUHR	85 PPMV (UNTIL 11/98)	DRY LOW NOX COMBUSTOR (BY 11/01/98)	0	BACT-PSD
HARRISANSETT ELECTRIC/NEW ENGLAND POWER CO.	RI	Apr-92	TURBINE, GAS AND DUCT BURNER	1,860 MMBTUHR EACH	9 PPM @ 15% O2	SCR	0	BACT-PSD
KENTUCKY UTILITIES COMPANY	KY	Mar-92	TURBINE, #2 FUEL OIL/NATURAL GAS (6)	1,500 MM BTUHR (EACH)	42 PPM @ 15% O2, N. GAS	WATER INJECTION	0	BACT-PSD
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	VA	Mar-92	TURBINE, COMBUSTION	1,175 MMBTUHR NAT. GAS	9 PPM @ 15% O2	SCR, STEAM INJECTION	81	BACT-PSD
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	VA	Mar-92	TURBINE, COMBUSTION	1,117 MMBTUHR NO2 FUEL OIL	15 PPM @ 15% O2	SCR, STEAM INJ.	81	BACT-PSD
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	VA	Mar-92	TURBINE, COMBUSTION, 2	0.0	191 TYP/UNIT	SCR	0	BACT-PSD
THEIRMO INDUSTRIES, LTD.	CO	Feb-92	TURBINE, GAS FIRED, 5 EACH	246 MMBTUHR	25 PPM @ 15% O2	DRY LOW NOX TECH.	0	BACT-PSD

Table B-2. Summary of Best Available Control Technology (BACT) Determinations for Nitrogen Oxide (NOx) Emissions

Facility Name	State	Permit Issue Date	Unit/Process Description	Capacity (size)	NOx Emission Limit	Control Method	Efficiency (%)	Type
HAWAII ELECTRIC LIGHT CO., INC.	HI	Feb-92	TURBINE, FUEL OIL #2	20 MW	42.3 LB/HR	COMBUSTOR WATER INJECTOR, WATER INJECTION	70	BACT-PSD
SAVANNAH ELECTRIC AND POWER CO.	GA	Feb-92	TURBINES, 8	1,032 MMSTU/H, NAT GAS	25 PPM @ 15% O2	MAX WATER INJECTION	0	BACT-PSD
SAVANNAH ELECTRIC AND POWER CO.	GA	Feb-92	TURBINES, 8	972 MMSTU/H, #2 OIL	0 SEE NOTES	MAX WATER INJECTION	0	BACT-PSD
LINDEN COGENERATION TECHNOLOGY	NJ	Jan-92	TURBINE, NATURAL GAS FIRED	50 X E12 BTU/YR	33.8 LB/HR	STEAM INJECTION AND SCR	85	BACT-PSD
ALYESKA PIPELINE SERVICE COMPANY	AK	Jan-92	SOLAR CENTAUR, 3	800 KW	150 PPMV @ 15% O2	LOW NOX BURNERS	0	NSPS
KAMMERDEPOT NATURAL DAM LP	NY	Dec-91	GE FRAME 8 GAS TURBINE	500 MMSTU/HR	42 PPM @ 15% O2	STEAM INJECTION	35	BACT
DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	NC	Dec-91	TURBINE, COMBUSTION	1,247 MM BTU/HR	287 LB/HR	MULTINOZZLE COMBUSTOR, MAXIMUM WATER INJECTION	0	BACT-PSD
DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	NC	Dec-91	TURBINE, COMBUSTION	1,313 MM BTU/HR	119 LB/HR	MULTINOZZLE COMBUSTOR, MAXIMUM WATER INJECTION	0	BACT-PSD
MAUI ELECTRIC COMPANY, LTD.	HI	Dec-91	TURBINE, FUEL OIL #2	26 MW	42 PPM	WATER INJECTION	71	BACT-PSD
KALAMAZOO POWER LIMITED	MI	Dec-91	TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS	1,806 MMSTU/H	15 PPMV	DRY LOW NOX TURBINES	0	BACT-PSD
LAKE COGEN LIMITED	FL	Nov-91	TURBINE, OIL, 2 EACH	42 MW	42 PPM @ 15% O2	COMBUSTION CONTROL	0	BACT-PSD
LAKE COGEN LIMITED	FL	Nov-91	TURBINE, GAS, 2 EACH	42 MW	25 PPM @ 15% O2	COMBUSTION CONTROL	0	BACT-PSD
SHELL PIPELINE CORPORATION	CA	Nov-91	GENERATOR, EMERGENCY, PROPANE FIRED	82 BHP	0.26 LB/H	3-WAY CATALYTIC CONVERTER	80	BACT-PSD
DE LA GUERRA POWER, INC	CA	Nov-91	ENGINE IC & GEN (1 OF 3)	380 HP	6.34 LB/D	NON-SELECTIVE CATALYTIC CONVERTER	80	BACT-PSD
ORLANDO UTILITIES COMMISSION	FL	Nov-91	TURBINE, GAS, 4 EACH	35 MW	42 PPM @ 15% O2	WET INJECTION	70	BACT-PSD
ORLANDO UTILITIES COMMISSION	FL	Nov-91	TURBINE, OIL, 4 EACH	35 MW	85 PPM @ 15% O2	WET INJECTION	0	BACT-PSD
SOUTHERN CALIFORNIA GAS	CA	Oct-91	TURBINE, GAS FIRED, SOLAR MODEL H	5,500 HP	6 PPM @ 15% O2	HIGH TEMP SELECT. CAT. REDUCTION	83	BACT-PSD
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, GAS, SOLAR CENTAUR H	5,500 HP	84.9 PPM @ 15% O2	LEAN BURN	0	NSPS
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, GAS, SOLAR CENTAUR H	5,500 HP	42 PPM @ 15% O2	DRY LOW NOX COMBUSTOR	51	BACT-PSD
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, GAS, SOLAR CENTAUR H	5,500 HP	65.1 PPM @ 15% O2	FUEL SPEC: LEAN FUEL MIX	0	NSPS
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, GAS, SOLAR CENTAUR H	5,500 HP	42 PPM @ 15% O2	DRY LOW NOX COMBUSTOR	51	BACT-PSD
FLORIDA POWER GENERATION	FL	Oct-91	TURBINE, OIL, 8 EACH	83 MW	42 PPM @ 15% O2	WET INJECTION	0	BACT-PSD
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, NAT. GAS TRANSM., GE FRAME 3	12,000 HP	225 PPM @ 15% O2	LEAN BURN	0	BACT-PSD
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, NAT. GAS TRANSM., GE FRAME 3	12,000 HP	42 PPM @ 15% O2	DRY LOW NOX COMBUSTOR	80	BACT-PSD
NUOGT OIL CO.	CA	Oct-91	GENERATOR, STEAM, GAS FIRED	63 MMSTU/H	0.043 LB/MMSTU	LOW NOX BURNER AND FLUE GAS RECIRCULATION*	57	BACT-PSD
CAROLINA POWER AND LIGHT CO.	SC	Sep-91	TURBINE, I.C.	80 MW	292 LB/H	WATER INJECTION	50	BACT-PSD
ENRON LOUISIANA ENERGY COMPANY	LA	Aug-91	TURBINE, GAS, 2	39 MMSTU/H	40 PPM @ 15% O2	H2O INJECT 0.67 LB/LB	71	BACT-PSD
ALCONOVIN GAS TRANSMISSION CO.	RI	Jul-91	TURBINE, GAS, 2	48 MMSTU/H	100 PPM @ 15% O2	LOW NOX COMBUSTION	0	BACT-OTHER
CHARLES LARSEN POWER PLANT	FL	Jul-91	TURBINE, OIL, 1 EACH	80 MW	42 PPM @ 15% O2	WET INJECTION	0	BACT-PSD
CHARLES LARSEN POWER PLANT	FL	Jul-91	TURBINE, GAS, 1 EACH	80 MW	25 PPM @ 15% O2	WET INJECTION	0	BACT-PSD
SUMAS ENERGY INC.	WA	Jun-91	TURBINE, NATURAL GAS	88 MW	6 PPM @ 15% O2	SCR	90	BACT-PSD
SAGUARO POWER COMPANY	NV	Jun-91	COMBUSTION TURBINE GENERATOR	35 MW	16.9 PPM (WINTER)	SELECTIVE CATALYTIC REDUCTION (SCR)	80	BACT-PSD
FLORIDA POWER AND LIGHT	FL	Jun-91	TURBINE, OIL, 2 EACH	400 MW	85 PPM @ 15% O2	LOW NOX COMBUSTORS	0	BACT-PSD
FLORIDA POWER AND LIGHT	FL	Jun-91	TURBINE, GAS, 4 EACH	400 MW	25 PPM @ 15% O2	LOW NOX COMBUSTORS	0	BACT-PSD
FLORIDA POWER AND LIGHT	FL	Jun-91	TURBINE, CO, 4 EACH	400 MW	42 PPM @ 15% O2	LOW NOX COMBUSTORS	0	BACT-PSD
GRANITE ROAD LIMITED	CA	May-91	TURBINE, GAS, ELECTRIC GENERATION	461 MMSTU/H*	3.5 PPMV @ 15% O2	SCR, STEAM INJECTION	97	BACT-PSD
NORTHERN CONSOLIDATED POWER	PA	May-91	TURBINES, GAS, 2	35 KW EACH	25 PPM @ 15% O2	STEAM INJECTION+SCR IN 1997	85	OTHER
CHAMBERN CHEMICAL	CO	Mar-91	TURBINE #1, GE FRAME 6	33 MW	25 PPM @ 15% O2	WATER INJECTION	0	OTHER
CHAMBERN CHEMICAL	CO	Mar-91	TURBINE #2, GE FRAME 6	33 MW	9 PPM @ 15% O2	SCR	0	OTHER
SEMINOLE FERTILIZER CORPORATION	FL	Mar-91	TURBINE, GAS	26 MW	9 PPM @ 15% O2	SCR	0	BACT-PSD
FLORIDA POWER AND LIGHT	FL	Mar-91	TURBINE, GAS, 4 EACH	240 MW	42 PPM @ 15% O2	COMBUSTION CONTROL	0	BACT-PSD
FLORIDA POWER AND LIGHT	FL	Mar-91	TURBINE, OIL, 4 EACH	0.0	65 PPM @ 15% O2	COMBUSTION CONTROL	0	BACT-PSD
CITY UTILITIES OF SPRINGFIELD	MO	Mar-91	GENERATION OF ELECTRICAL POWER	752 MMSTU/HR	42 PPM BY VOL. 1 HR AVG (O/WATER INJECTION	0	BACT-PSD	
CITY UTILITIES OF SPRINGFIELD	MO	Mar-91	GENERATION OF ELECTRICAL POWER	752 MMSTU/HR	65 PPM BY VOL. 1 HR AVG (O/WATER INJECTION	0	BACT-PSD	
CITY UTILITIES OF SPRINGFIELD	MO	Mar-91	GENERATION OF ELECTRICAL POWER	585 MMSTU/HR	42 PPM BY VOL. 1 HR AVG (O/WATER INJECTION	0	BACT-PSD	
CITY UTILITIES OF SPRINGFIELD	MO	Mar-91	GENERATION OF ELECTRICAL POWER	585 MMSTU/HR	65 PPM BY VOL. 1 HR AVG (O/WATER INJECTION	0	BACT-PSD	
NEVADA COGENERATION ASSOCIATES #2	NV	Jan-91	COMBINED-CYCLE POWER GENERATION	85 MW POWER OUTPUT	81.3 LB/SHR	SELECTIVE CATALYTIC SYSTEM ON ONE UNIT	0	BACT-PSD
NEVADA COGENERATION ASSOCIATES #1	NV	Jan-91	COMBINED-CYCLE POWER GENERATION	85 MW TOTAL OUTPUT	81.3 LB/SHR	SELECTIVE CATALYTIC SYSTEM ON ONE UNIT	0	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP	NJ	Nov-90	TURBINE, NATURAL GAS FIRED	585 MMSTU/HR	0.833 LB/MMSTU	STEAM INJECTION AND SCR	84	BACT-PSD
NORTHERN NATURAL GAS COMPANY	IA	Sep-90	ENGINE, COMPRESSOR	4,000 HP	1.8 O2/HIP-H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
NORTHERN NATURAL GAS COMPANY	IA	Sep-90	ENGINE, COMPRESSOR, 2	2,000 HP EACH	1.8 O2/HIP-H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
TBO COGEN COGENERATION PLANT	NY	Aug-90	GE LM2500 GAS TURBINE	215 MMSTU/HR	75 PPM + FBN CORRECTION	WATER INJECTION	80	BACT
PERCO - CHALK POINT PLANT	MD	Jun-90	TURBINE, 105 MW NATURAL GAS FIRED ELECTRIC	105 MW	77 PPM @ 15% O2	DRY PREMIX AND WATER INJECTION	0	BACT-PSD
PERCO - CHALK POINT PLANT	MD	Jun-90	TURBINE, 84 MW NATURAL GAS FIRED ELECTRIC	84 MW	25 PPM @ 15% O2	QUIET COMBUSTION AND WATER INJECTION	0	BACT-PSD
PACIFIC GAS TRANSMISSION COMPANY	OR	Jun-90	TURBINE GAS, COMPRESSOR STATION	110 MMSTU/HR	199 PPM @ 15% O2	LOW NOX BURNER DESIGN	30	NSPS
PERCO - STATION A	MD	May-90	TURBINE, 124 MW NATURAL GAS FIRED	125 MW	42 PPM @ 15% O2	WATER INJECTION	0	BACT-PSD
PEDRICKTOWN COGENERATION LIMITED PARTNERSHIP	NJ	Feb-90	TURBINE, NATURAL GAS FIRED	1,000 MMSTU/HR	0.044 LB/MMSTU	STEAM INJECTION AND SCR	83	BACT-PSD
SC ELECTRIC AND GAS COMPANY - HAGOODO STATION	SC	Dec-89	INTERNAL COMBUSTION TURBINE	110 MEGAWATTS	308 LB/SHR	WATER INJECTION	0	BACT-PSD
PEABODY MUNICIPAL LIGHT PLANT	MA	Nov-89	TURBINE, 38 MW NATURAL GAS FIRED	412 MMSTU/HR	25 PPM @ 15% O2	WATER INJECTION	0	BACT-OTHER
PACIFIC GAS TRANSMISSION	OR	Nov-89	TURBINE, NAT. GAS	14,800 HP	42 PPM @ 15% O2	LOW NOX BURNERS	75	BACT-PSD
SOUTHERN MARYLAND ELECTRIC COOPERATIVE (SMECO)	MD	Oct-89	TURBINE, NATURAL GAS FIRED ELECTRIC	90 MW	198 LB/HR	WATER INJECTION	0	BACT-PSD
KINGSBURG ENERGY SYSTEMS	CA	Sep-89	TURBINE, NATURAL GAS FIRED, DUCT BURNER	33 MW	6 PPM @ 15% O2	SCR, STEAM INJECTION	80	BACT-PSD
MEGAN-RACINE ASSOCIATES, INC	NY	Aug-89	GE LM5000-N COMBINED CYCLE GAS TURBINE	401 LB/MMSTU	42 PPMV @ 15% O2	WATER INJECTION	80	BACT

Note: PSD= Prevention of Significant Deterioration
 BACT= Best Available Control Technology
 LAER= Lowest Achievable Emission Rate

Table B-3. Capital Cost for Selective Catalytic Reduction for Westinghouse Frame 501F Simple Cycle Combustion Turbine

Cost Component	Costs	Basis of Cost Component
Direct Capital Costs		
SCR Associated Equipment	\$891,372	Vendor Based Estimate
Ammonia Storage Tank	\$128,156	\$35 per 1,000 lb mass flow developed from vendor quotes
Flue Gas Cooling	\$260,000	Vendor Based Estimate (110,000acfm)
Instrumentation	\$89,137	10% of SCR Associated Equipment
Taxes	\$131,275	6% of SCR Associated Equipment and Catalyst
Freight	\$109,396	5% of SCR Associated Equipment
Total Direct Capital Costs (TDCC)	\$1,609,336	
Direct Installation Costs		
Foundation and supports	\$232,470	8% of TDCC and RCC; OAQPS Cost Control Manual
Handling & Erection	\$406,823	14% of TDCC and RCC; OAQPS Cost Control Manual
Electrical	\$116,235	4% of TDCC and RCC; OAQPS Cost Control Manual
Piping	\$58,118	2% of TDCC and RCC; OAQPS Cost Control Manual
Insulation for ductwork	\$29,059	1% of TDCC and RCC; OAQPS Cost Control Manual
Painting	\$29,059	1% of TDCC and RCC; OAQPS Cost Control Manual
Site Preparation	\$5,000	Engineering Estimate
Buildings	\$15,000	Engineering Estimate
Total Direct Installation Costs (TDIC)	\$891,763	
Recurring Capital Costs (RCC)	\$1,296,542	Catalyst; Vendor Based Estimate
Total Capital Costs (TCC)	\$3,797,641	Sum of TDCC, TDIC and RCC
Indirect Costs		
Engineering	\$379,764	10% of Total Capital Costs; OAQPS Cost Control Manual
PSM/RMP Plan	\$50,000	Engineering Estimate
Construction and Field Expense	\$189,882	5% of Total Capital Costs; OAQPS Cost Control Manual
Contractor Fees	\$379,764	10% of Total Capital Costs; OAQPS Cost Control Manual
Start-up	\$75,953	2% of Total Capital Costs; OAQPS Cost Control Manual
Performance Tests	\$37,976	1% of Total Capital Costs; OAQPS Cost Control Manual
Contingencies	\$379,764	10% of Total Capital Costs; OAQPS Cost Control Manual
Total Indirect Capital Cost (TInCC)	\$1,493,104	
Total Direct, Indirect and Recurring Capital Costs (TDIRCC)	\$5,290,745	Sum of TCC and TInCC
Mass Flow of Combustion Turbine	4,518,595 lb/hr	"G"
	3,661,592 lb/hr	"F"

Table B-4. Annualized Cost for Selective Catalytic Reduction for Westinghouse Frame 501F Simple Cycle Operation

Cost Component	Costs	Basis of Cost Component
<u>Direct Annual Costs</u>		
Operating Personnel	18,720	24 hours/week at \$15/hr
Supervision	2,808	15% of Operating Personnel; OAQPS Cost Control Manual
Ammonia	61,054	\$300 per ton for Aqueous NH ₃
PSM/RMP Update	15,000	Engineering Estimate
Inventory Cost	47,453	Capital Recovery (10.98%) for 1/3 catalyst
Catalyst Disposal Cost	34,175	\$28/1,000 lb/hr mass flow over 3 years; developed from vendor quotes
Contingency	17,921	10% of Direct Annual Costs
Total Direct Annual Costs (TDAC)	197,132	
<u>Energy Costs</u>		
Electrical	42,000	80kW/h for SCR 200kW/h for cooling fan @ \$0.04/kWh times Capacity Factor
MW Loss and Heat Rate Penalty	246,833	0.5% of MW output; EPA, 1993 (Page 6-20)
Capacity Loss	42,922	3 days outage each 3 years; Capacity penalty of \$240,000 per % per year.
Fuel Escalation	9,953	Escalation of fuel over inflation; 3% of energy costs
Contingency	34,171	10% of Energy Costs
Total Energy Costs (TEC)	375,878	
<u>Indirect Annual Costs</u>		
Overhead	\$49,549	60% of Operating/Supervision Labor and Ammonia
Property Taxes	\$52,907	1% of Total Capital Costs
Insurance	\$52,907	1% of Total Capital Costs
Annualized Total Direct Capital	\$438,563	10.98% Capital Recovery Factor of 7% over 15 years times sum of TDCC, TDIC and TIInCC
Annualized Total Direct Recurring	\$494,112	38.11% Capital Recovery Factor of 7% over 3 years times RCC
Total Indirect Annual Costs (TIAC)	\$1,088,040	
Total Annualized Costs	\$1,661,050	Sum of TDAC, TEC and TIAC
Cost Effectiveness	\$11,850	NO _x Reduction Only
	\$18,381	Net Emission Reduction

Table B-5. Summary of Best Available Control Technology (BACT) Determinations for Carbon Monoxide (CO) Emissions

903251.F UNPMB-5.ah
10/1/99

Facility Name	State	Permit Issue Date	Unit/Process Description	Capacity (size)	CO Emission Limit	Control Method	Efficiency (%)	Type
POC EL PASO MILFORD LLC	CT	Apr-99	TURBINE, COMBUSTION, 888 GT-24E, #2 WITH 2 CHILLERS	1.97 MMCFM	13 LB/H NAT GAS	OXIDATION CATALYST	0	BACT-PSD
POC EL PASO MILFORD LLC	CT	Apr-99	TURBINE, COMBUSTION, 888 GT-24, #1 WITH 2 CHILLERS	1.97 MMCFM	13 LB/H NAT GAS	OXIDATION CATALYST	0	BACT-PSD
ALABAMA POWER COMPANY - THEODORE COGENERATION	AL	Mar-99	TURBINE, WITH DUCT BURNER	170 MW	0.068 LB/MMBTU	EFFICIENT COMBUSTION	0	BACT-PSD
MOBILE ENERGY LLC	AL	Jan-99	TURBINE, GAS, COMBINED CYCLE	168 MW	0.04 LB/MMBTU	GOOD COMBUSTION PRACTICES	0	BACT-PSD
TENASKA GEORGIA PARTNERS, L.P.	GA	Dec-98	TURBINE, COMBUSTION, SIMPLE CYCLE, 8	150 MW EA	15 PPMV @ 15% O2	USING 15% EXCESS AIR, CO EMISSION IS BECAUSE OF NATURAL GAS. CO EMISSION IS BECAUSE OF FUEL OIL WHEN OUTPUT IS BELOW 123 MW LIMIT IS 33 PPMV AND ABOVE 123 MW LIMIT IS 20 PPMV. USING 15% EXCESS AIR.	0	BACT-PSD
TENASKA GEORGIA PARTNERS, L.P.	GA	Dec-98	TURBINE, COMBUSTION, SIMPLE CYCLE, 8	160 MW EA	33 PPMV	123 MW LIMIT IS 33 PPMV AND ABOVE 123 MW LIMIT IS 20 PPMV. USING 15% EXCESS AIR.	0	BACT-PSD
WESTBROOK POWER LLC	ME	Dec-98	TURBINE, COMBINED CYCLE, TWO	526 MW TOTAL	15 PPM @ 15% O2	DRY LOW NOX BURNER GOOD COMBUSTION PRACTICE	0	BACT-PSD
SANTA ROSA ENERGY LLC	FL	Dec-98	TURBINE, COMBUSTION, NATURAL GAS	241 MW	0	0.05% SULFUR DISTILLATE OIL #2 IS USED. EMISSION IS FROM EACH 300 MW SYSTEM.	0	BACT-PSD
GORHAM ENERGY LIMITED PARTNERSHIP	ME	Dec-98	TURBINE, COMBINED CYCLE	900 MW TOTAL	5 PPM @ 15% O2 (NAT G)	3 - WAY CATALYST SYSTEM AND AIR/FUEL RATIO CONTROL-LLER.	0	BACT-PSD
WESTERN GAS RESOURCES - HILIGHT GAS PLANT	WY	Oct-98	ENGINES, COMPRESSOR, 2 EA	1650 HP	2 G/H-P-H	LEAN-BURN ENGINE DESIGN	0	BACT-PSD
WILLIAMS FIELD SERVICES	NM	Sep-98	IC ENGINE, COMPRESSOR	27240 HP	2.85 G/H-P-H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
CHAMPION INTERNATL. CORP. & CHAMP. CLEAN ENERGY	ME	Sep-98	TURBINE, COMBINED CYCLE, NATURAL GAS	175 MW	9 PPMV @ 15% O2 GAS	GOOD COMBUSTION PRACTICES	0	BACT-OTHER
TNP TECHL. LLC (FORMERLY TX-NM POWER CO.)	NM	Aug-98	GAS TURBINES	375 MMBTU/H	18 PPM	CLEAN BURN COMBUSTION TECHNOLOGY	0	BACT-PSD
WILLIAMS FIELD SERVICES CO.	NM	Jul-98	RECIPROCATING ENGINE, NAT. GAS	1375 HP	2.85 G/H-P-H	15% EXCESS AIR	0	BACT-PSD
CASCO RAY ENERGY CO	ME	Jul-98	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170 MW EACH	20 PPM @ 15% O2	GOOD COMBUSTION WITH DRY LOW NOX BURNERS OXIDATION CATALYST MAY BE USED	0	BACT-PSD
CITY OF LAKELAND ELECTRIC AND WATER UTILITIES	FL	Jul-98	TURBINE, COMBUSTION, GAS FIRED W/ FUEL OIL ALSO	2174 MMBTU/H	25 PPM	CATALYTIC OXIDATION	0	BACT-PSD
COLORADO SPRINGS UTILITIES-NIXON POWER PLANT	CO	Jun-98	SIMPLE CYCLE TURBINE, NATURAL GAS	1122 MM BTU/H	0.8 DHE	PREMIUM FUEL FAIR TO OPTIMIZE EFFICIENCY ACTUAL EMISSIONS	80	BACT-PSD
BRIDGEPORT ENERGY, LLC	CT	Jun-98	TURBINES, COMBUSTION MODEL VM4.3A, 2 SIEMES	260 MWH/HRSG PER TURBINE	10 PPM GAS & OIL	EXPECTED BETWEEN 6-7PPM	0	BACT-PSD
WILLIAMS FIELD SERVICES CO.	NM	Jun-98	RECIPROCATING ENGINES, NAT. GAS	21820 HP	2.85 G/H-P-H	LEAN BURN ENGINE DESIGN	0	BACT-PSD
ENCODEN HAWAII, L.P.	HI	Jun-98	TURBINES, COMBUSTION, 2 EA	23 MW	57.5 PPMV @ 15% O2	GOOD COMBUSTION DESIGN AND OPERATION.	0	BACT-PSD
GENERAL ELECTRIC PLASTICS	AL	May-98	COMBINED CYCLE (TURBINE AND DUCT BURNER)	0	0.08 LB/MMBTU	PROPER COMBUSTION	0	BACT-PSD
UNION PACIFIC RESOURCES - PATRICK DRAW GAS PLANT	WY	May-98	ENGINES, COMPRESSOR, 2 EA	1200 HP	2.8 G/H-P-H	ULTRA LOW NOX LEAN BURN TECHNOLOGY.	0	BACT-PSD
UNION PACIFIC RESOURCES - PATRICK DRAW GAS PLANT	WY	May-98	ENGINE, COMPRESSOR, 9 EA	3200 HP	0.5 G/H-P-H	ULTRA LOW NOX LEAN BURN TECHNOLOGY AND CATALYTIC CRACKING.	0	BACT-PSD
UNION PACIFIC RESOURCES - PATRICK DRAW GAS PLANT	WY	May-98	ENGINES, COMPRESSOR, 9 EA	3200 HP	0.5 G/H-P-H	ULTRA LOW NOX LEAN BURN TECHNOLOGY. CATALYTIC CONVERTER.	0	BACT-PSD
UNION PACIFIC RESOURCES - PATRICK DRAW GAS PLANT	WY	May-98	COMPRESSOR, ENGINES, 2 EA	1200 HP	2.8 G/H-P-H	ULTRA LOW NOX LEAN BURN TECHNOLOGY.	0	BACT-PSD
RUMFORD POWER ASSOCIATES	ME	May-98	TURBINE GENERATOR, COMBUSTION, NATURAL GAS	1908 MMBTU/H	15 PPM @ 15% O2	GE DRY LOW-NOX COMBUSTOR DESIGN. GOOD COMBUSTION CNTRL	0	BACT-PSD
WILLIAMS FIELD SERVICES CO.	NM	Apr-98	NATURAL GAS RECIPROCATING ENGINE	1478 HP	2.85 G/H-P-H	LEAN BURN DESIGN	0	BACT-PSD
WILLIAMS FIELD SERVICES CO.	NM	Apr-98	ENGINE, IC RECIPROCATING, NAT. GAS	1374 HP	2.85 G/H-P-H	CLEAN BURN COMBUSTION TECHNOLOGY	0	BACT-PSD
ANDROSOGGIN ENERGY LIMITED	ME	Mar-98	GAS TURBINES, COGEN, W/ DUCT BURNERS	675 MMBTU/H TURBINE	74.21 LB/H NO	CATALYTIC OXIDATION, GOOD COMBUSTION PRACTICES.	0	BACT-PSD
ANDROSOGGIN ENERGY LIMITED	ME	Mar-98	GAS TURBINES, COGEN, W/ DUCT BURNERS	675 MMBTU/H TURBINE	43.73 LB/H NO OIL	CATALYTIC OXIDATION, GOOD COMBUSTION PRACTICES.	0	BACT-PSD
TIVERTON POWER ASSOCIATES	RI	Feb-98	COMBUSTION TURBINE, NATURAL GAS	265 MW	12 PPM @ 15% O2	GOOD COMBUSTION	0	BACT-PSD
AIR LIQUIDE AMERICA CORPORATION	LA	Feb-98	TURBINE GAS, GE, 7ME 7	968 MMBTU/H	25 PPMV	GOOD EQUIPMENT DESIGN, PROPER COMBUSTION TECHNIQUE AND MIN. 2% EXCESS O2	0	BACT-PSD
MILLENNIUM POWER PARTNER, LP	MA	Feb-98	TURBINE, COMBUSTION, WESTINGHOUSE MODEL 501G	2534 MMBTU/H	0.07 LB/MMBTU	DRY LOW NOX COMBUSTION TECHNOLOGY IN CONJUNCTION WITH SOFA ADD-ON NOX CONTROL.	0	BACT-PSD
MAUI ELECTRIC COMPANY	HI	Jan-98	TURBINE, COMBUSTION, 2 EA	20 MW	44 PPMV @ 15% O2	GOOD COMBUSTION DESIGN AND OPERATION.	0	BACT-PSD
BAF CORPORATION	LA	Dec-97	TURBINE, COGEN UNIT 2, GE FRAME 8	42.4 MW	83.93 LB/MMBTU	GOOD DESIGN, PROPER COMBUSTION TECHNIQUES. 2% EXCESS O2	0	BACT-PSD
ARCHIE CRIPPEN	CA	Dec-97	IC ENGINE, DETROIT DIESEL, MODEL #V-92TA	500 BHP	0.61 G/H-P-H	NO CONTROL	0	BACT
WILLIAMS FIELD SERVICES-MIDDLE MESA CDP	NM	Dec-97	NATURAL GAS COMPRESSOR STATION, 14 ENGINES	1478 HP, EACH	8 LB/HR EACH ENGINE	CLEAN/LEAN BURN TECHNOLOGY	0	BACT-PSD
BUCKNELL UNIVERSITY	PA	Nov-97	NG FIRED TURBINE, SOLAR TAURUS T-7300S	5 MW	50 PPMV @ 15% O2	GOOD COMBUSTION	0	BACT-OTHER
LORDSBURG L.P.	NM	Jun-97	TURBINE, NATURAL GAS-FIRED, ELEC. GEN.	100 MW	27 LB/HR	DRY LOW-NOX TECHNOLOGY BY MAINTAINING PROPER AIR- FUEL RATIO.	0	BACT-PSD
MEAD COATED BOARD, INC.	AL	Mar-97	COMBINED CYCLE TURBINE (25 MW)	568 MMBTU/HR	28 PPMV @ 15% O2 (GAS)	PROPER DESIGN AND GOOD COMBUSTION PRACTICES	0	BACT-PSD
FORMOSA PLASTICS CORPORATION, BATON ROUGE PLANT	LA	Mar-97	TURBINE/HRSG, GAS COGENERATION	450 MM BTU/HR	70 LB/HR	COMBUSTION DESIGN AND CONSTRUCTION.	0	BACT-PSD
SOUTHWESTERN PUBLIC SERVICE COMPANY/CUNNINGHAM STA	NM	Feb-97	COMBUSTION TURBINE, NATURAL GAS	100 MW	0 SEE FACILITY NOTES	GOOD COMBUSTION PRACTICES	0	BACT-PSD
SOUTHWESTERN PUBLIC SERVICE CO/CUNNINGHAM STATION	NM	Nov-96	COMBUSTION TURBINE, NATURAL GAS	100 MW	0 SEE P2	GOOD COMBUSTION PRACTICES	0	BACT-PSD
ECOELECTRICA, L.P.	PR	Oct-96	TURBINES, COMBINED-CYCLE COGENERATION	461 MW	33 PPMV	COMBUSTION CONTROLS.	0	BACT-PSD
ECOELECTRICA, L.P.	PR	Oct-96	TURBINES, COMBINED-CYCLE COGENERATION	461 MW	100 PPMV AT MIN. LOAD	COMBUSTION CONTROLS.	0	BACT-PSD
BLUE MOUNTAIN POWER, LP	PA	Jul-96	COMBUSTION TURBINE WITH HEAT RECOVERY BOILER	153 MW	3.1 PPM @ 15% O2	OXIDATION CATALYST 18 PPM @ 15% O2 WHEN FIRING NO. 2 OIL. AT 75% NG LIMIT SET TO 22.1 PPM	80	OTHER
COMMONWEALTH CHESAPEAKE CORPORATION	VA	May-96	3 COMBUSTION TURBINES (OIL-FIRED)	8,000 HRS/YR	98 TYP	GOOD COMBUSTION OPERATING PRACTICES	0	BACT/NSPS
PORTSIDE ENERGY CORP.	IN	May-96	TURBINE, NATURAL GAS-FIRED	53 MEGAWATT	40 LB/HR	GOOD COMBUSTION AND EMISSIONS NOT TO EXCEED 40 PPMV AT 15% OXYGEN.	0	BACT-PSD
PORTSIDE ENERGY CORP.	IN	May-96	TURBINE, NATURAL GAS-FIRED	53 MEGAWATT	12 LB/HR	GOOD COMBUSTION AND EMISSIONS NOT TO EXCEED 10 PPMV AT 15% OXYGEN.	0	BACT-PSD
GENERAL ELECTRIC GAS TURBINES	SC	Apr-96	I.C. TURBINE	2,700 MMBTU/HR	27.169 LB/HR	GOOD COMBUSTION PRACTICES TO MINIMIZE EMISSIONS	0	BACT-PSD
CAROLINA POWER & LIGHT	NC	Apr-96	COMBUSTION TURBINE, 4 EACH	1,908 MMBTU/HR	81 LB/HR	COMBUSTION CONTROL	0	BACT-PSD
CAROLINA POWER & LIGHT	NC	Apr-96	COMBUSTION TURBINE, 4 EACH	1,908 MMBTU/HR	80 LB/HR	COMBUSTION CONTROL	0	BACT-PSD
SOUTH MISSISSIPPI ELECTRIC POWER ASSOC.	MS	Apr-96	COMBUSTION TURBINE, COMBINED CYCLE	1,290 MMBTU/HR NAT GAS	28.3 PPM @ 15% O2, GAS	GOOD COMBUSTION CONTROLS	0	BACT-PSD
MID-GEORGIA COGEN	GA	Apr-96	COMBUSTION TURBINE (2), FUEL OIL	118 MW	30 PPMV	COMPLETE COMBUSTION	0	BACT-PSD
MID-GEORGIA COGEN	GA	Apr-96	COMBUSTION TURBINE (2), NATURAL GAS	118 MW	10 PPMV	COMPLETE COMBUSTION	0	BACT-PSD
GEORGIA GULF CORPORATION	LA	Mar-96	GENERATOR, NATURAL GAS FIRED TURBINE	1,123 MM BTU/HR	972 TYP CAP FOR 3 TURB.	GOOD COMBUSTION PRACTICE AND PROPER OPERATION	0	BACT-PSD
SEMINOLE HARDEE UNIT 3	FL	Jan-96	COMBINED CYCLE COMBUSTION TURBINE	140 MW	20 PPM (NAT. GAS)	DRY LNB GOOD COMBUSTION PRACTICES	0	BACT-PSD
KEY WEST CITY ELECTRIC SYSTEM	FL	Sep-95	TURBINE, EXISTING CT RELOCATION TO A NEW PLANT	23 MW	20 PPM @ 15% O2 FULL LD	GOOD COMBUSTION	0	BACT-PSD
UNION CARBIDE CORPORATION	LA	Sep-95	GENERATOR, GAS TURBINE	1,313 MM BTU/HR	169 LB/HR	NO ADD-ON CONTROL GOOD COMBUSTION PRACTICE	0	BACT-PSD
PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	PR	Jul-95	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EACH	248 MW	20 LB/HR	MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND IMPLEMENT GOOD COMBUSTION PRACTICES.	0	BACT-PSD
PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	PR	Jul-95	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EACH	248 MW	104 LB/HR	MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND IMPLEMENT GOOD COMBUSTION PRACTICES.	0	BACT-PSD
BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.	NY	Jun-95	TURBINE, NATURAL GAS FIRED	240 MW	4 PPM @ 15% O2	COMBUSTION CONTROLS STANDARD ONLY APPLIES IF GE CT IS SELECTED, THE ABB CT WAS LESS THAN SIGNIFICANT EMIS. INCR FOR CO	0	LAER
PANDA-KATHLEEN, L.P.	FL	Jun-95	COMBINED CYCLE COMBUSTION TURBINE (TOTAL 116MW)	75 MW	25 PPM @ 15% O2		0	BACT-PSD
MILAGRO, WILLIAMS FIELD SERVICE	NM	May-95	TURBINE/COGEN, NATURAL GAS (2)	900 MMCF/DAY	28 PPM @ 15% O2		0	BACT-PSD
LEDERLE LABORATORIES	NY	Apr-95	(2) GAS TURBINES (EP #S 001018102)	110 MMBTU/HR	48 PPM, 12.6 LB/HR		0	BACT-OTHER
PLORFIM ENERGY CENTER	NY	Apr-95	(2) WESTINGHOUSE W501D6 TURBINES (EP #S 00001&2)	1,400 MMBTU/HR	10 PPM, 29.0 LB/HR		0	BACT-OTHER
BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT	MD	Mar-95	TURBINE, 140 MW NATURAL GAS FIRED ELECTRIC	140 MW	15.50 MM BTU/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
FORMOSA PLASTICS CORPORATION, LOUISIANA	LA	Mar-95	TURBINE/HRSG, GAS COGENERATION	450 MM BTU/HR	26 LB/HR	PROPER OPERATION	0	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	MO	Feb-95	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	89 MW	426 TYP	GOOD COMBUSTION CONTROL	0	BACT-PSD
MARATHON OIL CO. - INDIAN BASIN N.O. PLANT	NM	Jan-95	TURBINES, NATURAL GAS (2)	5,600 HP	13 LB/HR	LEAN-PREMIUM COMBUSTION TECHNOLOGY.	66	BACT-PSD
KAMINE/BECKOOP SYRACUSE LP	NY	Dec-94	SIEMENS V64.3 GAS TURBINE (EP #00001)	650 MMBTU/HR	9.5 PPM	NO CONTROLS	0	BACT-OTHER
INDECK-OSWEGO ENERGY CENTER	NY	Oct-94	GE FRAME 8 GAS TURBINE	633 LB/MMBTU	10 PPM, 10.00 LB/HR	NO CONTROLS	0	BACT-OTHER
FULTON COGEN PLANT	NY	Sep-94	GE L54500 GAS TURBINE	600 MMBTU/HR	107 PPM, 120 LB/HR	NO CONTROLS	0	BACT-OTHER
CAROLINA POWER AND LIGHT	SC	Aug-94	STATIONARY GAS TURBINE	1,520 MMBTU/H	792 LB/HR	PROPER OPERATION TO ACHIEVE GOOD COMBUSTION	0	BACT-PSD
CAROLINA POWER AND LIGHT	SC	Aug-94	STATIONARY GAS TURBINE	1,620 MMBTU/H	144 LB/HR	PROPER OPERATION TO ACHIEVE GOOD COMBUSTION	0	BACT-PSD
SNYDER OIL CORPORATION-RIVERTON DOME GAS PLANT	WY	Jul-94	NATURAL GAS-FIRED COMPRESSOR ENGINE	620 HORSEPOWER	1.7 LB/HR	GOOD COMBUSTION	0	BACT
SNYDER OIL CORPORATION-RIVERTON DOME GAS PLANT	WY	Jul-94	2 GAS-FIRED GENERATOR ENGINES	365 HORSEPOWER	1.3 LB/HR	GOOD COMBUSTION	0	BACT
SNYDER OIL CORPORATION-RIVERTON DOME GAS PLANT	WY	Jul-94	1 GAS-FIRED GENERATOR ENGINE	577 HORSEPOWER	1.9 LB/HR	GOOD COMBUSTION	0	BACT
COLORADO POWER PARTNERSHIP	CO	Jul-94	TURBINES, 2 NAT GAS & 2 DUCT BURNERS	365 MMBTU/H EACH TURBINE	22 PPM @ 15% O2		0	BACT-PSD
MUDDY RIVER L.P.	NV	Jun-94	COMBUSTION TURBINE, DIESEL & NATURAL GAS	140 MEGAWATT	77 LB/HR	FUEL SPEC: NATURAL GAS	0	BACT-PSD

Table B-5. Summary of Best Available Control Technology (BACT) Determinations for Carbon Monoxide (CO) Emissions

Facility Name	State	Permit Issue Date	Unit/Process Description	Capacity (size)	CO Emission Limit	Control Method	Efficiency (%)	Type
CSW NEVADA, INC.	NV	Jun-94	COMBUSTION TURBINE, DIESEL & NATURAL GAS	140 MEGAWATT	83 LB/HR	FUEL SPEC: NATURAL GAS	0	BACT-PSD
PORTLAND GENERAL ELECTRIC CO.	OR	May-94	TURBINES, NATURAL GAS (2)	1,720 MMBTU/H	15 PPM @ 15% O ₂	GOOD COMBUSTION PRACTICES	0	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	MO	May-94	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	1,345 MMBTU/H	120 TPD	NONE	0	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	MO	May-94	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	1,345 MMBTU/H	120 TPD	NONE	0	BACT-PSD
NAVY PUBLIC WORKS CENTER	VA	May-94	1 EMERGENCY GENERATOR	1,500 KW	14.4 TPD	RETARD TIMING 6 DEGREES	0	NSPS
WEST CAMPUS COGENERATION COMPANY	TX	Apr-94	GAS TURBINE	75 MW (TOTAL POWER)	300 TPD	INTERNAL COMBUSTION CONTROLS	0	BACT
HERMISTON GENERATING CO.	TX	Apr-94	TURBINES, NATURAL GAS (2)	1,696 MMBTU/H	15 PPM @ 15% O ₂	GOOD COMBUSTION PRACTICES	0	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	FL	Feb-94	TURBINE, NATURAL GAS (2)	1,510 MMBTU/H	25 PPMVD	GOOD COMBUSTION PRACTICES	0	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	FL	Feb-94	TURBINE, FUEL OIL (2)	1,730 MMBTU/H	30 PPMVD	GOOD COMBUSTION PRACTICES	0	BACT-PSD
TECO POLK POWER STATION	FL	Feb-94	TURBINE, SYNGAS (COAL GASIFICATION)	1,755 MMBTU/H	25 PPMVD	GOOD COMBUSTION	0	BACT-PSD
TECO POLK POWER STATION	FL	Feb-94	TURBINE, FUEL OIL	1,755 MMBTU/H	40 PPMVD	GOOD COMBUSTION	0	BACT-PSD
INTERNATIONAL PAPER	LA	Feb-94	TURBINE/HSG, GAS COGEN	338 MM BTU/HR TURBINE	186 LB/HR	COMBUSTION CONTROL	0	BACT
KAMINIESCORP CARTHAGE L.P.	NY	Jan-94	GE FRAME 6 GAS TURBINE	491 BTU/HR	10 PPM, 11.0 LB/HR	NO CONTROLS	0	BACT-OTHER
ORANGE COGENERATION L.P.	FL	Dec-93	TURBINE, NATURAL GAS, 2	368 MMBTU/H	30 PPMVD	GOOD COMBUSTION	0	BACT-PSD
PROJECT ORANGE ASSOCIATES	NY	Dec-93	GE LM-5000 GAS TURBINE	550 MMBTU/HR	92 LB/HR TEMP > 20F	NO CONTROLS	0	BACT-OTHER
WILLIAMS FIELD SERVICES CO. - EL CEDRO COMPRESSOR	NM	Oct-93	TURBINE, GAS-FIRED	11,257 HP	50 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
PATOWACK POWER PARTNERS, LIMITED PARTNERSHIP	VA	Sep-93	TURBINE, COMBUSTION, SIEMENS MODEL V84.2.3	10.2 X109 SCF/YR NAT GAS	26 LB/HR	GOOD COMBUSTION OPERATING PRACTICES	0	BACT-PSD
FLORIDA GAS TRANSMISSION COMPANY	AL	Aug-93	TURBINE, NATURAL GAS	12,800 BHP	0.42 GM/HP HR	AIR-TO-FUEL RATIO CONTROL DRY COMBUSTION CONTROLS	0	BACT-PSD
LOCKPORT COGEN FACILITY	NY	Jul-93	(6) GE FRAME 8 TURBINES (EP #S 00001-00006)	424 MMBTU/HR	10 PPM	NO CONTROLS	0	BACT-OTHER
AMTEC COGEN PLANT	NY	Jul-93	GE LM5000 COMBINED CYCLE GAS TURBINE EP #00001	451 MMBTU/HR	36 PPM, 33 LB/HR	BAFFLE CHAMBER	80	SEE NOTE #4
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NJ	Jun-93	TURBINES, COMBUSTION, KEROSENE-FIRED (2)	640 MMBTU/H (EACH)	2.6 PPMVD	OXIDATION CATALYST	0	OTHER
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NJ	Jun-93	TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)	617 MMBTU/HR (EACH)	1.5 PPMVD	OXIDATION CATALYST	0	OTHER
PSI ENERGY, INC. WABASH RIVER STATION	IN	May-93	COMBINED CYCLE SYNGAS TURBINE	1,775 MMBTU/HR	15 LESS THAN PPM	CYCLE SYNGAS TURBINE	0	BACT-PSD
TIGER BAY LP	FL	May-93	TURBINE, OIL	1,850 MMBTU/H	98.4 LB/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
TIGER BAY LP	FL	May-93	TURBINE, GAS	1,815 MMBTU/H	48 LB/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
INDECK ENERGY COMPANY	NY	May-93	GE FRAME 8 GAS TURBINE EP #00001	491 MMBTU/HR	40 PPM	NO CONTROLS	0	BACT-OTHER
TRIGEN MITCHELL FIELD	FL	Apr-93	GE FRAME 9 GAS TURBINE	425 MMBTU/HR	10 PPM, 10.0 LB/HR	NO CONTROLS	0	BACT-OTHER
KISSIMMEE UTILITY AUTHORITY	FL	Apr-93	TURBINE, FUEL OIL	928 MMBTU/H	65 LB/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	FL	Apr-93	TURBINE, FUEL OIL	371 MMBTU/H	78 LB/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	FL	Apr-93	TURBINE, NATURAL GAS	869 MMBTU/H	54 LB/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	FL	Apr-93	TURBINE, NATURAL GAS	387 MMBTU/H	40 LB/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
EAST KENTUCKY POWER COOPERATIVE	KY	Mar-93	TURBINES (3), #2 FUEL OIL AND NAT. GAS FIRED	1,492 MMBTU/H (EACH)	75 LB/SH (EACH)	PROPER COMBUSTION TECHNIQUES	0	BACT-OTHER
INTERNATIONAL PAPER CO. RIVERDALE MILL	AL	Sep-92	TURBINE, STATIONARY (GAS-FIRED) WITH DUCT BURNER	400 MW	22 LB/HR	GOOD COMBUSTION PRACTICES	0	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	FL	Dec-92	TURBINE, OIL	1,170 MMBTU/H	25 PPMVD	GOOD COMBUSTION PRACTICES	0	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	FL	Dec-92	TURBINE, GAS	1,214 MMBTU/H	15 PPMVD	GOOD COMBUSTION PRACTICES	0	BACT-PSD
SITHE/INDEPENDENCE POWER PARTNERS	NY	Nov-92	TURBINES, COMBUSTION (4) (NATURAL GAS) (1012 MW)	2,133 MMBTU/HR (EACH)	13 PPM	COMBUSTION CONTROLS	0	BACT-OTHER
KAMINIESCORP BEAVER FALLS COGENERATION FACILITY	NY	Nov-92	TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (70MW)	650 MMBTU/HR	9.5 PPM	COMBUSTION CONTROLS	0	BACT-OTHER
GRAY'S FERRY CO. GENERATION PARTNERSHIP	PA	Nov-92	TURBINE (NATURAL GAS & OIL)	1,150 MMBTU	0.0055 LB/MMBTU (GAS)	COMBUSTION	0	BACT-OTHER
BEAR ISLAND PAPER COMPANY, L.P.	VA	Oct-92	TURBINE, COMBUSTION GAS	468 X10(6) BTU/HR #2 OIL	11 LB/SHR	GOOD COMBUSTION	0	BACT-PSD
BEAR ISLAND PAPER COMPANY, L.P.	VA	Oct-92	TURBINE, COMBUSTION GAS (TOTAL)	478 X10(6) BTU/HR N. GAS	40 PPM	GOOD COMBUSTION	0	BACT-PSD
BEAR ISLAND PAPER COMPANY, L.P.	VA	Oct-92	TURBINE, COMBUSTION GAS	474 X10(6) BTU/HR N. GAS	11 LB/SHR	GOOD COMBUSTION	0	BACT-PSD
PHILADELPHIA SOUTHWEST WATER TREATMENT PLANT	PA	Oct-92	ENGINES (2) (NATURAL GAS)	443 KW (EACH)	0	LEAN BURN ENGINE	0	OTHER
PHILADELPHIA NORTHEAST WATER TREATMENT PLANT	PA	Oct-92	ENGINES (3) (NATURAL GAS)	443 KW (EACH)	0	LEAN BURN ENGINE	0	OTHER
GORDONVILLE ENERGY L.P.	VA	Sep-92	TURBINE FACILITY, GAS	7.44 X10(7) OPY FUEL OIL	250 TOTAL TPD	GOOD COMBUSTION PRACTICES	0	BACT-PSD
GORDONVILLE ENERGY L.P.	VA	Sep-92	TURBINES (2) [EACH WITH A SF]	1.36 X10(9) BTU/H #2 OIL	86 LB/SHR/UNIT	GOOD COMBUSTION PRACTICES	0	BACT-PSD
GORDONVILLE ENERGY L.P.	VA	Sep-92	TURBINE FACILITY, GAS	1,331 X10(7) SCF/YR NAT GAS	250 TOTAL TPD	GOOD COMBUSTION PRACTICES	0	BACT-PSD
GORDONVILLE ENERGY L.P.	VA	Sep-92	TURBINES (2) [EACH WITH A SF]	1.51 X10(9) BTU/HR N GAS	57 LB/SHR/UNIT	GOOD COMBUSTION PRACTICES	0	BACT-PSD
NEVADA POWER COMPANY, HARRY ALLEN PEAKING PLANT	NV	Sep-92	COMBUSTION TURBINE ELECTRIC POWER GENERATION	600 MW (8 UNITS 75 EACH)	153 TPD (EACH TURBINE)	PRECISION CONTROL FOR THE LOW NOX COMBUSTOR	0	BACT-PSD
KAMINE SOUTH GLENS FALLS COGEN CO	NY	Sep-92	GE FRAME 8 GAS TURBINE	486 MMBTU/HR	9 PPM, 11.0 LB/HR	NO CONTROLS	0	BACT-OTHER
NORTHERN STATES POWER COMPANY	SD	Sep-92	TURBINE, SIMPLE CYCLE, 4 EACH	129 MW	50 PPM FOR GAS	GOOD COMBUSTION TECHNIQUES	0	BACT-PSD
PASNY/HOLTSVILLE COMBINED CYCLE PLANT	NY	Sep-92	TURBINE, COMBUSTION GAS (150 MW)	1,146 MMBTU/HR (GAS)	6.5 PPM	COMBUSTION CONTROL	0	BACT-OTHER
WEPCU, PARIS SITE	WI	Aug-92	TURBINES, COMBUSTION (4)	0	25 LB/SHR (SEE NOTES)	0	BACT-PSD	
FLORIDA POWER CORPORATION	FL	Aug-92	TURBINE, OIL	1,029 MMBTU/H	54 LB/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
FLORIDA POWER CORPORATION	FL	Aug-92	TURBINE, OIL	1,868 MMBTU/H	78 LB/H	GOOD COMBUSTION PRACTICES	0	BACT-PSD
CNO TRANSMISSION	OH	Aug-92	TURBINE (NATURAL GAS) (3)	5,800 HP (EACH)	0.015 GM/HP-HR	FUEL SPEC: USE OF NATURAL GAS	0	OTHER
SARANAC ENERGY COMPANY	NY	Jul-92	TURBINES, COMBUSTION (2) (NATURAL GAS)	1,123 MMBTU/HR (EACH)	3 PPM	OXIDATION CATALYST	0	BACT-OTHER
HARTWELL ENERGY LIMITED PARTNERSHIP	GA	Jul-92	TURBINE, OIL FIRED (2 EACH)	1,840 M BTU/HR	25 PPMVD @ FULL LOAD	FUEL SPEC: CLEAN BURNING FUELS	0	BACT-PSD
MAUI ELECTRIC COMPANY, LTD./MAALAE GENERATING STA	HI	Jul-92	TURBINE, COMBINED-CYCLE COMBUSTION	28 MW	27 LB/HR	COMBUSTION TECHNOLOGY/DESIGN	0	BACT-OTHER
HARTWELL ENERGY LIMITED PARTNERSHIP	GA	Jul-92	TURBINE, GAS FIRED (2 EACH)	1,817 M BTU/HR	25 PPMVD @ FULL LOAD	FUEL SPEC: CLEAN BURNING FUELS	0	BACT-PSD
INDECK/VERKES ENERGY SERVICES	NY	Jun-92	GE FRAME 8 GAS TURBINE (EP #00001)	432 MMBTU/HR	10 PPM, 10 LB/HR	NO CONTROLS	0	BACT-OTHER
SELKIRK COGENERATION PARTNERS, L.P.	NY	Jun-92	COMBUSTION TURBINES (2) (252 MW)	1,173 MMBTU/HR (EACH)	10 PPM	COMBUSTION CONTROLS	0	BACT-OTHER
SELKIRK COGENERATION PARTNERS, L.P.	NY	Jun-92	COMBUSTION TURBINE (70 MW)	1,173 MMBTU/HR	25 PPM	COMBUSTION CONTROL	0	BACT-OTHER
TENASKA WASHINGTON PARTNERS, L.P.	WA	May-92	COGENERATION PLANT, COMBINED CYCLE	1.83 MMBTU/HR	20 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO.	RI	Apr-92	TURBINE, GAS AND DUCT BURNER	1,380 MMBTU/H EACH	11 PPM @ 15% O ₂ , GAS	0	BACT-PSD	
KENTUCKY UTILITIES COMPANY	KY	Mar-92	TURBINE, #2 FUEL OIL/NATURAL GAS (8)	1,600 MM BTU/HR (EACH)	76 LB/HR (EACH)	COMBUSTION CONTROL	0	BACT-PSD
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	VA	Mar-92	TURBINE, COMBUSTION	1,175 MMBTU/H NAT. GAS	62 LB/HR/UNIT	FURNACE DESIGN	91	BACT-PSD
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	VA	Mar-92	TURBINE, COMBUSTION	1,117 MMBTU/H NO2 FUEL OIL	62 LB/HR/UNIT	FURNACE DESIGN	91	BACT-PSD
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	VA	Mar-92	TURBINE, COMBUSTION	0	228 TPD/UNIT	0	BACT-PSD	
THERMO INDUSTRIES, LTD.	CO	Feb-92	TURBINE, GAS FIRED, 5 EACH	246 MMBTU/H	25 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
HAWAII ELECTRIC LIGHT CO., INC.	HI	Feb-92	TURBINE, FUEL OIL #2	20 MW	27 LB/HR @ 100% PEAKLD	COMBUSTION DESIGN	0	BACT-PSD
HAWAII ELECTRIC LIGHT CO., INC.	HI	Feb-92	TURBINE, FUEL OIL #2	20 MW	56 LB/H @ 75-100% PKLD	COMBUSTION DESIGN	0	BACT-PSD
HAWAII ELECTRIC LIGHT CO., INC.	HI	Feb-92	TURBINE, FUEL OIL #2	20 MW	181 LB/H @ 50-75% PKLD	COMBUSTION DESIGN	0	BACT-PSD
HAWAII ELECTRIC LIGHT CO., INC.	HI	Feb-92	TURBINE, FUEL OIL #2	20 MW	476 LB/H @ 25-50% PKLD	COMBUSTION DESIGN	0	BACT-PSD
SAVANNAH ELECTRIC AND POWER CO.	GA	Feb-92	TURBINES, 8	1,032 MMBTU/H, NAT GAS	9 PPM @ 15% O ₂	FUEL SPEC: LOW SULFUR FUEL OIL	0	BACT-PSD
SAVANNAH ELECTRIC AND POWER CO.	GA	Feb-92	TURBINES, 8	972 MMBTU/H, #2 OIL	9 PPM @ 15% O ₂	FUEL SPEC: LOW SULFUR FUEL OIL	0	BACT-PSD
KAMINIESCORP NATURAL GAS LP	NY	Dec-91	GE FRAME 8 GAS TURBINE	800 MMBTU/HR	0.02 LB/MMBTU, 10 LB/HR	NO CONTROLS	0	BACT-OTHER
DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	NC	Dec-91	TURBINE, COMBUSTION	1,247 MM BTU/HR	60 LB/HR	COMBUSTION CONTROL	0	BACT-OTHER
DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	NC	Dec-91	TURBINE, COMBUSTION	1,313 MM BTU/HR	60 LB/HR	COMBUSTION CONTROL	0	BACT-PSD
MAUI ELECTRIC COMPANY, LTD.	HI	Dec-91	TURBINE, FUEL OIL #2	28 MW	0 SEE NOTES	GOOD COMBUSTION PRACTICES	0	BACT-PSD
KALAMAZOO POWER LIMITED	MI	Dec-91	TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS	1,806 MMBTU/H	20 PPMV	DRY LOW NOX TURBINES	0	BACT-PSD
LAKE COGEN LIMITED	FL	Nov-91	TURBINE, OIL, 2 EACH	42 MW	78 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
LAKE COGEN LIMITED	FL	Nov-91	TURBINE, GAS, 2 EACH	42 MW	42 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
ORLANDO UTILITIES COMMISSION	FL	Nov-91	TURBINE, GAS, 4 EACH	35 MW	10 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
ORLANDO UTILITIES COMMISSION	FL	Nov-91	TURBINE, OIL, 4 EACH	35 MW	25 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
SOUTHERN CALIFORNIA GAS	CA	Oct-91	TURBINE, GAS-FIRED	46 MMBTU/H	7.74 PPM @ 15% O ₂	HIGH TEMPERATURE OXIDATION CATALYST	80	BACT-PSD
SOUTHERN CALIFORNIA GAS	CA	Oct-91	TURBINE, GAS FIRED, SOLAR MODEL H	5,600 HP	7.74 PPM @ 15% O ₂	HIGH TEMP OXIDATION CATALYST	80	BACT-PSD
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, GAS, SOLAR CENTAUR H	5,600 HP	10.5 PPM @ 15% O ₂	FUEL SPEC: LEAN FUEL MIX	0	BACT-PSD
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, GAS, SOLAR CENTAUR H	5,600 HP	10.5 PPM @ 15% O ₂	FUEL SPEC: LEAN FUEL MIX	0	BACT-PSD
FLORIDA POWER GENERATION	FL	Oct-91	TURBINE, OIL, 8 EACH	63 MW	54 LB/H	COMBUSTION CONTROL	0	BACT-PSD
EL PASO NATURAL GAS	AZ	Oct-91	TURBINE, NAT. GAS TRANSM., GE FRAME 3	12,000 HP	60 PPM @ 15% O ₂	LEAN BURN	0	BACT-PSD
CAROLINA POWER AND LIGHT CO.	SC	Sep-91	TURBINE, I.C.	80 MW	60 LB/H	0	BACT-PSD	
ENRON LOUISIANA ENERGY COMPANY	LA	Aug-91	TURBINE, GAS, 2	39 MMBTU/H	60 PPM @ 15% O ₂	BASE CASE, NO ADDITIONAL CONTROLS	0	BACT-PSD
ALCONQUIN GAS TRANSMISSION CO.	RI	Jul-91	TURBINE, GAS, 2	49 MMBTU/H	0.114 LB/MMBTU	GOOD COMBUSTION PRACTICES	0	BACT-OTHER
CHARLES LARSEN POWER PLANT	FL	Jul-91	TURBINE, OIL, 1 EACH	60 MW	25 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
CHARLES LARSEN POWER PLANT	FL	Jul-91	TURBINE, GAS, 1 EACH	60 MW	25 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
SUMAS ENERGY INC.	WA	Jun-91	TURBINE, NATURAL GAS	66 MW	6 PPM @ 15% O ₂	CO CATALYST	80	BACT-PSD
SAGUARO POWER COMPANY	NV	Jun-91	COMBUSTION TURBINE GENERATOR	34.5 MW	9 PPM	CONVERTER (CATALYTIC)	90	BACT-PSD

Table B-5. Summary of Best Available Control Technology (BACT) Determinations for Carbon Monoxide (CO) Emissions

Facility Name	State	Permit Issue Date	Unit/Process Description	Capacity (size)	CO Emission Limit	Control Method	Efficiency (%)	Type
FLORIDA POWER AND LIGHT	FL	Jun-91	TURBINE, OIL, 2 EACH	400 MW	33 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
FLORIDA POWER AND LIGHT	FL	Jun-91	TURBINE, GAS, 4 EACH	400 MW	30 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
FLORIDA POWER AND LIGHT	FL	Jun-91	TURBINE, CO, 4 EACH	400 MW	33 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
NORTHERN CONSOLIDATED POWER	PA	May-91	TURBINES, GAS, 2	34.6 KW EACH	110 T/YR	OXIDATION CATALYST	90	OTHER
LAKEWOOD COGENERATION, L.P.	NJ	Apr-91	TURBINES (#2 FUEL OIL) (2)	1,190 MMBTU/HR (EACH)	0.06 LB/MMBTU	TURBINE DESIGN	0	BACT-OTHER
LAKEWOOD COGENERATION, L.P.	NJ	Apr-91	TURBINES (NATURAL GAS) (2)	1,190 MMBTU/HR (EACH)	0.026 LB/MMBTU	TURBINE DESIGN	0	BACT-OTHER
CIMARRON CHEMICAL	CO	Mar-91	TURBINE #2, GE FRAME 6	33 MW	260 T/YR, LESS THAN	CO CATALYST	0	OTHER
FLORIDA POWER AND LIGHT	FL	Mar-91	TURBINE, GAS, 4 EACH	240 MW	30 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
FLORIDA POWER AND LIGHT	FL	Mar-91	TURBINE, OIL, 4 EACH	0	33 PPM @ 15% O ₂	COMBUSTION CONTROL	0	BACT-PSD
NEVADA COGENERATION ASSOCIATES #2	NV	Jan-91	COMBINED-CYCLE POWER GENERATION	85 MW POWER OUTPUT	40 LBS/HR	CATALYTIC CONVERTER	0	BACT-PSD
NEVADA COGENERATION ASSOCIATES #1	NV	Jan-91	COMBINED-CYCLE POWER GENERATION	85 MW TOTAL OUTPUT	40 LBS/HR	CATALYTIC CONVERTER	0	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP	NJ	Nov-90	TURBINE, NATURAL GAS FIRED	585 MMBTU/HR	0.0065 LB/MMBTU	CATALYTIC OXIDATION	80	BACT-PSD
TBG COGEN COGENERATION PLANT	NY	Aug-90	GE LM2500 GAS TURBINE	215 MMBTU/HR	0.181 LB/MMBTU	CATALYTIC OXIDIZER	80	SACT
SC ELECTRIC AND GAS COMPANY - HAGOOD STATION	SC	Dec-89	INTERNAL COMBUSTION TURBINE	110 MEGAWATTS	23 LBS/HR	GOOD COMBUSTION PRACTICES	0	BACT-PSD
PEABODY MUNICIPAL LIGHT PLANT	MA	Nov-89	TURBINE, 38 MW NATURAL GAS FIRED	412 MMBTU/HR	40 PPM @ 15% O ₂	GOOD COMBUSTION PRACTICES	0	BACT-OTHER
MEGARACINE ASSOCIATES, INC	NY	Aug-89	GE LM5000-N COMBINED CYCLE GAS TURBINE	401 LB/MMBTU	0.026 LB/MMBTU, 11 LBS/HR	NO CONTROLS	0	BACT-OTHER
UNOCAL	CA	Jul-89	TURBINE, GAS (SEE NOTES)	0	10 PPM @ 15% O ₂	OXIDATION CATALYST	75	BACT-OTHER

Note: PSD= Prevention of Significant Deterioration
 BACT= Best Available Control Technology
 LAER= Lowest Achievable Emission Rate

Table B-6. Direct and Indirect Capital Costs for CO Catalyst, Simple Cycle Mode

Cost Component	Costs	Basis of Cost Component
Direct Capital Costs		
CO Associated Equipment and Stack	\$235,000	Vendor Based Quote, Stack modifications
Instrumentation	\$23,500	10% of SCR Associated Equipment
Sales Tax		6% of SCR Associated Equipment/Catalyst
Freight	\$45,176	5% of SCR Associated Equipment/Catalyst
Total Direct Capital Costs (TDCC)	\$303,676	
Direct Installation Costs		
Foundation and supports	\$77,776	8% of TDCC and RCC; OAQPS Cost Control Manual
Handling & Erection	\$136,109	14% of TDCC and RCC; OAQPS Cost Control Manual
Electrical	\$38,888	4% of TDCC and RCC; OAQPS Cost Control Manual
Piping	\$19,444	2% of TDCC and RCC; OAQPS Cost Control Manual
Insulation for ductwork	\$9,722	1% of TDCC and RCC; OAQPS Cost Control Manual
Painting	\$9,722	1% of TDCC and RCC; OAQPS Cost Control Manual
Site Preparation	\$5,000	Engineering Estimate
Buildings	\$0	
Total Direct Installation Costs (TDIC)	\$296,662	
Recurring Capital Costs (RCC)	\$668,529	Catalyst; Vendor Based Estimate
Total Capital Costs	\$1,268,868	Sum of TDCC, TDIC and RCC
Indirect Costs		
Engineering	\$126,887	10% of Total Capital Costs; OAQPS Cost Control Manual
Construction and Field Expense	\$63,443	5% of Total Capital Costs; OAQPS Cost Control Manual
Contractor Fees	\$126,887	10% of Total Capital Costs; OAQPS Cost Control Manual
Start-up	\$25,377	2% of Total Capital Costs; OAQPS Cost Control Manual
Performance Tests	\$12,689	1% of Total Capital Costs; OAQPS Cost Control Manual
Contingencies	\$126,887	10% of Total Capital Costs; OAQPS Cost Control Manual
Total Indirect Capital Cost (TInDC)	\$482,170	
Total Direct, Indirect and Recurring Capital Costs (TDIRCC)	\$1,751,037	Sum of TCC and TInCC
Mass Flow of Combustion Turbine	4,518,595 lb/hr	*G*
	3,661,592 lb/hr	*F*

Table B-7. Annualized Cost for CO Catalyst, Simple Cycle Mode

Cost Component	Cost	Basis of Cost Estimate
Direct Annual Costs		
Operating Personnel	\$6,240	8 hours/week at \$15/hr
Supervision	\$936	15% of Operating Personnel; OAQPS Cost Control Manual
Inventory Cost	\$24,468	Capital Recovery (10.98%) for 1/3 catalyst
Catalyst Disposal Cost	\$34,175	\$28/1,000 lb/hr mass flow over 3 yrs; developed from vendor quotes
Contingency	\$6,582	10% of Direct Annual Costs
Total Direct Annual Costs (TDAC)		
Energy Costs		
Heat Rate Penalty	\$98,733	0.2% of MW output; EPA, 1993 (Page 6-20) and \$3/mmBtu addl fuel costs
MW Loss Penalty	\$44,750	2 days replacement energy costs @ \$0.01 kWh each three period
Fuel Escalation	\$4,305	Escalation of fuel over inflation; 3% of energy costs
Contingency	\$14,779	10% of Energy Costs
Total Energy Costs (TEC)		
Indirect Annual Costs		
Overhead	\$4,306	60% of Operating/Supervision Labor and Ammonia
Property Taxes	\$17,510	1% of Total Capital Costs
Insurance	\$17,510	1% of Total Capital Costs
Annualized Total Direct Capital	\$118,859	10.98% Capital Recy Factor of 7% over 15 yrs times sum of TDCC, TDIC, & TIACC
Annualized Total Direct Recurring	\$254,777	38.11% Capital Recovery Factor of 7% over 3 years times RCC
Total Indirect Annual Costs		
Total Annualized Costs		
Cost Effectiveness		
	\$575,529	Sum of TDAC, TEC and TIAC
	\$4,151	Simple Cycle Combustion Turbine
	\$4,294	Net Emission Reduction

APPENDIX C

AIR QUALITY MODELING PROTOCOL DOCUMENTS



"Chris Carlson TAL 850/921-9537" <Chris.Carlson@dep.state.fl.us> on
08/09/99 12:53:40 PM

To: Starla S Lacy/NGCCorp@NGCCorp
cc: Alvaro Linero TAL <Alvaro.Linero@dep.state.fl.us>, Cleve Holladay TAL
<Cleve.Holladay@dep.state.fl.us>

Subject:

Dear Ms. Lacy,

I am writing this e-mail to inform you that I have completed my review of the modeling protocol for the Palmetto Power Project in Osceola County, Florida. The protocol appears to be complete, and I do not have any additional requests at this time. Also, I forwarded a copy of the protocol to the National Park Service, and they stated that a Class I Impact Analysis would not be required for this project. Please contact me if you have any further questions about the dispersion modeling requirements for this project.

Sincerely,
Chris Carlson
Meteorologist
Florida Dept. of Environmental Protection
Division of Air Resources Management
2600 Blair Stone Road
MS # 5505
Tallahassee, FL 32399-2400
phone: (850)921-9537
fax: (850)922-6979
Chris.Carlson@dep.state.fl.us

Dynegy Inc.
1000 Louisiana Street, Suite 5800
Houston, Texas 77002
Phone 713.507.6400
www.dynegy.com



July 26, 1999

Florida Department of Environmental Protection
Bureau of Air Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Attention: Mr. A.A. Linero, P.E.

RE: DYNEGY INC.
AIR DISPERSION MODELING PROTOCOL FOR PREVENTION OF
SIGNIFICANT DETERIORATION APPLICATION
PALMETTO POWER PROJECT, OSCEOLA COUNTY, FLORIDA

Dear Mr. Linero:

Dynegy Inc. is proposing to construct and operate an independent power production facility capable of generating a nominal net electrical output of 540 megawatts (MW) in Osceola County, Florida. The proposed project, named Palmetto Power L.L.C., will consist of three combustion turbines (generating approximately 180 MW each) operating in simple cycle mode only. Each combustion turbine will be fired by natural gas only. This project is scheduled for second quarter 2002 completion. The facility will be designed for peaking service with up to 3,000 hours per year of operation.

Under new source review requirements for Prevention of Significant Deterioration (PSD), the proposed project will be considered a major source for nitrogen oxides (NO_x), total particulate matter (PM), particulate matter with aerodynamic diameters less than 10 microns (PM₁₀), and carbon monoxide (CO).

This protocol presents the air dispersion modeling methodology to be used for the PSD analysis, including a discussion of the site geography; air dispersion model to be used; meteorological data; emissions, stack, and building data; receptor locations; and additional impact analyses.

Air Dispersion Model

The air dispersion modeling analysis will be conducted in accordance with air modeling guidelines recommended by the Florida Department of Environmental Protection (DEP). Based on the types of sources for the project, the Industrial Source Complex Short-term (ISCST3, Version 98356) will be used to predict air quality impacts in all areas that are

beyond the project's property boundary. This is latest version of the ISCST3 model available from EPA. All modeling analyses will use the EPA default regulatory options.

Site Geography

The project site is approximately 12 kilometers (km) west of Cocoa. The site is about 20 ft above mean sea level (msl). Around the site, the terrain is flat with elevations at or less than 20 ft above msl.

Since the proposed stack heights for the combustion turbines will be 50 ft, the surrounding terrain is well below the proposed stack top heights. Therefore, the surrounding terrain can be considered as simple (i.e., less than stack top); the simple terrain option will be assumed for the air modeling analysis.

Based on topographical maps of the project site, the land use within a 3-km radius of the site can be classified as rural. As a result, the rural option will be selected in the model.

Meteorological Data

Meteorological data will consist of a 5-year record of hourly surface data from Orlando and upper air observations from Ruskin for the years 1987 to 1991. These data are assumed to be representative of the project site because both the project site and the weather station from Orlando are located in rural areas and are situated in central Florida to experience similar weather conditions, such as frontal passages. These data have been accepted for use by the DEP in other PSD permit applications to address air quality impacts for other proposed sources locating in this county and adjacent counties.

Significant Impact Analysis

Based on air modeling results for similar projects, the project's impacts are expected to be below the EPA Class II significant impact levels (SIL) for all pollutants. Therefore, PSD incremental and NAAQS analyses would not be required. If more detailed modeling indicates that the proposed project's emissions result in predicted ambient air quality impacts above the EPA Class II SIL, discussions will be held with the DEP and emission inventory data of background sources will be obtained as needed.

The nearest PSD Class I areas to the project site are the Chassahowitzka National Wilderness Area (NWA) and the Everglades National Park which are located about 170 and 220 km, respectively, from the site. Other PSD Class I areas are located more than 250 km away from the project site.

Since the project site is more than 150 km away from the Class I areas, it is not expected that the project's emissions will have a significant impact

on these Class I areas. Discussions will be held with the DEP and National Park Service to determine if an air modeling analysis will be required.

Building Data Processing

Building dimensions for the project's structures will be entered into the EPA's Building Profile Input Program (BPIP, Version 95086) for the purpose of obtaining direction-specific building heights and widths for all downwash-affected sources. The direction-specific building dimensions will be input to the ISCST3 model for processing.


Additional Impact Analysis

In addition to the air quality impact analyses, additional analyses will evaluate impairment to visibility and the impact of the proposed project on soils and vegetation. Impacts as a result of general commercial, residential, industrial, and other growth associated with the proposed project will also be addressed.

Please call me at (713) 767-8961 or Bob McCann at Golder Associates Inc. at (352) 336-5600 if you have any questions or comments on the protocol. Dynegey Inc. greatly appreciates the assistance of the DEP on this important project.

Very truly yours,

DYNEGY INC.



Starla Lacy
Environmental Specialist

cc: R.C.McCann, Golder
File

APPENDIX D

BUILDING DOWNWASH INFORMATION FROM BPIP

APPENDIX E

DETAILED SUMMARY OF ISCST MODEL RESULTS

APPENDIX C

AIR QUALITY MODELING PROTOCOL DOCUMENTS



"Chris Carlson TAL 850/921-9537" <Chris.Carlson@dep.state.fl.us> on
08/09/99 12:53:40 PM

To: Starla S Lacy/NGCCorp@NGCCorp
cc: Alvaro Linero TAL <Alvaro.Linero@dep.state.fl.us>, Cleve Holladay TAL
<Cleve.Holladay@dep.state.fl.us>

Subject:

Dear Ms. Lacy,

I am writing this e-mail to inform you that I have completed my review of the modeling protocol for the Palmetto Power Project in Osceola County, Florida. The protocol appears to be complete, and I do not have any additional requests at this time. Also, I forwarded a copy of the protocol to the National Park Service, and they stated that a Class I Impact Analysis would not be required for this project. Please contact me if you have any further questions about the dispersion modeling requirements for this project.

Sincerely,
Chris Carlson
Meteorologist
Florida Dept. of Environmental Protection
Division of Air Resources Management
2600 Blair Stone Road
MS # 5505
Tallahassee, FL 32399-2400
phone: (850)921-9537
fax: (850)922-6979
Chris.Carlson@dep.state.fl.us

Dynegy Inc.
1000 Louisiana Street, Suite 5800
Houston, Texas 77002
Phone 713.507.6400
www.dynegy.com



July 26, 1999

Florida Department of Environmental Protection
Bureau of Air Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Attention: Mr. A.A. Linero, P.E.

RE: DYNEGY INC.
AIR DISPERSION MODELING PROTOCOL FOR PREVENTION OF
SIGNIFICANT DETERIORATION APPLICATION
PALMETTO POWER PROJECT, OSCEOLA COUNTY, FLORIDA

Dear Mr. Linero:

Dynegy Inc. is proposing to construct and operate an independent power production facility capable of generating a nominal net electrical output of 540 megawatts (MW) in Osceola County, Florida. The proposed project, named Palmetto Power L.L.C., will consist of three combustion turbines (generating approximately 180 MW each) operating in simple cycle mode only. Each combustion turbine will be fired by natural gas only. This project is scheduled for second quarter 2002 completion. The facility will be designed for peaking service with up to 3,000 hours per year of operation.

Under new source review requirements for Prevention of Significant Deterioration (PSD), the proposed project will be considered a major source for nitrogen oxides (NO_x), total particulate matter (PM), particulate matter with aerodynamic diameters less than 10 microns (PM₁₀), and carbon monoxide (CO).

This protocol presents the air dispersion modeling methodology to be used for the PSD analysis, including a discussion of the site geography; air dispersion model to be used; meteorological data; emissions, stack, and building data; receptor locations; and additional impact analyses.

Air Dispersion Model

The air dispersion modeling analysis will be conducted in accordance with air modeling guidelines recommended by the Florida Department of Environmental Protection (DEP). Based on the types of sources for the project, the Industrial Source Complex Short-term (ISCST3, Version 98356) will be used to predict air quality impacts in all areas that are

beyond the project's property boundary. This is latest version of the ISCST3 model available from EPA. All modeling analyses will use the EPA default regulatory options.

Site Geography

The project site is approximately 12 kilometers (km) west of Cocoa. The site is about 20 ft above mean sea level (msl). Around the site, the terrain is flat with elevations at or less than 20 ft above msl.

Since the proposed stack heights for the combustion turbines will be 50 ft, the surrounding terrain is well below the proposed stack top heights. Therefore, the surrounding terrain can be considered as simple (i.e., less than stack top); the simple terrain option will be assumed for the air modeling analysis.

Based on topographical maps of the project site, the land use within a 3-km radius of the site can be classified as rural. As a result, the rural option will be selected in the model.

Meteorological Data

Meteorological data will consist of a 5-year record of hourly surface data from Orlando and upper air observations from Ruskin for the years 1987 to 1991. These data are assumed to be representative of the project site because both the project site and the weather station from Orlando are located in rural areas and are situated in central Florida to experience similar weather conditions, such as frontal passages. These data have been accepted for use by the DEP in other PSD permit applications to address air quality impacts for other proposed sources locating in this county and adjacent counties.

Significant Impact Analysis

Based on air modeling results for similar projects, the project's impacts are expected to be below the EPA Class II significant impact levels (SIL) for all pollutants. Therefore, PSD incremental and NAAQS analyses would not be required. If more detailed modeling indicates that the proposed project's emissions result in predicted ambient air quality impacts above the EPA Class II SIL, discussions will be held with the DEP and emission inventory data of background sources will be obtained as needed.

The nearest PSD Class I areas to the project site are the Chassahowitzka National Wilderness Area (NWA) and the Everglades National Park which are located about 170 and 220 km, respectively, from the site. Other PSD Class I areas are located more than 250 km away from the project site.

Since the project site is more than 150 km away from the Class I areas, it is not expected that the project's emissions will have a significant impact

on these Class I areas. Discussions will be held with the DEP and National Park Service to determine if an air modeling analysis will be required.

Building Data Processing

Building dimensions for the project's structures will be entered into the EPA's Building Profile Input Program (BPIP, Version 95086) for the purpose of obtaining direction-specific building heights and widths for all downwash-affected sources. The direction-specific building dimensions will be input to the ISCST3 model for processing.


Additional Impact Analysis

In addition to the air quality impact analyses, additional analyses will evaluate impairment to visibility and the impact of the proposed project on soils and vegetation. Impacts as a result of general commercial, residential, industrial, and other growth associated with the proposed project will also be addressed.

Please call me at (713) 767-8961 or Bob McCann at Golder Associates Inc. at (352) 336-5600 if you have any questions or comments on the protocol. Dynegey Inc. greatly appreciates the assistance of the DEP on this important project.

Very truly yours,

DYNEGY INC.



Starla Lacy
Environmental Specialist

cc: R.C.McCann, Golder
File

APPENDIX D

BUILDING DOWNWASH INFORMATION FROM BPIP

'DYNEGY PALMETTO OSCEOLA SC- PN, TN IS 0 DEG FROM PN 9/9/99'

'ST'

'FEET' 0.3048

'UTMN' 0.

6

'CT1 AIR INLET' 1 0.0

4 40.0

-90 -40

-90 0

-50 0

-50 -40

'CT2 AIR INLET' 1 0.0

4 40.0

40 -40

40 0

90 0

90 -40

'CT3 AIR INLET' 1 0.0

4 40.0

170 -40

170 0

210 0

210 -40

'CT1 GEN BLDG' 1 0.0

4 28.0

-40 -120

-40 -60

-20 -60

-20 -120

'CT2 GEN BLDG' 1 0.0

4 28.0

-10 -120

-10 -60

10 -60

10 -120

'CT3 GEN BLDG' 1 0.0

4 28.0

120 -120

120 -60

140 -60

140 -120

3

'CT1' 0.0 50. -130. 0.

'CT2' 0.0 50. 0. 0.

'CT3' 0.0 50. 130. 0.

0

BPIP (Dated: 95086)

DATE : 09/09/99

TIME : 16:21:59

DYNEGY PALMETTO OSCEOLA SC- PN, TN IS 0 DEG FROM PN 9/9/99

=====

BPIP PROCESSING INFORMATION:

=====

The ST flag has been set for processing for an ISCST2 run.

Inputs entered in FEET will be converted to meters using
a conversion factor of 0.3048. Output will be in meters.

UTMP is set to UTMN. The input is assumed to be in a local
X-Y coordinate system as opposed to a UTM coordinate system.
True North is in the positive Y direction.

Plant north is set to 0.00 degrees with respect to True North.

DYNEGY PALMETTO OSCEOLA SC- PN, TN IS 0 DEG FROM PN 9/9/99

PRELIMINARY* GEP STACK HEIGHT RESULTS TABLE

(Output Units: meters)

Stack Name	Stack Height	Stack-Building Base Elevation Differences	GEP** EQN1	Preliminary* GEP Stack Height Value
CT1	15.24	0.00	30.48	65.00
CT2	15.24	0.00	30.48	65.00
CT3	15.24	0.00	30.48	65.00

* Results are based on Determinants 1 & 2 on pages 1 & 2 of the GEP
Technical Support Document. Determinant 3 may be investigated for
additional stack height credit. Final values result after
Determinant 3 has been taken into consideration.

** Results were derived from Equation 1 on page 6 of GEP Technical
Support Document. Values have been adjusted for any stack-building
base elevation differences.

Note: Criteria for determining stack heights for modeling emission
limitations for a source can be found in Table 3.1 of the
GEP Technical Support Document.

BPIP (Dated: 95086)

DATE : 09/09/99

TIME : 16:21:59

DYNEGY PALMETTO OSCEOLA SC- PN, TN IS 0 DEG FROM PN 9/9/99

BPIP output is in meters

SO BUILDHGT CT1	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT CT1	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT CT1	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDHGT CT1	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT CT1	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT CT1	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDWID CT1	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID CT1	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID CT1	17.18	17.18	16.65	0.00	0.00	0.00
SO BUILDWID CT1	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID CT1	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID CT1	17.18	17.18	16.65	0.00	0.00	0.00

SO BUILDHGT CT2	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT CT2	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT CT2	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDHGT CT2	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT CT2	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT CT2	12.19	12.19	12.19	8.53	8.53	8.53

SO BUILDWID CT2	9.18	11.98	14.42	17.18	17.18	16.65
SO BUILDWID CT2	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID CT2	19.14	19.51	19.29	11.98	18.18	30.48
SO BUILDWID CT2	27.36	11.98	22.34	17.18	17.18	16.65
SO BUILDWID CT2	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID CT2	19.14	19.51	19.29	11.98	9.18	15.24
SO BUILDHGT CT3	8.53	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT CT3	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT CT3	12.19	12.19	12.19	8.53	0.00	0.00
SO BUILDHGT CT3	0.00	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT CT3	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT CT3	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID CT3	9.18	11.98	19.29	19.51	19.14	16.65
SO BUILDWID CT3	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID CT3	17.18	17.18	16.65	11.98	0.00	0.00
SO BUILDWID CT3	0.00	11.98	19.29	19.51	19.14	16.65
SO BUILDWID CT3	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID CT3	17.18	17.18	16.65	11.98	9.18	6.10

APPENDIX E

DETAILED SUMMARY OF ISCST MODEL RESULTS

ISCBOB3 RELEASE 98056

ISCST3 OUTPUT FILE NUMBER 1 :PALSC1.087
 ISCST3 OUTPUT FILE NUMBER 2 :PALSC1.088
 ISCST3 OUTPUT FILE NUMBER 3 :PALSC1.089
 ISCST3 OUTPUT FILE NUMBER 4 :PALSC1.090
 ISCST3 OUTPUT FILE NUMBER 5 :PALSC1.091

First title for last output file is: 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 10/4/99
 Second title for last output file is: GENERIC SIGNIFICANT IMPACT ANALYSIS- 3 x SC CT 50 FT STKS

AVERAGING TIME	YEAR	CONC (ug/m3)	DIR (deg) or X (m)	DIST (m) or Y (m)	PERIOD ENDING (YYMMDDHH)
SOURCE GROUP ID: BASE95					
Annual	1987	0.01324	240.	15000.	87123124
	1988	0.01456	230.	200.	88123124
	1989	0.01482	230.	200.	89123124
	1990	0.01378	240.	15000.	90123124
	1991	0.01069	360.	12000.	91123124
HIGH 1-Hour	1987	2.05139	90.	1600.	87041113
	1988	2.07672	240.	1600.	88051611
	1989	2.00431	240.	1600.	89072614
	1990	1.91196	260.	1600.	90082913
	1991	2.07700	270.	1600.	91050314
HIGH 3-Hour	1987	0.83776	180.	20000.	87110703
	1988	0.93695	250.	22500.	88010124
	1989	0.72930	90.	20000.	89112103
	1990	0.79469	300.	20000.	90090821
	1991	0.91371	360.	20000.	91032806
HIGH 8-Hour	1987	0.39627	360.	20000.	87072924
	1988	0.43843	300.	1800.	88061816
	1989	0.38840	290.	20000.	89101724
	1990	0.51623	180.	20000.	90122508
	1991	0.50485	300.	20000.	91021924
HIGH 24-Hour	1987	0.17612	160.	15000.	87101424
	1988	0.16708	300.	1800.	88061824
	1989	0.14514	120.	15000.	89122524
	1990	0.17228	180.	20000.	90122524
	1991	0.19659	300.	20000.	91021924
SOURCE GROUP ID: BASE59					
Annual	1987	0.01232	240.	15000.	87123124
	1988	0.01441	230.	200.	88123124
	1989	0.01467	230.	200.	89123124
	1990	0.01299	240.	15000.	90123124
	1991	0.01009	360.	12000.	91123124
HIGH 1-Hour	1987	1.97100	160.	1600.	87082013
	1988	1.94593	40.	1600.	88080913
	1989	1.98936	240.	1600.	89072614
	1990	1.89759	260.	1600.	90082913
	1991	2.00210	200.	1600.	91070713
HIGH 3-Hour	1987	0.80243	180.	20000.	87110703
	1988	0.89097	250.	25000.	88010124
	1989	0.69746	90.	20000.	89112103
	1990	0.76058	300.	20000.	90090821
	1991	0.87072	360.	20000.	91032806
HIGH 8-Hour	1987	0.37864	360.	20000.	87072924
	1988	0.39200	160.	20000.	88121808
	1989	0.36970	290.	20000.	89101724
	1990	0.49361	180.	20000.	90122508
	1991	0.48245	300.	20000.	91021924
HIGH 24-Hour	1987	0.16893	160.	17000.	87101424
	1988	0.15078	240.	13000.	88052924
	1989	0.13878	120.	17000.	89122524
	1990	0.16586	230.	1800.	90082024
	1991	0.18765	300.	20000.	91021924
SOURCE GROUP ID: BASE32					
Annual	1987	0.01201	240.	15000.	87123124
	1988	0.01435	230.	200.	88123124
	1989	0.01461	230.	200.	89123124
	1990	0.01268	240.	15000.	90123124
	1991	0.00977	360.	12000.	91123124

HIGH 1-Hour	1987	1.96448	160.	1600.	87082013
	1988	1.83193	60.	1800.	88041413
	1989	1.87740	130.	1600.	89062714
	1990	1.89159	260.	1600.	90082913
	1991	1.87139	140.	1600.	91061312
HIGH 3-Hour	1987	0.78702	180.	20000.	87110703
	1988	0.87125	250.	25000.	88010124
	1989	0.69441	320.	7000.	89061715
	1990	0.74571	300.	20000.	90090821
	1991	0.85208	360.	20000.	91032806
HIGH 8-Hour	1987	0.37097	360.	20000.	87072924
	1988	0.38406	160.	20000.	88121808
	1989	0.36160	290.	20000.	89101724
	1990	0.48378	180.	20000.	90122508
	1991	0.47272	300.	20000.	91021924
HIGH 24-Hour	1987	0.14734	160.	20000.	87101424
	1988	0.14841	240.	12000.	88052924
	1989	0.13608	120.	17000.	89122524
	1990	0.16500	230.	1800.	90082024
	1991	0.18377	300.	20000.	91021924
SOURCE GROUP ID: LD7095					
Annual	1987	0.01719	240.	13000.	87123124
	1988	0.01799	240.	15000.	88123124
	1989	0.01546	230.	200.	89123124
	1990	0.01779	240.	12000.	90123124
	1991	0.01475	360.	10000.	91123124
HIGH 1-Hour	1987	2.47485	100.	1600.	87043014
	1988	2.42657	230.	1600.	88041412
	1989	2.40193	120.	1600.	89071112
	1990	2.58830	290.	1600.	90050211
	1991	2.59113	110.	1600.	91062713
HIGH 3-Hour	1987	1.25101	250.	1600.	87071015
	1988	1.19097	250.	20000.	88010124
	1989	0.90195	90.	17000.	89112103
	1990	1.33751	160.	1600.	90052315
	1991	1.23872	140.	1800.	91052915
HIGH 8-Hour	1987	0.48998	360.	20000.	87072924
	1988	0.50319	160.	20000.	88121808
	1989	0.48886	290.	20000.	89101724
	1990	0.63153	180.	17000.	90122508
	1991	0.62701	300.	17000.	91021924
HIGH 24-Hour	1987	0.21520	160.	15000.	87101424
	1988	0.18879	240.	15000.	88052924
	1989	0.21458	340.	1800.	89042324
	1990	0.21285	230.	1800.	90041624
	1991	0.24580	300.	17000.	91021924
SOURCE GROUP ID: LD7059					
Annual	1987	0.01686	240.	13000.	87123124
	1988	0.01746	240.	15000.	88123124
	1989	0.01540	230.	200.	89123124
	1990	0.01750	240.	12000.	90123124
	1991	0.01411	360.	10000.	91123124
HIGH 1-Hour	1987	2.46643	100.	1600.	87043014
	1988	2.41761	230.	1600.	88041412
	1989	2.39392	120.	1600.	89071112
	1990	2.42381	220.	1600.	90041612
	1991	2.54010	180.	1600.	91070712
HIGH 3-Hour	1987	1.24486	250.	1600.	87071015
	1988	1.16126	250.	20000.	88010124
	1989	0.88183	90.	17000.	89112103
	1990	1.33254	160.	1600.	90052315
	1991	1.23291	140.	1800.	91052915
HIGH 8-Hour	1987	0.47965	360.	20000.	87072924
	1988	0.49247	160.	20000.	88121808
	1989	0.48031	340.	1800.	89042316
	1990	0.61833	180.	20000.	90122508
	1991	0.61287	300.	17000.	91021924
HIGH 24-Hour	1987	0.21073	160.	15000.	87101424
	1988	0.18493	240.	15000.	88052924

	1989	0.21362	340.	1800.	89042324
	1990	0.21097	230.	1800.	90041624
	1991	0.24011	300.	17000.	91021924
SOURCE GROUP ID:	LD7032				
Annual					
	1987	0.01634	240.	13000.	87123124
	1988	0.01713	240.	15000.	88123124
	1989	0.01534	230.	200.	89123124
	1990	0.01697	240.	13000.	90123124
	1991	0.01378	360.	10000.	91123124
HIGH 1-Hour					
	1987	2.45957	100.	1600.	87043014
	1988	2.41033	230.	1600.	88041412
	1989	2.38739	120.	1600.	89071112
	1990	2.41660	220.	1600.	90041612
	1991	2.40005	130.	1600.	91051612
HIGH 3-Hour					
	1987	1.23987	250.	1600.	87071015
	1988	1.15330	290.	1600.	88071215
	1989	0.86554	90.	17000.	89112103
	1990	0.94135	300.	17000.	90090821
	1991	1.22817	140.	1800.	91052915
HIGH 8-Hour					
	1987	0.47126	360.	20000.	87072924
	1988	0.48379	160.	20000.	88121808
	1989	0.47857	340.	1800.	89042316
	1990	0.60765	180.	20000.	90122508
	1991	0.60142	300.	17000.	91021924
HIGH 24-Hour					
	1987	0.20712	160.	15000.	87101424
	1988	0.18184	240.	15000.	88052924
	1989	0.21283	340.	1800.	89042324
	1990	0.20948	230.	1800.	90041624
	1991	0.23551	300.	17000.	91021924
All receptor computations reported with respect to a user-specified origin					
GRID	0.00	0.00			
DISCRETE	0.00	0.00			

CO STARTING
 CO TITLEONE 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 10/4/99
 CO TITLETWO GENERIC SIGNIFICANT IMPACT ANALYSIS- 3 x SC CT 50 FT STKS
 CO MODELOPT DFAULT CONC RURAL
 CO AVERTIME 1 3 8 24 PERIOD
 CO POLLUTID GENERIC
 CO RUNORNOT RUN
 CO FINISHED

SO STARTING
 ** MODELING ORIGIN IS AT STK FOR CT NO.2
 ** NOT A SOURCE - LOCATION IS USED FOR POLAR DISCREET RECEPTORS.
 SO LOCATION ORIGIN POINT 0.00 0.00 0.00
 SO SRCPARAM ORIGIN 0.0 10.0 500.0 30.00 10.00

** CT STACK LETTER CODE

** -----
 ** A - CT 1
 ** B - CT 2
 ** C - CT 3

** Source Location Cards:

** SRCID	** SRCTYP	XS (m)	YS (m)	ZS (m)
SO LOCATION	BASE95A POINT	-39.6	0.0	0.0
SO LOCATION	BASE95B POINT	0.0	0.0	0.0
SO LOCATION	BASE95C POINT	39.6	0.0	0.0
SO LOCATION	BASE59A POINT	-39.6	0.0	0.0
SO LOCATION	BASE59B POINT	0.0	0.0	0.0
SO LOCATION	BASE59C POINT	39.6	0.0	0.0
SO LOCATION	BASE32A POINT	-39.6	0.0	0.0
SO LOCATION	BASE32B POINT	0.0	0.0	0.0
SO LOCATION	BASE32C POINT	39.6	0.0	0.0
SO LOCATION	LD7095A POINT	-39.6	0.0	0.0
SO LOCATION	LD7095B POINT	0.0	0.0	0.0
SO LOCATION	LD7095C POINT	39.6	0.0	0.0
SO LOCATION	LD7059A POINT	-39.6	0.0	0.0
SO LOCATION	LD7059B POINT	0.0	0.0	0.0
SO LOCATION	LD7059C POINT	39.6	0.0	0.0
SO LOCATION	LD7032A POINT	-39.6	0.0	0.0
SO LOCATION	LD7032B POINT	0.0	0.0	0.0
SO LOCATION	LD7032C POINT	39.6	0.0	0.0

** Source Parameter Cards:

** POINT: SRCID	QS (g/s)	HS (m)	TS (K)	VS (m/s)	DS (m)
SO SRCPARAM BASE95A	3.333	15.2	879.0	41.4	5.8
SO SRCPARAM BASE95B	3.333	15.2	879.0	41.4	5.8
SO SRCPARAM BASE95C	3.334	15.2	879.0	41.4	5.8
SO SRCPARAM BASE59A	3.333	15.2	864.0	43.8	5.8
SO SRCPARAM BASE59B	3.333	15.2	864.0	43.8	5.8
SO SRCPARAM BASE59C	3.334	15.2	864.0	43.8	5.8
SO SRCPARAM BASE32A	3.333	15.2	858.0	44.9	5.8
SO SRCPARAM BASE32B	3.333	15.2	858.0	44.9	5.8
SO SRCPARAM BASE32C	3.334	15.2	858.0	44.9	5.8
SO SRCPARAM LD7095A	3.333	15.2	847.0	33.6	5.8
SO SRCPARAM LD7095B	3.333	15.2	847.0	33.6	5.8
SO SRCPARAM LD7095C	3.334	15.2	847.0	33.6	5.8
SO SRCPARAM LD7059A	3.333	15.2	834.0	34.7	5.8
SO SRCPARAM LD7059B	3.333	15.2	834.0	34.7	5.8
SO SRCPARAM LD7059C	3.334	15.2	834.0	34.7	5.8
SO SRCPARAM LD7032A	3.333	15.2	825.0	35.6	5.8
SO SRCPARAM LD7032B	3.333	15.2	825.0	35.6	5.8
SO SRCPARAM LD7032C	3.334	15.2	825.0	35.6	5.8

SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65

SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00

SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32B-BASE95B	9.18	11.98	14.42	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	18.18	30.48
SO BUILDWID	BASE32B-BASE95B	27.36	11.98	22.34	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	9.18	15.24

SO BUILDHGT	BASE32C-BASE95C	8.53	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	0.00	0.00
SO BUILDHGT	BASE32C-BASE95C	0.00	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32C-BASE95C	9.18	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	0.00	0.00
SO BUILDWID	BASE32C-BASE95C	0.00	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	9.18	6.10

SO BUILDHGT	LD7032A-LD7095A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	LD7032A-LD7095A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	LD7032A-LD7095A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDHGT	LD7032A-LD7095A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	LD7032A-LD7095A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	LD7032A-LD7095A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDWID	LD7032A-LD7095A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	LD7032A-LD7095A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	LD7032A-LD7095A	17.18	17.18	16.65	0.00	0.00	0.00
SO BUILDWID	LD7032A-LD7095A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	LD7032A-LD7095A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	LD7032A-LD7095A	17.18	17.18	16.65	0.00	0.00	0.00

SO BUILDHGT	LD7032B-LD7095B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	LD7032B-LD7095B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	LD7032B-LD7095B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDHGT	LD7032B-LD7095B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	LD7032B-LD7095B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	LD7032B-LD7095B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	LD7032B-LD7095B	9.18	11.98	14.42	17.18	17.18	16.65
SO BUILDWID	LD7032B-LD7095B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	LD7032B-LD7095B	19.14	19.51	19.29	11.98	18.18	30.48
SO BUILDWID	LD7032B-LD7095B	27.36	11.98	22.34	17.18	17.18	16.65
SO BUILDWID	LD7032B-LD7095B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	LD7032B-LD7095B	19.14	19.51	19.29	11.98	9.18	15.24

SO BUILDHGT	LD7032C-LD7095C	8.53	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	LD7032C-LD7095C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	LD7032C-LD7095C	12.19	12.19	12.19	8.53	0.00	0.00
SO BUILDHGT	LD7032C-LD7095C	0.00	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	LD7032C-LD7095C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	LD7032C-LD7095C	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	LD7032C-LD7095C	9.18	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	LD7032C-LD7095C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	LD7032C-LD7095C	17.18	17.18	16.65	11.98	0.00	0.00
SO BUILDWID	LD7032C-LD7095C	0.00	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	LD7032C-LD7095C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	LD7032C-LD7095C	17.18	17.18	16.65	11.98	9.18	6.10

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)

SO SRCGROUP	BASE95	BASE95A	BASE95B	BASE95C
SO SRCGROUP	BASE59	BASE59A	BASE59B	BASE59C
SO SRCGROUP	BASE32	BASE32A	BASE32B	BASE32C
SO SRCGROUP	LD7095	LD7095A	LD7095B	LD7095C
SO SRCGROUP	LD7059	LD7059A	LD7059B	LD7059C
SO SRCGROUP	LD7032	LD7032A	LD7032B	LD7032C

SO FINISHED

RE STARTING
RE GRIDPOLR POL STA

RE GRIDPOLR POL ORIG 0.0 0.0
RE GRIDPOLR POL DIST 200 400 600 800 1000 1200 1400 1600
RE GRIDPOLR POL DIST 1800 2000 2250 2500 2750 3000 3500 4000 4500
RE GRIDPOLR POL DIST 5000 6000 7000 8000 9000 10000 12000 13000 15000
RE GRIDPOLR POL DIST 17000 20000 22500 25000
RE GRIDPOLR POL GDIR 36 10.00 10.00
RE GRIDPOLR POL END
RE FINISHED

ME STARTING
ME INPUTFIL D:\MET\ORL87D.MET
ME ANEMHGHT 10.100 METERS
ME SURFDATA 12815 1987 ORLANDO
ME UAIRDATA 12842 1987 WPB
ME FINISHED

OU STARTING
OU RECTABLE ALLAVE FIRST
OU FINISHED

CO STARTING
 CO TITLEONE 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99
 CO TITLETWO PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M
 CO MODELOPT DFAULT CONC RURAL
 CO AVERTIME PERIOD
 CO POLLUTID GENERIC
 CO RUNORNOT RUN
 CO FINISHED

SO STARTING
 ** MODELING ORIGIN IS AT STK FOR CT NO.2
 ** NOT A SOURCE - LOCATION IS USED FOR POLAR DISCREET RECEPTORS.
 SO LOCATION ORIGIN POINT 0.00 0.00 0.00
 SO SRCPARAM ORIGIN 0.0 10.0 500.0 30.00 10.00

** CT STACK LETTER CODE
 ** -----
 ** A - CT 1
 ** B - CT 2
 ** C - CT 3

** Source Location Cards:
 ** SRCID SRCTYP XS YS ZS
 ** UTM (m) (m) (m)
 SO LOCATION BASE32A POINT -39.6 0.0 0.0
 SO LOCATION BASE32B POINT 0.0 0.0 0.0
 SO LOCATION BASE32C POINT 39.6 0.0 0.0

** Source Parameter Cards:
 ** 50 ft CT stack
 ** POINT: SRCID QS HS TS VS DS
 ** (g/s) (m) (K) (m/s) (m)
 SO SRCPARAM BASE32A 1.08 15.2 858.0 44.9 5.8
 SO SRCPARAM BASE32B 1.08 15.2 858.0 44.9 5.8
 SO SRCPARAM BASE32C 1.08 15.2 858.0 44.9 5.8

SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00

SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32B-BASE95B	9.18	11.98	14.42	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	18.18	30.48
SO BUILDWID	BASE32B-BASE95B	27.36	11.98	22.34	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	9.18	15.24

SO BUILDHGT	BASE32C-BASE95C	8.53	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	0.00	0.00
SO BUILDHGT	BASE32C-BASE95C	0.00	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32C-BASE95C	9.18	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	0.00	0.00
SO BUILDWID	BASE32C-BASE95C	0.00	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	9.18	6.10

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)

SO SRCGROUP BASE32 BASE32A BASE32B BASE32C

SO FINISHED

RE STARTING
 RE GRIDPOLR POL STA
 RE GRIDPOLR POL ORIG 0.0 0.0

RE GRIDPOLR POL DIST 200 300 400
RE GRIDPOLR POL GDIR 9 222 2.00
RE GRIDPOLR POL END
RE FINISHED

ME STARTING
ME INPUTFIL D:\MET\ORL89D.MET
ME ANEMHGHT 10.100 METERS
ME SURFDATA 12815 1989 ORLANDO
ME UAIRDATA 12842 1989 WPB
ME FINISHED

OU STARTING
OU RECTABLE ALLAVE FIRST
OU FINISHED

*** Message Summary For ISC3 Model Setup ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
A Total of 1 Warning Message(s)
A Total of 0 Informational Message(s)

***** FATAL ERROR MESSAGES *****
*** NONE ***

***** WARNING MESSAGES *****
SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter QS

*** SETUP Finishes Successfully ***

*** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTs:

CONC RURAL FLAT DEFAULT

*** MODEL SETUP OPTIONS SUMMARY ***

**Intermediate Terrain Processing is Selected

**Model Is Setup For Calculation of Average CONCentration Values.

-- SCAVENGING/DEPOSITION LOGIC --

**Model Uses NO DRY DEPLETION. DDPLETE = F

**Model Uses NO WET DEPLETION. WDPLETE = F

**NO WET SCAVENGING Data Provided.

**NO GAS DRY DEPOSITION Data Provided.

**Model Does NOT Use GRIDDED TERRAIN Data for Depletion Calculations

**Model Uses RURAL Dispersion.

**Model Uses Regulatory DEFAULT Options:

1. Final Plume Rise.
2. Stack-tip Downwash.
3. Buoyancy-induced Dispersion.
4. Use Calms Processing Routine.
5. Not Use Missing Data Processing Routine.
6. Default Wind Profile Exponents.
7. Default Vertical Potential Temperature Gradients.
8. "Upper Bound" Values for Supersquat Buildings.
9. No Exponential Decay for RURAL Mode

**Model Assumes Receptors on FLAT Terrain.

**Model Assumes No FLAGPOLE Receptor Heights.

**Model Calculates PERIOD Averages Only

**This Run Includes: 4 Source(s); 1 Source Group(s); and 27 Receptor(s)

**The Model Assumes A Pollutant Type of: GENERIC

**Model Set To Continue RUNning After the Setup Testing.

**Output Options Selected:

Model Outputs Tables of PERIOD Averages by Receptor

Model Outputs Tables of Highest Short Term Values by Receptor (RECTABLE Keyword)

**NOTE: The Following Flags May Appear Following CONC Values: c for Calm Hours
m for Missing Hours
b for Both Calm and Missing Hours

**Misc. Inputs: Anem. Hgt. (m) = 10.10 ; Decay Coef. = 0.000 ; Rot. Angle = 0.0
Emission Units = (GRAMS/SEC) ; Emission Rate Unit Factor = 0.10
Output Units = (MICROGRAMS/CUBIC-METER)

**Approximate Storage Requirements of Model = 1.2 MB of RAM.

**Input Runstream File: REFPMAN.I89

**Output Print File: REFPMAN.090

*** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTs:

CONC RURAL FLAT DEFAULT

*** POINT SOURCE DATA ***

SOURCE ID	NUMBER PART. CATS.	EMISSION RATE (USER UNITS)	X (METERS)	Y (METERS)	BASE ELEV. (METERS)	STACK HEIGHT (METERS)	STACK TEMP. (DEG.K)	STACK EXIT VEL. (M/SEC)	STACK DIAMETER (METERS)	BUILDING EXISTS	EMISS SCAL
ORIGIN	0	0.00000E+00	0.0	0.0	0.0	10.00	500.00	30.00	10.00	NO	
BASE32A	0	0.10800E+01	-39.6	0.0	0.0	15.20	858.00	44.90	5.80	YES	
BASE32B	0	0.10800E+01	0.0	0.0	0.0	15.20	858.00	44.90	5.80	YES	
BASE32C	0	0.10800E+01	39.6	0.0	0.0	15.20	858.00	44.90	5.80	YES	
*** ISCST3 - VERSION 99155 ***											
*** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS										9/9/99	***
*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M											***

**MODELOPTs:

CONC RURAL FLAT DEFAULT

*** SOURCE IDs DEFINING SOURCE GROUPS ***

GROUP ID

SOURCE IDs

BASE32 BASE32A , BASE32B , BASE32C ,

*** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTs:

CONC RURAL FLAT DEFAULT

*** DIRECTION SPECIFIC BUILDING DIMENSIONS ***

SOURCE ID: BASE32A

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	0.0,	0.0,	0	2	0.0,	0.0,	0	3	0.0,	0.0,	0	4	0.0,	0.0,	0	5	0.0,	0.0,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	0.0,	0.0,	0	17	0.0,	0.0,	0	
19	0.0,	0.0,	0	20	0.0,	0.0,	0	21	0.0,	0.0,	0	22	0.0,	0.0,	0	23	0.0,	0.0,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	17.2,	0	32	12.2,	17.2,	0	33	12.2,	16.6,	0	34	0.0,	0.0,	0	35	0.0,	0.0,	0	

SOURCE ID: BASE32B

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	8.5,	14.4,	0	4	12.2,	17.2,	0	5	12.2,	17.2,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	19.1,	0	14	12.2,	19.5,	0	15	12.2,	19.3,	0	16	8.5,	12.0,	0	17	8.5,	18.2,	0	
19	8.5,	27.4,	0	20	8.5,	12.0,	0	21	8.5,	22.3,	0	22	12.2,	17.2,	0	23	12.2,	17.2,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	19.1,	0	32	12.2,	19.5,	0	33	12.2,	19.3,	0	34	8.5,	12.0,	0	35	8.5,	9.2,	0	

SOURCE ID: BASE32C

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	12.2,	19.3,	0	4	12.2,	19.5,	0	5	12.2,	19.1,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	8.5,	12.0,	0	17	0.0,	0.0,	0	
19	0.0,	0.0,	0	20	8.5,	12.0,	0	21	12.2,	19.3,	0	22	12.2,	19.5,	0	23	12.2,	19.1,	0	

25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0
31	12.2,	17.2,	0	32	12.2,	17.2,	0	33	12.2,	16.6,	0	34	8.5,	12.0,	0	35	8.5,	9.2,	0

*** ISCST3 - VERSION 99155 ***

*** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS
*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M

9/9/99 ***

**MODELOPTs:
CONC

RURAL FLAT DFAULT

*** GRIDDED RECEPTOR NETWORK SUMMARY ***

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

*** ORIGIN FOR POLAR NETWORK ***
X-ORIG = 0.00 ; Y-ORIG = 0.00 (METERS)*** DISTANCE RANGES OF NETWORK ***
(METERS)

200.0, 300.0, 400.0,

*** DIRECTION RADIALS OF NETWORK ***
(DEGREES)

222.0,	224.0,	226.0,	228.0,	230.0,	232.0,	234.0,	236.0,	238.0,	
*** ISCST3 - VERSION 99155 ***	*** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS							9/9/99	***
	*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M								***

**MODELOPTs:
CONC

RURAL FLAT DFAULT

*** METEOROLOGICAL DAYS SELECTED FOR PROCESSING ***
(1=YES; 0=NO)

1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

NOTE: METEOROLOGICAL DATA ACTUALLY PROCESSED WILL ALSO DEPEND ON WHAT IS INCLUDED IN THE DATA FI

*** UPPER BOUND OF FIRST THROUGH FIFTH WIND SPEED CATEGORIES ***
(METERS/SEC)

1.54, 3.09, 5.14, 8.23, 10.80,

*** WIND PROFILE EXPONENTS ***

STABILITY CATEGORY	1	2	3	4	5	6
A	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01
B	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01
C	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+00
D	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+00
E	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+00
F	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+00

*** VERTICAL POTENTIAL TEMPERATURE GRADIENTS ***
(DEGREES KELVIN PER METER)

STABILITY CATEGORY	1	2	3	4	5	6
A	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
B	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
C	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
D	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
E	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01
F	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01

*** ISCST3 - VERSION 99155 ***

*** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS
*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M

9/9/99 ***

**MODELOPTs:
CONC

RURAL FLAT DFAULT

*** THE FIRST 24 HOURS OF METEOROLOGICAL DATA ***

FILE: D:\MET\ORL89D.MET

FORMAT: (4I2,2F9.4,F6.1,I2,2F7.1,f9.4,f10.1,f8.4,i4,f7.2)

SURFACE STATION NO.: 12815

UPPER AIR STATION NO.: 12842

NAME: ORLANDO

NAME: WPB

YEAR: 1989

YEAR: 1989

YR	MN	DY	HR	FLOW VECTOR	SPEED (M/S)	TEMP (K)	STAB CLASS	MIXING RURAL	HEIGHT (M) URBAN	USTAR (M/S)	M-O LENGTH (M)	Z-0 (M)	IPCODE	PRATE (mm/HR)
89	01	01	01	21.0	1.54	291.5	7	999.5	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	02	8.0	2.06	290.4	6	999.1	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	03	34.0	2.06	290.4	6	998.8	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	04	33.0	2.06	289.8	6	998.4	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	05	43.0	2.06	290.4	6	998.1	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	06	22.0	2.06	289.8	6	997.7	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	07	45.0	2.06	289.3	6	997.4	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	08	33.0	3.09	290.4	5	100.0	628.6	0.0000	0.0	0.0000	0	0.00
89	01	01	09	27.0	3.09	292.6	4	244.9	689.7	0.0000	0.0	0.0000	0	0.00
89	01	01	10	21.0	4.63	295.4	3	394.9	750.7	0.0000	0.0	0.0000	0	0.00
89	01	01	11	14.0	4.12	297.6	3	544.9	811.8	0.0000	0.0	0.0000	0	0.00
89	01	01	12	56.0	4.63	298.2	3	695.0	872.9	0.0000	0.0	0.0000	0	0.00
89	01	01	13	43.0	5.14	299.8	3	845.0	933.9	0.0000	0.0	0.0000	0	0.00
89	01	01	14	59.0	4.12	300.9	3	995.0	995.0	0.0000	0.0	0.0000	0	0.00
89	01	01	15	32.0	6.17	301.5	4	995.0	995.0	0.0000	0.0	0.0000	0	0.00
89	01	01	16	44.0	4.63	300.9	3	995.0	995.0	0.0000	0.0	0.0000	0	0.00
89	01	01	17	61.0	3.60	299.8	4	995.0	995.0	0.0000	0.0	0.0000	0	0.00
89	01	01	18	37.0	3.09	298.2	5	993.6	990.5	0.0000	0.0	0.0000	0	0.00
89	01	01	19	54.0	3.09	297.0	6	990.2	979.6	0.0000	0.0	0.0000	0	0.00
89	01	01	20	67.0	3.60	295.9	5	986.7	968.7	0.0000	0.0	0.0000	0	0.00
89	01	01	21	150.0	2.06	295.4	6	983.3	957.7	0.0000	0.0	0.0000	0	0.00
89	01	01	22	132.0	2.06	294.3	6	979.9	946.8	0.0000	0.0	0.0000	0	0.00
89	01	01	23	130.0	0.00	293.2	7	976.4	935.9	0.0000	0.0	0.0000	0	0.00
89	01	01	24	130.0	0.00	292.6	7	973.0	925.0	0.0000	0.0	0.0000	0	0.00

*** NOTES: STABILITY CLASS 1=A, 2=B, 3=C, 4=D, 5=E AND 6=F.

FLOW VECTOR IS DIRECTION TOWARD WHICH WIND IS BLOWING.

*** ISCST3 - VERSION 99155 ***

*** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS

9/9/99 ***

*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M

**MODELOPTs:

CONC

RURAL FLAT DEFAULT

*** THE PERIOD (8760 HRS) AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: BASE32 INCLUDING SOURCE(S): BASE32A , BASE32B , BASE32C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

DIRECTION (DEGREES)	200.00	300.00	400.00	DISTANCE (METERS)
-----------------------	--------	--------	--------	-------------------

222.00	0.00472	0.00454	0.00359
224.00	0.00473	0.00458	0.00364
226.00	0.00474	0.00462	0.00368
228.00	0.00474	0.00466	0.00373
230.00	0.00473	0.00468	0.00377
232.00	0.00472	0.00470	0.00381
234.00	0.00470	0.00471	0.00385
236.00	0.00467	0.00471	0.00387
238.00	0.00464	0.00470	0.00388

*** ISCST3 - VERSION 99155 ***

*** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS

9/9/99 ***

*** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M

**MODELOPTs:

CONC

RURAL FLAT DEFAULT

*** THE SUMMARY OF MAXIMUM PERIOD (8760 HRS) RESULTS ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

GROUP ID	AVERAGE CONC	RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE	NETWORK GRID-ID
BASE32	1ST HIGHEST VALUE IS 0.00474 AT (-143.87, -138.93, 0.00,	0.00)	GP POL

2ND HIGHEST VALUE IS	0.00474 AT (-148.63,	-133.83,	0.00,	0.00)	GP	POL
3RD HIGHEST VALUE IS	0.00473 AT (-153.21,	-128.56,	0.00,	0.00)	GP	POL
4TH HIGHEST VALUE IS	0.00473 AT (-138.93,	-143.87,	0.00,	0.00)	GP	POL
5TH HIGHEST VALUE IS	0.00472 AT (-157.60,	-123.13,	0.00,	0.00)	GP	POL
6TH HIGHEST VALUE IS	0.00472 AT (-133.83,	-148.63,	0.00,	0.00)	GP	POL
7TH HIGHEST VALUE IS	0.00471 AT (-242.71,	-176.34,	0.00,	0.00)	GP	POL
8TH HIGHEST VALUE IS	0.00471 AT (-248.71,	-167.76,	0.00,	0.00)	GP	POL
9TH HIGHEST VALUE IS	0.00470 AT (-161.80,	-117.56,	0.00,	0.00)	GP	POL
10TH HIGHEST VALUE IS	0.00470 AT (-236.40,	-184.70,	0.00,	0.00)	GP	POL

*** RECEPTOR TYPES: GC = GRIDCART
 GP = GRIDPOLR
 DC = DISCCART
 DP = DISCPOLR
 BD = BOUNDARY

*** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS
 *** PM SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M

9/9/99 ***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** Message Summary : ISCST3 Model Execution ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
 A Total of 1 Warning Message(s)
 A Total of 345 Informational Message(s)
 A Total of 345 Calm Hours Identified

***** FATAL ERROR MESSAGES *****
 *** NONE ***

***** WARNING MESSAGES *****
 SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter QS

 *** ISCST3 Finishes Successfully ***

CO STARTING
CO TITLEONE 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99
CO TITLETWO PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M
CO MODELOPT DFAULT CONC RURAL
CO AVERTIME 24
CO POLLUTID GENERIC
CO RUNORNOT RUN
CO FINISHED

SO STARTING
** MODELING ORIGIN IS AT STK FOR CT NO.2
** NOT A SOURCE - LOCATION IS USED FOR POLAR DISCREET RECEPTORS.
SO LOCATION ORIGIN POINT 0.00 0.00 0.00
SO SRCPARAM ORIGIN 0.0 10.0 500.0 30.00 10.00

** CT STACK LETTER CODE

** A - CT 1
** B - CT 2
** C - CT 3

** Source Location Cards:

** SRCID	SRCTYP	XS	YS	ZS
** UTM		(m)	(m)	(m)
SO LOCATION LD7032A	POINT	-39.6	0.0	0.0
SO LOCATION LD7032B	POINT	0.0	0.0	0.0
SO LOCATION LD7032C	POINT	39.6	0.0	0.0

** Source Parameter Cards:

** 50 ft CT stack
** POINT: SRCID

** SRCID	QS	HS	TS	VS	DS
** (g/s)	(m)	(K)	(m/s)	(m)	
SO SRCPARAM LD7032A	0.90	15.2	825.0	35.6	5.8
SO SRCPARAM LD7032B	0.90	15.2	825.0	35.6	5.8
SO SRCPARAM LD7032C	0.90	15.2	825.0	35.6	5.8

SO BUILDHGT LD7032A-LD7095A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT LD7032A-LD7095A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT LD7032A-LD7095A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDHGT LD7032A-LD7095A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT LD7032A-LD7095A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT LD7032A-LD7095A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDWID LD7032A-LD7095A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID LD7032A-LD7095A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID LD7032A-LD7095A	17.18	17.18	16.65	0.00	0.00	0.00
SO BUILDWID LD7032A-LD7095A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID LD7032A-LD7095A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID LD7032A-LD7095A	17.18	17.18	16.65	0.00	0.00	0.00

SO BUILDHGT LD7032B-LD7095B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT LD7032B-LD7095B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT LD7032B-LD7095B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDHGT LD7032B-LD7095B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT LD7032B-LD7095B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT LD7032B-LD7095B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID LD7032B-LD7095B	9.18	11.98	14.42	17.18	17.18	16.65
SO BUILDWID LD7032B-LD7095B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID LD7032B-LD7095B	19.14	19.51	19.29	11.98	18.18	30.48
SO BUILDWID LD7032B-LD7095B	27.36	11.98	22.34	17.18	17.18	16.65
SO BUILDWID LD7032B-LD7095B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID LD7032B-LD7095B	19.14	19.51	19.29	11.98	9.18	15.24

SO BUILDHGT LD7032C-LD7095C	8.53	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT LD7032C-LD7095C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT LD7032C-LD7095C	12.19	12.19	12.19	8.53	0.00	0.00
SO BUILDHGT LD7032C-LD7095C	0.00	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT LD7032C-LD7095C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT LD7032C-LD7095C	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID LD7032C-LD7095C	9.18	11.98	19.29	19.51	19.14	16.65
SO BUILDWID LD7032C-LD7095C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID LD7032C-LD7095C	17.18	17.18	16.65	11.98	0.00	0.00
SO BUILDWID LD7032C-LD7095C	0.00	11.98	19.29	19.51	19.14	16.65
SO BUILDWID LD7032C-LD7095C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID LD7032C-LD7095C	17.18	17.18	16.65	11.98	9.18	6.10

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)

SO SRCGROUP LD7032 LD7032A LD7032B LD7032C

SO FINISHED

RE STARTING
RE GRIDPOLR POL STA

```

RE GRIDPOLR POL ORIG      0.0    0.0
RE GRIDPOLR POL DIST    16100 16200 16300 16400 16500 16600 16700 16800 16900
RE GRIDPOLR POL DIST    17000 17100 17200 17300 17400 17500 17600 17700 17800
RE GRIDPOLR POL DIST    17900
RE GRIDPOLR POL GDIR      9    292 2.00
RE GRIDPOLR POL END
RE FINISHED

```

```

ME STARTING
ME INPUTFIL D:\MET\ORL91D.MET
ME ANEMHGHT    10.100 METERS
ME SURFDATA    12815 1991          ORLANDO
ME UAIRDATA    12842 1991          WPB
ME FINISHED

```

```

OU STARTING
OU RECTABLE ALLAVE FIRST
OU FINISHED

```

*** Message Summary For ISC3 Model Setup ***

----- Summary of Total Messages -----

```

A Total of      0 Fatal Error Message(s)
A Total of      1 Warning Message(s)
A Total of      0 Informational Message(s)

```

***** FATAL ERROR MESSAGES *****
 *** NONE ***

***** WARNING MESSAGES *****
 SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter QS

 *** SETUP Finishes Successfully ***

*** ISCST3 - VERSION 99155 *** *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
 *** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M ***

**MODELOPTs:
 CONC RURAL FLAT DEFAULT

*** MODEL SETUP OPTIONS SUMMARY ***

**Intermediate Terrain Processing is Selected

**Model Is Setup For Calculation of Average CONCentration Values.

-- SCAVENGING/DEPOSITION LOGIC --
 **Model Uses NO DRY DEPLETION. DDPLETE = F
 **Model Uses NO WET DEPLETION. WDPLETE = F
 **NO WET SCAVENGING Data Provided.
 **NO GAS DRY DEPOSITION Data Provided.
 **Model Does NOT Use GRIDDED TERRAIN Data for Depletion Calculations

**Model Uses RURAL Dispersion.

**Model Uses Regulatory DEFAULT Options:
 1. Final Plume Rise.
 2. Stack-tip Downwash.
 3. Buoyancy-induced Dispersion.
 4. Use Calms Processing Routine.
 5. Not Use Missing Data Processing Routine.
 6. Default Wind Profile Exponents.
 7. Default Vertical Potential Temperature Gradients.
 8. "Upper Bound" Values for Supersquat Buildings.
 9. No Exponential Decay for RURAL Mode

**Model Assumes Receptors on FLAT Terrain.

**Model Assumes No FLAGPOLE Receptor Heights.

**Model Calculates 1 Short Term Average(s) of: 24-HR

**This Run Includes: 4 Source(s); 1 Source Group(s); and 171 Receptor(s)

**The Model Assumes A Pollutant Type of: GENERIC

**Model Set To Continue RUNning After the Setup Testing.

**Output Options Selected:

Model Outputs Tables of Highest Short Term Values by Receptor (RECTABLE Keyword)

**NOTE: The Following Flags May Appear Following CONC Values: c for Calm Hours
m for Missing Hours
b for Both Calm and Missing Hours

**Misc. Inputs: Anem. Hgt. (m) = 10.10 ; Decay Coef. = 0.000 ; Rot. Angle = 0.0
Emission Units = (GRAMS/SEC) ; Emission Rate Unit Factor = 0.10
Output Units = (MICROGRAMS/CUBIC-METER)

**Approximate Storage Requirements of Model = 1.2 MB of RAM.

**Input Runstream File: REFPM24.I91

**Output Print File: REFPM24.091

*** ISCST3 - VERSION 99155 *** *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M ***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** POINT SOURCE DATA ***

SOURCE ID	NUMBER PART. CATS.	EMISSION RATE (USER UNITS)	X (METERS)	Y (METERS)	BASE ELEV. (METERS)	STACK HEIGHT (METERS)	STACK TEMP. (DEG.K)	STACK EXIT VEL. (M/SEC)	STACK DIAMETER (METERS)	BUILDING EXISTS	EMISS SCAL
ORIGIN	0	0.00000E+00	0.0	0.0	0.0	10.00	500.00	30.00	10.00	NO	
LD7032A	0	0.90000E+00	-39.6	0.0	0.0	15.20	825.00	35.60	5.80	YES	
LD7032B	0	0.90000E+00	0.0	0.0	0.0	15.20	825.00	35.60	5.80	YES	
LD7032C	0	0.90000E+00	39.6	0.0	0.0	15.20	825.00	35.60	5.80	YES	

*** ISCST3 - VERSION 99155 *** *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M ***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** SOURCE IDs DEFINING SOURCE GROUPS ***

GROUP ID

SOURCE IDs

LD7032 LD7032A , LD7032B , LD7032C ,

*** ISCST3 - VERSION 99155 *** *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M ***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** DIRECTION SPECIFIC BUILDING DIMENSIONS ***

SOURCE ID: LD7032A

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	0.0,	0.0,	0	2	0.0,	0.0,	0	3	0.0,	0.0,	0	4	0.0,	0.0,	0	5	0.0,	0.0,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	0.0,	0.0,	0	17	0.0,	0.0,	0	
19	0.0,	0.0,	0	20	0.0,	0.0,	0	21	0.0,	0.0,	0	22	0.0,	0.0,	0	23	0.0,	0.0,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	17.2,	0	32	12.2,	17.2,	0	33	12.2,	16.6,	0	34	0.0,	0.0,	0	35	0.0,	0.0,	0	

SOURCE ID: LD7032B

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	8.5,	14.4,	0	4	12.2,	17.2,	0	5	12.2,	17.2,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	19.1,	0	14	12.2,	19.5,	0	15	12.2,	19.3,	0	16	8.5,	12.0,	0	17	8.5,	18.2,	0	
19	8.5,	27.4,	0	20	8.5,	12.0,	0	21	8.5,	22.3,	0	22	12.2,	17.2,	0	23	12.2,	17.2,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	19.1,	0	32	12.2,	19.5,	0	33	12.2,	19.3,	0	34	8.5,	12.0,	0	35	8.5,	9.2,	0	

SOURCE ID: LD7032C

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	12.2,	19.3,	0	4	12.2,	19.5,	0	5	12.2,	19.1,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	

13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	8.5,	12.0,	0	17	0.0,	0.0,	0
19	0.0,	0.0,	0	20	8.5,	12.0,	0	21	12.2,	19.3,	0	22	12.2,	19.5,	0	23	12.2,	19.1,	0
25	12.2,	15.6,	0	26	12.2,	-14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0
31	12.2,	17.2,	0	32	12.2,	17.2,	0	33	12.2,	16.6,	0	34	8.5,	12.0,	0	35	8.5,	9.2,	0

9/9/99 ***

RURAL ELAT DEFAULT

*** GRIDDED RECEPTOR NETWORK SUMMARY ***

*** NETWORK ID: POL : NETWORK TYPE: GRIDPOLR ***

```

*** ORIGIN FOR POLAR NETWORK ***
X-ORIG = 0.00 ; Y-ORIG = 0.00 (METERS)

```

*** DISTANCE RANGES OF NETWORK ***
(METERS)

16100.0,	16200.0,	16300.0,	16400.0,	16500.0,	16600.0,	16700.0,	16800.0,	16900.0,	17000.0,
17100.0,	17200.0,	17300.0,	17400.0,	17500.0,	17600.0,	17700.0,	17800.0,	17900.0,	

*** DIRECTION RADIALS OF NETWORK ***
(DEGREES)

```

**MODELOPTs:
CONC

```

RURAL FLAT DEFAULT

*** METEOROLOGICAL DAYS SELECTED FOR PROCESSING ***
(1=YES; 0=NO)

[illegible]

NOTE: METEOROLOGICAL DATA ACTUALLY PROCESSED WILL ALSO DEPEND ON WHAT IS INCLUDED IN THE DATA FILE

*** UPPER BOUND OF FIRST THROUGH FIFTH WIND SPEED CATEGORIES ***
(METERS/SEC)

1.54, 3.09, 5.14, 8.23, 10.80,

*** WIND PROFILE EXPONENTS ***

STABILITY CATEGORY	WIND SPEED CATEGORY					
	1	2	3	4	5	6
A	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01
B	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01
C	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+00
D	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+00
E	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+00
F	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+00

*** VERTICAL POTENTIAL TEMPERATURE GRADIENTS ***
(DEGREES KELVIN PER METER)

STABILITY CATEGORY	WIND SPEED CATEGORY					
	1	2	3	4	5	6
A	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+
B	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+
C	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+
D	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+
E	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-
F	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-

*** ISCST3 - VERSION 99155 *** *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***

*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M

**MODELOPTs:
CONC

RURAL FLAT DEFAULT

*** THE FIRST 24 HOURS OF METEOROLOGICAL DATA ***

FILE: D:\MET\ORL91D.MET

FORMAT: (4I2,2F9.4,F6.1,I2,2F7.1,f9.4,f10.1,f8.4,i4,f7.2)

SURFACE STATION NO.: 12815

UPPER AIR STATION NO.: 12842

NAME: ORLANDO

NAME: WPB

YEAR: 1991

YEAR: 1991

YR	MN	DY	HR	FLOW VECTOR	SPEED (M/S)	TEMP (K)	STAB CLASS	MIXING HEIGHT (M)	USTAR (M/S)	M-O LENGTH (M)	Z-0 (M)	IPCODE	PRATE (mm/HR)
91	01	01	01	1.0	4.12	294.3	4	1598.7	1598.7	0.0000	0.0	0.0000	0 0.00
91	01	01	02	328.0	2.06	294.3	5	1613.5	383.0	0.0000	0.0	0.0000	0 0.00
91	01	01	03	74.0	1.54	292.6	6	1628.3	383.0	0.0000	0.0	0.0000	0 0.00
91	01	01	04	343.0	1.54	292.0	7	1643.0	383.0	0.0000	0.0	0.0000	0 0.00
91	01	01	05	123.0	1.54	290.9	7	1657.8	383.0	0.0000	0.0	0.0000	0 0.00
91	01	01	06	302.0	2.06	290.9	6	1672.6	383.0	0.0000	0.0	0.0000	0 0.00
91	01	01	07	195.0	2.06	289.8	6	1687.4	383.0	0.0000	0.0	0.0000	0 0.00
91	01	01	08	273.0	2.06	290.9	5	170.8	517.3	0.0000	0.0	0.0000	0 0.00
91	01	01	09	267.0	0.00	294.8	4	440.8	729.6	0.0000	0.0	0.0000	0 0.00
91	01	01	10	301.0	2.06	297.0	3	710.9	941.9	0.0000	0.0	0.0000	0 0.00
91	01	01	11	314.0	4.63	298.7	3	980.9	1154.1	0.0000	0.0	0.0000	0 0.00
91	01	01	12	316.0	4.12	299.8	3	1250.9	1366.4	0.0000	0.0	0.0000	0 0.00
91	01	01	13	293.0	3.09	300.9	2	1521.0	1578.7	0.0000	0.0	0.0000	0 0.00
91	01	01	14	319.0	4.63	300.9	3	1791.0	1791.0	0.0000	0.0	0.0000	0 0.00
91	01	01	15	302.0	3.60	301.5	3	1791.0	1791.0	0.0000	0.0	0.0000	0 0.00
91	01	01	16	284.0	4.12	300.9	3	1791.0	1791.0	0.0000	0.0	0.0000	0 0.00
91	01	01	17	271.0	5.14	299.3	4	1791.0	1791.0	0.0000	0.0	0.0000	0 0.00
91	01	01	18	237.0	4.63	297.6	4	1786.4	1786.4	0.0000	0.0	0.0000	0 0.00
91	01	01	19	244.0	3.09	295.4	5	1775.2	1497.4	0.0000	0.0	0.0000	0 0.00
91	01	01	20	227.0	3.60	294.3	5	1763.9	1289.5	0.0000	0.0	0.0000	0 0.00
91	01	01	21	220.0	4.12	293.2	5	1752.7	1081.7	0.0000	0.0	0.0000	0 0.00
91	01	01	22	212.0	4.12	292.0	4	1741.5	1741.5	0.0000	0.0	0.0000	0 0.00
91	01	01	23	250.0	4.12	291.5	4	1730.3	1730.3	0.0000	0.0	0.0000	0 0.00
91	01	01	24	230.0	3.09	291.5	4	1719.1	1719.1	0.0000	0.0	0.0000	0 0.00

*** NOTES: STABILITY CLASS 1=A, 2=B, 3=C, 4=D, 5=E AND 6=F.

FLOW VECTOR IS DIRECTION TOWARD WHICH WIND IS BLOWING.

*** ISCST3 - VERSION 99155 ***

*** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS

9/9/99

*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M

**MODELOPTs:
CONC

RURAL FLAT DEFAULT

*** THE 1ST HIGHEST 24-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: LD703
INCLUDING SOURCE(S): LD7032A , LD7032B , LD7032C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

DIRECTION	16100.00	16200.00	16300.00	16400.00
(DEGREES)				
292.0	0.03510 (91020624)	0.03513 (91020624)	0.03516 (91020624)	0.03518 (91020624)
294.0	0.03443 (91022024)	0.03447 (91022024)	0.03452 (91022024)	0.03456 (91022024)
296.0	0.04899 (91021924)	0.04901 (91021924)	0.04902 (91021924)	0.04903 (91021924)
298.0	0.07527 (91021924)	0.07531 (91021924)	0.07535 (91021924)	0.07538 (91021924)
300.0	0.06349 (91021924)	0.06351 (91021924)	0.06352 (91021924)	0.06354 (91021924)
302.0	0.03536 (91021924)	0.03535 (91021924)	0.03534 (91021924)	0.03533 (91021924)
304.0	0.03894 (91011124)	0.03896 (91011124)	0.03898 (91011124)	0.03899 (91011124)
306.0	0.03167 (91052724)	0.03162 (91052724)	0.03157 (91052724)	0.03153 (91052724)
308.0	0.04103 (91030124)	0.04106 (91030124)	0.04109 (91030124)	0.04111 (91030124)

*** ISCST3 - VERSION 99155 ***

*** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS

9/9/99

*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M

**MODELOPTs:
CONC

RURAL FLAT DEFAULT

*** THE 1ST HIGHEST 24-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: LD703
INCLUDING SOURCE(S): LD7032A , LD7032B , LD7032C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

DIRECTION (DEGREES)	16600.00	16700.00	16800.00	16900.00
292.0	0.03523 (91020624)	0.03525 (91020624)	0.03528 (91020624)	0.03530 (91020624)
294.0	0.03464 (91022024)	0.03468 (91022024)	0.03472 (91022024)	0.03475 (91022024)
296.0	0.04905 (91021924)	0.04906 (91021924)	0.04907 (91021924)	0.04907 (91021924)
298.0	0.07545 (91021924)	0.07549 (91021924)	0.07552 (91021924)	0.07555 (91021924)
300.0	0.06356 (91021924)	0.06357 (91021924)	0.06358 (91021924)	0.06358 (91021924)
302.0	0.03531 (91021924)	0.03530 (91021924)	0.03529 (91021924)	0.03528 (91021924)
304.0	0.03902 (91011124)	0.03904 (91011124)	0.03905 (91011124)	0.03906 (91011124)
306.0	0.03143 (91052724)	0.03139 (91052724)	0.03134 (91052724)	0.03130 (91052724)
308.0	0.04116 (91030124)	0.04119 (91030124)	0.04121 (91030124)	0.04123 (91030124)

*** ISCST3 - VERSION 99155 *** *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M ***

**MODELOPTs:
CONC

RURAL FLAT DEFAULT

*** THE 1ST HIGHEST 24-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: LD703
INCLUDING SOURCE(S): LD7032A , LD7032B , LD7032C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER) **

DIRECTION (DEGREES)	17100.00	17200.00	17300.00	17400.00
292.0	0.03534 (91020624)	0.03536 (91020624)	0.03538 (91020624)	0.03540 (91020624)
294.0	0.03483 (91022024)	0.03486 (91022024)	0.03490 (91022024)	0.03493 (91022024)
296.0	0.04908 (91021924)	0.04908 (91021924)	0.04909 (91021924)	0.04909 (91021924)
298.0	0.07560 (91021924)	0.07563 (91021924)	0.07565 (91021924)	0.07567 (91021924)
300.0	0.06359 (91021924)	0.06359 (91021924)	0.06360 (91021924)	0.06360 (91021924)
302.0	0.03525 (91021924)	0.03524 (91021924)	0.03522 (91021924)	0.03521 (91021924)
304.0	0.03908 (91011124)	0.03909 (91011124)	0.03910 (91011124)	0.03911 (91011124)
306.0	0.03126 (91022024)	0.03127 (91022024)	0.03128 (91022024)	0.03129 (91022024)
308.0	0.04127 (91030124)	0.04128 (91030124)	0.04130 (91030124)	0.04132 (91030124)

*** ISCST3 - VERSION 99155 *** *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M ***

**MODELOPTs:
CONC

RURAL FLAT DEFAULT

*** THE 1ST HIGHEST 24-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: LD703
INCLUDING SOURCE(S): LD7032A , LD7032B , LD7032C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER) **

DIRECTION (DEGREES)	17600.00	17700.00	17800.00	17900.00
292.0	0.03544 (91020624)	0.03546 (91020624)	0.03547 (91020624)	0.03549 (91020624)
294.0	0.03499 (91022024)	0.03502 (91022024)	0.03506 (91022024)	0.03509 (91022024)
296.0	0.04909 (91021924)	0.04909 (91021924)	0.04908 (91021924)	0.04908 (91021924)
298.0	0.07571 (91021924)	0.07573 (91021924)	0.07574 (91021924)	0.07576 (91021924)
300.0	0.06359 (91021924)	0.06359 (91021924)	0.06359 (91021924)	0.06358 (91021924)
302.0	0.03518 (91021924)	0.03516 (91021924)	0.03514 (91021924)	0.03512 (91021924)
304.0	0.03912 (91011124)	0.03912 (91011124)	0.03912 (91011124)	0.03913 (91011124)
306.0	0.03131 (91022024)	0.03131 (91022024)	0.03132 (91022024)	0.03132 (91022024)
308.0	0.04134 (91030124)	0.04136 (91030124)	0.04137 (91030124)	0.04138 (91030124)

*** ISCST3 - VERSION 99155 *** *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M ***

**MODELOPTs:
CONC

RURAL FLAT DEFAULT

*** THE SUMMARY OF HIGHEST 24-HR RESULTS ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER) **

GROUP ID	AVERAGE CONC	DATE (YYMMDDHH)	RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF
LD7032	HIGH 1ST HIGH VALUE IS	0.07576 ON 91021924: AT (-15804.76, 8403.54, 0.00,	0.00)

*** RECEPTOR TYPES: GC = GRIDCART
GP = GRIDPOLR
DC = DISCART

DP = DISCPOLR
BD = BOUNDARY

*** ISCST3 - VERSION 99155 *** - *** 1991 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS
*** PM SIG IMP- 24 HR- 70% 32 F/ 300 DEG, 17000 M

9/9/99 ***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** Message Summary : ISCST3 Model Execution ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
A Total of 1 Warning Message(s)
A Total of 144 Informational Message(s)

A Total of 144 Calm Hours Identified

***** FATAL ERROR MESSAGES *****
*** NONE ***

***** WARNING MESSAGES *****
SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter QS

*** ISCST3 Finishes Successfully ***

CO STARTING
 CO TITLEONE 1987 PALMETTO OSCEOLA-CO- SIMPLE CYCLE CTS 9/9/99
 CO TITLETWO CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M
 CO MODELOPT DFAULT CONC RURAL
 CO AVERTIME 1
 CO POLLUTID GENERIC
 CO RUNORNOT RUN
 CO FINISHED

SO STARTING
 ** MODELING ORIGIN IS AT STK FOR CT NO.2
 ** NOT A SOURCE - LOCATION IS USED FOR POLAR DISCREET RECEPTORS.
 SO LOCATION ORIGIN POINT 0.00 0.00 0.00
 SO SRCPARAM ORIGIN 0.0 10.0 500.0 30.00 10.00

** CT STACK LETTER CODE
 ** -----
 ** A - CT 1
 ** B - CT 2
 ** C - CT 3

** Source Location Cards:

UTM	SRCID	SRCTYP	XS (m)	YS (m)	ZS (m)
SO LOCATION	BASE32A	POINT	-39.6	0.0	0.0
SO LOCATION	BASE32B	POINT	0.0	0.0	0.0
SO LOCATION	BASE32C	POINT	39.6	0.0	0.0

** Source Parameter Cards:

POINT:	SRCID	QS (g/s)	HS (m)	TS (K)	VS (m/s)	DS (m)
SO SRCPARAM	BASE32A	14.2	15.2	858.0	44.9	5.8
SO SRCPARAM	BASE32B	14.2	15.2	858.0	44.9	5.8
SO SRCPARAM	BASE32C	14.2	15.2	858.0	44.9	5.8

SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00

SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32B-BASE95B	9.18	11.98	14.42	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	18.18	30.48
SO BUILDWID	BASE32B-BASE95B	27.36	11.98	22.34	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	9.18	15.24

SO BUILDHGT	BASE32C-BASE95C	8.53	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	0.00	0.00
SO BUILDHGT	BASE32C-BASE95C	0.00	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32C-BASE95C	9.18	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	0.00	0.00
SO BUILDWID	BASE32C-BASE95C	0.00	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	9.18	6.10

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)

SO SRCGROUP BASE32 BASE32A BASE32B BASE32C

SO FINISHED

RE STARTING
 RE GRIDPOLR POL STA
 RE GRIDPOLR POL ORIG 0.0 0.0

RE GRIDPOLR POL DIST 1500 1600 1700
 RE GRIDPOLR POL GDIR 9 152 2.00
 RE GRIDPOLR POL END
 RE FINISHED

ME STARTING
 ME INPUTFIL D:\MET\ORL87D.MET
 ME ANEMHGHT 10.100 METERS
 ME SURFDATA 12815 1987 ORLANDO
 ME UAIRDATA 12842 1987 WPB
 ME FINISHED

OU STARTING
 OU RECTABLE ALLAVE FIRST
 OU FINISHED

*** Message Summary For ISC3 Model Setup ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
 A Total of 1 Warning Message(s)
 A Total of 0 Informational Message(s)

***** FATAL ERROR MESSAGES *****
 *** NONE ***

***** WARNING MESSAGES *****
 SO W320 14 PPARAM :Input Parameter May Be Out-of-Range for Parameter QS

 *** SETUP Finishes Successfully ***

*** ISCST3 - VERSION 99155 *** *** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
 *** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M ***

**MODELOPTs:
 CONC RURAL FLAT DEFAULT

*** MODEL SETUP OPTIONS SUMMARY ***

**Intermediate Terrain Processing is Selected

**Model Is Setup For Calculation of Average CONCentration Values.

-- SCAVENGING/DEPOSITION LOGIC --
 **Model Uses NO DRY DEPLETION. DDPLETE = F
 **Model Uses NO WET DEPLETION. WDPLETE = F
 **NO WET SCAVENGING Data Provided.
 **NO GAS DRY DEPOSITION Data Provided.
 **Model Does NOT Use GRIDDED TERRAIN Data for Depletion Calculations

**Model Uses RURAL Dispersion.

**Model Uses Regulatory DEFAULT Options:
 1. Final Plume Rise.
 2. Stack-tip Downwash.
 3. Buoyancy-induced Dispersion.
 4. Use Calms Processing Routine.
 5. Not Use Missing Data Processing Routine.
 6. Default Wind Profile Exponents.
 7. Default Vertical Potential Temperature Gradients.
 8. "Upper Bound" Values for Supersquat Buildings.
 9. No Exponential Decay for RURAL Mode

**Model Assumes Receptors on FLAT Terrain.

**Model Assumes No FLAGPOLE Receptor Heights.

**Model Calculates 1 Short Term Average(s) of: 1-HR

**This Run Includes: 4 Source(s); 1 Source Group(s); and 27 Receptor(s)

**The Model Assumes A Pollutant Type of: GENERIC

**Model Set To Continue RUNning After the Setup Testing.

**Output Options Selected:
 Model Outputs Tables of Highest Short Term Values by Receptor (RECTABLE Keyword)

**NOTE: The Following Flags May Appear Following CONC Values: c for Calm Hours
m for Missing Hours
b for Both Calm and Missing Hours

**Misc. Inputs: Anem. Hgt. (m) = 10.10 ; Decay Coef. = 0.000 ; Rot. Angle = 0.0
Emission Units = (GRAMS/SEC) ; Emission Rate Unit Factor = 0.10
Output Units = (MICROGRAMS/CUBIC-METER)

**Approximate Storage Requirements of Model = 1.2 MB of RAM.

**Input Runstream File: REFCOL.I87

**Output Print File: REFCOL.087

*** ISCST3 - VERSION 99155 *** *** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M ***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** POINT SOURCE DATA ***

SOURCE ID	NUMBER PART. CATS.	EMISSION RATE (USER UNITS)	X (METERS)	Y (METERS)	BASE ELEV. (METERS)	STACK HEIGHT (METERS)	STACK TEMP. (DEG.K)	STACK EXIT VEL. (M/SEC)	STACK DIAMETER (METERS)	BUILDING EXISTS	EMISS SCAL
ORIGIN	0	0.00000E+00	0.0	0.0	0.0	10.00	500.00	30.00	10.00	NO	
BASE32A	0	0.14200E+02	-39.6	0.0	0.0	15.20	858.00	44.90	5.80	YES	
BASE32B	0	0.14200E+02	0.0	0.0	0.0	15.20	858.00	44.90	5.80	YES	
BASE32C	0	0.14200E+02	39.6	0.0	0.0	15.20	858.00	44.90	5.80	YES	
*** ISCST3 - VERSION 99155 ***											
*** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS											***
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M											***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** SOURCE IDs DEFINING SOURCE GROUPS ***

GROUP ID SOURCE IDs

BASE32 BASE32A , BASE32B , BASE32C ,
*** ISCST3 - VERSION 99155 *** *** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M ***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** DIRECTION SPECIFIC BUILDING DIMENSIONS ***

SOURCE ID: BASE32A

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	0.0,	0.0,	0	2	0.0,	0.0,	0	3	0.0,	0.0,	0	4	0.0,	0.0,	0	5	0.0,	0.0,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	0.0,	0.0,	0	17	0.0,	0.0,	0	
19	0.0,	0.0,	0	20	0.0,	0.0,	0	21	0.0,	0.0,	0	22	0.0,	0.0,	0	23	0.0,	0.0,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	17.2,	0	32	12.2,	17.2,	0	33	12.2,	16.6,	0	34	0.0,	0.0,	0	35	0.0,	0.0,	0	

SOURCE ID: BASE32B

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	8.5,	14.4,	0	4	12.2,	17.2,	0	5	12.2,	17.2,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	19.1,	0	14	12.2,	19.5,	0	15	12.2,	19.3,	0	16	8.5,	12.0,	0	17	8.5,	18.2,	0	
19	8.5,	27.4,	0	20	8.5,	12.0,	0	21	8.5,	22.3,	0	22	12.2,	17.2,	0	23	12.2,	17.2,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	19.1,	0	32	12.2,	19.5,	0	33	12.2,	19.3,	0	34	8.5,	12.0,	0	35	8.5,	9.2,	0	

SOURCE ID: BASE32C

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	12.2,	19.3,	0	4	12.2,	19.5,	0	5	12.2,	19.1,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	8.5,	12.0,	0	17	0.0,	0.0,	0	
19	0.0,	0.0,	0	20	8.5,	12.0,	0	21	12.2,	19.3,	0	22	12.2,	19.5,	0	23	12.2,	19.1,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	

```

*** ISCS T3 - VERSION 99155 ***      *** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS      9/9/99      ***
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG. 1600 M      ***

```

RURAL FLAT DEFAULT

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

*** DISTANCE RANGES OF NETWORK ***
(METERS)

1500.0, 1600.0, 1700.0,

```

152.0,    154.0,    156.0,    158.0,    160.0,    162.0,    164.0,    166.0,    168.0,
*** ISCST3 - VERSION 99155 ***      *** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS      9/9/99      ***
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M ***

```

RURAL FLAT DEFAULT

[illegible]

NOTE: METEOROLOGICAL DATA ACTUALLY PROCESSED WILL ALSO DEPEND ON WHAT IS INCLUDED IN THE DATA FI

1.54, 3.09, 5.14, 8.23, 10.80,

STABILITY CATEGORY	WIND SPEED CATEGORY					
	1	2	3	4	5	6
A	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-
B	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-
C	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+
D	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+
E	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+
F	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+

STABILITY CATEGORY	WIND SPEED CATEGORY					
	1	2	3	4	5	6
A	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
B	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
C	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
D	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
E	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01
F	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01

```

*** ISCS T3 - VERSION 99155 ***      1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS      9/9/99      ***
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG. 1600 M ***

```

RURAL FLAT DEFAULT

*** THE FIRST 24 HOURS OF METEOROLOGICAL DATA ***

FILE: D:\MET\ORL87D.MET

FORMAT: (4I2,2F9.4,F6.1,I2,2F7.1,f9.4,f10.1,f8.4,i4,f7.2)

SURFACE STATION NO.: 12815

UPPER AIR STATION NO.: 12842

NAME: ORLANDO

NAME: WPB

YEAR: 1987

YEAR: 1987

YR	MN	DY	HR	FLOW VECTOR	SPEED (M/S)	TEMP (K)	STAB CLASS	MIXING HEIGHT (M)	USTAR (M/S)	M-O LENGTH (M)	Z-0 (M)	IPCODE	PRATE (mm/HR)
87	01	01	01	341.0	7.20	292.0	4	602.1	602.1	0.0000	0.0	0.0000	0 0.00
87	01	01	02	348.0	6.17	292.0	4	654.8	654.8	0.0000	0.0	0.0000	0 0.00
87	01	01	03	354.0	6.17	292.0	4	707.6	707.6	0.0000	0.0	0.0000	0 0.00
87	01	01	04	353.0	6.17	292.0	4	760.4	760.4	0.0000	0.0	0.0000	0 0.00
87	01	01	05	13.0	6.17	291.5	4	813.1	813.1	0.0000	0.0	0.0000	0 0.00
87	01	01	06	42.0	6.17	292.0	4	865.9	865.9	0.0000	0.0	0.0000	0 0.00
87	01	01	07	65.0	9.26	290.9	4	918.7	918.7	0.0000	0.0	0.0000	0 0.00
87	01	01	08	63.0	9.26	289.8	4	971.4	971.4	0.0000	0.0	0.0000	0 0.00
87	01	01	09	77.0	9.26	289.3	4	1024.2	1024.2	0.0000	0.0	0.0000	0 0.00
87	01	01	10	101.0	7.72	288.2	4	1076.9	1076.9	0.0000	0.0	0.0000	0 0.00
87	01	01	11	84.0	9.77	287.6	4	1129.7	1129.7	0.0000	0.0	0.0000	0 0.00
87	01	01	12	76.0	8.75	287.0	4	1182.5	1182.5	0.0000	0.0	0.0000	0 0.00
87	01	01	13	73.0	6.69	286.5	4	1235.2	1235.2	0.0000	0.0	0.0000	0 0.00
87	01	01	14	69.0	9.77	287.0	4	1288.0	1288.0	0.0000	0.0	0.0000	0 0.00
87	01	01	15	92.0	9.26	287.0	4	1288.0	1288.0	0.0000	0.0	0.0000	0 0.00
87	01	01	16	94.0	7.72	287.0	4	1288.0	1288.0	0.0000	0.0	0.0000	0 0.00
87	01	01	17	111.0	5.66	287.0	4	1288.0	1288.0	0.0000	0.0	0.0000	0 0.00
87	01	01	18	87.0	3.60	285.9	5	1285.9	1223.3	0.0000	0.0	0.0000	0 0.00
87	01	01	19	84.0	3.60	285.4	5	1280.7	1066.2	0.0000	0.0	0.0000	0 0.00
87	01	01	20	67.0	4.12	284.3	5	1275.6	909.2	0.0000	0.0	0.0000	0 0.00
87	01	01	21	80.0	3.60	284.3	5	1270.4	752.1	0.0000	0.0	0.0000	0 0.00
87	01	01	22	92.0	4.12	284.8	4	1265.3	1265.3	0.0000	0.0	0.0000	0 0.00
87	01	01	23	110.0	4.12	284.8	4	1260.2	1260.2	0.0000	0.0	0.0000	0 0.00
87	01	01	24	110.0	4.63	284.8	4	1255.0	1255.0	0.0000	0.0	0.0000	0 0.00

*** NOTES: STABILITY CLASS 1=A, 2=B, 3=C, 4=D, 5=E AND 6=F.

FLOW VECTOR IS DIRECTION TOWARD WHICH WIND IS BLOWING.

*** ISCST3 - VERSION 99155 ***

*** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M

9/9/99

*****MODELOPTS:
CONC

RURAL FLAT DEFAULT

*** THE 1ST HIGHEST 1-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: BASE3
INCLUDING SOURCE(S): BASE32A , BASE32B , BASE32C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

DIRECTION	1500.00	1600.00	DISTANCE (METERS)
(DEGREES)			1700.00

152.0	7.18447 (87082013)	7.59373 (87082013)	7.64203 (87082013)
154.0	7.55917 (87082013)	7.97427 (87082013)	8.01792 (87082013)
156.0	7.81741 (87082013)	8.23612 (87082013)	8.27651 (87082013)
158.0	7.94903 (87082013)	8.36930 (87082013)	8.40792 (87082013)
160.0	7.94888 (87082013)	8.36871 (87082013)	8.40710 (87082013)
162.0	7.81703 (87082013)	8.23443 (87082013)	8.27415 (87082013)
164.0	7.55878 (87082013)	7.97170 (87082013)	8.01424 (87082013)
166.0	7.18439 (87082013)	7.59067 (87082013)	7.63739 (87082013)
168.0	6.70859 (87082013)	7.10589 (87082013)	7.15797 (87082013)

*** ISCST3 - VERSION 99155 ***

*** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M

9/9/99

*****MODELOPTS:
CONC

RURAL FLAT DEFAULT

*** THE SUMMARY OF HIGHEST 1-HR RESULTS ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

GROUP ID	AVERAGE CONC	DATE (YYMMDDHH)	RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF
BASE32 HIGH 1ST HIGH VALUE IS	8.40792	ON 87082013: AT (636.83, -1576.21, 0.00,	0.00)

*** RECEPTOR TYPES: GC = GRIDCART
GP = GRIDPOLR
DC = DISCCART
DP = DISCPOLR
BD = BOUNDARY

*** ISCST3 - VERSION 99155 ***

*** 1987 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS
*** CO SIG IMP- 1 HR- BASE 32 F/ 160 DEG, 1600 M

9/9/99

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** Message Summary : ISCST3 Model Execution ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
A Total of 1 Warning Message(s)
A Total of 273 Informational Message(s)

A Total of 273 Calm Hours Identified

***** FATAL ERROR MESSAGES *****
*** NONE ***

***** WARNING MESSAGES *****
SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter QS

*** ISCST3 Finishes Successfully ***

CO STARTING
 CO TITLEONE 1990 PALMETTO OSCEOLA-CO- SIMPLE CYCLE CTS 9/9/99
 CO TITLETWO CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M
 CO MODELOPT DFAULT CONC RURAL
 CO AVERTIME 8
 CO POLLUTID GENERIC
 CO RUNORNOT RUN
 CO FINISHED

SO STARTING
 ** MODELING ORIGIN IS AT STK FOR CT NO.2
 ** NOT A SOURCE - LOCATION IS USED FOR POLAR DISCREET RECEPTORS.
 SO LOCATION ORIGIN POINT 0.00 0.00 0.00
 SO SRCPARAM ORIGIN 0.0 10.0 500.0 30.00 10.00

** CT STACK LETTER CODE

** -----
 ** A - CT 1
 ** B - CT 2
 ** C - CT 3

** Source Location Cards:

UTM	SRCID	SRCTYP	XS (m)	YS (m)	ZS (m)
SO LOCATION	BASE32A	POINT	-39.6	0.0	0.0
SO LOCATION	BASE32B	POINT	0.0	0.0	0.0
SO LOCATION	BASE32C	POINT	39.6	0.0	0.0

** Source Parameter Cards:

POINT:	SRCID	QS (g/s)	HS (m)	TS (K)	VS (m/s)	DS (m)
SO SRCPARAM	BASE32A	14.2	15.2	858.0	44.9	5.8
SO SRCPARAM	BASE32B	14.2	15.2	858.0	44.9	5.8
SO SRCPARAM	BASE32C	14.2	15.2	858.0	44.9	5.8

SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00

SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32B-BASE95B	9.18	11.98	14.42	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	18.18	30.48
SO BUILDWID	BASE32B-BASE95B	27.36	11.98	22.34	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	9.18	15.24

SO BUILDHGT	BASE32C-BASE95C	8.53	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	0.00	0.00
SO BUILDHGT	BASE32C-BASE95C	0.00	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32C-BASE95C	9.18	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	0.00	0.00
SO BUILDWID	BASE32C-BASE95C	0.00	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	9.18	6.10

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)

SO SRCGROUP BASE32 BASE32A BASE32B BASE32C

SO FINISHED

RE STARTING
 RE GRIDPOLR POL STA
 RE GRIDPOLR POL ORIG 0.0 0.0

RE GRIDPOLR POL DIST 19100 19200 19300 19400 19500 19600 19700 19800 19900
 RE GRIDPOLR POL DIST 20000 20100 20200 20300 20400 20500 20600 20700 20800
 RE GRIDPOLR POL DIST 20900
 RE GRIDPOLR POL GDIR 9 172 2.00
 RE GRIDPOLR POL END
 RE FINISHED

ME STARTING
 ME INPUTFIL D:\MET\ORL90D.MET
 ME ANEMHGHT 10.100 METERS
 ME SURFDATA 12815 1990 ORLANDO
 ME UAIRDATA 12842 1990 WPB
 ME FINISHED

OU STARTING
 OU RECTABLE ALLAVE FIRST
 OU FINISHED

*** Message Summary For ISC3 Model Setup ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
 A Total of 1 Warning Message(s)
 A Total of 0 Informational Message(s)

***** FATAL ERROR MESSAGES *****
 *** NONE ***

***** WARNING MESSAGES *****
 SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter QS

 *** SETUP Finishes Successfully ***

*** ISCST3 - VERSION 99155 *** *** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
 *** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M ***
 **MODELOPTs:
 CONC RURAL FLAT DEFAULT

*** MODEL SETUP OPTIONS SUMMARY ***

 **Intermediate Terrain Processing is Selected

**Model Is Setup For Calculation of Average CONCentration Values.

-- SCAVENGING/DEPOSITION LOGIC --
 **Model Uses NO DRY DEPLETION. DDPLETE = F
 **Model Uses NO WET DEPLETION. WDPLETE = F
 **NO WET SCAVENGING Data Provided.
 **NO GAS DRY DEPOSITION Data Provided.
 **Model Does NOT Use GRIDDED TERRAIN Data for Depletion Calculations

**Model Uses RURAL Dispersion.

**Model Uses Regulatory DEFAULT Options:
 1. Final Plume Rise.
 2. Stack-tip Downwash.
 3. Buoyancy-induced Dispersion.
 4. Use Calms Processing Routine.
 5. Not Use Missing Data Processing Routine.
 6. Default Wind Profile Exponents.
 7. Default Vertical Potential Temperature Gradients.
 8. "Upper Bound" Values for Supersquat Buildings.
 9. No Exponential Decay for RURAL Mode

**Model Assumes Receptors on FLAT Terrain.

**Model Assumes No FLAGPOLE Receptor Heights.

**Model Calculates 1 Short Term Average(s) of: 8-HR

**This Run Includes: 4 Source(s); 1 Source Group(s); and 171 Receptor(s)

**The Model Assumes A Pollutant Type of: GENERIC

**Model Set To Continue RUNning After the Setup Testing.

**Output Options Selected:

Model Outputs Tables of Highest Short Term Values by Receptor (RECTABLE Keyword)

**NOTE: The Following Flags May Appear Following CONC Values: c for Calm Hours
m for Missing Hours
b for Both Calm and Missing Hours

**Misc. Inputs: Anem. Hgt. (m) = 10.10 ; Decay Coef. = 0.000 ; Rot. Angle = 0.0
Emission Units = (GRAMS/SEC) ; Emission Rate Unit Factor = 0.10
Output Units = (MICROGRAMS/CUBIC-METER)

**Approximate Storage Requirements of Model = 1.2 MB of RAM.

**Input Runstream File: REFCO8.I90

**Output Print File: REFCO8.090

*** ISCST3 - VERSION 99155 *** *** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M ***

**MODELOPTs:

CONC RURAL FLAT DEFAULT

*** POINT SOURCE DATA ***

SOURCE ID	PART. CATS.	NUMBER EMISSION RATE (USER UNITS)	X (METERS)	Y (METERS)	BASE ELEV. (METERS)	STACK HEIGHT (METERS)	STACK TEMP. (DEG.K)	STACK EXIT VEL. (M/SEC)	STACK DIAMETER (METERS)	BUILDING EXISTS	EMISS SCAL
ORIGIN	0	0.00000E+00	0.0	0.0	0.0	10.00	500.00	30.00	10.00	NO	
BASE32A	0	0.14200E+02	-39.6	0.0	0.0	15.20	858.00	44.90	5.80	YES	
BASE32B	0	0.14200E+02	0.0	0.0	0.0	15.20	858.00	44.90	5.80	YES	
BASE32C	0	0.14200E+02	39.6	0.0	0.0	15.20	858.00	44.90	5.80	YES	
*** ISCST3 - VERSION 99155 *** *** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***											
*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M ***											

**MODELOPTs:

CONC RURAL FLAT DEFAULT

*** SOURCE IDs DEFINING SOURCE GROUPS ***

GROUP ID SOURCE IDs

BASE32 BASE32A , BASE32B , BASE32C ,
*** ISCST3 - VERSION 99155 *** *** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M ***

**MODELOPTs:

CONC RURAL FLAT DEFAULT

*** DIRECTION SPECIFIC BUILDING DIMENSIONS ***

SOURCE ID: BASE32A

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	0.0,	0.0,	0	2	0.0,	0.0,	0	3	0.0,	0.0,	0	4	0.0,	0.0,	0	5	0.0,	0.0,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	0.0,	0.0,	0	17	0.0,	0.0,	0	
19	0.0,	0.0,	0	20	0.0,	0.0,	0	21	0.0,	0.0,	0	22	0.0,	0.0,	0	23	0.0,	0.0,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	17.2,	0	32	12.2,	17.2,	0	33	12.2,	16.6,	0	34	0.0,	0.0,	0	35	0.0,	0.0,	0	

SOURCE ID: BASE32B

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	8.5,	14.4,	0	4	12.2,	17.2,	0	5	12.2,	17.2,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	19.1,	0	14	12.2,	19.5,	0	15	12.2,	19.3,	0	16	8.5,	12.0,	0	17	8.5,	18.2,	0	
19	8.5,	27.4,	0	20	8.5,	12.0,	0	21	8.5,	22.3,	0	22	12.2,	17.2,	0	23	12.2,	17.2,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	19.1,	0	32	12.2,	19.5,	0	33	12.2,	19.3,	0	34	8.5,	12.0,	0	35	8.5,	9.2,	0	

SOURCE ID: BASE32C

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	12.2,	19.3,	0	4	12.2,	19.5,	0	5	12.2,	19.1,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	8.5,	12.0,	0	17	0.0,	0.0,	0	

RURAL FLAT DEFAULT

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

*** DISTANCE RANGES OF NETWORK ***
(METERS)

*** DIRECTION RADIALS OF NETWORK ***
(DEGREES)

RURAL FLAT DEFAULT

[illegible]

NOTE: METEOROLOGICAL DATA ACTUALLY PROCESSED WILL ALSO DEPEND ON WHAT IS INCLUDED IN THE DATA FI

1.54, 3.09, 5.14, 8.23, 10.80,

*** WIND PROFILE EXPONENTS ***

STABILITY CATEGORY	WIND SPEED CATEGORY					
	1	2	3	4	5	6
A	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-
B	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-
C	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+
D	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+
E	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+
F	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+

*** VERTICAL POTENTIAL TEMPERATURE GRADIENTS ***
(DEGREES KELVIN PER METER)

STABILITY CATEGORY	WIND SPEED CATEGORY					
	1	2	3	4	5	6
A	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+
B	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+
C	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+
D	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+
E	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-
F	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-

Page: 4

**MODELOPTS:

CONC

RURAL FLAT

DEFAULT

*** THE FIRST 24 HOURS OF METEOROLOGICAL DATA ***

FILE: D:\MET\ORL90D.MET

FORMAT: (4I2,2F9.4,F6.1,I2,2F7.1,f9.4,f10.1,f8.4,i4,f7.2)

SURFACE STATION NO.: 12815

UPPER AIR STATION NO.: 12842

NAME: ORLANDO

NAME: WPB

YEAR: 1990

YEAR: 1990

YR	MN	DY	HR	FLOW VECTOR	SPEED (M/S)	TEMP (K)	STAB CLASS	MIXING HEIGHT (M) RURAL	MIXING HEIGHT (M) URBAN	USTAR (M/S)	M-O LENGTH (M)	Z-O (M)	IPCODE	PRATE (mm/HR)
90	01	01	01	11.0	5.14	292.6	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	02	18.0	5.66	293.2	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	03	14.0	6.17	293.7	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	04	33.0	5.14	293.7	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	05	23.0	6.17	293.2	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	06	22.0	5.66	293.2	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	07	25.0	6.17	293.2	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	08	53.0	5.14	293.7	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	09	67.0	5.14	293.7	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	10	71.0	4.63	292.6	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	11	124.0	7.20	292.6	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	12	116.0	5.14	292.6	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	13	133.0	5.14	291.5	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	14	139.0	4.12	290.9	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	15	172.0	6.17	289.3	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	16	174.0	5.14	288.7	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	17	181.0	4.12	288.7	4	1309.0	1309.0	0.0000	0.0	0.0000	0	0.00
90	01	01	18	247.0	3.09	287.0	5	1309.0	1241.9	0.0000	0.0	0.0000	0	0.00
90	01	01	19	214.0	1.54	284.8	6	1309.0	1079.3	0.0000	0.0	0.0000	0	0.00
90	01	01	20	197.0	3.09	283.2	5	1309.0	916.6	0.0000	0.0	0.0000	0	0.00
90	01	01	21	190.0	3.09	282.0	5	1309.0	754.0	0.0000	0.0	0.0000	0	0.00
90	01	01	22	192.0	3.09	281.5	5	1309.0	591.3	0.0000	0.0	0.0000	0	0.00
90	01	01	23	200.0	3.09	281.5	5	1309.0	428.7	0.0000	0.0	0.0000	0	0.00
90	01	01	24	170.0	3.09	281.5	5	1309.0	266.0	0.0000	0.0	0.0000	0	0.00

*** NOTES: STABILITY CLASS 1=A, 2=B, 3=C, 4=D, 5=E AND 6=F.

FLOW VECTOR IS DIRECTION TOWARD WHICH WIND IS BLOWING.

*** ISCST3 - VERSION 99155 ***

*** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS

9/9/99

*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M

**MODELOPTS:

CONC

RURAL FLAT

DEFAULT

*** THE 1ST HIGHEST 8-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: BASE3
INCLUDING SOURCE(S): BASE32A , BASE32B , BASE32C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

DIRECTION (DEGREES)	19100.00	19200.00	19300.00	19400.00
-----------------------	----------	----------	----------	----------

172.0	0.95159 (90092508)	0.95197 (90092508)	0.95234 (90092508)	0.95269 (90092508)
174.0	0.81291 (90030524)	0.81380 (90030524)	0.81469 (90030524)	0.81556 (90030524)
176.0	1.15274 (90030524)	1.15411 (90030524)	1.15546 (90030524)	1.15679 (90030524)
178.0	1.40204 (90122508)	1.40213 (90122508)	1.40219 (90122508)	1.40223 (90122508)
180.0	2.05300 (90122508)	2.05403 (90122508)	2.05502 (90122508)	2.05597 (90122508)
182.0	1.44305 (90122508)	1.44301 (90122508)	1.44294 (90122508)	1.44285 (90122508)
184.0	0.96412 (90111824)	0.96482 (90111824)	0.96550 (90111824)	0.96617 (90111824)
186.0	1.30713 (90010308)	1.30845 (90010308)	1.30975 (90010308)	1.31102 (90010308)
188.0	1.64845 (90010308)	1.65014 (90010308)	1.65181 (90010308)	1.65344 (90010308)

*** ISCST3 - VERSION 99155 ***

*** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS

9/9/99

*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M

**MODELOPTS:

CONC

RURAL FLAT

DEFAULT

*** THE 1ST HIGHEST 8-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: BASE3
INCLUDING SOURCE(S): BASE32A , BASE32B , BASE32C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

DIRECTION	DISTANCE (METERS)
-----------	-------------------

(DEGREES)	19600.00	19700.00	19800.00	19900.00
172.0	0.95335 (90092508)	0.95365 (90092508)	0.95394 (90092508)	0.95421 (90092508)
174.0	0.81726 (90030524)	0.81810 (90030524)	0.81892 (90030524)	0.81972 (90030524)
176.0	1.15939 (90030524)	1.16065 (90030524)	1.16190 (90030524)	1.16313 (90030524)
178.0	1.40223 (90122508)	1.40219 (90122508)	1.40214 (90122508)	1.40206 (90122508)
180.0	2.05776 (90122508)	2.05859 (90122508)	2.05939 (90122508)	2.06016 (90122508)
182.0	1.44260 (90122508)	1.44244 (90122508)	1.44225 (90122508)	1.44204 (90122508)
184.0	0.96744 (90111824)	0.96805 (90111824)	0.96864 (90111824)	0.96921 (90111824)
186.0	1.31350 (90010308)	1.31470 (90010308)	1.31588 (90010308)	1.31704 (90010308)
188.0	1.65661 (90010308)	1.65816 (90010308)	1.65967 (90010308)	1.66115 (90010308)
*** ISCST3 - VERSION 99155 ***				
*** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS				
*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M				

**MODELOPTS:
CONC

RURAL FLAT DEFAULT

*** THE 1ST HIGHEST 8-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: BASE3
INCLUDING SOURCE(S): BASE32A , BASE32B , BASE32C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER) **

DIRECTION	20100.00	20200.00	20300.00	20400.00
(DEGREES)				
172.0	0.95387 (90092508)	0.95316 (90092508)	0.95245 (90092508)	0.95174 (90092508)
174.0	0.82048 (90030524)	0.82032 (90030524)	0.82015 (90030524)	0.81998 (90030524)
176.0	1.16434 (90030524)	1.16421 (90030524)	1.16408 (90030524)	1.16394 (90030524)
178.0	1.40068 (90122508)	1.39925 (90122508)	1.39781 (90122508)	1.39637 (90122508)
180.0	2.05969 (90122508)	2.05846 (90122508)	2.05722 (90122508)	2.05596 (90122508)
182.0	1.44040 (90122508)	1.43881 (90122508)	1.43721 (90122508)	1.43561 (90122508)
184.0	0.96939 (90111824)	0.96897 (90111824)	0.96854 (90111824)	0.96810 (90111824)
186.0	1.31798 (90010308)	1.31766 (90010308)	1.31732 (90010308)	1.31697 (90010308)
188.0	1.66237 (90010308)	1.66200 (90010308)	1.66162 (90010308)	1.66122 (90010308)
*** ISCST3 - VERSION 99155 ***				
*** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS				
*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M				

**MODELOPTs:
CONC

RURAL FLAT DEFAULT

*** THE 1ST HIGHEST 8-HR AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: BASE3
INCLUDING SOURCE(S): BASE32A , BASE32B , BASE32C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER) **

DIRECTION	20600.00	20700.00	20800.00	20900.00
(DEGREES)				
172.0	0.95029 (90092508)	0.94956 (90092508)	0.94883 (90092508)	0.94809 (90092508)
174.0	0.81963 (90030524)	0.81944 (90030524)	0.81925 (90030524)	0.81906 (90030524)
176.0	1.16363 (90030524)	1.16347 (90030524)	1.16329 (90030524)	1.16311 (90030524)
178.0	1.39346 (90122508)	1.39200 (90122508)	1.39054 (90122508)	1.38907 (90122508)
180.0	2.05340 (90122508)	2.05210 (90122508)	2.05078 (90122508)	2.04946 (90122508)
182.0	1.43239 (90122508)	1.43077 (90122508)	1.42914 (90122508)	1.42752 (90122508)
184.0	0.96721 (90111824)	0.96676 (90111824)	0.96630 (90111824)	0.96583 (90111824)
186.0	1.31625 (90010308)	1.31588 (90010308)	1.31549 (90010308)	1.31510 (90010308)
188.0	1.66039 (90010308)	1.65996 (90010308)	1.65951 (90010308)	1.65905 (90010308)
*** ISCST3 - VERSION 99155 ***				
*** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS				
*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M				

**MODELOPTs:
CONC

RURAL FLAT DEFAULT

*** THE SUMMARY OF HIGHEST 8-HR RESULTS ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER) **

GROUP ID	AVERAGE CONC	DATE (YYMMDDHH)	RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF
BASE32 HIGH 1ST HIGH VALUE IS	2.06088	ON 90122508: AT (0.00, -20000.00, 0.00,	0.00)

*** RECEPTOR TYPES: GC = GRIDCART
GP = GRIDPOLR
DC = DISCCART
DP = DISCPOLR

```
BD = BOUNDARY
*** ISCST3 - VERSION 99155 ***      *** 1990 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS      9/9/99      ***
*** CO SIG IMP- 8 HR- BASE 32 F/ 180 DEG, 20000 M      ***
**MODELOPTs:
CONC          RURAL FLAT          DFAULT
```

*** Message Summary : ISCST3 Model Execution ***

----- Summary of Total Messages -----

```
A Total of          0 Fatal Error Message(s)
A Total of          1 Warning Message(s)
A Total of          382 Informational Message(s)
A Total of          382 Calm Hours Identified
```

```
***** FATAL ERROR MESSAGES *****
*** NONE ***
```

```
***** WARNING MESSAGES *****
SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter      QS
```

```
*****
*** ISCST3 Finishes Successfully ***
*****
```


CO STARTING
 CO TITLEONE 1989 PALMETTO OSCEOLA-CO- SIMPLE CYCLE CTS 9/9/99
 CO TITLETWO NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M
 CO MODELOPT DFAULT CONC RURAL
 CO AVERTIME PERIOD
 CO POLLUTID GENERIC
 CO RUNORNOT RUN
 CO FINISHED

SO STARTING
 ** MODELING ORIGIN IS AT STK FOR CT NO.2
 ** NOT A SOURCE - LOCATION IS USED FOR POLAR DISCREET RECEPTORS.
 SO LOCATION ORIGIN POINT 0.00 0.00 0.00
 SO SRCPARAM ORIGIN 0.0 10.0 500.0 30.00 10.00

** CT STACK LETTER CODE

** -----
 ** A - CT 1
 ** B - CT 2
 ** C - CT 3

** Source Location Cards:

UTM	SRCID	SRCTYP	XS (m)	YS (m)	ZS (m)
SO LOCATION	BASE32A	POINT	-39.6	0.0	0.0
SO LOCATION	BASE32B	POINT	0.0	0.0	0.0
SO LOCATION	BASE32C	POINT	39.6	0.0	0.0

** Source Parameter Cards:

50 ft CT stack	POINT:	SRCID	QS (g/s)	HS (m)	TS (K)	VS (m/s)	DS (m)
SO SRCPARAM	BASE32A		14.0	15.2	858.0	44.9	5.8
SO SRCPARAM	BASE32B		14.0	15.2	858.0	44.9	5.8
SO SRCPARAM	BASE32C		14.0	15.2	858.0	44.9	5.8

SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDHGT	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32A-BASE95A	12.19	12.19	12.19	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00
SO BUILDWID	BASE32A-BASE95A	0.00	0.00	0.00	0.00	0.00	16.65
SO BUILDWID	BASE32A-BASE95A	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32A-BASE95A	17.18	17.18	16.65	0.00	0.00	0.00

SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDHGT	BASE32B-BASE95B	8.53	8.53	8.53	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32B-BASE95B	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32B-BASE95B	9.18	11.98	14.42	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	18.18	30.48
SO BUILDWID	BASE32B-BASE95B	27.36	11.98	22.34	17.18	17.18	16.65
SO BUILDWID	BASE32B-BASE95B	15.63	14.12	12.19	14.12	15.63	18.18
SO BUILDWID	BASE32B-BASE95B	19.14	19.51	19.29	11.98	9.18	15.24

SO BUILDHGT	BASE32C-BASE95C	8.53	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	0.00	0.00
SO BUILDHGT	BASE32C-BASE95C	0.00	8.53	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	12.19	12.19	12.19
SO BUILDHGT	BASE32C-BASE95C	12.19	12.19	12.19	8.53	8.53	8.53
SO BUILDWID	BASE32C-BASE95C	9.18	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	0.00	0.00
SO BUILDWID	BASE32C-BASE95C	0.00	11.98	19.29	19.51	19.14	16.65
SO BUILDWID	BASE32C-BASE95C	15.63	14.12	12.19	14.12	15.63	16.65
SO BUILDWID	BASE32C-BASE95C	17.18	17.18	16.65	11.98	9.18	6.10

SO EMISUNIT .100000E+07 (GRAMS/SEC) (MICROGRAMS/CUBIC-METER)

SO SRCGROUP BASE32 BASE32A BASE32B BASE32C

SO FINISHED

RE STARTING
 RE GRIDPOLR POL STA

RE GRIDPOLR POL ORIG 0.0 0.0
RE GRIDPOLR POL DIST 200 300 400
RE GRIDPOLR POL GDIR 9 222 2.00
RE GRIDPOLR POL END
RE FINISHED

ME STARTING
ME INPUTFIL D:\MET\ORL89D.MET
ME ANEMHGHT 10.100 METERS
ME SURFDATA 12815 1989 ORLANDO
ME UAIRDATA 12842 1989 WPB
ME FINISHED

OU STARTING
OU RECTABLE ALLAVE FIRST
OU FINISHED

*** Message Summary For ISC3 Model Setup ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
A Total of 1 Warning Message(s)
A Total of 0 Informational Message(s)

***** FATAL ERROR MESSAGES *****
*** NONE ***

***** WARNING MESSAGES *****
SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter QS

*** SETUP Finishes Successfully ***

*** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
*** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTS:
CONC RURAL FLAT DEFAULT

*** MODEL SETUP OPTIONS SUMMARY ***

**Intermediate Terrain Processing is Selected

**Model Is Setup For Calculation of Average CONCentration Values.

-- SCAVENGING/DEPOSITION LOGIC --

**Model Uses NO DRY DEPLETION. DDPLETE = F
**Model Uses NO WET DEPLETION. WDPLETE = F
**NO WET SCAVENGING Data Provided.
**NO GAS DRY DEPOSITION Data Provided.
**Model Does NOT Use GRIDDED TERRAIN Data for Depletion Calculations

**Model Uses RURAL Dispersion.

**Model Uses Regulatory DEFAULT Options:
1. Final Plume Rise.
2. Stack-tip Downwash.
3. Buoyancy-induced Dispersion.
4. Use Calms Processing Routine.
5. Not Use Missing Data Processing Routine.
6. Default Wind Profile Exponents.
7. Default Vertical Potential Temperature Gradients.
8. "Upper Bound" Values for Supersquat Buildings.
9. No Exponential Decay for RURAL Mode

**Model Assumes Receptors on FLAT Terrain.

**Model Assumes No FLAGPOLE Receptor Heights.

**Model Calculates PERIOD Averages Only

**This Run Includes: 4 Source(s); 1 Source Group(s); and 27 Receptor(s)

**The Model Assumes A Pollutant Type of: GENERIC

**Model Set To Continue RUNning After the Setup Testing.

**Output Options Selected:

Model Outputs Tables of PERIOD Averages by Receptor
 Model Outputs Tables of Highest Short Term Values by Receptor (RECTABLE Keyword)

**NOTE: The Following Flags May Appear Following CONC Values: c for Calm Hours
 m for Missing Hours
 b for Both Calm and Missing Hours

**Misc. Inputs: Anem. Hgt. (m) = 10.10 ; Decay Coef. = 0.000 ; Rot. Angle = 0.0
 Emission Units = (GRAMS/SEC) ; Emission Rate Unit Factor = 0.10
 Output Units = (MICROGRAMS/CUBIC-METER)

**Approximate Storage Requirements of Model = 1.2 MB of RAM.

**Input Runstream File: REFNO2AN.I89

**Output Print File: REFNO2AN.089

*** ISCST3 - VERSION 99155 *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
 *** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTS:

CONC RURAL FLAT DEFAULT

*** POINT SOURCE DATA ***

SOURCE ID	PART. CATS.	NUMBER EMISSION RATE (USER UNITS)	X (METERS)	Y (METERS)	BASE ELEV. (METERS)	STACK HEIGHT (METERS)	STACK TEMP. (DEG.K)	STACK EXIT VEL. (M/SEC)	STACK DIAMETER (METERS)	BUILDING EXISTS	EMISS SCAL
ORIGIN	0	0.00000E+00	0.0	0.0	0.0	10.00	500.00	30.00	10.00	NO	
BASE32A	0	0.14000E+02	-39.6	0.0	0.0	15.20	858.00	44.90	5.80	YES	
BASE32B	0	0.14000E+02	0.0	0.0	0.0	15.20	858.00	44.90	5.80	YES	
BASE32C	0	0.14000E+02	39.6	0.0	0.0	15.20	858.00	44.90	5.80	YES	
*** ISCST3 - VERSION 99155 ***											

**MODELOPTS:

CONC RURAL FLAT DEFAULT

*** SOURCE IDs DEFINING SOURCE GROUPS ***

GROUP ID

SOURCE IDs

BASE32 BASE32A , BASE32B , BASE32C ,

*** ISCST3 - VERSION 99155 *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
 *** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTS:

CONC RURAL FLAT DEFAULT

*** DIRECTION SPECIFIC BUILDING DIMENSIONS ***

SOURCE ID: BASE32A

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	0.0,	0.0,	0	2	0.0,	0.0,	0	3	0.0,	0.0,	0	4	0.0,	0.0,	0	5	0.0,	0.0,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	0.0,	0.0,	0	17	0.0,	0.0,	0	
19	0.0,	0.0,	0	20	0.0,	0.0,	0	21	0.0,	0.0,	0	22	0.0,	0.0,	0	23	0.0,	0.0,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	17.2,	0	32	12.2,	17.2,	0	33	12.2,	16.6,	0	34	0.0,	0.0,	0	35	0.0,	0.0,	0	

SOURCE ID: BASE32B

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	8.5,	14.4,	0	4	12.2,	17.2,	0	5	12.2,	17.2,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	19.1,	0	14	12.2,	19.5,	0	15	12.2,	19.3,	0	16	8.5,	12.0,	0	17	8.5,	18.2,	0	
19	8.5,	27.4,	0	20	8.5,	12.0,	0	21	8.5,	22.3,	0	22	12.2,	17.2,	0	23	12.2,	17.2,	0	
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0	
31	12.2,	19.1,	0	32	12.2,	19.5,	0	33	12.2,	19.3,	0	34	8.5,	12.0,	0	35	8.5,	9.2,	0	

SOURCE ID: BASE32C

IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	IFV	BH	BW	WAK	I
1	8.5,	9.2,	0	2	8.5,	12.0,	0	3	12.2,	19.3,	0	4	12.2,	19.5,	0	5	12.2,	19.1,	0	
7	12.2,	15.6,	0	8	12.2,	14.1,	0	9	12.2,	12.2,	0	10	12.2,	14.1,	0	11	12.2,	15.6,	0	
13	12.2,	17.2,	0	14	12.2,	17.2,	0	15	12.2,	16.6,	0	16	8.5,	12.0,	0	17	0.0,	0.0,	0	

19	0.0,	0.0,	0	20	8.5,	12.0,	0	21	12.2,	19.3,	0	22	12.2,	19.5,	0	23	12.2,	19.1,	0
25	12.2,	15.6,	0	26	12.2,	14.1,	0	27	12.2,	12.2,	0	28	12.2,	14.1,	0	29	12.2,	15.6,	0
31	12.2,	17.2,	0	32	12.2,	17.2,	0	33	12.2,	16.6,	0	34	8.5,	12.0,	0	35	8.5,	9.2,	0

*** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
 *** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTs:
 CONC

RURAL FLAT DEFAULT

*** GRIDDED RECEPTOR NETWORK SUMMARY ***

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

*** ORIGIN FOR POLAR NETWORK ***
 X-ORIG = 0.00 ; Y-ORIG = 0.00 (METERS)

*** DISTANCE RANGES OF NETWORK ***
 (METERS)

200.0, 300.0, 400.0,

*** DIRECTION RADIALS OF NETWORK ***
 (DEGREES)

222.0, 224.0, 226.0, 228.0, 230.0, 232.0, 234.0, 236.0, 238.0,
 *** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
 *** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTs:
 CONC

RURAL FLAT DEFAULT

*** METEOROLOGICAL DAYS SELECTED FOR PROCESSING ***
 (1=YES; 0=NO)

1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

NOTE: METEOROLOGICAL DATA ACTUALLY PROCESSED WILL ALSO DEPEND ON WHAT IS INCLUDED IN THE DATA FI

*** UPPER BOUND OF FIRST THROUGH FIFTH WIND SPEED CATEGORIES ***
 (METERS/SEC)

1.54, 3.09, 5.14, 8.23, 10.80,

*** WIND PROFILE EXPONENTS ***

STABILITY CATEGORY	1	2	3	4	5	6
A	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01
B	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01	.70000E-01
C	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+00	.10000E+00
D	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+00	.15000E+00
E	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+00	.35000E+00
F	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+00	.55000E+00

*** VERTICAL POTENTIAL TEMPERATURE GRADIENTS ***
 (DEGREES KELVIN PER METER)

STABILITY CATEGORY	1	2	3	4	5	6
A	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
B	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
C	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
D	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00	.00000E+00
E	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01	.20000E-01
F	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01	.35000E-01

*** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS 9/9/99 ***
 *** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M ***

**MODELOPTs:

CONC RURAL FLAT DEFAULT

*** THE FIRST 24 HOURS OF METEOROLOGICAL DATA ***

FILE: D:\MET\ORL89D.MET

FORMAT: (4I2,2F9.4,F6.1,I2,2F7.1,f9.4,f10.1,f8.4,i4,f7.2)

SURFACE STATION NO.: 12815

UPPER AIR STATION NO.: 12842

NAME: ORLANDO

NAME: WPB

YEAR: 1989

YEAR: 1989

YR	MN	DY	HR	FLOW VECTOR	SPEED (M/S)	TEMP (K)	STAB CLASS	MIXING RURAL	HEIGHT URBAN (M)	USTAR (M/S)	M-O LENGTH (M)	Z-0 (M)	IPCODE	PRATE (mm/HR)
89	01	01	01	21.0	1.54	291.5	7	999.5	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	02	8.0	2.06	290.4	6	999.1	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	03	34.0	2.06	290.4	6	998.8	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	04	33.0	2.06	289.8	6	998.4	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	05	43.0	2.06	290.4	6	998.1	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	06	22.0	2.06	289.8	6	997.7	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	07	45.0	2.06	289.3	6	997.4	590.0	0.0000	0.0	0.0000	0	0.00
89	01	01	08	33.0	3.09	290.4	5	100.0	628.6	0.0000	0.0	0.0000	0	0.00
89	01	01	09	27.0	3.09	292.6	4	244.9	689.7	0.0000	0.0	0.0000	0	0.00
89	01	01	10	21.0	4.63	295.4	3	394.9	750.7	0.0000	0.0	0.0000	0	0.00
89	01	01	11	14.0	4.12	297.6	3	544.9	811.8	0.0000	0.0	0.0000	0	0.00
89	01	01	12	56.0	4.63	298.2	3	695.0	872.9	0.0000	0.0	0.0000	0	0.00
89	01	01	13	43.0	5.14	299.8	3	845.0	933.9	0.0000	0.0	0.0000	0	0.00
89	01	01	14	59.0	4.12	300.9	3	995.0	995.0	0.0000	0.0	0.0000	0	0.00
89	01	01	15	32.0	6.17	301.5	4	995.0	995.0	0.0000	0.0	0.0000	0	0.00
89	01	01	16	44.0	4.63	300.9	3	995.0	995.0	0.0000	0.0	0.0000	0	0.00
89	01	01	17	61.0	3.60	299.8	4	995.0	995.0	0.0000	0.0	0.0000	0	0.00
89	01	01	18	37.0	3.09	298.2	5	993.6	990.5	0.0000	0.0	0.0000	0	0.00
89	01	01	19	54.0	3.09	297.0	6	990.2	979.6	0.0000	0.0	0.0000	0	0.00
89	01	01	20	67.0	3.60	295.9	5	986.7	968.7	0.0000	0.0	0.0000	0	0.00
89	01	01	21	150.0	2.06	295.4	6	983.3	957.7	0.0000	0.0	0.0000	0	0.00
89	01	01	22	132.0	2.06	294.3	6	979.9	946.8	0.0000	0.0	0.0000	0	0.00
89	01	01	23	130.0	0.00	293.2	7	976.4	935.9	0.0000	0.0	0.0000	0	0.00
89	01	01	24	130.0	0.00	292.6	7	973.0	925.0	0.0000	0.0	0.0000	0	0.00

*** NOTES: STABILITY CLASS 1=A, 2=B, 3=C, 4=D, 5=E AND 6=F.

FLOW VECTOR IS DIRECTION TOWARD WHICH WIND IS BLOWING.

*** ISCST3 - VERSION 99155 ***

*** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS

9/9/99

*** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M

**MODELOPTs:

CONC

RURAL FLAT

DEFAULT

*** THE PERIOD (8760 HRS) AVERAGE CONCENTRATION VALUES FOR SOURCE GROUP: BASE32 INCLUDING SOURCE(S): BASE32A , BASE32B , BASE32C ,

*** NETWORK ID: POL ; NETWORK TYPE: GRIDPOLR ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

DIRECTION (DEGREES)	200.00	300.00	400.00
222.00	0.06115	0.05883	0.04659
224.00	0.06129	0.05940	0.04715
226.00	0.06143	0.05991	0.04771
228.00	0.06141	0.06035	0.04829
230.00	0.06136	0.06071	0.04886
232.00	0.06122	0.06097	0.04939
234.00	0.06098	0.06108	0.04985
236.00	0.06057	0.06107	0.05018
238.00	0.06010	0.06087	0.05035

*** ISCST3 - VERSION 99155 ***

*** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS

9/9/99

*** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M

**MODELOPTs:

CONC

RURAL FLAT

DEFAULT

*** THE SUMMARY OF MAXIMUM PERIOD (8760 HRS) RESULTS ***

** CONC OF GENERIC IN (MICROGRAMS/CUBIC-METER)

**

GROUP ID	AVERAGE CONC	RECEPTOR (XR, YR, ZELEV, ZFLAG)	OF TYPE	NETWORK GRID-ID
----------	--------------	---------------------------------	---------	-----------------

BASE32	1ST HIGHEST VALUE IS	0.06143 AT (-143.87,	-138.93,	0.00,	0.00)	GP	POL
	2ND HIGHEST VALUE IS	0.06141 AT (-148.63,	-133.83,	0.00,	0.00)	GP	POL
	3RD HIGHEST VALUE IS	0.06136 AT (-153.21,	-128.56,	0.00,	0.00)	GP	POL
	4TH HIGHEST VALUE IS	0.06129 AT (-138.93,	-143.87,	0.00,	0.00)	GP	POL
	5TH HIGHEST VALUE IS	0.06122 AT (-157.60,	-123.13,	0.00,	0.00)	GP	POL
	6TH HIGHEST VALUE IS	0.06115 AT (-133.83,	-148.63,	0.00,	0.00)	GP	POL
	7TH HIGHEST VALUE IS	0.06108 AT (-242.71,	-176.34,	0.00,	0.00)	GP	POL
	8TH HIGHEST VALUE IS	0.06107 AT (-248.71,	-167.76,	0.00,	0.00)	GP	POL
	9TH HIGHEST VALUE IS	0.06098 AT (-161.80,	-117.56,	0.00,	0.00)	GP	POL
	10TH HIGHEST VALUE IS	0.06097 AT (-236.40,	-184.70,	0.00,	0.00)	GP	POL

*** RECEPTOR TYPES: GC = GRIDCART
GP = GRIDPOLR
DC = DISCCART
DP = DISCPOLR
BD = BOUNDARY

*** ISCST3 - VERSION 99155 *** *** 1989 PALMETTO OSCEOLA CO- SIMPLE CYCLE CTS
*** NO2 SIG IMP- ANNUAL- BASE 32 F/ 230 DEG, 200 M

9/9/99 ***

**MODELOPTs:

CONC RURAL FLAT DFAULT

*** Message Summary : ISCST3 Model Execution ***

----- Summary of Total Messages -----

A Total of 0 Fatal Error Message(s)
A Total of 1 Warning Message(s)
A Total of 345 Informational Message(s)

A Total of 345 Calm Hours Identified

***** FATAL ERROR MESSAGES *****
*** NONE ***

***** WARNING MESSAGES *****
SO W320 14 PPARM :Input Parameter May Be Out-of-Range for Parameter QS

*** ISCST3 Finishes Successfully ***
