


JEFF



May 19, 2003

RECEIVED

MAY 23 2003

BUREAU OF AIR REGULATION

Department of Environmental Protection
Bureau of Air Regulation
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, FL 32399-2400

Re: Permit No. 990019-003-AV, Appendix SO-1. (Permit PSD-FL-197G,
Specific Condition 17(f) of Section III.)

Gentlemen:

The referenced Permit and Specific Condition requires sampling and analyzing the fuel oil stored for use by the sugar mill boilers and report the sulfur content to the Bureau of Air Regulation and Compliance Authorities.

The sulfur content is 0.983% by weight. A copy of the fuel analysis is attached.

Sincerely,

OSCEOLA FARMS CO.

Carlos S. Rionda
Vice President and
General Manager

cc: FDEP South District
Ajaya Satyal - PBCPHU

CSR/gr
Attachment

CUSTOMER: I2J Environmental Services
540 N. E. 3rd St.
Belle Glade, Fl. 33430



PANAIR LABORATORY, INC
4301 N.W. 72 AVE. MIAMI, FL 33166 (305) 594-9055 FAX (305) 477-9137

ATTENTION: Irhahim Alava

DATE: 4/22/03

REFERENCE: Sample received 4/15/03 and repeat of sample received 3/12/03.

Lab No.	Source	Sulfur (D4294), % mass	
41148T-S	Osceola Farms 4/15/03	0.983	
40988T-S	Osceola Farms 3/12/03 re-check	0.983	

Comments:


Carl E. Johnson, President