



Permit Application

APPLICATION FOR TITLE V AIR OPERATION PERMIT REVISION

Florida Power & Light Company
Riviera Beach Energy Center

Prepared For: Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408

Submitted By: Golder Associates Inc.
6026 NW 1st Place
Gainesville, FL 32607 USA

Distribution: 4 copies – FDEP
2 copies – FPL
1 copy – Golder Associates Inc.

June 2014

14-02852

**A world of
capabilities
delivered locally**



APPLICATION FOR AIR PERMIT

LONG FORM



Department of Environmental Protection

Division of Air Resource Management

APPLICATION FOR AIR PERMIT - LONG FORM

I. APPLICATION INFORMATION

Air Construction Permit – Use this form to apply for an air construction permit:

- For any required purpose at a facility operating under a federally enforceable state air operation permit (FESOP) or Title V air operation permit;
- For a proposed project subject to prevention of significant deterioration (PSD) review, nonattainment new source review, or maximum achievable control technology (MACT);
- To assume a restriction on the potential emissions of one or more pollutants to escape a requirement such as PSD review, nonattainment new source review, MACT, or Title V; or
- To establish, revise, or renew a plantwide applicability limit (PAL).

Air Operation Permit – Use this form to apply for:

- An initial federally enforceable state air operation permit (FESOP); or
- An initial, revised, or renewal Title V air operation permit.

To ensure accuracy, please see form instructions.

Identification of Facility

1. Facility Owner/Company Name: Florida Power & Light Company (FPL)	
2. Site Name: Riviera Beach Energy Center (RBEC)	
3. Facility Identification Number: 0990042	
4. Facility Location... Street Address or Other Locator: 200-300 Broadway City: Riviera Beach County: Palm Beach Zip Code: 33404	
5. Relocatable Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6. Existing Title V Permitted Facility? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Application Contact

1. Application Contact Name: Mary J. Archer, QEP, Project Manager	
2. Application Contact Mailing Address... Organization/Firm: Florida Power & Light Company Street Address: 700 Universe Blvd. City: Juno Beach State: FL Zip Code: 33408	
3. Application Contact Telephone Numbers... Telephone: (561) 691-7057 ext. Fax: (561) 758-3760	
4. Application Contact E-mail Address: Mary.Archer@fpl.com	

Application Processing Information (DEP Use)

1. Date of Receipt of Application:	3. PSD Number (if applicable):
2. Project Number(s):	4. Siting Number (if applicable):

APPLICATION INFORMATION

Purpose of Application

This application for air permit is being submitted to obtain: (Check one)

Air Construction Permit

- Air construction permit.
- Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL).
- Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL), and separate air construction permit to authorize construction or modification of one or more emissions units covered by the PAL.

Air Operation Permit

- Initial Title V air operation permit.
- Title V air operation permit revision.
- Title V air operation permit renewal.
- Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is required.
- Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is not required.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit (Concurrent Processing)

- Air construction permit and Title V permit revision, incorporating the proposed project.
- Air construction permit and Title V permit renewal, incorporating the proposed project.

Note: By checking one of the above two boxes, you, the applicant, are requesting concurrent processing pursuant to Rule 62-213.405, F.A.C. In such case, you must also check the following box:

- I hereby request that the department waive the processing time requirements of the air construction permit to accommodate the processing time frames of the Title V air operation permit.

Application Comment

Application is for the initial Title V air operating permit for the Riviera Beach Energy Center incorporating Air Construction (AC) Permit Nos. 0990042-006-AC and 0990042-007-AC.

AC Permit 0990042-006-AC authorized construction of 1,250-MW Combined Cycle (CC) Unit 5 comprising three nominal 265 MW combustion turbine-electrical generators (EU IDs 007, 008, 009) with natural gas-fired duct burners located in HRSGs and other ancillary equipment.

The auxiliary boiler (010), gas-fired process heaters (011), natural gas compressors (012) and temporary natural gas-fired boiler (015) authorized in AC Permit No. 0990042-006-AC were not installed. Therefore, they are not included in this air operation permit.

AC Permit 0990042-007-AC revised excess emissions provisions for CC Unit 5 and authorized excess emissions of NO_x and CO resulting from startup, shutdown, or malfunction to be excluded from the CEMS data in any 24-hour period. This permit also reduced allowable hours of operation for the emergency generators.

A compliance plan is attached for the two diesel-fired emergency generators (EU013).

APPLICATION INFORMATION


Owner/Authorized Representative Statement

Complete if applying for an air construction permit or an initial FESOP.

1. Owner/Authorized Representative Name :
2. Owner/Authorized Representative Mailing Address... Organization/Firm: Street Address: City: State: Zip Code:
3. Owner/Authorized Representative Telephone Numbers... Telephone: () ext. Fax: ()
4. Owner/Authorized Representative E-mail Address:
5. Owner/Authorized Representative Statement: <i>I, the undersigned, am the owner or authorized representative of the corporation, partnership, or other legal entity submitting this air permit application. To the best of my knowledge, the statements made in this application are true, accurate and complete, and any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department.</i> _____ Signature Date



Application Responsible Official Certification

Complete if applying for an initial, revised, or renewal Title V air operation permit or concurrent processing of an air construction permit and revised or renewal Title V air operation permit. If there are multiple responsible officials, the “application responsible official” need not be the “primary responsible official.”

1. Application Responsible Official Name: Timothy Bryant
2. Application Responsible Official Qualification (Check one or more of the following options, as applicable): <input checked="" type="checkbox"/> For a corporation, the president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit under Chapter 62-213, F.A.C. <input type="checkbox"/> For a partnership or sole proprietorship, a general partner or the proprietor, respectively. <input type="checkbox"/> For a municipality, county, state, federal, or other public agency, either a principal executive officer or ranking elected official. <input type="checkbox"/> The designated representative at an Acid Rain source or CAIR source.
3. Application Responsible Official Mailing Address... Organization/Firm: Florida Power & Light Company Street Address: 200-300 Broadway City: Riviera Beach State: FL Zip Code: 33404
4. Application Responsible Official Telephone Numbers... Telephone: (561) 863 - 1801 ext. Fax: () -
5. Application Responsible Official E-mail Address: Timothy.Bryant@fpl.com
6. Application Responsible Official Certification: I, the undersigned, am a responsible official of the Title V source addressed in this air permit application. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof and all other applicable requirements identified in this application to which the Title V source is subject. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department, and I will promptly notify the department upon sale or legal transfer of the facility or any permitted emissions unit. Finally, I certify that the facility and each emissions unit are in compliance with all applicable requirements to which they are subject, except as identified in compliance plan(s) submitted with this application. Signature  Date 6/25/14

APPLICATION INFORMATION

Professional Engineer Certification

1. Professional Engineer Name: Kennard F. Kosky Registration Number: 14996
2. Professional Engineer Mailing Address... Organization/Firm: Golder Associates Inc.** Street Address: 6026 NW 1st Place City: Gainesville State: FL Zip Code: 32607
3. Professional Engineer Telephone Numbers... Telephone: (352) 336-5600 ext. Fax: (352) 336-6603
4. Professional Engineer E-mail Address: kkosky@golder.com
5. Professional Engineer Statement: <i>I, the undersigned, hereby certify, except as particularly noted herein*, that:</i> <i>(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this application for air permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and</i> <i>(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.</i> <i>(3) If the purpose of this application is to obtain a Title V air operation permit (check here <input checked="" type="checkbox"/> , if so), I further certify that each emissions unit described in this application for air permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance plan and schedule is submitted with this application.</i> <i>(4) If the purpose of this application is to obtain an air construction permit (check here <input type="checkbox"/> , if so) or concurrently process and obtain an air construction permit and a Title V air operation permit revision or renewal for one or more proposed new or modified emissions units (check here <input type="checkbox"/> , if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.</i> <i>(5) If the purpose of this application is to obtain an initial air operation permit or operation permit revision or renewal for one or more newly constructed or modified emissions units (check here <input type="checkbox"/> , if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.</i>  _____ Signature (seal)   _____ Date

* Attach any exception to certification statement.

**Board of Professional Engineers Certificate of Authorization #00001670.

II. FACILITY INFORMATION

A. GENERAL FACILITY INFORMATION

Facility Location and Type

1. Facility UTM Coordinates... Zone 17 East (km) 523.1 North (km) 3149		2. Facility Latitude/Longitude... Latitude (DD/MM/SS) 28/28/10 Longitude (DD/MM/SS) 80/45/51	
3. Governmental Facility Code: 0	4. Facility Status Code: A	5. Facility Major Group SIC Code: 49	6. Facility SIC(s): 4911
7. Facility Comment :			

Facility Contact

1. Facility Contact Name: Wilfredo Rosario
2. Facility Contact Mailing Address... Organization/Firm: Florida Power & Light Company Street Address: 200 Broadway City: Riviera Beach State: FL Zip Code: 33404
3. Facility Contact Telephone Numbers: Telephone: (561) 863-1808 ext. Fax: (561) 863-1840
4. Facility Contact E-mail Address: wilfredo.rosario@fpl.com

Facility Primary Responsible Official

Complete if an “application responsible official” is identified in Section I that is not the facility “primary responsible official.”

1. Facility Primary Responsible Official Name:
2. Facility Primary Responsible Official Mailing Address... Organization/Firm: Street Address: City: State: Zip Code:
3. Facility Primary Responsible Official Telephone Numbers... Telephone: () ext. Fax: ()
4. Facility Primary Responsible Official E-mail Address:

Facility Regulatory Classifications

Check all that would apply *following* completion of all projects and implementation of all other changes proposed in this application for air permit. Refer to instructions to distinguish between a “major source” and a “synthetic minor source.”

1. <input type="checkbox"/> Small Business Stationary Source	<input type="checkbox"/> Unknown
2. <input type="checkbox"/> Synthetic Non-Title V Source	
3. <input checked="" type="checkbox"/> Title V Source	
4. <input checked="" type="checkbox"/> Major Source of Air Pollutants, Other than Hazardous Air Pollutants (HAPs)	
5. <input type="checkbox"/> Synthetic Minor Source of Air Pollutants, Other than HAPs	
6. <input type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)	
7. <input type="checkbox"/> Synthetic Minor Source of HAPs	
8. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS (40 CFR Part 60)	
9. <input type="checkbox"/> One or More Emissions Units Subject to Emission Guidelines (40 CFR Part 60)	
10. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NESHAP (40 CFR Part 61 or Part 63)	
11. <input type="checkbox"/> Title V Source Solely by EPA Designation (40 CFR 70.3(a)(5))	
12. Facility Regulatory Classifications Comment: Gas Turbines and Duct Burners are subject to NSPS 40 CFR 60 Subpart KKKK. Emergency fire pump engine are subjected to NSPS 40 CFR 60 Subpart IIII. Two nominal 2,250 kW emergency generators are subjected to NESHAP 40 CFR 63 Subpart ZZZZ and NSPS 40 CFR 60 Subpart IIII.	

List of Pollutants Emitted by Facility

1. Pollutant Emitted	2. Pollutant Classification	3. Emissions Cap [Y or N]?
PM	A	N
PM10	A	N
VOC	A	N
SO2	A	N
NOx	A	N
CO	A	N

C. FACILITY ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

1. Facility Plot Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: RBEC-FI-C1 <input type="checkbox"/> Previously Submitted, Date: _____
2. Process Flow Diagram(s): (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: See EU sections <input type="checkbox"/> Previously Submitted, Date: _____
3. Precautions to Prevent Emissions of Unconfined Particulate Matter: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: RBEC-FI-C3 <input type="checkbox"/> Previously Submitted, Date: _____

Additional Requirements for Air Construction Permit Applications

1. Area Map Showing Facility Location: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable (existing permitted facility)
2. Description of Proposed Construction, Modification, or Plantwide Applicability Limit (PAL): <input type="checkbox"/> Attached, Document ID: _____
3. Rule Applicability Analysis: <input type="checkbox"/> Attached, Document ID: _____
4. List of Exempt Emissions Units: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable (no exempt units at facility)
5. Fugitive Emissions Identification: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
6. Air Quality Analysis (Rule 62-212.400(7), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
7. Source Impact Analysis (Rule 62-212.400(5), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
8. Air Quality Impact since 1977 (Rule 62-212.400(4)(e), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
9. Additional Impact Analyses (Rules 62-212.400(8) and 62-212.500(4)(e), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
10. Alternative Analysis Requirement (Rule 62-212.500(4)(g), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable

C. FACILITY ADDITIONAL INFORMATION (CONTINUED)

Additional Requirements for FESOP Applications

- | |
|---|
| 1. List of Exempt Emissions Units:
<input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable (no exempt units at facility) |
|---|

Additional Requirements for Title V Air Operation Permit Applications

- | |
|---|
| 1. List of Insignificant Activities: (Required for initial/renewal applications only)
<input checked="" type="checkbox"/> Attached, Document ID: <u>RBEC-FI-CV1</u> <input type="checkbox"/> Not Applicable (revision application) |
| 2. Identification of Applicable Requirements: (Required for initial/renewal applications, and for revision applications if this information would be changed as a result of the revision being sought)
<input checked="" type="checkbox"/> Attached, Document ID: <u>RBEC-FI-CV2</u>
<input type="checkbox"/> Not Applicable (revision application with no change in applicable requirements) |
| 3. Compliance Report and Plan: (Required for all initial/revision/renewal applications)
<input checked="" type="checkbox"/> Attached, Document ID: <u>RBEC-FI-CV3</u>
Note: A compliance plan must be submitted for each emissions unit that is not in compliance with all applicable requirements at the time of application and/or at any time during application processing. The department must be notified of any changes in compliance status during application processing. |
| 4. List of Equipment/Activities Regulated under Title VI: (If applicable, required for initial/renewal applications only)
<input checked="" type="checkbox"/> Attached, Document ID: <u>RBEC-FI-CV4</u>
<input type="checkbox"/> Equipment/Activities Onsite but Not Required to be Individually Listed
<input type="checkbox"/> Not Applicable |
| 5. Verification of Risk Management Plan Submission to EPA: (If applicable, required for initial/renewal applications only)
<input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable |
| 6. Requested Changes to Current Title V Air Operation Permit:
<input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable |

C. FACILITY ADDITIONAL INFORMATION (CONTINUED)

Additional Requirements for Facilities Subject to Acid Rain, CAIR, or Hg Budget Program

1. Acid Rain Program Forms:

Acid Rain Part Application (DEP Form No. 62-210.900(1)(a)):

Attached, Document ID: **RBEC-FI-CA1** Previously Submitted, Date: _____

Not Applicable (not an Acid Rain source)

Phase II NO_x Averaging Plan (DEP Form No. 62-210.900(1)(a)1.):

Attached, Document ID: _____ Previously Submitted, Date: _____

Not Applicable

New Unit Exemption (DEP Form No. 62-210.900(1)(a)2.):

Attached, Document ID: _____ Previously Submitted, Date: _____

Not Applicable

2. CAIR Part (DEP Form No. 62-210.900(1)(b)):



Attached, Document ID: **RBEC-FI-CA2** Previously Submitted, Date:-- _____

Not Applicable (not a CAIR source)

Additional Requirements Comment

ATTACHMENT RBEC-FI-C1

FACILITY PLOT PLAN



- LEGEND**
- HEAT RECOVERY STEAM GENERATOR (HRSG)
 - HRSG ELECTRICAL EQUIPMENT ENCLOSURE (PDC)
 - SAMPLE PANEL
 - SECONDARY COOLING CHILLER FOR SAMPLE PANEL
 - CEMS ENCLOSURE
 - HRSG DUCT BURNER BLOWER SKID
 - HRSG DUCT BURNER GAS SKID
 - HRSG DCS EQUIPMENT
 - HRSG BLOWDOWN TANK
 - BOILER FEED PUMP LUBE OIL SKID
 - BOILER FEED PUMP
 - AMMONIA FLOW CONTROL UNIT
 - 15% AQUEOUS AMMONIA STORAGE TANKS
 - AMMONIA FORWARDING PUMPS
 - CO2 STORAGE
 - HYDROGEN STORAGE TRAILER
 - AMMONIA UNLOADING SKID
 - CT MAIN FUEL OIL PUMP STRAINER
 - CT MAIN FUEL OIL PUMP
 - CT WATER INJECTION PUMP
 - FUEL OIL INLET FILTER
 - NON-HAZARDOUS MATERIAL TRASH ROLL OFF AREA
 - COMBUSTION TURBINE
 - CT POWER CONTROL CENTERS
 - CT EXHAUST DIFFUSER
 - VT AND SURGE CUBICLE
 - CT NEUTRAL GROUNDING CUBICLE
 - CT ISO PHASE BUS DUCT
 - STATIC EXCITATION EQUIPMENT (SEE) TRANSFORMER
 - AIR COMPRESSORS
 - MISCELLANEOUS SERVICE BUILDING
 - UNIT AUXILIARY TRANSFORMER
 - CT GENERATOR STEP-UP TRANSFORMER
 - CT CO2 FIRE PROTECTION
 - SEE / SFC PACKAGE
 - CT CONTROL OIL SKID
 - CT LUBE OIL MODULE
 - CT INSTRUMENT AIR COMPRESSOR
 - LP ECONOMIZER HEAT EXCHANGER
 - CT WASH WATER DRAINS TANK
 - CT GENERATOR NEUTRAL CUBICLE
 - CT GENERATOR SEAL OIL EQUIPMENT
 - CT GENERATOR GAS SYSTEM EQUIPMENT
 - CT GENERATOR
 - CT PURGE AIR COMPRESSORS
 - CT GENERATOR BREAKER
 - STATIC FREQUENCY CONVERTER (SFC) TRANSFORMER
 - CT PURGE AIR RECEIVER
 - AIR INTAKE
 - CYCLE CHEMICAL FEED EQUIPMENT
 - CONTROL AIR RECEIVER TANK
 - STATION AIR RECEIVER TANK
 - DESICCANT AIR DRYERS
 - AIR RECEIVER TANKS
 - AIR COMPRESSORS
 - MISCELLANEOUS SERVICE BUILDING
 - SEWAGE LIFT STATION
 - HVAC EQUIPMENT ROOM
 - ELECTRIC EQUIPMENT ROOM
 - ADMINISTRATION OFFICES
 - WAREHOUSE
 - CONTROL / PROGRAMMING ROOM
 - MAINTENANCE / MACHINE SHOP
 - BUILDING CONDENSING UNITS
 - RETENTION POND
 - PIPE RACK
 - DRAINAGE TRENCH OR DRAINAGE PIPE
 - SERVICE WATER / FIRE WATER STORAGE TANK
 - SERVICE WATER PUMPS
 - FIRE PUMPS
 - DEMINERALIZED WATER STORAGE TANK
 - DEMINEALIZED WATER PUMPS
 - DEMINEALIZED WATER TRAILER AREA
 - VACUUM PUMPING PUMPS
 - STEAM JET AIR EJECTOR SKIDS
 - STEAM TURBINE
 - STEAM TURBINE CONDENSER
 - STEAM TURBINE GENERATOR
 - ST GENERATOR ELECTRICAL EQUIPMENT ENCLOSURE
 - ST ISO PHASE BUS DUCT
 - STEAM TURBINE BLOWDOWN TANK
 - ST EXCITATION COMPARTMENT (THY & FCB CUBICLES)
 - ST GENERATOR EXCITATION TRANSFORMER
 - ST GENERATOR STEP-UP TRANSFORMER
 - CONDENSATE PUMPS
 - GENERATOR VT AND SURGE COMPARTMENT
 - ST STATOR COOLING UNIT
 - ST EMERGENCY SEAL OIL PUMP
 - ST MAIN SEAL OIL PUMP
 - ST GENERATOR NEUTRAL GROUNDING CUBICLE XFMR
 - H2 GAS DRYER
 - ST LUBE OIL CONDITIONER
 - ST LUBE OIL RESERVOIR
 - ST LUBE OIL COOLER
 - FIRE PROTECTION STEAM TURBINE VALVE HOUSE
 - ST EHC OIL UNIT
 - WATER TRTMT PROCESS DRAINS TRANSFER SUMP
 - FUEL OIL TRANSFER PUMPS
 - FUEL OIL TANK UNLOADING PUMPS
 - DIESEL GENERATOR
 - FUEL OIL STORAGE AREA
 - FUEL OIL TRUCK UNLOADING STATION
 - PARKING AREA
 - FUEL OIL TANK FIRE SUPPRESSION EQUIPMENT
 - FUEL OIL STORAGE TANK
 - FUEL GAS DEWPOINT / STARTUP ELECTRIC HEATER
 - FUEL GAS PERFORMANCE HEATER
 - FUEL GAS REGULATION
 - DIESEL GENERATOR PDC
 - FUEL GAS YARD
 - EXISTING FUEL GAS YARD
 - EXISTING MANATEE WARM WATER AG PIPING
 - FUEL GAS PILOT FILTER/SEPARATOR
 - FUEL GAS MAIN FILTER/SEPARATOR
 - FUEL GAS LEAK DETECTION SEPARATOR
 - FUEL GAS SEPARATOR / FLASH DRAINS TANK
 - FUEL TRANSFORMER
 - COLLECTOR YARD
 - ELECTRICAL PULLBOX
 - ELECTRICAL MANHOLE
 - MV SWITCHGEAR ELECTRICAL EQUIPMENT ENCLOSURE
 - EXISTING FUEL OIL EQUIPMENT
 - COMMON AREA 480V SUS TRANSFORMER
 - COMMON AREA SUS MCC ENCLOSURE
 - OIL/WATER SEPARATOR
 - BLOWDOWN SUMP AND PUMPS
 - WASTEWATER TRANSFER SUMPS
 - AUXILIARY COOLING WATER PRIMING PUMP
 - WATER TREATMENT AREA
 - CIRCULATING WATER CHEMICAL FEED
 - CLOSED CYCLE COOLING WATER PUMPS AND EXCHANGERS
 - CLOSED CYCLE COOLING WATER EXPANSION AND HEAD TANK
 - CIRCULATING WATER PUMPS
 - CIRCULATING WATER LINES
 - AUXILIARY COOLING WATER PUMPS
 - HURRICANE SHELTER W/PG TANKS AND GENERATORS
 - EXISTING MANATEE WARM WATER DISCHARGE STRUCTURE
 - EXISTING MANATEE WARM WATER INTAKE STRUCTURE
 - EXISTING MANATEE WARM WATER PUMPS
 - EXISTING MANATEE WARM WATER HEAT EXCHANGER
 - EXISTING MANATEE WARM WATER TRV / SWITCHGEAR
 - EXISTING MANATEE WARM WATER CIRC. WATER HEATERS
 - EXISTING MANATEE WARM WATER UNDERGROUND PIPE
 - SOLAR PANEL ELECTRICAL EQUIPMENT
 - WATER PUMP AREA DRAINS SUMP
 - COMBINED WATER WASH SKID
 - EXISTING FUEL OIL LINE
 - EVAPORATIVE COOLER PROCESS DRAINS TANK AND PUMPS
 - MISC. SERVICES BUILDING AREA PROCESS DRAINS SUMP
 - CT FIRE WATER DELUGE HOUSE
 - CT MAINTENANCE CRANE APRONS
 - ST MAINTENANCE APRON
 - AUXILIARY COOLING WATER SWITCH (BAB40)
 - HYDROGEN BULK STORAGE
 - COMMON BLOWDOWN TANK
 - WAREHOUSE DRAINS SUMP
 - POTABLE WATER PUMPS AND TANK
 - EXISTING WATER WELLS
 - FPL TRANSMISSION POLE
 - INTAKE TRASH ROLL-OFF AREA
 - INTAKE SCREEN SPRAY WATER EQUIPMENT
 - AMMONIA UNLOADING SUMPS
 - EXIST UNDERGROUND DISTRIBUTION LINES
 - EXISTING SEWAGE LIFT STATION
 - FPL 138KV DUCTBANK
 - PLANT FUEL GAS SUPPLY LINE
 - PLANT WATER METER AND BACKFLOW PREVENTER
 - FUEL GAS RELIEF SILENCERS
 - INTAKE CATHODIC PROTECTION RECTIFIER
 - ACUMULATORS
 - FUEL OIL BLADDER TANK
 - AQUATIC ORGANISM RETURN PIPING
 - BAR SCREEN
 - VERTICAL TRAVELING WATER SCREEN

NO.	REVISION	DATE	DRWN	DSND	CHKD	CHKD
6	ADDED ITEMS 23, 100, 108 & NORTHEAST PARKING	07/10/13	TK	RY	RET	BES
5	ADDED FENCE FOR PDC RECEIVING AREA REARRANGED FUEL GAS YARD. ADDED ITEMS 166, 167, 168 & 169.	01/08/13	CLJ	JB	MHS	DD
4	ADDED FENCE FOR PDC RECEIVING AREA REARRANGED FUEL GAS YARD. ADDED ITEMS 166, 167, 168 & 169.	06/03/12	JAB	JB	AG	DD
3	MOVED HYDROGEN STORAGE TRAILER ITEM 17. MOVED WAREHOUSE BUILDING DRAINS SUMP ITEM 156 TO THE SOUTH REARRANGED BUILDING CONDENSING UNITS, HURRICANE SHELTER WITH LPG TANKS & GENERATORS, REARRANGED AIR COMPRESSOR ITEMS 38 & 45. RENAMED ITEM 108. ADDED ITEM 165. FPL 138KV DUCTBANK.	03/02/12	BC	JB	RSS	DD
2	MOVED SERVICE WATER / FIRE WATER TANK AND PUMPS EAST. ADDED ITEMS 161, 162, 163 AND 164. STAGE TRAVELER OFF AREA AND AMMONIA UNLOADING SUMPS. RESIZED POND AT E1. MOVED CIRCULATING WATER CHEMICAL FEED.	11/16/11	RET	JB	MHS	DD
1	ADDED PLANT EL & NAVD 88. ITEM 120. MOVED TAGS FOR 100, 109, 110, 111, 147, 154, 156. MOVED LEGEND TO BOTTOM. ADDED ITEMS 97, 98, 99, 97, 112, 119, 147, 153, 154, 155. ADDED ITEM 158. ROTATED CIRC CHEM FEED. ADJUSTED ITEMS 51 & 52. REARRANGED PUMPS & AROUND COLLECTOR YARD. REVISED NORTH ARROW.	08/23/11	RET	JB	MHS	DD
0	ISSUED FOR CONSTRUCTION					

NO.	REVISION	DATE	DRWN	DSND	CHKD	CHKD
6	ADDED ITEMS 23, 100, 108 & NORTHEAST PARKING	07/10/13	TK	RY	RET	BES
5	ADDED FENCE FOR PDC RECEIVING AREA REARRANGED FUEL GAS YARD. ADDED ITEMS 166, 167, 168 & 169.	01/08/13	CLJ	JB	MHS	DD
4	ADDED FENCE FOR PDC RECEIVING AREA REARRANGED FUEL GAS YARD. ADDED ITEMS 166, 167, 168 & 169.	06/03/12	JAB	JB	AG	DD
3	MOVED HYDROGEN STORAGE TRAILER ITEM 17. MOVED WAREHOUSE BUILDING DRAINS SUMP ITEM 156 TO THE SOUTH REARRANGED BUILDING CONDENSING UNITS, HURRICANE SHELTER WITH LPG TANKS & GENERATORS, REARRANGED AIR COMPRESSOR ITEMS 38 & 45. RENAMED ITEM 108. ADDED ITEM 165. FPL 138KV DUCTBANK.	03/02/12	BC	JB	RSS	DD
2	MOVED SERVICE WATER / FIRE WATER TANK AND PUMPS EAST. ADDED ITEMS 161, 162, 163 AND 164. STAGE TRAVELER OFF AREA AND AMMONIA UNLOADING SUMPS. RESIZED POND AT E1. MOVED CIRCULATING WATER CHEMICAL FEED.	11/16/11	RET	JB	MHS	DD
1	ADDED PLANT EL & NAVD 88. ITEM 120. MOVED TAGS FOR 100, 109, 110, 111, 147, 154, 156. MOVED LEGEND TO BOTTOM. ADDED ITEMS 97, 98, 99, 97, 112, 119, 147, 153, 154, 155. ADDED ITEM 158. ROTATED CIRC CHEM FEED. ADJUSTED ITEMS 51 & 52. REARRANGED PUMPS & AROUND COLLECTOR YARD. REVISED NORTH ARROW.	08/23/11	RET	JB	MHS	DD
0	ISSUED FOR CONSTRUCTION					

FPL

ZACHRY

ZACHRY ENGINEERING CORPORATION - 101 WEST COLFAX AVENUE, SUITE 500, DENVER, CO, 80202-3315
 FLORIDA BOARD OF PROFESSIONAL ENGINEERS CERTIFICATE OF AUTHORIZATION NUMBER: AMARILLO, TX CHARLOTTE, NC HOUSTON, TX MINNEAPOLIS, MN OMAHA, NE SAN ANTONIO, TX TYLER, TX

RIVIERA BEACH ENERGY CENTER UNIT 5
SITE RELATED WORK
3x1 COMBINED CYCLE - STGG-800H
GENERAL ARRANGEMENT - PLAN

DRWN: R. THOMPSON (DESIGN) B. JOHNSON (CHECKED) N. NGUYEN (REV)
 APPRVD: [Signature] (SEAL) [Signature] (SEAL)
 DATE: 7/1/13

D008720-STWL0001 01 6

11-12-48 AM 7/1/2013
 P:\PPL\008720\echer\vdg\Layout\Chp01STWL0001.dwg

ATTACHMENT RBEC-FI-C3

**PRECAUTIONS TO PREVENT EMISSIONS OF
UNCONFINED PARTICULATE MATTER**

ATTACHMENT RBEC-FI-C3

PRECAUTIONS TO PREVENT EMISSIONS OF UNCONFINED PARTICULATE MATTER

Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include:

- Paving of roads, parking areas, and equipment yards
- Landscaping and planting vegetation
- Use of thick poly flaps over the doorways to prevent any sandblasting material from leaving the sandblast facility. Temporary sandblasting enclosures are constructed and operated when necessary, in order to perform sandblasting on fixed plant equipment
- Maintenance of paved roads as needed
- Regular mowing of grass and care of vegetation
- Limiting access to plant property by unnecessary vehicles
- Bagged chemical products are stored in weather tight buildings until they are used. Spills of any powdered chemical products are cleaned up as soon as practicable
- Vehicles are restricted to slow speeds on the plant site.

ATTACHMENT RBEC-FI-CV1A
LIST OF INSIGNIFICANT ACTIVITIES

ATTACHMENT RBEC-FI-CV1A LIST OF INSIGNIFICANT ACTIVITIES

A list of existing units and/or activities that are considered to be insignificant and are exempted from Title V permitting under Rule 62-213.430(6) is presented below. The exempt activities listed are also those activities that are included in Rule 62-210.300(3)(a) that would not exceed the thresholds in Rule 62-213.430(6)(b)3.

Brief Description of Emissions Units and/or Activities:

- 6,278,925-gallon No. 2 fuel oil storage tank
- 500-gallon No. 2 diesel storage tank for fire pump
- Miscellaneous new and used oil drums in storage building
- Portable diesel generators (wheel mounted)
- Equipment used for steam cleaning
- Belt or drum sanders having a total sanding surface of 5 square feet or less
- Brazing, soldering, or welding equipment
- Fire and safety equipment
- Petroleum lubrication systems
- Degreasing units
- Non-halogenated solvent storage and cleaning operations
- Surface coating operations
- Combustion turbine lube oil vents
- Steam turbine lube oil vents
- Two 40,000-gallon aqueous ammonia (19-percent) storage tanks
- Natural gas metering station
- Storage & use of water treatment chemicals
- Parts washer (aliphatic hydrocarbon solvent)
- Miscellaneous painting activities
- Two 12,000-gallon each oil/water separators
- Water treatment sulfuric acid tank
- Water treatment sodium hydroxide tank
- Miscellaneous electrical equipment
- Miscellaneous enclosed oil filled equipment
- No. 2 fuel oil tank truck unloading area
- No. 2 fuel oil barge unloading area
- Lube oil storage area (55-gallon lube oil drums)
- Lube oil storage tanks:
 - 9,247-gallon steam turbine lube oil storage tank
 - Three 6,200-gallon each lube oil storage tanks for the CTs
 - Three 93-gallon each boiler feed pump lube oil storage tanks
- Three 2,693-gallon each No. 2 fuel oil and fuel gas hydrocarbon condensate tanks

- 264-gallon hydraulic oil tank for steam turbine electro-hydraulic control unit skid
- Condensate storage tanks:
 - 150-gallon gas inlet metering station pipeline scrubber tank
 - 250-gallon gas outlet metering station pipeline scrubber tank
- Various oily wastewater tanks
- Two propane-fired Generac Model 0047253 hurricane emergency generators (Generator A and Generator B)

* Please see tanks 4.0.9d emissions calculation report in attachment RBEC-FI-CV1B.

ATTACHMENT RBEC-FI-CV1B

**TANKS 4.0.9d
EMISSIONS REPORT**

TANKS 4.0.9d
Emissions Report - Summary Format
Tank Identification and Physical Characteristics

Identification

User Identification: FOA-TK-0004
City: Miami
State: Florida
Company: FPL
Type of Tank: Vertical Fixed Roof Tank
Description: No.2 fuel oil storage tank

Tank Dimensions

Shell Height (ft): 44.00
Diameter (ft): 155.80
Liquid Height (ft) : 44.00
Avg. Liquid Height (ft): 44.00
Volume (gallons): 6,274,955.65
Turnovers: 27.00
Net Throughput(gal/yr): 169,423,802.60
Is Tank Heated (y/n): N

Paint Characteristics

Shell Color/Shade: Gray/Medium
Shell Condition: Good
Roof Color/Shade: Gray/Medium
Roof Condition: Good

Roof Characteristics

Type: Dome
Height (ft) 0.00
Radius (ft) (Dome Roof) 0.00

Breather Vent Settings

Vacuum Settings (psig): -0.03
Pressure Settings (psig) 0.03

Meteorological Data used in Emissions Calculations: Miami, Florida (Avg Atmospheric Pressure = 14.75 psia)

TANKS 4.0.9d
Emissions Report - Summary Format
Liquid Contents of Storage Tank

FOA-TK-0004 - Vertical Fixed Roof Tank
Miami, Florida

Mixture/Component	Month	Daily Liquid Surf. Temperature (deg F)			Liquid Bulk Temp (deg F)	Vapor Pressure (psia)			Vapor Mol. Weight.	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Distillate fuel oil no. 2	All	85.88	76.07	95.68	78.97	0.0144	0.0108	0.0194	130.0000			188.00	Option 1: VP70 = .009 VP80 = .012

TANKS 4.0.9d
Emissions Report - Summary Format
Individual Tank Emission Totals

Emissions Report for: Annual

FOA-TK-0004 - Vertical Fixed Roof Tank
Miami, Florida

Components	Losses(lbs)		
	Working Loss	Breathing Loss	Total Emissions
Distillate fuel oil no. 2	7,525.24	1,607.20	9,132.44

ATTACHMENT RBEC-FI-CV2
IDENTIFICATION OF APPLICABLE REQUIREMENTS

ATTACHMENT RBEC-FI-CV2
IDENTIFICATION OF APPLICABLE REQUIREMENTS
TITLE V CORE LIST

Effective: 03/01/02

(Updated based on current version of FDEP Air Rules)

[Note: The Title V Core List is meant to simplify the completion of the "List of Applicable Regulations" for DEP Form No. 62-210.900(1), Application for Air Permit - Long Form. The Title V Core List is a list of rules to which all Title V Sources are presumptively subject. The Title V Core List may be referenced in its entirety, or with specific exceptions. The Department may periodically update the Title V Core List.]

Federal: **(description)**

Acid Rain, Phase I and II
Rule 62-296.470, F.A.C., Clean Air Interstate Rule (CAIR)
40 CFR 60, Subpart KKKK: NSPS for Stationary Combustion Turbines that Commence Construction after February 18, 2005.
40 CFR 60, Subpart IIII: NSPS for Stationary Compression Ignition Internal Combustion Engines.
40 CFR 63, Subpart ZZZZ: National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)
40 CFR 98, Subpart C: General Stationary Fuel Combustion Sources

State: **(description)**

CHAPTER 62-4, F.A.C.: PERMITS, effective 02-16-12

62-4.030, F.A.C.: General Prohibition.
62-4.040, F.A.C.: Exemptions.
62-4.050, F.A.C.: Procedure to Obtain Permits; Application.
62-4.060, F.A.C.: Consultation.
62-4.070, F.A.C.: Standards for Issuing or Denying Permits; Issuance; Denial.
62-4.080, F.A.C.: Modification of Permit Conditions.
62-4.090, F.A.C.: Renewals.
62-4.100, F.A.C.: Suspension and Revocation.
62-4.110, F.A.C.: Financial Responsibility.
62-4.120, F.A.C.: Transfer of Permits.
62-4.130, F.A.C.: Transferability of Definitions.
62-4.150, F.A.C.: Review.
62-4.160, F.A.C.: Permit Conditions.
62-4.210, F.A.C.: Construction Permits.
62-4.220, F.A.C.: Operation Permit for New Sources.

CHAPTER 62-210, F.A.C.: STATIONARY SOURCES - GENERAL REQUIREMENTS, effective 03-28-12

62-210.300, F.A.C.: Permits Required.
62-210.300(1), F.A.C.: Air Construction Permits.
62-210.300(2), F.A.C.: Air Operation Permits.
62-210.300(3), F.A.C.: Exemptions.
62-210.300(5), F.A.C.: Notification of Startup.
62-210.300(6), F.A.C.: Emissions Unit Reclassification.
62-210.300(7), F.A.C.: Transfer of Air Permits.
62-210.350, F.A.C.: Public Notice and Comment.
62-210.350(1), F.A.C.: Public Notice of Proposed Agency Action.

62-210.350(2), F.A.C.: Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment-Area Preconstruction Review.

62-210.350(3), F.A.C.: Additional Public Notice Requirements for Sources Subject to Operation Permits for Title V Sources.

62-210.360, F.A.C.: Administrative Permit Corrections.

62-210.370, F.A.C.: Emissions Computation and Reporting.

62-210.400, F.A.C.: Emission Estimates.

62-210.650, F.A.C.: Circumvention.

62-210.700, F.A.C.: Excess Emissions.

62-210.900, F.A.C.: Forms and Instructions.

62-210.900(1), F.A.C.: Application for Air Permit – Title V Source, Form and Instructions.

62-210.900(5), F.A.C.: Annual Operating Report for Air Pollutant Emitting Facility, Form and Instructions.

62-210.900(7), F.A.C.: Application for Transfer of Air Permit – Title V and Non-Title V Source.

CHAPTER 62-212, F.A.C.: STATIONARY SOURCES - PRECONSTRUCTION REVIEW, effective 03-28-12

CHAPTER 62-213, F.A.C.: OPERATION PERMITS FOR MAJOR SOURCES OF AIR POLLUTION, effective 02-16-12

62-213.205, F.A.C.: Annual Emissions Fee.

62-213.400, F.A.C.: Permits and Permit Revisions Required.

62-213.410, F.A.C.: Changes Without Permit Revision.

62-213.412, F.A.C.: Immediate Implementation Pending Revision Process.

62-213.415, F.A.C.: Trading of Emissions Within a Source.

62-213.420, F.A.C.: Permit Applications.

62-213.430, F.A.C.: Permit Issuance, Renewal, and Revision.

62-213.440, F.A.C.: Permit Content.

62-213.450, F.A.C.: Permit Review by EPA and Affected States

62-213.460, F.A.C.: Permit Shield.

62-213.900, F.A.C.: Forms and Instructions.

62-213.900(1), F.A.C.: Major Air Pollution Source Annual Emissions Fee Form.

62-213.900(7), F.A.C.: Statement of Compliance Form.

CHAPTER 62-296, F.A.C.: STATIONARY SOURCES - EMISSION STANDARDS, effective 02-16-12

62-296.320(4)(c), F.A.C.: Unconfined Emissions of Particulate Matter.

62-296.320(2), F.A.C.: Objectionable Odor Prohibited.

CHAPTER 62-297, F.A.C.: STATIONARY SOURCES - EMISSIONS MONITORING, effective 02-16-12

62-297.310, F.A.C.: General Test Requirements.

62-297.310(4), F.A.C.: Applicable Test Procedures.

62-297.310(7), F.A.C.: Frequency of Compliance Tests.

62-297.310(6), F.A.C.: Repaired Stack Sampling Facilities.

62-297.310(5), F.A.C.: Determination of Process Variables.

62-297.510(8), F.A.C.: Test Report.

62-297.620, F.A.C.: Exceptions and Approval of Alternate Procedures and Requirements.

Miscellaneous:

CHAPTER 28-106, F.A.C.: Decisions Determining Substantial Interests effective 02-05-13

CHAPTER 62-110, F.A.C.: Exception to the Uniform Rules of Procedure, effective 07-01-98

CHAPTER 62-256, F.A.C.: Open Burning and Frost Protection Fires, effective 10-06-08

CHAPTER 62-257, F.A.C.: Asbestos Notification and Fee, effective 02-16-12

CHAPTER 62-281, F.A.C.: Motor Vehicle Air Conditioning Refrigerant Recovery and Recycling,
effective 02-16-12


ATTACHMENT RBEC-FI-CV3A
COMPLIANCE REPORT

**ATTACHMENT RBEC-FI-CV3A
COMPLIANCE REPORT**


Florida Power & Light Company (FPL) certifies that the Riviera Beach Energy Center (Facility ID 0990042) located in Palm Beach, Florida, as of the date of this application, is in compliance with each applicable requirement addressed in this Title V air operation permit application.

I, the undersigned, am the responsible official as designed in Chapter 62-213, F.A.C., of the Title V source for which this report is being submitted. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made and data contained in this report are true, accurate, and complete.

Compliance statements for this facility will be submitted on an annual basis to FDEP, within 60 days after the end of each calendar year.



Signature, Responsible Official



Date

ATTACHMENT RBEC-FI-CV3B

**COMPLIANCE PLAN FOR
RIVIERA BEACH ENERGY CENTER**

ATTACHMENT RBEC-FI-CV3B COMPLIANCE PLAN FOR RIVIERA BEACH ENERGY CENTER

A. EU013 Emergency Generators

Deviation

Air Construction Permit No. 0990042-006-AC authorized construction for two nominal 2,250 kilowatts (kW) diesel-fired emergency generators, which are subject to 40 CFR 60 Subpart IIII, NSPS for Stationary Compression Ignition Internal Combustion Engines (Stationary ICE). Since the purchasing agreement for these generators has been completed yet, the installation is not known.

Compliance Plan

FPL expects to acquire the emergency generators prior to expiration of construction permit No. 0990042-006-AC in December 2015. FPL will notify FDEP as soon as the installation and readiness testing is complete. Please note that based on Permit No. 0990042-006-AC, the units are subject to NSPS 40 CFR 60, Subpart IIII and manufacturer certification can be provided to the Department in lieu of actual stack testing for the applicable emissions limits. The units are also subject to 40 CFR 63 Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines (RICE) and will comply with the Subpart ZZZZ requirements by complying with the Subpart IIII requirements.

An initial visible emission (VE) testing using EPA Method 9 will be conducted within 60 days after achieving the maximum operating rate of the unit, but not later than 180 days after the initial startup. A report indicating the results of the results of the initial VE testing will be submitted to the Compliance Authority no later than 45 days after completion of the test.

ATTACHMENT RBEC-FI-CV4
EQUIPMENT/ACTIVITIES REGULATED UNDER TITLE VI

**ATTACHMENT CCEC-FI-CV4
EQUIPMENT/ACTIVITIES REGULATED UNDER TITLE VI**

The facility currently has no equipment with CFCs greater than 50 pounds

ATTACHMENT RBEC-FI-CA1
ACID RAIN PART APPLICATION

Plant Name (from STEP 1) Riviera Beach Energy Center

STEP 3

Read the standard requirements.

Acid Rain Part Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
 - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
- (4) For applications including a SO₂ Opt-in unit, a monitoring plan for each SO₂ Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO₂ Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
 - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
 - (ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and

Plant Name (from STEP 1) Riviera Beach Energy Center

**STEP 3,
Continued.**

Recordkeeping and Reporting Requirements (cont)

(iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

Liability.

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.

(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.

(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

(4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.

(5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.

(6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO_x averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.

(7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities.

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;

(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,

(5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

**STEP 4
For SO₂ Opt-in
units only.**

In column "f" enter the unit ID# for every SO₂ Opt-in unit identified in column "a" of STEP 2.

For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.

In column "h" enter the hours.

f	g	h (not required for renewal application)
Unit ID#	Description of the combustion unit	Number of hours unit operated in the six months preceding initial application

Plant Name (from STEP 1) Riviera Beach Energy Center

STEP 5

For SO₂ Opt-in units only.
(Not required for SO₂ Opt-in renewal applications.)

In column "i" enter the unit ID# for every SO₂ Opt-in unit identified in column "a" (and in column "f").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.

i	j	k	l	m	n
Unit ID#	Baseline or Alternative Baseline under 40 CFR 74.20 (mmBtu)	Actual SO ₂ Emissions Rate under 40 CFR 74.22 (lbs/mmBtu)	Allowable 1985 SO ₂ Emissions Rate under 40 CFR 74.23 (lbs/mmBtu)	Current Allowable SO ₂ Emissions Rate under 40 CFR 74.24 (lbs/mmBtu)	Current Promulgated SO ₂ Emissions Rate under 40 CFR 74.25 (lbs/mmBtu)

STEP 6

For SO₂ Opt-in units only.


Attach additional requirements, certify and sign.

- A. If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
- B. A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
- C. A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
- D. Attach a complete compliance plan for SO₂ under 40 CFR 72.40.
- E. The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
- F. The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."

Signature	Date
-----------	------

STEP 7

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

Certification (for designated representative or alternate designated representative only)	
I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.	
Name Christian Kiernan	Title PGD Technical Services General Manager
Owner Company Name Florida Power & Light	
Phone 561-691-2781	E-mail address: christian.kiernan@fpl.com
Signature 	Date 5/15/2014

ATTACHMENT RBEC-FI-CA2

CAIR PART

Plant Name (from STEP 1) Riviera Beach Energy Center

STEP 3

Read the
standard
requirements.

CAIR NO_x ANNUAL TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO_x source and each CAIR NO_x unit at the source shall:
 - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
 - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO_x source and each CAIR NO_x unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO_x source and each CAIR NO_x unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NO_x source with the following CAIR NO_x Emissions Requirements.

NO_x Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x source and each CAIR NO_x unit at the source shall hold, in the source's compliance account, CAIR NO_x allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NO_x emissions for the control period from all CAIR NO_x units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
- (2) A CAIR NO_x unit shall be subject to the requirements under paragraph (1) of the NO_x Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR NO_x allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_x Requirements, for a control period in a calendar year before the year for which the CAIR NO_x allowance was allocated.
- (4) CAIR NO_x allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
- (5) A CAIR NO_x allowance is a limited authorization to emit one ton of NO_x in accordance with the CAIR NO_x Annual Trading Program. No provision of the CAIR NO_x Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO_x allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO_x allowance to or from a CAIR NO_x unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_x unit.

Excess Emissions Requirements.

If a CAIR NO_x source emits NO_x during any control period in excess of the CAIR NO_x emissions limitation, then:

- (1) The owners and operators of the source and each CAIR NO_x unit at the source shall surrender the CAIR NO_x allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NO_x source and each CAIR NO_x unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
 - (i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NO_x unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
 - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Annual Trading Program.
 - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_x Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Annual Trading Program.
- (2) The CAIR designated representative of a CAIR NO_x source and each CAIR NO_x unit at the source shall submit the reports required under the CAIR NO_x Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

Plant Name (from STEP 1) Riviera Beach Energy Center

**STEP 3,
Continued**

Liability.

- (1) Each CAIR NO_x source and each CAIR NO_x unit shall meet the requirements of the CAIR NO_x Annual Trading Program.
- (2) Any provision of the CAIR NO_x Annual Trading Program that applies to a CAIR NO_x source or the CAIR designated representative of a CAIR NO_x source shall also apply to the owners and operators of such source and of the CAIR NO_x units at the source.
- (3) Any provision of the CAIR NO_x Annual Trading Program that applies to a CAIR NO_x unit or the CAIR designated representative of a CAIR NO_x unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_x Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x source or CAIR NO_x unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR SO₂ TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall:
 - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
 - (ii) [Reserved];
- (2) The owners and operators of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR SO₂ source and each SO₂ CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO₂ source with the following CAIR SO₂ Emission Requirements.

SO₂ Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO₂ allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO₂ units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
- (2) A CAIR SO₂ unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR SO₂ allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO₂ Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated.
- (4) CAIR SO₂ allowances shall be held in, deducted from, or transferred into or among CAIR SO₂ Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
- (5) A CAIR SO₂ allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO₂ Trading Program. No provision of the CAIR SO₂ Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR SO₂ allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO₂ allowance to or from a CAIR SO₂ unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO₂ unit.

Excess Emissions Requirements.

If a CAIR SO₂ source emits SO₂ during any control period in excess of the CAIR SO₂ emissions limitation, then:

- (1) The owners and operators of the source and each CAIR SO₂ unit at the source shall surrender the CAIR SO₂ allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

Plant Name (from STEP 1) Riviera Beach Energy Center

**STEP 3,
Continued**

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR SO₂ source and each CAIR SO₂ unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.
 - (i) The certificate of representation under 40 CFR 96.213 for the CAIR designated representative for the source and each CAIR SO₂ unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.213 changing the CAIR designated representative.
 - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO₂ Trading Program.
 - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR SO₂ Trading Program.
- (2) The CAIR designated representative of a CAIR SO₂ source and each CAIR SO₂ unit at the source shall submit the reports required under the CAIR SO₂ Trading Program, including those under 40 CFR Part 96, Subpart HHH.

Liability.

- (1) Each CAIR SO₂ source and each CAIR SO₂ unit shall meet the requirements of the CAIR SO₂ Trading Program.
- (2) Any provision of the CAIR SO₂ Trading Program that applies to a CAIR SO₂ source or the CAIR designated representative of a CAIR SO₂ source shall also apply to the owners and operators of such source and of the CAIR SO₂ units at the source.
- (3) Any provision of the CAIR SO₂ Trading Program that applies to a CAIR SO₂ unit or the CAIR designated representative of a CAIR SO₂ unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR SO₂ Trading Program, a CAIR Part, or an exemption under 40 CFR 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO₂ source or CAIR SO₂ unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR NO_x OZONE SEASON TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall:
 - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
 - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO_x Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO_x Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO_x Ozone Season source with the following CAIR NO_x Ozone Season Emissions Requirements.

NO_x Ozone Season Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_x Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO_x emissions for the control period from all CAIR NO_x Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.
- (2) A CAIR NO_x Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO_x Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1),(2), or (3) and for each control period thereafter.
- (3) A CAIR NO_x Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_x Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO_x Ozone Season allowance was allocated.
- (4) CAIR NO_x Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.
- (5) A CAIR NO_x Ozone Season allowance is a limited authorization to emit one ton of NO_x in accordance with the CAIR NO_x Ozone Season Trading Program. No provision of the CAIR NO_x Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO_x Ozone Season allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a

CAIR NO_x Ozone Season allowance to or from a CAIR NO_x Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_x Ozone Season unit.

Plant Name (from STEP 1) Riviera Beach Energy Center

**STEP 3,
Continued**

Excess Emissions Requirements.

If a CAIR NO_x Ozone Season source emits NO_x during any control period in excess of the CAIR NO_x Ozone Season emissions limitation, then:
 (1) The owners and operators of the source and each CAIR NO_x Ozone Season unit at the source shall surrender the CAIR NO_x Ozone Season allowances required for deduction under 40 CFR 96.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
 (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
 (i) The certificate of representation under 40 CFR 96.313 for the CAIR designated representative for the source and each CAIR NO_x Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
 (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
 (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Ozone Season Trading Program.
 (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_x Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Ozone Season Trading Program.
 (2) The CAIR designated representative of a CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall submit the reports required under the CAIR NO_x Ozone Season Trading Program, including those under 40 CFR Part 96, Subpart HHHH.

Liability.

(1) Each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit shall meet the requirements of the CAIR NO_x Ozone Season Trading Program.
 (2) Any provision of the CAIR NO_x Ozone Season Trading Program that applies to a CAIR NO_x Ozone Season source or the CAIR designated representative of a CAIR NO_x Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO_x Ozone Season units at the source.
 (3) Any provision of the CAIR NO_x Ozone Season Trading Program that applies to a CAIR NO_x Ozone Season unit or the CAIR designated representative of a CAIR NO_x Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.


No provision of the CAIR NO_x Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x Ozone Season source or CAIR NO_x Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

STEP 4

Certification (for designated representative or alternate designated representative only)

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Christian Kiernan	Title PGD Technical Services General Manager (DR)
Company Owner Name: Florida Power & Light	
Phone 561-691-2781	E-mail Address: Christian.Kiernan@fpl.com
Signature 	Date 5/15/14

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

III. EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Application - For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for an initial, revised or renewal Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

Air Construction Permit or FESOP Application - For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an “unregulated emissions unit” does not apply. If this is an application for an air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application – Where this application is used to apply for both an air construction permit and a revised or renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes, and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this application that is subject to air construction permitting and for each such emissions unit that is a regulated or unregulated unit for purposes of Title V permitting. (An emissions unit may be exempt from air construction permitting but still be classified as an unregulated unit for Title V purposes.) Emissions units classified as insignificant for Title V purposes are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

Emissions Unit Control Equipment/Method: Control 1 of 3

1. Control Equipment/Method Description:
SCR for NOx control

2. Control Device or Method Code: **139**

Emissions Unit Control Equipment/Method: Control 2 of 3

1. Control Equipment/Method Description:
Water Injection for NOx control

2. Control Device or Method Code: **028**

Emissions Unit Control Equipment/Method: Control 3 of 3

1. Control Equipment/Method Description:
Low NOx burners for NOx control

2. Control Device or Method Code: **205**

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

C. EMISSION POINT (STACK/VENT) INFORMATION

(Optional for unregulated emissions units.)

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram: EUs 007, 008 and 009		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking: Each CTG exhaust is emitted through a separate HRSG stack			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 149 feet	7. Exit Diameter: 22 feet	
8. Exit Temperature: 185°F	9. Actual Volumetric Flow Rate: 1,427,000 acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates... Zone: East (km): North (km):		14. Emission Point Latitude/Longitude... Latitude (DD/MM/SS) Longitude (DD/MM/SS)	
15. Emission Point Comment: Exit temperature and flow rate are for each CT/HRSG/Duct Burner and based on natural gas firing at 100-percent load at 59°F ambient temperature (Permit application dated January 2009).			

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

D. SEGMENT (PROCESS/FUEL) INFORMATION

Segment Description and Rate: Segment 1 of 2

1. Segment Description (Process/Fuel Type): Internal Combustion Engines: Electric Generation; Natural Gas; Turbine Generator		
2. Source Classification Code (SCC): 2-01-002-01		3. SCC Units: Million cubic feet
4. Maximum Hourly Rate: 8.32	5. Maximum Annual Rate: 72,883.2	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: 933
10. Segment Comment: Maximum hourly rate=2,586 MMBtu/hr ÷ 933 MMBtu/ft³ x 3 CTGs= 8.32 MMft³/hr Maximum annual fuel rate= 8.32 MMft³/hr x 8,760 hr/yr= 72,883.2 MMft³/hr Fuel heat content based on LHV. Maximum hourly and annual rates do not consider maximum annual heat input of 3,697,920 MMBtu/yr for three DBs combined.		

Segment Description and Rate: Segment 2 of 2

1. Segment Description (Process/Fuel Type): Internal Combustion Engines: Electric Generation; Distillate Oil (No. 2); Turbine Generator		
2. Source Classification Code (SCC): 2-01-001-01		3. SCC Units: 1,000 Gallons
4. Maximum Hourly Rate: 55.9	5. Maximum Annual Rate: 47,515	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: 0.0015	8. Maximum % Ash:	9. Million Btu per SCC Unit: 131
10. Segment Comment: Maximum hourly rate=2,440 MMBtu/hr ÷ 131 kGal/ft³ x 3 CTGs = 55.9 kGal/hr Maximum annual fuel rate= 55.9 kGal/hr x (2,550 ÷ 3) hr/yr= 47,515 kGal/yr Fuel heat content based on LHV.		

EMISSIONS UNIT INFORMATION

Section [1]
 Combined Cycle Units 5A, 5B, and 5C

POLLUTANT DETAIL INFORMATION

Page [1] of [7]
 Particulate Matter Total - PM/PM10

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: PM/PM10		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 90 lb/hour 185.5 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 2 gr S/100 SCF of gas 0.0015-percent sulfur fuel oil Reference: Permit No. 0990042-006-AC		7. Emissions Method Code: 0	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Potential hourly emissions based on distillate oil firing at 59°F inlet condition. Potential hourly emissions for one CT/HRSG at base load = 30 lb/hr based on Table 2-3B of PSD permit application dated January, 2009. Potential hourly emissions for three CT/HRSGs at base load= 30 lb/hr x 3 = 90 lb/hr based on Table 2-3B of PSD permit application dated January, 2009. Potential annual emissions for 3 CTGs = 185.5 TPY based on Table 2-3B of PSD permit application dated January, 2009.			
11. Potential, Fugitive, and Actual Emissions Comment: Potential emissions vary with turbine inlet conditions.			

EMISSIONS UNIT INFORMATION

Section [1]
 Combined Cycle Units 5A, 5B, and 5C

POLLUTANT DETAIL INFORMATION

Page [1] of [7]
 Particulate Matter Total – PM/PM10

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 2 gr S/100 SCF of gas	4. Equivalent Allowable Emissions: 49.2 lb/hour tons/year
5. Method of Compliance: Fuel Analysis Records	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing: Fuel sulfur content limited to 2 grains per 100 scf. Equivalent hourly emissions based on 59°F inlet condition. Hourly emissions of one CT/HRSG with DB = 16.4 lb/hr. Hourly emissions of three CT/HRSGs with DB = 16.4 x 3 = 49.2 lb/hr.	

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 0.0015-percent sulfur fuel oil	4. Equivalent Allowable Emissions: 90 lb/hour tons/year
5. Method of Compliance: Fuel Analysis Records	
6. Allowable Emissions Comment (Description of Operating Method): Fuel oil firing: Fuel sulfur content limited to 0.0015 percent, by weight. Equivalent hourly emissions based on 59°F inlet condition. Hourly emissions of one CT/HRSG = 30 lb/hr Hourly emissions of three CT/HRSG = 30 x 3 = 90 lb/hr	

Allowable Emissions Allowable Emissions ____ of ____

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]
 Combined Cycle Units 5A, 5B, and 5C

Page [2] of [7]
 Sulfur Dioxide - SO2

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: SO2		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 51.3 lb/hour 201.9 tons/year		4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 2 gr S/100 SCF of gas 0.0015-percent sulfur fuel oil Reference: Permit No. 0990042-006-AC		7. Emissions Method Code: 0	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Potential hourly emissions based on natural gas firing with DB at 59°F inlet conditions: Potential hourly emissions of one CT/HRSG with DB = 17.1 lb/hr. Potential hourly emissions of three CT/HRSGs = 17.1 lb/hr x 3 = 51.3 lb/hr. Potential annual Emissions of one CT/HRSG = 67.1 TPY (Table 2-3B of PSD permit application dated January 2009). Annual Emissions for three CT/HRSGs = 67.1 x 3 = 201.9 TPY			
11. Potential, Fugitive, and Actual Emissions Comment: Potential mass emissions vary with turbine inlet conditions. Duct-firing limited to 3,697,920 MMBtu for three CT/HRSGs (equivalent to 2,679 hr/yr per CT/HRSG). Distillate oil firing limited to 2,550 hr/yr aggregated over 3 CTGs.			

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions **1** of **2**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 2 gr S/100 SCF of gas	4. Equivalent Allowable Emissions: 51.3 lb/hour tons/year
5. Method of Compliance: Fuel Analysis Records	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing: Fuel sulfur content limited to 2 grains per 100 scf. Equivalent hourly emissions based on 59°F inlet condition. Hourly emissions of one CT/HRSG = 17.1 lb/hr. Hourly emissions of three CT/HRSGs = 17.1 lb/hr x 3 = 51.3 lb/hr.	

Allowable Emissions Allowable Emissions **2** of **2**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 0.0015-percent sulfur fuel oil	4. Equivalent Allowable Emissions: 11.1 lb/hour tons/year
5. Method of Compliance: Fuel Analysis Records	
6. Allowable Emissions Comment (Description of Operating Method): Fuel oil firing: Fuel sulfur content limited to 0.0015 percent. Equivalent hourly emissions based on 59°F inlet condition. Hourly emissions of one CT/HRSG = 3.7 lb/hr. Hourly emissions of three CT/HRSGs = 3.7 lb/hr x 3 = 11.1 lb/hr.	

Allowable Emissions Allowable Emissions ____ of ____

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [1]
 Combined Cycle Units 5A, 5B, and 5C

POLLUTANT DETAIL INFORMATION

Page [3] of [7]
 Nitrogen Oxides - NOx

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: NOx		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 240.0 lb/hour 357.6 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 2.0 ppmvd at 15% O₂ firing natural gas 8.0 ppmvd at 15% O₂ firing fuel oil		7. Emissions Method Code: 0	
Reference: Permit No. 0990042-006-AC			
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Potential hourly emissions based on Fuel Oil firing at 59°F inlet conditions: Potential hourly emissions of one CT/HRSG = 80.0 lb/hr. Potential hourly emissions of three CT/HRSG = 80.0 x 3 = 240.0 lb/hr. Potential annual Emissions for one CTG= 119.2 TPY (Table 2-3B of PSD permit application dated January 2009). Potential annual emissions of 3 CTGs = 119.2 TPY x 3 = 357.6 TPY			
11. Potential, Fugitive, and Actual Emissions Comment: Potential mass emissions vary with turbine inlet conditions. Distillate oil firing limited to 2,550 hr/yr aggregated over three CTG. Duct-firing limited to 3,697,920 MMBtu for three CT/HRSGs (equivalent to 2,679 hr/yr per CT/HRSG, Maximum heat input 460 MMBtu/hr).			

EMISSIONS UNIT INFORMATION**POLLUTANT DETAIL INFORMATION**

Section [1]

Page [3] of [7]

Combined Cycle Units 5A, 5B, and 5C

Nitrogen Oxides - NOx

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -**ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions **1** of **3**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 2.0 ppmvd@15% O₂ and 19.3 lb/hr	4. Equivalent Allowable Emissions: 57.9 lb/hour 253.6 tons/year
5. Method of Compliance: CEMS 30-day rolling average, initial stack test using EPA Methods 7E or 20.	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing CT only. Equivalent hourly emissions based on 59°F inlet condition. Equivalent hourly emissions of one CT = 19.3 lb/hr Equivalent hourly emissions of three CTs = 19.3 x 3 = 57.9 lb/hr Equivalent Annual Emissions= 57.9 lb/hr x 8,760 hr/yr x 1 ton/2,000 lb = 253.6 TPY	

Allowable Emissions Allowable Emissions **2** of **3**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 2.0 ppmvd@15% O₂ and 22.8 lb/hr	4. Equivalent Allowable Emissions: 68.4 lb/hour 91.6 tons/year
5. Method of Compliance: CEMS 30-day rolling average, initial stack test using EPA Methods 7E or 20.	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing with duct burners. Equivalent hourly emissions based on 59°F inlet condition. Equivalent hourly emissions of one CT = 22.8 lb/hr Equivalent hourly emissions of three CTs = 22.8 x 3 = 68.4 lb/hr Equivalent Annual Emissions= 68.4 lb/hr x 2,679 hr/yr x 1 ton/2,000 lb = 91.6 TPY	

Allowable Emissions Allowable Emissions **3** of **3**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 8.0 ppmvd@15% O₂ and 80.0 lb/hr	4. Equivalent Allowable Emissions: 240 lb/hour 102 tons/year
5. Method of Compliance: CEMS 30-day rolling average, initial stack test using EPA Methods 7E or 20.	
6. Allowable Emissions Comment (Description of Operating Method): Fuel oil firing. Equivalent hourly emissions based on 59°F inlet condition. Equivalent hourly emissions of one CT = 80.0 lb/hr Equivalent hourly emissions of three CTs = 80.0 x 3 = 240.0 lb/hr Equivalent Annual Emissions= 80 lb/hr x 2,550 hr/yr x 1 ton/2,000 lb = 102 TPY	

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]

Page [4] of [7]

Combined Cycle Units 5A, 5B, and 5C

Carbon Monoxide - CO

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS
(Optional for unregulated emissions units.)**

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: CO		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 183.0 lb/hour 511.2 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 7.6 ppmvd @ 15% O₂ (NG-firing with DB) 5.0 ppmvd @ 15% O₂ (NG-firing without DB) 10.0 ppmvd @ 15% O₂ (Fuel Oil)		7. Emissions Method Code: 0	
Reference: Permit No. 0990042-006-AC			
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Potential hourly emissions based on Fuel Oil firing with DB at 59°F inlet conditions. Potential hourly emissions of one CT/HRSG = 61.0 lb/hr. Potential hourly emissions of three CT/HRSG = 61.0 x 3 = 183.0 lb/hr. Potential annual emissions for one CT/HRSG = 170.4 TPY (Table 2-3B of PSD permit application dated January 2009). Potential annual emissions for three CT/HRSGs = 170.4 x 3 = 511.2 TPY.			
11. Potential, Fugitive, and Actual Emissions Comment: Potential mass emissions vary with turbine inlet conditions. Distillate oil firing limited to 3,000 hr/yr aggregated over three CTG (equivalent to 1,000 hr/yr per CT/HRSG). Duct-firing limited to 3,697,920 MMBtu for three CT/HRSGs (equivalent to 2,679 hr/yr per CT/HRSG, Maximum heat input 460 MMBtu/hr).			

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]

Page [4] of [7]

Combined Cycle Units 5A, 5B, and 5C

Carbon Monoxide - CO

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -

ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 5.0 ppmvd @15% O₂ and 29.0 lb/hr	4. Equivalent Allowable Emissions: 87.0 lb/hour 381.1 tons/year
5. Method of Compliance: Initial stack test (EPA Method 10)	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing CT only. Equivalent hourly emissions based on 59°F inlet condition. Equivalent hourly emissions of one CT = 29.0 lb/hr Equivalent hourly emissions of three CTs = 29.0 x 3 = 87.0 lb/hr Equivalent Annual Emissions= 87.0 lb/hr x 8,760 hr/yr x 1 ton/2,000 lb = 381.1 TPY	

Allowable Emissions Allowable Emissions 2 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 7.6 ppmvd @15% O₂ and 52.7 lb/hr	4. Equivalent Allowable Emissions: 158.1 lb/hour 211.8 tons/year
5. Method of Compliance: Initial stack test (EPA Method 10)	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing with duct burners. Duct firing limited to 2,679 hr/yr per CT/HRSG. Equivalent hourly emissions based on 59°F inlet condition. Equivalent hourly emissions of one CT = 52.7 lb/hr Equivalent hourly emissions of three CTs = 52.7 x 3 = 158.1 lb/hr Equivalent Annual Emissions= 158.1 lb/hr x 2,679 hr/yr x 1 ton/2,000 lb = 211.8 TPY	

Allowable Emissions Allowable Emissions 3 of 4

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 10.0 ppmvd @15% O₂ and 61.0 lb/hr	4. Equivalent Allowable Emissions: 183 lb/hour 77.8 tons/year
5. Method of Compliance: CEMs 30-day rolling average; Initial stack test using EPA Method 10	
6. Allowable Emissions Comment (Description of Operating Method): Fuel oil firing. Oil firing limited to 2,550 hr/yr for all three CT/HRSGs combined. Equivalent hourly emissions based on 59°F inlet condition. Hourly emissions for one CT/HRSG = 61 lb/hr. Equivalent hourly emissions for three CT/HRSG = 61 lb/hr x 3 = 183 lb/hr. Equivalent Annual Emissions= 61 lb/hr x 2,550 hr/yr x 1 ton/2,000 lb = 77.8 TPY	

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

POLLUTANT DETAIL INFORMATION

Page [4] of [7]

Carbon Monoxide - CO

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS****Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.****Allowable Emissions** Allowable Emissions **4** of **4**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 7.5 ppmvd @ 15-percent O₂	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: CEMS 30-day rolling average	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing	

Allowable Emissions Allowable Emissions ____ of ____

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions ____ of ____

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [1]
 Combined Cycle Units 5A, 5B, and 5C

POLLUTANT DETAIL INFORMATION

Page [5] of [7]
 Volatile Organic Compounds - VOC

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: VOC		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 56.7 lb/hour 77.1 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 1.9 ppmvd @ 15% O₂ (NG-firing with DB) 1.5 ppmvd @ 15% O₂ (NG-firing without DB) 6.0 ppmvd @ 15% O₂ (Fuel Oil)		7. Emissions Method Code: 0	
Reference: Permit No. 0990042-006-AC			
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Potential hourly emissions based on fuel oil firing at 59°F inlet condition. Potential hourly emissions of one CT/HRSG = 18.9 lb/hr. Potential hourly emissions of three CT/HRSG = 18.9 lb/hr x 3 = 56.7 lb/hr. Potential annual emissions for one CT/HRSG = 25.7 TPY (Table 2-3B of PSD permit application dated January 2009). Potential annual emissions for three CT/HRSGs = 25.7 x 3 = 77.1 TPY.			
11. Potential, Fugitive, and Actual Emissions Comment: Potential mass emissions vary with turbine inlet conditions. Distillate oil firing limited to 2,550 hr/yr aggregated over three CTG. Duct-firing limited to 3,697,920 MMBtu for three CT/HRSGs (equivalent to 2,679 hr/yr per CT/HRSG, Maximum heat input 460 MMBtu/hr).			

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]

Page [5] of [7]

Combined Cycle Units 5A, 5B, and 5C

Volatile Organic Compounds - VOC

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -

ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions **1** of **3**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 1.5 ppmvd @15% O₂ and 4.8 lb/hr	4. Equivalent Allowable Emissions: 14.4 lb/hour 63.1 tons/year
5. Method of Compliance: Initial stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing CT only. Equivalent hourly emissions for one CT/HRSG = 4.8 lb/hr. Equivalent hourly emissions for three CT/HRSGs = 4.8 lb/hr x 3 = 14.4 lb/hr. Equivalent Annual Emissions= 14.4 lb/hr x 8,760 hr/yr x (1 ton/2,000 lb) = 63.1 TPY	

Allowable Emissions Allowable Emissions **2** of **3**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 1.9 ppmvd @15% O₂ and 7.2 lb/hr	4. Equivalent Allowable Emissions: 21.6 lb/hour 28.9 tons/year
5. Method of Compliance: Initial stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing with duct burners. Equivalent hourly emissions for one CT/HRSG = 7.2 lb/hr. Equivalent hourly emissions for three CT/HRSG = 7.2 lb/hr x 3 = 21.6 lb/hr. Equivalent Annual Emissions= 21.6 lb/hr x 2,679 hr/yr x (1 ton/2,000 lb) = 28.9 TPY	

Allowable Emissions Allowable Emissions **3** of **3**

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 6.0 ppmvd @15% O₂ and 18.9 lb/hr	4. Equivalent Allowable Emissions: 56.7 lb/hour 28.4 tons/year
5. Method of Compliance: Initial stack test using EPA Methods 25A or 18	
6. Allowable Emissions Comment (Description of Operating Method): Fuel oil firing. Fuel oil firing limited to 2,550 hr/yr for all three CT/HRSGs combined. Equivalent hourly emissions based on 59°F inlet condition and 100% load. Equivalent hourly emissions of one CT/HRSG = 18.9 lb/hr Equivalent hourly emissions of three CT/HRSGs = 18.9 x 3 = 56.7 lb/hr Equivalent Annual Emissions= 18.9 lb/hr x 2,550 hr/yr x 1 ton/2,000 lb = 24.1 TPY	

EMISSIONS UNIT INFORMATION

POLLUTANT DETAIL INFORMATION

Section [1]
 Combined Cycle Units 5A, 5B, and 5C

Page [6] of [7]
 Sulfuric Acid Mist - SAM

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: SAM		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 11.1 lb/hour 40.8 tons/year		4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 2 gr S/100 SCF of gas 0.0015-percent of sulfur fuel oil Reference: Permit No. 0990042-006-AC		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Potential hourly emissions based on natural gas firing with DB at 59°F inlet conditions: Potential hourly emissions of one CT/HRSG = 3.7 lb/hr. Potential hourly emissions of three CT/HRSGs = 3.7 lb/hr x 3 = 11.1 lb/hr. Potential annual emissions of one CT/HRSG = 13.6 TPY (Table 2-3B of PSD permit application dated December 2008) Potential annual emissions for three CT/HRSGs = 13.6 x 3 = 40.8 TPY			
11. Potential, Fugitive, and Actual Emissions Comment: Potential hourly emissions vary with turbine inlet conditions. Duct-firing limited to 3,697,920 MMBtu for three CT/HRSGs (equivalent to 2,880 hr/yr per CT/HRSG). Distillate oil firing limited to 2,550 hr/yr aggregated over 3 CT/HRSGs.			

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 2 gr S/100 SCF of gas	4. Equivalent Allowable Emissions: 11.1 lb/hour tons/year
5. Method of Compliance: Fuel Analysis Records	
6. Allowable Emissions Comment (Description of Operating Method): Natural gas firing: Fuel sulfur content limited to 2 grains per 100 standard cubic feet of natural gas. Equivalent hourly emissions based on 59°F inlet condition. Hourly emissions of one CT/HRSG = 3.7 lb/hr. Hourly emissions of three CT/HRSGs = 3.7 lb/hr x 3 = 11.1 lb/hr.	

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 0.0015-percent of sulfur fuel oil	4. Equivalent Allowable Emissions: 2.1 lb/hour tons/year
5. Method of Compliance: Fuel Analysis Records	
6. Allowable Emissions Comment (Description of Operating Method): Fuel oil firing: Fuel sulfur content limited to 0.0015 percent. Equivalent hourly emissions based on 59°F inlet condition. Hourly emissions of one CT/HRSG = 0.7 lb/hr. Hourly emissions of three CT/HRSGs = 0.7 lb/hr x 3 = 2.1 lb/hr.	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [1]
 Combined Cycle Units 5A, 5B, and 5C

POLLUTANT DETAIL INFORMATION

Page [7] of [7]
 Ammonia - NH3

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: NH3		2. Total Percent Efficiency of Control:	
3. Potential Emissions: See Comment lb/hour tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 5 ppmvd @15% O₂ Reference: Permit No. 0990042-006-AC		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions:			
11. Potential, Fugitive, and Actual Emissions Comment: Ammonia slip limited to 5 ppmvd @ 15-percent O₂. State requirement only. Ammonia is not a regulated air pollutant under Title V or NSPS.			

EMISSIONS UNIT INFORMATION

Section [1]
 Combined Cycle Units 5A, 5B, and 5C

POLLUTANT DETAIL INFORMATION

Page [7] of [7]
 Ammonia - NH3

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
 ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 5 ppmvd @ 15-percent O₂	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance: Annual stack test using EPA Method CTM-027 or EPA Method 320.	
6. Allowable Emissions Comment (Description of Operating Method): For natural gas and fuel oil firing including duct burner operation.	

Allowable Emissions Allowable Emissions _____ of _____

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions _____ of _____

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

G. VISIBLE EMISSIONS INFORMATION

Complete Subsection G if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

Visible Emissions Limitation: Visible Emissions Limitation 1 of 2

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: EPA Method 9	
5. Visible Emissions Comment: Visible emissions limited to 10% opacity for each 6-minute block average.	

Visible Emissions Limitation: Visible Emissions Limitation 2 of 2

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: 20 % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: EPA Method 9	
5. Visible Emissions Comment: Visible emissions due to startup, shutdown, and malfunction limited to ten 6-minute periods per calendar day. Alternative visible emission standard. Rule 62-4.070(3), F.A.C.; Permit No. 0990042-006-AC.	

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

H. CONTINUOUS MONITOR INFORMATION

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 1 of 9

1. Parameter Code: EM	2. Pollutant(s): NOx
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Thermo Model Number: 42i-LS Serial Number: 1304256577	
5. Installation Date:	6. Performance Specification Test Date: 3/4/2014
7. Continuous Monitor Comment: Continuous monitoring of NOx emissions. Unit 5A 40 CFR 75	

Continuous Monitoring System: Continuous Monitor 2 of 9

1. Parameter Code: EM	2. Pollutant(s): CO
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Thermo Model Number: 48i Serial Number: CM13090050	
5. Installation Date:	6. Performance Specification Test Date: 3/4/2014
7. Continuous Monitor Comment: Continuous monitoring of CO emissions. Unit 5A 40 CFR 75	

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

H. CONTINUOUS MONITOR INFORMATION (CONTINUED)

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 3 of 9

1. Parameter Code: O2	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Servomex Model Number: 1440 Serial Number: 01440D1/4760	
5. Installation Date:	6. Performance Specification Test Date: 3/4/2014
7. Continuous Monitor Comment: Monitoring of O₂ for dilution with NO_x and CO monitors. Unit 5A 40 CFR 75	

Continuous Monitoring System: Continuous Monitor 4 of 9

1. Parameter Code: EM	2. Pollutant(s): NOx
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Thermo Model Number: 42i - LS Serial Number: 1304256576	
5. Installation Date:	6. Performance Specification Test Date: 3/4/2014
7. Continuous Monitor Comment: Continuous monitoring of NO_x emissions. Unit 5B 40 CFR 75	

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

H. CONTINUOUS MONITOR INFORMATION (CONTINUED)**Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.****Continuous Monitoring System:** Continuous Monitor **5** of **9**

1. Parameter Code: EM	2. Pollutant(s): CO
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Thermo Model Number: 48i Serial Number: CM13030004	
5. Installation Date:	6. Performance Specification Test Date: 3/4/2014
7. Continuous Monitor Comment: Continuous monitoring of CO emissions. Unit 5B 40 CFR 75	

Continuous Monitoring System: Continuous Monitor **6** of **9**

1. Parameter Code: O2	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Servomex Model Number: 01140D1 Serial Number: 3/4/2014	
5. Installation Date:	6. Performance Specification Test Date: 12/05/2012
7. Continuous Monitor Comment: Monitoring of O₂ for dilution with NO_x and CO monitors. Unit 5B 40 CFR 75	

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

H. CONTINUOUS MONITOR INFORMATION (CONTINUED)

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 7 of 9

1. Parameter Code: EM	2. Pollutant(s): NOx
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Thermo Model Number: 42i - LS Serial Number: 1304256578	
5. Installation Date:	6. Performance Specification Test Date: 3/4/2014
7. Continuous Monitor Comment: Continuous monitoring of NOx emissions. Unit 5C 40 CFR 75	

Continuous Monitoring System: Continuous Monitor 8 of 9

1. Parameter Code: EM	2. Pollutant(s): CO
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Thermo Model Number: 48i Serial Number: CM13030003	
5. Installation Date:	6. Performance Specification Test Date: 3/4/2014
7. Continuous Monitor Comment: Continuous monitoring of CO emissions. Unit 5C 40 CFR 75	

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

H. CONTINUOUS MONITOR INFORMATION (CONTINUED)

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 9 of 9

1. Parameter Code: O2	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Servomex Model Number: 1440 Serial Number: 0144001	
5. Installation Date:	6. Performance Specification Test Date: 3/4/2014
7. Continuous Monitor Comment: Monitoring of O₂ for dilution with NO_x and CO monitors. Unit 5C. 40 CFR 75	

Continuous Monitoring System: Continuous Monitor _____ of _____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment:	

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

I. EMISSIONS UNIT ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

1. Process Flow Diagram: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: RBEC-EU1-I1 <input type="checkbox"/> Previously Submitted, Date _____
2. Fuel Analysis or Specification: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: RBEC-EU1-I2 <input type="checkbox"/> Previously Submitted, Date _____
3. Detailed Description of Control Equipment: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: RBEC-EU1-I3 <input type="checkbox"/> Previously Submitted, Date _____
4. Procedures for Startup and Shutdown: (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input checked="" type="checkbox"/> Attached, Document ID: RBEC-EU1-I4 <input type="checkbox"/> Previously Submitted, Date _____ <input type="checkbox"/> Not Applicable (construction application)
5. Operation and Maintenance Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____ <input checked="" type="checkbox"/> Not Applicable
6. Compliance Demonstration Reports/Records: <input checked="" type="checkbox"/> Attached, Document ID: RBEC-EU1-I6 Test Date(s)/Pollutant(s) Tested: NOx, CO, VOC, NH₃, VE; <u>Oil Testing: 5A - 4/22/2014, 5B - 5/13/2014, 5C - 6/1/2014; Gas Testing: 5A, 5B, 5C - 3/4/14</u> <input type="checkbox"/> Previously Submitted, Date: _____ Test Date(s)/Pollutant(s) Tested: _____ _____ <input type="checkbox"/> To be Submitted, Date (if known): _____ Test Date(s)/Pollutant(s) Tested: _____ _____ <input type="checkbox"/> Not Applicable Note: For FESOP applications, all required compliance demonstration records/reports must be submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a compliance plan must be submitted at the time of application.
7. Other Information Required by Rule or Statute: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

EMISSIONS UNIT INFORMATION

Section [1]

Combined Cycle Units 5A, 5B, and 5C

I. EMISSIONS UNIT ADDITIONAL INFORMATION (CONTINUED)

Additional Requirements for Air Construction Permit Applications

1. Control Technology Review and Analysis (Rules 62-212.400(10) and 62-212.500(7), F.A.C.; 40 CFR 63.43(d) and (e)): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
2. Good Engineering Practice Stack Height Analysis (Rules 62-212.400(4)(d) and 62-212.500(4)(f), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
3. Description of Stack Sampling Facilities: (Required for proposed new stack sampling facilities only) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable


Additional Requirements for Title V Air Operation Permit Applications

1. Identification of Applicable Requirements: <input checked="" type="checkbox"/> Attached, Document ID: <u>RBEC-EU1-IV1</u>
2. Compliance Assurance Monitoring: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
3. Alternative Methods of Operation: <input checked="" type="checkbox"/> Attached, Document ID: <u>RBEC-EU1-IV3</u> <input type="checkbox"/> Not Applicable
4. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

Additional Requirements Comment

<p>Combined Cycle Units 5A, 5B, and 5C are exempt from the CAM requirements for NO_x control using SCR since continuous compliance is required to be demonstrated by a CEMS. Rule:40 CFR 64.29(b)(vi).</p>
--

ATTACHMENT RBEC-EU1-I1
PROCESS FLOW DIAGRAM



RBEC-EU1-I1 . Process Flow Diagram for CTG/HRSG
 FPL Riviera Beach Energy Center, Palm Beach, Florida

Source: Golder, 2014.

Process Flow Legend

- Solid/Liquid —————>
- Gas - - - - ->
- Steam ·······>



ATTACHMENT RBEC-EU1-I2
FUEL ANALYSIS OR SPECIFICATION



Total Sulfur Previous Day

04/28/2014 08:00 AM

Florida Gas Transmission

Florida Gas makes no warranty or representation whatsoever as to the accuracy of the information provided. This information is provided on a best efforts basis and is an estimate. The information is not used for billing purposes. Florida Gas is not responsible for any reliance on this information by any party.

Stream History

Gas Day	Perry 36" Stream #1		Perry 30" Stream #2		Perry 24" Stream #3		Brooker 24" Stream	
	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf
04/26/2014	1.116	0.070	0.954	0.060	0.976	0.061	2.368	0.148
04/26/2014	1.199	0.075	1.082	0.068	1.099	0.069	2.646	0.165
04/25/2014	1.382	0.086	1.258	0.079	1.270	0.079	3.547	0.222
04/24/2014	1.202	0.075	1.119	0.070	1.127	0.070	3.638	0.227
04/23/2014	1.196	0.075	1.150	0.072	1.161	0.073	3.891	0.243
04/22/2014	1.246	0.078	1.188	0.074	1.192	0.075	3.845	0.240
04/21/2014	1.270	0.079	1.182	0.074	1.176	0.073	3.481	0.218
04/20/2014	1.204	0.075	1.120	0.070	1.105	0.069	2.294	0.143
04/19/2014	1.139	0.071	1.057	0.066	1.042	0.065	2.960	0.185
04/18/2014	1.077	0.067	1.015	0.063	1.008	0.063	3.075	0.192
04/17/2014	1.087	0.068	1.023	0.064	1.020	0.064	2.767	0.173
04/16/2014	1.048	0.065	0.997	0.062	0.988	0.062	0.021	0.001
04/15/2014	1.093	0.068	1.022	0.064	1.008	0.063	1.789	0.112
04/14/2014	1.188	0.074	1.153	0.072	1.154	0.072	4.298	0.269
04/13/2014	1.197	0.075	1.146	0.072	1.145	0.072	4.658	0.291
04/12/2014	1.098	0.069	1.082	0.068	1.097	0.069	4.663	0.291
04/11/2014	1.139	0.071	1.133	0.071	1.126	0.070	3.774	0.236
04/10/2014	1.063	0.066	1.074	0.067	1.073	0.067	3.209	0.201
04/09/2014	0.980	0.061	0.965	0.060	0.949	0.059	1.776	0.111
04/08/2014	0.912	0.057	0.792	0.050	0.752	0.047	2.375	0.148
04/07/2014	0.913	0.057	0.722	0.045	0.695	0.043	3.108	0.194
04/06/2014	1.018	0.064	0.884	0.055	0.904	0.056	2.924	0.183
04/05/2014	1.075	0.067	0.980	0.061	0.991	0.062	3.352	0.209
04/04/2014	1.083	0.068	1.026	0.064	1.043	0.065	2.852	0.178
04/03/2014	1.108	0.069	1.089	0.068	1.105	0.069	2.906	0.182
04/02/2014	1.278	0.080	1.304	0.081	1.325	0.083	2.860	0.179
04/01/2014	1.256	0.079	1.282	0.080	1.304	0.082	3.115	0.195
03/31/2014	1.282	0.080	1.317	0.082	1.330	0.083	2.316	0.145
03/30/2014	1.269	0.079	1.344	0.084	1.349	0.084	2.196	0.137
03/29/2014	1.237	0.077	1.321	0.083	1.321	0.083	2.344	0.146
03/28/2014	1.249	0.078	1.214	0.076	1.218	0.076	2.374	0.148
03/27/2014	1.265	0.079	1.216	0.076	1.227	0.077	2.035	0.127
03/26/2014	1.250	0.078	1.313	0.082	1.318	0.082	1.609	0.101
03/25/2014	1.230	0.077	1.300	0.081	1.319	0.082	1.528	0.096
03/24/2014	1.336	0.084	1.434	0.090	1.449	0.091	2.531	0.158
03/23/2014	1.272	0.080	1.389	0.087	1.394	0.087	3.638	0.227
03/22/2014	1.287	0.080	1.308	0.082	1.321	0.083	3.780	0.236
03/21/2014	1.325	0.083	1.358	0.085	1.368	0.086	3.729	0.233
03/20/2014	1.365	0.085	1.377	0.086	1.392	0.087	3.450	0.216
03/19/2014	1.333	0.083	1.354	0.085	1.356	0.085	2.642	0.165



Total Sulfur Previous Day

04/28/2014 08:00 AM

Florida Gas Transmission

	Perry 36" Stream #1		Perry 30" Stream #2		Perry 24" Stream #3		Brooker 24" Stream	
Gas Day	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf
03/18/2014	1.273	0.080	1.275	0.080	1.281	0.080	2.892	0.181
03/17/2014	1.235	0.077	1.251	0.078	1.245	0.078	2.502	0.156
03/16/2014	1.364	0.085	1.366	0.085	1.379	0.086	2.553	0.160
03/15/2014	1.344	0.084	1.348	0.084	1.359	0.085	2.444	0.153
03/14/2014	1.421	0.089	1.405	0.088	1.417	0.089	2.102	0.131
03/13/2014	1.765	0.110	1.731	0.108	1.740	0.109	1.061	0.066
03/12/2014	1.340	0.084	1.292	0.081	1.326	0.083	0.023	0.001
03/11/2014	1.322	0.083	1.344	0.084	1.358	0.085	0.029	0.002
03/10/2014	315.600	19.725	118.010	7.376	304.890	19.056	0.026	0.002
03/09/2014	3814.328	238.396	3913.751	244.609	4009.173	250.573	1.357	0.085
03/08/2014	1.302	0.081	1.267	0.079	1.278	0.080	1.369	0.086
03/07/2014	1.198	0.075	1.143	0.071	1.136	0.071	1.640	0.103
03/06/2014	1.120	0.070	1.026	0.064	1.015	0.063	1.667	0.104
03/05/2014	1.221	0.076	1.083	0.068	1.078	0.067	1.700	0.106
03/04/2014	1.181	0.074	1.089	0.068	1.086	0.068	1.802	0.113
03/03/2014	1.148	0.072	1.086	0.068	1.093	0.068	2.490	0.156
03/02/2014	1.200	0.075	1.082	0.068	1.093	0.068	2.449	0.153
03/01/2014	1.228	0.077	1.107	0.069	1.103	0.069	3.750	0.234
02/28/2014	1.094	0.068	1.020	0.064	1.025	0.064	3.018	0.189
02/27/2014	1.062	0.066	1.067	0.067	1.061	0.066	2.611	0.163
02/26/2014	1.088	0.068	1.107	0.069	1.099	0.069	3.361	0.210
02/25/2014	1.084	0.068	1.083	0.068	1.093	0.068	3.112	0.195
02/24/2014	1.054	0.066	1.071	0.067	1.078	0.067	2.335	0.146
02/23/2014	1.057	0.066	1.089	0.068	1.077	0.067	2.339	0.146
02/22/2014	1.099	0.069	1.071	0.067	1.077	0.067	2.871	0.179
02/21/2014	1.129	0.071	1.068	0.067	1.088	0.068	3.102	0.194
02/20/2014	1.167	0.073	1.143	0.071	1.148	0.072	3.241	0.203
02/19/2014	1.071	0.067	1.052	0.066	1.066	0.067	2.738	0.171
02/18/2014	1.148	0.072	1.104	0.069	1.117	0.070	2.491	0.156
02/17/2014	1.138	0.071	1.085	0.068	1.090	0.068	1.909	0.119
02/16/2014	1.104	0.069	0.985	0.062	0.989	0.062	1.665	0.104
02/15/2014	0.987	0.062	0.829	0.052	0.830	0.052	1.443	0.090
02/14/2014	1.046	0.065	0.871	0.054	0.869	0.054	1.578	0.099
02/13/2014	0.916	0.057	0.757	0.047	0.750	0.047	1.212	0.076
02/12/2014	1.031	0.064	0.945	0.059	0.942	0.059	1.555	0.097
02/11/2014	1.094	0.068	1.022	0.064	1.030	0.064	2.404	0.150
02/10/2014	1.056	0.066	0.941	0.059	0.943	0.059	2.898	0.181
02/09/2014	0.891	0.056	0.847	0.053	0.849	0.053	2.688	0.168
02/08/2014	0.989	0.062	0.919	0.057	0.924	0.058	2.692	0.168
02/07/2014	1.205	0.075	1.145	0.072	1.153	0.072	2.787	0.174
02/06/2014	0.830	0.052	0.802	0.050	0.799	0.050	2.492	0.156
02/05/2014	0.894	0.056	0.879	0.055	0.884	0.055	2.250	0.141
02/04/2014	0.871	0.054	0.834	0.052	0.845	0.053	2.428	0.152
02/03/2014	0.850	0.053	0.841	0.053	0.854	0.053	1.823	0.114
02/02/2014	0.847	0.053	0.834	0.052	0.843	0.053	0.023	0.001
02/01/2014	0.850	0.053	0.852	0.053	0.867	0.054	0.023	0.001



Total Sulfur Previous Day

04/28/2014 08:00 AM

Florida Gas Transmission

	Perry 36" Stream #1		Perry 30" Stream #2		Perry 24" Stream #3		Brooker 24" Stream	
Gas Day	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf	Avg ppm	Avg Grains/hcf
01/31/2014	0.831	0.052	0.822	0.051	0.831	0.052	0.024	0.002
01/30/2014	0.837	0.052	0.794	0.050	0.788	0.049	0.014	0.001
01/29/2014	0.792	0.049	0.782	0.049	0.774	0.048	0.012	0.001
01/28/2014	0.794	0.050	0.787	0.049	0.783	0.049	0.023	0.001
01/27/2014	0.795	0.050	0.784	0.049	0.792	0.049	0.030	0.002
01/26/2014	0.745	0.047	0.717	0.045	0.724	0.045	0.020	0.001
01/25/2014	0.661	0.041	0.639	0.040	0.643	0.040	0.025	0.002
01/24/2014	0.761	0.048	0.723	0.045	0.730	0.046	0.020	0.001
01/23/2014	0.863	0.054	0.801	0.050	0.807	0.050	0.017	0.001

Inspectorate
 4350 Oakes Road, Suite 521 A
 Davie, Florida 33314 USA
 T:954-525-1196
 F:954-525-5097



INSPECTORATE

ISO 9001:2008 Certified

Certificate of Analysis

Vessel / Shore Tank: **TANK# 7**
 Product: **Ultra Low Sulfur Diesel**
 Client Reference: **131101**
 Terminal / Port: **TPSI SOUTH - PORT EVERGLADES**
 Job ID: **2013-041-00886**


Sample Submitted By : **IAC Fort Lauderdale**
 Analysis Performed By : **IAC Fort Lauderdale**
 Date Sampled : **18-Nov-2013**
 Date Reported : **20-Nov-2013**
 Submission ID : **2013-041-00886**

Comments :

2013-041-00886-001			
Method	Test	Result	
ASTM D4052	API Gravity	33.5	
ASTM D93 Proc A	Automated / Manual	Manual	
	Flash Point, ° F	144	
ASTM D86	Distillation, Recovered	----	
	Observed Barometric Pressure, mm Hg	761	
	Initial Boiling Point, ° F	332.9	
	10% Recovered, ° F	408.8	
	20% Recovered, ° F	448.1	
	50% Recovered, ° F	524.0	
	90% Recovered, ° F	625.9	
	Endpoint, ° F	667.4	
ASTM D-5191	RVP	<1	
-----	Visual Color	Undyed	
ASTM D445	Viscosity, cSt @ 37.8 C	3.192	
ASTM D2161	Viscosity, SUS @ 37.8 C	36.6	
ASTM D97	Pour Point, Deg C	-18	
ASTM D130	Corrosion, 3 Hrs @50 C	1a	
ASTM D7039	Total Sulfur, ppm	8.6	
ASTM D482	Ash, Wt%	<0.001	
ASTM D4530	MCRT on 10% Bottom, Wt%	<0.1	
ASTM D95	Water by Distillation, Vol %	0.00	
ASTM D473	Sediment by Extraction, Wt%	0	
ASTM D-4868	Gross Heat of combustion, BTU/lb	19547	
	Gross Heat of combustion, BTU/gal	139572	
ASTM D-6217	Particulate Contamination, mg/L	5.0	
	Sample Volume, ml	1000	
ASTM D6468	Aging Time	90 Minutes	
	Pad Rating	B-1	
	Aged color	L1.0	
	Reflection Pad Rating %	98	
IAC-002	Calcium, ppm	<1	
	Potassium, ppm	<1	
	Sodium, ppm	<1	
	Lead, ppm	<1	
	Vanadium, ppm	<1	
ASTM D-4737 Proc A	Cetane Index	44.7	
	Filtered	No	
ASTM D-5291 - A *	Carbon , Mass%	88.14	
	Hydrogen, Mass %	11.81	
	Nitrogen, Mass%	0.02	

* TEST PERFORMED BY OUTSIDE LAB

For Inspectorate:


 Yvonne Fernandez-Chemist, Laboratory Manager

ATTACHMENT RBEC-EU1-I3
DETAILED DESCRIPTION OF CONTROL EQUIPMENT

SECTION 1 - INTRODUCTION

The Selective Catalytic Reduction (SCR) System described in this manual is designed to reduce oxides of Nitrogen (NO_x) from combustion turbine exhaust gases. As the exhaust gas mixes with ammonia and flows over a catalyst bed, the NO_x is reduced to Nitrogen (N_2) gas and water (H_2O) vapor.

The NO_x reduction system is commonly termed selective catalytic reduction (SCR), and requires ammonia as a reducing agent. Aqueous ammonia is supplied to the SCR system, and vaporized by a high temperature exhaust gas in a packed tower. The mixture of ammonia and exhaust, or process gas, is injected upstream of the SCR catalyst bed. As the gas flows through the catalyst bed, a chemical reaction occurs and reduces the NO_x emissions.

NOTES:

1. Six (6) units are required:
 - Three (3) for Cape Canaveral E.C. (PMC SO# 206382)
 - Three (3) for Riviera Beach E.C. (PMC SO# 206383)

DESIGN BASIS

A. Performance:	
Combustion Turbine Type	Siemens SGT6-8000H
Outlet NOx (Natural Gas)	25 ppmvd @ 15% O ₂
(Distillate)	42 ppmvd @ 15% O ₂
Max. Exhaust Flow (Natural Gas)	5,436,226 lb/hr
(Distillate)	5,519,879 lb/hr
Stack NOx (Natural Gas)	2.0 ppmvd @ 15% O ₂
(Distillate)	8.0 ppmvd @ 15% O ₂
Stack NH ₃	5.0 ppmvd @ 15% O ₂
Ammonia Consumption (19% by weight)	
Skid capacity	975 lb/hr
Dilution Air	6,585 ACFM @ 32" w.c. SP
B. Site Conditions:	
Location	Cape Canaveral & Riviera Beach, FL
Elevation	12 ft
Ambient Temperature Range	19 – 103°F
Design Criteria	
Building Code	IBC 2006
Electrical Classification	Class 1, Group D, Div. 2, NEMA 4
Utilities Available	
Control	120 VAC
Motor Power	460 Volt, 3 Phase, 60 Hz
Aqueous Ammonia	40 psig (minimum)
Instrument Air	60-125 psig (@ 20-100°F)

SYSTEM DESCRIPTION

I. AMMONIA SUPPLY

Technical grade ammonia (99.5% or higher in purity with a impurity content of 0.2%) mixed with de-ionized water to a concentration of approximately 19% by weight is required for this system. Ammonia storage equipment is furnished by others.

II. EQUIPMENT

The SCR system is composed of the following items:

- A. Each turbine has a dedicated ammonia flow control unit (AFCU). Aqueous ammonia is supplied to the AFCU skid at 40 PSIG and ambient temperature. Two fans, a primary and secondary, are used to direct the gas through the skid and distribution piping. They are designed to provide 6585 ACFM each with a static pressure gain of 32" w.c. SP.
- B. The process gas, a combination of exhaust gas and vaporized ammonia, is distributed from the AFCU skid through the interconnecting piping to the manifold and AIG assemblies. The gas is then injected with ammonia upstream of the internal structure frame containing the catalyst modules (provided by others).

III. CONTROL

Wiring for instrumentation is terminated in a junction box (YCCF-JB-X001) located on the AFCU skid. Control of the SCR system is achieved through a DCS system (supplied by others).

ATTACHMENT RBEC-EU1-I4
PROCEDURES FOR STARTUP AND SHUTDOWN

ATTACHMENT RBEC-EU1-I4

PROCEDURES FOR STARTUP/SHUTDOWN/MALFUNCTION/DLN TUNING

Startup for the combustion turbine (CT)/heat recovery steam generator (HRSG) system begins with an electric control system using a switch to initiate the unit startup cycle. A period of several hours is required to allow metal temperatures in the HRSG and in the steam turbine to equilibrate without undue metal stress, before putting the unit “on the line” and sending electric power to the grid.

The CTs can be started on either natural gas or distillate fuel oil. The CTs utilize Dry Low-NO_x (DLN) combustion technology during natural gas firing and water injection during oil firing to reduce emissions of nitrogen oxides (NO_x). Since this may occur multiple times in any 24-hour period an allowance for excess emissions is necessary. A selective catalytic reduction (SCR) system is also used to further reduce NO_x emissions. During startups, the SCR system requires specific temperatures to be effective that requires extended periods of non-operation. In addition, the combustion turbines require periodic tuning of the combustion and DLN system to assure proper operation. This results in periods where excess emission could occur. To accommodate these necessary operating conditions, the following are the conditions of Final Permit No. 0990042-007-AC related to opacity, excess emissions, and DLN tuning during these conditions.

Alternate Visible Emissions Standard: Visible emissions due to startups, shutdowns, fuel switches and malfunctions shall not exceed 10% opacity except for up to ten, 6-minute averaging periods during a calendar day, which shall not exceed 20% opacity.

Excess Emissions Allowed: As specified in this condition, excess emissions resulting from startup, shutdown, fuel switches, and documented malfunctions are allowed provided that operators employ best operational practices to minimize the amount and duration of emissions during such incidents.

For each gas turbine/HRSG system, excess emissions of NO_x and CO resulting from startup, shutdown, or malfunction shall be excluded from CEMS data in any 24-hour period (“any 24-hour period” means a calendar day, midnight to midnight) for the following conditions (these conditions are considered separate events and each event may occur independently within any 24-hour period):

- *Steam Turbine Cold Startup:* For cold startup of the steam turbine, excluded emissions from any gas turbine/HRSG system shall not exceed 12 hours for the first CD and shall not exceed no more than 8 hours for subsequent CTs in any 24-hour period. A cold “startup of the steam turbine system” is defined as startup of the 3-on-1 combined cycle system following a shutdown of the steam turbine lasting at least 48 hours.
- *Shutdown Combined Cycle Operation:* For shutdown of combined cycle operation, excluded emissions from any CTG/HRSG system shall not exceed three (3) hours in any 24-hour period.

- *CTG /HRSG System Cold Startup:* For cold startup of a CTG/HRSG system, excluded emissions shall not exceed four (4) hours in any 24-hour period. "Cold startup of a CTG /HRSG system" is defined as a startup after the pressure in the high-pressure (HP) steam drum falls below 450 pounds per square inch gauge (psig) for at least a one-hour period.
- *Fuel Switching:* For fuel switching, excluded emissions shall not exceed 2 hours in any 24-hour period for each fuel switch and no more than four hours in any 24-hour period for any CTG/HRSG system. This provision applies to each individual CTG/HRSG system.
- *CTG/HRSG System Warm Startup:* For warm startup of a CTG/HRSG system, excluded emissions shall not exceed two hours in any 24-hour period. "Warm startup of a CTG/HRSG system" is defined as a startup after the pressure in the high-pressure (HP) steam drum is above 450 psig.
- *CTG/HRSG System Shutdown:* For shutdown of the CTG/HRSG operation, excluded emissions from any CTG/HRSG system shall not exceed two hours in any 24-hour period.
- *Documented Malfunction:* For the CTG/HRSG system, excess emissions of NOX and CO resulting from documented malfunctions shall not exceed two hours in any 24-hour period. A "documented malfunction" means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic mail.

DLN Tuning: CEMS data collected during initial or other major DLN tuning sessions and during manufacturer required Full Speed No Load (FSNL) trip tests may be excluded by the permittee from the CEMS compliance demonstration provided the tuning session is performed in accordance with the manufacturer's specifications. A "major tuning session" may occur after completion of initial construction, a major repair or other similar circumstances. Prior to performing any major tuning session, where the intent is to exclude data from the CEMS compliance demonstration, the permittee shall provide the Compliance Authority with an advance notice of at least one working (business) day that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail.

Shutdown is performed by reducing the unit load (electrical production) to a minimum level, opening the breaker (which disconnects the unit generator from the system electrical grid), shutting off the fuel, and coasting to a stop.

ATTACHMENT RBEC-EU1-16
COMPLIANCE DEMONSTRATION REPORTS



April 23, 2014

James Stormer
Division of Environmental Public Health
Air and Waste Program
Palm Beach County – Department of Health
800 Clematis St., 4th Floor
West Palm Beach, Florida 33401

RE: Florida Power & Light Company
Riviera Beach Energy Center
Regulatory Required Submittal
Air Construction Permit No. 0990042-007-AC

Dear Mr. Stormer:

Florida Power & Light Company (FPL) is submitting the CEMS Certification Report for each unit (5A, 5B, 5C), which includes the Emissions Performance Test Reports per the requirements of 40 CFR Part 60 and 40 CFR Part 75. Also included in this submittal are the Emissions Compliance Test Reports for each unit (5A, 5B, 5C) per the requirements of 40 CFR Part 75. FPL would also like to provide the updated testing and first fire dates on fuel oil for the remaining Units.

Table I. Dates for start-up activities using ULSD at Riviera Beach Energy Center Unit 5.

Units	First Fire Date	Performance Emission Test	Opacity Observations
CT 5A	April 9, 2014	April 22, 2014	April 22, 2014
CT 5B	April 29, 2014	May 13, 2014	May 13, 2014
CT 5C	May 18, 2014	June 1, 2014	June 1, 2014
40CFR Part 60 Req.		60.8(d)& PSD Permit	60.7(a)(6), 60.11(b)& 60.7(a)(7)
Bold lettering indicates actual dates			

If you have any comments or questions regarding the attached, please feel free to contact me at 561-691-2781 or Kristin Peekstok at 561-691-7132.

I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made.

I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Sincerely,
Florida Power & Light Company



Christian Kiernan
Florida Power & Light
Technical Services General Manager
Designated Representative

Cc (by email): Rich Merrill, FPL Ingrid Nickolaus, FPL Syed Arif, FDEP
Ashley Pinnock, FPL Tim Bryant, FPL FDEP-SED Air Program
Steve Coombe, FPL Wil Rosario, FPL Laxmana Tallam, PBCDOH
Dave McNeal, EPA Paul Kalamaras, PBCDOH

SUMMARY OF SIEMENS, 8000H, UNIT #5A RESULTS

Parameter	Base w/DB Load	Base w/DB Permit Limits	Base Load	Base Load Permit Limits
Date (mm/dd/yy)	03/04/14	--	03/04/14	--
Start Time (hh:mm:ss)	9:45:29	--	16:46:29	--
End Time (hh:mm:ss)	14:15:59	--	20:07:59	--
Run Duration (min / run)	84	--	60	--
Bar. Pressure (in. Hg)	30.03	--	29.97	--
Amb. Temp. (°F)	76	--	77	--
Rel. Humidity (%)	69	--	68	--
Spec. Humidity (lb water / lb air)	0.013120	--	0.013340	--
Load Designator	Base w/DB	--	Base	--
Turbine Fuel Flow (lb/min)	1,847	--	1,854	--
Duct Burner Fuel Flow (lb/min)	186	--	0	--
Total Fuel Flow (lb/min)	2,033	--	1,854	--
Stack Flow (RM19) (SCFH)	41,958	--	42,867	--
Stack Moisture (% Method 4 or 320)	8.9	--	8.9	--
Heat Input (MMBtu/hr)	2,801.8	--	2,555.7	--
Power Output (megawatts)	257.2	--	256.2	--
NH ₃ Injection Flow (lb/hr)	415.42	--	448.52	--
NO _x (ppm@15%O ₂)	1.83	2.0	1.75	2.0
NO _x (lb/hr)	0.01	22.8	0.01	19.3
CO (ppm@15%O ₂)	0.16	7.6	0.16	5.0
CO (lb/hr)	0.00	52.7	0.00	29.0
THC as CH ₄ (ppm@15%O ₂)	0.00	--	0.04	--
THC as CH ₄ (lb/hr)	0.00	--	0.00	--
VOC as CH ₄ (ppm@15%O ₂)	0.00	1.9	0.02	1.5
VOC as CH ₄ (lb/hr)	0.00	7.2	0.00	4.8
NH ₃ (ppm@15%O ₂)	0.34	5	0.67	5
Opacity (%)	0	10	0	10
O ₂ (%)	12.13	--	13.07	--

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol.

SUMMARY OF SIEMENS, 8000H, UNIT #5B RESULTS

Parameter	Base w/DB Load	Base w/DB Permit Limits	Base Load	Base Load Permit Limits
Date (mm/dd/yy)	03/04/14	--	03/04/14	--
Start Time (hh:mm:ss)	10:54:03	--	16:46:03	--
End Time (hh:mm:ss)	15:15:33	--	20:07:33	--
Run Duration (min / run)	81	--	60	--
Bar. Pressure (in. Hg)	30.01	--	29.97	--
Amb. Temp. (°F)	76	--	77	--
Rel. Humidity (%)	68	--	68	--
Spec. Humidity (lb water / lb air)	0.012956	--	0.013340	--
Load Designator	Base w/DB	--	Base	--
Turbine Fuel Flow (lb/min)	1,784	--	1,804	--
Duct Burner Fuel Flow (lb/min)	183	--	0	--
Total Fuel Flow (lb/min)	1,967	--	1,804	--
Stack Flow (RM19) (SCFH)	40,781	--	41,302	--
Stack Moisture (% Method 4 or 320)	8.7	--	8.7	--
Heat Input (MMBtu/hr)	2,711.0	--	2,485.8	--
Power Output (megawatts)	257.7	--	258.0	--
NH ₃ Injection Flow (lb/hr)	401.89	--	428.37	--
NO _x (ppm@15%O ₂)	1.72	2.0	1.65	2.0
NO _x (lb/hr)	0.01	22.8	0.01	19.3
CO (ppm@15%O ₂)	0.51	7.6	0.68	5.0
CO (lb/hr)	0.00	52.7	0.00	29.0
THC as CH ₄ (ppm@15%O ₂)	0.02	--	0.07	--
THC as CH ₄ (lb/hr)	0.00	--	0.00	--
VOC as CH ₄ (ppm@15%O ₂)	0.00	1.9	0.04	1.5
VOC as CH ₄ (lb/hr)	0.00	7.2	0.00	4.8
NH ₃ (ppm@15%O ₂)	0.61	5	0.56	5
Opacity (%)	0	10	0	10
O ₂ (%)	12.17	--	13.00	--

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol.

SUMMARY OF SIEMENS, 8000H, UNIT #5C RESULTS

Parameter	Base w/DB Load	Base w/DB Permit Limits	Base Load	Base Load Permit Limits
Date (mm/dd/yy)	03/04/14	--	03/04/14	--
Start Time (hh:mm:ss)	9:45:12	--	16:46:12	--
End Time (hh:mm:ss)	14:15:42	--	20:07:42	--
Run Duration (min / run)	84	--	60	--
Bar. Pressure (in. Hg)	30.02	--	29.97	--
Amb. Temp. (°F)	76	--	77	--
Rel. Humidity (%)	69	--	68	--
Spec. Humidity (lb water / lb air)	0.013219	--	0.013340	--
Load Designator	Base w/DB	--	Base	--
Turbine Fuel Flow (lb/min)	1,826	--	1,831	--
Duct Burner Fuel Flow (lb/min)	186	--	0	--
Total Fuel Flow (lb/min)	2,012	--	1,831	--
Stack Flow (RM19) (SCFH)	41,515	--	42,078	--
Stack Moisture (% Method 4 or 320)	10.3	--	9.7	--
Heat Input (MMBtu/hr)	2,773.0	--	2,522.8	--
Power Output (megawatts)	259.9	--	258.3	--
NH ₃ Injection Flow (lb/hr)	593.56	--	619.86	--
NO _x (ppm@15%O ₂)	1.89	2.0	1.78	2.0
NO _x (lb/hr)	0.01	22.8	0.01	19.3
CO (ppm@15%O ₂)	0.32	7.6	0.45	5.0
CO (lb/hr)	0.00	52.7	0.00	29.0
THC as CH ₄ (ppm@15%O ₂)	0.09	--	0.06	--
THC as CH ₄ (lb/hr)	0.00	--	0.00	--
VOC as CH ₄ (ppm@15%O ₂)	0.08	1.9	0.05	1.5
VOC as CH ₄ (lb/hr)	0.00	7.2	0.00	4.8
NH ₃ (ppm@15%O ₂)	1.00	5	3.37	5
Opacity (%)	0	10	0	10
O ₂ (%)	12.13	--	13.03	--

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol.

ATTACHMENT RBEC-EU1-IV1
IDENTIFICATION OF APPLICABLE REQUIREMENTS



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blairstone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor
Jeff Kottkamp
Lt. Governor
Michael W. Sole
Secretary

PERMITTEE:

Florida Power and Light Company (FPL)
700 Universe Boulevard
Juno Beach, Florida 33408

Authorized Representative:

Randall R. LaBauve, Vice President

DEP File No. 0990042-006-AC
FPL Riviera Beach Energy Center
Plant Conversion Project
Palm Beach County
SIC No. 4911
Expires: December 31, 2015

PROJECT AND LOCATION

This permit authorizes the construction of one nominal 1,250 megawatts (MW) combined cycle unit and ancillary equipment at the FPL Riviera Beach Energy Center previously known as the Riviera Plant.

Two existing steam generators with a total nominal capacity of 600 MW will be shut down and dismantled as part of this project.

The proposed project will be located at 200-300 Broadway, Riviera Beach in Palm Beach County. The UTM coordinates are Zone 17, 594.249 km East and 2960.632 km North.

STATEMENT OF BASIS


This air construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297 of the Florida Administrative Code (F.A.C.). The permittee is authorized to install the proposed equipment in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department.

CONTENTS

- Section I. General Information
- Section II. Administrative Requirements
- Section III. Emissions Units Specific Conditions
- Section IV. Appendices



Joseph Kahn, Director
Division of Air Resource Management



(Date)

SECTION I. GENERAL INFORMATION

FACILITY DESCRIPTION

FPL operates the Riviera Plant (RP), which is an existing power plant (SIC No. 4911). The plant currently consists of two steam generating units designated as Units 3 and 4 that produce 300 MW each of electrical power. Units 3 and 4 use residual fuel oil and natural gas. There are two 298-foot stacks, four fuel oil storage tanks, water intake structures for once-through cooling and other ancillary equipment.

The project is a plant conversion that includes the construction of a nominal 1,250 MW natural gas-fueled combined cycle unit (Unit 5) and requires the permanent shutdown and dismantling of Units 3 and 4. The converted plant will be called the Riviera Beach Energy Center (RBEC). Unit 5 will consist of:

- Three nominal 265 MW combustion turbine-electrical generators (CTG) with evaporative inlet cooling systems;
- Three supplementary-fired heat recovery steam generators (HRSG) with selective catalytic reduction (SCR) reactors;
- Three maximum 460 million Btu per hour, lower heating value (mmBtu/hr, LHV), natural gas-fueled duct burners (DB) located in the three HRSG (one DB/HRSG);
- Three 149-foot exhaust stacks;
- One nominal 6.3 million gallon distillate fuel oil storage tank; and
- One common nominal 500 MW steam-electrical generator (STG).

Unit 5 will use ultralow sulfur distillate (ULSD) fuel oil as backup fuel.

Additional ancillary equipment to be installed includes: a permanent auxiliary boiler; a temporary boiler used during the construction phase; two emergency generators; two process (fuel) heaters; a diesel fire pump; and a gas compression station. The details of the equipment to be installed are listed in the table below.

The project includes and requires the permanent shutdown and dismantling of Units 3 and 4 and the respective stacks as well as four fuel oil storage tanks. When emissions from Unit 5 are considered and offset by reductions from the shut down and dismantlement of Units 3 and 4, there will not be a significant net emission increase in any PSD pollutant.

{Note: Throughout this permit, the electrical generating capacities represent nominal values for the given operating conditions.}

NEW EMISSIONS UNITS

This permit authorizes construction and installation of the following new emissions units.

ID	Emission Unit Description
007	Unit 5A – one nominal 265 MW CTG with supplementary-fired HRSG
008	Unit 5B – one nominal 265 MW CTG with supplementary-fired HRSG
009	Unit 5C – one nominal 265 MW CTG with supplementary-fired HRSG
010	One nominal 85,000 pounds per hour (lb/hr) auxiliary boiler (99.8 mmBtu/hr)
011	Two nominal 10 mmBtu/hr natural gas-fired process heaters (one is a spare)
012	Seven nominal 1,340 horsepower (hp) natural gas compressors
013	Two nominal 2,250 kilowatts (kW) liquid fueled emergency generators
014	One nominal 300-hp emergency diesel fire pump engine and 500 gallon fuel oil storage tank
015	One temporary 110 mmBtu/hr natural gas-fueled boiler to be used only during construction
016	One nominal 6.3 million gallon distillate fuel oil storage tank

SECTION I. GENERAL INFORMATION

REGULATORY CLASSIFICATION

The RP is a “Major Stationary Source” as defined in Rule 62-210.200, Florida Administrative Code (F.A.C.). The RBEC project does not trigger the rules for the Prevention of Significant Deterioration (PSD) pursuant to Rule 62-212.400, F.A.C. and does not require a best available control technology (BACT) determination.

The RBEC will be a Title V or “Major Source” of air pollution in accordance with Chapter 213, F.A.C. because the potential emissions of at least one regulated pollutant exceed 100 tons per year (TPY). Regulated pollutants include pollutants such as carbon monoxide (CO), nitrogen oxides (NO_x), particulate matter (PM/PM₁₀/PM_{2.5}), sulfur dioxide (SO₂), volatile organic compounds (VOC) and sulfuric acid mist (SAM).

The RBEC will be subject to several subparts under 40 Code of Federal Regulations (CFR), Part 60 – Standards of Performance for New Stationary Sources (NSPS). Unit 5 is subject to 40 CFR 60, Subpart KKKK – NSPS for Stationary Combustion Turbines that Commence Construction after February 18, 2005. This rule also applies to duct burners (DB) that are incorporated into combined cycle projects.

Two emergency generators will be subject to 40 CFR 60, Subpart IIII – NSPS for Stationary Compression Ignition Internal Combustion Engines.

Natural gas compressors will be subject to 40 CFR 60, Subpart JJJJ – NSPS for Stationary Spark Ignition Internal Combustion Engines.

The temporary natural gas-fueled boiler will be subject to 40 CFR 60, Subpart Db – NSPS for Industrial-Commercial-Institutional Steam Generating Units.

The auxiliary boiler and two process (fuel) heaters will be subject to 40 CFR 60, Subpart Dc – NSPS Requirements for Small Industrial-Commercial-Institutional Steam Generating Units.

The RBEC will be a minor (area source) of hazardous air pollutants (HAP). The RBEC will include emission units that will be subject to certain area source provisions of 40 CFR Part 63 - National Emission Standards for Hazardous Air Pollutants (NESHAP). The specific subpart is 40 CFR 63, Subpart ZZZZ – NESHAP for Stationary Reciprocating Internal Combustion Engines (RICE).

The RBEC will operate units subject to the Title IV Acid Rain provisions of the Clean Air Act (CAA).

The RBEC is subject to the Clean Air Interstate Rule (CAIR) in accordance with the Final Department Rules issued pursuant to CAIR as implemented by the Department in Rule 62-296.470, F.A.C.

The project is subject to certification under the Florida Power Plant Siting Act, 403.501-518, Florida Statutes (F.S.) and Chapter 62-17, F.A.C.

APPENDICES

The following Appendices are attached as part of this permit.

Appendix A: Identification of General Provisions Subpart A from NSPS 40 CFR 60 and Subpart A from NESHAP 40 CFR 63.

Appendix GC: General Conditions.

Appendix Db: NSPS Subpart Db Requirements for Industrial-Commercial-Institutional Steam Generating Units.

Appendix Dc: NSPS Subpart Dc Requirements for Small Industrial Commercial-Institutional Steam Generating Units.

Appendix IIII: NSPS Requirements for Compression Ignition Internal Combustion Engines.

Appendix JJJJ: NSPS Requirements for Stationary Spark Ignition Internal Combustion Engines.

Appendix KKKK: NSPS Requirements for Gas Turbines, 40 CFR 60, Subpart KKKK.

Appendix SC: Standard Conditions.

Appendix XS: Semiannual NSPS Excess Emissions Report.

Appendix ZZZZ: NESHAP Requirements for Stationary Reciprocating Internal Combustion Engines, 40 CFR 63, Subpart ZZZZ.

SECTION I. GENERAL INFORMATION

RELEVANT DOCUMENTS

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action and are on file with the Department.

- Permit application received on February 13, 2009;
- Department request for additional information (RAI) dated March 13, 2009;
- Electronic mail dated April 13, 2009 summarizing resolution of key RAI issue; and
- Draft permit package issued on April 17, 2009.
- Final Determination summarizing FPL comments and responses thereto issued concurrently with this Final permit.

SECTION II. ADMINISTRATIVE REQUIREMENTS

1. Permitting Authority: All documents related to applications for permits to construct, operate or modify an emissions unit shall be submitted to the Permitting Authority, which is the Bureau of Air Regulation of the Florida Department of Environmental Protection (DEP or the Department) at 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. Copies of all such documents shall also be submitted to the Compliance Authority. Telephone: (850)488-0114. Fax: (850)921-9533.
2. Compliance Authority: All documents related to compliance activities such as reports, tests, and notifications shall be submitted to the Southeast District Office. The mailing address and phone number of the Southeast District Office are Department of Environmental Protection, Southeast District Office, 400 North Congress Avenue, Suite 200, West Palm Beach, Florida 33401. Telephone: (561)681-6632. Fax: (561)681-6790.
3. Appendices: The following Appendices are attached as part of this permit: Appendices A, Db, Dc, GC (General Conditions), IIII, JJJJ, KKKK, SC, XS and ZZZZ.
4. Applicable Regulations, Forms and Application Procedures: Unless otherwise specified in this permit, the construction and operation of the subject emissions units shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of: Chapter 403, F.S.; and Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296, and 62-297, F.A.C. Issuance of this permit does not relieve the permittee from compliance with any applicable federal, state, or local permitting or regulations.
5. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
6. Modifications: No emissions unit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification. [Rules 62-210.300(1) and 62-212.300(1)(a), F.A.C.]
7. Construction and Expiration: The permit expiration date includes sufficient time to complete construction, perform required testing, submit test reports, and submit an application for a Title V operation permit to the Department. For good cause, the permittee may request that this air construction permit be extended. Such a request shall be submitted to the Department's Bureau of Air Regulation at least sixty (60) days prior to the expiration of this permit. [Rules 62-4.070(4), 62-4.080, and 62-210.300(1), F.A.C.]
8. Permanent Shutdown and Dismantlement of Units 3 and 4: Units 3 and 4 shall be permanently shut down and dismantled before December 31, 2012. [Application and Avoidance of Rule 62-212.400(4) through (12), F.A.C.]
9. Source Obligation: At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by virtue of a relaxation in any enforceable limitation which was established after August 7, 1980, on the capacity of the source or modification otherwise to emit a pollutant, such as a restriction on hours of operation, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification. [Rule 62-212.400(12)(b), F.A.C.]
10. Title IV Permit: At least 24 months before the date on which the new unit begins serving an electrical generator greater than 25 MW, the permittee shall submit an application for a Title IV Acid Rain Permit to the Department's Bureau of Air Regulation in Tallahassee and a copy to the Region 4 Office of the U.S. Environmental Protection Agency (EPA) in Atlanta, Georgia. This permit does not specify the Acid Rain program requirements. These will be included in the Title V air operation permit. [40 CFR 72]

SECTION II. ADMINISTRATIVE REQUIREMENTS

11. Title V Permit: This permit authorizes specific modifications and/or new construction on the affected emissions units as well as initial operation to determine compliance with conditions of this permit. A Title V operation permit is required for regular operation of the permitted emissions unit. The permittee shall apply for a Title V operation permit at least 90 days prior to expiration of this permit, but no later than 180 days after completing the required work and commencing operation. To apply for a Title V operation permit, the applicant shall submit the appropriate application form, compliance test results, and such additional information as the Department may by law require. The application shall be submitted to the Bureau of Air Regulation with copies to the Compliance Authority.
[Rules 62-4.030, 62-4.050, 62-4.220, and Chapter 62-213, F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

This section of the permit addresses the following emissions units.

Unit 5 and associated equipment

Description: Unit 5 will be comprised of emissions units (EU) 007, 008, and 009. Each EU will consist of: a CTG with automated control, inlet air filtration system and evaporative cooling, a gas-fired HRSG with DB, a HRSG stack, and associated support equipment. The project also includes one STG that will serve the combined cycle unit.

Fuels: Each CTG fires natural gas as the primary fuel and ULSD fuel oil as a restricted alternate fuel.

Generating Capacity: Each of the three CTG has a nominal generating capacity of 265 MW. The STG has a nominal generating capacity of 500 MW. The total nominal generating capacity of the “3 on 1” combined cycle unit is approximately 1,250 MW.

Controls: The efficient combustion of natural gas and restricted firing of ULSD fuel oil minimizes the emissions of CO, PM/PM₁₀, SAM, SO₂ and VOC. Dry Low-NO_x (DLN) combustion technology for gas firing and water injection for oil firing reduce NO_x emissions. A SCR system further reduces NO_x emissions.

Stack Parameters: Each HRSG has a stack at least 149 feet tall with a nominal diameter of 22 feet. The Department may require the permittee to perform additional air dispersion modeling should the actual specified stack dimensions change.

Continuous Monitors: Each stack is equipped with continuous emissions monitoring systems (CEMS) to measure and record CO and NO_x emissions as well as flue gas oxygen or carbon dioxide content.

APPLICABLE STANDARDS AND REGULATIONS

1. **NSPS Requirements:** The CTG shall comply with all applicable requirements of 40 CFR 60, listed below, adopted by reference in Rule 62-204.800(7)(b), F.A.C. The Department determines that compliance with the emissions standards in Condition 10 below also assures compliance with the New Source Performance Standards given in 40 CFR 60, Subpart KKKK. Some separate reporting and monitoring may be required by the individual subparts.
 - a. *Subpart A, General Provisions*, including:
 - 40 CFR 60.7, Notification and Record Keeping
 - 40 CFR 60.8, Performance Tests
 - 40 CFR 60.11, Compliance with Standards and Maintenance Requirements
 - 40 CFR 60.12, Circumvention
 - 40 CFR 60.13, Monitoring Requirements
 - 40 CFR 60.19, General Notification and Reporting Requirements
 - b. *Subpart KKKK, Standards of Performance for Stationary Gas Turbines:* These provisions include standards for CTG and DB.

EQUIPMENT AND CONTROL TECHNOLOGY

2. **Combustion Turbines-Electrical Generators (CTG):** The permittee is authorized to install, tune, operate, and maintain three “G” or “H” technology CTG each with a nominal generating capacity of 265 MW. Each CTG shall include an automated control system and have dual-fuel capability. Ancillary equipment includes an inlet air filtration system and an evaporative inlet air-cooling system. The CTG will utilize DLN combustors. [Application and Design]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

3. Heat Recovery Steam Generators (HRSG): The permittee is authorized to install, operate, and maintain three new HRSG with separate exhaust stacks. Each HRSG shall be designed to recover exhaust heat energy from one of the three CTG (5A to 5C) and deliver steam to the steam turbine-electrical generator (STG). Each HRSG may be equipped with a gas-fired duct burner (DB) having a maximum heat input rate of 460 mmBtu per hour (LHV).
4. CTG/Supplementary-fired HRSG Emission Controls
 - a. *Dry Low NO_x (DLN) Combustion*: The permittee shall operate and maintain the DLN system to control NO_x emissions from each CTG when firing natural gas. Prior to the initial emissions performance tests required for each CTG, the DLN combustors and automated control system shall be tuned to achieve sufficiently low CO and NO_x values to meet the CO and NO_x limits with the additional SCR control technology described below. Thereafter, each turbine shall be maintained and tuned in accordance with the manufacturer's recommendations.
 - b. *Wet Injection (WI)*: The permittee shall install, operate, and maintain a WI system (water or steam) to reduce NO_x emissions from each CTG when firing ULSD fuel oil. Prior to the initial emissions performance tests required for each CTG, the WI system shall be tuned to achieve sufficiently low CO and NO_x values to meet the CO and NO_x limits with the additional SCR control technology described below. Thereafter, each turbine shall be maintained and tuned in accordance with the manufacturer's recommendations.
 - c. *Selective Catalytic Reduction (SCR) System*: The permittee shall install, tune, operate, and maintain an SCR system to control NO_x emissions from each CTG when firing either natural gas or distillate fuel oil. The SCR system consists of an ammonia (NH₃) injection grid, catalyst, ammonia storage, monitoring and control system, electrical, piping and other ancillary equipment. The SCR system shall be designed, constructed and operated to achieve the permitted levels for NO_x and NH₃ emissions.
 - d. *Oxidation Catalyst*: The permittee shall design and build the project to facilitate possible future installation of an oxidation catalyst system to control CO emissions from each CTG/supplementary-fired HRSG.
 - e. *Ammonia Storage*: In accordance with 40 CFR 60.130, the storage of ammonia shall comply with all applicable requirements of the Chemical Accident Prevention Provisions in 40 CFR 68.

[Application and Design; Rule 62-4.070, F.A.C.]

PERFORMANCE RESTRICTIONS

5. Permitted Capacity – Combustion Turbine-Electric Generators (CTG): The maximum heat input rate to each CTG is 2,586 mmBtu per hour when firing natural gas and 2,440 mmBtu per hour when firing distillate fuel oil (based on a compressor inlet air temperature of 59° F, LHV of each fuel, and 100% load). Heat input rates will vary depending upon CTG characteristics, ambient conditions, alternate methods of operation, and evaporative cooling. The permittee shall provide manufacturer's performance curves (or equations) that correct for site conditions to the Permitting and Compliance Authorities within 45 days of completing the initial compliance testing. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department.
[Rule 62-210.200(PTE), F.A.C.]
6. Permitted Capacity - HRSG Duct Burners (DB): The total maximum heat input rate to the DB for each HRSG is 460 mmBtu per hour based on the LHV of natural gas. Only natural gas shall be fired in the DB.
[Rule 62-210.200(PTE), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

7. **Authorized Fuels:** The CTG shall fire natural gas as the primary fuel, which shall contain no more than 2.0 grains of sulfur per 100 standard cubic feet (gr S/100 SCF) of natural gas. As a restricted alternate fuel, the CTG may fire ULSD fuel oil containing no more than 0.0015% sulfur by weight. Fuel oil may be fired up to the fuel equivalent of 2,550 hours aggregated over the three CTG during any calendar year.
[Rules 62-210.200(PTE), F.A.C.]
8. **Hours of Operation:** Subject to the operational restrictions of this permit, the CTG may operate throughout the year (8760 hours per year). Restrictions on individual methods of operation are specified below.
[Rules 62-210.200(Definitions - PTE), F.A.C.]
9. **Methods of Operation:** Subject to the restrictions and requirements of this permit, the CTG may operate under the following methods of operation.
 - a. **Combined Cycle Operation:** Each CTG/HRSG system may operate to produce direct, shaft-driven electrical power and steam-generated electrical power from the steam turbine-electrical generator as a three-on-one combined cycle unit subject to the restrictions of this permit. In accordance with the specifications of the SCR and HRSG manufacturers, the SCR system shall be on line and functioning properly during combined cycle operation or when the HRSG is producing steam.
 - b. **Inlet Conditioning:** In accordance with the manufacturer's recommendations and appropriate ambient conditions, the evaporative cooling system may be operated to reduce the compressor inlet air temperature and provide additional direct, shaft-driven electrical power.
 - c. **Duct Burner (DB) Firing:** When firing natural gas in a CTG, the respective HRSG may fire natural gas in the DB to raise additional steam for use in the STG or in the operation of CTG components. The total combined heat input rate to the DB (all three HRSG) shall not exceed 3,697,920 mmBtu (LHV) during any consecutive 12 months.

[Application; Rule 62-210.200(PTE), F.A.C.]

EMISSIONS STANDARDS

10. **Emissions Standards:** Emissions from each CTG/DB shall not exceed the following standards developed under state implementation plan (SIP) permitting procedures. Compliance with these limits also assures compliance with the emission limitations in 40 CFR 60, Subpart KKKK.

Pollutant	Fuel	Method of Operation	Initial Stacks Tests		CEMS Rolling Average Limit ppmvd ^a
			ppmvd ^a	lb/hr ^b	
CO ^d	Oil	CTG	10.0	61.0	10.0, 30 unit operating days ^{c,d}
	Gas	CTG & DB	7.6	52.7	7.5, 30 unit operating days ^{c,d}
CTG Normal Mode		5.0	29.0		
NO _x ^e	Oil	CTG	8.0	80.0	8.0, 30 unit operating days ^{c,e}
	Gas	CTG & DB	2.0	22.8	2.0, 30 unit operating days ^{c,e}
CTG Normal Mode		2.0	19.3		
VOC ^f	Oil	CTG	6.0	18.9	NA
	Gas	CTG & DB	1.9	7.2	
CTG Normal Mode		1.5	4.8		
NH ₃ ^g	Oil/Gas	CTG, All Modes	5	NA	NA
SAM/SO ₂ ^h	Oil/Gas	All Modes	2 gr S/100 SCF of gas, 0.0015% sulfur fuel oil Visible emissions shall not exceed 10% opacity for each 6-minute block average.		
PM/PM ₁₀ ⁱ					

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

- a. Concentration standards are given in terms of parts per million, by volume, dry at 15 percent oxygen and abbreviated as ppmvd.
- b. The mass emission rate standards in pounds per hour (lb/hr) are based on a turbine inlet condition of 59° F and may be adjusted to actual test conditions in accordance with the performance curves and/or equations filed with the Department.
- c. “Unit operating day” means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period. [40 CFR 60.4420]
- d. Compliance with the continuous 30-unit operating days rolling CO standard shall be demonstrated based on data collected by the required CEMS. The initial EPA Method 10 tests associated with the certification of the CEMS instruments shall also be used to demonstrate initial performance guarantees for natural gas, oil, and DB mode.
- e. Continuous compliance with the 30-unit operating days rolling NO_x standards shall be demonstrated based on data collected by the required CEMS and will also insure compliance with the less stringent Subpart KKKK limits of 15 and 42 ppmvd for gas and fuel oil respectively on a 30-unit operating day rolling average basis. The initial EPA Method 7E or Method 20 tests associated with demonstration of compliance with 40 CFR 60, Subpart KKKK or certification of the CEMS instruments shall also be used to demonstrate compliance with the individual standards for natural gas, fuel oil, and duct burner modes during the time of those tests. NO_x mass emission rates are defined as oxides of nitrogen expressed as nitrogen dioxide (NO₂).
- f. Compliance with the VOC standards shall be demonstrated by conducting tests in accordance with EPA Method 25A. Optionally, EPA Method 18 may also be performed to deduct emissions of methane and ethane. The emission standards are based on VOC measured as methane. After initial compliance with the VOC standards is demonstrated, annual compliance tests for VOC emissions are not required.
- g. Compliance with the NH₃ slip standard shall be demonstrated by conducting tests in accordance with EPA Method CTM-027 or EPA Method 320.
- h. The clean fuel sulfur specifications and visible emissions standard effectively limit the potential emissions of SAM and SO₂ from the CTG. Compliance with the fuel sulfur specifications shall be determined by the ASTM methods for determination of fuel sulfur as detailed in the draft permit.
- i. The clean fuel sulfur specifications, low CO and NO_x limits, and the visible emissions standard will effectively limit PM/PM₁₀/PM_{2.5} emissions. Compliance with the visible emissions standard shall be demonstrated by conducting tests in accordance with EPA Method 9.

[Application and Avoidance of Rule 62-212.400(4) through (12), F.A.C.; 40 CFR 60, Subpart KKKK]

EXCESS EMISSIONS

{Permitting Note: The following conditions apply only to the SIP-based emissions standards specified in Condition No. 10 of this section. Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal provision of the NSPS, or Acid Rain programs.}

11. Operating Procedures: The emission standards established by this permit rely on “good operating practices” to reduce emissions. Therefore, all operators and supervisors shall be properly trained to operate and maintain the CTG, DB, HRSG, and pollution control systems in accordance with the guidelines and procedures established by each manufacturer. The training shall include good operating practices as well as methods of minimizing excess emissions. [Rules 62-4.070(3), F.A.C.]
12. Alternate Visible Emissions Standard: Visible emissions due to startups, shutdowns, and malfunctions shall not exceed 10% opacity except for up to ten, 6-minute averaging periods during a calendar day, which shall not exceed 20% opacity. [Applicant Request and Rule 62-4.070(3), F.A.C.]
13. Definitions:
 - a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions. [Rule 62-210.200(245), F.A.C.]
 - b. *Shutdown* is the cessation of the operation of an emissions unit for any purpose. [Rule 62-210.200(230), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

- c. *Malfunction* is defined as any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner. [Rule 62-210.200(159), F.A.C.]
14. **Excess Emissions Prohibited:** Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.]
15. **Excess Emissions Allowed:** As specified in this condition, excess emissions resulting from startup, shutdown, fuel switching and documented malfunctions are allowed provided that operators employ the best operational practices to minimize the amount and duration of emissions during such incidents. For each CTG/HRSG system, NO_x and CO emission data exclusions resulting from startup, shutdown, or documented malfunctions shall not exceed two hours in any 24-hour period except for the specific cases listed below. A “documented malfunction” means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic mail.
- a. *STG/HRSG System Cold Startup: For cold startup of the steam turbine system, NO_x and CO emission data exclusions for any CTG/HRSG system shall not exceed eight (8) hours in any 24-hour period. A cold “startup of the steam turbine system” is defined as startup of the 3-on-1 combined cycle system following a shutdown of the steam turbine lasting at least 48 hours.*
- {Permitting Note: During a cold startup of the STG system, each CTG/HRSG system is sequentially brought on line at low load to gradually increase the temperature of the STG and prevent thermal metal fatigue. Note that shutdowns and documented malfunctions are separately regulated in accordance with the requirements of this condition.}*
- b. *Shutdown Steam Turbine System: For shutdown of steam turbine system, NO_x and CO emission data exclusions for any CTG/HRSG system shall not exceed three (3) hours in any 24-hour period.*
- c. *CTG/HRSG System Cold Startup: For cold startup of a CTG/HRSG system, NO_x and CO emission data exclusions shall not exceed four (4) hours in any 24-hour period. “Cold startup of a CTG/HRSG system” is defined as a startup after the pressure in the high-pressure (HP) steam drum falls below 450 psig for at least a one-hour period.*
- d. *Fuel Switching: For fuel switching, NO_x and CO emission data exclusions shall not exceed two (2) hours in any 24-hour period.*
16. **Ammonia Injection:** Ammonia injection shall begin as soon as operation of the CTG/HRSG system achieves the operating parameters specified by the manufacturer. As authorized by Rule 62-210.700(5), F.A.C., the above conditions allow excess emissions only for specifically defined periods of startup, shutdown, fuel switching, and documented malfunction of the CTG. [Design; Rules 62-4.070(3) and 62-210.700, F.A.C.]
17. **DLN Tuning:** CEMS data collected during initial or other major DLN tuning sessions may be excluded by the permittee from the CEMS compliance demonstration provided the tuning session is performed in accordance with the manufacturer’s specifications. A “major tuning session” may occur after completion of initial construction, a major repair, or other similar circumstances. Prior to performing any major tuning session, where the intent is to exclude data from the CEMS compliance demonstration, the permittee shall provide the Compliance Authority with an advance notice of at least 7 days that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Design; Rule 62-4.070(3), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

EMISSIONS PERFORMANCE TESTING

18. Test Methods: Required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
CTM-027 or 320	Procedure for Collection and Analysis of Ammonia in Stationary Source. {Notes: This is an EPA conditional test method. The minimum detection limit shall be 1 ppm.} Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources {Notes: The method shall be based on a continuous sampling train. The ascarite trap may be omitted or the interference trap of section 10.1 may be used in lieu of the silica gel and ascarite traps.}
18	Measurement of Gaseous Organic Compound Emissions by Gas Chromatography {Note: EPA Method 18 may be used (optional) concurrently with EPA Method 25A to deduct emissions of methane and ethane from the measured VOC emissions.}
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines
25A	Determination of Volatile Organic Concentrations

No other methods may be used for compliance testing unless prior written approval is received from the administrator of the Department's Emissions Monitoring Section in accordance with an alternate sampling procedure pursuant to 62-297.620, F.A.C.

[Rules 62-204.800 and 62-297.100, F.A.C.; 40 CFR 60, Appendix A]

19. Initial Compliance Determinations: Initial compliance tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the initial startup of the unit. Each CTG shall be stack tested to demonstrate initial compliance with the emission standards for CO, NO_x, VOC, visible emissions, and ammonia slip. Each unit shall be tested when firing natural gas, when using the duct burners and when firing distillate fuel oil. Referenced method data collected during the required Relative Accuracy Test Audits (RATAs) may be used to demonstrate compliance with the initial CO and NO_x standards. With appropriate flow measurements (or fuel measurements and approved F-factors), CEMS data may be used to demonstrate compliance with the CO and NO_x mass rate emissions standards. CO and NO_x emissions recorded by the CEMS shall also be reported for each run during tests for visible emissions, VOC and ammonia slip. The Department may require the permittee to conduct additional tests after major replacement or major repair of any air pollution control equipment, such as the SCR catalyst, oxidation catalyst, DLN combustors, etc.

[Rule 62-297.310(7)(a)1, F.A.C. and 40 CFR 60.8].

20. Continuous Compliance: The permittee shall demonstrate continuous compliance with the 30-unit operating days rolling average CO and NO_x emissions standards based on data collected by the certified CEMS. Within 45 days of conducting any RATA on a CEMS, the permittee shall submit a report to the Compliance Authority summarizing results of the RATA. Compliance with the CO emission standards also serves as an indicator of efficient fuel combustion and oxidation catalyst operation, which reduces emissions of particulate matter and volatile organic compounds.

[Rule 62-4.070(3), F.A.C.; 40 CFR 60, Subpart KKKK]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

21. Annual Compliance Tests: During each federal fiscal year (October 1st to September 30th), each CTG shall be tested to demonstrate compliance with the emission standards for visible emissions and ammonia slip. Testing to determine the ammonia slip shall be conducted while firing the primary fuel. NO_x emissions recorded by the CEMS shall be reported for each ammonia slip test run. CO emissions recorded by the CEMS shall be reported for the visible emissions observation period.

{Permitting Note: After initial compliance with the VOC standards is demonstrated, annual compliance tests for VOC emissions are not required. Compliance with the continuously monitored CO standards shall indicate efficient combustion and low VOC emissions. The Department retains the right to require VOC testing if CO limits are exceeded or for the reasons given in Appendix SC, Condition 17, Special Compliance Tests.}

[Rules 62-4.070(3) and 62-297.310(7)(a)4, F.A.C.]

22. Compliance for SAM, SO₂ and PM/PM₁₀/PM_{2.5}: In stack compliance testing is not required for SAM, SO₂ and PM/PM₁₀/PM_{2.5}. Compliance with the limits and control requirements for SAM, SO₂ and PM/PM₁₀/PM_{2.5} is based on the recordkeeping required in Specific Condition 28, the visible emissions standard and the CO/NO_x continuous monitoring. [Rule 62-4.070(3), F.A.C.]

CONTINUOUS MONITORING REQUIREMENTS

23. Continuous Emissions Monitoring System(s) (CEMS): The permittee shall install, calibrate, maintain, and operate CEMS to measure and record the emissions of CO and NO_x from the combined cycle CTG in a manner sufficient to demonstrate continuous compliance with the CEMS emission standards of this section. Each monitoring system shall be installed, calibrated, and properly functioning prior to the initial performance tests. Within one working day of discovering emissions in excess of a CO or NO_x standard (and subject to the specified averaging period), the permittee shall notify the Compliance Authority.
- CO Monitors*: The CO monitors shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A within 60 calendar days of achieving permitted capacity as defined in Rule 62-297.310(2), F.A.C., but no later than 180 calendar days after initial startup. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report in Section 7 shall be made each calendar quarter, and reported semiannually to the Compliance Authority. The RATA tests required for the CO monitor shall be performed using EPA Method 10 in Appendix A of 40 CFR 60 and shall be based on a continuous sampling train. The CO monitor span values shall be set appropriately considering the allowable methods of operation and corresponding emission standards.
 - NO_x Monitors*: Each NO_x monitor shall be certified, operated, and maintained in accordance with the requirements of 40 CFR 75. Record keeping and reporting shall be conducted pursuant to Subparts F and G in 40 CFR 75. The RATA tests required for the NO_x monitor shall be performed using EPA Method 20 or 7E in Appendix A of 40 CFR 60.
 - Diluent Monitors*: The oxygen (O₂) or carbon dioxide (CO₂) content of the flue gas shall be monitored at the location where CO and NO_x are monitored to correct the measured emissions rates to 15% oxygen. If a CO₂ monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

24. CEMS Data Requirements:

- Data Collection*: Emissions shall be monitored and recorded at all times including startup, operation, shutdown, and malfunction except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments. The CEMS shall be designed and operated to sample, analyze,

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

and record data evenly spaced over an hour. If the CEMS measures concentration on a wet basis, the CEM system shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the owner or operator may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load for each allowable fuel, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Final results of the CEMS shall be expressed as ppmvd corrected to 15% oxygen. The CEMS shall be used to demonstrate compliance with the CEMS emission standards for CO and NO_x as specified in this permit. For purposes of determining compliance with the CEMS emissions standards of this permit, missing (or excluded) data shall not be substituted. Upon request by the Department, the CEMS emission rates shall be corrected to International Organization of Standardization (ISO) conditions.

- b. *Valid Hour:* Hourly average values shall begin at the top of each hour. Each hourly average value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). If less than two such data points are available, the hourly average value is not valid. An hour in which any oil is fired is attributed towards compliance with the permit standards for oil firing. The permittee shall use all valid measurements or data points collected during an hour to calculate the hourly average values.
- c. *30-Unit Operating Day Rolling Averages:* Compliance shall be determined after each operating day by calculating the arithmetic average of all the valid hourly averages from that operating day and the prior 29 operating days. For purposes of determining compliance with the 30-unit operating day rolling CEMS standards, the missing data substitution methodology of 40 CFR Part 75, subpart D, shall not be utilized. Instead, the 30-unit operating day rolling average shall be determined using the remaining hourly data in the 30-day rolling period.
- {Permitting Note: There may be more than one 30-unit operating day compliance demonstration required for CO and NO_x emissions depending on the use of alternate fuels.}*
- d. *Data Exclusion:* Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, fuel switches and DLN tuning. Some of the CEMS emissions data recorded during these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of Condition Nos. 15 and 17 of this section. All periods of data excluded shall be consecutive for each such episode and only data obtained during the described episodes (startup, shutdown, malfunction, fuel switches, DLN tuning) may be used for the appropriate exclusion periods. The permittee shall minimize the duration of data excluded for such episodes to the extent practicable. Data recorded during such episodes shall not be excluded if the episode was caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented. Best operational practices shall be used to minimize hourly emissions that occur during such episodes. Emissions of any quantity or duration that occur entirely or in part from poor maintenance, poor operation, or any other equipment or process failure, which may reasonably be prevented, shall be prohibited.
- e. *Data Exclusion during Installation of Oxidation Catalyst:* The permittee may exclude CO CEMS data in excess of the 7.5 ppmvd @15% O₂ from the 30 operating day rolling average calculation during the installation of the oxidation catalyst (which shall not exceed 12 months) provided all reasonable efforts are used to minimize such emissions. However, all CEMS data must be included when determining whether there is a net emission increase [as defined in Section 62-210.200 (definitions), F.A.C.] of CO greater or equal to the significant emissions rate of 100 tons per year.

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

- f. *Availability*: Monitor availability for the CEMS shall be 95% or greater in any calendar quarter. The quarterly excess emissions report shall be used to demonstrate monitor availability. In the event 95% availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving 95% availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Compliance Authority.

[Rule 62-297.520, F.A.C.; 40 CFR 60.7(a)(5) and 40 CFR 60.13; 40 CFR Part 51, Appendix P; 40 CFR 60, Appendix B - Performance Specifications; 40 CFR 60, Appendix F - Quality Assurance Procedures; and Rules 62-4.070(3), F.A.C.]

25. Ammonia Monitoring Requirements: In accordance with the manufacturer's specifications, the permittee shall install, calibrate, operate and maintain an ammonia flow meter to measure and record the ammonia injection rate to the SCR system by the time of the initial compliance tests. The permittee shall document and periodically update the general range of ammonia flow rates required to meet permitted emissions levels over the range of load conditions allowed by this permit by comparing NO_x emissions recorded by the CEM system with ammonia flow rates recorded using the ammonia flow meter. During NO_x monitor downtimes or malfunctions, the permittee shall operate at the ammonia flow rate and, as applicable for fuel oil firing, the water-to-fuel ratio, that are consistent with the documented flow rate for the combustion turbine load condition. [Rules 62-4.070(3), F.A.C.]

RECORDS AND REPORTS

26. Monitoring of Capacity: The permittee shall monitor and record the operating rate of each CTG and HRSG DB system on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown, malfunction and fuel switching). Such monitoring shall be made using a monitoring component of the CEMS required above, or by monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D. [Rule 62-4.070(3), F.A.C.]
27. Monthly Operations Summary: By the fifth calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for each CTG for the previous month of operation: fuel consumption, hours of operation, hours of duct firing, and the updated 12-month rolling totals for each. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. The fuel consumption shall be monitored in accordance with the provisions of 40 CFR 75, Appendix D. [Rules 62-4.070(3), F.A.C.]
28. Fuel Sulfur Records: The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.
- a. *Natural Gas*: Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D4468-85, D5504-01, D6228-98 and D6667-01, D3246-81 or more recent versions.
- b. *ULSD Fuel Oil*: Compliance with the distillate fuel oil sulfur limit shall be demonstrated by taking a sample, analyzing the sample for fuel sulfur, and reporting the results to each Compliance Authority before initial startup. Sampling the fuel oil sulfur content shall be conducted in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM methods D5453-00, D129-91,

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

A. UNIT 5 – COMBUSTION TURBINE GENERATORS (EU 007, 008, and 009)

D1552-90, D2622-94, or D4294-90. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor. At the request of a Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.

The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75, Appendix D. [Rules 62-4.070(3) and 62-4.160(15), F.A.C.]

29. Emissions Performance Test Reports: A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. and in Appendix SC of this permit. [Rule 62-297.310(8), F.A.C.]
30. Excess Emissions Reporting:
- a. *Malfunction Notification*: If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.
 - b. *SIP Quarterly Permit Limits Excess Emissions Report*: Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of CO and NO_x emissions in excess of the permit emission standards following the NSPS format in 40 CFR 60.7(c), Subpart A. Periods of startup, shutdown and malfunction, shall be monitored, recorded and reported as excess emissions when emission levels exceed the standards specified in this permit. In addition, the report shall summarize the CEMS systems monitor availability for the previous quarter.
 - c. *NSPS Semi-Annual Excess Emissions Reports*: For purposes of reporting emissions in excess of NSPS Subpart KKKK, excess emissions from the CTG are defined as: a specified averaging period over which either the NO_x emissions are higher than the applicable emission limit in 40 CFR 60.4320; or the total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in 60.4330. Within thirty (30) days following each calendar semi-annual period, the permittee shall submit a report on any periods of excess emissions that occurred during the previous semi-annual period to the Compliance Authority.
- {Note: If there are no periods of excess emissions as defined in NSPS Subpart KKKK, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}*
- [Rules 62-4.130, 62-204.800, 62-210.700(6), F.A.C.; 40 CFR 60.7, and 60.4420]
31. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating hours and emissions from this facility. The permittee shall also keep records sufficient to determine the annual throughput of distillate fuel oil for the fuel oil storage tank for use in the Annual Operating Report. Annual operating reports shall be submitted to the Compliance Authority by April 1st of each year. [Rule 62-210.370(2), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

B. AUXILIARY BOILER AND TEMPORARY CONSTRUCTION BOILER (010 AND 015)

This section of the permit addresses the following emissions units.

ID	Emission Unit Description
010	One nominal 85,000 pounds per hour (lb/hr) natural gas fueled auxiliary boiler (99.8 mmBtu/hr)
015	One temporary 110 mmBtu/hr natural gas-fueled boiler to be used only during construction

AUXILIARY BOILER REQUIREMENTS

- Equipment:** The permittee is authorized to install, operate, and maintain one auxiliary boiler with a maximum design heat input of 99.8 mmBtu/hr (85,000 lb/hr) to produce steam during start up of the CTG. [Applicant Request; Rule 62-210.200(PTE), F.A.C.]
- Hours of Operation:** The hours of operation of the auxiliary boiler shall not exceed 750 hours per year. [Applicant Request; Rule 62-210.200(PTE), F.A.C.]
- NSPS Subpart Dc Applicability:** The auxiliary boiler is subject to all applicable requirements of 40 CFR 60, Subpart Dc which applies to Small Industrial, Commercial, or Institutional Steam Generating Units. Specifically, this emission unit shall comply with 40 CFR 60.48c Reporting and Recordkeeping Requirements. [40 CFR 60, NSPS-Subpart Dc - Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, attached as Appendix Dc].
- Auxiliary Boiler Emissions Limits:** The auxiliary boiler shall comply with the following emission limits.

NO _x	CO	VOC, SO ₂ , PM/PM ₁₀
0.05 lb/mmBtu	0.08 lb/mmBtu	2 gr S/100 SCF natural gas spec and 10% Opacity

[Applicant request; Rule 62-4.070(3), F.A.C.]

{Permitting note: There are no Subpart Dc emission standards for auxiliary boilers fueled by natural gas.}

- Auxiliary Boiler Testing Requirements:** The auxiliary boiler shall be stack tested to demonstrate initial compliance with the emission standards for CO, NO_x and visible emissions. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the initial startup. [Rule 62-297.310(7)(a)1, F.A.C.]

Test Methods: Any required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources

- Notification:** Initial notification is required for the auxiliary boiler pursuant to 40 CFR 60.7.
- Reporting:** The permittee shall maintain records of the amount of natural gas used in the auxiliary boiler. These records shall be submitted to the Compliance Authority on an annual basis or upon request. [Rule 62-4.070(3), F.A.C.]

SECTION III - EMISSIONS UNITS SPECIFIC CONDITIONS

B. AUXILIARY BOILER AND TEMPORARY CONSTRUCTION BOILER (010 AND 015)

TEMPORARY BOILER REQUIREMENTS

8. Equipment: The permittee is authorized to install, operate, and maintain a temporary boiler during the construction of the RBEC with a maximum design heat input of 110 mmBtu/hr.
[Applicant Request; Rule 62-210.200(PTE), F.A.C.]
9. Hours of Operation: The hours of operation of the temporary boiler shall not exceed 1000 hours per year and the temporary boiler shall not operate beyond the expiration date of this permit.
[Applicant Request; Rule 62-210.200(PTE), F.A.C.]
10. NSPS Subpart Db Applicability: The temporary 110 mmBtu natural gas-fueled boiler is subject to all applicable requirements of 40 CFR 60, Subpart Db which applies to Industrial, Commercial, or Institutional Steam Generating Units.
[40 CFR 60, NSPS-Subpart Db - Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, attached as Appendix Db].

SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

C. PROCESS HEATERS (EU 011)

This section of the permit addresses the following emissions unit.

ID	Emission Unit Description
011	Two nominal 10 mmBtu/hr natural gas-fired process heaters (one is a spare)

- Equipment:** The permittee is authorized to install, operate, and maintain two 10 mmBtu/hr process heaters for the purpose of heating the natural gas supply to the CTG.
[Applicant Request and Rule 62-210.200(PTE), F.A.C.]
- Hours of Operation:** The two natural gas-fueled process heaters are allowed to operate a combined total of 8760 hours per year. [Applicant Request and Rule 62-210.200(PTE), F.A.C.]
- NSPS Subpart Dc Applicability:** Each process heater is subject to all applicable requirements of 40 CFR 60, Subpart Dc which applies to Small Industrial, Commercial, or Institutional Boiler. Specifically, each emission unit shall comply with 40 CFR 60.48c Reporting and Recordkeeping Requirements.
[40 CFR 60, NSPS-Subpart Dc - Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, attached as Appendix Dc]
- Emission Limits:** Each natural gas fired process heater shall comply with the following emission limits.

NO_x	CO	VOC, SO₂, PM/PM₁₀
0.095 lb/mmBtu	0.08 lb/mmBtu	2 gr S/100 SCF natural gas spec and 10% Opacity

[Applicant request; Rule 62-4.070(3), F.A.C.]

{Permitting note: There are no Subpart Dc emission standards for gas-fired process heaters fueled by natural gas.}

- Testing Requirements:** Each unit shall be stack tested to demonstrate initial compliance with the emission standards for CO, NO_x and visible emissions. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the initial startup. As an alternative, a Manufacturer certification of emissions characteristics of the purchased model that are at least as stringent as the emission limits values can be used to fulfill this requirement.
[Rule 62-297.310(7)(a)1, F.A.C.]

Test Methods: Any required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources

- Notification, Recordkeeping and Reporting Requirements:** The permittee shall maintain records of the amount of natural gas used in the process heaters and shall comply with the notification, recordkeeping and reporting requirements pursuant to 40 CFR 60.48c and 40 CFR 60.7. These records shall be submitted to the Compliance Authority on an annual basis or upon request.
[Rule 62-4.070(3), F.A.C.; 40 CFR 60, Subparts A and Dc]

SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

D. COMPRESSOR STATION (EU 012)

This section of the permit addresses the following emissions unit.

ID	Emission Unit Description
012	Seven nominal 1,340 horsepower (hp) natural gas compressors

1. **Equipment:** The permittee is authorized to install, operate, and maintain seven nominal 1,340 horsepower (hp) natural gas compressors. Maximum heat input shall not exceed 10.11 mmBtu/hr each. [Applicant Request and Rule 62-210.200(PTE), F.A.C.]
2. **Hours of Operation and Fuel Specifications:** Each compressor is allowed to operate continuously (8760 hr/yr). The compressors are allowed to burn natural gas only. [Applicant Request and Rule 62-210.200(PTE), F.A.C.]
3. **NSPS Subpart JJJJ Applicability:** These compressors are Stationary Spark Ignition Internal Combustion Engines and shall comply with applicable provisions of 40 CFR 60, Subpart JJJJ. [40 CFR 60, Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines]
4. **NESHAPS Subpart ZZZZ Applicability:** These compressors are Reciprocating Internal Combustion Engines (RICE) and shall comply with applicable provisions of 40 CFR 63, Subpart ZZZZ. Pursuant to 40 CFR 63.6590(c) the compressors must meet the requirements of Subpart ZZZZ by meeting the requirements of 40 CFR 60, Subpart JJJJ. [40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)]
5. **Pollution Control Equipment:** Each gas compressor shall be equipped with an oxidation catalyst to control CO and VOC/hydrocarbons. [Applicant request; Rule 62-4.070(3), F.A.C.]
6. **Visible Emission (VE) Limit:** Each natural gas compressor shall comply with a visible emission limit of 10% opacity. [Applicant request; Rule 62-4.070(3), F.A.C.]
7. **Emissions Limits:** Each natural gas compressors shall comply with the following emission limits.

Standard (manufacture date)	CO (g/hp-hr) ^a	VOC (g/hp-hr)	NO _x (g/hp-hr)	PM (g/hp-hr)	SO ₂ (gas S spec.)
Permit Emission Limit	0.10	0.16	1.5 ^b	0.034	2 gr/100 SCF
Subpart JJJJ (1/1/2008)	4.0	1.0	2.0	NA	
Subpart JJJJ (7/1/2010)	2.0	0.7	1.0		

a. grams per horsepower-hour (g/hp-hr)

b. Reduced to 1.0 g/hp-hr if manufacture date is 7/1/2010 or later to insure compliance with Subpart JJJJ.

{Permitting note: Installation of an oxidation catalyst and adherence to the visible emission standard and fuel specification shall be considered sufficient to insure compliance with the listed PM limit.}

[Applicant request; 40 CFR 60, Subpart JJJJ; Rule 62-4.070(3), F.A.C.]

8. **Compressor Testing Requirements:** Each unit shall be stack tested to demonstrate initial compliance with the emission standards for CO, VOC, NO_x and visible emissions. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the initial startup. With the exception of visible emissions testing, manufacturer certification can be provided to the Department in lieu of actual testing. [Rule 62-297.310(7)(a)1, F.A.C.; 40 CFR 60.8 and 40 CFR 60.4244]

SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

D. COMPRESSOR STATION (EU 012)

9. Test Methods: Any required tests shall be performed in accordance with the following reference methods.

Method	Description of Method and Comments
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources
18	Determination of Volatile Organic Compounds Emissions from Stationary Sources

[Rule 62-4.070(3), F.A.C.; 40 CFR 60, Subpart JJJJ and 40 CFR 60.8]

10. Notification, Recordkeeping and Reporting Requirements: The permittee shall maintain records of the amount of natural gas used in the compressor station and shall comply with the notification, recordkeeping and reporting requirements pursuant to 40 CFR 60.4245 and 40 CFR 60.7. These records shall be submitted to the Compliance Authority on an annual basis or upon request.

[Rule 62-4.070(3), F.A.C.; 40 CFR 60, Subparts A and JJJJ]

SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

E. EMERGENCY GENERATORS (013)

This section of the permit addresses the following emissions units.

ID	Emission Unit Description
013	Two nominal 2,250 kilowatts (kW) liquid fueled emergency generators

1. **Equipment:** The permittee is authorized to install, operate, and maintain two 2,250 kW emergency generators. [Applicant Request and Rule 62-210.200(PTE), F.A.C.]
2. **Hours of Operation and Fuel Specifications:** The hours of operation shall not exceed 160 hours per year per generator. The generators shall burn ultralow sulfur diesel fuel oil (0.0015% sulfur). [Applicant Request and Rule 62-210.200(PTE), F.A.C.]
3. **NSPS Subpart III Applicability:** These emergency generators are Stationary Compression Ignition Internal Combustion Engines (Stationary ICE) and shall comply with applicable provisions of 40 CFR 60, Subpart III, including emission testing or certification. [40 CFR 60, Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines]
4. **NESHAPS Subpart ZZZZ Applicability:** These emergency generators are Liquid Fueled Reciprocating Internal Combustion Engines (RICE) and shall comply with applicable provisions of 40 CFR 63, Subpart ZZZZ. Pursuant to 40 CFR 63.6590(c) the compressors must meet the requirements of Subpart ZZZZ by meeting the requirements of 40 CFR 60, Subpart III. [40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)]
5. **Emissions Limits:** Each emergency generator shall comply with the following emission limits and demonstrate compliance in accordance with the procedures given in 40 CFR 60, Subpart III. Manufacturer certification can be provided to the Department in lieu of actual testing.

Source (model year)	CO (g/hp-hr)	PM (g/hp-hr)	Hydrocarbons (g/hp-hr)	NO _x (g/hp-hr)
Subpart III (2007-2010)	8.5	0.4	1.0	6.9
Subpart III (2011 and later)	2.6	0.15	4.8 (NMHC ^a +NO _x)	

a. NMHC means Non-Methane Hydrocarbons.

[Applicant Request; 40 CFR 60, Subpart III and Rule 62-4.070(3), F.A.C.]

6. **Visible Emission (VE) Limit:** Each liquid-fueled emergency generator shall comply with a visible emission limit of 10% opacity. An initial VE test shall be conducted in accordance with EPA Method 9 within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after initial startup. [Applicant request; Rule 62-4.070(3), F.A.C.]
7. **Notification, Recordkeeping and Reporting Requirements:** The permittee shall maintain records of the amount of fuel used in the emergency generators and shall comply with the notification, recordkeeping and reporting requirements pursuant to 40 CFR 60.4214 and 40 CFR 60.7. These records shall be submitted to the Compliance Authority on an annual basis or upon request. [Rule 62-4.070(3), F.A.C.; 40 CFR 60, Subparts A and III]

SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

F. EMERGENCY FIRE PUMP (014)

This section of the permit addresses the following emissions unit.

ID	Emission Unit Description
014	One emergency diesel fire pump engine (≤ 300 hp) and a nominal 500 gallon fuel oil storage tank

1. **Equipment:** The permittee is authorized to install, operate, and maintain one diesel engine driven fire pump (≤ 300 hp) and an associated nominal 500 gallon fuel oil storage tank. [Applicant Request and Rule 62-210.200(PTE), F.A.C.]
2. **Hours of Operation:** The fire pump may operate in response to emergency conditions and 80 non-emergency hours per year for maintenance testing. [Applicant Request; Rule 62-210.200 (PTE), F.A.C.]
3. **Authorized Fuel:** This unit shall fire ULSD fuel oil, which shall contain no more than 0.0015% sulfur by weight. [Applicant Request]
4. **NSPS Subpart III Applicability:** The fire pump engine is an Emergency Stationary Compression Ignition Internal Combustion Engine (Stationary ICE) and shall comply with applicable provisions of 40 CFR 60, Subpart III. [40 CFR 60, Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines]
5. **Emissions Limits:** The emergency fire pump engine shall comply with the following emission limits and demonstrate compliance in accordance with the procedures given in 40 CFR 60, Subpart III.

Model Year	CO (g/hp-hr)	NMHC + NO _x (g/hp-hr)	PM (g/hp-hr)
Subpart III (2008)	2.6	7.8	0.40
Subpart III (2009 or later)	NA	3.0	0.15

[Applicant Request; 40 CFR 60, Subpart III and Rule 62-4.070(3), F.A.C.]

6. **Fire Pump Engine Certification:** Manufacturer certification shall be provided to the Department in lieu of actual testing. [40 CFR 60.4211 and Rule 62-4.070(3), F.A.C.]

SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

G. DISTILLATE FUEL OIL STORAGE TANK (016)

This section of the permit addresses the following emissions unit.

ID	Emission Unit Description
016	One nominal 6.3 million gallon distillate fuel oil storage tank

NSPS APPLICABILITY

1. NSPS Subpart Kb Applicability: The distillate fuel oil tank is not subject to Subpart Kb, which applies to any storage tank with a capacity greater than or equal to 10,300 gallons (40 cubic meters) that is used to store volatile organic liquids for which construction, reconstruction, or modification is commenced after July 23, 1984. Tanks with a capacity greater than or equal to 40,000 gallons (151 cubic meters) storing a liquid with a maximum true vapor pressure less than 3.5 kilopascals (kPa) are exempt from the General Provisions (40 CFR 60, Subpart A) and from the provisions of NSPS Subpart Kb. [40 CFR 60.110b(a) and (c); Rule 62-204.800(7)(b), F.A.C.]

EQUIPMENT SPECIFICATIONS

2. Equipment: The permittee is authorized to install, operate, and maintain one nominal 6.3 million gallon distillate fuel oil storage tank designed to provide ultra low sulfur diesel fuel oil to the gas turbines. [Applicant Request; Rule 62-210.200(PTE), F.A.C.]

EMISSIONS AND PERFORMANCE REQUIREMENTS

3. Hours of Operation: The hours of operation are not restricted (8760 hours per year). [Applicant Request; Rule 62-210.200(PTE), F.A.C.]

NOTIFICATION, REPORTING AND RECORDS

4. Oil Tank Records: The permittee shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage tank. Records shall be retained for the life of the facility. The permittee shall also keep records sufficient to determine the annual throughput of distillate fuel oil for the storage tank for use in the Annual Operating Report. [Rule 62-4.070(3) F.A.C]
5. Fuel Oil Records: The permittee shall keep readily accessible records showing the maximum true vapor pressure of the stored liquid. The maximum true vapor pressure shall be less than 3.5 kPa. Compliance with this condition may be demonstrated by using the information from the respective MSDS for the ULSD fuel oil stored in the tank. [Rule 62-4.070(3), F.A.C.; Avoidance of 40 CFR 60, Subpart Kb]

{Permitting Note: An evaluation of several Material Safety Data Sheets (MSDS) by the Department and applicant demonstrated that the vapor pressure is much less than 3.5 kPa for ULSD fuel oil.}



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

PERMITTEE

Florida Power & Light Company (FPL)
Riviera Beach Energy Center

Authorized Representative:
Mr. Randall R. LaBauve, Vice President

Final Permit No. 0990042-007-AC
Air Construction Permit Revision -
Changes to: Excess Emissions Provisions for
the Gas Turbines, Maximum Heat Input for the
Process Heaters and Hours of Operation for the
Emergency Generators.

Riviera Beach Energy Center
Palm Beach County, Florida

PROJECT

This is the final air construction permit revision which revises specific conditions of Permit No. 0990042-006-AC for the 1,250 megawatt (MW) combined cycle unit at the Riviera Beach Energy Center. The revised permit conditions are related to excess emissions provisions for the gas turbines, reducing the maximum heat input for the process heaters and reducing the allowable hours of operation for the emergency generators. The existing plant is a power plant categorized under Standard Industrial Classification No. 4911. The plant is located in Palm Beach County at 200-300 Broadway, Riviera Beach. The Universal Transverse Mercator (UTM) coordinates are Zone 17, 594.249 kilometers (km) East and 2960.632 km North. This final permit is organized into the following sections: Section 1 (General Information) and Section 2 (Permit Revisions). As noted in the Final Determination provided with this final permit, no changes and clarifications were made to the draft permit.

STATEMENT OF BASIS

This air pollution construction permit revision is issued under the provisions of: Chapter 403 of the Florida Statutes (F.S.) and Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297 of the Florida Administrative Code (F.A.C.). This project is subject to the general preconstruction review requirements in Rule 62-212.300, F.A.C. and is not subject to the preconstruction review requirements for major stationary sources in Rule 62-212.400, F.A.C., for the Prevention of Significant Deterioration (PSD) of Air Quality. A copy of this permit revision shall be filed with the referenced permit and shall become part of the permit.

Upon issuance of this final permit revision, any party to this order has the right to seek judicial review of it under Section 120.68 of the Florida Statutes by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within 30 days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida
Office of Permitting and Compliance
Division of Air Resource Management
(Electronic Signature)

PERMIT REVISION

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Final Air Permit package (including the Final Determination and Final Permit Revision) was sent by electronic mail, or a link to these documents made available electronically on a publicly accessible server, with received receipt requested before the close of business on the date indicated below to the following persons.

Mr. Randall R. LaBauve, FPL: Randall.R.LaBauve@fpl.com

Mr. John Hampp, FPL: john.hampp@fpl.com

Ms. Jessica Peck, FPL: Jessica.Peck@fpl.com

Mr. Kennard F. Kosky, P.E., Golder Associates, Inc.: ken_kosky@golder.com

Mr. Lennon Anderson, P.E., DEP Southeast District Office: lennon.anderson@dep.state.fl.us

Ms. Cindy Mulkey, DEP Siting Office: cindy.mulkey@dep.state.fl.us

Ms. Heather Ceron, U.S. EPA Region 4: ceron.heather@epa.gov

Ms. Katy R. Forney, U.S. EPA Region 4: forney.kathleen@epa.gov

Ms. Ana Oquendo-Vazquez, U.S. EPA Region 4: oquendo.ana@epa.gov

Ms. Barbara Friday, DEP OPC: barbara.friday@dep.state.fl.us (for posting with U.S. EPA, Region 4)

Ms. Lynn Scarce, DEP OPC: lynn.scarce@dep.state.fl.us (for reading file)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

(Electronic Signature)

SECTION 1. GENERAL INFORMATION

FACILITY DESCRIPTION

The project authorized by 0090006-005-AC was a plant conversion that included the construction of a nominal 1,250 MW natural gas-fueled combined cycle unit (Unit 3) and ancillary equipment and required the permanent shutdown and dismantling of Units 1 and 2 at the facility. Unit 3 consists of:

- Three nominal 265 MW combustion turbine-electrical generators (CTG) with evaporative inlet cooling systems;
- Three supplementary-fired heat recovery steam generators (HRSG) with selective catalytic reduction (SCR) reactors;
- Three maximum 460 million Btu per hour, lower heating value (MMBtu/hr, LHV), natural gas-fueled duct burners (DB) located in the three HRSG (one DB/HRSG);
- Three 149-foot exhaust stacks; and
- One common nominal 500 MW steam-electrical generator (STG).

Unit 3 uses ultralow sulfur distillate (ULSD) fuel oil as backup fuel. Unit 3 relies on some of the existing infrastructure including one of the fuel oil storage tanks.

Additional ancillary equipment installed includes: a permanent auxiliary boiler; a temporary boiler used during the construction phase; two emergency generators; two process (fuel) heaters; a diesel fire pump; and a gas compression station.

FACILITY REGULATORY CLASSIFICATION

- This facility is a major source of hazardous air pollutants (HAP).
- This facility operates units subject to the acid rain provisions of the Clean Air Act (CAA).
- The facility is a Title V major source of air pollution in accordance with Chapter 213, F.A.C.
- The facility is a major stationary source in accordance with Rule 62-212.400 (PSD), F.A.C.

PROPOSED PROJECT

For the current project, the applicant has requested an air construction permit revision to change several of the underlying construction permit conditions related to the gas turbine excess emissions provisions, the heat input for the process heaters and the hours of operation for the emergency generators.

SECTION 2. PERMIT REVISIONS

The following facility unit description table and permit specific conditions are revised as indicated. ~~Strikethrough~~ is used to denote the deletion of text. Double-underlines are used to denote the addition of text.

Air Construction Permit Being Revised: Permit No. 0990042-006-AC (expiration date December 31, 2015).

Emission Unit Descriptions

ID	Emission Unit Description
007	Unit 5A – one nominal 265 mega watt (MW) combustion turbine generator (CTG) with supplementary-fired heat recovery steam generator (HRSG)
008	Unit 5B – one nominal 265 MW CTG with supplementary-fired HRSG
009	Unit 5C – one nominal 265 MW CTG with supplementary-fired HRSG
010	One nominal 85,000 pounds per hour (lb/hr) auxiliary boiler (99.8 MMBtu/hr)
011	Two maximum design 40 <u>9.9</u> MMBtu/hr natural gas-fired process heaters (one is a spare)
012	Seven nominal 1,340 horsepower (hp) natural gas compressors
013	Two nominal 2,250 kilowatts (kW) liquid fueled emergency generators
014	One nominal 300-hp emergency diesel fire pump engine and 500 gallon fuel oil storage tank
015	One temporary 110 MMBtu/hr natural gas-fueled boiler to be used only during construction
016	One nominal 6.3 million gallon distillate fuel oil storage tank

1. Affected Emissions Units: Combustion Turbine Generators (CTG) and Heat Recovery Steam Generators (HRSG) (E.U. ID Nos. 007 - 009)

Specific Conditions **A.12., 15., 17., 24.** and **31.** of Permit No. 0990042-006-AC are hereby changed as follows (the remainder of the permit remains unchanged as a result of this permitting action):

A.12. Alternate Visible Emissions Standard: Visible emissions due to startups, shutdowns, fuel switches and malfunctions shall not exceed 10% opacity except for up to ten, 6-minute averaging periods during a calendar day, which shall not exceed 20% opacity. [Applicant Request and Rule 62-4.070(3), F.A.C.]

A.15. Excess Emissions Allowed: As specified in this condition, excess emissions resulting from startup, shutdown, fuel switching and documented malfunctions are allowed provided that operators employ the best operational practices to minimize the amount and duration of emissions during such incidents. ~~For each CTG/HRSG system, excess emissions of NO_x and CO resulting from startup, shutdown, or documented malfunctions shall not exceed two hours in any 24-hour period except for the specific cases listed below.~~ For each CTG/HRSG System, excess emissions of NO_x and CO resulting from startup, shutdown, or malfunction may be excluded from CEMS data in any 24-hour period (“any 24-hour period” means a calendar day, midnight to midnight) for the following conditions (these conditions are considered separate events and each event may occur independently within any 24-hour period):A “documented malfunction” means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic mail.

- a. ~~STG/HRSG System Cold Startup:~~ Steam Turbine Cold Startup: For cold startup of the steam turbine system, ~~NO_x and CO emission data exclusions~~ excluded emissions for any CTG/HRSG system shall not exceed eight (8) hours in any 24-hour period. A cold “startup of the steam turbine system” is defined as startup of the “3 on 1” combined cycle unit following a shutdown of the steam turbine lasting at least 48 hours.

{Permitting note: During a cold startup of the ~~STG system~~ steam turbine, each CTG/HRSG system is sequentially brought on line at low load to gradually increase the temperature of the ~~STG~~ steam-electrical turbine and prevent thermal metal fatigue. Note that shutdowns and documented malfunctions are separately regulated in accordance with the requirements of this condition.}

SECTION 2. PERMIT REVISIONS

- b. ~~Shutdown Steam Turbine System~~ Combined Cycle Operation: For shutdown of ~~steam turbine system combined cycle operation~~, ~~NO_x and CO emission data exclusions~~ excluded emissions from any CTG/HRSG system shall not exceed three (3) hours in any 24-hour period.
 - c. CTG /HRSG System Cold Startup: For cold startup of a CTG/HRSG system, ~~NO_x and CO emission data exclusions~~ excluded emissions shall not exceed four (4) hours in any 24-hour period. “Cold startup of a CTG /HRSG system” is defined as a startup after the pressure in the high-pressure (HP) steam drum falls below 450 pounds per square inch gauge (psig) for at least a one-hour period.
 - d. Fuel Switching: For fuel switching, ~~excess NO_x and CO emission data exclusions~~ excluded emissions shall not exceed 2 hours in any 24-hour period for each fuel switch and no more than four hours in any 24-hour period for any CTG/HRSG system. This provision applies to each individual CTG/HRSG system.
 - e. CTG/HRSG System Warm Startup: For warm startup of a CTG/HRSG system, excluded emissions shall not exceed two hours in any 24-hour period. “Warm startup of a CTG/HRSG system” is defined as a startup after the pressure in the high-pressure (HP) steam drum is above 450 psig.
 - f. CTG/HRSG System Shutdown: For shutdown of the CTG/HRSG operation, excluded emissions from any CTG/HRSG system shall not exceed two hours in any 24-hour period.
 - g. Documented Malfunction: For the CTG/HRSG system, excess emissions of NO_x and CO resulting from documented malfunctions shall not exceed two hours in any 24-hour period. A "documented malfunction" means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic mail.
- A.17. DLN Tuning**: CEMS data collected during initial or other major DLN tuning sessions and during manufacturer required Full Speed No Load (FSNL) trip tests may be excluded by the permittee from the CEMS compliance demonstration provided the tuning session is performed in accordance with the manufacturer’s specifications. A “major tuning session” may occur after completion of initial construction, a major repair or other similar circumstances. Prior to performing any major tuning session, where the intent is to exclude data from the CEMS compliance demonstration, the permittee shall provide the Compliance Authority with an advance notice of at least ~~7 days~~ one working (business) day that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail.
[Design; Rule 62-4.070(3), F.A.C.]
- A.23. Continuous Emissions Monitoring System(s) (CEMS)**: ...
- a. CO Monitors. The CO monitors shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A within 60 calendar days of achieving permitted capacity as defined in Rule 62-297.310(2), F.A.C., but no later than 180 calendar days after initial startup. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, or 40 CFR Part 75, and the Data Assessment Report in Section 7 shall be made each calendar quarter, and reported semiannually to the Compliance Authority. The RATA tests required for the CO monitor shall be performed using EPA Method 10 in Appendix A of 40 CFR 60 and shall be based on a continuous sampling train. The CO monitor span values shall be set appropriately considering the allowable methods of operation and corresponding emission standards.

SECTION 2. PERMIT REVISIONS

A.30. Excess Emissions Reporting:

- a. *Malfunction Notification:* If emissions in excess of a standard (subject to the specified averaging period) occur due to malfunction, the permittee shall notify the Compliance Authority within (1) working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Department may request a written summary report of the incident.
- b. *SIP Quarterly Permit Limits Excess Emissions Report:* Within 30 days following the end of each calendar-quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of CO and NO_x emissions in excess of the SIP-based permit emissions standards, and the amounts of authorized data excluded following the NSPS format in 40 CFR 60.7(c), Subpart A Figure XSE attached to this permit. Periods of startup, shutdown ~~and~~, malfunction, fuel switching and tuning shall be monitored, and recorded at all times and reported as excess emissions when emission levels exceed the standards specified in this permit. In addition, the report shall summarize the CEMS systems monitor availability for the previous quarter.
- c. *NSPS Semi-Annual Excess Emissions Reports:* For purposes of reporting emissions in excess of NSPS Subpart KKKK, excess emissions from the gas turbine are defined as: a specified averaging period over which either the NO_x emissions are ~~higher than the applicable emission limit in 60.4320~~ greater than 15 ppm at 15% O₂ on a 30-day rolling average while firing natural gas and greater than 42 ppm at 15% O₂ on a 30-day rolling average while firing ultra low sulfur distillate; or the total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in 40 CFR 60.4330. Within thirty (30) days following each calendar semi-annual period, the permittee shall submit a report on any periods of excess emissions that occurred during the previous semi-annual period to the Compliance Authority.

{Note: If there are no periods of excess emissions as defined in NSPS Subpart KKKK, a statement to that effect may be submitted with the SIP Quarterly Report to suffice for the NSPS Semi-Annual Report.}

[Rules 62-4.130, 62-204.800, 62-210.700(6), F.A.C., and 40 CFR 60.7, and 60.4420]

- 2. Affected Emissions Unit:** Two nominal 10 MMBtu/hr natural gas-fired process heaters (one is a spare) (E.U. ID No. 011).

Specific Condition Nos. **C.3. C.4., C.5. and C.6.** from Permit No. 0990042-006-AC are hereby changed as follows:

ID	Emission Unit Description
011	Two maximum design 10 <u>9.9</u> MMBtu/hr natural gas-fired process heaters (one is a spare)

Equipment: The permittee is authorized to install, operate, and maintain two maximum design ~~10~~ 9.9 MMBtu/hr process heaters for the purpose of heating the natural gas supply to the CTG. [Applicant Request and Rule 62-210.200(PTE), F.A.C.]

- C.3. ~~Reserved, NSPS Subpart De Applicability:~~** Each process heater is subject to all applicable requirements of 40 CFR 60, Subpart De which applies to Small Industrial, Commercial, or Institutional Boiler. Specifically, each emission unit shall comply with 40 CFR 60.48c Reporting and Recordkeeping Requirements. [~~40 CFR 60, NSPS Subpart De Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, attached as Appendix De~~]

SECTION 2. PERMIT REVISIONS

C.4. Reserved Emission Limits: ~~Each natural gas fired process heater shall comply with the following emission limits:~~

NO_x	CO	VOC, SO₂, PM/PM₁₀
0.095 lb/mmBtu	0.08 lb/mmBtu	2 gr S/100 SCF natural gas spec and 10% Opacity

~~[Applicant request; Rule 62-4.070(3), F.A.C.]~~

~~{Permitting note: There are no Subpart Dc emission standards for gas fired process heaters fueled by natural gas.}~~

C.5. Reserved Testing Requirements: ~~Each unit shall be stack tested to demonstrate initial compliance with the emission standards for CO, NO_x and visible emissions. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the initial startup. As an alternative, a Manufacturer certification of emissions characteristics of the purchased model that are at least as stringent as the emission limits values can be used to fulfill this requirement. [Rule 62-297.310(7)(a)1, F.A.C.]~~

~~**Test Methods:** Any required tests shall be performed in accordance with the following reference methods.~~

Method	Description of Method and Comments
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources

C.6. Notification, Recordkeeping and Reporting Requirements: ~~The permittee shall maintain records of the amount of natural gas used in the process heaters and shall comply with the notification, recordkeeping and reporting requirements pursuant to 40 CFR 60.48c and 40 CFR 60.7. These records shall be submitted to the Compliance Authority on an annual basis or upon request. [Rule 62-4.070(3), F.A.C.; 40 CFR 60, Subparts A and De]~~

3. Affected Emissions Unit: Two nominal 2,250 kilowatts (kW) liquid fueled emergency generators (E.U. ID No. 013).

Specific Condition No. **E.2.** from Permit No. 0990042-006 is hereby changed as follows:

E.2. Hours of Operation and Fuel Specifications: ~~The hours of operation shall not exceed 160 hours per year per generator~~ 100 hours per year for each engine for the purpose of maintenance checks and readiness testing with unlimited operation for emergency use. The generators shall burn ultralow sulfur diesel fuel oil (0.0015% sulfur). [Applicant Request and Rule 62-210.200(PTE), F.A.C.]

ATTACHMENT RBEC-EU1-IV3
ALTERNATIVE METHODS OF OPERATION

ATTACHMENT RBEC-EU1-IV3 ALTERNATIVE METHODS OF OPERATION COMBINED CYCLE UNIT 5

Riviera Beach Energy Center (RBEC) combined-cycle Unit 5 (5A, 5B & 5C) fires both natural gas as primary fuel and Ultra Low Sulfur Diesel (ULSD) oil as a restricted alternate fuel. The maximum sulfur content of natural gas is limited to 2 grains per 100 standard cubic feet (scf) and of the ULSD oil to 0.0015 percent by weight. Each CT can operate for the entire year (i.e., 8,760 hours) with natural gas and for 2,550 hours/year aggregated over three combustion turbines with fuel oil. These units may also operate at various loads. Evaporative cooling may be used to lower the inlet air temperature and provide additional electric power.

Maximum heat input to each CT is limited to 2,586 million British thermal units per hour (MMBtu/hr) when firing natural gas and 2,440 MMBtu/hr when firing fuel oil based on 59°F ambient temperature, 100-percent load, and lower heating value (LHV) of each fuel. The heat input rate varies with inlet temperatures. Each CT/HRSG units is equipped with a duct burner rated at 460 MMBtu/hr (LHV). The duct burners are fired with natural gas only. Duct firing is limited to 3,697,920 MMBtu/yr for all three CT/HRSGs combined.

Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternative methods of operation, and evaporative cooling.

EMISSIONS UNIT INFORMATION

Section [2]

Emergency Generators

III. EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Application - For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for an initial, revised or renewal Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

Air Construction Permit or FESOP Application - For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an “unregulated emissions unit” does not apply. If this is an application for an air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application – Where this application is used to apply for both an air construction permit and a revised or renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes, and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this application that is subject to air construction permitting and for each such emissions unit that is a regulated or unregulated unit for purposes of Title V permitting. (An emissions unit may be exempt from air construction permitting but still be classified as an unregulated unit for Title V purposes.) Emissions units classified as insignificant for Title V purposes are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.

EMISSIONS UNIT INFORMATION

Section [2]

Emergency Generators

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

EMISSIONS UNIT INFORMATION

Section [2]

Emergency Generators

C. EMISSION POINT (STACK/VENT) INFORMATION

(Optional for unregulated emissions units.)

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram:		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking:			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 30 feet	7. Exit Diameter: 1.0 feet	
8. Exit Temperature: 916 °F	9. Actual Volumetric Flow Rate: 17,463 acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates... Zone: East (km): North (km):		14. Emission Point Latitude/Longitude... Latitude (DD/MM/SS) Longitude (DD/MM/SS)	
15. Emission Point Comment: Stack parameters are based on Table 2-5 of the Air Permit Application submitted in January 2009.			

EMISSIONS UNIT INFORMATION

Section [2]

Emergency Generators

D. SEGMENT (PROCESS/FUEL) INFORMATION

Segment Description and Rate: Segment **1** of **1**

1. Segment Description (Process/Fuel Type): Internal Combustion Engines; Electric Generation; Distillate Oil; Reciprocating		
2. Source Classification Code (SCC): 2-01-001-02		3. SCC Units: 1000 Gallons Burned
4. Maximum Hourly Rate: 0.311	5. Maximum Annual Rate: 31.1	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: 0.0015%	8. Maximum % Ash:	9. Million Btu per SCC Unit: 131
10. Segment Comment: Max annual rate (2 engines) = 155.5 gal/hr x 100 hr/yr x 2 engines x 1 kgal/1000 gal= 31.1 kgal/yr Max hourly rate (2 engines) = 155.5 gal/hr x 2 engines x 1 kgal/1000 gal= 0.311 kgal/hr Unit is limited to firing ultra low sulfur diesel fuel with maximum 0.0015% S.		

Segment Description and Rate: Segment _____ of _____

1. Segment Description (Process/Fuel Type):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment:		

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: CO		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 56.50 lb/hour 2.83 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 8.5 g/hp-hr Reference: Permit No. 0990042-006-AC		7. Emissions Method Code: 2	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Hourly emissions: 2,250 kW x 1.341 hp/kW x 8.5 g/hp-hr x 0.002205 lb/g = 56.50 lb/hr Annual emissions: 56.50 lb/hr x 100 hr/yr x 1 ton / 2,000 lb = 2.83 TPY Emissions are for one generator.			
11. Potential, Fugitive, and Actual Emissions Comment:			

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: RULE	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 8.5 g/hp-hr	4. Equivalent Allowable Emissions: 17.3 lb/hour 2.83 tons/year
5. Method of Compliance: Manufacturer Certification of Subpart III Standards	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
 POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**
 (Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: PM/PM10		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 2.66 lb/hour 0.133 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 0.4 g/hp-hr Reference: Permit No. 0990042-006-AC		7. Emissions Method Code: 0	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Hourly emissions: 2,250 kW x 1.341 hp/kW x 0.4 g/hp-hr x 0.002205 lb/g = 2.66 lb/hr Annual emissions: 2.66lb/hr x 100 hr/yr x 1 ton / 2,000 lb = 0.133 TPY Emissions are for one generator.			
11. Potential, Fugitive, and Actual Emissions Comment:			

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: RULE	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 0.4 g/hp-hr (NSPS Subpart III, 2011 or later)	4. Equivalent Allowable Emissions: 2.66 lb/hour 0.133 tons/year
5. Method of Compliance: Manufacturer Certification of Subpart III Standards	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions of

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION POLLUTANT DETAIL INFORMATION

Section [2]
Emergency Generators

Page [3] of [3]
Nitrogen Oxides (NOx)

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: NOx		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 45.9 lb/hour 2.3 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to 6.9 g/hp-hr tons/year			
6. Emission Factor: Reference: Permit No. 0990042-006-AC		7. Emissions Method Code: 0	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Hourly emissions: 2,250 kW x 1.341 hp/kW x 6.9 g/hp-hr x 0.002205 lb/g = 45.9 lb/hr Annual emissions: 45.9 lb/hr x 160 hr/yr x 1 ton / 2,000 lb = 2.3 TPY Emissions are for one generator.			
11. Potential, Fugitive, and Actual Emissions Comment:			

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: RULE	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 6.9 g/hp-hr	4. Equivalent Allowable Emissions: 45.9 lb/hour 2.3 tons/year
5. Method of Compliance: Manufacturer Certification of Subpart III Standards	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions ____ of ____

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions ____ of ____

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [2]

Emergency Generators

G. VISIBLE EMISSIONS INFORMATION

Complete Subsection G if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

Visible Emissions Limitation: Visible Emissions Limitation **1** of **1**

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: Initial testing using EPA Method 9	
5. Visible Emissions Comment: Permit No. 0990042-006-AC	

Visible Emissions Limitation: Visible Emissions Limitation ____ of ____

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment:	

EMISSIONS UNIT INFORMATION

Section [2]

Emergency Generators

H. CONTINUOUS MONITOR INFORMATION

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor ____ of ____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment:	

Continuous Monitoring System: Continuous Monitor ____ of ____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment:	

EMISSIONS UNIT INFORMATION

Section [2]

Emergency Generators

I. EMISSIONS UNIT ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

<p>1. Process Flow Diagram: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____</p>
<p>2. Fuel Analysis or Specification: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input checked="" type="checkbox"/> Attached, Document ID: <u>RBEC-EU1-I2</u> <input type="checkbox"/> Previously Submitted, Date _____</p>
<p>3. Detailed Description of Control Equipment: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____</p>
<p>4. Procedures for Startup and Shutdown: (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____</p> <p><input type="checkbox"/> Not Applicable (construction application)</p>
<p>5. Operation and Maintenance Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____</p> <p><input checked="" type="checkbox"/> Not Applicable</p>
<p>6. Compliance Demonstration Reports/Records:</p> <p><input type="checkbox"/> Attached, Document ID: _____ Test Date(s)/Pollutant(s) Tested: _____</p> <p><input type="checkbox"/> Previously Submitted, Date: _____ Test Date(s)/Pollutant(s) Tested: _____</p> <p><input type="checkbox"/> To be Submitted, Date (if known): _____ Test Date(s)/Pollutant(s) Tested: _____</p> <p><input type="checkbox"/> Not Applicable</p> <p>Note: For FESOP applications, all required compliance demonstration records/reports must be submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a compliance plan must be submitted at the time of application.</p>
<p>7. Other Information Required by Rule or Statute:</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable</p>

EMISSIONS UNIT INFORMATION

Section [3]

Emergency Diesel Fire Pump Engine

III. EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Application - For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for an initial, revised or renewal Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

Air Construction Permit or FESOP Application - For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an “unregulated emissions unit” does not apply. If this is an application for an air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application – Where this application is used to apply for both an air construction permit and a revised or renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes, and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this application that is subject to air construction permitting and for each such emissions unit that is a regulated or unregulated unit for purposes of Title V permitting. (An emissions unit may be exempt from air construction permitting but still be classified as an unregulated unit for Title V purposes.) Emissions units classified as insignificant for Title V purposes are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.

EMISSIONS UNIT INFORMATION

Section [3]

Emergency Diesel Fire Pump Engine

A. GENERAL EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Emissions Unit Classification

1. Regulated or Unregulated Emissions Unit? (Check one, if applying for an initial, revised or renewal Title V air operation permit. Skip this item if applying for an air construction permit or FESOP only.)
- The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.
- The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in this Section: (Check one)
- This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).
- This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.
- This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.
2. Description of Emissions Unit Addressed in this Section:
One nominal 300 hp Emergency Diesel Fire Pump Engine
3. Emissions Unit Identification Number: **014**
- | | | | |
|--|--------------------------------|--------------------------|--|
| 4. Emissions Unit Status Code:
A | 5. Commence Construction Date: | 6. Initial Startup Date: | 7. Emissions Unit Major Group SIC Code:
49 |
|--|--------------------------------|--------------------------|--|
8. Federal Program Applicability: (Check all that apply)
- Acid Rain Unit
- CAIR Unit
9. Package Unit:
Manufacturer: **Clarke Fire Protection Products, Inc.** Model Number: **JU6H-UFAD98**
10. Generator Nameplate Rating: **0.234 MW**
11. Emissions Unit Comment: 315 bhp manufactured 9/2012.

EMISSIONS UNIT INFORMATION

Section [3]

Emergency Diesel Fire Pump Engine

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Emissions Unit Control Equipment/Method: Control ____ of ____

1. Control Equipment/Method Description:

2. Control Device or Method Code:

EMISSIONS UNIT INFORMATION

Section [3]

Emergency Diesel Fire Pump Engine

C. EMISSION POINT (STACK/VENT) INFORMATION**(Optional for unregulated emissions units.)****Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram:		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking:			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 17 feet		7. Exit Diameter: 0.79 feet
8. Exit Temperature: 744°F	9. Actual Volumetric Flow Rate: 1,750 acfm		10. Water Vapor: %
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates... Zone: East (km): North (km):		14. Emission Point Latitude/Longitude... Latitude (DD/MM/SS) Longitude (DD/MM/SS)	
15. Emission Point Comment: Stack parameters are based on Table 2-7 of the Air Permit Application submitted in January 2009.			

EMISSIONS UNIT INFORMATION

Section [3]

Emergency Diesel Fire Pump Engine

D. SEGMENT (PROCESS/FUEL) INFORMATION

Segment Description and Rate: Segment 1 of 1

1. Segment Description (Process/Fuel Type): Internal Combustion Engines; Electric Generation; Distillate Oil; Reciprocating		
2. Source Classification Code (SCC): 2-01-001-02		3. SCC Units: 1000 Gallons Burned
4. Maximum Hourly Rate: 0.0172	5. Maximum Annual Rate: 1.72	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: 0.0015%	8. Maximum % Ash:	9. Million Btu per SCC Unit: 131
10. Segment Comment: Max hourly rate= 17.2 gal/hr x 1 kgal/1,000 gal = 0.0172 kgal/yr Max annual rate= 17.2 gal/hr x 100 hr/yr x 1 kgal/1,000 gal = 1.72 kgal/yr Hourly fuel usage based on manufacturer data.		

Segment Description and Rate: Segment ____ of ____

1. Segment Description (Process/Fuel Type):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment:		

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: PM		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 0.10 lb/hour 0.005 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 0.15 g/hp-hr Reference: Permit No. 0990042-006-AC		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Hourly emissions = 0.15 g/hp-hr x 315 hp x lb/453.6g = 0.10 lb/hr Annual emissions = 0.10 lb/hr x 100 hp/yr x ton/2,000 lb = 0.005 ton/yr			
11. Potential, Fugitive, and Actual Emissions Comment: The emergency diesel fire pump engine has a nominal power of 315 hp.			

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: RULE	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 0.15 g/hp-hr (NSPS Subpart IIII, 2009 or later)	4. Equivalent Allowable Emissions: 0.10 lb/hour 0.005 tons/year
5. Method of Compliance: Manufacturer Certification of Subpart IIII Standards	
6. Allowable Emissions Comment (Description of Operating Method): Date of manufacturer 9/2012.	

Allowable Emissions Allowable Emissions _ of _

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions _ of _

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

**F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION –
POTENTIAL, FUGITIVE, AND ACTUAL EMISSIONS**

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive, and Baseline & Projected Actual Emissions

1. Pollutant Emitted: NOx		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 2.08 lb/hour 0.104 tons/year		4. Synthetically Limited? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5. Range of Estimated Fugitive Emissions (as applicable): to tons/year			
6. Emission Factor: 3.0 g/hp-hr Reference: Permit No. 0990042-006-AC		7. Emissions Method Code:	
8.a. Baseline Actual Emissions (if required): tons/year		8.b. Baseline 24-month Period: From: To:	
9.a. Projected Actual Emissions (if required): tons/year		9.b. Projected Monitoring Period: <input type="checkbox"/> 5 years <input type="checkbox"/> 10 years	
10. Calculation of Emissions: Hourly emissions = 3.0 g/hp-hr x 315 hp x lb/453.6g = 2.08 lb/hr Annual emissions = 2.08 lb/hr x 100 hp/yr x ton/2,000 lb = 0.104 ton/yr			
11. Potential, Fugitive, and Actual Emissions Comment: The emergency diesel fire pump engine has a nominal power of 315 hp. Emission Limit of the total of NMHC and NOx is permitted to be 3.0 g/hp-hr.			

**F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -
ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: RULE	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units: 3.0 g/hp-hr (NSPS Subpart IIII 2009 or later)	4. Equivalent Allowable Emissions: 2.08 lb/hour 0.104 tons/year
5. Method of Compliance: Manufacturer Certification of Subpart IIII Standards	
6. Allowable Emissions Comment (Description of Operating Method): Date of manufacturer 9/2012.	

Allowable Emissions Allowable Emissions _ of _

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

Allowable Emissions Allowable Emissions _ of _

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year
5. Method of Compliance:	
6. Allowable Emissions Comment (Description of Operating Method):	

EMISSIONS UNIT INFORMATION

Section [3]

Emergency Diesel Fire Pump Engine

G. VISIBLE EMISSIONS INFORMATION

Complete Subsection G if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

Visible Emissions Limitation: Visible Emissions Limitation _____ of _____

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment:	

Visible Emissions Limitation: Visible Emissions Limitation _____ of _____

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3. Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment:	

EMISSIONS UNIT INFORMATION

Section [3]

Emergency Diesel Fire Pump Engine

H. CONTINUOUS MONITOR INFORMATION

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor ____ of ____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment:	

Continuous Monitoring System: Continuous Monitor ____ of ____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information... Manufacturer: Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment:	

EMISSIONS UNIT INFORMATION

Section [3]

Emergency Diesel Fire Pump Engine

I. EMISSIONS UNIT ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

<p>1. Process Flow Diagram: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____</p>
<p>2. Fuel Analysis or Specification: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input checked="" type="checkbox"/> Attached, Document ID: <u>RBEC-EU1-I2</u> <input type="checkbox"/> Previously Submitted, Date _____</p>
<p>3. Detailed Description of Control Equipment: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____</p>
<p>4. Procedures for Startup and Shutdown: (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____</p> <p><input type="checkbox"/> Not Applicable (construction application)</p>
<p>5. Operation and Maintenance Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought)</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously Submitted, Date _____</p> <p><input checked="" type="checkbox"/> Not Applicable</p>
<p>6. Compliance Demonstration Reports/Records:</p> <p><input type="checkbox"/> Attached, Document ID: _____ Test Date(s)/Pollutant(s) Tested: _____</p> <p><input type="checkbox"/> Previously Submitted, Date: _____ Test Date(s)/Pollutant(s) Tested: _____</p> <p><input type="checkbox"/> To be Submitted, Date (if known): _____ Test Date(s)/Pollutant(s) Tested: _____</p> <p><input type="checkbox"/> Not Applicable</p> <p>Note: For FESOP applications, all required compliance demonstration records/reports must be submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a compliance plan must be submitted at the time of application.</p>
<p>7. Other Information Required by Rule or Statute:</p> <p><input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable</p>

