RECEIVED

JUL 05 2002

BUREAU OF AIR REGULATION

TITLE V PERMIT RENEWAL APPLICATION LAKE WORTH UTILITIES CITY OF LAKE WORTH, FLORIDA

Prepared For: Lake Worth Utilities 1900 Second Avenue North Lake Worth, Florida 33461

Prepared By: Golder Associates Inc. 6241 NW 23rd Street, Suite 500 Gainesville, Florida 32653-1500

> July 2002 0237548

DISTRIBUTION:

- 4 Copies FDEP Bureau of Air Regulation
- 2 Copies Lake Worth Utilities
- 2 Copies Golder Associates Inc.
- 1 Copy Palm Beach County Health Department
- 1 Copy FDEP Southeast District Office



Department of Environmental Protection of Air Resources Management FUREAU OF AIR REGULATION

APPLICATION FOR AIR PERMIT - TITLE V SOURCE

I. APPLICATION INFORMATION

Identification of Facility

1.	Facility Owner/Company Name:		
	Lake Worth Utilities		
2.	Site Name:		
	Tom G. Smith Power Plant and Lake Worth V	Vater Treatment Pl	ant
3.	Facility Identification Number: 0990045		[] Unknown
4.	Facility Location:		_
	Street Address or Other Locator: 117 South	College Street	
	City: Lake Worth County: I	Palm Beach	Zip Code: 33460
5.	Relocatable Facility?	6. Existing Peri	mitted Facility?
	[] Yes [X] No	[X]Yes	[] No
<u>A</u> p	pplication Contact		
1.	Name and Title of Application Contact:		

1.	Name and Title of Ap	plication Con	tact:		
	Margaret Johnstone, Environmental Compliance Officer				
2.	Application Contact Mailing Address:				
	Organization/Firm:	City of Lake V	Vorth Utilities		
	Street Address:	1900 2nd Ave	nue North		
	City:	Lake Worth	State: FI	Zip Code:	33461
3.	Application Contact	Telephone Nur	nbers:		
	Telephone: (561)	586 - 1666	Fa	x: (561) 586 <u>-1702</u>	

Application Processing Information (DEP Use)

1. Date of Receipt of Application:	7/5/02
2. Permit Number:	0990045-003-AV
3. PSD Number (if applicable):	
4. Siting Number (if applicable):	

Purpose of Application

Air Operation Permit Application

Th	is	Application for Air Permit is submitted to obtain: (Check one)
[]	Initial Title V air operation permit for an existing facility which is classified as a Title V source.
[]	Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.
		Current construction permit number:
[]	Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application.
		Current construction permit number:
		Operation permit number to be revised:
[]	Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.)
		Operation permit number to be revised/corrected:
[X]	Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.
		Operation permit number to be revised: 0990045-002-AV
		Reason for revision: Title V Renewal, Current Permit Expires December 31, 2002
Aiı	• (Construction Permit Application
Th	s	Application for Air Permit is submitted to obtain: (Check one)
[]	Air construction permit to construct or modify one or more emissions units.
[]	Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.
[]	Air construction permit for one or more existing, but unpermitted, emissions units.

Owner/Authorized Representative or Responsible Official

1. Name and Title of Owner/Authorized Re	epresentative or Responsible Official:
--	--

Patrick D. Miller, Assistant City Manager/Utilities Director

2. Owner/Authorized Representative or Responsible Official Mailing Address:

Organization/Firm: City of Lake Worth Utilities Street Address: 1900 2nd Avenue North

City: Lake Worth

State: FL

Zip Code: **33461**

3. Owner/Authorized Representative or Responsible Official Telephone Numbers:

Telephone: (561) 586 - 1665

Fax: (561) 586 - 1702

4. Owner/Authorized Representative or Responsible Official Statement:

I, the undersigned, am the owner or authorized representative*(check here [X], if so) or the responsible official (check here [], if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit. Date 2002

Signature

Professional Engineer Certification

1. Professional Engineer Name: Scott A. McCann

Registration Number: 54172

2. Professional Engineer Mailing Address:

Organization/Firm: Golder Associates Inc.

Street Address: 6241 NW 23rd Street, Suite 500

City: Gainesville State: FL Zip Code: **32653-1500**

3. Professional Engineer Telephone Numbers:

Telephone: (352) 336 - 5600, Ext. 543 Fax: (352) 336 - 6603

^{*} Attach letter of authorization if not currently on file.

RECEIVED

4. Professional Engineer Statement:

BUREAU OF AIR REGULATION

I, the undersigned, hereby certify, except as particularly noted herein*. that:

- (1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and
- (2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [X], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

BUD MC

(seal)

* Attach any exception to certification statement.

DEP Form No. 62-210.900(1) - Form

Effective: 2/11/99

Form1_EU5 7/3/02

4

Scope of Application

Emissions Unit		Permit	Processing
ID	Description of Emissions Unit	Туре	Fee
001-005	MU-1 through MU-5; five 2,000-kW Diesel Generators		
006	GT-1; Gas Turbine #1		
007	S-1; Fossil Fuel Steam Generating Unit #1		
009	S-3; Fossil Fuel Steam Generating Unit #3		
011	CC1 (GT-2/S-5); Combined Cycle Combustion Turbine 2/Steam Unit 5		
012	T-10, T-11, and T-12 Fuel Oil Storage Tanks		
013	T-3, T-4, T-5, and T-8 Fuel Oil Storage Tanks; 5,000- and 950-gallon Lube Oil Storage Tanks and Fuel Oil Fittings and Pumps		

Application Processing Fee

Check one: [] Attached - Amount: \$:	[X] Not Applicable
--------------	--------------------------	--------------------

<u>Construction/Modification Information</u>	
1. Description of Proposed Project or Alterations:	
2. Projected or Actual Date of Commencement of Construction:	_
3. Projected Date of Completion of Construction:	
Application Comment	_
Application Comment	_

DEP Form No. 62-210.900(1) - Form Effective: 2/11/99

II. FACILITY INFORMATION

A. GENERAL FACILITY INFORMATION

Facility Location and Type

1.	Facility UTM Coor	dinates:			
	Zone: 17	East (km):	59	92.8 Nort	th (km): 2943.7
2.	Facility Latitude/Lo	ongitude:			
	Latitude (DD/MM/	SS): 26/ 36/ 45		Longitude (DD/MN	M/SS): 80 / 04 / 04
3.	Governmental	4. Facility Status	5.	Facility Major	6. Facility SIC(s):
	Facility Code:	Code:		Group SIC Code:	
	4	A		49	4931
7.	Facility Comment (limit to 500 characters):			

Facility Contact

1.	Name and Title of Facility Contact:				
	Margaret Johnstone, Environmental Compliance Officer				
2.	Facility Contact Ma	iling Address:			
	Organization/Firm:	City of Lake Wo	rth Utilities		
	Street Address:	1900 2nd Avenu	e North		
	City:	Lake Worth	State:	FL	Zip Code: 33461
3.	Facility Contact Tel	ephone Numbers	S:		

Telephone: (561) 586 - 1666 Fax: (561) 586 - 1702

Facility Regulatory Classifications

Check all that apply:

1. [] Small Business Stationary Source? [] Unknown
2. [X] Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)?
3. [] Synthetic Minor Source of Pollutants Other than HAPs?
4. [] Major Source of Hazardous Air Pollutants (HAPs)?
5. [] Synthetic Minor Source of HAPs?
6. [X] One or More Emissions Units Subject to NSPS?
7. [] One or More Emission Units Subject to NESHAP?
8. [] Title V Source by EPA Designation?
9. Facility Regulatory Classifications Comment (limit to 200 characters):

List of Applicable Regulations

Federal:
rederal.
40 CFR 72 Acid Rain Program
40 CFR 73 SO, Allowance System
\cdot
40 CFR 75 Continuous Emissions Monitoring
State:
Title V Core List (3/1/02), Presumptively Applicable (Federal & State)

B. FACILITY POLLUTANTS

List of Pollutants Emitted

1. Pollutant Emitted	2. Pollutant Classif.	3. Requested En	missions Cap	4. Basis for Emissions	5. Pollutant Comment
Emitted	Classii.	lb/hour	tons/year	Cap	Comment
SO ₂	Α	_			
NO _x	Α				
PM	Α				
со	Α				
voc	В				
PM ₁₀	Α				
					,

C. FACILITY SUPPLEMENTAL INFORMATION

Supplemental Requirements

1.	Area Map Showing Facility Location:
	[X] Attached, Document ID: <u>LW-FI-C1</u> [] Not Applicable [] Waiver Requested
2.	Facility Plot Plan:
	[X] Attached, Document ID: <u>LW-FI-C2</u> [] Not Applicable [] Waiver Requested
3.	Process Flow Diagram(s):
	[X] Attached, Document ID: <u>LW-FI-C3</u> [] Not Applicable [] Waiver Requested
4.	Precautions to Prevent Emissions of Unconfined Particulate Matter:
	[X] Attached, Document ID: <u>LW-FI-C4</u> [] Not Applicable [] Waiver Requested
5.	Fugitive Emissions Identification:
	[X] Attached, Document ID: <u>LW-FI-C5</u> [] Not Applicable [] Waiver Requested
6.	Supplemental Information for Construction Permit Application:
	[] Attached, Document ID: [X] Not Applicable
7.	Supplemental Requirements Comment:

Additional Supplemental Requirements for Title V Air Operation Permit Applications

8. List of Proposed Insignificant Activities:
[X] Attached, Document ID: <u>LW-FI-C8</u>] Not Applicable
9. List of Equipment/Activities Regulated under Title VI:
[] Attached, Document ID:
[] Equipment/Activities On site but Not Required to be Individually Listed
[X] Not Applicable
10. Alternative Methods of Operation:
[] Attached, Document ID: [X] Not Applicable
11. Alternative Modes of Operation (Emissions Trading):
[] Attached, Document ID: [X] Not Applicable
12. Identification of Additional Applicable Requirements:
[X] Attached, Document ID: <u>LW-FI-C12</u> [] Not Applicable
13. Risk Management Plan Verification:
[X] Plan previously submitted to Chemical Emergency Preparedness and Prevention Office (CEPPO). Verification of submittal attached (Document ID: <u>LW-FI-C13</u>) or previously submitted to DEP (Date and DEP Office:)
[] Plan to be submitted to CEPPO (Date required:)
[] Not Applicable
14. Compliance Report and Plan:
[] Attached, Document ID: [X] Not Applicable
15. Compliance Certification (Hard-copy Required):
[] Attached, Document ID: [X] Not Applicable

ATTACHMENT LW-FI-A

APPLICABLE REGULATIONS

Title V Core List

[Note: The Title V Core List is meant to simplify the completion of the "List of Applicable Regulations" for DEP Form No. 62-210.900(1), Application for Air Permit - Long Form. The Title V Core List is a list of rules to which all Title V Sources are presumptively subject. The Title V Core List may be referenced in its entirety, or with specific exceptions. The Department may periodically update the Title V Core List.]

Federal:

(description)

- 40 CFR 61, Subpart M: NESHAP for Asbestos.
- 40 CFR 82: Protection of Stratospheric Ozone.
- 40 CFR 82, Subpart B: Servicing of Motor Vehicle Air Conditioners (MVAC).
- 40 CFR 82, Subpart F: Recycling and Emissions Reduction.

State:

(description)

CHAPTER 62-4, F.A.C.: PERMITS, effective 06-01-01

- 62-4.030, F.A.C.: General Prohibition.
- 62-4.040, F.A.C.: Exemptions.
- 62-4.050, F.A.C.: Procedure to Obtain Permits; Application.
- 62-4.060, F.A.C.: Consultation.
- 62-4.070, F.A.C.: Standards for Issuing or Denying Permits; Issuance; Denial.
- 62-4.080, F.A.C.: Modification of Permit Conditions.
- 62-4.090, F.A.C.: Renewals.
- 62-4.100, F.A.C.: Suspension and Revocation.
- 62-4.110, F.A.C.: Financial Responsibility.
- 62-4.120, F.A.C.: Transfer of Permits.
- 62-4.130, F.A.C.: Plant Operation Problems.
- 62-4.150, F.A.C.: Review.
- 62-4.160, F.A.C.: Permit Conditions.
- 62-4.210, F.A.C.: Construction Permits.
- 62-4.220, F.A.C.: Operation Permit for New Sources.

CHAPTER 62-210, F.A.C.: STATIONARY SOURCES - GENERAL REQUIREMENTS, effective 06-21-01

- 62-210.300, F.A.C.: Permits Required.
- 62-210.300(1), F.A.C.: Air Construction Permits.
- 62-210.300(2), F.A.C.: Air Operation Permits.
- 62-210.300(3), F.A.C.: Exemptions.
- 62-210.300(5), F.A.C.: Notification of Startup.
- 62-210.300(6), F.A.C.: Emissions Unit Reclassification.
- 62-210.300(7), F.A.C.: Transfer of Air Permits.

Effective: 03/01/02

Title V Core List

- 62-210.350, F.A.C.: Public Notice and Comment.
- 62-210.350(1), F.A.C.: Public Notice of Proposed Agency Action.
- 62-210.350(2), F.A.C.: Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment-Area Preconstruction Review.
- 62-210.350(3), F.A.C.: Additional Public Notice Requirements for Sources Subject to Operation Permits for Title V Sources.
- 62-210.360, F.A.C.: Administrative Permit Corrections.
- 62-210.370(3), F.A.C.: Annual Operating Report for Air Pollutant Emitting Facility.
- 62-210.400, F.A.C.: Emission Estimates.
- 62-210.650, F.A.C.: Circumvention.
- 62-210.700, F.A.C.: Excess Emissions.
- 62-210.900, F.A.C.: Forms and Instructions.
- 62-210.900(1), F.A.C.: Application for Air Permit Title V Source, Form and Instructions.
- 62-210.900(5), F.A.C.: Annual Operating Report for Air Pollutant Emitting Facility, Form and Instructions.
- 62-210.900(7), F.A.C.: Application for Transfer of Air Permit Title V and Non-Title V Source.

CHAPTER 62-212, F.A.C.: STATIONARY SOURCES - PRECONSTRUCTION REVIEW, effective 08-17-00

CHAPTER 62-213, F.A.C.: OPERATION PERMITS FOR MAJOR SOURCES OF AIR POLLUTION, effective 04-16-01

- 62-213.205, F.A.C.: Annual Emissions Fee.
- 62-213.400, F.A.C.: Permits and Permit Revisions Required.
- 62-213.410, F.A.C.: Changes Without Permit Revision.
- 62-213.412, F.A.C.: Immediate Implementation Pending Revision Process.
- 62-213.415, F.A.C.: Trading of Emissions Within a Source.
- 62-213.420, F.A.C.: Permit Applications.
- 62-213.430, F.A.C.: Permit Issuance, Renewal, and Revision.
- 62-213.440, F.A.C.: Permit Content.
- 62-213.450, F.A.C.: Permit Review by EPA and Affected States
- 62-213.460, F.A.C.: Permit Shield.
- 62-213.900, F.A.C.: Forms and Instructions.
- 62-213.900(1), F.A.C.: Major Air Pollution Source Annual Emissions Fee Form.
- 62-213.900(7), F.A.C.: Statement of Compliance Form.

Effective: 03/01/02

Title V Core List

CHAPTER 62-296, F.A.C.: STATIONARY SOURCES - EMISSION STANDARDS, effective 03-02-99

62-296.320(4)(c), F.A.C.: Unconfined Emissions of Particulate Matter.

62-296.320(2), F.A.C.: Objectionable Odor Prohibited.

CHAPTER 62-297, F.A.C.: STATIONARY SOURCES - EMISSIONS MONITORING, effective 03-02-99

62-297.310, F.A.C.: General Test Requirements.

62-297.330, F.A.C.: Applicable Test Procedures.

62-297.340, F.A.C.: Frequency of Compliance Tests.

62-297.345, F.A.C.: Stack Sampling Facilities Provided by the Owner of an Emissions Unit.

62-297.350, F.A.C.: Determination of Process Variables.

62-297.570, F.A.C.: Test Report.

62-297.620, F.A.C.: Exceptions and Approval of Alternate Procedures and Requirements.

Miscellaneous:

CHAPTER 28-106, F.A.C.: Decisions Determining Substantial Interests

CHAPTER 62-110, F.A.C.: Exception to the Uniform Rules of Procedure, effective 07-01-98

CHAPTER 62-256, F.A.C.: Open Burning and Frost Protection Fires, effective 11-30-94


CHAPTER 62-257, F.A.C.: Asbestos Notification and Fee, effective 02-09-99

CHAPTER 62-281, F.A.C.: Motor Vehicle Air Conditioning Refrigerant Recovery and Recycling, effective 09-10-96

Effective: 03/01/02

ATTACHMENT LW-FI-C1

AREA MAP



Attachment LW-FI-C1. Area Map Lake Worth Utilities, City of Lake Worth, Florida

Source: Golder, 2002.



ATTACHMENT LW-FI-C2
FACILITY PLOT PLAN

ATTACHMENT LW-FI-C3

PROCESS FLOW DIAGRAM

(Process flow diagrams for each emission unit are presented in the emission unit information section of the application.)



PRECAUTIONS TO PREVENT EMISSIONS OF UNCONFINED PARTICULATE MATTER

ATTACHMENT LW-FI-C4

PRECAUTIONS TO PREVENT EMISSIONS OF UNCONFINED PARTICULATE MATTER

The facility has negligible amounts of unconfined particulate matter as a result of the operation of the facility. Sources of particulate matter include:

- Fugitive dust from paved and unpaved roads, and
- Fugitive particulates from the use of bagged chemical products.

Operational measures are undertaken at the facility which also minimize particulate emissions, in accordance with 62-296.320(4)(c)2, F.A.C.:

- Maintenance of paved areas,
- · Regular mowing of grass and care of vegetation, and
- Limiting access to plant property by unnecessary vehicles.

ATTACHMENT LW-FI-C5 FUGITIVE EMISSIONS IDENTIFICATION

ATTACHMENT LW-FI-C5

FUGITIVE EMISSIONS IDENTIFICATION

CALCULATION OF FUGITIVE EMISSIONS FROM PIPING

Fugitive vapor emissions that result from the leaking of connections and seals in the fuel oil and lubrication oil piping systems throughout the plant were quantified. The components at the Tom G. Smith Power Plant contributing to these emissions are the following:

Pump Seals Valves Flange Joints Open-Ended Lines

CALCULATIONAL METHODS

The first step in quantifying the fugitive emissions from piping is to obtain a count of the above items. Rather than attempt to physically count these numerous components, their quantities can be estimated using estimating factors based on pump count. Equipment counts are estimated by multiplying the number of pumps in service by the appropriate factor. The factors are from "Improving Air Quality: Guidance for Estimating Fugitive Emissions from Equipment," published by the Chemical Manufacturers Association, 1989. The factors were based on counts obtained in the chemical processing industry, where piping configurations are often more complicated than in a typical power plant. It therefore is justifiable to use component count estimating factors from the "low" column. These factors are as follows:

Equipment Item	Components Per Liquid Pump
Pump	1
Valves	20
Flanges	59
Open Ended Lines	0.25

The pump count was obtained by examining process diagrams, conducting the plant walkdown and interviewing plant personnel. Spared pumps were not included in the count. Piping fugitive emissions are based on pump running times. Due to the difficulties associated with obtaining precise pump run times, the operating periods of the units is used instead. Therefore, the pump count is intended to reflect those pumps that continuously run while the various units run. This count was overstated somewhat to reflect the reduced run times of forwarding pumps that periodically cycle.

Fugitive emissions from piping are calculated using emissions factors found in Table 9.1-10 of AP-42. The factors depend on the designation of the fluid as "heavy" or "light". This classification is based on the vapor pressure of the liquid. Diesel, No. 6 fuel oil, and lube oil all qualify as heavy liquids. Along with component counts, pump run times are required for the calculation. As noted above, unit run times will be used as a surrogate for pump run times. Unit run times were taken from the 1994 and 1995 Annual Operating Reports. The resulting emissions for these two years were averaged to obtain actual emissions. The calculations and results are displayed in Table F-1.

TABLE 4-8. CITY OF LAKE WORTH TOM G. SMITH POWER PLANT TITLE V AIR PERMIT APPLICATION ESTIMATION OF FUGITIVE VAPOR EMISSIONS FROM FUEL OIL PIPING

RAYTHEON ENGINEERS AND CONSTRUCTORS

UNIT	FUEL	PUMP COUNT	EM (HE C	UMP MISSIONS p/hr)	VALVE COUNT	(I	/ALVE :MISSIONS lb/hr)	FLANGE COUNT	FLANGE EMISSIONS (lb/hr)	OPEN ENDED LINE COUNT	OPEN ENDED LINE EMISSIONS (Ib/hr) K	TOTAL PIPING FUGITIVE EMISSIONS (Ib/hr)	1994 OPERATING HOURS (hre) M	TOTAL 1994 PIPING FUGITIVE EMISSIONS (lb/yr) N	1895 OPERATING HOURS (hrs)	TOTAL 1886 PIPING FUGITIVE EMISSIONS (Ib/yr) P	AVERAGE 1894-85 PIPING FUGITIVE EMISSIONS (Ib/yr)	AVERAGE 1994-95 PIPING FUGITIVE EMISSIONS (tone/yr)
l 				46*A	20 A		0006 • D	69*A	.00066°G	.26 ° A	.006*J	(C+F+I+K)		L*M		L*0	AVG(N,P)	AVG(N,P)/2000
S-1	NO, 5 LUBE		3 1	0.138 0.046		0	0.03 0.01	177 59	0.09912 0.03304	0.76 0.25			34 34		59 59	16.98 5.33	12,60 4,20	
S-3	NO. 5		3	0.138	6	0	0.03	177	0.09912	0.76	0.00376	0,27087	1497	405.49	2817	783,04	584.27	0.29
	LUBE		1	0.048	2	0	0.01	59	0.03304	0.26	0.00125	0.09029	1497	135.18	2817	254.35	194.76	0.10
GT-1	NO. 2		2	0.092	4		0.02	118				0.18058	13	2.36	20	3.61	2.98	0,00
	LUBE		1	0.046	2	0	0.01	59	0.03304	0.25	0.00125	0.09029	13	1.17	20	1.81	1.49	0.00
GT-2/S-6	NO. 2		1	0.046	2	0	0.01	59	0.03304	0.26	0.00126	0.09029	7448	672.48	8278	688.67	619.52	0.31
	LUBE		1	0.046	2	0	0.01	59	0,03304	0.26	0.00126	0.09029	7448	672.48	6275	688,67	619.52	0.31
MU 1-6	NO. 2		2	0.092	4	0	0.02	118	0.06806	0.6	0.0025	0.18068	60	9.03	679	104.66	56.79	0.03
TOTAL														1910.46		2281.81	2096.13	1.05

NOTES: 1. COMPONENT COUNT ESTIMATION IS PER "IMPROVING AIR QUALITY; GUIDANCE FOR ESTIMATING FUGITIVE EMISSIONS FORM EQUIPMENT", CHEMICAL MANUFACTURERS ASSICIATION, 1989, THE ABOVE ARE TAKEN FROM THE LOW COLUMN IN THE TABLE OF COMPONENTS PER LIQUID PUMP.

2. THE EMISSION FACTORS ARE TAKEN FROM THE TABLE OF AVERAGE SOCMI EMISSION FACTORS IN THE ABOVE REFERENCE. NO. 2 AND NO. 5 FUEL OILS AND THE LUBE OILS ARE TAKEN TO BE HEAVY LIQUIDS.

3. OPERATING HOURS ARE TAKEN FROM THE 1984 AND 1885 ANNUAL OPERATING REPORTS.

ATTACHMENT LW-FI-C8

LIST OF PROPOSED INSIGNIFICANT ACTIVITIES

UNREGULATED EMISSION UNITS AND EXEMPT ACTIVITIES (REVISED 7/97)

1. Dust Collector Hopper Discharge Valve

Exemption Basis: This unit should be exempt based on the minimal amount of material passing through the valve, the small frequency of usage, and work practices that precludes the generation of fugitive emissions.

This valve is used to remove ash from Unit S-3 following the use of oil. Oil has historically been used very sparingly in the S-3 unit (i.e. <1% oil use annually), therefore, very little ash is generated. The hopper is emptied on an as needed basis. Historically, when emptied, the ash fills on average, four 55 gallon drums/year. To minimize fugitive emissions generation, prior to opening the valve, the outlet is connected to a hose which is inserted into a fabricated hood connected to the 55 gallon drum. This design precludes the generation of fugitive emissions.

2. Liquid Propane Gas Emergency Generator 120 gal. tank

Exemption Basis Rule 62-210.300(3)(a)(20) F.A.C. This unit has historically burned much less than 4.4 million scf/yr and will continue to do so in the future.

ATTACHMENT A

LIST OF ACTIVITIES THAT MAY BE TREATED AS "TRIVIAL"

The following types of activities and emissions units may be presumptively omitted from part 70 permit applications. Certain of these listed activities include qualifying statements intended to exclude many similar activities.

Combustion emissions from propulsion of mobile sources, except for vessel emissions from Outer Continental Shelf sources.

Air-conditioning units used for human comfort that do not have applicable requirements under title VI of the Act.

Ventilating units used for human comfort that do not exhaust air pollutants into the ambient air from any manufacturing/industrial or commercial process.

Non-commercial food preparation.

Consumer use of office equipment and products, not including printers or businesses primarily involved in photographic reproduction.

Janitorial services and consumer use of janitorial products.

Internal combustion engines used for landscaping purposes.

Laundry activities, except for dry-cleaning and steam boilers.

Bathroom/toilet vent emissions.

Emergency (backup) electrical generators at residential \checkmark

Tobacco smoking rooms and areas.

Blacksmith forges.

Plant maintenance and upkeep activities (e.g., grounds-keeping, general repairs, cleaning, painting, welding, plumbing, re-tarring roofs, installing insulation, and paving parking lots) provided these activities are not conducted as part of a manufacturing process, are not related to the source's primary business activity, and not

otherwise triggering a permit modification.1

Repair or maintenance shop activities not related to the source's primary business activity, not including emissions from surface coating or de-greasing (solvent metal cleaning) activities, and not otherwise triggering a permit modification.

Portable electrical generators that can be moved by hand from one location to another².

Hand-held equipment for buffing, polishing, cutting, drilling, sawing, grinding, turning or machining wood, metal or plastic.

Brazing, soldering and welding equipment, and cutting torches related to manufacturing and construction activities that do not result in emission of HAP metals.

Air compressors and pneumatically operated equipment, including hand tools.

Batteries and battery charging stations, except at battery manufacturing plants.

Storage tanks, vessels, and containers holding or storing liquid substances that will not emit any VOC or HAP. \checkmark

^{&#}x27;Cleaning and painting activities qualify if they are not subject to VOC or HAP control requirements. Asphalt batch plant owners/operators must still get a permit if otherwise required.

²"Moved by hand" means that it can be moved without the assistance of any motorized or non-motorized vehicle, conveyance, or device.

³Brazing, soldering and welding equipment, and cutting torches related to manufacturing and construction activities that emit HAP metals are more appropriate for treatment as insignificant activities based on size or production level thresholds. Brazing, soldering, welding and cutting torches directly related to plant maintenance and upkeep and repair or maintenance shop activities that emit HAP metals are treated as trivial and listed separately in this appendix.

Exemptions for storage tanks containing petroleum liquids or other volatile organic liquids should be based on size limits such as storage tank capacity and vapor pressure of liquids stored and are not appropriate for this list.

Storage tanks, reservoirs, and pumping and handling equipment of any size containing soaps, vegetable oil, grease, animal fat, and nonvolatile aqueous salt solutions, provided appropriate lids and covers are utilized.

Equipment used to mix and package, soaps, vegetable oil, grease, animal fat, and nonvolatile aqueous salt solutions, provided appropriate lids and covers are utilized.

Drop hammers or hydraulic presses for forging or metalworking.

Equipment used exclusively to slaughter animals, but not including other equipment at slaughterhouses, such as rendering cookers, boilers, heating plants, incinerators, and electrical power generating equipment.

Vents from continuous emissions monitors and other analyzers.

Natural gas pressure regulator vents, excluding venting at oil and gas production facilities.

Hand-held applicator equipment for hot melt adhesives with no VOC in the adhesive formulation.

Equipment used for surface coating, painting, dipping or spraying operations, except those that will emit VOC or HAP.

CO. lasers, used only on metals and other materials which do not emit HAP in the process.

Consumer use of paper trimmers/binders.

Electric or steam-heated drying ovens and autoclaves, but not the emissions from the articles or substances being processed in the ovens or autoclaves or the boilers delivering the steam.

Salt baths using nonvolatile salts that do not result in emissions of any regulated air pollutants.

Laser trimmers using dust collection to prevent fugitive emissions.

Bench-scale laboratory equipment used for physical or chemical analysis, but not lab fume hoods or vents.

⁵Many lab fume hoods or vents might qualify for treatment as insignificant (depending on the applicable SIP) or be grouped together for purposes of description.

Routine calibration and maintenance of laboratory equipment or other analytical instruments.

Equipment used for quality control/assurance or inspection purposes, including sampling equipment used to withdraw materials for analysis.

Hydraulic and hydrostatic testing equipment.

Environmental chambers not using hazardous air pollutant (HAP) gasses.

Shock chambers.

Humidity chambers.

Solar simulators.

Fugitive emission related to movement of passenger vehicles, provided the emissions are not counted for applicability purposes and any required fugitive dust control plan or its equivalent is submitted.

Process water filtration systems and demineralizes.

Demineralized water tanks and demineralizer vents.

Boiler water treatment operations, not including cooling towers.

Oxygen scavenging (de-aeration) of water.

Ozone generators.

Fire suppression systems.

Emergency road flares.

Steam vents and safety relief valves.

Steam leaks.

Steam cleaning operations.

Steam sterilizers.

ATTACHMENT LW-FI-C12

IDENTIFICATION OF ADDITIONAL APPLICABLE REQUIREMENTS

City of Lake Worth Utilities Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Facility ID No.: 0990045 Palm Beach County

Initial Title V Air Operation Permit FINAL Permit No.: 0990045-002-AV

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Title V Section

Mail Station #5505 2600 Blair Stone Road Tallahassee, Florida 32399-2400

Telephone: 850/488-1344 Fax: 850/922-6979

Initial Title V Air Operation Permit **FINAL Permit No.:** 0990045-002-AV

Table of Contents

Section	Page Number
Placard Page	1
I. Facility Information	2 - 3
A. Facility Description.	
B. Summary of Emissions Unit ID No(s). and Brief Description(s).	
C. Relevant Documents.	
II. Facility-wide Conditions	4 - 6
III. Emissions Unit(s) and Conditions	
A. Emissions Units 001 through 005, Diesel Engine Generators 1 - 5	7 - 8
B. Emissions Unit 007, Fossil Fuel Steam Generating Unit 1, S-1	9 - 10
C. Emissions Unit 009, Fossil Fuel Steam Generating Unit 3, S-3	
Emissions Unit 010, Fossil Fuel Steam Generating Unit 4, S-4	11 - 14
D. Emissions Unit 006, Gas Turbine # 1, GT-1	
Emissions Unit 011, Combined Cycle Unit, GT-2/S-5	15 - 16
E. Common Conditions, Emissions Units 001 through 011	17 - 23
IV. Acid Rain Part	
A. Acid Rain, Phase II	24
Attachments	end

Permittee:

City of Lake Worth Utilities

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045 SIC Nos.: 49, 4931

Project: Initial Title V Air Operation Permit

This permit is for the operation of the Tom G. Smith Power Plant and Lake Worth Water Treatment Plant. This facility is located at 117 College Street, Lake Worth, FL 33461; UTM Coordinates: Zone 17, 592.8 km East and 2943.7 km North; Latitude: 26° 36' 45" North and Longitude: 80° 04' 04" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix U-1, List of Unregulated Emissions Units and/or Activities Appendix I-1, List of Insignificant Emissions Units and/or Activities Appendix TV-1, Title V Conditions (version dated 12/02/97) Appendix SS-1, Stack Sampling Facilities (version dated 10/07/96) Table 297.310-1, Calibration Schedule (version dated 10/07/96) Phase II Acid Rain Application/Compliance Plan received 07/01/95 Alternate Sampling Procedure: ASP Number 97-B-01 Scrivener's Order dated July 9, 1997 correcting ASP 97-B-01 Order Extending Permit Expiration Date (dated 11/04/97)

Effective Date: January 1, 1998

Renewal Application Due Date: July 5, 2002

Expiration Date: December 31, 2002

Howard L. Rhodes, Director Division of Air Resources Management

HLR/sms/jk

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 2 of 24

Section I. Facility Information.

Subsection A. Facility Description.

This facility is an electric power generating plant and an adjacent potable water treatment facility and consists of:

Five 2000 kW diesel engine generators; Fossil Fuel Steam Generating Units 1 (S-1), 3 (S-3) and 4 (S-4); Gas Turbine # 1, (GT-1); and a Combined Cycle Unit, (GT-2/S-5).

Also included in this permit are miscellaneous unregulated/insignificant emissions units and/or activities.

No activities at the water treatment plant were required to be included in this permit as emissions units.

Based on the initial Title V permit application received June 13, 1996, this facility is not a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).

E.U. ID	
No.	Brief Description
001 -	Five 2000 kW diesel engine generators, an MP 36 Power Pack; each diesel
005	generator is a model 567D4 manufactured by GM Electro Motive Division.
007	Fossil Fuel Steam Generating Unit 1 (S-1), nominally rated at 7.5 MW, 111
	mmBtu/hr, capable of burning any combination of natural gas and number 6 fuel
	oil, with emissions exhausted through a 60 ft. stack
009	Fossil Fuel Steam Generating Unit 3 (S-3), nominally rated at 26.5 MW, 325.1
	mmBtu/hr, capable of burning any combination of natural gas and number 6 fuel
	oil, with emissions exhausted through a 113 ft. stack
010	Fossil Fuel Steam Generating Unit 4, (S-4), nominally rated at 33 MW, 419.1
	mmBtu/hr, capable of burning any combination of natural gas and number 6 fuel
	oil, with emissions exhausted through a 115 ft. stack
006	Gas Turbine # 1, (GT-1), nominally rated at 30 MW, 435 mmBtu/hr, capable of
	burning number 2 fuel oil, with emissions exhausted through a 46 ft. stack
011	Combined Cycle Unit, (GT-2/S-5), nominally rated at 29.5 MW, consists of a gas
	turbine (GT-2) nominally rated at 20 MW and a heat recovery steam generator (S5)
	nominally rated at 10 MW. GT-2 has a maximum heat input of 317.6 mmBtu/hr,
	capable of burning any combination of natural gas and number 2 fuel oil, with
	emissions exhausted through a 75 ft. stack

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 3 of 24

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only: Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers Appendix H-1, Permit History/ID Number Changes Table 1-1, Summary of Air Pollutant Standards and Terms Table 2-1, Summary of Compliance Requirements

These documents are on file with the permitting authority: Initial Title V Permit Application received June 13, 1996 Additional Information Request dated May 5, 1997 Additional Information Response received July 31, 1997

City of Lake Worth Utilities **FINAL Permit No.:** 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 4 of 24

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

- 1. APPENDIX TV-1, TITLE V CONDITIONS, is a part of this permit. {Permitting note: APPENDIX TV-1, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.
- 2. Not Federally Enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor. [Rule 62-296.320(2), F.A.C.]
- 3. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. [Rule 62-296.320(4)(b)1. & 4, F.A.C.]

- 4. Prevention of Accidental Releases (Section 112(r) of CAA). If required by 40 CFR 68, the permittee shall submit to the implementing agency:
 - a. a risk management plan (RMP) when, and if, such requirement becomes applicable; and
- b. certification forms and/or RMPs according to the promulgated rule schedule. [40 CFR 68]
- 5. Insignificant Emissions Units and/or Activities. Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit. [Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]
- 6. Not Federally Enforceable. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. The owner or operator shall:
 - a. Tightly cover or close all VOC or OS containers when they are not in use.
 - b. Immediately clean up VOC or OS spills and make sure wastes are placed in closed containers for reuse, recycling or proper disposal.

[Rule 62-296.320(1)(a), F.A.C.]

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 5 of 24

- 7. Not Federally Enforceable. Unconfined Particulate Matter. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include:
 - a. When performing sandblasting on fixed plant equipment, the facility shall construct temporary enclosures when practical and necessary, in order to prevent unconfined particulate emissions.
 - b. Maintenance of paved areas as needed.
 - c. Regular care of vegetation.
 - d. Limiting access to plant property by unnecessary vehicles.
 - e. Bagged chemical products shall be stored in buildings until they are used.
 - f. Spills of powdered chemical products are cleaned up as soon as practicable.
 - g. Sweeping paved roads with a wet vacuum truck.
 - h. Watering, if necessary, the lime backwash residue holding area.

[Rule 62-296.320(4)(c)2., F.A.C.; Items 7.g. & h. proposed by applicant in the Additional Information Response received July 31, 1997]

{Note: This condition implements the requirements of Rules 62-296.320(4)(c)1., 3., & 4. F.A.C. (condition 58 of Appendix TV-1, dated 12/02/97).}

- 8. When appropriate, any recording, monitoring or reporting requirements that are time-specific shall be in accordance with the effective date of this permit, which define day one. [Rule 62-213.440, F.A.C.]
- 9. Submittals. All reports, tests, notifications or other submittals required by this permit shall be submitted to the Palm Beach County Health Department's Air Section, and copies of those submittals shall be sent to the Department of Environmental Protection, Southeast District Office, Air Section. Addresses and telephone numbers are:

Palm Beach County Health Department Air Section PO Box 29 West Palm Beach, FL 33402-0029

Phone: 561/355-3070

Department of Environmental Protection Southeast District Office, Air Section PO Box 15425 West Palm Beach, FL 33416

Phone: 561/681-6600

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 6 of 24

Any reports, data, notifications, certifications and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency Region 4 Air, Pesticides & Toxics Management Division Operating Permits Section 61 Forsyth Street Atlanta, GA 30303 Phone: 404/562-9099

Fax: 404/562-9095

For Acid Rain submittals, submittals should be sent to:

United States Environmental Protection Agency Region 4 Air, Pesticides & Toxics Management Division Acid Rain Section 61 Forsyth Street Atlanta, GA 30303

10. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year. {See condition No. 52., Appendix TV-1, Title V Conditions} [Rule 62-214.420(11), F.A.C.]

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 7 of 24

Section III. Emissions Unit(s) and Conditions.

Subsection A. This section addresses the following emissions units.

E.U. ID	
No.	Brief Description
001 -	Five 2000 kW diesel engine generators, an MP 36 Power Pack; each diesel
005	generator is a model 567D4 manufactured by GM Electro Motive Division.

{Permitting note(s): These emissions units are regulated under Rule 62-296.570, F.A.C., NOx RACT.}

The following specific conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

A.1. Methods of Operation - (i.e., Fuels). These emissions units shall burn only diesel fuel. [Rule 62-213.410, F.A.C.]

Emission Limitations and Standards

{Note: Emissions units 001 through 005 are also subject to the visible emissions standard of specific condition 3 of this permit.}

A.2. NOx RACT. Emissions of nitrogen oxides (NOx) from these emissions units shall not exceed 4.75 pounds per million Btu. [Rule 62-296.570, F.A.C.]

Test Methods and Procedures

A.3. NOx Testing. Compliance with the NOx emission limitation shall be demonstrated by annual emission testing in accordance with EPA Test Method 7E. [Rule 62-296.570, F.A.C.]

Monitoring of Operations

A.4. Annual Tests Required - NOx and VE. Except as provided in specific conditions **E.6** through **E.8** of this permit, emission testing for nitrogen oxide emissions and visible emissions shall be performed annually, no later than the end of each federal fiscal year (September 30), except for units that are not operating because of scheduled maintenance outages and emergency repairs, which will be tested within thirty days of returning to service. Annual compliance testing while firing oil is not required for units that operated on oil for less than 400 hours in the previous federal fiscal year (ending September 30th). [Rules 62-4.070(3) and 62-213.440, F.A.C.]

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 8 of 24

Record Keeping and Reporting Requirements

- **A.5.** The owner or operator shall make and keep records of:
 - a. The number of hours each emissions unit operates every calendar month; and
- b. The total fuel consumption of all five units combined each calendar month. Such monthly records shall be prepared no later than fifteen days after the end of each month. [Rule 62-4.070(3), F.A.C.]

Common Conditions

A.6. This emissions unit is also subject to conditions E.1 through E.19, except for E.3, E.10, E.11 and E.18, contained in Subsection E. Common Conditions.

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 9 of 24

Subsection B. This section addresses the following emissions unit.

E.U. ID	
No.	Brief Description
007	Fossil Fuel Steam Generating Unit 1 (S-1), nominally rated at 7.5 MW, 111
	mmBtu/hr, capable of burning any combination of natural gas and number 6 fuel
	oil, with emissions exhausted through a 60 ft. stack

{Permitting note(s): The emissions unit is regulated under Rule 62-296.406, F.A.C., Fossil Fuel Steam Generators with Less than 250 million Btu per Hour Heat Input, and Rule 62-296.570, F.A.C., NOx RACT. Fossil fuel fired steam generator Unit 1 (S-1) began commercial operation in 1961.}

The following specific conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

B.1. Permitted Capacity. The maximum operation heat input rate is as follows:

Unit No.	mmBtu/hr Heat Input	Fuel Type
007	111	Natural Gas
	111	No. 6 Fuel Oil

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.406, F.A.C.]

B.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **E.14**. [Rule 62-297.310(2), F.A.C.]

B.3. Methods of Operation. Fuels.

- a. Startup: The only fuel(s) allowed to be burned are any combination of natural gas and/or number 6 fuel oil.
- b. Normal: The only fuel(s) allowed to be burned are any combination of natural gas and/or number 6 fuel oil.

[Rule 62-213.410, F.A.C.]

Emission Limitations and Standards

- **B.4.** <u>Visible Emissions</u>. Visible emissions shall not exceed 20 percent opacity, except for one two-minute period per hour during which opacity shall not exceed 40 percent. [Rule 62-296.406(1), F.A.C.]
- **B.5.** <u>Visible emissions Soot Blowing and Load Change</u>. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more. [Rule 62-210.700(3), F.A.C.]

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 10 of 24

- **B.6.** Particulate Matter. Particulate matter emissions shall be controlled by the firing of natural gas and/or low sulfur content liquid fuel. See specific condition **B.7**. [Rules 62-4.070(3) and 62-296.406(2), F.A.C.]
- **B.7.** Sulfur Dioxide Sulfur Content. The No. 6 fuel oil sulfur content shall not exceed 2.25 percent, by weight. See specific condition **B.10**. [Rules 62-4.070(3) and 62-296.406(3), F.A.C.; BACT for this unit assumed to equal the sulfur limit established by PPSC No. PA 74-05 for units S-3 and S-4]
- **B.8.** NOx RACT. Emissions of nitrogen oxides (NOx) from these emissions units shall not exceed 0.50 pounds per million Btu while firing natural gas or number 6 fuel oil. [Rule 62-296.570, F.A.C.]

Test Methods and Procedures

- **B.9.** Sulfur Dioxide Sulfur Content. The permittee shall demonstrate compliance with the liquid fuel sulfur limit by fuel sampling and analysis. See specific conditions **B.7.** and **B.10**. [Rules 62-213.440 and 62-296.406(3), F.A.C.]
- **B.10.** Fuel Sampling & Analysis Sulfur. For this emissions unit, the following fuel sampling and analysis protocol shall be used to demonstrate compliance with the fuel sulfur limitation of specific condition B.7 of this permit:
 - a. Sample the as-fired fuel oil each day fuel oil is fired.
- b. Composite the daily samples and each month determine and record the as-fired fuel sulfur content, percent by weight, for liquid fuels using either ASTM D2622-94, ASTM D4294-90(95), ASTM D1552-95, ASTM D1266-91, or both ASTM D4057-88 and ASTM D129-95 (or latest editions) to analyze a representative sample of the composited as-fired fuel oil. [Rules 62-4.070(3) and 62-213.440, F.A.C.]
- **B.11.** NOx Testing. Compliance with the NOx emission limitation shall be demonstrated by annual emission testing in accordance with EPA Test Method 7E. [Rule 62-296.570, F.A.C.]

Monitoring of Operations

B.12. Annual Tests Required - NOx and VE. Except as provided in specific conditions **E.6** through **E.8** of this permit, emission testing for nitrogen oxide emissions and visible emissions shall be performed annually, no later than the end of each federal fiscal year (September 30), except for units that are not operating because of scheduled maintenance outages and emergency repairs, which will be tested within thirty days of returning to service. Annual compliance testing while firing oil is not required for units that operated on oil for less than 400 hours in the previous federal fiscal year (ending September 30th). [Rules 62-4.070(3) and 62-213.440, F.A.C.]

Common Conditions

B.13. This emissions unit is also subject to conditions E.1 through E.19, except for E.2, E.9 and E.18, contained in Subsection E. Common Conditions.

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

Page 11 of 24

Subsection C. This section addresses the following emissions units.

009	Fossil Fuel Steam Generating Unit 3 (S-3), nominally rated at 26.5 MW, 325.1
	mmBtu/hr, capable of burning any combination of natural gas and number 6 fuel
	oil, with emissions exhausted through a 113 ft. stack
010	Fossil Fuel Steam Generating Unit 4, (S-4), nominally rated at 33 MW, 419.1
	mmBtu/hr, capable of burning any combination of natural gas and number 6 fuel
	oil, with emissions exhausted through a 115 ft. stack

{Permitting note(s): The emissions units are regulated under Acid Rain, Phase II, Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input, and Rule 62-296.570, F.A.C., NOx RACT, Power Plant Siting Certification No. PA 74-05, and the modified conditions of PA 74-05 ordered September 28, 1987. Fossil fuel fired steam generator Unit 3 (S-3) began commercial operation in 1966; and, fossil fuel fired steam generator Unit 4 (S-4) began commercial operation in 1970. The permittee reported it operates the following continuous monitors for Unit S-3: SO₂, NOx, CO₂, flow, visible emissions, and temperature.}

The following specific conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

C.1. Permitted Capacity. The maximum operation heat input rates are as follows:

Unit No.	mmBtu/hr Heat Input	Fuel Type
009	325.1	Natural Gas
	325.1	No. 6 Fuel Oil
010	419.1	Natural Gas
	419.1	No. 6 Fuel Oil

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.]

C.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **E.14**. [Rule 62-297.310(2), F.A.C.]

C.3. Methods of Operation. Fuels.

- a. Startup: The only fuel(s) allowed to be burned are any combination of natural gas and/or number 6 fuel oil.
- b. Normal: The only fuel(s) allowed to be burned are any combination of natural gas and/or number 6 fuel oil.

[Rule 62-213.410, F.A.C.]

Emission Limitations and Standards

C.4. <u>Visible Emissions</u>. Visible emissions shall not exceed 20 percent opacity, except for one two-minute period per hour during which opacity shall not exceed 40 percent. Emissions units

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 12 of 24

governed by this visible emissions limit shall compliance test for particulate matter emissions annually and as otherwise required by Chapter 62-297, F.A.C. [Rule 62-296.405(1)(a), F.A.C.]

C.5. <u>Visible Emissions - Soot Blowing and Load Change</u>. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.

(The following paragraph is applicable to emissions unit 009 (Unit S-3) and will become applicable to emissions unit 010 (Unit S-4) only upon installation of an operational continuous opacity monitor at Unit S-4.) Visible emissions above 60 percent opacity shall be allowed for not more than 4, six (6)-minute periods, during the 3-hour period of excess emissions allowed by this condition.

[Rule 62-210.700(3), F.A.C., Note: Unit S-3 has an operational continuous opacity monitor. Unit S-4 may install an operational continuous opacity monitor in the future, and at that time be allowed visible emissions greater than 60% opacity pursuant to Rule 62-210.700(3), F.A.C., and specific condition C.5 of this permit.]

- **C.6.** Particulate Matter. Particulate matter emissions shall not exceed 0.1 pound per million Btu heat input, as measured by applicable compliance methods. [Rule 62-296.405(1)(b), F.A.C.]
- C.7. Particulate Matter Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change. [Rule 62-210.700(3), F.A.C.]
- C.8. <u>Sulfur Dioxide Sulfur Content</u>. The No. 6 fuel oil sulfur content shall not exceed 2.25 percent, by weight. See specific condition C.11. [Rules 62-4.070(3) and 62-213.440, F.A.C., and Power Plant Siting Certification No. PA 74-05]
- C.9. NOx RACT. Emissions of nitrogen oxides (NOx) from these emissions units shall not exceed 0.50 pounds per million Btu while firing natural gas or number 6 fuel oil. [Rule 62-296.570, F.A.C.]

Test Methods and Procedures

C.10. Particulate Matter. The test methods for particulate emissions shall be EPA Methods 17, 5, 5B, or 5F, incorporated by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. EPA Method 5 may be used with filter temperature no more than 320 degrees Fahrenheit. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. The owner or operator may use EPA Method 5 to demonstrate compliance. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen based F-factor, computed according to EPA Method 19, is used in lieu of heat input. Acetone wash shall be used with EPA Method 5 or 17.

[Rules 62-213.440, 62-296.405(1)(e)2., and 62-297.401, F.A.C.]

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 13 of 24

- C.11. <u>Sulfur Dioxide Sulfur Content</u>. The permittee shall demonstrate compliance with the liquid fuel sulfur limit by fuel sampling and analysis. See specific conditions C.8. and C.12. [Rules 62-213.440 and 62-296.406(3), F.A.C.]
- **C.12.** Fuel Sampling & Analysis Sulfur. For each emissions unit, the following fuel sampling and analysis protocol shall be used to demonstrate compliance with the fuel sulfur limitation of specific condition C.8 of this permit:
 - a. Sample the as-fired fuel oil each day fuel oil is fired.
 - b. Composite the daily samples and each month determine and record the as-fired fuel sulfur content, percent by weight, for liquid fuels using either ASTM D2622-94, ASTM D4294-90(95), ASTM D1552-95, ASTM D1266-91, or both ASTM D4057-88 and ASTM D129-95 (or latest editions) to analyze a representative sample of the composited as-fired fuel oil. Each composite sample shall also be analyzed for heating value.
 - c. Record monthly the amount of each fuel fired, and maintain records of the monthly analyses of the heating value of each fuel, and the percent sulfur content by weight of each fuel, to enable calculations of sulfur dioxide emissions.

[Rules 62-4.070(3) and 62-213.440, F.A.C., and PPSC PA 74-05]

C.13. NOx Testing. Compliance with the NOx emission limitation shall be demonstrated by annual emission testing in accordance with EPA Test Method 7E, for emissions unit 010. If a continuous emission monitoring system (CEMS) for NOx is installed at emissions unit 010, compliance shall then be demonstrated by the CEMS. Compliance with the NOx emission limitation shall be demonstrated by a CEMS for emissions unit 009. See specific conditions C.15 and C.16.

[Rule 62-296.570, F.A.C.]

Monitoring of Operations

- C.14. Annual Tests Required PM and VE. Except as provided in specific conditions E.6 through E.8 of this permit, emission testing for particulate matter emissions and visible emissions shall be performed annually, no later than the end of each federal fiscal year (September 30), except for units that are not operating because of scheduled maintenance outages and emergency repairs, which will be tested within thirty days of returning to service. [Rules 62-4.070(3) and 62-213.440, F.A.C.]
- C.15. Annual NOx Tests Required Unit 4 (S-4, Emissions Unit 010). For emissions unit 010, emission testing for NOx shall be performed annually, no later than the end of each federal fiscal year (September 30), except for units that are not operating because of scheduled maintenance outages and emergency repairs, which will be tested within thirty days of returning to service. Annual compliance testing while firing oil is not required for units that operated on oil for less than 400 hours in the previous federal fiscal year (ending September 30th).

Should the owner or operator install a continuous emission monitoring system (CEMS) for NOx emissions at emission unit 010, compliance with the NOx limitation shall be demonstrated with the CEMS. Compliance shall be based on a 30-day rolling average. The CEMS shall be properly maintained and operated and shall meet the performance specifications of 40 CFR 60, Appendix B, or 40 CFR 75. The CEMS data shall be maintained on site for inspection by the Department.

[Rules 62-4.070(3), 62-213.410, F.A.C. and 62-296.570(4)(a)3. & 4.]

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 14 of 24

C.16. NOx CEMS Required - Unit 3 (S-3, Emissions Unit 009). For emissions unit 009, compliance with the NOx limitation shall be demonstrated with a continuous emission monitoring system (CEMS). Compliance shall be based on a 30-day rolling average, excluding periods of startup, shutdown or malfunction as provided by Rule 62-210.700, F.A.C. The CEMS shall be properly maintained and operated and shall meet the performance specifications of 40 CFR 60, Appendix B, or 40 CFR 75. The CEMS data shall be maintained on site for inspection by the Department and need not be submitted to the Department unless specifically requested. [Rules 62-4.070(3), 62-213.440, F.A.C. and 62-296.570(4)(a)4., and request of applicant]

Common Conditions

C.17. This emissions unit is also subject to conditions E.1 through E.19, except for E.2 and E.9, contained in Subsection E. Common Conditions.

Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

Page 15 of 24

Subsection D. This section addresses the following emissions units.

006	Gas Turbine # 1, (GT-1), manufactured by Westinghouse, nominally rated at 30
	MW, 435 mmBtu/hr, capable of burning number 2 fuel oil, with emissions
	exhausted through a 46 ft. stack
011	Combined Cycle Unit, (GT-2/S-5), nominally rated at 29.5 MW, consists of a gas
	turbine (GT-2) nominally rated at 20 MW and a heat recovery steam generator (S5)
	nominally rated at 10 MW. GT-2 has a maximum heat input of 317.6 mmBtu/hr,
	capable of burning any combination of natural gas and number 2 fuel oil, with
	emissions exhausted through a 75 ft. stack

{Permitting notes: These emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required and Rule 62-296.570, F.A.C., NOx RACT. Emissions unit 011 is also regulated under Power Plant Siting Certification No. PA 74-05, and the modified conditions of PA 74-05 ordered September 28, 1987. Based on information submitted by the applicant in the Title V application, these emissions units are not subject to 40 CFR 60, Subpart GG, Standards of Performance for New Stationary Gas Turbines. Each combustion turbine has its own stack.. Emissions unit 006 (Unit GT-1) began commercial operation in 1976; and, emissions unit 011 (Unit GT-2/S-5) began commercial operation in 1978.}

The following specific conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

D.1. Permitted Capacity. The maximum operation heat input rates are as follows:

Unit No.	mmBtu/hr Heat Input	Fuel Type
006	435	No. 2 Fuel Oil
011	317.6	Natural Gas
	317.6	No. 2 Fuel Oil

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

D.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **E.14.** [Rule 62-297.310(2), F.A.C.]

D.3. Methods of Operation - Fuels.

- a. Emissions unit 006: Only number 2 fuel oil shall be fired in the combustion turbine.
- b. Emissions unit 011: Only any combination of natural gas and/or number 2 fuel oil shall be fired in the combustion turbine.

[Rule 62-213.410, F.A.C.]

Emission Limitations and Standards

{Note: Emissions unit 006 is also subject to the visible emissions standard of specific condition 3 of this permit.}

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 16 of 24

D.4. Sulfur Dioxide - Sulfur Content - Emissions Unit 011. For emissions unit 011 (Unit GT-2/S-5), the No. 2 fuel oil sulfur content shall not exceed 0.35 percent, by weight. See specific condition **D.6**.

[Rules 62-4.070(3) and 62-213.440, F.A.C., and Power Plant Siting Certification No. PA 74-05]

D.5. NOx RACT. Emissions of nitrogen oxides (NOx) from these emissions units shall not exceed 0.50 pounds per million Btu while firing natural gas and 0.90 pounds per million Btu while firing number 2 fuel oil.

[Rule 62-296.570, F.A.C.]

Test Methods and Procedures

D.6. Sulfur Dioxide - Sulfur Content - Emissions Unit 011. The permittee shall demonstrate compliance with the liquid fuel sulfur limit by fuel sampling and analysis. See specific conditions **D.4.** and **D.7**.

[Rules 62-213.440 and 62-296.406(3), F.A.C.]

- **D.7.** Fuel Sampling & Analysis Sulfur Emissions Unit 011. For each emissions unit, the following fuel sampling and analysis protocol shall be used to demonstrate compliance with the fuel sulfur limitation of specific condition **D.4** of this permit:
 - a. Sample the as-fired fuel oil each day fuel oil is fired.
 - b. Composite the daily samples and each month determine and record the as-fired fuel sulfur content, percent by weight, for liquid fuels using either ASTM D2622-94, ASTM D4294-90(95), ASTM D1552-95, ASTM D1266-91, or both ASTM D4057-88 and ASTM D129-95 (or latest editions) to analyze a representative sample of the composited as-fired fuel oil. Each composite sample shall also be analyzed for heating value.
 - c. Record monthly the amount of each fuel fired, and maintain records of the monthly analyses of the heating value of each fuel, and the percent sulfur content by weight of each fuel, to enable calculations of sulfur dioxide emissions.

[Rules 62-4.070(3) and 62-213.440, F.A.C., and PPSC PA 74-05]

D.8. NOx Testing. Compliance with the NOx emission limitation shall be demonstrated by annual emission testing in accordance with EPA Test Method 7E. [Rule 62-296.570, F.A.C.]

Monitoring of Operations

D.9. Annual Tests Required - NOx and VE. Except as provided in specific conditions **E.6** through **E.8** of this permit, emission testing for nitrogen oxide emissions and visible emissions shall be performed annually, no later than the end of each federal fiscal year (September 30), except for units that are not operating because of scheduled maintenance outages and emergency repairs, which will be tested within thirty days of returning to service. Annual compliance testing while firing oil is not required for units that operated on oil for less than 400 hours in the previous federal fiscal year (ending September 30th).

[Rules 62-4.070(3) and 62-213.440, F.A.C.]

D.10. These emissions units are also subject to conditions E.1 through E.19, except for E.3, E.10, E.11 and E.18, contained in Subsection E. Common Conditions.

Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

Page 17 of 24

Subsection E. Common Conditions.

E.U. ID	
No.	Brief Description
001 -	Five 2000 kW diesel engine generators
005	
007	Fossil Fuel Steam Generating Unit 1 (S-1)
009	Fossil Fuel Steam Generating Unit 3 (S-3)
010	Fossil Fuel Steam Generating Unit 4, (S-4)
006	Gas Turbine # 1, (GT-1)
011	Combined Cycle Unit, (GT-2/S-5)

The following conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

E.1. Hours of Operation. The emissions units may operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

Excess Emissions

- **E.2.** (This condition is applicable only to emissions units 001 005, 006 and 011.) Excess emissions resulting from startup, shutdown or malfunction shall be permitted provided (1) that best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
- **E.3.** (This condition is applicable only to emissions units 007, 009 and 010.) Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

Excess emissions resulting from malfunction shall be permitted provided (1) that best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1) & (2), F.A.C.]

Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

Page 18 of 24

E.4. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

E.5. Determination of Process Variables.

- (a) <u>Required Equipment</u>. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- (b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.
- (c) Heat input rate shall be determined by average fuel use during testing (to be determined by fuel flow meters or fuel tank measurements) and the latest fuel analysis available from the vendor or operator (for Btu content of the fuel used).

{Permitting Note: The permittee and the Department agree that the CEMS used for the federal Acid Rain Program conservatively overestimates the heat input rate for Unit S-3 (emissions unit 009). The monitoring data for heat input is therefore not appropriate for purposes of compliance, including annual compliance certifications.}

[Rules 62-297.310(5) and 62-213.440, F.A.C., and request of applicant]

- **E.6.** Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.
- (a) General Compliance Testing.
 - 2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid and/or solid fuel for more than 400 hours other than during startup.
 - 3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:
 - a. Did not operate; or
 - b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 19 of 24

- 4. During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
 - a. Visible emissions, if there is an applicable standard;
 - b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
- 5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.
- 8. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit.
- 9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
- (b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.
- (c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply. [Rule 62-297.310(7), F.A.C.]
- **E.7.** When PM Tests Not Required. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:
 - a. only gaseous fuel(s); or
 - b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year. [Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]
- **E.8.** When VE Tests Not Required. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:
 - a. only gaseous fuel(s); or
 - b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 20 of 24

c. only liquid fuel(s) for less than 400 hours per year. [Rule 62-4.070(3), F.A.C.]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

E.9. (This condition is applicable only to emissions units 001 - 005, 006 and 011.) <u>Visible Emissions - Turbines, Diesel Engine Generators</u>. The test method for visible emissions for emissions units 006 (GT-1), 011 (GT-2/S-5), and 001 through 005 (diesel engine generators) shall be EPA Method 9, adopted and incorporated by reference in Rule 62-204.800, F.A.C., and referenced in Chapter 62-297, F.A.C.

[Rules 62-204.800, 62-296.320(4)(b)4.a. and 62-297.401, F.A.C., and modified conditions of PA 74-05 ordered September 28, 1987]

E.10. (This condition is applicable only to emissions units 007, 009 and 010.) <u>Visible Emissions - Boilers</u>. The test method for visible emissions for emissions units 007 (S-1), 009 (S-3) and 010 (S-4) shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. A transmissometer may be used and calibrated according to Rule 62-297.520, F.A.C. See specific condition E.11.

[Rule 62-296.405(1)(e)1., F.A.C.]

- E.11. (This condition is applicable only to emissions units 007, 009 and 010.) <u>DEP Method</u> 9. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:
 - 1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.
 - 2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
 - a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
 - b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value.

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 21 of 24

[Rule 62-297.401, F.A.C.]

E.12. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

- **E.13.** Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
- **E.14.** Operating Rate During Testing. Testing of emissions shall be conducted with each emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rules 62-297.310(2) & (2)(b), F.A.C.]

E.15. Applicable Test Procedures.

- (a) Required Sampling Time.
 - 1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.
 - 2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
 - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 22 of 24

- (b) <u>Minimum Sample Volume</u>. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.
- (c) <u>Required Flow Rate Range</u>. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and
- 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.
- (d) <u>Calibration of Sampling Equipment</u>. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1.
- (e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]
- **E.16.** Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit. Temporary stack sampling facilities under Rule 62-297.310(6)(b), F.A.C. may be used in lieu of permanent facilities. [Rule 62-297.310(6), F.A.C.]

Record Keeping and Reporting Requirements

E.17. Malfunctions - Notification. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Palm Beach County Health Department's Air Section in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Palm Beach County Health Department's Air Section.

[Rule 62-210.700(6), F.A.C.]

E.18. (This condition is applicable only to emissions units 009 and 010.) Excess Emissions - Report. Submit to the Palm Beach County Health Department's Air Section a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years. [Rules 62-213.440 and 62-296.405(1)(g), F.A.C.]

E.19. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Palm Beach County Health Department's Air Section on the results of each such test.
- (b) The required test report shall be filed with the Palm Beach County Health Department's Air Section as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Palm Beach County Health Department's Air Section to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
 - 1. The type, location, and designation of the emissions unit tested.
 - 2. The facility at which the emissions unit is located.
 - 3. The owner or operator of the emissions unit.

City of Lake Worth Utilities FINAL Permit No.: 0990045-002-AV Tom G. Smith Power Plant and Lake Worth Water Treatment Plant Page 23 of 24

- 4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
- 5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
- 6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
- 7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
- 8. The date, starting time and duration of each sampling run.
- 9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
- 10. The number of points sampled and configuration and location of the sampling plane.
- 11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
- 12. The type, manufacturer and configuration of the sampling equipment used.
- 13. Data related to the required calibration of the test equipment.
- 14. Data on the identification, processing and weights of all filters used.
- 15. Data on the types and amounts of any chemical solutions used.
- 16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
- 17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
- 18. All measured and calculated data required to be determined by each applicable test procedure for each run.
- 19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
- 20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
- 21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

Page 24 of 24

Section IV. This section is the Acid Rain Part.

Operated by: City of Lake Worth **ORIS code:** 0673

Subsection A. This subsection addresses Acid Rain, Phase II.

The emissions unit(s) listed below are regulated under Acid Rain, Phase II.

E.U. ID	
No.	Brief Description
009	Fossil Fuel Steam Generator, Unit 3, (S-3)
010	Fossil Fuel Steam Generator, Unit 4, (S-4)

A.1. The Phase II permit application(s) submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these Phase II acid rain unit(s) must comply with the standard requirements and special provisions set forth in the application(s) listed: DEP Form No. 62-210.900(1)(a), dated 07/01/95. [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

A.2. Sulfur dioxide (SO₂) allowance allocations for each Acid Rain unit are as follows:

E.U. ID	Ì				
No.	EPA ID	Year	2000	2001	2002
009	S-3	SO2 allowances,			
		under Table 2 or 3 of			
		40 CFR Part 73	9*	9*	9*
010	S-4	SO2 allowances,			
		under Table 2 or 3 of			
		40 CFR Part 73	80*	80*	80*

- * The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 or 3 of 40 CFR 73.
- A.3. Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.
 - 1. No permit revision shall be required for increase in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
 - 2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
- 3. Allowances shall be accounted for under the Federal Acid Rain Program. [Rule 62-213.440(1)(c), F.A.C.]
- **A.4.** Fast-Track Revisions of Acid Rain Parts. Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, Fast-Track Revisions of Acid Rain Parts. [Rule 62-213.413, F.A.C.]
- **A.5.** Comments, notes, and justifications: None.

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers (version dated 02/05/97)

Abbreviations and Acronyms:

°F: Degrees Fahrenheit

BACT: Best Available Control Technology

CFR: Code of Federal Regulations

DEP: State of Florida, Department of Environmental Protection

DARM: Division of Air Resource Management

EPA: United States Environmental Protection Agency

F.A.C.: Florida Administrative Code

F.S.: Florida Statute

ISO: International Standards Organization

LAT: Latitude LONG: Longitude

MMBtu: million British thermal units

MW: Megawatt

ORIS: Office of Regulatory Information Systems

SOA: Specific Operating Agreement **UTM**: Universal Transverse Mercator

Citations:

The following examples illustrate the methods used in this permit to abbreviate and cite the references of rules, regulations, guidance memorandums, permit numbers, and ID numbers.

Code of Federal Regulations:

Example: [40 CFR 60.334]

Where: 40 reference to Title 40

CFR reference to Code of Federal Regulations

60 reference to Part 60

60.334 reference to Regulation 60.334

Florida Administrative Code (F.A.C.) Rules:

Example: [Rule 62-213, F.A.C.]

Where: 62 reference to Title 62

62-213 reference to Chapter 62-213

62-213.205 reference to Rule 62-213.205, F.A.C.

ISO: International Standards Organization refers to those conditions at 288 degrees K, 60 percent relative humidity, and 101.3 kilopascals pressure.

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers (continued)

Identification Numbers:

Facility Identification (ID) Number:

Example: Facility ID No.: 1050221

Where:

105 = 3-digit number code identifying the facility is located in Polk County

0221 = 4-digit number assigned by state database.

Permit Numbers:

Example: 1050221-002-AV, or

1050221-001-AC

Where:

AC = Air Construction Permit

AV = Air Operation Permit (Title V Source)

105 = 3-digit number code identifying the facility is located in Polk County

0221 = 4-digit number assigned by permit tracking database

001 or 002 = 3-digit sequential project number assigned by permit tracking

database

Example: PSD-FL-185

PA95-01

AC53-208321

Where:

PSD= Prevention of Significant Deterioration Permit

PA = Power Plant Siting Act Permit

AC = old Air Construction Permit numbering

Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

Facility ID No.: 0990045

Appendix I-1, List of Insignificant Emissions Units and/or Activities

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62.210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

- 1. Dust collector hopper discharge valve for Unit S-3
- 2. Liquid propane gas emergency generator

Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

Facility ID No.: 0990045

Appendix H-1, Permit History/ID Number Changes

Permit History (for tracking purposes):

E.U.			Issue	Expiration	Extended	Revised
ID No.	Description	Permit No.	Date	Date	Date ^{1, 2}	Date(s)
001	Diesel Generator #1 Peaking Unit	AO 50-172357	01/18/90	07/17/94		
002	Diesel Generator #2 Peaking Unit	AO 50-172357	01/18/90	07/17/94		
003	Diesel Generator #3 Peaking Unit	AO 50-172357	01/18/90	07/17/94		
004	Diesel Generator #4 Peaking Unit	AO 50-172357	01/18/90	07/17/94		
005	Diesel Generator #5 Peaking Unit	AO 50-172357	01/18/90	07/17/94		
006	Combustion Gas Turbine #1	AO 50-219177	11/06/92	10/30/97		
	(GT-1)	AC 50-2168A	09/10/76	09/01/77		
		AC 50-2168	09/28/73	03/01/75		
007	Fossil Fuel Steam Generator Unit #1 (S-1)	AO 50-169444	01/31/96	09/15/96		
008	Fossil Fuel Steam Generator Unit #2 (S-2)*					
009	Fossil Fuel Steam Generator Unit #3 (S-3)	AO 50-169444 PA - 74-05	01/31/96 05/18/76	09/15/96		09/28/87 03/27/96
010	Fossil Fuel Steam Generator Unit #4 (S-4)	AO 50-169444 PA - 74-05	01/31/96 05/18/76	09/15/96		09/28/87 03/27/96
011	Combined Cycle Gas Turbine (GT-2/S-5)	PA - 74-05	05/18/76			09/28/87 03/27/96
001 -	Diesel engine generators #1	0990045-001-AO	01/31/96			
005,	- 5	(amendment of AO				
006,		50-169444, AO 50-				
007,	GT-1	172357, AO 50-				
009,	S-1	219177, for NOx				
010	S-3	RACT)				
	S-4					

ID Number Changes (for tracking purposes):

From: Facility ID No.: 50PMB500045

To: Facility ID No.: 0990045

Notes:

1 - AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

2 - AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96.

{Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}

* Unit S-2 is not in service. Operation of this unit is not permitted by this permit.

Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

Facility ID No.: 0990045

Appendix U-1, List of Unregulated Emissions Units and/or Activities

<u>Unregulated Emissions Units and/or Activities</u>. An emissions unit which emits no "emissions-limited pollutant" and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither 'regulated emissions units' nor 'insignificant emissions units'.

E.U. ID	
No.	Brief Description of Emissions Units and/or Activity
012	Fuel oil storage tanks (tanks 10 & 11, both 20,134 gallons capacity, and tank 12, 140,785
	gallons capacity) subject to NSPS, Subpart Kb.*
013	Fuel oil storage tanks (tanks 3, 4, 5, 6, and 8), lube oil tanks, fittings and pumps.

^{*} The owner or operator shall keep readily accessible records showing the dimension of each storage vessel (tank) and an analysis showing the capacity of each storage vessel (tank), and shall retain the records as long as each tank remains at the facility.

City of Lake Worth Utilities
Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Appendix S Permit Summary Tables

Table 1-1, Summary of Air Pollutant Emission Standards

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Emission	s Unit	Brief Desc	Brief Description						
001 -	005	Five 2000	kW diesel engine generators						
			Allowable Emissions			Equivalent Emissions			
Pollutant	Fuel(s)	Hours	Standard(s)	lbs./hour	TPY	lbs:/hour TPY	Regulatory	See Permit	
		per Year					Citations	Condition(s)	
VE	Diesel	8760	20% opacity				Rule 62-	Section II,	
	Fuel						296.320(4)(b),	Condition 3	
							F.A.C.		
NOx	Diesel	8760	4.75 lb/mmBtu			99.8 (43691)	Rules 62-	A.2	
	Fuel						296.570., F.A.C.		

Note for EU 001 - 005: Equivalent emissions are listed for each diesel generator.

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Table 1-1, Continued

Emissions Unit	Brief Description
007	Fossil Fuel Steam Generating Unit 1 (S-1), nominally rated at 7.5 MW, 111 mmBtu/hr, capable of burning any combination of
	natural gas and number 6 fuel oil

			Allowable Emissions			Equivalent Emissions		-
Pollutant	Fuel(s)	Hours per Year	Standard(s)	lbs./hour	TPY	-lbs:/hour TPY	Regulatory Citations	See Permit Condition(s)
VE Steady State	Oil, Natural Gas	8760	20% opacity, except for 40% for 2 min. each hour				Rule 62- 296.406(1), F.A.C.	B.4
VE Soot Blowing or Load Change	Oil, Natural Gas	8760	60% opacity				Rule 62- 210.700(3), F.A.C.	B.5
SO ₂ (& PM)	Oil, Natural Gas	8760	2.25% S by weight, fuel oil			267* 1;170* (oil) (oil)	Rules 62- 4.070(3) & 296.406(3)., F.A.C.	B.7
NOx	Oil, Natural Gas	8760	0.5 lb/mmBtu			56 243	Rules 62- 296.570, F.A.C.	B.8

^{*} Equivalent emissions are for SO_2 emissions firing fuel oil.

City of Lake Worth Utilities
Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Table 1-1, Continued

Emissions Unit	Brief Description
009	Fossil Fuel Steam Generating Unit 3 (S-3), nominally rated at 26.5 MW, 325.1 mmBtu/hr, capable of burning any combination
	of natural gas and number 6 fuel oil
010	Fossil Fuel Steam Generating Unit 4, (S-4), nominally rated at 33 MW, 419.1 mmBtu/hr, capable of burning any combination
	of natural gas and number 6 fuel oil

-			Allowable Emissions			Equivalent — Emissions —		
Pollutant	Fuel(s)	Hours per Year	Standard(s)	lbs./hour	TPY	îbs:/hour TPY	Regulatory Citations	See Permit Condition(s)
VE Steady State	Oil, Natural Gas	8760	20% opacity, except for 40% for 2 min. each hour				Rule 62- 296.405(1)(a), F.A.C.	C.4
VE Soot Blowing or Load Change	Oil, Natural Gas	8760	60 % opacity (>60% opacity for not more than 4, six-minute periods)				Rule 62- 210.700(3), F.A.C.	C.5
PM Steady State	Oil, Natural Gas	8760	0.1 lb/mmBtu		_	33 142 (EU 009) (EU 009) 42 184 (EU 010) (EU 010);	Rule 62- 296.405(1)(b), F.A.C.	C.6
PM Soot Blowing or Load Change	Oil, Natural Gas	8760	0.3 lb/mmBtu			99 426 (EU 009) ±126 552 (EU 010) (EU 010)	Rule 62- 210.700(3), F.A.C.	C.7

City of Lake Worth Utilities
Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Table 1-1, Continued, Emissions Units 009 & 010

			Allowable Emissions			Equivalent Emissions	The second secon		
Pollutant	Fuel(s)	Hours per Year	Standard(s)	lbs./hour	TPY	lbs:/hour	TPY	Regulatory Citations	See Permit Condition(s)
SO ₂	Oil, Natural Gas	8760	2.25% S by weight, fuel oil			(EU 009) (6il) 1072 (EU 010)	1072 (EU 009) (oil) 4695 (EU 010) (oil)		C.8
NOx	Oil, Natural Gas	8760	0.5 lb/mmBtu			009) 210 (EU	712 ŒU 009) 918 ŒU 010)	296.570, F.A.C.	C.9

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Table 1-1, Continued

Emissions Unit	Brief Description
006	Gas Turbine # 1, (GT-1), nominally rated at 30 MW, 435 mmBtu/hr, capable of burning number 2 fuel oil
011	Combined Cycle Unit, (GT-2/S-5), nominally rated at 29.5 MW, consists of a gas turbine (GT-2) nominally rated at 20 MW
	and a heat recovery steam generator (S5) nominally rated at 10 MW. GT-2 has a maximum heat input of 317.6 mmBtu/hr,
	capable of burning any combination of natural gas and number 2 fuel oil

			Allowable Emissions			Equivalent Emissions!		
Pollutant	Fuel(s)	Hours	Standard(s)	lbs./hour	TPY	lbs:/hour .TPY	Regulatory	See Permit
		per Year					Citations	Condition(s)
VE	Oil ^a ,	8760	20% Opacity				Rule 62-	Section II,
	Natural						296.320(4)(b),	Condition 3
	Gas ^b						F.A.C.	
SO ₂ (EU	Oil,	8760	0.35% S by weight, fuel oil			109 - 4 478	Rule 62-213.440,	D.4
011 only)	Natural					(oil)*******(oil)	F.A.C. & PPSC	
	Gas						No. PA 74-05	
NOx	Oil ^a ,	8760	0.90 lb/mmBtu (fuel oil)			392	Rules 62-570,	D.5
(EU 006)	Natural		0.50 lb/mmBtu (natural gas)			218 953	F.A.C.	
	Gas ^b							
NOx	Oil ^a ,	8760	0.90 lb/mmBtu (fuel oil)			286 1252	Rules 62-570,	D.5
(EU 011)	Natural		0.50 lb/mmBtu (natural gas)			159 4 696	F.A.C.	
	Gas ^b						12 A	

a Number 2 fuel oil may be fired in emissions unit 006 or 011.

b Natural gas may be fired in emissions unit 011.

City of Lake Worth Utilities
Tom G. Smith Power Plant and Lake Worth Water Treatment Plant

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Appendix S Permit Summary Tables

Table 1-1, Continued

Emission	s Unit	Brief Description						
012		Fuel oil storage tanks (tanks 10 & 11, both 20,134 gallons capacity, and tank 12, 140,785 gallons capacity) subject to NSPS Subpart Kb						ject to NSPS,
			Allowable Emissions			Equivalent Emissions ¹		
Pollutant	Fuel(s)	Hours per Year	Standard(s)	lbs./hour	TPY	lbs:/hour TPY	Regulatory Citations	See Permit Condition(s)
None		8760	No emission limits - record keeping only					F.2, F.3

Notes for all tables:

¹ The "Equivalent Emissions" listed are for informational purposes only.

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Appendix S Permit Summary Tables

Table 2-1, Summary of Compliance Requirements

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

Emissions Unit	Brief Description
001 - 005	Five 2000 kW diesel engine generators

Pollutant or	Fuel(s)	Compliance	Testing	Frequency	Minimum	CMS ²	See Permit
Parameter		Method	Frequency	Base Date ¹	Compliance Test		Condition(s)
					Duration		
NOx	Diesel	EPA Test Method 7E	Annual	February	3 hours	No	A.3 & A.4
	Fuel		_	28th			
VE	Diesel	EPA Method 9	Annual	February	30 min.	No	A.4 & E.9
	Fuel			28th			

Emissions Unit	Brief Description
007	Fossil Fuel Steam Generating Unit 1 (S-1), nominally rated at 7.5 MW, 111 mmBtu/hr, capable of burning any combination of
	natural gas and number 6 fuel oil

Pollutant or	Fuel(s)	Compliance	Testing	Frequency	Minimum	CMS^2	See Permit
Parameter		Method	Frequency	Base Date ¹	Compliance Test		Condition(s)
			_		Duration		
SO ₂	Oil, Natural Gas	Fuel sampling & analysis	Sampling daily, analysis of monthly composite			No	B.7, B9 & B.10
NOx	Oil, Natural Gas	EPA Test Method 7E	Annual	February 28th	3 hours	No	B.11 & B.12
VE	Oil, Natural Gas	DEP Method 9	Annual	February 28th	1 hour	No	B.12 & E.10

FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Appendix S Permit Summary Tables

Table 2-1, Continued

Emissions Unit		Brief Description						
009		Fossil Fuel Steam Generating Unit 3 (S-3), nominally rated at 26.5 MW, 325.1 mmBtu/hr, capable of burning any combination of natural gas and number 6 fuel oil						
010		Fossil Fuel Steam Generating Unit 4, (S-4), nominally rated at 33 MW, 419.1 mmBtu/hr, capable of burning any combination of natural gas and number 6 fuel oil						
Pollutant or Parameter	Fuel(s)	Compliance Method	Testing Frequency	Frequency Base Date ¹	Minimum Compliance Test Duration	CMS ²	See Permit Condition(s)	
SO ₂	Oil, Natural Gas	Fuel sampling & analysis	Sampling daily, analysis of monthly composite			Noª	C.8, C.11 & C.12	
NOx (EU 009)	Oil, Natural Gas	CEMS	Continuous			Yes	C.13 & C.16	
NOx (EU 010)	Oil, Natural Gas	EPA Test Method 7E (If CEMS installed see next row)	Annual	February 28th	3 hours	No	C.13 & C.15	
NOx (EU 010)	Oil, Natural Gas	CEMS (If installed)	Continuous			Yes, if installed for Acid Rain	C.13 & C.15	
PM	Oil, Natural Gas	EPA Test Methods 17,5,5B or 5F	Annual	Februrary	3 hours	No	C.10 & C.14	
VE	Oil, Natural Gas	DEP Method 9	Annual	February 28th	1 hour	Yes	C.14 & E.10	

Note for EU 009 & 010:

a A continuous monitor for SO2 is operated by the City for emissions unit 009. Compliance with the fuel sulfur limitation is not via the continuous monitor.

City of Lake Worth Utilities Tom G. Smith Power Plant and Lake Worth Water Treatment Plant **FINAL Permit No.:** 0990045-002-AV

Facility ID No.: 0990045

Table 2-1, Continued

Emissions Unit	Brief Description
006	Gas Turbine # 1, (GT-1), nominally rated at 30 MW, 435 mmBtu/hr, capable of burning number 2 fuel oil
011	Combined Cycle Unit, (GT-2/S-5), nominally rated at 29.5 MW, consists of a gas turbine (GT-2) nominally rated at 20 MW
	and a heat recovery steam generator (S5) nominally rated at 10 MW. GT-2 has a maximum heat input of 317.6 mmBtu/hr,
	capable of burning any combination of natural gas and number 2 fuel oil

Pollutant or Parameter	Fuel(s)	Compliance Method	Testing Frequency	Frequency Base Date ¹	Minimum Compliance Test Duration	CMS ²	See Permit Condition(s)
SO ₂ (Emissions Unit 011 only)	Oil, Natural Gas	Fuel sampling & analysis	Sampling daily, analysis of monthly composite			No	D.4, D.6 & D.7
NOx	Oil, Natural Gas	EPA Test Method 7E	Annual	February 28th	3 hours	No	D.8 & D.9
VE	Oil, Natural Gas	EPA Method 9	Annual	February 28th	1 hour	No	D.9 & E.9

City of Lake Worth Utilities Tom G. Smith Power Plant and Lake Worth Water Treatment Plant FINAL Permit No.: 0990045-002-AV

Facility ID No.: 0990045

Appendix S Permit Summary Tables

Table 2-1, Continued

Emissions Unit	Brief Description
012	Fuel oil storage tanks (tanks 10 & 11, both 20,134 gallons capacity, and tank 12, 140,785 gallons capacity) subject to NSPS,
	Subpart Kb

Pollutant or Parameter	Fuel(s)	Compliance Method	Testing Frequency	Frequency Base Date ¹	Minimum Compliance Test Duration	CMS ²	See Permit Condition(s)
Capacity		Record keeping			Duration		F.2 & F.3

Notes for all tables:

¹ Frequency base date established for planning purposes only; see Rule 62-297.310, F.A.C. ² CMS = continuous monitoring system

Appendix TV-1, the Title V Core Conditions, has been provided only to the applicant. The most recent version of these conditions may be obtained from the Department's Internet Web site at:

http://www.dep.state.fl.us/air/


If you do not have access to the Internet and would like a copy of Appendix TV, please contact Joseph Kahn, P.E., Department of Environmental Protection, Division of Air Resources Management, Bureau of Air Regulation, Mail Station 5505, 2600 Blair Stone Road, Tallahassee, FL 32399-2400, 850/488-1344.

An electronic version of this permit is also available from the Department's Internet Web site above.

ATTACHMENT LW-FI-C13 RISK MANAGEMENT PLAN VERIFICATION LETTER

Facility Name: Lake Worth Water Treatment Plant

EPA ID: 1000 0009 5853





UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

WASHINGTON, D.C. 20460

OFFICE OF SOLID WASTE AND EMERGENCY RESPONSE

Harvey F. Wildschuetz Lake Worth Utilities 1900 Second Avenue, North Lake Worth, FL 33461

July 07, 1999

EPA Facility ID#:

1000 0009 5853

Postmark Date:

06/17/1999

Anniversary Date:

06/17/2004

NOTIFICATION LETTER: COMPLETE RMP

The U.S. Environmental Protection Agency (EPA) received your Risk Management Plan (RMP) dated with the above postmark date. This letter notifies you that your RMP is "complete" according to EPA's completion check. The completion check is a program implemented by EPA to determine whether a submitted RMP includes the minimum amount of information every RMP must provide. The completion check does not assess whether a submitted RMP should have provided additional information or whether the information it provides is accurate or appropriate. In other words, it does not indicate that the RMP meets the requirements of 40 CFR Part 68.

Please note the anniversary date indicated above. Your RMP must be revised and updated by this date or earlier as required by 40 CFR §68.190. Please also note your EPA Facility ID number as identified at the top of this letter; all future Risk Management Plan submissions, corrections and other correspondence must include this number.

Your RMP (excluding the Offsite Consequence Analysis data) can be viewed on RMP*Info[™], a national database on the Internet at http://www.epa.gov/enviro.

Facility Name: Lake Worth Waler Treatment Plant

EPA ID:

1000 0009 5853

If you have any questions, please call one of the following numbers:

- (1) For RMP rule interpretation questions, call the EPCRA Hotline at (800) 424-9346 or (703) 412-9810 (in the D.C. Metro area).
- (2) For RMP*Submit installation and software questions, or information on the status of your RMP, contact the RMP Reporting Center at (703) 816-4434, or write to the:

RMP Reporting Center P.O. Box 3346 Merrifield, VA 22116-3346

(3) For more information on the Risk Management Program, you can contact your Implementing Agency. Your Implementing Agency is Florida Department of Community Affairs, 2555 Shumard Oak Boulevard, Tallahassee, FL, 32399, Phone: 850-413-9970.

Thank you for your cooperation in this matter.

Sincerely,

RMP Reporting Center

Enclosure:

Risk Management Plan (if submitted on paper)

Diesel Generator Units 1-5

Emissions Unit Information Section 1 of 6

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

Emissions Unit Description and Status

1.	Type of Emission	s Unit Addressed in Thi	s Se	ection: (Check one)		
[This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).					
[x	process or prod		s w	ldresses, as a single emis hich has at least one defi re emissions.	•	
[-			Idresses, as a single emis hich produce fugitive em		
2.	Regulated or Unr	egulated Emissions Unit	? (0	Check one)		
[x	The emissions unit.	unit addressed in this Em	nissi	ons Unit Information Sec	ction is a regulated	
[] The emissions unit.	unit addressed in this Em	nissi	ons Unit Information Sec	ction is an unregulated	
3.	•	nissions Unit Addressed Units 1 through 5, each 2		This Section (limit to 60 o	characters):	
4.	Emissions Unit Io	dentification Number:		[] No ID	
	ID: 001, 002, 003,	004, and 005]] ID Unknown	
5.	Emissions Unit Status Code:	6. Initial Startup Date: 1965	7.	Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit?	
9.	Emissions Unit C	Comment: (Limit to 500 (Cha	racters)		
		,		in Attachment LW-EU1-A	\9 .	

Emi	ssions Unit Information Section 1 of 6 Diesel Generator Units 1-5
E•	
	ssions Unit Control Equipment
1. (Control Equipment/Method Description (Limit to 200 characters per device or method):
2. (Control Device or Method Code(s):

Emissions Unit Details

1.	Package Unit:		
	Manufacturer: GM EMD	Model Number: 567D4	
2.	Generator Nameplate Rating: 2	MW Each	
3.	Incinerator Information:		
	Dwell Temper	ature:	°F
	Dwell	Time:	seconds
	Incinerator Afterburner Temperat	ure:°F	

Emissions Unit Information Section 1 of 6 Diesel Generator U	Jnits	;	1	ŀ	-	-:	:
--	-------	---	---	---	---	----	---

B. EMISSIONS UNIT CAPACITY INFORMATION (Regulated Emissions Units Only)

Emissions Unit Operating Capacity and Schedule

1.	Maximum Heat Input Rate:		105	mmBtu/hr Total
2.	Maximum Incineration Rate:	lb/hr		tons/day
3.	Maximum Process or Through	put Rate:		
4.	Maximum Production Rate:			
5.	Requested Maximum Operatin	g Schedule:		
		hours/day		days/week
		weeks/year	8,760	hours/year Each
6.	Operating Capacity/Schedule C	Comment (limit to 200 chara	acters):	
			•	

C. EMISSIONS UNIT REGULATIONS (Regulated Emissions Units Only)

List of Applicable Regulations

Federal: None
State:
62-4, F.A.C. Gen. Permitting Requirements
62-210, F.A.C. Stationary Sources – Gen. Requirements
62-213, F.A.C. Title V Permitting Requirements
62-296.310(2)(a), F.A.C. Stationary Sources – Visible Emissions Standards
62-296.570(4)(b)(7), F.A.C. NO _x RACT Limitations
62-297.410(9), F.A.C. Stationary Sources – EPA Method 9 for Visible Emissions
Title V Core List (3/1/02), Presumptively Applicable (Federal & State)
Local: None

D. EMISSION POINT (STACK/VENT) INFORMATION (Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on P	lot Plan or Flow	2. Emission	on Point Type Code:	
Diagram? MU-1, MU-2, MU-3,	MU-4, MU-5	3		
3. Descriptions of Emission Policy 100 characters per point): MU-1 Diesel Generating Unit MU-2 Diesel Generating Unit MU-3 Diesel Generating Unit MU-4 Diesel Generating Unit MU-5 Diesel Generating Unit MU-5 Diesel Generating Unit	t 1 t 2 t 3 t 4			
4. ID Numbers or Descript	tions of Emission Uni	its with this l	Emission Point in Con	nmon:
N/A				
5. Discharge Type Code:	6. Stack Height:		7. Exit Diameter:	
V	16.5	feet	1.83	feet
8. Exit Temperature:	9. Actual Volumet	ric Flow	10. Water Vapor:	~
667 °F	Rate:	C		%
11 Mayimayan Day Standard El	19,208		als Emission Doint Hai	
11. Maximum Dry Standard Flo	dscfm	12. Nonstac	ck Emission Point Hei	gni: feet
13. Emission Point UTM Coord	dinates:	<u> </u>		
	East (km): 592.8	Norti	h (km): 2943.7	
14. Emission Point Comment (limit to 200 character	s):		
The operation parameters fo	or all five diesel units	are identical.		

E. SEGMENT (PROCESS/FUEL) INFORMATION (All Emissions Units)

Segment Description and Rate: Segment 1 of 1

1.	. Segment Description (Process/Fuel Type) (limit to 500 characters):					
	Internal Combustion Engin	ies - Electric Gene	eration-Distillat	e Oil	(Diesel)	
2.	Source Classification Code	e (SCC):	3. SCC Units	s:		
	2-01-001-02		1,000 gallo	ns b		
4.	Maximum Hourly Rate: 0.15	5. Maximum A	Annual Rate:	6.	Estimated Annual Activity Factor:	
7.	Maximum % Sulfur: 0.23	8. Maximum 9	% Ash:	9.	Million Btu per SCC Unit: 139.30	
10.	. Segment Comment (limit	to 200 characters):			
Se	gment Description and Ra	ite: Segment	of			
1.	Segment Description (Proc			narac	ters):	
-	ooge Doomption (1 tot	bess, ruer rype)	(mine to 500 c.	. rur uv	(O10).	
2.	Source Classification Code	e (SCC):	3. SCC Uni	ts:		
			3. 800 0111			
4.	Maximum Hourly Rate:	5. Maximum A	Annual Rate:	6.	Estimated Annual Activity Factor:	
7.	Maximum % Sulfur:	8. Maximum 9	% Ash:	9.	Million Btu per SCC Unit:	
10.	Segment Comment (limit)	to 200 characters):	1	-	
		·				

F. EMISSIONS UNIT POLLUTANTS (All Emissions Units)

1. Pollutant Emitted	Primary Control Device Code	3. Secondary Control Device Code	Pollutant Regulatory Code
SO ₂			NS
NO _x			EL
со	· ,		NS
voc			NS
PM			NS
PM ₁₀			NS

Emissions Unit Information Section	1	of	6	Diesel Generator Units 1-5
Pollutant Detail Information Page	_1_	of	1	Nitrogen Oxides

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

T Overline I de l'est l'				
1. Pollutant Emitted:	2. Total Percent Efficiency of Control:			
NO _x				
3. Potential Emissions:	4. Synthetically			
99.8 lb/hour	436.91 tons/year Limited? []			
5. Range of Estimated Fugitive Emissions:	·			
	to tons/year			
6. Emission Factor: 4.75 lb NO _x per mmBtu	7. Emissions			
Reference: NO _x RACT Rule	Method Code:			
8. Calculation of Emissions (limit to 600 cha	racters):			
	670			
Potential emissions based on oil firing. (4.)	75 lb NO _x per mmBtu x 1,320.603 per			
1,000 gal Oil/yr x 139.3 mmBtu/1,000 gal Oil) / 2,000 lb/ton			
9. Pollutant Potential/Fugitive Emissions Con	mment (limit to 200 characters):			
Potential emissions are based on maximum heat input, 8,760 hr/yr, and the minimum				
heating value of oil reported from 1992 thro	ugn 1995.			
Allowable Emissions Allowable Emissions	1 of 1			
1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable			
RULE	Emissions:			
3. Requested Allowable Emissions and Units	: 4. Equivalent Allowable Emissions:			
4.75 lb NO _x per mmBtu	499 lb/hour 2,185 tons/year			
5. Method of Compliance (limit to 60 charact	ers):			
EDA Tost Mathod 7E conducted annually w	than burning liquid fuels for 400 or more bours			
per year.	hen burning liquid fuels for 400 or more hours			
6. Allowable Emissions Comment (Desc. of Comment	Operating Method) (limit to 200 characters):			
2. The waste Emissions Comment (Desc. Of C	operating intented, (initial to 200 offactions).			

Emissions	Unit	Information	Section	1	of	6

Diesel Generator Units 1-5

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

	——————————————————————————————————————
Visible Emissions Subtype: VE	2. Basis for Allowable Opacity: [X] Rule [] Other
3. Requested Allowable Opacity:	
	xceptional Conditions: %
Maximum Period of Excess Opacity Allow	ved: min/hour
4. Method of Compliance:	
hours per year. Testing conducted using the	ally when burning liquid fuels for 400 or more ne fuel and/or process input which are expected n 10 percent of the rated capacity of the source.
5. Visible Emissions Comment (limit to 200	characters):
I. CONTINUOUS MO	ONITOR INFORMATION
(Only Regulated Emissions Unit	s Subject to Continuous Monitoring)
Continuous Monitoring Systems Continuous	
Continuous Monitoring System: Continuous	s Monitor of
1. Parameter Code:	2. Pollutant(s):
 Parameter Code: CMS Requirement: Monitor Information: 	2. Pollutant(s):
 Parameter Code: CMS Requirement: Monitor Information: Manufacturer: 	2. Pollutant(s): [] Rule [] Other
 Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: 	2. Pollutant(s): [] Rule [] Other Serial Number:
 Parameter Code: CMS Requirement: Monitor Information: Manufacturer: 	2. Pollutant(s): [] Rule [] Other
 Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: 	2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:
 Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date: 	2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:
 Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date: 	2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:
 Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date: 	2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:
 Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date: 	2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:

Emissions Unit Information Section	1	of	6	Diesel Generator Units
---	---	----	---	------------------------

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION (Regulated Emissions Units Only)

Supplemental Requirements

1.	Process Flow Diagram [X] Attached, Document ID: <u>LW-EU1-J1</u> [] Not Applicable [] Waiver Requested
2.	Fuel Analysis or Specification [X] Attached, Document ID: <u>LW-EU1-J2</u> [] Not Applicable [] Waiver Requested
3.	Detailed Description of Control Equipment [] Attached, Document ID: [X] Not Applicable [] Waiver Requested
4.	Description of Stack Sampling Facilities [X] Attached, Document ID: <u>LW-EU1-J4</u> [] Not Applicable
5.	Compliance Test Report
	[] Attached, Document ID:
	[X] Previously submitted, Date: <u>LW-EU1-J5</u>
	[] Not Applicable
6.	Procedures for Startup and Shutdown [] Attached, Document ID: [X] Not Applicable [] Waiver Requested
7.	Operation and Maintenance Plan
	[] Attached, Document ID: [X] Not Applicable [] Waiver Requested
8.	Supplemental Information for Construction Permit Application
	[] Attached, Document ID: [X] Not Applicable
9.	Other Information Required by Rule or Statute
	[] Attached, Document ID: [X] Not Applicable
10	. Supplemental Requirements Comment:
	\cdot

1-5

Emissions	Unit	Information Section	1 1	of	6

Diesel Generator Units 1-5

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation
[] Attached, Document ID: [X] Not Applicable
12. Alternative Modes of Operation (Emissions Trading)
[] Attached, Document ID: [x] Not Applicable
12. Identification of Additional Applicable Dequipments
13. Identification of Additional Applicable Requirements [X] Attached, Document ID: LW-FI-C12 [] Not Applicable
14. Compliance Assurance Monitoring Plan
[] Attached, Document ID: [X] Not Applicable
15. Acid Rain Part Application (Hard-copy Required)
[] Acid Rain Part - Phase II (Form No. 62-210.900(1)(a))
Attached, Document ID:
[] Repowering Extension Plan (Form No. 62-210.900(1)(a)1.)
Attached, Document ID:
[] New Unit Exemption (Form No. 62-210.900(1)(a)2.)
Attached, Document ID:
[] Retired Unit Exemption (Form No. 62-210.900(1)(a)3.)
Attached, Document ID:
[] Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.)
Attached, Document ID:
[] Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID:
[X] Not Applicable

ATTACHMENT LW-EU1-A9

EMISSIONS UNIT COMMENT




Photo 1. Front View - Diesel Generator Units 1-5




Photo 2. Rear View - Diesel Generator Units 1-5


Attachment LW-EU1-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities

Source: Golder, 2002.



ATTACHMENT LW-EU1-J1
PROCESS FLOW DIAGRAM

7/2/2002



Attachment LW-EU1-J1
Process Flow Diagram
Lake Worth Utilities - City of Lake Worth, Florida

Golder

Source: Golder, 2002.

ATTACHMENT LW-EU1-J2

FUEL ANALYSIS OR SPECIFICATION



CITY OF LAKE WORTH

1900 2ND AVENUE NORTH LAKE WORTH, FLORIDA 33461-4298

UTILITIES DEPARTMENT POWER RESOURCES

(561) 586-1703 FAX (561) 586-1759

April 29, 2002

Mr. Laxmana Tallam
Supervisor of Permitting, Compliance & Enforcement
Florida Department of Environmental Protection
Post Office Box 15425
400 North Congress Avenue
West Palm Beach, Florida 33416

Subject:

City of Lake Worth Utilities

Quarterly Fuel Oil Analysis Reports First Quarter 2002 (Jan- Feb - Mar)

Dear Mr. Tallam:

Please find attached our quarterly fuel oil analysis as required by our operating permit. Samples reported below have been collected from a composite sample from the on site oil storage facility.

On site quarterly sample:

Type	Date	%S	Note
No.6	04/01/02	1.97	On site quarterly sample
No.2	04/01/02	0.0390	On site quarterly sample

Mr. Laxmana Tallam Supervisor of Permitting, Compliance and Enforcement April 29, 2002

Page 2

The results indicate the oil is within our permit limits of 0.35% sulfur for No. 2 oil and 2.25% sulfur for No. 6 oil. If you need more information, please do hesitate to call me at 561.533.7379 or email at mridge@lakeworth.net.

Sincerely,

CITY OF LAKE WORTH UTILITIES

Mike Ridge

Environmental/ Performance Specialist

Attachments

cc: A.J. Satyal, Environmental Manager, Palm Beach County Health Unit

Larry Baker, Power Resources Superintendent

Margaret Johnstone, Environmental Compliance Officer

Joe Brockway, Results Supervisor

SAYBOLT LP.

2610 So. Federal Highway Fort Lauderdale, FL. 33316



Best Available Copy

LABORATORY NO.: 0483

DATE: 04/08/02

INVOICE NO:

LABORATORY ANALYSIS REPOR.

CUSTOMER

REF. NO(S): #129018/

DESCRIPTION

- Sample designated as: #2 FUEL OIL
- Identifying Marks: SUBMITTED QUARTERLY SAMPLE (04/01/02) CITY POWER PLANT LAKE WORTH, FLORDA
- Submitted by: CITY OF LAKE WORTH
- Client: CITY OF LAKE WORTH

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST	METHOD	RESULT
GRAVITY, API AT 60 F	D-1298	,34.7
GRAVITY, SPECIFIC	D-1298	0.8514
SULFUR, X-RAY, WT PCT	D-4294	0.0390
ASH, WT PCT	D-482	0.0036
HEAT OF COMBUSTION, BTU/LB	D-4868	19576
HEAT OF COMBUSTION, BTU/GAL		139011
HEAT OF COMBUSTION, BTU/BBL		5838462

MEMBERS ASTM-API-SAE

A B SAYBOLT

ATTACHMENT LW-EU1-J4 DESCRIPTION OF STACK SAMPLING FACILITIES

ATTACHMENT LW-EU1-J4

DESCRIPTION OF STACK SAMPLING FACILITIES

DIESEL GENERAL UNITS 1 THROUGH 5 (MU-1 THROUGH MU-5)

Emission testing can be performed on all of the major emission units. However, on MU-1 to MU-5, permanent platform structures do not exist. In order to perform emission tests on these units, a bucket truck is used to hoist personnel and equipment to the stack test port elevations. For the diesel engines, MU-1 to MU-5, temporary stack extensions are installed with sample ports to perform the emission tests. Access to the diesel engine stack is via a temporary ladder installed during the testing. The stack sampling locations are identified for MU-1 through MU-5 on the attached figure.




FIGURE 11
SAMPLING POINT LOCATION
M-UNIT MU-1 to MU-5
LAKE WORTH UTILITIES
LAKE WORTH, FLORIDA

AIR CONSULTING and ENGINEERING

ATTACHMENT LW-EU1-J5
COMPLIANCE TEST REPORT

ATTACHMENT LW-EU1-J5

COMPLIANCE TEST REPORT

The Compliance Tests and dates submitted for Diesel Generator Units 1-5 (M1-5) are as listed below.

M-Units			
M-1(EU001)	Tested 9/27/2000	Submitted 12/01/2000	$NO_{x_{s}}VE$
M-2(EU002)	Tested 9/11/2001	Submitted 10/17/2001	NO_x
M-3(EU003)	Tested 9/27/2000	Submitted 12/01/2000	NO_{x} , VE
M-4(EU004)	Tested 2/13/1997	Submitted 3/19/1997	NO_x
M-5(EU005)	Tested 2/13/1997	Submitted 3/19/1997	NO_x

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

Emissions Unit Description and Status

1.	Type of Emission	s Unit Addressed in This	s Section: (Check one)	-	
[x	X] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).				
[process or prod		n addresses, as a single emis s which has at least one defin gitive emissions.	•	
[-		n addresses, as a single emis tivities which produce fugiti		
2.	Regulated or Unr	egulated Emissions Unit	? (Check one)		
[x] The emissions emissions unit.	unit addressed in this Em	issions Unit Information Sec	ction is a regulated	
[] The emissions emissions unit.	unit addressed in this Em	issions Unit Information Sec	ction is an unregulated	
3.	 Description of Emissions Unit Addressed in This Section (limit to 60 characters): Fossil Fuel Steam Generating Unit 1 (S-1) 				
4.	Emissions Unit Identification Number: [] No ID D: 007 [] ID Unknown				
5.	Emissions Unit Status Code:	6. Initial Startup Date: 1961	7. Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit?	
9.	9. Emissions Unit Comment: (Limit to 500 Characters) Lake Worth Utilities requests a permit condition prohibiting operation of this emission unit effective on the date Lake Worth Generation LLC commences commercial operation to routinely supply steam to Emission Unit 009 (S-3; Fossil Fuel Steam Generation Unit No. 3). See Specific Permit Condition Nos. 18 and 19 of Permit No. 0990568-001-AC. A photo of Unit S-1 is presented in Attachment LW-EU2-A9.				

Emissions Unit Information Section	2 of _	6 Fos	sil Fuel Steam Generating Unit 1
Emissions Unit Control Equipment			
1. Control Equipment/Method Descriptio	n (Limit	to 200 chara	cters per device or method):
2. Control Device or Method Code(s):			
Emissions Unit Details			
1. Package Unit:			
Manufacturer:		Model Nur	nber:
2. Generator Nameplate Rating:	7.5	MW	
3. Incinerator Information: Dwell Temperature			°F
Dwell Time			seconds
Incinerator Afterburner Temperature	:		°F

B. EMISSIONS UNIT CAPACITY INFORMATION (Regulated Emissions Units Only)

Emissions Unit Operating Capacity and Schedule

1.	Maximum Heat Input Rate:		111	mmBtu/hr			
2.	Maximum Incineration Rate:	lb/hr	:	tons/day			
3.	Maximum Process or Through	put Rate:					
4.	Maximum Production Rate:			-			
5.	. Requested Maximum Operating Schedule:						
		hours/day		days/week			
		weeks/year	8,760	hours/year			

C. EMISSIONS UNIT REGULATIONS (Regulated Emissions Units Only)

List of Applicable Regulations

Federal: None
State:
62-4, F.A.C Permitting Requirements
62-210, F.A.C. Stationary Sources – General Requirements
62-213, F.A.C. Title V Permitting Requirements
62-296.406(1), F.A.C. Stationary Sources – Visible Emissions Standards (Steam Generating Unit with Max. Heat Input < 250 mmBtu/hr)
62-296.570(4)(b)(9), F.A.C. NO RACT Emission Limitations
62-297.410(9), F.A.C. Stationary Sources – EPA Method 9 for Visible Emissions Testing
Title V Core List (3/1/02) Presumptively Applicable (Federal and State)
Title V Core List (3/1/02) Fresumptively Applicable (Federal and State)
Local: None

D. EMISSION POINT (STACK/VENT) INFORMATION (Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on Pl	2. Emission Point Type Code:					
Diagram? Fossil Fuel Steam Generating Unit #1 (S-1)						
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):						
4. ID Numbers or Descriptions	s of Emission Units with	this Emi	ssion Point in Common	n:		
5. Discharge Type Code:	6. Stack Height:		7. Exit Diameter:			
V	60	feet	5	feet		
8. Exit Temperature:	9. Actual Volumetric I	Flow	10. Water Vapor:			
311 °F	Rate: 40,659 acfm			%		
11. Maximum Dry Standard Flow Rate: dscfm			12. Nonstack Emission Point Height:			
13. Emission Point UTM Coord	linates:	10301				
Zone: 17 East (km): 592.8 North (km): 2943.7						
14. Emission Point Comment (limit to 200 characters):						
Stack parameters listed for natural gas operation.						

DEP Form No. 62-210.900(1) - Form Effective: 2/11/99

16

E. SEGMENT (PROCESS/FUEL) INFORMATION (All Emissions Units)

Segment I	<u>Description</u>	and Rate:	Segment	1	of	2

1. Segment Description (Process/Fuel Type) (limit to 500 characters):								
Natural Gas Used in Boiler								
2. Source Classification Code (SCC): 1-01-006-01 3. SCC Units: mmcf								
4. Maximum Hourly Rate: 0.11	5. Maximum <i>i</i> 946.8	n Annual Rate: 6. Estimated Annual A Factor:						
7. Maximum % Sulfur:	8. Maximum % Ash: 9. Million Btu per SCC 1,027		9. Million Btu per SCC Unit: 1,027					
10. Segment Comment (limit	to 200 characters):						
Segment Description and Rate: Segment 2 of 2								
1. Segment Description (Process/Fuel Type) (limit to 500 characters):								
No. 6 Fuel Oil Used in Boiler								
2. Source Classification Cod 1-01-004-05	le (SCC):		3. SCC Units: 1,000 gallons Burned					
4. Maximum Hourly Rate: 0.76	5. Maximum <i>i</i> 6,623.71		6. Estimated Annual Activity Factor:					
7. Maximum % Sulfur: 2.25	8. Maximum 9	% Ash:	9. Million Btu per SCC Unit: 146.8					
10. Segment Comment (limit to 200 characters):								

F. EMISSIONS UNIT POLLUTANTS (All Emissions Units)

1. Pollutant Emitted	Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant ' Regulatory Code
SO ₂		***	EL
NO _x			EL
РМ			NS
СО	***		NS
voc	244		NS
PM ₁₀			NS
			-

Emissions Unit Information Section	2	of _	6	Fossil Fuel Steam Generating Unit 1
Pollutant Detail Information Page	1	of	2	Sulfur Dioxides

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1.	Pollutant Emitted:	2.	Total	Per	cent Ef	ficie	ncy of Control:
	SO,						
3.	Potential Emissions:						4. Synthetically
	268 lb/hour	1,1	170	ton	s/year		Limited? []
5.	Range of Estimated Fugitive Emissions:						
	[] 1 [] 2 [] 3	_		_ to		_ tor	ns/year
6.	Emission Factor: 157 lb SO, per 1,000 gal O	il					7. Emissions
	Reference: EPA AP-42 Table 1.3-2 Criteria Pollutant Emission Method Code:						
	Factors for Uncontrolled Fuel Oil Combustion 3						
8.	8. Calculation of Emissions (limit to 600 characters):						
	(157 lb SO ₂ /1,000 gal Oil x 2.25%S x 6,623.71	x 1.0	00 gal	Oil	per vea	r) / 2	.000 lb/ton
	(.o. 15 oo f 1,000 ga. o. 1 = 150 to 1 o,000 to 1	.,,,		•	po. you	.,. –	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
					•		
9.	9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):						
	Potential emissions based on maximum firing rate, 8,760 hr/yr and the minimum oil heating value from 1992 through 1995.						
	value IIOIII 1332 tillougii 1335.						
<u>Al</u>	Allowable Emissions 1 of 1						
1.	Basis for Allowable Emissions Code:	2.	Futur	re E	Effective	e Da	te of Allowable
	OTHER		Emis	sio	ns:		
3.	Requested Allowable Emissions and Units:	4.	Equi	vale	ent Allo	wab	le Emissions:
	2.25% S		2	68	lb/hou	r	1,170 tons/year
5.	Method of Compliance (limit to 60 character	rs):					
	As-fired fuel oil will be sampled each day oil						
	Composite fuel analysis reports submitted questions will be calculated stoichiomet						
6.	Allowable Emissions Comment (Desc. of O			eth	od) (lin	nit to	200 characters):
		r	0		/ (
	See Permit No. 0990045-002-AV specific cond	ditior	s III.B	.7 tł	rough	III.B.	10.

Emissions Unit Information Section	2	of	6	Fossil Fuel Steam Generating Unit 1
Pollutant Detail Information Page	2	of	2	Nitrogen Oxides

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

<u> Po</u>	Potential/Fugitive Emissions						
1.	Pollutant Emitted:	2.	Total	Per	cent Ef	ficie	ency of Control:
	NO _x						
3.	Potential Emissions:						4. Synthetically
	56 lb/hour	243	.09	ton	s/year		Limited? []
5.	Range of Estimated Fugitive Emissions:						,
_				<u>_ to</u>		_ to	ns/year
ο.	Emission Factor: 0.5 lb NO_x per mmBtu						7. Emissions Method Code:
	Reference: NO _x RACT Rule						1
	Will be met as demonstrated by stack test at Tom G. Smith Power Plant (7/93).						
8.							
	Potential emissions based on oil firing. (0.5 lb NO _x per mmBtu x 6623.71 1,000 gal Oil x 146.8 mmBtu / 1,000 gal Oil) / 2,000 lb/ton						
9.	9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):					ters):	
	Potential emissions based on maximum heat input, 8,760 hr/yr, and the minimum heating value of oil reported from 1992 through 1995.						
Al	Allowable Emissions 1 of 1						
1.	Basis for Allowable Emissions Code: RULE	2.	Futu Emis			e Da	ate of Allowable
3.	Requested Allowable Emissions and Units:	4.	Equi	vale	ent Allo	wat	ole Emissions:
	0.5 lb NO _x per mmBtu			56	lb/hou	ır	243.09 tons/year
5.	Method of Compliance (limit to 60 character	rs):					
	EPA Test Method 7E conducted annually, wh per year.	en b	urninç	g liq	uid fuel	is fo	r 400 or more hours
6.	Allowable Emissions Comment (Desc. of Op	perat	ing M	leth	od) (lin	nit to	o 200 characters):
	and the second comment (a second a perming vicinity (minit to 200 cinal action).						

IMINSTORS UNIT THEOLINATION VECTOR AND A LOSSILLAGING OFFICIALITY OF	Emissions Unit Information Section	2	of	6	Fossil Fuel Steam Generating Ur
--	---	---	----	---	---------------------------------

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

<u> </u>	sible Emissions Limitation: Visible Emiss	ions Limitation 1 of 1				
1.	Visible Emissions Subtype: VE	2. Basis for Allowable Opacity: [X] Rule [] Other				
3.	Requested Allowable Opacity: Normal Conditions: 20 % Existence of Excess Opacity Allow	cceptional Conditions: % ed: min/hour				
4.	4. Method of Compliance: Compliance Test Method 9 conducted annually when burning liquid fuels for 400 or more hours per year. Testing conducted using the fuel and/or process input which are expected to result in the highest emissions and within 10 percent of the rated capacity of the source.					
5.	Visible Emissions Comment (limit to 200 c	haracters):				
	I CONTINUOUS MO	NITOD INFODMATION				
		NITOR INFORMATION Subject to Continuous Monitoring)				
<u>C</u>		Subject to Continuous Monitoring)				
<u>Co</u>	(Only Regulated Emissions Units	Subject to Continuous Monitoring)				
1.	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous	Subject to Continuous Monitoring) Monitor of				
1.	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information:	Monitor of 2. Pollutant(s):				
3.	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information: Manufacturer:	Monitor of 2. Pollutant(s): [] Rule [] Other				
3. 4.	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number:	Subject to Continuous Monitoring) Monitor of 2. Pollutant(s): [] Rule [] Other Serial Number:				
 3. 4. 5. 	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date:	Subject to Continuous Monitoring) Monitor of 2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:				
 3. 4. 5. 	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number:	Subject to Continuous Monitoring) Monitor of 2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:				
 3. 4. 5. 	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date:	Subject to Continuous Monitoring) Monitor of 2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:				
 3. 4. 5. 	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date:	Subject to Continuous Monitoring) Monitor of 2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:				
 3. 4. 5. 	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date:	Subject to Continuous Monitoring) Monitor of 2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:				
 3. 4. 5. 	(Only Regulated Emissions Units ontinuous Monitoring System: Continuous Parameter Code: CMS Requirement: Monitor Information: Manufacturer: Model Number: Installation Date:	Subject to Continuous Monitoring) Monitor of 2. Pollutant(s): [] Rule [] Other Serial Number: 6. Performance Specification Test Date:				

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION (Regulated Emissions Units Only)

Supplemental Requirements

	1.	Process Flow Diagram [X] Attached, Document ID: <u>LW-EU2-J1</u> [] Not Applicable [] Waiver Requested
	2.	Fuel Analysis or Specification [X] Attached, Document ID: <u>LW-EU2-J2</u> [] Not Applicable [] Waiver Requested
	3.	Detailed Description of Control Equipment [] Attached, Document ID: [X] Not Applicable [] Waiver Requested
	4.	Description of Stack Sampling Facilities [X] Attached, Document ID: LW-EU2-J4 [] Not Applicable [] Waiver Requested
	5.	Compliance Test Report
		[] Attached, Document ID:
		[X] Previously submitted, Date: 19 Mar 1997
		[] Not Applicable
	6.	Procedures for Startup and Shutdown [] Attached, Document ID: [X] Not Applicable [] Waiver Requested
	7.	Operation and Maintenance Plan [] Attached, Document ID: [X] Not Applicable [] Waiver Requested
	8.	Supplemental Information for Construction Permit Application
		[] Attached, Document ID: [X] Not Applicable
	9.	Other Information Required by Rule or Statute
		[] Attached, Document ID: [X] Not Applicable
	10.	. Supplemental Requirements Comment:
-1	i	

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation
[] Attached, Document ID: [X] Not Applicable
12. Alternative Modes of Operation (Emissions Trading)
[] Attached, Document ID: [X] Not Applicable
13. Identification of Additional Applicable Requirements
[X] Attached, Document ID: <u>LW-FI-C12</u> [] Not Applicable
14. Compliance Assurance Monitoring Plan
[] Attached, Document ID: [X] Not Applicable
15. Acid Rain Part Application (Hard-copy Required)
[] Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID:
[] Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID:
[] New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID:
[] Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID:
[] Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID:
Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID:
[X] Not Applicable

ATTACHMENT LW-EU2-A9
EMISSIONS UNIT COMMENT

7/2/2002




Photo 1. Outside View - Stack and Building Location for Unit S-1


Attachment LW-EU2-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities

Source: Golder, 2002.



ATTACHMENT LW-EU2-J1
PROCESS FLOW DIAGRAM

7/2/2002



Attachment LW-EU2-J1
Process Flow Diagram
Lake Worth Utilities - City of Lake Worth, Florida

Source: Golder, 2002.



ATTACHMENT LW-EU2-J2
FUEL ANALYSIS OR SPECIFICATION



CITY OF LAKE WORTH

1900 2ND AVENUE NORTH LAKE WORTH, FLORIDA 33461-4298

UTILITIES DEPARTMENT POWER RESOURCES

(561) 586-1703 FAX (561) 586-1759

April 29, 2002

Mr. Laxmana Tallam
Supervisor of Permitting, Compliance & Enforcement
Florida Department of Environmental Protection
Post Office Box 15425
400 North Congress Avenue
West Palm Beach, Florida 33416

Subject:

City of Lake Worth Utilities

Quarterly Fuel Oil Analysis Reports First Quarter 2002 (Jan- Feb - Mar)

Dear Mr. Tallam:

Please find attached our quarterly fuel oil analysis as required by our operating permit. Samples reported below have been collected from a composite sample from the on site oil storage facility.

On site quarterly sample:

Type	Date	%S	Note
No.6	04/01/02	1.97	On site quarterly sample
No.2	04/01/02	0.0390	On site quarterly sample

Mr. Laxmana Tallam Supervisor of Permitting, Compliance and Enforcement April 29, 2002

Page 2

The results indicate the oil is within our permit limits of 0.35% sulfur for No. 2 oil and 2.25% sulfur for No. 6 oil. If you need more information, please do hesitate to call me at 561.533.7379 or email at mridge@lakeworth.net.

Sincerely,

CITY OF LAKE WORTH UTILITIES

Mike Ridge

Environmental/ Performance Specialist

Attachments

cc: A.J. Satyal, Environmental Manager, Palm Beach County Health Unit

Larry Baker, Power Resources Superintendent

Margaret Johnstone, Environmental Compliance Officer

Joe Brockway, Results Supervisor

Best Available Copy

SAYBOLT LP.

2610 So. Federal Highway Fort Lauderdale, FL. 33316



LABORATORY NO.: 0484

CUSTOMER

REF. NO(S): #129018/

LABORATORY ANALYSIS REPORT

DATE: 04/08/02

INVOICE NO:

DESCRIPTION

Sample designated as: #6 FUEL OIL

- Identifying Marks: SUBMITTED QUARTERLY SAMPLE (04/01/02) CITY POWER PLANT LAKE WORTH, FLORDA
- Submitted by: CITY OF LAKE WORTH
- Client: CITY OF LAKE WORTH

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST	METHOD	RESULT
GRAVITY, API AT 60 F	D-1298	,21.3
GRAVITY, SPECIFIC	D-1298	0.9260
SULFUR, X-RAY, WT PCT	D-4294	1.97
ASH, WT PCT	D-482	0.032
HEAT OF COMBUSTION, BTU/LB	D-4868	18761
HEAT OF COMBUSTION, BTU/GAL		144904
HEAT OF COMBUSTION, BTU/BBL		6085968

MEMBERS ASTM-API-SAE

JABOLT T

ATTACHMENT LW-EU2-J4

DESCRIPTION OF STACK SAMPLING FACILITIES

ATTACHMENT LW-EU2-J4

DESCRIPTION OF STACK SAMPLING FACILITIES

FOSSIL FUEL STEAM GENERATING UNIT (S-1)

Emission testing can be performed on all of the major emission units. However, on S-1, permanent platform structures do not exist. In order to perform emission tests on these units, a bucket truck is used to hoist personnel and equipment to the stack test port elevations. The stack sampling locations are identified for S-1 on the attached figure.




FIGURE 3 SAMPLING POINT LOCATION UNIT S-I LAKE WORTH UTILITIES LAKE WORTH, FLORIDA

AIR CONSULTING and ENGINEERING

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

Emissions Unit Description and Status

238	masions emit bes	DI I DI COLL MILA DI CAUCAD				
1.	Type of Emission	ns Unit Addressed in This	s Section: (Check one)			
[X	X] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).					
[] This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.					
[This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.					
2.	Regulated or Unr	egulated Emissions Unit	? (Check one)			
[X	X] The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.					
[] The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.					
3.	3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Fossil Fuel Steam Generating Unit 3 (S-3)					
4.		dentification Number:	[] No ID		
	ID: 009		[] ID Unknown		
5.	Emissions Unit Status Code:	6. Initial Startup Date: 1966	7. Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit? [X]		
9.	Emissions Unit C	Comment: (Limit to 500 C	Characters)			
	not provide steam	n to operate the generatio	e operated when Lake Worth on portion of S-3. See Specifi AC. A photo of Unit S-3 is pro	c Permit Condition		

Eı	nissions Unit Information Section	3	_ of _	6	Fossil Fuel Steam Generating Unit 3
<u>E</u> 1	nissions Unit Control Equipment				
1.	Control Equipment/Method Descrip	otion (Limit	to 200	characters per device or method):
2.	Control Device or Method Code(s):				
Er	nissions Unit Details				
1.	Package Unit:			3.5 .	137
	Manufacturer:				el Number:
2.	Generator Nameplate Rating: 26.5			MW	
3.	Incinerator Information:	uro			°F
	Dwell Temperat Dwell Ti				r seconds
	Incinerator Afterburner Temperat				°F
		_			

Emissions Unit Information Section	3	of	6	Fossil Fuel Steam Generating Unit 3
	-	O.	_	

B. EMISSIONS UNIT CAPACITY INFORMATION (Regulated Emissions Units Only)

Emissions Unit Operating Capacity and Schedule

1.	Maximum Heat Input Rate:		325.1	mmBtu/hr
2.	Maximum Incineration Rate:	lb/hr		tons/day
3.	Maximum Process or Through	put Rate:		
4.	Maximum Production Rate:			
5.	Requested Maximum Operatin	g Schedule:		
		hours/day		days/week
		weeks/year	8,760	hours/year
6.	Operating Capacity/Schedule C	Comment (limit to 200 ch	aracters):	

C. EMISSIONS UNIT REGULATIONS (Regulated Emissions Units Only)

List of Applicable Regulations

Federal:
40 CFR 72 Acid Rain Program
40 CFR 73 SO ₂ Allowance
40 CFR 75 Continuous Emissions Monitoring
State:
62-4, F.A.C. Permitting Requirements
62-210, F.A.C. Stationary Sources – General Requirements
62-210.700(3) Visible Emissions Soot Blowing Opacity Limit (60%)
62-213, F.A.C. Title V Permitting Requirements
62-296.405(1)(a), F.A.C. Stationary Sources – Visible Emissions Standards (Steam Generating
Unit with Max. Heat Input > 250 mmBtu/hr)
62-296.405(1)(b), F.A.C. 0.1 lb PM/mmBtu Particulate Emission Limit
62-296.570(4)(b)(9), F.A.C. NO, RACT Emission Limitations
62-297.401(5), F.A.C. EPA Test Method 5 for PM (Stack Temperature >375°F)
62-297.410(9), F.A.C. Stationary Sources – EPA Method 9 for Visible Emissions Testing
62-297.410(17), F.A.C. EPA Test Method 17 for PM (Stack Temperature < 375°F)
Section 403.502, Florida Statutes [PPSA Certification #PA 74-05(I.1)] Compliance with %S limit
by sampling and analysis of as-fired fuel oil. Sample on used
fuel. Analyze composite monthly.
Section 403.501, Florida Statutes [PPSA Certification #PA 74-05 (I.1)] 2.25%S in Fuel Oil Limit
Title V Core List (3/1/02) Presumptively Applicable (Federal and State)
Local: None

D. EMISSION POINT (STACK/VENT) INFORMATION (Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on P.	lot Plan or	2. Emission Po	oint Type Code:			
Flow Diagram?	1					
Fossil Fuel Steam Generatir						
3. Descriptions of Emission P	oints Comprising	g this Emissions 1	Unit for VE Tracking	(limit to		
100 characters per point):						
4. ID Numbers or Description	s of Emission U	nits with this Emi	ssion Point in Comm	on.		
Is realisely of Beschiption	of Emission C	anto with this bin		0111		
5. Discharge Type Code:	6. Stack Heig	ht:	7. Exit Diameter:			
v		113 feet	7	feet		
			·	1001		
8. Exit Temperature:	9. Actual Vol	umetric Flow	10. Water Vapor:			
Gas: 293 °F	1	118,719 acfm		%		
	1					
Oil· 289 °F	Oil: 1	21,338 acfm	mission Point Height:			
	Oil: 1	21,338 acfm	mission Point Height:			
Oil· 289 °F	Oil: 1	21,338 acfm	-			
Oil· 289 °F	Oil: 1 Ow Rate: dscfm	21,338 acfm	-			
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord	Oil: 1 Ow Rate: dscfm dinates:	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord	Oil: 1 Ow Rate: dscfm	12. Nonstack En	-			
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				
Oil· 289 °F 11. Maximum Dry Standard Flo 13. Emission Point UTM Coord Zone: 17 E	Oil: 1 Ow Rate: dscfm dinates: ast (km): 592.8	12. Nonstack En				

E. SEGMENT (PROCESS/FUEL) INFORMATION (All Emissions Units)

Segment Description and Rate: Segment 1 of 2

1. Segment Description (Pro	1. Segment Description (Process/Fuel Type) (limit to 500 characters):					
Natural Gas Used in Boiler						
2. Source Classification Cod	e (SCC):	3. SCC Units mmcf	:			
4. Maximum Hourly Rate: 0.317	5. Maximum A 2,773	Annual Rate:	6. Estimated Annual Activity Factor:			
7. Maximum % Sulfur:	8. Maximum 9	% Ash:	9. Million Btu per SCC Unit: 1,027			
10. Segment Comment (limit	to 200 characters)):				
Segment Description and Ra	ate: Segment 2	2 of <u>2</u>				
1. Segment Description (Pro	cess/Fuel Type)	(limit to 500 ch	aracters):			
No. 6 Fuel Oil Used in Boil	er					
			·			
2. Source Classification Cod 1-01-004-05	e (SCC):	3. SCC Units 1,000 gall	s: ons burned			
4. Maximum Hourly Rate: 2.22	5. Maximum <i>A</i> 19,432.13		6. Estimated Annual Activity Factor:			
7. Maximum % Sulfur: 2.25						
10. Segment Comment (limit	to 200 characters)):				

F. EMISSIONS UNIT POLLUTANTS (All Emissions Units)

1. Pollutant Emitted	2. Primary Control	3. Secondary Control	4. Pollutant
	Device Code	Device Code	Regulatory Code
SO,		,	EL
NO _x			EL
РМ			EL
со			NS
voc			NS
PM ₁₀		•••	NS
	·		

DEP Form No. 62-210.900(1) - Form

Emissions Unit Information Section	3	of _	6	Fossil Fuel Steam Generating Unit 3
Pollutant Detail Information Page	1	of	3	Sulfur Dioxides

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1.	Pollutant Emitted:	2. Total Percent Efficie	ency of Control:
	SO,		,
3.	Potential Emissions: 784 lb/hour	3,432 tons/year	4. Synthetically Limited? []
5.	Range of Estimated Fugitive Emissions:		
	[] 1 [] 2 [] 3		ns/year
6.	Emission Factor: 157 lb SO ₂ per 1,000 gal O		7. Emissions
	Reference: EPA AP-42 Table 1.3-2 Criteria F Factors for Uncontrolled Fuel O		Method Code:
8.	Calculation of Emissions (limit to 600 chara		<u> </u>
	(157 lb SO ₂ /1,000 gal Oil x 2.25% S x 19,432.13	3 x 1,000 gal Oil per year)	/ 2,000 lb/ton
9.	Pollutant Potential/Fugitive Emissions Com Potential emissions based on maximum firing value from 1992 through 1995.	,	,
Al	lowable Emissions Allowable Emissions	<u>1</u> of 1	
1.	Basis for Allowable Emissions Code: OTHER	2. Future Effective Da Emissions:	ate of Allowable
3.	Requested Allowable Emissions and Units:	4. Equivalent Allowal	ole Emissions:
	2.475 lb SO ₂ per mmBtu	804.6 lb/hour 3	, 524.25 tons/year
5. 6.	Method of Compliance (limit to 60 character As-fired fuel oil will be sampled each day oil Composite fuel analysis reports submitted questions will be calculated stoichiomet Allowable Emissions Comment (Desc. of O	is fired. uarterly. rically. See below.	o 200 characters):
υ.	SO ₂ emissions obtained from CEMs may be u emissions.	, ,	

Emissions Unit Information Section	3_	of	6	Fossil Fuel Steam Generating Unit 3
Pollutant Detail Information Page	2	of	3	Nitrogen Oxides

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Po	tential/Fugitive Emissions					
1.	Pollutant Emitted:	2.	Total Pe	rcent Effici	ency of Control:	
	NO _x					
3.	Potential Emissions:				4. Synthetically	
	162.6 lb/hour	711	.97 to	ns/year	Limited? []_	
5.	Range of Estimated Fugitive Emissions:		6 .	a to	ons/year	
6.	Emission Factor: 0.5 lb NO _x per mmBtu			o to	7. Emissions	
	Reference: NO, RACT Rule				Method Code:	
_					1	
8.	Calculation of Emissions (limit to 600 charac	cters):			
	Potential emissions based on oil firing.					
	(0.5 lb NO _x per mmBtu Oil x 2847,876 mmBtu/	yr) /	2,000 lb/1	on		
9.	Pollutant Potential/Fugitive Emissions Com	men	(limit to	200 charac	eters):	
	Potential emissions based on maximum firing	g rat	e and 8,7	60 hr/yr.		
				•		
L						
<u>Al</u>	lowable Emissions Allowable Emissions	1	of1			
1.	Basis for Allowable Emissions Code: RULE	2.			ate of Allowable	
3	Requested Allowable Emissions and Units:	1	Emissio		ble Emissions:	
5.	•		-		_	
	0.5 lb NO _x per mmBtu	Ļ	162.6	lb/hour	711.97 tons/year	
3.	5. Method of Compliance (limit to 60 characters):					
	CEMS 30-day rolling average.					
6.	6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):					
		•	Č	, ,	ŕ	
				,		

Emissions Unit Information Section	3	of _	6	Fossil Fuel Steam Generating Unit 3
Pollutant Detail Information Page	3	of	3	Particulate Matter - Total

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

	D. H E. to. 1	0 E : 1D : ECC: 1	
1.	Pollutant Emitted:	2. Total Percent Effici	ency of Control:
	PM		
3.	Potential Emissions:		4. Synthetically
	53 lb/hour	232 tons/year	Limited? [],
5.	Range of Estimated Fugitive Emissions:		<u> </u>
	[] 1 [] 2 [] 3	to to	ons/year
6.	Emission Factor: 9.19 x % S + 3.22 lb PM/1,	000 gal Oil	7. Emissions
	Reference: EPA AP-42 Table 1.3-2		Method Code:
8.	Calculation of Emissions (limit to 600 chara	cters):	
	Potential emissions based on oil firing.	10 400 40 4 000 1 03//	1 / 0 000 lb //
	[(9.19 x 2.25% S + 3.22 lb PM/1,000 gal Oil) x 1	19,432.13 x 1,000 gai Oil/y	/r] / 2,000 lb/ton
<u> </u>		. (1)	
9.	Pollutant Potential/Fugitive Emissions Com	ment (limit to 200 charac	eters):
	Potential emissions based on maximum firing	n rate 8 760 hr/vr and the	minimum heating
	value of oil from 1992 through 1995.	g rate, e, oo my and me	
L			_
<u>Al</u>	lowable Emissions Allowable Emissions	<u>1</u> of 1	
1.	Basis for Allowable Emissions Code:	2. Future Effective D	ate of Allowable
	RULE	Emissions:	_
3.	Requested Allowable Emissions and Units:	4. Equivalent Allowa	ble Emissions:
	0.1 lb PM per mmBtu	32.5 lb/hour	142.35 tons/year
5.	Method of Compliance (limit to 60 character	rs):	
	Test required only if unit operation on oil, exc	clusive of startup, exceed	ls 400 hr/yr.
6.	Allowable Emissions Comment (Desc. of Op	perating Method) (limit t	o 200 characters):
	Dula 02 200 407/4\/la)		
	Rule 62-296.405(1)(b)		

Emissions Unit Information Section	3	of	6	Fossil Fuel Steam Generating Unit	: 3
---	---	----	---	-----------------------------------	-----

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity:
VE	[X] Rule [] Other
3. Requested Allowable Opacity:	10 10
	exceptional Conditions: 40 % yed: 2 min/hour
Maximum Period of Excess Opacity Allov	ved: 2 min/hour
4. Method of Compliance:	
hours per year. Testing conducted using the	nally when burning liquid fuels for 400 or more the fuel and/or process input which are expected in 10 percent of the rated capacity of the source.
5. Visible Emissions Comment (limit to 200	characters):
Rule 62-296.405(1)(a)	
	ONITOR INFORMATION s Subject to Continuous Monitoring) s Monitor 1 of 6
	S Monton of
1. Parameter Code: SO ₂	2. Pollutant(s):
 Parameter Code: SO₂ CMS Requirement: 	
	2. Pollutant(s):
CMS Requirement: Monitor Information: Manufacturer: TECO/Spectrum System	2. Pollutant(s): [X] Rule [Other
CMS Requirement: Monitor Information: Manufacturer: TECO/Spectrum System Model Number: 43B	2. Pollutant(s): [X] Rule [Other Serial Number: 43B-48835-282
 3. CMS Requirement: 4. Monitor Information:	2. Pollutant(s): [X] Rule [Other Serial Number: 43B-48835-282 6. Performance Specification Test Date:
CMS Requirement: Monitor Information: Manufacturer: TECO/Spectrum System Model Number: 43B	2. Pollutant(s): [X] Rule [] Other Serial Number: 43B-48835-282 6. Performance Specification Test Date: 20 DEC 1994
 3. CMS Requirement: 4. Monitor Information:	2. Pollutant(s): [X] Rule [] Other Serial Number: 43B-48835-282 6. Performance Specification Test Date: 20 DEC 1994

DEP Form No. 62-210.900(1) - Form

Emissions Unit Information Section	3	of	6	Fossil Fuel Steam Generating Unit
	-	O.	_	

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

(Omy Regulated Emissions)	onto Subject to a v E Emmonton
Visible Emissions Limitation: Visible Emissions	sions Limitation 2 of 2
 Visible Emissions Subtype: VES 	2. Basis for Allowable Opacity: [X] Rule [] Other
Requested Allowable Opacity: Normal Conditions: Maximum Period of Excess Opacity Allow	Exceptional Conditions: % ved:4 six-min periods per 3 hours min/hour
4. Method of Compliance:	
Compliance Test Method 9 conducted annu hours per year.	ually when burning liquid fuels for 400 or more
5. Visible Emissions Comment (limit to 200	characters):
Rule 62-210.700(3)	
I. CONTINUOUS MO	ONITOR INFORMATION
(Only Regulated Emissions Unit Continuous Monitoring System: Continuou	s Subject to Continuous Monitoring)
	s Subject to Continuous Monitoring)
Continuous Monitoring System: Continuou	s Subject to Continuous Monitoring) s Monitor 2 of 6
Continuous Monitoring System: Continuou 1. Parameter Code: NO _x	s Subject to Continuous Monitoring) s Monitor2 of6 2. Pollutant(s): [X] Rule [] Other
Continuous Monitoring System: Continuou 1. Parameter Code: NO _x 3. CMS Requirement: 4. Monitor Information: Manufacturer: TECO/Spectrum System Model Number: 42D 5. Installation Date:	S Subject to Continuous Monitoring) S Monitor2 of6 2. Pollutant(s): [X] Rule
Continuous Monitoring System: Continuou 1. Parameter Code: NO _x 3. CMS Requirement: 4. Monitor Information: Manufacturer: TECO/Spectrum System Model Number: 42D	s Subject to Continuous Monitoring) s Monitor2 of6 2. Pollutant(s): [X] Rule [] Other s
Continuous Monitoring System: Continuou 1. Parameter Code: NO _x 3. CMS Requirement: 4. Monitor Information: Manufacturer: TECO/Spectrum System Model Number: 42D 5. Installation Date: 12 DEC 1994	s Subject to Continuous Monitoring) s Monitor 2 of 6 2. Pollutant(s): [X] Rule [] Other s Serial Number: 42D-48739-281 6. Performance Specification Test Date: 20 DEC 1994

DEP Form No. 62-210.900(1) - Form Effective: 2/11/99

0237548\4\4.3\4.3.1\Lake Worth_Form1_EU5 7/2/02

Emissions Unit Information Section	3	of	6	Fossil Fuel Steam Generating Unit
------------------------------------	---	----	---	-----------------------------------

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissi	ons Limitation of
1. Visible Emissions Subtype:	Basis for Allowable Opacity: Nule Other
3. Requested Allowable Opacity: Normal Conditions: % Ex Maximum Period of Excess Opacity Allower	aceptional Conditions: % ed: min/hour
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 c	haracters):
	NITOR INFORMATION Subject to Continuous Monitoring) Monitor 3 of 6
1. Parameter Code: CO ₂	2. Pollutant(s):
3. CMS Requirement:	[X] Rule [] Other
Monitor Information: Manufacturer: TECO/Spectrum Systems Model Number: 42D	Serial Number: 42D-48739-281
5. Installation Date: 12 DEC 1994	6. Performance Specification Test Date: 20 DEC 1994
7. Continuous Monitor Comment (limit to 200 Rule 62-214, F.A.C.	

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

<u>Vi</u>	sible Emissions Limitation: Visible Emissi	ons Limitation of		
1.	Visible Emissions Subtype:	2. Basis for Allowable Opacity:		
	[] Rule [] Other			
3.	Requested Allowable Opacity: Normal Conditions: % Ex Maximum Period of Excess Opacity Allower	ceptional Conditions: % ed: min/hour		
4.	Method of Compliance:			
5.	Visible Emissions Comment (limit to 200 c	haracters):		
Co		NITOR INFORMATION Subject to Continuous Monitoring) Monitor4 of6		
1.	Parameter Code: FLOW	2. Pollutant(s):		
3.	CMS Requirement:	[X] Rule [] Other		
4.	Monitor Information: Manufacturer: United Sciences/Spectrur Model Number: Ultra Flow 100	n Systems Serial Number: 9401746		
5.	Installation Date: Scheduled	 Performance Specification Test Date: 12 DEC 1994 		
7.	Continuous Monitor Comment (limit to 200			
	Rule 62-214, F.A.C.			

Emissions Unit Information Section	3	of	6	Fossil Fuel Steam Generating Unit 3
Dimesione out into mation ection	•	U1	•	

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emiss	
	ions Limitation of
1. Visible Emissions Subtype:	2. Basis for Allowable Opacity:
2. Doguestad Allowakia Openitus	[] Rule [] Other
Requested Allowable Opacity: Normal Conditions: Maximum Period of Excess Opacity Allow	cceptional Conditions: % ed: min/hour
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 of	haracters):
I. CONTINUOUS MC	NITOR INFORMATION
` • B	Subject to Continuous Monitoring)
Continuous Monitoring System: Continuous	-
	-
Continuous Monitoring System: Continuous	Monitor <u>5</u> of <u>6</u>
Continuous Monitoring System: Continuous 1. Parameter Code: VE 3. CMS Requirement: 4. Monitor Information:	Monitor5 of6 2. Pollutant(s): [X] Rule [] Other
Continuous Monitoring System: Continuous 1. Parameter Code: VE 3. CMS Requirement:	Monitor5 of6 2. Pollutant(s): [X] Rule [] Other
Continuous Monitoring System: Continuous 1. Parameter Code: VE 3. CMS Requirement: 4. Monitor Information: Manufacturer: United Sciences/Spectru Model Number: 500C 5. Installation Date:	Monitor5 of6 2. Pollutant(s): [X] Rule [] Other m Systems Serial Number: 0394853 6. Performance Specification Test Date:
Continuous Monitoring System: Continuous 1. Parameter Code: VE 3. CMS Requirement: 4. Monitor Information: Manufacturer: United Sciences/Spectru Model Number: 500C	Monitor5 of6 2. Pollutant(s): [X] Rule [] Other m Systems Serial Number: 0394853 6. Performance Specification Test Date: 20 DEC 1994
Continuous Monitoring System: Continuous 1. Parameter Code: VE 3. CMS Requirement: 4. Monitor Information: Manufacturer: United Sciences/Spectrum Model Number: 500C 5. Installation Date: 12 DEC 1994	Monitor5 of6 2. Pollutant(s): [X] Rule [] Other m Systems Serial Number: 0394853 6. Performance Specification Test Date: 20 DEC 1994
Continuous Monitoring System: Continuous 1. Parameter Code: VE 3. CMS Requirement: 4. Monitor Information: Manufacturer: United Sciences/Spectru Model Number: 500C 5. Installation Date: 12 DEC 1994 7. Continuous Monitor Comment (limit to 200)	Monitor5 of6 2. Pollutant(s): [X] Rule [] Other m Systems Serial Number: 0394853 6. Performance Specification Test Date: 20 DEC 1994
Continuous Monitoring System: Continuous 1. Parameter Code: VE 3. CMS Requirement: 4. Monitor Information: Manufacturer: United Sciences/Spectru Model Number: 500C 5. Installation Date: 12 DEC 1994 7. Continuous Monitor Comment (limit to 200)	Monitor5 of6 2. Pollutant(s): [X] Rule

20

DEP Form No. 62-210.900(1) - Form Effective: 2/11/99

0237548\4\4.3\4.3.1\Lake Worth_Form1_EU5 7/2/02

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissi	ons Limitation of
1. Visible Emissions Subtype:	Basis for Allowable Opacity: Nule Other
3. Requested Allowable Opacity: Normal Conditions: % Ex Maximum Period of Excess Opacity Allower	sceptional Conditions: %
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 c	haracters):
	NITOR INFORMATION Subject to Continuous Monitoring) Monitor 6 of 6
1. Parameter Code: TEMP	2. Pollutant(s):
3. CMS Requirement:	[X] Rule [] Other
4. Monitor Information: Manufacturer: United Sciences/Spectrum Model Number: Ultra Flow 100	n Systems Serial Number: 9401746
5. Installation Date: 12 DEC 1994	6. Performance Specification Test Date: 20 DEC 1994
7. Continuous Monitor Comment (limit to 200 Rule 62-214, F.A.C. Temperature calculated	characters):

DEP Form No. 62-210.900(1) - Form

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION (Regulated Emissions Units Only)

Supplemental Requirements

1.	Process Flow Diagram
	[X] Attached, Document ID: <u>LW-EU3-J1</u> [] Not Applicable [] Waiver Requested
2.	Fuel Analysis or Specification
	[X] Attached, Document ID: <u>LW-EU3-J2</u> [X] Not Applicable [] Waiver Requested
3.	Detailed Description of Control Equipment
	[] Attached, Document ID: [X] Applicable [] Waiver Requested
4.	Description of Stack Sampling Facilities
	[X] Attached, Document ID: <u>LW-EU3-J4</u> [] Not Applicable [] Waiver Requested
5.	Compliance Test Report
	[] Attached, Document ID:
	[X] Previously submitted, Date: 7 Dec 2001
	[] Not Applicable
6.	Procedures for Startup and Shutdown
	[] Attached, Document ID: [X] Applicable [] Waiver Requested
7.	Operation and Maintenance Plan
	[] Attached, Document ID: [X] Not Applicable [] Waiver Requested
8.	Supplemental Information for Construction Permit Application
	[] Attached, Document ID: [X] Not Applicable
9.	Other Information Required by Rule or Statute
	[] Attached, Document ID: [X] Not Applicable
10	. Supplemental Requirements Comment:

DEP Form No. 62-210.900(1) - Form

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation
[] Attached, Document ID: [X] Not Applicable
12. Alternative Modes of Operation (Emissions Trading)
[] Attached, Document ID: [X] Not Applicable
13. Identification of Additional Applicable Requirements
[X] Attached, Document ID: <u>LW-FI-C12</u> [] Not Applicable
14. Compliance Assurance Monitoring Plan
[] Attached, Document ID:[X] Not Applicable
15. Acid Rain Part Application (Hard-copy Required)
[X] Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: LW-EU3-J15
[] Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID:
[] New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID:
[] Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID:
[] Phase II NO _x Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID:
[] Phase NO _x Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID:
[] Not Applicable

ATTACHMENT LW-EU3-A9
EMISSIONS UNIT COMMENT




Photo 1. Inside View - Turbine and Generator for Unit S-3




Photo 2. Outside View - Right Stack is for Unit S-3

Attachment LW-EU3-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities


Source: Golder, 2002.



ATTACHMENT LW-EU3-J1

PROCESS FLOW DIAGRAM

7/2/2002 0237548/4/4.4/4.4.1/LW-EU3-J1



Attachment LW-EU3-J1 Process Flow Diagram Lake Worth Utilities - City of Lake Worth, Florida

Source: Golder, 2002.



ATTACHMENT LW-EU3-J2
FUEL ANALYSIS OR SPECIFICATION



CITY OF LAKE WORTH

1900 2ND AVENUE NORTH LAKE WORTH, FLORIDA 33461-4298

UTILITIES DEPARTMENT POWER RESOURCES

(561) 586-1703 FAX (561) 586-1759

April 29, 2002

Mr. Laxmana Tallam
Supervisor of Permitting, Compliance & Enforcement
Florida Department of Environmental Protection
Post Office Box 15425
400 North Congress Avenue
West Palm Beach, Florida 33416

Subject:

City of Lake Worth Utilities

Quarterly Fuel Oil Analysis Reports First Quarter 2002 (Jan- Feb - Mar)

Dear Mr. Tallam:

Please find attached our quarterly fuel oil analysis as required by our operating permit. Samples reported below have been collected from a composite sample from the on site oil storage facility.

On site quarterly sample:

Type	Date	%S	Note
No.6	04/01/02	1.97	On site quarterly sample
No.2	04/01/02	0.0390	On site quarterly sample

Mr. Laxmana Tallam Supervisor of Permitting, Compliance and Enforcement April 29, 2002

Page 2

The results indicate the oil is within our permit limits of 0.35% sulfur for No. 2 oil and 2.25% sulfur for No. 6 oil. If you need more information, please do hesitate to call me at 561.533.7379 or email at mridge@lakeworth.net.

Sincerely,

CITY OF LAKE WORTH UTILITIES

mi nj

Mike Ridge

Environmental/Performance Specialist

Attachments

cc: A.J. Satyal, Environmental Manager, Palm Beach County Health Unit

Larry Baker, Power Resources Superintendent

Margaret Johnstone, Environmental Compliance Officer

Joe Brockway, Results Supervisor

Best Available Copy

SAYBOLT LP.

2610 So. Federal Highway Fort Lauderdale, FL. 33316



LABORATORY NO.: 0484

CUSTOMER

REF. NO(S): #129018/

LABORATORY ANALYSIS REPORT

DATE: 04/08/02

INVOICE NO:

DESCRIPTION

Sample designated as: #6 FUEL OIL

■ Identifying Marks: SUBMITTED QUARTERLY SAMPLE (04/01/02) CITY POWER PLANT LAKE WORTH, FLORDA

Submitted by: CITY OF LAKE WORTH

Client: CITY OF LAKE WORTH

SAMPLES SMALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE [45] DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST	METHOD	RESULT
GRAVITY, API AT 60 F	D-1298	,21.3
GRAVITY, SPECIFIC	D-1298	0.9260
SULFUR, X-RAY, WT PCT	D-4294	1.97
ASH, WT PCT	D-482	0.032
HEAT OF COMBUSTION, BTU/LB	D-4868	18761
HEAT OF COMBUSTION, BTU/GAL		144904
HEAT OF COMBUSTION, BTU/BBL		6085968

MEMBERS ASTM-API-SAE

ALB J SAYBOLT

ATTACHMENT LW-EU3-J4 DESCRIPTION OF STACK SAMPLING FACILITIES

ATTACHMENT LW-EU3-J4


DESCRIPTION OF STACK SAMPLING FACILITIES

FOSSIL FUEL STEAM GENERATING UNIT 3 (S-3)

On S-3, a continuous emission monitoring system is installed. The continuous emission monitoring system equipment is serviced and tested from two permanently installed stack platforms, one at elevation 114'-0" and one at elevation 101'-6". Both platforms are accessed by a caged ladder.

The stack configuration of the continuous emission monitoring system equipment and test ports on S-3 is presented in the attached figure.

Best Available Copy



ATTACHMENT LW-EU3-J15
ACID RAIN PERMIT APPLICATION



CITY OF L

LAKE WORTH

1900 2ND AVENUE NORTH LAKE WORTH, FLORIDA 33461-4298

> (407) 586-1668 FAX (407) 586-1702

UTILITIES DEPARTMENT December 13, 1995

Mr. John C. Brown
Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Subject:

Acid Rain Permit Application

Tom G. Smith Electric Power Plant

Lake Worth, Florida

Dear Mr. Brown:

Enclosed please find the original and three copies of the Phase II Acid Rain Permit Application for the Tom G. Smith Electric Power Plant.

Please note that Unit S-4 has not been available for service since June 1989. The unit experienced extensive damage in a forced outage and is in extended shutdown for repair. Unit S-4 is an affected Phase II unit currently permitted, thus included on this application with Unit S-3. Upon Unit S-4's return to service, Continuous Emission Monitors will be installed.

If you have any questions or require any additional information to process this application, please notify us.

Sincerely,

CITY OF LAKE WORTH UTILITIES

Harvey F. Wildschuetz, Utilities Director

Designated Representative

Enclosure

c: AJ Satyal, Palm Beach County Health Department, w/enclosure Al Magley, Jr., Raytheon Engineers and Constructors, w/enclosure Anatole Bezugly, Assistant Utilities Director Lloyd Gibb, Power Resources Superintendent (ADR) Margaret Johnstone, Environmental Compliance Officer Bill Michael, Mechanical Systems Engineer

Phase II Permit Application

Pene 1

	This submission is	: X New [Revised		
STEP 1 dentify the source by	Tom G. Sm	ith		FL	673
dentify the source by plant name, State, and ORIS code from NADB	Plant Name			State	ORIS Cod
ONIS code Holl NADB					
		Comp Pl	liance an		
STEP 2	ŧ	b		d	· a
Enter the boiler ID#	Boiler ID#	Unit Will	Repowering	Now Units	New Units
affected unit, and indicate whether a repowering plan is being submitted for	351101 131	Hold Allow- ances in Accordance	Plan	11011 01112	(tott oma
"yes" or "no" at column c. For new	·	with 40 CFR 72.9(c)(1)		Commence Operation Date	Monitor Certificatio Deedline
units, enter the re- quested information in columns d and e	S-3	Yes	NO		
	S-4	Yos	NO		
		Yos			
		Yos			
		Yes			
		Yes	· · · · · · · · · · · · · · · · · · ·		
		Yes			
	•	Yes			
		Yos			
		Yes			
		Yes			
		Yes			
STEP 3 Check the box if the		ring Technology Po		wering Extension Plan for dubited or will be sub-	

DEP Farm Na. 62-210.900(1)(a) - Farm

Effective: 7-1-95

Recordkeeping and Reporting Requirements (cont.)

fiv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 support I and 40 CFR part 75.

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, complete Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.

(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the

Act and 18 U.S.C. 1001.

(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

(4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program. (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.

(6) Any provision of the Acid Rain Program that applies to an Acid Rain unit lincluding a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violetion by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source

of which they are not owners or operators or the designated representative.
(7) Each violation of a provision of 40 CFR parts 72, 73, 75, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a

separate violation of the Act.

Effect on Other Authorities. No provision of the Acid Rain Program, an Acid Rain part application, en Acid Rain pert, or a written exemption under 40 CFR 72.7 or 72.3 shall be construed as

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners end operators and, to the extant applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shell not affect the source's obligation to comply with any other provisions of the Act

(3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;

(4) Modifying the Federal Power Act or effecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act or

(5) Intertening with ar impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this supmission on benalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familier with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I cartify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I em aware that there are significant panalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Nome Harvey	F. Wildschuetz, Atilities Dire	ctor, Designated Rep.
Signapuracoucu	Hillschuet	Date 12/13/95
/		· · · · · · · · · · · · · · · · · · ·

DEP Form No. 62-210.900(1)(a) - Form

Effective: 7-1-95

Plant Name (from Step 1)

STEP 4
Read the standard requirements and certification, enter the name of the designated representative, and sign and data

_...` .

Standard Requirements

Permit Requirements.

- (1) The designated representative of each Acid Rein source and each Acid Rein unit at the source shell:
 (i) Submit a complete Acid Rein part application (including a compliance plan) under 40 CFR part 72,
 Rules 62-214.320 and 330, F.A.C. in accordance with the deedlines specified in Rule 62-214.320,
 F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain part application and issue or dany an Acid Rain permit:
- (2) The owners and operators of each Acid Rein source and each Acid Rein unit at the source shall;

 (i) Operate the unit in compliance with a complete Acid Rein part application or a superseding Acid Rein part issued by the permitting authority; and (ii) Have an Acid Rein Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR pert 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR pert 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall;
 (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxida for the previous calendar year from the unit; and
- (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.

 (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under peragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rein Program.
- (5) An allowence shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written examption under 40 CFR 72.7 and 72.8 and no provision of law shell be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shell comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rein unit that has excess emissions in any calendar year shall support a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall: (i) Pay without damend the penalty required, and pay upon damend the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements.

- (1) Unlass otherwise provided, the owners and operators of the source end each Acid Rein unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the dete the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
 - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the cartificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative:
 - (ii) All errissions monitoring information, in accordance with 40 CFR part 75;
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

STEP 5 (optional) Enter the source AIRS and FINDS identification numbers, if known

AIRS	e 100 - 100 - 1		t ting during a	
FINOS	e sterriber	يعمم سيس		

Emissions	Unit	Informat	tion Secti	on	4	of	6	

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

Emissions Unit Description and Status

1. Type of Emission	ns Unit Addressed in This	s Section: (Check one)				
process or produc	[X] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).					
process or produc		addresses, as a single emission which has at least one definative emissions.				
		addresses, as a single emission which produce fugitive emis				
2. Regulated or Uni	egulated Emissions Unit	? (Check one)	_			
[X]The emissions ur emissions unit.	it addressed in this Emis	sions Unit Information Secti	on is a regulated			
[]The emissions ur emissions unit.	it addressed in this Emis	sions Unit Information Secti	on is an unregulated			
	3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Gas Turbine #1 (GT-1)					
4. Emissions Unit I	dentification Number:		[] No ID			
ID: 006			[] ID Unknown			
5. Emissions Unit Status Code:	6. Initial Startup Date: 1976	7. Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit?			
	9. Emissions Unit Comment: (Limit to 500 Characters) A photograph of this emission unit is presented in Attachment LW-EU4-A9.					
	•					

DEP Form No. 62-210.900(1) - Form Effective: 2/11/99

Gas Turbine #1 (GT-1)

Emissions Unit Information Section	4	of	6	Gas Turbine #1 (GT	-1

Emissions	Unit	Control	Eq	uipment

1.	Control Equipment/Method Description (Limit to 200 characters per device or method):						
2	Control Davice or Method Codo(s):						
۷.	. Control Device or Method Code(s):						

Emissions Unit Details

1.	Package Unit:		
	Manufacturer: Westinghouse	Model Number:	
2.	Generator Nameplate Rating: 30	MW	
3.	Incinerator Information:		
	Dwell Temperature:		°F
	Dwell Time:		seconds
	Incinerator Afterburner Temperature:		$^{\circ}\mathrm{F}$

Emissions	Unit	Information	Section	4	of	6	

B. EMISSIONS UNIT CAPACITY INFORMATION (Regulated Emissions Units Only)

Emissions Unit Operating Capacity and Schedule

1.	Maximum Heat Input Rate:		435	mmBtu/hr
2.	Maximum Incineration Rate:	lb/hr	_	tons/day
3.	Maximum Process or Through	put Rate:		
4.	Maximum Production Rate:			
5.	Requested Maximum Operatir	g Schedule:		
		hours/day		days/week
		weeks/year		8,760 hours/year
6.	Operating Capacity/Schedule (Comment (limit to 200 char	acters):	

Emissions Unit Information Section 4	of	6
--------------------------------------	----	---

C. EMISSIONS UNIT REGULATIONS (Regulated Emissions Units Only)

List of Applicable Regulations

Federal: None	
State: 62-4, F.A.C. Permitting Requiremen 62-210, F.A.C. Stationary Sources – 62-213, F.A.C. Title V Permitting Rec 62-296.310(2), F.A.C. Stationary Sou 62-296.570(4)(b)(5), F.A.C. NO _x RAC 62-297.410(9), F.A.C. Stationary Sou Title V Core List (3/1/02) Presumptive	General Requirements quirements urces – Visible Emissions T Emission Limitations urces – EPA Method 9 for Visible Emissions Testing
Local: None	

D. EMISSION POINT (STACK/VENT) INFORMATION (Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on P	lot Plan or	2. Emission Po	oint Type Code:	
Flow Diagram: GT-1 Gas Turbine #1		1		
3. Descriptions of Emission P	oints Comprising	g this Emissions I	Unit for VE Tracking (limit	to
100 characters per point):				
4. ID Numbers or Description	s of Emission U	nits with this Emi	ssion Point in Common:	
	т .			
5. Discharge Type Code: v	6. Stack Heig	ht: 46 feet	7. Exit Diameter: 16 feet	
· .		40 rect	TO Teet	
8. Exit Temperature:	9. Actual Vol		10. Water Vapor:	
837°F	Rate:	983,593 acfm	%	
11. Maximum Dry Standard Flo		12. Nonstack Er	nission Point Height:	
	dscfm		feet	
13. Emission Point UTM Coord	dinates:			
Zone: 17 E	ast (km): 592.8	Nort	h (km): 2943.7	
14. Emission Point Comment (limit to 200 char	acters):		

Emissions Unit Information Section 4 of 6

Gas Turbine #1 (GT-1)

E. SEGMENT (PROCESS/FUEL) INFORMATION (All Emissions Units)

<u>Seg</u>	ment Description and Ra	ite:	Segment 1	of 1		
1.	Segment Description (Pro-	cess	Fuel Type) (limit to 500 ch	aract	ters):
	Internal Combustion Engin	es -	Electric Gene	eration-Distillat	e Oil-	Turbine
	Source Classification Cod 2-01-001-01	e (S	CC):	3. SCC Units		
4.	Maximum Hourly Rate: 3.1	5.	Maximum A 27,230		6.	Estimated Annual Activity Factor:
	Maximum % Sulfur: 0.23	8.	Maximum 9 0.0033	6 Ash:	9.	Million Btu per SCC Unit: 139.3
10.	Segment Comment (limit	to 20	00 characters)):	•	
Coo	mont Description and De	.4	C	- f		
	ment Description and Ra			of		
1.	Segment Description (Prod	Jessi	ruel Type)	(iimit to 300 ci	narac	ters):
				<u> </u>		
2.	Source Classification Cod	e (S	CC):	3. SCC Uni	ts:	
4.	Maximum Hourly Rate:	5.	Maximum A	Annual Rate:	6.	Estimated Annual Activity Factor:
7.	Maximum % Sulfur:	8.	Maximum 9	% Ash:	9.	Million Btu per SCC Unit:
10.	Segment Comment (limit	to 20	00 characters)):		
l						

Effective: 2/11/99

F. EMISSIONS UNIT POLLUTANTS (All Emissions Units)

1. Pollutant Emitted	2. Primary Control	3. Secondary Control	4. Pollutant
1. I Officiant Efficied	Device Code	Device Code	Regulatory Code
SO ₂		201100 0000	NS
NO _x			EL
PM			NS
со			NS
voc			NS
PM ₁₀			NS

Emissions Unit Information Section	4	of _	6	Gas Turbine #1 (GT-1)
Pollutant Detail Information Page	1	of	1	Nitrogen Oxides

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted:	2. Total Percent Efficie	ency of Control:
NO _x		
3. Potential Emissions:		4. Synthetically
390 lb/hour	1,707 tons/year	Limited? []
5. Range of Estimated Fugitive Emissions:		
	to to	ns/year
6. Emission Factor: 0.9 lb NO _x per mmBtu		7. Emissions
Reference: NO _x RACT Rule		Method Code: 1
9. Calculation of Emissions (limit to 600 chara	acters):	
(-	
Potential emissions based on oil firing.)() / 2 000 lb/t
(0.9 lb NO _x per mmBtu Oil x 27,230 1,000 gal/	yr x 139.3 mmbtu Oii/1,000	gai) / 2,000 ib/ton
10. Pollutant Potential/Fugitive Emissions Com	ment (limit to 200 charac	ters):
Detential emissions based on maximum based	4 imm. 4 wata 9 760 hw/sw am	d the minimum
Potential emissions based on maximum hea heating value of oil reported from 1992 throu	_	a the minimum
Allowable Emissions Allowable Emissions	<u>1</u> of <u>1</u>	
1. Basis for Allowable Emissions Code:	2. Future Effective Da	ite of Allowable
RULE	Emissions:	
3. Requested Allowable Emissions and Units:	4. Equivalent Allowat	ole Emissions:
0.9 lb NO _x per mmBtu	389.7 lb/hour	1,706.89 tons/year
5. Method of Compliance (limit to 60 characte	ers):	
EPA Test Method 7E conducted annually, wh	on hurning liquid fuols fo	r 100 or more hours
per year.	ien burning nquid rueis to	1 400 Of Illote flours
6. Allowable Emissions Comment (Desc. of C	nerating Method) (limit to	200 characters):
and the waste Emissions comment (Bess. of S	porating internous (mine to	s =00 characters).

																																																																																														6	6	(F	f)	0			4	•								1
																																																																																															;	6	6	6	6	6	6	6	f 6	f 6	\mathbf{of} 6	of 6	of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6
																																																																																															;	6	6	6	6	6	6	6	f 6	f 6	\mathbf{of} 6	of 6	of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6
																																																																																															;	6	6	6	6	6	6	6	f 6	f 6	\mathbf{of} 6	of 6	of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6
																																																																																															;	6	6	6	6	6	6	? 6	f 6	f 6	\mathbf{of} 6	\mathbf{of} 6	of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6
																																																																																															;	6	6	6	6	6	6	6	f 6	f 6	of 6	\mathbf{of} 6	of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6
																																																																																															ì	6	6	6	6	6	6	6	f 6	f 6	of 6	of 6	\mathbf{of} 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6
																																																																																															ì	6	6	6	6	6	6	6	f 6	f 6	of 6	of 6	of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6
																																																																																														ì	į	6	6	6	6	6	6	· 6	f 6	of 6	of 6	of 6	of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6	4 of 6
of 6	of (of	0	C	•				4	4	4	4	4	4	4	4	4																																																																																																			
of 6	of (of	0	(4	4	4	4	4	4	4	4	4																																																																																																			
of 6	of	0	•	,				4	4	4	4	4	4	4	4	4																																																																																																				
of 6	\mathbf{of} 6	\mathbf{of} 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	\mathbf{of} 6	of 6	\mathbf{of} 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	\mathbf{of} 6	of 6	of 6	of 6	\mathbf{of} 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	\mathbf{of} 6	of 6	of 6	of 6	of	0	(,				4	4	4	4	4	4	4	4	4																
\mathbf{of} 6	\mathbf{of} 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	\mathbf{of} 6	\mathbf{of} 6	\mathbf{of} 6	of 6	\mathbf{of} 6	of 6	of 6	\mathbf{of} 6	\mathbf{of} 6	of 6	\mathbf{of} 6	of 6	\mathbf{of} 6	\mathbf{of} 6	\mathbf{of} 6	of 6	\mathbf{of} 6	of 6	\mathbf{of} 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	of 6	\mathbf{of} 6	of 6	of (of	0	(,				4	4	4	4	4	4	4	4	4						
1 4 of 6	1 4 of (n 4 of	ı 4 of	n 4 of	ı 4 of	ı 4 of	ı 4 of	1 4 of	1 4 o	1 4 c	1 4	1 4	լ 4	1 4	1	1	1	1	ı	1	1	1																																																																																														
n 4 of 6	n 4 of	n 4 o	n 4 c	n 4	n 4	n 4	n '	n	n	n	n	n	n	n	n	I																																																																																																				
on 4 of 6	on 4 of	n 4 of	n 4 of	n 4 o	n 4 c	n 4	n 4	n 4	n '	n	n	n	n	n	n	n	n	1(
on 4 of 6	on 4 of	on 4 o	on 4 c	on 4	on 4	on 4	on '	on	10																																																																																																											
ion 4 of 6	ion 4 of (ion 4 of	ion 4 o	ion 4 d	ion 4	ion 4	ion 4	ion '	ion	ıoi																																																																																																										
tion 4 of 6	tion 4 of	tion 4 o	tion 4 c	tion 4	tion 4	tion 4	tion '	tion	tior																																																																																																											
ction 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	ction 4 of 6	ction 4 of 6	tion 4 of 6	ction 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	tion 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	tion 4 of 6	tion 4 of 6	ction 4 of 6	tion 4 of 6	tion 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	tion 4 of 6	ction 4 of 6	ction 4 of 6	tion 4 of 6	tion 4 of 6	ction 4 of 6	tion 4 of 6	ction 4 of 6	ction 4 of 6	tion 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of 6	ction 4 of	ction 4 o	ction 4 c	ction 4	tion 4	tion 4	tion 4	tion	tior														
ction 4 of 6	ction 4 of	ction 4 o	ction 4 c	ction 4	ction 4	ction 4	ction '	ction																																																																																																												
ection 4 of 6	ection 4 of	ection 4 o	ection 4 c	ection 4	ection 4	ection 4	ection 4	ection	ction																																																																																																											
ection 4 of 6	ection 4 of	ection 4 o	ection 4 c	ection 4	ection 4	ection 4	ection 4	ection																																																																																																												
ection 4 of 6	ection 4 of	ection 4 o	ection 4 c	ection 4	ection 4	ection 4	ection 4	ection																																																																																																												
Section 4 of 6	Section 4 of	ection 4 o	section 4 c	ection 4	ection 4	ection 4	ection '	ection																																																																																																												
Section 4 of 6	Section 4 of	Section 4 o	Section 4 o	Section 4	Section 4	Section 4	Section 4	Section																																																																																																												
Section 4 of 6	Section 4 of	Section 4 o	Section 4 c	Section 4	Section 4	Section 4	Section	Section	Section	Section	Section	Section	Section	Section	Section	Section																																																																																																				
Section 4 of 6	Section 4 of	Section 4 o	Section 4 o	Section 4	Section 4	Section 4	Section	Section	Section	Section	Section	Section	Section	Section	Section	Section																																																																																																				
Section 4 of 6	Section 4 of	Section 4 o	Section 4 c	Section 4	Section 4	Section 4	Section 6	1 Section	Section	i Section																																																																																																										
n Section 4 of 6	n Section 4 of	n Section 4 o	n Section 4 o	n Section 4	n Section 4	n Section 4	n Section 6	n Section																																																																																																												

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

<u>Vi</u>	sible Emissions Limitation: Visible Emissi	ons Limitation <u>1</u> of <u>1</u>		
1.	Visible Emissions Subtype: VE	2. Basis for Allowable Opacity: [X] Rule [] Other		
3.		ceptional Conditions: %		
4.	Compliance Test Method 9 conducted annua hours per year. Testing conducted using the	e fuel and/or process input which are expected		
4.	Visible Emissions Comment (limit to 200 cl	haracters):		
	Rule 62-296.310(2)			
	• •			
1. Visible Emissions Subtype: VE 2. Basis for Allowable Opacity: [X] Rule [] Other 3. Requested Allowable Opacity: Normal Conditions: 20 % Exceptional Conditions: %				
1.	Parameter Code:	2. Pollutant(s):		
3.	CMS Requirement:	[] Rule [] Other		
4.	Manufacturer:			
_				
٥.	Installation Date:	6. Performance Specification Test Date:		
7.	Continuous Monitor Comment (limit to 200	characters):		
l				

DEP Form No. 62-210.900(1) - Form Effective: 2/11/99

Emissions Unit Information Section 4 of 6

Gas Turbine #1 (GT-1)

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION (Regulated Emissions Units Only)

Supplemental Requirements

1.	Process Flow Diagram [X] Attached, Document ID: <u>LW-EU4-J1</u> [] Not Applicable [] Waiver Requested
2.	Fuel Analysis or Specification [X] Attached, Document ID: <u>LW-EU4-J2</u> [] Not Applicable[] Waiver Requested
3.	Detailed Description of Control Equipment [] Attached, Document ID: [X] Not Applicable [] Waiver Requested
4.	Description of Stack Sampling Facilities [X] Attached, Document ID: <u>LW-EU4-J4</u> [] Not Applicable[] Waiver Requested
5.	Compliance Test Report
	[] Attached, Document ID:
	[X] Previously submitted, Date: 1 Dec 2000
	[] Not Applicable
6.	Procedures for Startup and Shutdown
	[] Attached, Document ID: [X] Not Applicable [] Waiver Requested
7.	Operation and Maintenance Plan
	[] Attached, Document ID: [X] Not Applicable [] Waiver Requested
8.	Supplemental Information for Construction Permit Application
	[] Attached, Document ID: [X] Not Applicable
9.	Other Information Required by Rule or Statute
	[] Attached, Document ID: [X] Not Applicable
10	. Supplemental Requirements Comment:

Emissions	Unit	Information	Section	4	of	6
LILLIOUIGITO	CALLE	THEOR HIMSION	Dection	-	O.	-

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation
[] Attached, Document ID: [X] Not Applicable
12. Alternative Modes of Operation (Emissions Trading)
[] Attached, Document ID: [X] Not Applicable
13. Identification of Additional Applicable Requirements
[X] Attached, Document ID: <u>LW-FI-C12</u> [] Not Applicable
14. Compliance Assurance Monitoring Plan
[] Attached, Document ID: [X] Not Applicable
15. Acid Rain Part Application (Hard-copy Required)
[] Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID:
[] Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID:
[] New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID:
[] Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID:
[] Phase II NO _x Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID:
[] Phase NO _x Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID:
[X] Not Applicable

ATTACHMENT LW-EU4-A9
EMISSIONS UNIT COMMENT

7/2/2002 0237548/4/4.4/1/LW-EU4-A9.doc




Photo I. Aerial View - Stack and Building Location for Unit GT-1

Attachment LW-EU4-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities


Source: Golder, 2002.



ATTACHMENT LW-EU4-J1

PROCESS FLOW DIAGRAM

7/2/2002 0237548/4/4.4/4.4.1/LW-EU4-J1



Attachment LW-EU4-J1
Process Flow Diagram
Lake Worth Utilities - City of Lake Worth, Florida



Source: Golder, 2002.

ATTACHMENT LW-EU4-J2

FUEL ANALYSIS OR SPECIFICATION



CIPY OF LAKE WORTH

1900 2ND AVENUE NORTH LAKE WORTH, FLORIDA 33461-4298

UTILITIES DEPARTMENT POWER RESOURCES

(561) 586-1703 FAX (561) 586-1759

April 29, 2002

Mr. Laxmana Tallam
Supervisor of Permitting, Compliance & Enforcement
Florida Department of Environmental Protection
Post Office Box 15425
400 North Congress Avenue
West Palm Beach, Florida 33416

Subject:

City of Lake Worth Utilities

Quarterly Fuel Oil Analysis Reports First Quarter 2002 (Jan- Feb - Mar)

Dear Mr. Tallam:

Please find attached our quarterly fuel oil analysis as required by our operating permit. Samples reported below have been collected from a composite sample from the on site oil storage facility.

On site quarterly sample:

Type	Date	%S	Note
No.6	04/01/02	1.97	On site quarterly sample
No.2	04/01/02	0.0390	On site quarterly sample

Mr. Laxmana Tallam Supervisor of Permitting, Compliance and Enforcement April 29, 2002

Page 2

The results indicate the oil is within our permit limits of 0.35% sulfur for No. 2 oil and 2.25% sulfur for No. 6 oil. If you need more information, please do hesitate to call me at 561.533.7379 or email at mridge@lakeworth.net.

Sincerely,

CITY OF LAKE WORTH UTILITIES

mi nj

Mike Ridge

Environmental/ Performance Specialist

Attachments

cc: A.J. Satyal, Environmental Manager, Palm Beach County Health Unit Larry Baker, Power Resources Superintendent

Margaret Johnstone, Environmental Compliance Officer

Joe Brockway, Results Supervisor

Best Available Copy

LABORATORY NO.: 0483

REF. NO(S): #129018/

CUSTOMER

DATE: 04/08/02

LABORATORY ANALYSIS REPORT

INVOICE NO:

SAYBOLT LP. 2610 So. Federal Highway



2610 So. Federal Highway Fort Lauderdale, FL. 33316

DESCRIPTION

Sample designated as: #2 FUEL OIL

Identifying Marks: SUBMITTED QUARTERLY SAMPLE (04/01/02) CITY POWER PLANT LAKE WORTH, FLORDA

Submitted by: CITY OF LAKE WORTH

■ Client: CITY OF LAKE WORTH

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

TEST	METHOD	RESULT
GRAVITY, API AT 60 F	D-1298	,34.7
GRAVITY, SPECIFIC	D-1298	0.8514
SULFUR, X-RAY, WT PCT	D-4294	0.0390
ASH, WT PCT	D-482	0.0036
HEAT OF COMBUSTION, BTU/LB	D-4868	19576
HEAT OF COMBUSTION, BTU/GAL		139011
HEAT OF COMBUSTION, BTU/BBL		5838462

MEMBERS ASTM-API-SAE

B SAYBOLT

ATTACHMENT LW-EU4-J4 DESCRIPTION OF STACK SAMPLING FACILITIES

ATTACHMENT LW-EU4-J4

DESCRIPTION OF STACK SAMPLING FACILITIES

GAS TURBINE NO. 1 (GT-1)

Emission testing can be performed on all of the major emission units. However, on GT-1, permanent platform structures do not exist. In order to perform emission tests on this unit, a bucket truck is used to hoist personnel and equipment to the stack test port elevations. The stack sampling locations are identified for GT-1 on the attached figure.

Golder Associates




FIGURE 9
SAMPLING POINT LOCATION
GAS TURBINE-UNIT | GT-1
LAKE WORTH UTILITIES
LAKE WORTH, FLORIDA

.

AIR CONSULTING and ENGINEERING

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

Emissions Unit Description and Status

	·						
1.	1. Type of Emissions Unit Addressed in This Section: (Check one)						
[X	[X] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).						
[] This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities, which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.						
[] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.						
2.	Regulated or Unregulated Emissions Unit? (Check one)						
[X	[X] The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.						
[] The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.						
3.	3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): CC1 Combined Cycle Unit Combustion Turbine #2/Steam Unit #5 (GT-2/S-5)						
4.	Emissions Unit Identification Number: [] No ID ID: 011 [] ID Unknown						
5.	Emissions Unit Status Code:	6. Initial Startup Date: 1978	7. Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit?			
9.	Emissions Unit Comment: (Limit to 500 Characters) A photograph of this Emission Unit is present in Attachment LW-EU5-A9.						

<u>En</u>	Emissions Unit Control Equipment					
	Control Equipment/Method Description (Lim	it to 200 characters per o	device or method):			
2.	Control Device or Method Code(s):					
En	nissions Unit Details					
1.	Package Unit: Manufacturer:	Model Number:				
2.	Generator Nameplate Rating: 29.5	MW	-			
3.	Incinerator Information: Dwell Temperature: Dwell Time:		°F seconds			
	Incinerator Afterburner Temperature:		°F			

Emissions Unit Information Section ___ 5 __ of __ 6 __ CC1 Combined Cycle Unit (GT-2/S-5)

Emissions Unit Information Section 5 of 6 CC1 Combined Cycle Unit (GT-2/S-5)

B. EMISSIONS UNIT CAPACITY INFORMATION (Regulated Emissions Units Only)

Emissions Unit Operating Capacity and Schedule

1.	Maximum Heat Input Rate:		317.6	mmBtu/hr
2.	Maximum Incineration Rate:	lb/hr	1	tons/day
3.	Maximum Process or Throughput	t Rate:		
4.	Maximum Production Rate:			
5.	Requested Maximum Operating S	Schedule:		
		hours/day		days/week
		weeks/year	8,760	hours/year
6.	Operating Capacity/Schedule Cor GT-2/S-5 is nominally rated at 29.5 20 MW and a Heat Recovery Steam	5 MW consisting of a gas turbi	ne (GT-2)	

Emissions Unit Information Section 5 of 6 CC1 Combined Cycle Unit (GT-2/S-5)

C. EMISSIONS UNIT REGULATIONS (Regulated Emissions Units Only)

List of Applicable Regulations

Federal: None			
State:			
62-4, F.A.C. Permitting Requirements			
62-210, F.A.C. Stationary Sources – General Requirements			
62-213, F.A.C. Title V Permitting Requirements			
62-296.570(4)(b)(5), F.A.C. NO _x RACT Emission Limitations			
62-297.410(9), F.A.C. Stationary Sources – EPA Method 9 for Visible Emissions Testing			
Section 403.501 Florida Statutes Power Plant Siting Act (PPSA)			
Title V Core List (3/1/02) Presumptively Applicable (Federal and State)			
Local: None			

D. EMISSION POINT (STACK/VENT) INFORMATION

(Regulated Emissions Units Only)

Emission Point Description and Type

1.	Identification of Point on Plot Plan or		2. Emission Po	oint Type Code:			
	Flow Diagram?		1	• •			
	CC1 Combined Cycle Unit (ST-2/S-5)					
3.	Descriptions of Emission P	oints Comprising this Emissions Unit for VE Tracking (limit to					
	100 characters per point):						
4.	ID Numbers or Description	s of Emission U	nits with this Emi	ssion Point in Common:			
	•						
5.	Discharge Type Code:	6. Stack Heigh	ht:	7. Exit Diameter:			
	V	-	75 feet	10 feet			
8.	Exit Temperature:	9. Actual Vol		10. Water Vapor:			
	Oil: 404°F		412,466 acfm	%			
	Gas: 406°F	Gas: 406°F Gas:					
11.	Maximum Dry Standard Flo	ow Rate:	12. Nonstack Emission Point Height:				
	dscfm			feet			
12	Estate Date VEDA Consultation	<u> </u>	<u> </u>				
13.	Emission Point UTM Coord	imates:					
	Zone: 17	ast (km): 592.8	Norti	h (km): 2943.7			
14	Emission Point Comment (imit to 200 char	acters):				
1		innit to 200 char	uctors).				
	By-pass stack parameters:						
	Stack Height = 49 feet						
	Exit Dimensions = 12 feet 7		6.5 inches				
	Maximum Exit Temperature						
	Maximum Actual Volumetric Discharge Type = Vertical	Flow rate = 733 ,	562 (gas) actm				
	Discharge Type – Vertical						
ĺ .							

Emissions Unit Information Section __5 of __6 CC1 Combined Cycle Unit (GT-2/S-5)

E. SEGMENT (PROCESS/FUEL) INFORMATION (All Emissions Units)

Segment Description (Process/Fuel Type) (limit to 500 characters): Internal Combustion Engines-Electric Generation-Distillate Oil-Turbines 2. Source Classification Code (SCC): 2-01-001-01 3. SCC Units: 1,000 gallons						
Source Classification Code (SCC): 3. SCC Units:						
	Internal Combustion Engines-Electric Generation-Distillate Oil-Turbines					
2-01-001-01 1,000 gallons						
4. Maximum Hourly Rate: 5. Maximum Annual Rate: 6. Estimated Annual Acti Factor:	ity					
7. Maximum % Sulfur: 8. Maximum % Ash: 8. Million Btu per SCC U	nit:					
10. Segment Comment (limit to 200 characters):						
Segment Description and Rate: Segment 2 of 2						
Segment Description (Process/Fuel Type) (limit to 500 characters):						
Internal Combustion Engines-Electric Generation-Natural Gas-Turbine						
internal Combustion Engines-Liectife Generation-Natural Gas-Turbine						
Internal Combustion Engines-Electric Generation-Natural Gas-Turbine						
Internal Combustion Engines-Liectife Generation-Natural Gas-Turbine						
2. Source Classification Code (SCC): 2-01-002-01 3. SCC Units: mmcf						
Source Classification Code (SCC): 3. SCC Units:	ity					
2. Source Classification Code (SCC): 2-01-002-01 3. SCC Units: mmcf 3. Maximum Hourly Rate: 4. Maximum Annual Rate: 6. Estimated Annual Active	•					
2. Source Classification Code (SCC): 2-01-002-01 3. SCC Units: mmcf 3. Maximum Hourly Rate: 0.31 4. Maximum Annual Rate: 2,709 Factor: 7. Maximum % Sulfur: 8. Maximum % Ash: 9. Million Btu per SCC Units: mmcf 6. Estimated Annual Active Factor: 9. Million Btu per SCC Units: mmcf 9. Million Btu per SCC Units						
2. Source Classification Code (SCC): 2-01-002-01 3. Maximum Hourly Rate: 0.31 4. Maximum Annual Rate: 2,709 Factor: 7. Maximum % Sulfur: 8. Maximum % Ash: 9. Million Btu per SCC Using the second secon						
2. Source Classification Code (SCC): 2-01-002-01 3. Maximum Hourly Rate: 0.31 4. Maximum Annual Rate: 2,709 Factor: 7. Maximum % Sulfur: 8. Maximum % Ash: 9. Million Btu per SCC Using the second secon						

F. EMISSIONS UNIT POLLUTANTS (All Emissions Units)

1. Pollutant Emitted	2. Primary Control	3. Secondary Control	4. Pollutant
	Device Code	Device Code	Regulatory Code
SO ₂			EL
NO _x			EL
РМ			NS
со			NS
voc			NS
PM ₁₀			NS
	_	-	

DEP Form No. 62-210.900(1) - Form

Emissions Unit Information Section $_$	_5_	_ of _	6	CC1 Combined Cycle Unit (GT-2/S-5)
Pollutant Detail Information Page	1	of	2	Sulfur Dioxides

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1 otential/1 agitive Dimissions			
1. Pollutant Emitted:	2. Total Percent Efficiency of Control:		
SO,			
3. Potential Emissions:	4. Synthetically		
115 lb/hour	503 tons/year Limited? []		
5. Range of Estimated Fugitive Emissions:			
	to tons/year		
6. Emission Factor: 7.2 % S x 2 lb SO ₂ per 1,0	00 gal Oil 7. Emissions		
Reference: Stoicheometric Calculation Method 3			
8. Calculation of Emissions (limit to 600 char	acters):		
Potential emissions based on oil firing. (7.2 lb Oil/Gas x 19,972,548 gal Oil/yr x 0.0035 S/lb Oil x 2 lb SO ₂ /1 lb S) / 2,000 lb/ton			
Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Potential emissions based on maximum firing rate, 8,760 hr/yr and the minimum oil heating value from 1992 through 1995.			
Allowable Emissions Allowable Emissions	<u>1</u> of <u>1</u>		
Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:	4. Equivalent Allowable Emissions:		
2.475 lb SO₂ per mmBtu	786.1 lb/hour 3,442.94 tons/year		
As-fired fuel oil will be sampled each day oil	Method of Compliance (limit to 60 characters): As-fired fuel oil will be sampled each day oil is fired. Composite fuel analysis reports submitted quarterly.		
6. Allowable Emissions Comment (Desc. of Comment			
Power Plant Citing Act Specific Condition I.			

${\bf Emissions~Unit~Information~Section~_}$	5	of _	6	CC1 Combined Cycle Unit (GT-2/S-5)
Pollutant Detail Information Page	2	of	2	Nitrogen Oxides

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -**Emissions-Limited and Preconstruction Review Pollutants Only)**

Potentia	I/Fugitive :	Emissions

Potential/Fugitive Emissions				
1. Pollutant Emitted:	2. Total Percent Efficiency of Control:			
NO _x				
3. Potential Emissions:	4. Synthetically			
286 lb/hour	1,252 tons/year Limited? []			
5. Range of Estimated Fugitive Emissions:	to tonglyour			
6. Emission Factor: 0.9 lb NO, per mmBtu (Oil	tons/year 7. Emissions			
• • • • • • • • • • • • • • • • • • • •	Method Code:			
Reference: NO _x RACT Rule 1				
8. Calculation of Emissions (limit to 600 chara	cters):			
Potential emissions based on oil firing.				
(0.9 lb NO, per mmBtu Oil x 19,973 1,000 gal/)	yr x 139.3 mmBtu Oil/1,000 gal) / 2,000 lb/ton			
9. Pollutant Potential/Fugitive Emissions Com	ment (limit to 200 characters):			
. Tondant Totolician agitive Limissions Comment (mint to 200 characters).				
Potential emissions based on maximum heat input rate, 8,760 hr/yr, and minimum heating				
value of oil reported from 1992 through 1995.				
Allowable Emissions Allowable Emissions	1 of 1			
Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable			
RULE	Emissions:			
3. Requested Allowable Emissions and Units:	4. Equivalent Allowable Emissions:			
0.9 lb NO _x per mmBtu	285.8 lb/hour 1,251.98 tons/year			
5. Method of Compliance (limit to 60 character	rs):			
EPA Test Method 7E conducted annually, wh per year.	en burning liquid fuels for 400 or more hours			
6. Allowable Emissions Comment (Desc. of O	perating Method) (limit to 200 characters):			
(2 100, 01 0)	3			

Emissions Unit Information Section	5	of	6	CC1 Combined Cycle Unit (GT-2/S-5
	-	U.	-	

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

1. Visible Emissions Subtype: VE 2. Basis for Allowable Opacity: [X] Rule [] Other					
VE [X] Rule [] Othe					
	r				
3. Requested Allowable Opacity: Normal Conditions: 20 % Exceptional Conditions: Maximum Period of Excess Opacity Allowed: min	/hour				
4. Method of Compliance:					
Compliance Test Method 9 conducted annually when burning liquid fuels for 400 or more hours per year. Testing conducted using the fuel and/or process input, which are expected to result in the highest emissions and within 10 percent of the rated capacity of the source.					
5. Visible Emissions Comment (limit to 200 characters):					
Rule 62-296.310(2)					
I. CONTINUOUS MONITOR INFORMATION (Only Regulated Emissions Units Subject to Continuous Monitoring) Continuous Monitoring System: Continuous Monitor of					
1. Parameter Code: 2. Pollutant(s):					
3. CMS Requirement: [] Rule [] Other					
4. Monitor Information:					
Manufacturer:					
Model Number: Serial Number:					
5. Installation Date: 6. Performance Specification Test I	Date:				
7. Continuous Monitor Comment (limit to 200 characters):					

Emissions Unit Information Section __5 _ of __6 _ CC1 Combined Cycle Unit (GT-2/S-5)

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION (Regulated Emissions Units Only)

Supplemental Requirements

1.	Process Flow Diagram
	[X] Attached, Document ID: <u>LW-EU5-J1</u> [] Not Applicable [] Waiver Requested
2.	Fuel Analysis or Specification
	[X] Attached, Document ID: <u>LW-EU5-J2</u> [X] Not Applicable [] Waiver Requested
3.	Detailed Description of Control Equipment
	[] Attached, Document ID:[X] Not Applicable [] Waiver Requested
4.	Description of Stack Sampling Facilities
	[X] Attached, Document ID: <u>LW-EU5-J4</u> [] Not Applicable [] Waiver Requested
5.	Compliance Test Report
	[] Attached, Document ID:
	[X] Previously submitted, Date: 17 Oct 2001
	[] Not Applicable
6.	Procedures for Startup and Shutdown
	[] Attached, Document ID:[X] Not Applicable [] Waiver Requested
7.	Operation and Maintenance Plan
	[] Attached, Document ID: [X] Not Applicable [] Waiver Requested
8.	Supplemental Information for Construction Permit Application
	[] Attached, Document ID: [X] Not Applicable
9.	Other Information Required by Rule or Statute
	[] Attached, Document ID: [X] Not Applicable
10	. Supplemental Requirements Comment:

Emissions Unit Information Section __5 of __6 CC1 Combined Cycle Unit (GT-2/S-5)

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation
[] Attached, Document ID: ————[X] Not Applicable
12. Alternative Modes of Operation (Emissions Trading)
[] Attached, Document ID: [X] Not Applicable
13. Identification of Additional Applicable Requirements
[X] Attached, Document ID: <u>LW-FI-C12</u> [] Not Applicable
14. Compliance Assurance Monitoring Plan
[] Attached, Document ID: [X] Not Applicable
15. Acid Rain Part Application (Hard-copy Required)
[] Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID:
[] Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID:
[] New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID:
[] Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID:
[] Phase II NO _x Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID:
[] Phase NO _x Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID:
[X] Not Applicable

ATTACHMENT LW-EU5-A9
EMISSION UNIT COMMENT

7/2/2002





Photo 1. Outside View - Stack and Building Location for Unit GT-2/S-5

Attachment LW-EU5-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities



ATTACHMENT LW-EU5-J1
PROCESS FLOW DIAGRAM



Attachment LW-EU5-J1
Process Flow Diagram
Lake Worth Utilities - City of Lake Worth, Florida



ATTACHMENT LW-EU5-J2
FUEL ANALYSIS OR SPECIFICATION



CITY OF LAKE WORTH

1900 2ND AVENUE NORTH LAKE WORTH, FLORIDA 33461-4298

UTILITIES DEPARTMENT POWER RESOURCES

(561) 586-1703 FAX (561) 586-1759

April 29, 2002

Mr. Laxmana Tallam
Supervisor of Permitting, Compliance & Enforcement
Florida Department of Environmental Protection
Post Office Box 15425
400 North Congress Avenue
West Palm Beach, Florida 33416

Subject:

City of Lake Worth Utilities

Quarterly Fuel Oil Analysis Reports First Quarter 2002 (Jan- Feb - Mar)

Dear Mr. Tallam:

Please find attached our quarterly fuel oil analysis as required by our operating permit. Samples reported below have been collected from a composite sample from the on site oil storage facility.

On site quarterly sample:

Type	Date	%S	Note
No.6	04/01/02	1.97	On site quarterly sample
No.2	04/01/02	0.0390	On site quarterly sample

Mr. Laxmana Tallam Supervisor of Permitting, Compliance and Enforcement April 29, 2002

Page 2

The results indicate the oil is within our permit limits of 0.35% sulfur for No. 2 oil and 2.25% sulfur for No. 6 oil. If you need more information, please do hesitate to call me at 561.533.7379 or email at mridge@lakeworth.net.

Sincerely,

CITY OF LAKE WORTH UTILITIES

Mike Ridge

Environmental/ Performance Specialist

Attachments

cc: A.J. Satyal, Environmental Manager, Palm Beach County Health Unit

Larry Baker, Power Resources Superintendent

Margaret Johnstone, Environmental Compliance Officer

Joe Brockway, Results Supervisor

SAYBOLT LP.

2610 So. Federal Highway Fort Lauderdale, FL. 33316



Best Available Copy

LABORATORY NO.: 0483

CUSTOMER

REF. NO(S): #129018/

LABORATORY ANALYSIS REPOR.

DATE: 04/08/02

INVOICE NO:

DESCRIPTION

- Sample designated as: #2 FUEL OIL
- Identifying Marks: SUBMITTED QUARTERLY SAMPLE (04/01/02) CITY POWER PLANT LAKE WORTH, FLORDA
- Submitted by: CITY OF LAKE WORTH
- Client: CITY OF LAKE WORTH

SAMPLES SHALL BE RETAINED BY SAYBOLT INC. FOR FORTY-FIVE (45) DAYS UNLESS OTHERWISE REQUESTED IN WRITING.

NOTES

- This laboratory report may not be published or used except in full. It shall not be used in connection with any form of advertising unless written consent is received from an officer of Saybolt Inc.
- Results were based on analysis made at the time samples were received at the laboratory.
- Sample nomenclature is designated by the customer.

ANALYSIS

TEST	METHOD	RESULT
GRAVITY, API AT 60 F	D-1298	,34.7
GRAVITY, SPECIFIC	D-1298	0.8514
SULFUR, X-RAY, WT PCT	D-4294	0.0390
ASH, WT PCT	D-482	0.0036
HEAT OF COMBUSTION, BTU/LB	D-4868	19576
HEAT OF COMBUSTION, BTU/GAL		139011
HEAT OF COMBUSTION, BTU/BBL		5838462

MEMBERS ASTM-API-SAE

A B SAYBOLT

ATTACHMENT LW-EU5-J4

DESCRIPTION OF STACK SAMPLING FACILITIES

ATTACHMENT LW-EU5-J4

DESCRIPTION OF STACK SAMPLING FACILITIES

COMBINED CYCLE UNIT NO. 1 (CC-1)

Emission testing can be performed on all of the major emission units. However, on CC-1, permanent platform structures do not exist. In order to perform emission tests on this unit, a bucket truck is used to hoist personnel and equipment to the stack test port elevations. The stack sampling locations are identified for CC-1 on the attached figure.




FIGURE 10*
SAMPLING POINT LOCATION
COMBINED CYCLE UNIT I CC-1
LAKE WORTH UTILITIES
LAKE WORTH, FLORIDA

AIR CONSULTING and ENGINEERING

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in Th	is Section: (Check one)					
process or production unit, or activity,						
	on addresses, as a single emissions unit, a group of des which has at least one definable emission point agitive emissions.					
•	on addresses, as a single emissions unit, one or more es which produce fugitive emissions only.					
2. Regulated or Unregulated Emissions Uni	it? (Check one)					
[X] The emissions unit addressed in this Enemissions unit.	missions Unit Information Section is a regulated					
[] The emissions unit addressed in this Enemissions unit.	missions Unit Information Section is an unregulated					
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Fuel Oil Storage Tanks 10, 11, and 12 Tank 10 is fixed roof 20,134-gallon capacity, constructed 05/92. Tank 11 is fixed roof 20,134-gallon capacity, constructed 05/92. Tank 12 is fixed roof 140,798-gallon capacity, constructed 05/92.						
4. Emissions Unit Identification Number: ID:	[X] No ID [] ID Unknown					
5. Emissions Unit Status Code: Date:	7. Emissions Unit Major 8. Acid Rain Unit? Group SIC Code: []					
9. Emissions Unit Comment: (Limit to 500	Characters)					

3. Incinerator Information:

٥F

°F

seconds

Dwell Temperature:

Incinerator Afterburner Temperature:

Dwell Time:

Emissions Unit Information Section 6 of 6 Fuel Oil Storage Tanks 10, 11, & 12

B. EMISSIONS UNIT CAPACITY INFORMATION (Regulated Emissions Units Only)

Emissions Unit Operating Capacity and Schedule

1.	Maximum Heat Input Rate:		mmBtu/hr
2.	Maximum Incineration Rate:	lb/hr	tons/day
3.	Maximum Process or Throughp	put Rate:	
4.	Maximum Production Rate:		
5.	Requested Maximum Operating	g Schedule:	
		hours/day	days/week
		weeks/year	8,760 hours/year
6.	Operating Capacity/Schedule C	Comment (limit to 200 characters):	

C. EMISSIONS UNIT REGULATIONS (Regulated Emissions Units Only)

List of Applicable Regulations

Federal:
40 CFR 60 Subpart Kb Volatile Organic Liquid Storage Vessel with capacity greater than or equal to 20,568 gallons constructed after 7/23/84
40 CFR 60, Subpart Kb New Source Performance Standards, Volatile Organic Storage Vessels
State:
62-213.420(3), F.A.C. Title V reportable quantities of all known and suspected emissions sources
62-296.320, F.A.C. General Pollutant Emissions Limiting Standards
Title V Core List (3/1/02) Presumptively Applicable (Federal and State)
Local: None

D. EMISSION POINT (STACK/VENT) INFORMATION (Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on Plot Plan or		2. Emission Point Type Code:				
Flow Diagram:		3				
1-10, 1-11, and 1-12	T-10, T-11, and T-12					
3. Descriptions of Emission	Points Comprisin	this Emissions \	Unit for VE Tracking (limit to			
100 characters per point):		8				
4. ID Numbers or Description	ns of Emission U	nits with this Emi	ssion Point in Common:			
5. Discharge Type Code:	6. Stack Heig	ht:	7. Exit Diameter:			
P		feet	feet			
8. Exit Temperature:	9. Actual Vol	umetric Flow	10. Water Vapor:			
77°F	Rate:	acfm	%			
11. Maximum Dry Standard Flow Rate: 12. Nonstack Emission Point Height:			_			
	dscfm		31 feet			
13. Emission Point UTM Coo	ordinates:					
Zone: 17	East (km): 592.8	North (km): 2943.7				
14. Emission Point Comment	(limit to 200 char	racters):				
		·				
· ·		-	r each. Tanks 10 and 11 are			
identical. The VOC potential emissions from Tank 12 are 392 lb/yr.						

E. SEGMENT (PROCESS/FUEL) INFORMATION (All Emissions Units)

Segment 1	<u>Description</u>	and Rate:	Segment	1	of	1
			_			-

Segment Description (Proceedings)		limit to 500 ch	aract	ters):		
i sogment zosompuon (r rot	oossil der lype)	(,.		
Working loss and breathin	g loss from fixed	roof storage tan	ıks.			
2. Source Classification Code	e (SCC):	3. SCC Units	:			
4. Maximum Hourly Rate:	5. Maximum A		6.	Estimated Annual Activity Factor:		
11. Maximum % Sulfur:	12. Maximum 9	% Ash:	9.	Million Btu per SCC Unit:		
10. Segment Comment (limit	to 200 characters):				
4-03-010-21 Distillate Fuel	No. 2 Fixed Roof \	Working Loss				
4-03-010-19 Distillate Fuel		-				
Capacity: Tanks 10 and 11 Tank 12 = 140,7	_	each				
Segment Description and Ra	ate: Segment	of				
1. Segment Description (Process/Fuel Type) (limit to 500 characters):						
2. Source Classification Code (SCC): 3. SCC Units:						
4. Maximum Hourly Rate:	4. Maximum Hourly Rate: 5. Maximum Annual Rate: 6. Estimated Annual Activity Factor:					
7. Maximum % Sulfur:	8. Maximum % Ash: 9. Million Btu per SCC Unit			Million Btu per SCC Unit:		
10. Segment Comment (limit	10. Segment Comment (limit to 200 characters):					

F. EMISSIONS UNIT POLLUTANTS (All Emissions Units)

1. Pollutant Emitted	Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
voc			NS
	,		
			-




Photo 1. Front View - Diesel Generator Units 1-5




Photo 2. Rear View - Diesel Generator Units 1-5

Attachment LW-EU1-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities



7/2/2002 0237548/4/4.4/4.1/LW-EU2-A9.doc




Photo 1. Outside View - Stack and Building Location for Unit S-1

Attachment LW-EU2-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities



7/2/2002 0237548/4/4.4/1/LW-EU3-A9.doc



Photo 1. Inside View - Turbine and Generator for Unit S-3





Photo 2. Outside View - Right Stack is for Unit S-3

Attachment LW-EU3-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities





7/2/2002 0237548/4/4.4/4.4.1/LW-EU4-A9.doc



Photo 1. Aerial View - Stack and Building Location for Unit GT-1

Attachment LW-EU4-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities



7/2/2002 0237548/4/4.4/4.1/LW-EU5-A9.doc




Photo 1. Outside View - Stack and Building Location for Unit GT-2/S-5

Attachment LW-EU5-A9. Emission Unit Comment Tom G. Smith Powerplant and Lake Worth Water Treatment Plant Lake Worth Utilities



7/2/2002 0237548/4/4.4/4.4.1/LW-FI-CI



Attachment LW-FI-C1. Area Map Lake Worth Utilities, City of Lake Worth, Florida



