

Bruce Mitchell

JACKSONVILLE ELECTRIC AUTHORITY

21 WEST CHURCH STREET • JACKSONVILLE, FL 32202-3139



October 21, 1997

Mr. Bruce Mitchell
Environmental Administrator
Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, FL 32399-2400

RECEIVED
OCT 22 1997
BUREAU OF
AIR REGULATION

RE: Kennedy Generating Station Combustion Turbines 3, 4, and 5
Title V Permit Application - Supplemental Information

Dear Mr. Mitchell:

Enclosed please find a heat input curve (in tabular form) for the above referenced Combustion Turbines at the Kennedy Generating Station. This is a regression curve based on empirical data and will vary slightly from unit to unit and day to day. Since no manufacturer curve is available for these old units, this is the best data available to describe the relationship between load and temperature for these units.

Also enclosed is the Florida Publishing Company affidavit for the Northside Generating Station and St. Johns River Power Park attesting to the October 4, 1997 publication in the Florida Times Union of the "Public Notice of Intent to Issue Title V Operating Permit".

If you have any questions with regard to this matter please contact Bert Gianazza of my staff at (904) 632-6247.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Bert Gianazza', is written over a horizontal line.

Bert Gianazza, P.E.
Environmental
Health and Safety Group

NBG

cc: Ron Roberson, RESD
Emerson Raulerson, FDEP, Northeast District

KENNEDY STATION COMBUSTION TURBINES
BASE LOAD MW vs TEMPERATURE

AMBIENT TEMP #	AMBIENT TEMP *F	GROSS MW (X)	HEAT CONSUMED MBTU/HR	AMBIENT TEMP #	AMBIENT TEMP *F	GROSS MW (X)	HEAT CONSUMED MBTU/HR
1	20	70.90	871	60	59.30	769	
2	21	70.61	868	61	59.01	766	
3	22	70.32	866	62	58.72	764	
4	23	70.03	863	63	58.43	761	
5	24	69.74	860	64	58.14	758	
6	25	69.45	858	65	57.85	756	
7	26	69.16	855	66	57.56	753	
8	27	68.87	853	67	57.27	751	
9	28	68.58	850	68	56.98	748	
10	29	68.29	848	69	56.69	746	
11	30	68.00	845	70	56.40	743	
12	31	67.71	843	71	56.11	741	
13	32	67.42	840	72	55.82	738	
14	33	67.13	837	73	55.53	736	
15	34	66.84	835	74	55.24	733	
16	35	66.55	832	75	54.95	731	
17	36	66.26	830	76	54.66	728	
18	37	65.97	827	77	54.37	726	
19	38	65.68	825	78	54.08	723	
20	39	65.39	822	79	53.79	720	
21	40	65.10	820	80	53.50	718	
22	41	64.81	817	81	53.21	715	
23	42	64.52	814	82	52.92	713	
24	43	64.23	812	83	52.63	710	
25	44	63.94	809	84	52.34	708	
26	45	63.65	807	85	52.05	705	
27	46	63.36	804	86	51.76	703	
28	47	63.07	802	87	51.47	700	
29	48	62.78	799	88	51.18	698	
30	49	62.49	797	89	50.89	695	
31	50	62.20	794	90	50.60	693	
32	51	61.91	792	91	50.31	690	
33	52	61.62	789	92	50.02	688	
34	53	61.33	786	93	49.73	685	
35	54	61.04	784	94	49.44	683	
36	55	60.75	781	95	49.15	680	
37	56	60.46	779	96	48.86	677	
38	57	60.17	776	97	48.57	675	
39	58	59.88	774	98	48.28	672	
40	59	59.59	771	99	47.99	670	
41	60	59.30	769	100	47.70	667	

KSCT
Y INTE 76.700
SLOPE 0.2900

DISPATCH HEAT RATE CURVES

A = 2.57955E+02
B = 8.61082E+00
C = -6.18610E-04
D = 2.11490E-05
AA = 2.50025E-01
BB = 9.99997E-01
CC = 4.45030E-08
DATE: 10/01/91

RECEIVED

OCT 22 1997

BUREAU OF
AIR REGULATION

Appendix JEPB Rule 2

JACKSONVILLE ENVIRONMENTAL PROTECTION BOARD

RULE 2 AIR POLLUTION CONTROL

	Effective	03/18/85
	Amended	12/15/85
	Amended	06/18/86
	Amended	06/15/86
	Amended	10/27/88
	Amended	12/20/88
	Amended	07/09/90
	Amended	10/22/92
Repealed, renumbered and readopted		01/10/93
	Amended	12/19/94, Effective 01/11/95
	Amended	09/11/95, Effective 10/05/95
	Amended	11/12/96, Effective 12/16/96

RULE OF THE
JACKSONVILLE ENVIRONMENTAL PROTECTION BOARD
RULE 2
AIR POLLUTION CONTROL

INDEX

PART I - GENERAL PROVISIONS

- 2.101 Definitions
- 2.102 Authority and Intent
- 2.103 Severability
- 2.104 Registration and Reports
- 2.105 Maintenance of Pollution Control Devices
- 2.106 General Restrictions
- 2.107 Air Pollution Prohibited
- 2.108 Enforcement
- 2.109 Investigations - Right of Entry
- 2.110 Penalties and Injunctive Relief

PART II - AIR POLLUTION CONTROL GENERAL PROVISIONS

- 2.201 Adopts 62-204 FAC by reference

PART III - STATIONARY SOURCES GENERAL REQUIREMENTS

- 2.301 Adopts 62-210 FAC by reference

PART IV - STATIONARY SOURCES - PRECONSTRUCTION REVIEW

- 2.401 Adopts 62-212 FAC by reference

PART V - OPERATION PERMITS FOR MAJOR SOURCES OF AIR POLLUTION

- 2.501 Adopts 62-213 FAC by reference

PART VI - GASOLINE VAPOR CONTROL

- 2.601 Adopts 62-252 FAC by reference
- 2.602 Expanded Stage I Controls in Duval County

PART VII - OPEN BURNING AND FROST PROTECTION FIRES

- 2.701 Adopts 62-256 FAC by reference

PART VIII - AMBIENT AIR QUALITY STANDARDS

- 2.801 Ambient Air Quality Standard for Aggregate Reduced Sulfur (ARS)

PART IX - AIR POLLUTION EPISODES

2.901 Air Pollution Episodes - Local Rules

PART X - STATIONARY SOURCES EMISSION STANDARDS

2.1001 Adopts 62-296 FAC by reference

PART XI - STATIONARY SOURCES - EMISSIONS MONITORING

2.1101 Adopts 62-297 FAC by reference

PART XII - AIR POLLUTION NUISANCE RULES

2.1201 General Standard for Volatile Organic Compounds

2.1202 Emissions from Ships and Locomotives

2.1203 Air Pollution Nuisances

PART XIII - PERMITS - GENERAL PROVISIONS

2.1301 Adopts 62-4 FAC by reference

2.1302 Adopts 120.57 FS and 62 103.150 FAC by reference

Bruce

Equal Opportunity/Affirmative Action Employer

REGULATORY & ENVIRONMENTAL
SERVICES DEPARTMENT
Air & Water Quality Division



September 3, 1997

RECEIVED

SEP 19 1997

BUREAU OF
AIR REGULATION

Mr. Scott M. Sheplak, P.E.
Department of Environmental Protection
Bureau of Air Regulation
111 South Magnolia Drive, Suite 4
Tallahassee, FL 32301

**RE: Draft Title V Operation Permit
Jacksonville Electric Authority - Kennedy Generating Station
Title V Operation Permit No.: 0310047-001-AV**

Dear Mr. Sheplak:

The City of Jacksonville, Regulatory and Environmental Services Department, Air and Water Quality Division (AWQD) has reviewed the above referenced Draft Title V Permit and submit the following comments.

1. The Jacksonville Environmental Protection Board (JEPB) Rule 2, Air Pollution Control, attached, was amended effective December 16, 1996. All references to JEPB Rule 2, should be corrected to the current citations.
2. Section II. Facility-wide Conditions should be corrected as follows:

From: 3. **Not federally enforceable. Odor Nuisance.** Pursuant to Jacksonville Ordinance Code (JOC) Chapter 376.110, any facility that causes or contributes to the emission of objectionable odors which results in the City of Jacksonville Air and Water Quality Division (AWQD) receiving and validating complaints from five (5) or more different households within a 90 day period and can be cited for objectionable odors.
[JOC Chapter 376.100]

To: 3. **Not federally enforceable. Odor Nuisance.** Pursuant to Jacksonville Ordinance Code (JOC) Chapter 376, any facility that causes or contributes to the emission of objectionable odors which results in the City of Jacksonville Air and Water Quality Division (AWQD) receiving and validating complaints from five (5) or more different households within a 90 day period can be cited for objectionable odors.
[JOC Chapter 376]



421 West Church Street - Suite 422
Jacksonville, Florida 32202-4111

Air Quality	630-3484
Water Quality	630-3461
Ground Water	630-4900
Hazardous Materials	630-3404

Mr. Scott M. Sheplak, P.E.
Department of Environmental Protection
Bureau of Air Regulation
September 3, 1997
Page 2

Add: 11. Not federally enforceable. The facility shall be subject to the City of Jacksonville Ordinance Code, Title X, Chapter 360 [Environmental Regulation], Chapter 362 [Air and Water Pollution], Chapter 376 [Odor Control], and JEPB Rule 85-1 [Final Rules with Respect to Organization, Procedures, and Practice].

Add: 12. Not federally enforceable. The facility shall be subject to JEPB Rule 2, Parts I through VII, and Parts IX through XIII.

3. Section III. Emission Units., Subsection A, Specific Condition A.3. - This condition prohibits the use of used oil containing PCBs above the detectable level for startup or shutdown. AWQD requests clarification of detectable level. Is there a specific test method with a specified detectable limit or range? Or, does this Specific Condition prohibit the use of any PCB containing oil for the purpose of startup or shutdown? If the latter is correct, the Specific Condition should read: Used oil containing any PCBs shall not be used for startup or shutdown.

Please address any comments to Mr. Ronald L. Roberson at (904) 630-3484.

Very truly yours,



Richard L. Roberson, P.E., Manager
Air Pollution Permitting Section


RLR/RR/ecr

Attachment

c: Mr. Burce Mitchell, FDEP/Talla.
Mr. Chris Kirts, P.E., FDEP/NED
AWQD File 1670 - A
AWQD Permitting File

JACKSONVILLE ELECTRIC AUTHORITY

21 WEST CHURCH STREET • JACKSONVILLE, FL 32202-3139



August 12, 1997

Mr. Bruce Mitchell
Environmental Administrator
Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, FL 32399-2400

RECEIVED

AUG 13 1997

BUREAU OF
AIR REGULATION

RE: Southside Generating Station
Kennedy Generating Station
Title V Permit Applications - Supplemental Information

Dear Mr. Mitchell:

Attached please find the propane Fuel Segments, revised O&M plans, and Designated Representative Certificates of Representation for the above referenced facilities.

As a clarification, the magnesium based fuel additives referred to in the original applications are typically in the form of magnesium oxide or hydroxide. Other constituents that may be present include sulfonates, sulfates, nitrates, and/or other non-HAP compounds.


Also, the Southside Generating Station currently has no emergency generators while the Kennedy Generating Station has two black-start generators and one emergency generator. These generators operate very infrequently and qualify for the insignificant activity exemption.

Finally, please change the opacity election under 62-296.405(1)(a) for KGS units 8, 9, and 10; and SGS units 4 and 5 from one 2-minute average at 40% per hour to one 6-minute average at 27% per hour.

Mr. Mitchell
August 12, 1997
Page Two

If you have any questions with regard to this matter please contact Bert Gianazza
of my staff at (904) 632-6247.

Sincerely,

A handwritten signature in cursive script, appearing to read "Richard Breitmoser".

Richard Breitmoser, P.E.
Vice President, Environmental
Health and Safety Group

RB/NBG

bc: G. Connell (w/o Atta.)

R. Kappelmann (")

S. Stokes (")

B. Gianazza

Files 4.2.1

4.4.1

TVADDIT

JACKSONVILLE ELECTRIC AUTHORITY
OPERATION AND MAINTENANCE PLAN

Following is a list of activities to be accomplished for the control of particulate emissions from units in or impacting the Duval County non-attainment area. These schedules apply to each on-line units.

Daily as needed:

1. Clean one deck of burners (renew tips as necessary).
2. Conduct one complete soot-blowing cycle (or as needed).
3. Maintain optimum fuel oil temperature and pressure.

Weekly as needed:

1. Clean fuel oil strainers (more frequently if required).

Annually as needed:

1. Clean the boiler and inspect baffles.
2. Inspect the: (a) wind box;
(b) registers;
(c) diffusers;
(d) refractory throat.
3. Adjust the air registers for optimum flame pattern
(more frequently if required).
4. Replace burner tips (more frequently if required).

Major Outages:

1. Overhaul the: (a) turbine/generator;
(b) boiler and auxiliary equipment.
2. Calibrate the: (a) flow meters including sensing line checks;
(b) pneumatic controls;
(c) temperature gauges.

Performance Parameters

The following operational parameters are to be recorded every four hours:

1. Steam flow;
2. Number of burners in service;
3. Burner oil pressure;
4. Burner oil temperature.

Fuel Type: Number 6 residual oil unless otherwise stated.

Records

Records of all operating data and maintenance procedures listed herein shall be retained at the generating station for review, upon request, for a period of two years.

Allowance Tracking System Report

Date: 06/18/97

Page: 1

AUTHORIZED ACCOUNT REPRESENTATIVE INFORMATION

AAR Number 000833
AAR Name Jon P. Eckenbach
Firm Name Jacksonville Electric Authority
Address 1 21 W. Church St.
Address 2
City/State/Zip Jacksonville, FL 32202
Phone 904-632-6315
Fax 904-632-7366

Account Num	Plant/Account Name	AAR/Alternate	AAR Start Date
000207000001	St Johns River Power	AAR	06/17/97
000207000002	St Johns River Power	AAR	06/17/97
000666000008	J D Kennedy	AAR	06/17/97
000666000009	J D Kennedy	AAR	06/17/97
000666000010	J D Kennedy	AAR	06/17/97
000667000001	Northside	AAR	06/17/97
000667000002	Northside	AAR	06/17/97
000667000003	Northside	AAR	06/17/97
000668000001	Southside	AAR	06/17/97
000668000002	Southside	AAR	06/17/97
000668000003	Southside	AAR	06/17/97
000668000004	Southside	AAR	06/17/97
000668000005	Southside	AAR	06/17/97
999900000189	Jacksonville Electric Auth.	AAR	06/17/97

Please review the information shown above and report any errors, along with supporting documentation, to the address listed below, or call the Acid Rain Hotline.



Acid Rain Hotline: (202) 233-9620

U.S. Environmental Protection Agency
Acid Rain Division
401 M Street, SW
Mail Code 6204J
Washington, DC 20460

Emissions Unit Information Section _____ of _____

Segment Description and Rate: Segment _____ of _____

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Propane used as ignitor fuel	
2. Source Classification Code (SCC): 1-01-011-02	
3. SCC Units: kgal	
4. Maximum Hourly Rate: N/A	5. Maximum Annual Rate: N/A
6. Estimated Annual Activity Factor: N/A	
7. Maximum Percent Sulfur: N/A	8. Maximum Percent Ash: N/A
9. Million Btu per SCC Unit: 84	
10. Segment Comment (limit to 200 characters):	

JACKSONVILLE ELECTRIC AUTHORITY
OPERATION AND MAINTENANCE PLAN

RECEIVED

JUN 19 1997

BUREAU OF
FIRE PROTECTION
AIR REGULATION

In compliance with Section 17-2.650(2)(g)4. of the Administrative Code, the Jacksonville Electric Authority submits its "Operation and Maintenance Plan", to be appended where appropriate to unit operating permits.

Operation and Maintenance

Following is a list of activities to be accomplished for the control of particulate emissions from units in or impacting the Duval County non-attainment area. These schedules apply to each on-line unit.

Daily:

1. Clean one deck of burners (renew tips as necessary).
2. Conduct one complete soot-blowing cycle (or as needed).
3. Maintain optimum fuel oil temperature and pressure.

Weekly:

1. Clean fuel oil strainers (more frequently if required).

Annually:

1. Clean the boiler and inspect baffles.
2. Inspect the:
 - (a) wind box;
 - (b) registers;
 - (c) diffusers;
 - (d) refractory throat.
3. Adjust the air registers for optimum flame pattern (more frequently if required).
4. Replace burner tips (more frequently if required).

Major Outages:

1. Overhaul the: (a) turbine/generator
(b) boiler and auxiliary equipment.
2. Calibrate the: (a) flow meters including sensing
line checks;
(b) pneumatic controls;
(c) temperature gauges.

Performance Parameters

The following operational parameters are to be recorded on a bi-hourly basis.

1. Steam flow.
2. Number of burners in service.
3. Burner oil pressure.
4. Burner oil temperature.

Fuel Type: Number 6 residual oil unless otherwise stated.

Records

Records of all operating data and maintenance procedures listed herein shall be retained at the Generating Station for review, upon request, for a period of two years.

Best Available Control Technology (BACT) Determination
Jacksonville Electric Authority (JEA)
Duval County

The JEA plans to install one auxiliary boiler at their Southside generating station and one auxiliary boiler at their Kennedy generating station. Both units will be fossil-fuel-fired and have a design heat input of 20 million Btu/hour. The fuel will be natural gas or No. 2 distillate oil.

JEA is currently modifying the local electrical in-town distribution network and anticipate that the existing stabilizing generator located at the two generating stations will be placed on cold standby. The auxiliary boilers will be used to supply the station steam requirements to allow the stabilizing generators to respond to above normal network power demands.

Both boilers will be located within the area of influence of the Jacksonville particulate nonattainment area (Rule 17-2.410(2)2.).

Particulate emissions are nil when firing natural gas and less than one pound per hour when firing distillate fuel oil. The amount of particulate emissions will not have a significant impact within the nonattainment area, and therefore the two sources are exempt from Rule 17-2.510 New Source Review for Nonattainment Areas. Each source will be subject to a BACT determination as set forth in Rule 17-2.600(6) - Emission Limiting and Performance Standards.

BACT Determination Requested by the Applicant:

Pollutant	Emission Limit
Particulates	0.3 lb/hr maximum
SO ₂	10.5 lb/hr maximum
NO _x	3.0 lb/hr maximum

Date of Receipt of a BACT application:

May 14, 1984

Date of Publication in the Florida Administrative Weekly:

June 1, 1984

Review Group Members:

The determination was based upon comments received from the New Source Review Section and Jacksonville Division of Bio-Environmental Services.

BACT Determined by DER:

The amount of particulate and sulfur dioxide emissions emitted from this source are to be controlled by the firing of natural gas or No. 2 new (1) distillate oil having a sulfur content not to exceed 0.50 percent.

Visible Emissions Not to exceed 15% opacity. 40% opacity is permitted for not more than two minutes in any one hour.

DER Method 9 (17-2.700(6)(a)9. FAC) will be used to determine compliance.

(1) The term "new" means an oil which has been refined from crude oil and has not been used, and which may or may not contain additives.

BACT Determination Rationale:

Sulfur in fuel oil is a primary air pollution concern, in that most of the fuel sulfur becomes SO₂. The emission factors for SO₂ and particulate emissions from oil burning are related to the sulfur content. The department agrees with the applicant's proposal that the firing of No. 2 distillate oil, containing less than 0.5% sulfur or natural gas is BACT for the two auxiliary boilers.

The term "new oil" disallows the use of re-refined or waste oil or any non-fossil fuels, emissions from which were not considered in this BACT analysis.

Details of the Analysis May be Obtained by Contacting:

Edward Palagyi, BACT Coordinator
Department of Environmental Regulation
Bureau of Air Quality Management
2600 Blair Stone Road
Tallahassee, Florida 32301

Recommended By:

CH Fancy

C. H. Fancy, Deputy Bureau Chief

10/15/84

Date

Approved:

Terry Cole for

Victoria J. Tschinkel, Secretary

10/15/84

Date

JACKSONVILLE ELECTRIC AUTHORITY

21 WEST CHURCH STREET • JACKSONVILLE, FL 32202-3139



January 8, 1997

Mr. Jonathan Holtom
Engineer IV
Title V Section, Mail Station 5505
Florida Dept. of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399

RECEIVED
JAN 09 1997
BUREAU OF
AIR REGULATION

Dear Mr. Holtom:

RE: Northside Generating Station/St. Johns River Power Park
Kennedy Generating Station
Southside Generating Station
Title V Permit Applications -- Supplemental Information

Attached please find revised lists of exempt and trivial activities for the above referenced facilities. The trivial activities list is standardized for all three JEA facilities.

Please note that the changes to the "trivial" activities list are shown as overstrikes, and the exempt activities are limited to emergency generators and, in the case of Northside Generating Station, a small lime silo.

If you have any questions with regard to this matter, please contact Bert Gianazza of my staff at (904) 632-6247.

Sincerely,

A handwritten signature in black ink, appearing to be 'Richard Breitmoser', written over a horizontal line.

Richard Breitmoser, P.E.
Vice-President, Environmental
Health & Safety Group

RB/NBG

Document ID #6

trivial
List of Exempt Activities

Indoor sand blasting and abrasive grit blasting where temporary enclosures are used to contain particulates

Coal pile runoff ponds

Open stockpiling of material

Plant grounds maintenance

Routine maintenance/repair activities such as cleaning, welding, non-asbestos insulation removal, hand held tools/equip., meter repair/maintenance, on-line/off-line cleaning of equip.

Main steam pressure/relief valves; steam from boiler operations

Non-halogenated solvent cleaning operations

Indoor fugitives such as vacuum cleaning, solvent storage, office supplies/equipment

Testing equipment such as CEMs, stack sampling calibration gases, oxygen detector

Internal combustion engines which drive compressors, generators, water pumps, or other auxiliary equipment

HVAC (heating, ventilation, and air conditioning systems)

Vent/exhaust systems for:

- Print room storage cabinets
- Transformer vaults/bldg.
- Maint./welding bldgs.
- Operating equipment vents
- Degasifier/dearators/decarbonators
- Air blowers/evacuators/air locks
- Feedwater heater vents

Transformers, switches, and switchgear processing (including cleaning and changing) and venting

Use of nitrogen cap during boiler shut-down

Generator venting

Vent/exhaust from kitchen and breakrooms

Vents/stacks for sewer lines or enclosed areas req. for safety or by code

Electrically heated equipment used for heat treating, tracing, drying, soaking, case hardening or surface conditioning

Sewage treatment fac./equip. ranging in size from porta-john to sewage treatment plants

Stack washing (water, soot)

Cleaning and dewatering of ash basins (heavy equipment/pumps)

Engine rebuilding

Lube oil changes

Receiving fuel oil (truck & pipeline)

Aerosol can use (cleaners, etc.)

Boiler chemical cleaning (cirtosolv & ammonia)

Sootblowing

Liming the boilers (CaOH)

Turbine washing

Boiler gun cleaning (guns dipped into vats of solvent)

Vehicle servicing (oil changes, antifreeze changes, etc.)

Soldering of electrical components (silver, tine solder)

Portable equipment and tools, including electric and gasoline powered

Electro plating

Welding, grinding and cutting activities (metal fumes)

Machining metal parts (cutting oil, metal fumes)

Cleaning condensers (water vapor, "snoop")

Oil spills (#6, #2, turbine lube oil)

Oil-filled electrical equipment vents

Storage and use of boiler chemicals (phosphates, ammonia, hydrazine, magnesium oxide, sodium tripolyphosphate, soda ash, di- and tri-sodium phosphate)

Fume hood in laboratory

Laboratory equipment

Space heaters

Fire and safety equipment

Steam releases

Storage and use of chemicals solely for water/waste water treatment

Neutralization basins/ponds, ash pits/ponds, TETF/ENU, percolation, equalization

Transfer sumps

Firefighting training facilities

Turbine vapor extractor

Lawn maintenance equipment/activities

Application of fungicide, herbicide, pesticide

Air compressors and centrifuges used for compressing air

Handling and removal of clinkers, slag and bottom ash

Recovered materials recycling systems including: bulb crushers, aerosol can puncturing

Waste accumulation/consolidation

Compressed air system

Storage tanks less than 550 gallons

Storage of products in sealed containers

Nuclear gauges used for the purpose of process monitoring

Hydrogen and acid venting from battery rooms vacuum vents for gypsum dewatering bldg

Flue gas desulfurization system absorber feed tank mist eliminator/spray header vent

Renovation/demolition of asbestos

Fires

Chemical spills, leaks & transfers

Oil spills, leaks & change out

Insulating activities

Asphalt or concrete sealing

High pressure water blasting

Excavations for construction activities

Chemical cleaning

boiler
turbine
heat exchanger
misc. plant machinery
solvent cleaning (parts & circuit boards)

Cleaning furnace bottoms or slag removal

Welding all types

Cutting all types
milling & machining

Sanding or grinding - all types

Emission from portable equipment
welding machines (diesel or gas)
pumps (diesel or gas)

Sweeping

Pipe line repairs

fly ash
bottom ash
slurry or sludge transfer
fuel line
process water (cooling water, ash water or condensate)
refuse transport line
Miscellaneous other process lines -

Bag house repairs

Filter change out (oil & air)

Air conditioner repairs

Battery maintenance

Coal feeder maintenance

Refuse feeder maintenance

Other miscellaneous maintenance

Bottom ash removal (from boilers)

Fuel oil storage tank cleaning

Small parts washing using parts washer

A/C servicing by licensed contractor

Searching for condenser leaks using helium

~~Emergency generators~~

mercury containing equipment such as manometers

non-chlorinated solvent degreasing equipment

vacuum pumps in laboratory operations

equipment use for steam cleaning

Document ID #6A

Southside Generating Station

List of Exempt Activities

Emergency Generators

Document ID #6A

Kennedy Generating Station

List of Exempt Activities

Emergency Generators

Document ID #6A

Northside Generating Station/St. Johns River Power Park

List of Exempt Activities

Emergency Generators

Lime Silo

JACKSONVILLE ELECTRIC AUTHORITY

21 WEST CHURCH STREET • JACKSONVILLE, FL 32202-3139



September 11, 1996

RECEIVED
SEP 16 1996
BUREAU OF
AIR REGULATION

Mr. Jonathan Holtom

Title V Section
Mail Station 5505
Florida Dept. of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399

Dear Mr. Holtom:

RE: Northside Generating Station
Kennedy Generating Station
Southside Generating Station
Title V Permit Applications -- Supplemental Information

Attached please find the permit revision dated May 1, 1995 removing the throughput limits on the fuel storage tanks at each of the above facilities.

Also enclosed is the permit revision dated July 16, 1996 removing the fuel sulfur limits at the Northside station and providing for using the CEMs to show continuous compliance with the SO₂ emission limit using a 24-hour midnight-to-midnight average.

Finally, please note that no information was provided for Unit 3 at the Southside station since that unit is no longer in service and the air operating permit has been allowed to expire. Southside Units 1 and 2 air operating permits were surrendered during the St. Johns River Power Park permitting process and the emissions were used as offsets for modeling PSD increment consumption.


was it extend by Rule? surrendered by letter 5-14-97 RA

Mr. Jonathan Holtom
September 11, 1996
Page Two

All of these conditions are reflected in the Title V permit application as previously submitted.

If you have any questions with regard to this matter, please contact Bert Gianazza of my staff at (904) 632-6247.

Sincerely,

A handwritten signature in black ink, appearing to be "Richard Breitmoser", with a long horizontal line extending to the right.

Richard Breitmoser, P.E.
Vice-President
Environmental Health &
Safety Group

RB/NBG

TITLEV2

**REGULATORY & ENVIRONMENTAL
SERVICES DEPARTMENT**

Air Quality Division



May 1, 1995

Mr. Robert Leetch, P.E.
Department of Environmental Protection
Northeast District
7825 Baymeadows Way, Suite B200
Jacksonville, Florida 32256-7590

JACKSONVILLE ELECTRIC AUTHORITY

RECEIVED

MAY 03 1995

Environmental, Health
& Safety Department

**RE: Duval County - Air Pollution
JEA Generating Station Fuel Storage Tanks
Kennedy Permit No. AO16-225064
Northside Permit No. AO16-225069
Southside Permit No. AO16-225066**

Dear Mr. Leetch:

The City of Jacksonville, Regulatory and Environmental Services Department, Air Quality Division (AQD) received a request on March 31, 1995 from JEA to amend the above referenced permits (attachment). The request is to delete throughput limits and the associated record-keeping requirements. In accordance with the Standard Operating Agreement, AQD is referring this request to your office for processing and final agency action.

AQD has reviewed this request and provides the following recommendations.

1. Specific Condition 7. of each referenced permit limits the throughput of No. 6 and No. 2 fuel oil. AQD agrees with JEA that the throughput limits should be eliminated.
2. AQD recommends that the record-keeping requirements for fuel oil throughput be maintained. An estimate of emissions for the AOR and Title V inventories will require this data.



421 West Church Street - Suite 412
Jacksonville, Florida 32202-4111

Area Code 904/630-3484


Mr. Robert Leetch, P.E.

May 1, 1995

Page 2

Please contact me or Mr. Ronald L. Roberson at (904) 630-3484 for any additional information.

Very truly yours,



Richard L. Robinson, P.E.

Pollution Control Engineer

RLR/ecr

Attachment

c: ✓ Mr. Richard Breitmoser, P.E. - JEA
Mr. Wayne Tutt, AQD
AQD File 1700-A
AQD Permitting File



CITY OF LAKE WORTH

1900 2ND AVENUE NORTH
LAKE WORTH, FLORIDA 33461
www.lakeworth.org

UTILITIES
DEPARTMENT

(561) 586-1666
FAX (561) 586-1702

October 23, 2006

RECEIVED

OCT 26 2006

Mr. Scott Sheplak, P.E.
Florida Department of Environmental Protection
Twin Towers Office Bldg. Mail Station 5500 BUREAU OF AIR REGULATION
2600 Blair Stone Road
Tallahassee, FL 32399-2400

Subject: Title V Responsible Official/ Designated Representative
City of Lake Worth Utilities, Tom G. Smith Power Plant
Facility #0990045

Dear Mr. Sheplak:

Please be advised that the City Commission has authorized Mr. Paul C. Boyer, Jr., City Manager to be the Responsible Official and Authorized Representative for our Title V Permit and the Designated Representative (DR) under the Acid Rain Program and Mr. David Mulvay, Power Plant Manager as the Alternate Designated Representative (ADR). The notification for the (DR/ADR) was published for public comment on October 20, 2006. An updated DEP Responsible Official form and a copy of the EPA Certificate of Representation form reflecting this change are attached. The updated Certificate of Representation form was submitted to EPA as well.

If you have any questions, please contact me at 561-533-7384 or email mjohnstone@lakeworth.org

Sincerely,
CITY OF LAKE WORTH UTILITIES

Margaret Johnstone
Margaret Johnstone
Environmental Compliance Officer

- cc: Mr. Ajaya Satyal, Environmental Manager Palm Beach County Health Dept.
- Mr. Laxmana Tallum, DEP SE District
- Mr. Paul C. Boyer, Jr., City Manager
- Dave Mulvay, Power Plant Manager
- Mike Ridge, Environmental/Performance Specialist



Certificate of Representation

For more information, see instructions and refer to 40 CFR 72.24

This submission is: • New • Revised (submission must be complete; see instructions)

STEP 1
Identify the source by plant name, State, and ORIS code.

Plant Name	Tom G. Smith Power Plant	State	FL	ORIS Code	0673
------------	--------------------------	-------	----	-----------	------

STEP 2
Enter requested information for the designated representative.

Name		Paul C. Boyer, Jr.			
Address					
Lake Worth Utilities					
1900 2nd Avenue North					
Lake Worth, FL 33461					
Phone Number			Fax Number		
561-586-1665			561-586-1702		
E-mail address (if available)					
pboyer@lakeworth.org					

STEP 3
Enter requested information for the alternate designated representative, if applicable.

Name		David Mulvay			
Address					
Lake Worth utilities					
1900 2nd Avenue North					
Lake Worth, FL 33461					
Phone Number			Fax Number		
561-533-7379			561-533-7387		
E-mail address (if available)					
dmulvay@lakeworth.org					

STEP 4: Complete Steps 5 and 6, read the certifications, sign and date.

I certify that I was selected as the designated representative or alternate designated representative, as applicable, by an agreement binding on the owners and operators of the affected source and each affected unit at the source.

I certify that I have all necessary authority to carry out my duties and responsibilities under the Acid Rain Program on behalf of the owners and operators of the affected source and of each affected unit at the source and that each such owner and operator shall be fully bound by my representations, actions, inactions, or submissions.

I certify that the owners and operators of the affected source and of each affected unit at the source shall be bound by any order issued to me by the Administrator, the permitting authority, or a court regarding the source or unit.

Where there are multiple holders of a legal or equitable title to, or a leasehold interest in, an affected unit, or where a utility or industrial customer purchases power from an affected unit under life-of-the-unit, firm power contractual arrangements, I certify that:

I have given a written notice of my selection as the designated representative or alternate designated representative, as applicable, and of the agreement by which I was selected to each owner and operator of the affected source and of each affected unit at the source; and

Allowances and the proceeds of transactions involving allowances will be deemed to be held or distributed in proportion to each holder's legal, equitable, leasehold, or contractual reservation or entitlement, except that, if such multiple holders have expressly provided for a different distribution of allowances by contract, that allowances and the proceeds of transactions involving allowances will be deemed to be held or distributed in accordance with the contract.

Plant Name (from Step 1) Tom G. Smith Power Plant

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

<i>Paul C. [Signature]</i> Signature (designated representative)	10/23/06 Date
<i>David J. [Signature]</i> Signature (alternate designated representative)	10/23/06 Date

STEP 5
Provide the name of every owner and operator of the source and identify each affected unit they own and/or operate.

Name City of Lake Worth					<input checked="" type="checkbox"/> Owner	<input checked="" type="checkbox"/> Operator
ID# S-3	ID# S-4	ID#	ID#	ID#	ID#	ID#
ID#	ID#	ID#	ID#	ID#	ID#	ID#

Name					<input type="checkbox"/> Owner	<input type="checkbox"/> Operator
ID#	ID#	ID#	ID#	ID#	ID#	ID#
ID#	ID#	ID#	ID#	ID#	ID#	ID#

Name					<input type="checkbox"/> Owner	<input type="checkbox"/> Operator
ID#	ID#	ID#	ID#	ID#	ID#	ID#
ID#	ID#	ID#	ID#	ID#	ID#	ID#

STEP 6
For any new affected units listed at STEP 5 that have not commenced commercial operation, enter the projected date on which the unit is expected to commence commercial operation.

ID#	Projected Commence Commercial Operation Date:
ID#	Projected Commence Commercial Operation Date:
ID#	Projected Commence Commercial Operation Date:
ID#	Projected Commence Commercial Operation Date: