STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

NOTICE OF ADMINISTRATIVELY CORRECTED TITLE V OPERATION PERMIT

In the Matter of an Administrative Correction:

Mr. Donald L. Lockhart
Executive Director
Solid Waste Authority of Palm Beach County
7501 North Jog Road
West Palm Beach, Florida 33412

FINAL Permit No.: 0990234-001-AV Project No.: 0990234-003-AV

North County Resource Recovery Facility

Enclosed is an ADMINISTRATIVELY CORRECTED page to the initial Title V operation permit, 0990234-001-AV for the operation of the North County Resource Recovery Facility located at 6501 North Jog Road, West Palm Beach, Palm Beach County. This correction is issued pursuant to Rule 62-210.360, Florida Administrative Code and Chapter 403, Florida Statutes (F.S.). On March 28, 2001, the applicant brought the error to the department's attention. This corrective action does not alter the effective dates of the existing permit.

Any party to this order (permit) has the right to seek judicial review of it under Section 120.68 of the Florida Statutes., by the filing of a Notice of Appeal under Rule 9.110 of the Florida Rules of Appellate Procedure, with the clerk of the Department of Environmental Protection in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within thirty days from the date this notice is filed with the clerk of the permitting authority.

Executed in Tallahassee, Florida.

Sincerely.

C. H. Fancy, P.E

Chief

Bureau of Air Regulation

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT (including the corrected page(s)) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on ________ to the person(s listed or as otherwise noted:

Mr. Donald L. Lockhart, SWA

Ms. Mary Beth Mihalik, SWA

Mr. Isidore Goldman, DEP/SED

Mr. James E. Stormer, Palm Beach County

USEPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of

which is hereby acknowledged.

(Clerk)

(Date)

ADMINISTRATIVE PERMIT CORRECTION

TO FINAL Permit No.: 0990234-001-AV

Project No.: 0990234-003-AV

North County Resource Recovery Facility

Condition number A.1.0. is changed

From:

A.1.0. Permitted Capacity. The maximum heat input rates (operation rates) are as follows:

E.U. ID No.	Steam Flow Rate a	Heat Input Rate b	Fuel Type
001	324,000 lb/hour	412.5 MMBtu/hour	RDF
002	324,000 lb/hour	412.5 MMBtu/hour	RDF

Notes:

{Permitting note: The heat input limitations have been placed in each permit to identify the capacity of each emissions unit for purposes of confirming that emissions testing is conducted within 90-100 percent of the emissions unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate limits and to aid in determining future rule applicability.}

[Rules 62-4.160(2) and 62-210.228(PTE), F.A.C. and PSD-FL-108A]

To:

A.1.0. Permitted Capacity. The maximum heat input rates (operation rates) are as follows:

E.U. ID No.	Steam Flow Rate a	Heat Input Rate b	Fuel Type
001	324,000 lb/hour	412.5 MMBtu/hour	RDF
002	324,000 lb/hour	412.5 MMBtu/hour	RDF

Notes:

{Permitting note: The heat input limitations have been placed in each permit to identify the capacity of each emissions unit for purposes of confirming that emissions testing is conducted within 90-100 percent of the emissions unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate limits and to aid in determining future rule applicability.}

[Rules 62-4.160(2) and 62-210.228(PTE), F.A.C. and PSD-FL-108A]

^a 4 hour block average {See Condition R.14.}

^b Maximum heat input rate is based upon a reference heating value of 5500 BTU/lb. of RDF. Actual heating values range from 4500 to 6200 BTU/lb.

^a 4 hour block average {See Condition R.19.}

^b Maximum heat input rate is based upon a reference heating value of 5500 BTU/lb. of RDF. Actual heating values range from 4500 to 6200 BTU/lb.

SENDER: COMPLETE THIS SECTION	<i></i>	COMPLETE THIS SECTION ON DELIVERY		
 Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits. 		A. Received by (Please Print Clearly) B. Date of Deliver 23 C. Signature X R. Murphy Agent Addresse		
1. Article Addressed to: Mr. Donald L. Lockha Executive Director Solid Waste Authorit Palm Beach County		Due delivery address different from item 1?		
7501 North Jog Road West Palm Beach, Florida 33413		3. Service Type Certified Mail Express Mail Registered Return Receipt for Mel	rchandis	
		4. Restricted Delivery? (Extra Fee)	es	
0.441.41.4				
2. Article Number (Copy from service label) 7099 3400 0000 1449	5052			

г <u>л</u> ¦	U.S. Postal Service CERTIFIED MAIL RECEIPT (Domestic Mail Only; No Insurance Coverage Provided) Article Sent To: Mr. Donald L. Lockhart				
7					
5.0					
T T T	Postage				
F-7	Certified Fee				
0	Return Receipt Fee (Endorsement Required)		Post He		
0.0	Restricted Delivery Fee (Endorsement Required)				
0 D h	Total Postage & Fees	\$			
, m	Name (Please Print Clear)	nnt Clearly) (to be completed by mailer)			
	Mr. Donald L. Lockhart Street Agt No. of PO Box No.				
0"	/501 North Jog Road				
	City State Zip. 4 West Palm Beach, Florida 33413				
{	PS Form 0500, July 1999			e for Instructions	