

- Title V permit file -
application

INTEROFFICE MEMORANDUM

Date: 07-Apr-2000 01:47pm
From: Mary Beth Mihalik
mmihalik@swa.org
Dept:
Tel No:

To: 'Scott Sheplak' (Scott.Sheplak@dep.state.fl.us)

Subject: FW: Title V Proposed Permit - Correction of Equivalent Numbers in Table 1-1

Scott,

The first message was returned. I am trying this again!

Thanks.

Mary Beth

-----Original Message-----

From: Marybeth Mihalik ext. 4613
Sent: Friday, April 07, 2000 1:36 PM
To: 'Scott Sheplak'
Cc: Richard Statom ext. 4612; Marc Bruner ext. 4607
Subject: Title V Proposed Permit - Correction of Equivalent Numbers in Table 1-1

Scott,

After reviewing the calculations for the "equivalent numbers" from Table 1-1 Summary of Air Pollutant Standards and Terms in the proposed permit Title V, it was discovered in the permit application that an average dry standard flow rate, obtained from previous stack tests, was being used instead of the maximum dry standard flow rate for the boilers.

The following are the corrected "equivalent numbers" which need to be changed in Table 1-1 for Units 1 & 2 as part of the Solid Waste Authority's Title V Proposed Permit 0990234-001-AV:

Pollutant	lb/hr	TPY
S02	45.82	200.68
N0x	284.77	1247.29
PM	16.35	71.63
CO	137.8	603.56
HCl	28.08	122.98
Hg	4.16E-02	0.182
Pb	2.61E-01	1.14

Thanks,

Mary Beth