



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blainstone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor
Jeff Kottkamp
Lt. Governor
Mimi Drew
Secretary

Sent by Electronic Mail – Received Receipt Requested

mhammond@swa.org

Mark Hammond, Executive Director
Solid Waste Authority of Palm Beach County
7501 North Jog Road
West Palm Beach, FL 33412

Re: DEP File No. 0990234-017-AC (PSD-FL-413)
Palm Beach Renewable Energy Park
Palm Beach Renewable Energy Facility No. 2 (PBREF-2)

Dear Mr. Hammond:

On May 17, 2010, you submitted an application for an air construction permit subject to the preconstruction review requirements of Rule 62-212.400, Florida Administrative Code, for the Prevention of Significant Deterioration (PSD) of Air Quality.

The PBREF-2 project consists of the construction of three 1,000 tons per day mass-burn municipal waste combustors, a 90 to 100 megawatts steam turbine-electrical generator and ancillary equipment. The proposed work will be conducted at the existing Palm Beach Renewable Energy Park.

Enclosed are the following documents: Written Notice of Intent to Issue Air Permit; Public Notice of Intent to Issue Air Permit; Technical Evaluation and Preliminary Determination; and Draft Permit with Appendices.

The Public Notice of Intent to Issue Air Permit is the actual notice that you must have published in the legal advertisement section of a newspaper of general circulation in the area affected by this project. If you have any questions, please contact the Project Engineer, Bobby Bull, P.E., at 850/921-7744.

Sincerely,


Trina Vielhauer, Chief
Bureau of Air Regulation

11/12/10
(Date)

Enclosures

TLV/aal/rlb

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

*In the Matter of an
Application for Air Permit by:*

Solid Waste Authority of Palm Beach County
7501 North Jog Road
West Palm Beach, FL 33412

DEP File No. 0990234-017-AC (PSD-FL-413)
Palm Beach Renewable Energy Park
Palm Beach Renewable Energy Facility No. 2
Palm Beach County, Florida

Authorized Representative:

Mark Hammond, Executive Director

Facility Location: The Solid Waste Authority of Palm Beach County proposes to construct the new Palm Beach Renewable Energy Facility No. 2 (PBREF-2), which will be located at the existing Palm Beach Renewable Energy Park in Palm Beach County at 7501 North Jog Road in West Palm Beach, Florida.

Project: The PBREF-2 project consists of the construction of three 1,000 tons per day mass-burn municipal waste combustors, a 90 to 100 megawatts steam turbine-electrical generator and ancillary equipment. The proposed work will be conducted at the existing Palm Beach Renewable Energy Park.

The project is subject to the preconstruction review requirements of Rule 62-212.400, Florida Administrative Code (F.A.C.) for the Prevention of Significant Deterioration of Air Quality requiring a best available control technology determination.

Permitting Authority: Applications for air construction permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210 and 62-212, F.A.C. The proposed project is not exempt from air permitting requirements and an air permit is required to perform the proposed work. The Florida Department of Environmental Protection's Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination for this project. The Bureau of Air Regulation's physical address is 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301 and the mailing address is 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Bureau of Air Regulation's phone number is 850/488-0114.

Project File: A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at address indicated above for the Permitting Authority. The complete project file includes the Draft Permit, the Technical Evaluation and Preliminary Determination, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address and phone number listed above.

Notice of Intent to Issue Air Permit: The Permitting Authority gives notice of its intent to issue an air permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of the proposed equipment will not adversely impact air quality and that the project will comply with all applicable provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a Final Permit in accordance with the conditions of the proposed Draft Permit unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, F.S. or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.

Public Notice: Pursuant to Section 403.815, F.S. and Rules 62-110.106 and 62-210.350, F.A.C., you (the applicant) are required to publish at your own expense the enclosed Public Notice of Intent to Issue Air Permit (Public Notice). The Public Notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected by this project. The newspaper used must meet the requirements of Sections 50.011 and 50.031, F.S. in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the Permitting Authority at the address or phone number listed above. Pursuant to Rule 62-110.106(5) and (9), F.A.C., the applicant shall provide proof of publication to the Permitting Authority at the above address within 7 days of publication. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rule 62-110.106(11), F.A.C.

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

Comments: The Permitting Authority will accept written comments concerning the proposed Draft Permit and requests for a public meeting for a period of 30 days from the date of publication of the Public Notice. Written comments must be received by the Permitting Authority by close of business (5:00 p.m.) on or before the end of this 30-day period. In addition, if a public meeting is requested within the 30-day comment period and conducted by the Permitting Authority, any oral and written comments received during the public meeting will also be considered by the Permitting Authority. If timely received comments result in a significant change to the Draft Permit, the Permitting Authority shall revise the Draft Permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.

Petitions: A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 850/245-2241; Fax: 850/245-2303). Petitions filed by the applicant or any of the parties listed below must be filed within 14 days of receipt of this Written Notice of Intent to Issue Air Permit. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within 14 days of publication of the attached Public Notice or within fourteen 14 days of receipt of this Written Notice of Intent to Issue Air Permit, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of when and how each petitioner received notice of the agency action or proposed decision; (d) A statement of all disputed issues of material fact; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C. Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Written Notice of Intent to Issue Air Permit. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation: Mediation is not available in this proceeding.

Executed in Tallahassee, Florida.



Trina Vielhauer, Chief
Bureau of Air Regulation

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Written Notice of Intent to Issue Air Permit Package (including the Written Notice of Intent to Issue Air Permit, the Public Notice of Intent to Issue Air Permit, the Technical Evaluation and Preliminary Determination and the Draft Permit with Appendices) was sent by electronic mail, or link to these documents made available electronically on a publicly assessable server, with received receipt requested before close of business on 11/17/10 to the persons listed below.

- Mark Hammond, SWA Executive Director: mhammond@swa.org
- Michael Halpin, DEP Siting: mike.halpin@dep.state.fl.us
- Kevin Claridge, DEP SED: kevin.claridge@dep.state.fl.us
- Jim Stormer, Palm Beach County Health Department: james_stormer@doh.state.fl.us
- Heather Abrams, EPA Region 4: abrams.heather@epa.gov
- Dee Morse, NPS: dee_morse@nps.gov
- Amit Chattopadhyay, P.E., Malcolm Pirnie: achattopadhyay@pirnie.com
- Vickie Gibson, DEP BAR Reading File: victoria.gibson@dep.state.fl.us

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.



(Clerk) 11/12/10
(Date)



**TECHNICAL EVALUATION
&
PRELIMINARY DETERMINATION**

APPLICANT

Solid Waste Authority of Palm Beach County
7501 North Jog Road
West Palm Beach, Florida 33412

PROJECT

DEP File No. 0990234-017-AC (PSD-FL-413)
Palm Beach Renewable Energy Facility No. 2

COUNTY

Palm Beach County, Florida

PERMITTING AUTHORITY

Florida Department of Environmental Protection
Division of Air Resource Management
Bureau of Air Regulation
2600 Blair Stone Road, MS#5505
Tallahassee, Florida 32399-2400

November 15, 2010

1. APPLICATION INFORMATION

1.1. Applicant Name and Address

Solid Waste Authority of Palm Beach County (the SWA)
7501 North Jog Road
West Palm Beach, Florida 33412

Authorized Representative: Mr. Mark Hammond, Executive Director

1.2. Key Dates

- May 17, 2010 Received a Prevention of Significant Deterioration (PSD) air construction permit application from the SWA.
- June 16 Department issued first request for additional information (RAI).
- August 9 & 23 Received responses to first RAI.
- September 14 Received further information in response to first RAI and modification of application to incorporate selective catalytic reduction (SCR).
- October 6 Received ambient air quality modeling to demonstrate compliance with the 1-hour nitrogen dioxide (NO₂) and 1-hour sulfur dioxide (SO₂) National Ambient Air Quality Standards (NAAQS).
- November 15 Department issued Draft Permit decision for SRF and posted documents.

1.3. Facility Location

Palm Beach County (PBC) owns the Palm Beach County Renewable Energy Park (PBREP), which is located at 7501 North Jog Road (immediately west of the Turnpike) in West Palm Beach. The PBREP consists of Class I and Class III landfills, a biosolids pelletizer facility, a compost facility and a waste-to-energy (WTE) plant known as the North County Resource Recovery Facility (NCRRF).

The existing NCRRF is operated by Palm Beach Resource Recovery Corporation, which is a subsidiary of Babcock and Wilcox Corporation (B&W). It consists of a municipal solid waste (MSW) tipping floor, a refuse derived fuel (RDF) processing plant, a RDF storage building, two RDF-fueled municipal waste combustors (MWC), a steam turbine-electric generator (STG), pollution control equipment, and associated facilities and equipment. The location of the PBREP is shown in Figure 1. The UTM coordinates are Zone 17; 585.3 kilometers (km) East and 2,961.7km North.



Figure 1 - Location of the Existing PBREP **Figure 2 - Aerial View from Northeast of the PBREP**

The PBREP is located approximately 118 kilometers north northeast of the Everglades National Park (ENP), a Class I area with respect to the PSD rules and 123 km north of the Class II Biscayne Bay National Park. The landfill and waste unloading area at the PBREP are shown below.



Figure 3 – Existing SWA Landfill



Figure 4 – Waste Transfer Trucks

1.4. Project Description

The applicant proposes to construct a second WTE plant to be known as the Palm Beach Renewable Energy Facility No. 2 (PBREF-2) and will be located immediately north of the existing PBREP as shown in a preliminary rendition below. PBREF-2 will consist of:



Figure 5 – Existing NCRRF (left, south) and Artist Rendition of the new PBREF-2 (right, north)

- Three nominal 1,000 TPD mass burn MWC, each with an estimated maximum continuous rating (MCR) of 416.7 million Btu per hour heat input (mmBtu/hr) and a peak rating of 458.3 mmBtu/hr;
- A 100 megawatt (MW) STG with an air cooled condenser;
- One ash building and handling system;
- Three lime storage silos and one carbon storage silo; and
- Two 250 horsepower (hp) diesel fire pumps and one 250 kilowatt (kW) emergency generator.



Figure 6 - Northeast View of New PBREF-2 Figure 7 - View of Stacks from IronHorse – 17th Tee

The three MWC furnaces will be based on grate stoker technology. Each boiler will produce approximately 291,000 pounds per hour (lb/hr) of steam on a 24-hr basis and 320,100 lb/hr of steam on a 4-hr block average. Approximately 78 MW of electric power from the single STG will be delivered to the grid. Table 1 indicates the new emissions units (EUs) that will be added by this project.

Table 1. - New EUs for PBREF #2

Facility ID No. 0990234	
ID No.	Emission Unit Description
024	Municipal Waste Combustor #1
025	Municipal Waste Combustor #2
026	Municipal Waste Combustor #3
027	Lime Storage Silo A
028	Lime Storage Silo B
029	Lime Storage Silo C
030	Carbon Storage Silo
031	Diesel Fire Pump A
032	Diesel Fire Pump B
033	Emergency Generator
034	Ash Building and Handling System

1.5. Additional Project Features

Fuels

The SWA proposes to fuel the new mass-burn MWC stoker units primarily with MSW rather than RDF. A natural gas-fired auxiliary burner system will be used on a limited basis during periods of startup and shutdown and to maintain good combustion conditions. MSW includes the items and materials that fit within the definition of MSW contained in either 40 CFR 60.51b or Section 403.706(5), Florida Statutes (1995). The PBREF-2 will also process other solid wastes that are not strictly classified as MSW. Following is an example of a typical fuel slate for MWC in Florida. The actual fuel slate for the proposed project will be stated in the permit.

The facility shall not burn any of the following materials:

- a) those materials that are prohibited by state or federal law;
- b) those materials that are prohibited by this permit;
- c) lead acid batteries;
- d) hazardous waste;
- e) nuclear waste;
- f) radioactive waste;

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

- g) sewage sludge;
- h) explosives; and
- i) beryllium-containing waste, as defined in 40 CFR 61, Subpart C.

Further, the facility shall not knowingly burn:

- a) nickel-cadmium batteries pursuant to Section 403.7192 (3);
- b) mercury containing devices and lamps pursuant to Sections 403.7186(2) & (3);
- c) untreated biomedical waste from biomedical waste generators regulated pursuant to Chapter 64E-16, F.A.C., and from similar generators (or sources);
- d) segregated loads of biological waste; and
- e) chromated copper arsenate (CCA) treated wood.

The following other solid waste may be used as fuel at the facility:

- a) confidential, proprietary or special documents (including but not limited to business records, lottery tickets, event tickets, coupons and microfilm);
- b) contraband which is being destroyed at the request of appropriately authorized local, state or federal governmental agencies, provided that such material is not an explosive, a propellant, a hazardous waste, or otherwise prohibited at the facility. For the purposes of this determination, contraband includes but is not limited to drugs, narcotics, fruits, vegetables, plants, counterfeit money, and counterfeit consumer goods;
- c) wood pallets, clean wood, and land clearing debris;
- d) packaging materials and containers;
- e) clothing, natural and synthetic fibers, fabric remnants, and similar debris, including but not limited to aprons and gloves;
- f) rugs, carpets, and floor coverings, but not asbestos-containing materials or polyethylene or polyurethane vinyl floor coverings;
- g) construction and demolition debris;
- h) oil spill debris from aquatic, coastal, estuarine or river environments. Such items or materials include but are not limited to rags, wipes, and absorbents;
- i) items suitable for human, plant or domesticated animal use, consumption or application where the item's shelf-life has expired or the generator wishes to remove the items from the market. Such items or materials include but are not limited to off-specification or expired consumer products, pharmaceuticals, medications, health and personal care products, cosmetics, foodstuffs, nutritional supplements, returned goods, and controlled substances;
- j) consumer-packaged products intended for human or domesticated animal use or application but not consumption. Such items or materials include but are not limited to carpet cleaners, household or bathroom cleaners, polishes, waxes and detergents;
- k) Waste materials that:
 - i. are generated in the manufacture of items in categories (c) or (d) above and are functionally or commercially useless (expired, rejected or spent); or
 - ii. are not yet formed or packaged for commercial distribution. Such items or materials must be substantially similar to other items or materials routinely found in MSW.
- l) Waste materials that contain oil from:
 - i. the routine cleanup of industrial or commercial establishments and machinery; or
 - ii. spills of virgin or used petroleum products. Such items or materials include but are not limited to rags, wipes, and absorbents.
- m) used oil and used oil filters. Used oil containing a PCB concentration equal or greater than 50 parts per million (ppm) shall not be burned, pursuant to the limitations of 40 CFR 761.20(e); and
- n) waste materials generated by manufacturing, industrial or agricultural activities, provided that these items or materials are substantially similar to items or materials that are found routinely in MSW, subject to prior approval of the Department.

Air Pollution Controls

MWC

The exact design details of the proposed PBREF-2 will be available after a bidder is selected. However, the basic features of the MWC and associated air pollution control equipment are known. The typical pollution control measures and equipment for recently constructed mass burn units in the U.S. consist of Good Combustion Practices (GCP), Spray Dryer (SD) Absorber, Fabric Filter (FF) Baghouse, Activated Carbon Injection (CI) and Selective Non-Catalytic Reduction (SNCR). The shorthand notation for this arrangement is GCP/SD/FF/CI/SNCR. The PBREF-2 project is based on this arrangement, but will incorporate an advanced feature known as selective catalytic reduction (SCR) in lieu of or in addition to SNCR. Thus the PBREF-2 strategy is GCP/SD/FF/CI/SCR.

Figure 8 is a diagram of the typical Martin GmbH (a partner of Covanta) mass burn grate stoker MWC with the typical air pollution control equipment configuration of GCP/SD/FF/CI/SNCR. MSW is unloaded and then charged to grate stoker furnace where it is combusted. The ammonia (NH₃) tank and injection system shown in the figure are for the SNCR system that controls nitrogen oxides (NO_x) formed in the furnace. A possible location of a SCR unit is indicated as well.




Figure 8 – Typical Martin GmbH Mass Burn MWC with GCP/SD/FF/CI/SNCR Configuration

The lime silos, lime addition point and semidry scrubber shown in the figure comprise the SD absorber system wherein acid gases in the furnace exhaust such as hydrogen chloride (HCl) and sulfur dioxide (SO₂) are neutralized and captured as particulate matter (PM). The carbon silo and addition point comprise the activated CI system which serves to capture (adsorb) certain metals such as mercury (Hg) and organic hazardous air pollutants (HAP) such as dioxin and furan (D/F) and then remove them in the FF baghouse. The baghouse contains the FF media that captures PM originating from the combustion, the acid gas reactions and the spent activated carbon. However it would be located between the FF baghouse and the stack and would (in conjunction with or in the absence of SNCR) destroy NO_x, react and reduce excess NH₃, and provide addition organic HAP and D/F control.

Storage

- PM Emissions from the carbon and limo silos will be controlled by a FF baghouses.

Emergency Support Equipment

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

- The emergency generator and fire pumps will be designed to meet the emission limits given in New Source Performance Standards (NSPS) Subpart IIII and National Emission Standards for Hazardous Air Pollutants (NESHAP) Subpart ZZZZ.
- Ultra low sulfur distillate (ULSD) fuel oil will be utilized, and operation of these units will be limited to 100 hours per year or less per unit.

1.6. Project Emissions

Tabulations of project emissions are given and discussed in conjunction with major source review applicability in Section 2.3.

2. APPLICABLE REGULATIONS

2.1. State Regulations

This project is subject to the applicable environmental laws specified in Chapter 403 of the Florida Statutes (F.S.). The F.S. authorize the Department of Environmental Protection (Department) to establish rules and regulations regarding air quality as part of the Florida Administrative Code (F.A.C.). This project is subject to the applicable rules and regulations defined in the following Chapters of the F.A.C. and summarized in Table 2.

Table 2 - Applicable Rules from the F.A.C.

F.A.C. Rule	Description
62-4	Permits
62-204	Air Pollution Control – General Provisions
62-210	Stationary Sources of Air Pollution – General Requirements
62-212	Stationary Sources – Preconstruction Review
62-213	Operation Permits for Major Sources (Title V) of Air Pollution
62-214	Requirements for Sources Subject to the Federal (Title IV) Acid Rain Program
62-296	Stationary Sources – Emission Standards
62-297	Stationary Sources – Emissions Monitoring

2.2. Federal Regulations

The U.S. Environmental Protection Agency (EPA) establishes air quality regulations in 40 CFR Part 60 that identifies New Source Performance Standards (NSPS) for a variety of industrial activities. 40 CFR Part 61 specifies National Emission Standards for Hazardous Air Pollutants (NESHAP). 40 CFR Part 63 specifies NESHAP provisions based on the Maximum Achievable Control Technology (MACT) for given source categories. Federal regulations adopted by reference are given in Rule 62-204.800, F.A.C. State regulations approved by EPA are given in 40 CFR Part 52, Subpart K – Florida, also known as the State Implementation Plan (SIP) for Florida.

2.3. PSD Major Stationary Source Applicability Determination

The Department regulates major stationary sources in accordance with Florida’s PSD program pursuant to Rule 62-212.400, F.A.C. PSD preconstruction review is required in areas that are currently in attainment with the state and federal Ambient Air Quality Standards (AAQS) or areas designated as “unclassifiable” for these regulated pollutants.

As defined in Rule 62-210.200(189), F.A.C., a facility is considered a “major stationary source” if it emits or has the potential to emit (PTE) 5 tons per year (TPY) of lead (Pb), 250 TPY or more of any PSD pollutant, or 100 TPY or more of any PSD pollutant and the facility belongs to one of the 28 listed PSD major facility categories. The existing NCRRF (to which the PBREF-2 is an expansion) is a major stationary source because it contains: *“Municipal incinerators capable of charging more than 250 tons of refuse per day which emits, or has the PTE, 100 TPY or more of any PSD pollutant.”*

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

PSD pollutants include: carbon monoxide (CO); NO_x; SO₂; PM; PM smaller than 10 micrometers (PM₁₀); VOC; Pb; fluorides (F); sulfuric acid mist (SAM); total reduced sulfur (TRS), including hydrogen sulfide (H₂S); MWC organics measured as total tetra- through octa-chlorinated dibenzo-p-dioxins and dibenzofurans (D/F); MWC metals measured as PM; MWC acid gases (MWC-AG) measured as SO₂ and hydrogen chloride (HCl); MSW landfill emissions as non-methane organic compounds (NMOC); and Hg.

Refer to Table 3. For existing major stationary sources (such as the existing NCRRF), PSD applicability is based on emissions thresholds known as the significant emission rates (SER) as defined in Rule 62-210.200, (Definitions) F.A.C. Emissions of PSD pollutants from the PBREF-2 project exceeding these SER are considered “significant” and BACT must be employed to minimize emissions of each pollutant.

Table 3 – List of SER by PSD-Pollutant

Pollutant	SER (TPY)	Pollutant	SER (TPY)
CO	100	NO _x	40
PM/PM ₁₀	25/15	Ozone (VOC) ¹	40
Ozone (NO _x) ¹	40	SAM	7
SO ₂	40	F	3
MWC organics as D/F	3.5 x 10 ⁻⁶	MWC-AG as HCl+SO ₂	40
MWC metals as PM	15	MSW Landfill Emissions as NMOC	50
Pb	0.6	TRS	10
H ₂ S	10	Hg	0.1

1. Ozone (O₃) is regulated by its precursors (VOC and NO_x).

Table 4 is a summary of the applicant’s revised estimates of key regulated air pollutants from the proposed PBREF-2 and whether each pollutant exceeds the respective SER thus triggering PSD.

Table 4 – Applicant’s Revised Estimated PTE of Key Pollutants (in TPY) for the PBREF-2

Pollutant and Emissions in TPY	3 MWC	Silos	Diesel Fire Pumps	Emergency Generator	Total	PSD?
NO _x	401.9		0.14	0.15	402.2	Yes
CO	434.9		0.07	0.09	435.1	Yes
SO ₂	298.7		0.0003	0.0002	298.7	Yes
MWC-AG as HCl, SO ₂	440.4				440.4	Yes
VOC	59.8		0.003	0.006	59.8	Yes
PM ¹ and MWC metals as PM ¹	56.1	0.04	0.006	0.003	56.1	Yes
PM ₁₀ ¹	56.1	0.036	0.006	0.003	56.1	Yes
Pb	0.65				0.65	Yes
SAM	95.2				95.2	Yes
MWC organics as D/F	6.08 x 10 ⁻⁵				6.08 x 10 ⁻⁵	Yes
Hg	0.056				0.056	No
Fluorides (Estimated as HF) ^{3,5}	13.6				13.6	No ⁵
PM _{2.5} ¹	56.1	0.036	0.006	0.003	56.1	Note 2
HCl	141.7				141.7	Note 3
HF	~13.6				~13.6	Note 3
Cadmium (Cd)	0.047				0.047	Note 3
NH ₃	33.00				33.0	Note 4

1. PM, PM₁₀, and PM with a diameter less than 2.5 micrometers (PM_{2.5}) from the MWC are estimated as filterable (front-half sampling train) material measured by EPA Method 5.
 2. PM_{2.5} is also a PSD pollutant under federal rules, but an SER has not yet been defined in the Department’s rules. It is regulated by its precursors and surrogates (e.g. PM/PM₁₀ NH₃, SO₂, NO_x).
 3. HCl, HF and Cd are HAP which are not regulated by the PSD program.
 4. NH₃ is introduced as a pollution control reagent for the SCR system.
 5. Applicant assumed that HF constitutes Fluorides. However, HF is regulated as a HAP (see Note 3). Non-HF Fluoride emissions will be much less than 13.6 TPY and less than 3 TPY based on tests conducted at existing NCRRF.

2.4. Regulatory Classification

Following is a summary of the applicability of key regulations to the PBREF-2 project.

Chapter 62-4, F.A.C. www.dep.state.fl.us/air/rules/fac/62-4.pdf

Rule 62-4.070(1), F.A.C., Standards for Issuing or Denying Permits; Issuance; Denial.

This rule applies to all permitting decisions:

- A permit shall be issued to the applicant upon such conditions as the Department may direct, only if the applicant affirmatively provides the Department with reasonable assurance based on plans, test results, installation of pollution control equipment, or other information, that the construction, expansion, modification, operation, or activity of the installation will not discharge, emit, or cause pollution in contravention of Department standards or rules.

Chapter 62-17, F.A.C. www.dep.state.fl.us/siting/files/rules_statutes/pps_rule.pdf

- The PBREF-2 project requires a modification of the previously issued conditions of certification for the NCRRF pursuant to the power plant siting provisions of this rule.

Chapter 62-204, F.A.C. www.dep.state.fl.us/air/rules/fac/62-204.pdf

Rule 62-204.220(1), F.A.C., Ambient Air Quality Protection.

This rule applies to all air permitting decisions.

- The Department shall not issue an air permit authorizing a person to build, erect, construct, or implant any new emissions unit; operate, modify, or rebuild any existing emissions unit; or by any other means release or take action which would result in the release of an air pollutant into the atmosphere which would cause or contribute to a violation of an ambient air quality standard established under Rule 62-204.240, F.A.C.

Rule 62-204.240, F.A.C., Ambient Air Quality Standards.

This rule applies to all air permitting decisions.

- Refer to list of pollutants and ambient air quality standards provided therein and discussed in the Ambient Air Quality Section of this evaluation.

Rule 62-204.800(8), F.A.C., 40 CFR 60, NSPS.

The following provisions incorporated into Rule 62-204.800(8), F.A.C. adopted from 40 CFR 60 and incorporated into this rule apply to this project:

- 40 CFR 60, Subpart A – General Provisions;
- 40 CFR 60, Subpart Eb – Standards of Performance for Large Municipal Waste Combustors for Which Construction is Commenced After September 20, 1994 or for Which Modification or Reconstruction is Commenced After June 19, 1996; and
- 40 CFR 60, Subpart IIII – Stationary Compression Ignition Internal Combustion Engines (ICE).

In accordance with Section 129 of the Clean Air Act (CAA), Subpart Eb accomplishes the purposes of both the NSPS and NESHAP MACT requirements for MWC.

Rule 62-204.800(11), F.A.C., 40 CFR 63, NESHAP.

The following provision incorporated into Rule 62-204.800(11), F.A.C. adopted from 40 CFR 63 and incorporated into this rule applies to this project:

- 40 CFR 63, Subpart ZZZZ – Stationary Reciprocating Internal Combustion Engines (RICE). This subpart requires all affected area source units to meet the applicable emission standards of 40 CFR 60, Subpart IIII.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Chapter 62-210, F.A.C. www.dep.state.fl.us/air/rules/fac/62-210.pdf

Rule 62-210.200, F.A.C., Definitions.

- The facility (including the PBREF-2) is a Title V or “Major Source” of air pollution because the PTE of at least one regulated pollutant will exceed 100 TPY.
- The facility (including the PBREF-2) is a major source of HAP because it emits or has a PTE of 10 TPY or more of any one HAP or 25 TPY or more of any combination of HAP.
- The facility (including the PBREF-2) is classified as a “Major Stationary Source” (PSD-source) because it emits 100 TPY or more of a PSD pollutant and is one of the 28 facility categories listed in the definition with the PSD applicability threshold of 100 TPY.

Rule 62-210.300, F.A.C., Permits Required.

- Unless exempted, the owner or operator of any facility or emissions unit which emits or can reasonably be expected to emit any air pollutant shall obtain appropriate authorization (i.e. a permit) from the Department prior to undertaking any activity at the facility or emissions unit for which such authorization is required.

Rule 62-210.350, F.A.C. Public Notice and Comment.

- A notice of proposed agency action on permit application, where the proposed agency action is to issue the permit, shall be published by any applicant.
- The rule details additional public notice requirements for emissions units subject to PSD. Examples include: the location and nature of the project; whether BACT has been determined; PSD increment consumption; and notification to the public of the opportunity to submit comments or request a public hearing (meeting).

Rule 62-210.700, F.A.C., Excess Emissions.

This rule applies to all air permitting decisions. Only the key provisions potentially affecting this project are listed.

- Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
- Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction shall be prohibited.
- Considering operational variations in types of industrial equipment operations affected by this rule, the Department may adjust maximum and minimum factors to provide reasonable and practical regulatory controls consistent with the public interest.

Chapter 62-212, F.A.C. www.dep.state.fl.us/air/rules/fac/62-212.pdf

Rule 62-212.300, F.A.C., General Preconstruction Review Requirements.

- This rule generally applies to the construction or modification of air pollutant emitting facilities in those parts of the state in which the state ambient air quality standards are being met.

Rule 62-212.400, F.A.C., PSD.

- The rule applies because the project is a major stationary (PSD) source and the project emissions exceed the SER.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Chapter 62-213, F.A.C. www.dep.state.fl.us/air/rules/fac/62-213.pdf

- Because the facility is a Title V source, the applicant will be required to apply for and obtain a Title V operation permit revision for the PBREF-2 project in the future.

Chapter 62-214, F.A.C. www.dep.state.fl.us/air/rules/fac/62-214.pdf

- The proposed plant will be a Title V source, will serve an electric generator capable of generating 25 MW or more of electricity and will sell the resultant electricity. At this time, the unit will burn less than 20% fossil fuels in the MWC units and will not be required to apply for and obtain a Title IV Acid Rain Part within its Title V operation permit. However, if increased fossil fuels are fired at the MWC units, the facility is subject to the requirements of Chapter 62-214.320(1)(h), F.A.C.

Chapter 62-296, F.A.C. www.dep.state.fl.us/air/rules/fac/62-296.pdf

Rule 62-296.320, F.A.C., General Pollutant Emission Limitation Standards.

- This rule prohibits the discharge of air pollutants which cause or contribute to an objectionable odor;
- This rule specifies a visible emissions (VE) standard of 20 percent (%) opacity; and
- The rule prohibits emissions of unconfined PM provisions without taking reasonable precautions to prevent such emissions.

Rules 62-296.401, F.A.C., Incinerators

- Incinerators and WTE facilities combust waste. The fuel slate authorized by this permit constitutes a waste or MSW according to the Department's rules, but the rule applies to permits charging 50 tons per year
- TPD or less. Therefore, this rule does not apply to this project.

Rule 62-296.416, F.A.C., WTE Facilities.

- Incinerators and waste to energy facilities combust waste. The fuel slate authorized by this permit constitutes a waste or MSW according to the Department's rules, and the rule applies to this permit since it authorizes charging is 50 TPD or greater.

Rule 62-296.406, F.A.C., Fossil Fuel Steam Generators with Less than 250 mmBtu Heat Input

- This rule applies only to the extent that fossil fuel is burned in the MWC unit. The fossil fuel heat input capability of the MWC unit will be less than 250 mmBtu/hr. This provision specifies a VE standard of 20 percent (%) opacity; and compliance with the Best Available Control Technology limits for NO_x and SO₂ (e.g., this permit BACT Determination).

Rule 62-296.470, F.A.C., Implementation of Federal Clean Air Interstate Rule (CAIR).

- The Palm Beach Renewable Energy Park is subject to CAIR.

3. BACT REVIEW

BACT determinations are required for the pollutants that are subject to PSD review, including NO_x, CO, SO₂, PM/PM₁₀, VOC, Pb, F, SAM, MWC organics as D/F, MWC metals as PM, and MWC-AG as SO₂ and HCl.

A BACT determination for PM_{2.5} is not required primarily because the Department has not yet adopted a SER for PM_{2.5} and identified it as a PSD-pollutant. Even without a SIP requirement and without approved test methods or accounting requirements, the Department nevertheless relies on precursors and surrogates to minimize direct emissions and subsequent formation of PM_{2.5} per the rationale given below.

On September 16, 1997, EPA revised the NAAQS for particulate matter, which includes a new NAAQS for PM_{2.5}. Florida implemented an ambient monitoring program for PM_{2.5}. As EPA mentioned in its guidance dated October 23, 1997, there are significant technical difficulties with respect to PM_{2.5} monitoring, emissions estimation and modeling.

This guidance recommended the use of PM₁₀ as a surrogate for PM_{2.5} in meeting New Source Review (NSR) requirements under the CAA, including the permit programs for PSD. Meeting these measures in the interim will serve as a surrogate approach for reducing PM_{2.5} emissions and protecting air quality. Florida is in the process of revising its SIP to address the new PM_{2.5}, NAAQS, PSD SER and ambient air quality impact thresholds for modeling analyses as required by EPA for approved states by early 2011. Until state regulations support PSD preconstruction review for PM_{2.5} emissions, the Department will rely on PM₁₀ emission limits and PM_{2.5} precursor limits (e.g., SAM, SO₂, VOC, NH₃, and NO_x). This approach is more robust than the EPA guidance memoranda.

3.1. Definition of BACT

Rule 62-210.200, F.A.C. defines "BACT" as:

An emission limitation, including a visible emissions standard, based on the maximum degree of reduction of each pollutant emitted which the Department, on a case by case basis, taking into account:

- 1. Energy, environmental and economic impacts, and other costs;*
- 2. All scientific, engineering, and technical material and other information available to the Department; and*
- 3. The emission limiting standards or BACT determinations of Florida and any other state; determines is achievable through application of production processes and available methods, systems and techniques (including fuel cleaning or treatment or innovative fuel combustion techniques) for control of each such pollutant.*

If the Department determines that technological or economic limitations on the application of measurement methodology to a particular part of an emissions unit or facility would make the imposition of an emission standard infeasible, a design, equipment, work practice, operational standard or combination thereof, may be prescribed instead to satisfy the requirement for the application of BACT. Such standard shall, to the degree possible, set forth the emissions reductions achievable by implementation of such design, equipment, work practice or operation.

Each BACT determination shall include applicable test methods or shall provide for determining compliance with the standard(s) by means which achieve equivalent results.

In no event shall application of best available control technology result in emissions of any pollutant which would exceed the emissions allowed by any applicable standard under 40 CFR Parts 60, 61, and 63.

3.2. BACT Review for the MWC (EU 024, 25, 26)

Generation of Pollutants from MWC

A very basic description of the mass burn process and planned air pollution control equipment was provided in Section 1.5 above. A WTE facility is a complete industrial installation containing most or all of the following features:

- Waste receiving and separation
- Waste storage and handling
- Waste feeding
- Furnace for combustion
- Heat recovery equipment followed by steam and electricity generation
- Air pollution control devices (flue gas treatment)
- Residue (ash and wastewater) handling installations

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

A schematic of a mass-burn MWC with steam electrical power production is shown in the following figure. Some of the points where pollutants can be removed or formation prevented are shown.




Figure 9. Pollutant Generation/Control Points



Figure 10 - Refuse pit at Brescia facility, Italy

Waste is delivered, weighed, sorted/separated if necessary, and tipped into the refuse pit, such as the one shown in Figure 10, where it is temporarily stored. The tipping hall and refuse pit are closed buildings to minimize dust and odor releases. The waste is mixed in the refuse pit which is designed to hold sufficient fuel for several days of combustion as waste is typically delivered during normal working hours while the plant operates “24/7”. Air is continually extracted from the pit to maintain a negative pressure and serves as combustion air for the furnace.

A crane system lifts the waste from the refuse pit and transports it to the feed chute, which consists of a hopper and chute. Hydraulic-driven feed rams push the waste onto the horizontal combustion grate. Refer to Figures 11 and 12.




Figure 11 - Martin GmbH Grate System




Figure 12 - Seghers Water and Air Cooled Grate

GCP Concepts.

The grate system and furnace comprise the core of a MWC and provide the opportunities to implement the GCP. Most NO_x is released from combustion of fuel nitrogen, with the exception of thermal NO_x formed in “hot spots”. Martin GmbH (partner of Covanta) designs can be horizontal or reverse-acting grates. Options exist regarding the manner by which the waste is mixed on the grates, number of zones, the way underfire air is introduced and the manner by which grate cooling is accomplished. The waste begins to burn at the grate front end and the fuel bed temperatures reach over 1,000°C. The waste is combusted to inert mineral bottom ash through the slow and uniform mixing and agitating motion of the fuel bed.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Rows of water-cooled tiles can be added to rows of air cooled tiles in a hybrid grate arrangement based on the characteristics of the waste (i.e. high calorific value, or wet, etc.). These last longer than air cooled grates, allow more efficient use of primary air for combustion rather than cooling, and can aid in NO_x minimization. The heat absorbed by the water within the grates is recovered.

Additional GCP options include the overfire air (OFA) arrangement, flue gas recirculation (FGR) or other sophisticated combustion techniques. Basically, the temperature is maintained high enough to destroy hazardous organic compounds such as D/F but low enough to reduce the potential for refractory damage and minimize thermal NO_x emissions. OFA is injected into the furnace above the fuel bed via nozzles arranged opposite each other in the front and rear furnace walls. The flue gases are thus subject to turbulence, mixed in an extremely efficient manner, and char and CO effectively burn out.

In response to the Department's aggressive NO_x requirement for the Hillsborough County WTE Facility Unit 4 in 2006, Covanta and Martin GmbH embarked on an effort to improve the profile of the Martin Grate stoker design by employing more advanced GCP concepts. They call their designs low NO_x (LNTM) and very low NO_x (VLNTM)¹.

The technology, known as VLNTM, employs combustion system design, which in addition to conventional primary and secondary air streams, also features a new internal stream of gas called "VLNTM gas," which is drawn from the combustor and re-injected into the furnace. The gas flow distribution between the primary and secondary air, as well as the VLNTM gas, is controlled to yield the optimal flue gas composition and furnace temperature profile to minimize NO_x formation and optimize combustion.

Figure 13 is a simplified diagram of the VLNTM process. Figure 14 demonstrates that operation of the VLNTM system reduces NO_x concentration by roughly half.




Figure 13 – Diagram of the VLNTM Process **Figure 14 – Operation with/without VLNTM System**

The basic principle of the VLNTM and similar processes is to maintain a reducing zone to destroy or inhibit the formation of NO_x. The theoretical approach of these types of arrangement is as follows:

Equation 1. The material fuel immediately above and on the grate is heated and pyrolyzed releasing hydrocarbon radicals (CH_i*). These, in turn, catalytically or otherwise react with nitrogen oxide (NO) to form hydrogen cyanide (HCN) according to:



Where:

$$i = 1, 2, 3$$

Equation 2. HCN in turn destroys more NO_x in the reducing environment according to:



¹ Covanta and Martin GmbH. New Process for Achieving Very Low NO_x. Proceedings of the 17th Annual North American Waste-to-Energy Conference. May 2009.

Equation 3. Ammonia-like radicals (NH_i*) are also released during pyrolysis. Under reducing conditions these radicals destroy NO according to:



This mechanism suppresses formation of NO by the pyrolyzed fuel nitrogen and recruits that nitrogen to combat NO_x in reactions that at first glance look much like SNCR or SCR discussed further below.

Reactions 2 and 3 can be catalytically enhanced based on the presence of various species within such an environment. Also, they can be accelerated by attaining a relatively high temperature within the reducing atmosphere but well below that which would promote thermal NO_x formation. Other reactions involving CO or hydrogen (H₂) also destroy NO_x in this reducing atmosphere and can be to varying degrees catalytically enhanced. Additional volatile and char combustion occurs in the higher temperature free board region above the bed. CharC denotes char carbon and CharN denotes char nitrogen.

Equation 4 and 5. Under the reducing conditions, even the char can assist on NO_x destruction as follows:



Eventually the NO_x destruction reactions will proceed much more slowly and some of the remaining fuel nitrogen forms additional NO_x.

Equations 6, 7, 8 and 9. In the presence of the progressively oxidizing environment effected by the two OFA levels, NO_x formation rather than destruction predominates.



The management of NO_x formation and destruction involves promotion of Eq. 1 through 5 to form nitrogen (N₂) before the inevitable and progressive addition of OFA causes Eq. 6 through 9 to dominate. This can be accomplished to the greatest degree by delaying and then adding the OFA in stages.

Peak flame temperatures will increase when lower moisture content materials are combusted and during low load boiler operations. During these periods, FGR can be employed to lower the peak flame temperatures thus avoiding the tendency to form thermal NO_x.

There are numerous approaches which are marketed under names like Mobotec, EcoJet, EcoTube, Prizm, etc. that incorporate innovations such that emissions from grate stokers can be minimized by modern GCP and then achieve very low emissions with add-on controls.

Besides NO_x, other pollutants released in the furnace include: CO, PM/PM₁₀/PM_{2.5} including MWC metals such as Pb and Cd; MWC-AG including SO₂ and HCl; MWC organics including D/F, VOC and Hg.

The following figure includes a picture of the Tampa MacKay Bay RRF and a side view diagram of one of their Riley boilers. Each boiler includes a furnace, two empty passes and several superheater and economizers in the final passes. Radiant and calorific energy released in the combustion chamber and furnace is recovered by the furnace waterwall, convective zone, superheater and economizer. The steam that is produced is used to run a STG.




Figure 15 - Aerial View, Tampa MacKay Bay RRF and Side Elevation of a Riley Furnace/Boiler

Table 5 is a summary of the basic MWC boiler characteristics for the PBREF-2 project.

Table 5 – MWC Characteristics for the PBREF-2 Project

Parameter	Description
MWC Type	Grate stoker technology with waterwall, superheaters, fans, economizers, air heaters, soot blowers
Primary Fuel	MSW
Supplemental Fuel	Additional specified solid waste fuel slate and pipeline natural gas
Ash Removal	From baghouse and MWC to ash storage silo via an enclosed conveyor
Condenser	Air cooled condenser to provide dry cooling of exhaust steam
Heat Input Rate	Maximum capacity is 458 mmBtu/hr of which a maximum of 246 mmBtu/hr is from natural gas
Steam Production	291,000 lb/hr (24-hr average), 320,100 lb/hour (4-hr block average)
Stack Parameters	8.1 feet (ft) diameter (maximum); 310 ft tall (minimum) with three independent flues
Flue Gas	184,310 actual cubic feet per minute (acfm) at 315 °F
Pollution Control System	GCP/SD/FF/CI/SCR (with or without SNCR)

The collected ash will be transferred from the boiler and the air pollution control buildings to the ash management building via enclosed conveyor. The collected ash will be combined and quenched with water. The ash management building will contain ash processing equipment including ferrous and non-ferrous recovery systems. Since the ash will be wetted to a moisture content level in the approximate range of 20 to 25 percent, fugitive particulate matter emissions for the ash handling building are expected to be negligible.

To further minimize PM emissions from the ash management building ventilation air will be routed to a fabric filter control device prior to discharge to the atmosphere. The residual ash will be transferred from the ash management building in covered, leak resistant vehicles for disposal at the onsite landfill. All loading and preparation for ash transport will occur within the enclosed ash management building. Because the ash is moist, dust will not be generated during transportation and disposal.

Requirements of NSPS for Large MWC

In no event shall the application of BACT result in emissions of any pollutant from the PBREF-2 project which would exceed the emissions allowed by 40 CFR 60, Subpart Eb; the NSPS and MACT for Large MWC.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Table 6 is a comparison of the SWA BACT proposal with the Subpart Eb Large MWC MACT promulgated by EPA in May 2006.²

Table 6 – Comparison of PBREF-2 BACT Proposal with Subpart Eb MACT Limits

Pollutant		Subpart Eb MACT	PBREF-2 BACT Proposal	
NO _x		180 ppmvd ¹ (1 st year) 150 ppmvd (thereafter) (24 hr mean)	50 ppmvd (24-hr mean) 45 ppmvd (Annual)	GCP/SCR with or w/o SNCR
CO		100 ppmvd (4-hr block mean)	100 ppmvd (4-hr block mean) 80 ppmvd (30-day)	GCP
MWC-AG	SO ₂	30 ppmvd or 80 percent (%) reduction ⁵ (24-hr geometric mean)	24 ppmvd or 80% reduction ⁵ (24-hr geometric mean)	SD/FF/CI
	HCl	25 ppmvd or 95% reduction ⁵	20 ppmvd or 95% reduction ⁵	SD/FF
PM, MWC metals as PM		20 mg/dscm ² (filterable)	12 mg/dscm (filterable)	GCP/SD/FF/CI/SCR
Pb		140 µg/dscm ³	125 µg/dscm	SD/FF/CI
Cd		10 µg/dscm	10 µg/dscm	
Hg		50 µg/dscm or 85% reduction ⁵	25 µg/dscm or 85% reduction ⁵ 113 lb/yr (12-month) ⁶	
MWC organics as D/F		13 ng total/dscm ⁴	13 ng total/dscm	GCP/SD/FF/CI/SCR
VE (opacity)		10% (6 minute average)	10% (6 minute average)	GCP/SD/FF/CI/SCR
PM ₁₀ and PM _{2.5}		No Standard	12 mg/dscm (filterable)	GCP/SD/FF/CI/SCR
VOC		No Standard	7 ppmvd	GCP/CI/SCR
Fluoride		No Standard	3.5 ppmvd as HF	SD/FF
SAM		No Standard	5 ppmvd	SD/FF/CI
NH ₃ Slip		No Standard	10 ppmvd	SCR

1. ppmvd means parts per million by volume, dry at 7 percent oxygen (@ 7% O₂).
 2. mg/dscm means milligrams dry standard cubic meter @ 7% O₂.
 3. µg/dscm means micrograms/dscm @ 7% O₂.
 4. ng/dscm means nanograms/dscm @ 7% O₂. D/F is measured as total and not as the toxic equivalent (TEQ).
 5. The least stringent of the two values.
 6. Equivalent to approximately 12 µg/dscm.

The SWA proposed BACT limits for the PBREF-2 are at least as stringent as the Subpart Eb MACT requirements for the pollutants subject to both BACT and MACT. The central role of GCP and the integration of all of the techniques is also clear. The use of SCR in lieu of or in addition to SNCR makes it possible to meet a much lower NO_x BACT limit than required by the MACT which relies primarily on SNCR.

Reduction of Annual Emissions from Large and Small MWC

The implementation of MACT in accordance with 40 CFR Part 60 at existing and new units for large and small MWC resulted in very significant reductions in emissions nation-wide by 2005 compared with emissions in 1990. The reductions were estimated by EPA and are summarized in Table 7.³

² Final Rule. 40 CFR 60 – Standards of Performance for New Stationary Sources and Emission Guidelines for Existing Sources; Large MWC; Final Rule. Federal Register / Vol 71, No. 90 / May 10, 2006. Pages 27324-332.
³ Memorandum. Stevenson, Walt of EPA to Docket EPA-HQ-OAR-2005-0117. August 10, 2007.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Table 7 – Total Emissions from All Large and Small MWC in the U.S. in 1990 and 2005

Pollutant	1990 Emissions	2005 Emissions	Reduction (%)
NO _x	64,900	49,500	24
SO ₂	38,300	4,600	88
HCl	57,400	3,200	94
PM	18,600	780	96
Pb	170	5.5	97
Hg	57	2.3	96
Cd	9.6	0.4	96
D/F (total, not TEQ)	4.85 x 10 ⁻³	1.65 x 10 ⁻⁵	99+

Most, though not all MWC, installed the GCP/SD/FF/CI/SNCR configuration. Some did not install SNCR for NO_x control or did not install CI for Hg and D/F. Some rely on electrostatic precipitators (ESP) instead of FF baghouses for PM control. Some have wet scrubbers instead of SD to eliminate acid gases.

The nation-wide reductions are based on actual measurements rather than emission limits which are greater and based on the applicable MACT regulations such as 40 CFR 60, Subpart Eb or Cb. The actual reductions are very impressive for all pollutants except for NO_x. The major focus of Department reviews has been to concentrate on NO_x reduction as it is clear that the standard design of GCP/SD/FF/CI/SNCR has not resulted in reductions commensurate with those in other industries, such as coal-fueled power plants.

Figures 16 and 17 indicate the average performance of large MWC in the U.S. with respect to Hg and D/F. While Hg reductions continue on average, there have not been commensurate reductions in D/F.





Figure 16 – Average Hg Concentrations (µg/dscm) Figure 17 – Average D/F Concentrations (ng/dscm)

Total Hg emissions have been considerably reduced at MWC in Florida as indicated in Figure 18. Emissions in 1991 were more than 5 tons and by 2007 had been reduced to approximately 0.275 tons or 550 lb. Recent values, while greatly improved, are still significant and the Department continues to focus on Hg control. D/F is subject to BACT and is also a focus of the Department’s project review.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION



Actual Performance of Large MWC Compared with Subpart Eb

Table 8 is a comparison of the performance of large MWC with the Subpart Eb MACT limits.

Table 8 – Comparison of Performance of Large MWC with Subpart Eb MACT Limits

Pollutant	Subpart Eb (2006)	Large MWC (mean/99%UCL) ¹	Hillsborough 4 ²
NO _x	150 ppmvd	173 / 215 ppmvd	109 ppmvd (SNCR) ~ 70 ppmvd (SNCR+LN)
CO	100 ppmvd	Not Available	26 ppmvd
SO ₂	30 ppmvd or 80 percent (%) reduction ⁵	6.4 / 21.8 ppmvd	0.56 ppmvd and 99.1% reduction
HCl	25 ppmvd or 95% reduction ⁵	8.5 / 23.5 ppmvd	11.5 ppmvd and 98.2% reduction
MWC metals as PM	20 mg/dscm ²	3.2 / 9.5 mg/dscm	1.0 mg/dscm
Pb	140 µg/dscm	11.3 / 35.6 µg/dscm	18.3 µg/dscm
Hg	50 µg/dscm or 85% reduction ⁵	7.9 / 26.7 µg/dscm	1.5 µg/dscm and 97.8% reduction
Cd	10 µg/dscm	0.77 / 2.2 µg/dscm	0.2 µg/dscm
MWC organics as D/F	13 ng total/dscm ⁴	2.4 / 9.5 ng total/dscm	0.26 ng/dscm
VE (opacity)	10% (6 minute average)	Not Available	0%

1. Mean and 99% upper confidence limit (UCL) values from summary statistics developed in 2005 and used in development of the Subpart Eb MACT limits for the GCP/SD/FF/CI/SNCR arrangement.

2. Initial compliance test results from newest MWC with GCP/SD/FF/CI/SNCR in the U.S. NO_x was further reduced after tuning of Covanta LNTM system.

The values in the third column represent the statistical average and the statistical 99% UCL concentrations based on tests conducted at numerous MWC with the GCP/SD/FF/CI/SNCR configuration. The summary is based on a 2005 compilation by EPA's contractor and was used when determining the limits in Subpart Eb for new MWC with the GCP/SD/FF/CI/SNCR configuration.⁴

It is clear that EPA relied on the 99% UCL when setting the Subpart Eb limits so it is not surprising that any large MWC with the standard configuration of GCP/SD/FF/CI/SNCR will readily meet these limits with the possible exception of NO_x. The Department has commented to EPA that the approach when used in other industries (such as cement and coal power plants) does not comport with the CAA requirement that MACT for existing sources is based on the average of the best performing 12% of existing sources. Adherence to the 99% UCL is contrary to the notion of the average of the best performing 12%.

More importantly, the approach used by EPA for MACT on new sources makes it difficult for the regions and state programs to explain to applicants the feasibility and requirement for more stringent limits through the PSD/BACT process.

The final column represents the results of the performance tests conducted at the recently commissioned Hillsborough County WTE Unit 4.⁵ Unit 4 was the first MWC constructed after promulgation of the 2006 Subpart Eb MACT and was based on GCP/SD/FF/CI/SNCR control strategy and BACT. Unit 4 performed well within the Subpart Eb requirements as expected and, on balance, much better than the average large MWC upon which Subpart Eb was based.

Notably, Unit 4 performed much better than the Subpart Eb limitation for NO_x (which was not revised in the 2006 Rule). The main reason was that the Department set BACT limits of 110 and 90 ppmvd on 24-hour and 12-month bases, respectively. As mentioned, this led to improvements by Covanta of its grate and furnace GCP to insure that the limit could be met without excessive use of NH₃ in the SNCR system.

NO_x BACT Analysis

Add-on Controls for NO_x Control.

Initial add-on NO_x controls for MWC consisted of SNCR whereby NH₃ or urea is injected at a point in the process characterized by a suitable temperature window between about 1,500 and 1,900 °F depending on residence time, turbulence, oxygen content, and a number of other factors specific to the given gas stream. The reaction products are N₂ and water vapor (H₂O). SNCR destroys NO_x by a multi-step process as described in the simplified equations below.

Equation 10. NH₃ reacts with available hydroxyl radicals (OH*) to form amine radicals (NH₂*) and water per the following theoretical equation:



Equation 11. Amine radicals combine with NO to form nitrogen and water as follows:



Equation 12. The two steps are typically expressed as a single "global reaction".



Similar simplified reactions describe the destruction of NO₂.

⁴ Memorandum. Huckaby, Jason of Eastern Research Group (ERG) to Stevenson, Walt of EPA. Large MWC 5-Year Review/Stack Test Pollutants. October 27, 2005.

⁵ Initial Compliance Report. Transmitted from Boldissar, B. of Hillsborough County Solid Waste Management Department to Henry, Danielle of the Florida Department of Environmental Protection. MWC No. 4 Initial Compliance Test Report. October 8, 2009.

One drawback with SNCR is that some of the NH₃ can be converted to NO_x and excessive NH₃ injection is occasionally required to effect good reduction. Excess NH₃ (called slip) can combine with chloride and sulfate species in the exhaust and cause visible emissions. Additionally, good CO control is necessary when employing SNCR due to interference with the reaction as described.

Equation 13. CO competes with NH₃ for available OH radicals needed to effect Eq. 10.



In the case of SCR technology, the NH₃ is injected in the presence of catalyst and at a lower temperature than encountered in the furnace. The reactions are more complete and efficient and NH₃ slip is minimized. Minimization of NH₃ emissions reduces the formation of ammoniated chlorides and sulfates, plume opacity and condensable PM including condensable PM₁₀ and PM_{2.5}.

Advanced techniques have been developed to minimize the use of excessive reagent while using SNCR. Examples include smart systems such as DyNOR shown in Figure 19.⁶ Basically reagent NH₃ is directed most precisely to the instantaneous points within the furnace that have the highest NO_x concentrations or correct temperature window to provide best NO_x destruction and least temperature window. This is accomplished through the use of sophisticated instrumentation such as: infrared (IR) pyrometers to detect temperature distributions; multilevel injection levels, computerized feedback and individual injector control; and tunable diode laser (TDL) to measure NH₃ in the furnace. This approach not only avoids excessive NH₃ use for the NO_x present, it also minimizes conversion (combustion) of NH₃ into additional NO_x which would otherwise require even more NH₃ reagent to destroy.




Figure 19 – VonRoll DyNOR SNCR System **Figure 20 – Comparison of Slip for SCR and SNCR**

The basic shapes of curves describing NO_x emissions versus NH₃ slip are shown in Figure 20. The blue area relates to the option of injecting excessive NH₃ to achieve low NO_x and removing/recovering the excess NH₃ in a wet scrubber. The Department concurs with the trends implied by the curves, but not necessarily the numerical NH₃ slip values associated with the given NO_x reduction objectives. For example, a well designed SCR yields closer to 1 ppmvd of NH₃ slip versus the range given (2-14 ppmvd).

A combination of SCR and SNCR would involve injection of urea or NH₃ in the furnace and reliance on a smaller reactor and less catalyst than required by SCR alone. The issue is an economic one and will be determined by the selected supplier.

⁶ Paper. Zigg et al, VonRoll. DyNOR™ DeNOx Performance Confirmed in Further MSW Plants. Proceedings of the 18th Annual North American WTE Conference. Orlando. May 2010.

Applicant's NO_x BACT Proposal

Per Table 6, the applicant proposes to meet a NO_x limit of 50 ppmvd on a 24-hour basis and 45 ppmvd on a 12-month rolling basis as demonstrated by the continuous emissions monitoring system (CEMS) required by Subpart Eb. The SWA proposes to rely on GCP and SCR or a combination of GCP, SNCR and SCR. Following is a short discussion of SNCR and SCR.

The SWA estimates the cost of three SCR installations will be \$61.5 million and \$6,585/ton NO_x removed whereas the cost of three SNCR installations to meet a higher NO_x limit would have been approximately \$4 million and \$1,449/ton NO_x removed.

The Department believes costs for the SCR systems and cost per ton NO_x removed will be much less if provided as part of an integrated bid. SNCR and SCR would likely be less expensive than SCR alone. The Department agrees that the cost will be significant (but nevertheless cost-effective) with respect to the overall estimated cost of the entire project.

Department's NO_x BACT Determination

The NO_x proposal is equivalent to 0.085 pounds per million Btu heat input (lb/mmBtu) short-term and 0.77 lb/mmBtu long-term. The Department accepts the SWA BACT proposal for NO_x from the PBREF-2 based on the following rationale:

- The proposal is much more stringent than the requirement in Subpart Eb;
- The proposed values are less than any permitted WTE facility in the U.S.;
- The proposed values are in-line with most of the recent NO_x BACT determinations for renewable energy facilities;
- The SCR technology provides the freedom to optimize operation of the grate and furnace so that low CO, VOC and organic HAP emissions can be achieved without installation of oxidation catalyst (ox-cat as discussed below);
- The SCR technology has several co-benefits including direct reductions of PM/PM₁₀/PM_{2.5}, NH₃, VE, VOC, organic HAP including and as D/F; and
- SCR technology is cost-effective.

MWC organics as D/F BACT Analysis

Mechanism of D/F Formation and Control

D/F constitute a class of cyclic halogenated hydrocarbons with halogen atoms (such as chlorine) substituting some of the points in the ringed carbon structures normally occupied by hydrogen. Furthermore, two ringed halogenated hydrocarbons are joined to each other in such a manner that includes one or two oxygen atoms. Figure 21 includes generalized diagrams of dioxin and of furan.




Figure 21. Skeletal Diagrams of Generalized Dioxin and Furan Molecules

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

The compound 2,3,7,8 tetrachlorinated dibenzo-p-dioxin (TCDD) has chlorine atoms substituting for hydrogen atoms at the lateral positions. It is considered the most toxic congener of dioxin. In the U.S., the regulations and reporting requirements for MWC are specified as the total mass of all D/F compounds with four (tetra) through eight (octa) chloride substitutions for hydrogen.

There is an alternative quantification scheme used in other industries and internationally to the total mass known as toxic equivalent (TEQ). The congener 2,3,7,8 TCDD is assigned a weighting factor of 1.0 and its contribution is simply its mass. The contribution of each of the other congeners is multiplied by a weighting factor less than 1.0 (based on its toxicity relative to 2,3,7,8 TCDD) prior to its addition when calculating the TEQ value. This is relevant in the discussion below when comparing U.S. limits and test results with those in other countries.

The potential for D/F formation is inherently high in MWC because of the presence of aromatic hydrocarbons, chlorides, metals and fly ash. However with sufficient residence time and temperature, D/F can be almost completely destroyed. Figure 22 is a diagram showing the relative concentration of D/F remaining after exposure to varying temperatures for 0.5 and 2 seconds.⁷




Figure 22. Relative D/F Concentrations with respect to Furnace Temperature and Residence Time

⁷ Paper. Licata, A. and Hartenstein, H. Modern Technologies to Reduce Emissions of Dioxins and Furans from Waste Incineration. Proceedings of the 16th Annual North American WTE Conference. Philadelphia, May 2008.

D/F can reform from precursors (and catalyzed by fly ash and metals) in the heat recovery sections as the temperature drops. The first mechanism occurs in the range of 300-800° C and is a homogenous gas phase reaction whereby D/F formed from precursors such as polychlorinated benzenes, phenols and biphenyls.

The second mechanism is the so called *de novo* synthesis of D/F in a temperature window of 200-500° C as a heterogeneous gas-solid phase reaction on the surface of fly ash particles.

Equation 13. Inorganic chlorides such as NaCl or HCl in the presence of with catalytic active metallic chlorides like CuCl₂ or FeCl₃ will form elemental chlorine (Cl₂) in the presence of O₂ according to the Deacon reaction:



Subsequently, Cl₂ reacts with aromatic components in flue gas or carbon in the fly ash to form chlorinated organic compounds and fragments, which combine to become D/F via complicated theoretical mechanisms.



Various temperature management options (again GCP) are possible to rapidly cool (quench) the gases in order to minimize D/F formation. The FF baghouse will catch much of the D/F that adheres onto fly ash particles and the capture can be enhanced by addition of sorbents such as activated carbon (i.e. by CI).

Application of such control strategies to existing and new units since 1990 lead to the significant reduction of D/F from MWC in the U.S. as documented in Table 7. However, per Figure 17 there has been no reduction in D/F concentrations from MWC on average in the past 10 years, notwithstanding the excellent performance of the Hillsborough County WTE Unit 4.

According the 2008 paper (by Licata and Hartenstein) from which Figure 22 was taken, “*honeycomb catalysts similar to those familiar from the well known SCR DeNOx process are commonly employed for this residue free D/F control technology.*” The paper further states: “*Most Central European and Scandinavian Countries have decided to reduce their D/F emissions drastically. This led to the development and installation of extremely efficient air pollution control equipment such as activated carbon reactors and catalytic DeDiox reactors. Other countries such as the U.S. take a somewhat less stringent approach and define adsorbent injection as the BACT*”.

The analysis by Licata and Hartenstein is further buttressed by vendors such as CRI (a vendor) who states that SCR catalyst is also an effective system to reduce D/F⁸. This benefit is elsewhere corroborated in the literature as well as the destruction of VOC by SCR (though possibly not quite as efficiently as by oxidation catalyst).^{9, 10}

Equations 15 and 16. The theoretical equations for the proven oxidation of D/F on the SCR catalyst at a cement plant are shown below:



According to one publication, SCR catalyst reduced D/F emissions by approximately a factor of 100 at the IVAGO WTE plant in Ghent, Belgium. The measured D/F emissions were less than 0.050 ng

⁸ Paper. Tang, H.S. The Shell Dioxin Destruction System. Solid & Hazardous Waste Management Conference, Singapore, February 2003. www.cricatalyst.com/products/pdfs/sporeconference.pdf

⁹ E.g. Tzimas, E., and Peteves, S.D. NO_x and Dioxin Emissions from Waste Incineration Plants. Joint Research Center, European Commission. Circa 2001.

¹⁰ E.g. Leibacher, U., Bellin, C., and Linero, A. High Dust SCR Solutions. International Cement Review. December 2006. www.cementeriadimonselice.it/pdf/HD_SCR_solutions.pdf

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

total/dscm (value estimated from TEQ by the Department).¹¹ Similar experience was documented at the MVA WTE plant in Spittelau, Austria (a 20-year old installation) where D/F emissions are between roughly 0.1 to 0.3 ng total/dscm.¹²

SCR was installed at the Algonquin Power WTE facility in Ontario, Canada for the dual purpose of NO_x and D/F reduction. A paper prepared by the government and the operator states:¹³

“In evaluating the technology options, it was suggested that the operating costs for SNCR would be lower than for SCR. However, the SCR system had the potential advantage of dioxin and furan destruction. Thermal oxidation of PCDD/F in the presence of a catalyst produces water, carbon dioxide (CO₂) and HCl. Therefore, SCR was the chosen technology after the evaluation of pollution control options was complete”.

According to a report prepared for the Canadian Council of Ministers of the Environment (CCME), *“during commissioning testing (of the SCR system) in November 2001 the facility recorded three D/F emission concentration values well below the Environment Canada Level of Quantification (LOQ) of 32 picograms toxic equivalent (TEQ) per normal cubic meter at 11% oxygen (pg TEQ/Nm³) @11% O₂”.*¹⁴ This equates to 0.045 ng TEQ/Nm³ @7% O₂ and roughly 2 ng total/dscm. For reference, subsequent installation of activated carbon further reduced D/F at Algonquin by at least another order of magnitude and less than 0.2 total ng/dscm.

Applicant’s MWC Organics as D/F BACT Proposal

The SWA proposed to meet the Subpart Eb MACT limit for D/F of 13 ng total/dscm as BACT for MWC organics as D/F. SWA’s consultants advised that they are either not able to confirm the efficacy of SCR to achieve low D/F values or that their installation will be optimized for NO_x reduction and the benefits on D/F reduction cannot be estimated.

For reference, the most recent BACT determinations and proposals for D/F (the 2009 permit for the Mahoning, Ohio project and the 2010 draft permit for the Fairfield, Maryland project) are both 13 ng D/F total/dscm. Clearly the permit reviewers were not aware of the potential for further reduction by SCR catalyst or considered the MACT from Eb to be adequate for the purposes of BACT.

Department’s MWC Organics as D/F BACT Determination

In view of the foregoing discussion and the performance of the Hillsborough County WTE Unit 4 (0.26 ng D/F total/dscm without SCR), the Department believes that BACT for D/F can and should be lower than proposed by the applicant.

The Department will include an initial limit of 10 ng D/F total/dscm and will specify the inclusion SCR within the GCP/SD/FF/CI/SCR strategy as BACT for D/F rather than fix a very low limit. It is clear that a very low level will actually be achieved as evidenced by the European and Canadian experience. Also, other states and EPA regions will be able to note from the entries in the control equipment Clearinghouse (known as the RACT/BACT/LAER Clearinghouse) that BACT is the SCR technology.

The Department will include a requirement that the SWA conduct additional testing to measure the effectiveness of the SCR system in destroying D/F after startup after which the Department will set a final BACT limitation between 0.75 and 10 ng D/F total/dscm (inclusive). At a level less than 0.75 ng D/F

¹¹ Paper. IVAGO and Seghers. Seghers deInOX: Catalytic Reduction with Simultaneous Dioxin Destruction in a Municipal Waste Incinerator in Belgium. Paris NO_x Conference. 2001.

¹² Paper. Fernwaerme Wien GmbH and Integral Umwelt. Latest Developments and the State of the Art of Catalytic DeNO_x Plants after 15 years of Experience. Paris NO_x Conference. 2001.

¹³ Paper. A Case Study of the SCR System at the Algonquin Power WTE Facility. Annual NA WTE Conference. NAWTEC 16-1903. 2008. www.seas.columbia.edu/earth/wtert/sofos/nawtec/nawtec16/nawtec16-1903.pdf

¹⁴ Report. Review of Dioxins and Furans from Incineration in Support of a Canada-wide Standard Review. CCME Project #390-2007. December 15, 2006. www.ccme.ca/assets/pdf/1395_d_f_review_chandler_e.pdf

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

total/dscm PSD is avoided. If it is clear based on the tests that emissions will consistently be much less than 0.75 ng D/F total/dscm, the Department will set a non-BACT limit of 0.74 ng D/F total/dscm.

The rationale for this determination as BACT is that:

- The determination is more stringent than the requirement in Subpart Eb;
- The D/F limit is the lowest to-date in the U.S. for a MWC; and
- This is the first specification of SCR to be included as part of a D/F BACT determination in the U.S.

CO and VOC BACT Analysis

CO and VOC Discussion

Refer to the previous discussion of GCP concepts and descriptions of the grate stoker/furnace. CO and VOC (including organic HAP) are products of incomplete combustion. Initial combustion occurs on the grate and lower furnace in substoichiometric conditions. As a result, a great deal of CO is evolved as well as VOC (including hydrocarbon radicals and other species). The CO, hydrocarbon radicals and reduced nitrogen compounds (as previously mentioned) participate in reactions that assist in primary NO_x control.

Sufficient OFA, temperature and turbulence is necessary to complete the burnout of CO, fine char and VOC. Clearly, throttling NO_x formation by staging combustion using the OFA ports affects CO and VOC formation in the furnace. Basically, the manner by which the boiler is operated (e.g. favoring NO_x over CO/VOC control) is part of an overall source emission strategy that considers the emissions limits and costs of add-on controls.

This fact can be appreciated in Figure 23 from a Babcock and Wilcox (B&W) publication that demonstrates the modeled relative effects upon CO when switching to a low NO_x control strategy. Under the low NO_x strategy (newly designed air system including higher OFA ports) moderate levels of CO (and presumably VOC) persist at greater heights within the furnace compared with the previous combustion strategy.¹⁵




Figure 23. Modeled NO_x, Temperature and CO after Switching to Low NO_x strategy.

¹⁵ Dessam et al, B&W. Use of Numerical Modeling for Designing a Biomass-fired BFB Boiler Air System for Low NO_x Emissions. 2009 Power-Gen International Conference. Las Vegas. December 2009.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

According to the article, “in favor of achieving low NO_x emissions, higher CO values were accepted in the Precision Jet air system. However, these CO emissions were well within the acceptable range to meet state and federal requirements”.

Conversely, in favor of achieving low CO and VOC emissions, greater NO_x formation in the furnace will occur and can be abated by the add-on NO_x control equipment as described above. The inclusion of SCR (with or without SNCR) will make it easier to pursue such a strategy. As discussed above, SCR is effective in the reduction of MWC organic HAP as D/F and VOC in general.

If GCP are not sufficient to achieve low CO and VOC emissions, an ox-cat is an option. The preferred location of an ox-cat system is after the FF baghouse proposed for the PBREF-2 if the temperature regime is acceptable.

Refer to Figure 24. The information in the curves suggests that ox-cat is effective for CO removal at temperatures as low as 300 °F.¹⁶ Clearly this allows installation downstream of the PM device and obviates the claimed necessity of reheat. The exit stack temperature from the PBREF-2 stacks is estimated at 315 °F.




Figure 24. Ox-cat Performance vs. Temperature (°F)

Ox-cat Performance vs. Temperature (°C)

Applicant's CO and VOC BACT Proposals

The applicant proposed BACT CO emission limits of 100 ppmvd (4-hour basis and equal to the Subpart Eb MACT requirement) and 80 ppmvd (24 hour rolling average). The applicant also proposed a BACT VOC emission limit of 7 ppmvd. These limits will be achieved by GCP as discussed above.

Department's CO BACT Determination

The CO proposal is equivalent to 0.105 lb/mmBtu (4-hour) and 0.084 lb/mmBtu (24-hour basis). For reference, the new Hillsborough County WTE Unit 4 achieved 26 ppmvd of CO (~ 0.027 lb/mmBtu) which by comparison with typical grate stoker applications is excellent performance. Unit 4 relies on SNCR for NO_x control and GCP for CO (specifically the Covanta LNTM technology). The additional challenge of a lower NO_x limit is not likely to cause greater CO emissions given the use of SCR for the future PBREF-2 and flexibility for more aggressive CO GCP control measures.

The Department accepts the SWA proposal for CO from the PBREF-2 and is including the installation of SCR as part of this determination because it destroys VOC and provides for the opportunity of lower CO strategies in the furnace. The Department accepts the proposed value of 7 ppmvd as BACT for VOC but expects much lower emissions given the GCP for CO and the presence of the SCR catalyst.

Compliance will be demonstrated using the CO-CEMS required by Subpart Eb and by initial and annual tests for VOC. The overall rationale of the BACT determinations is as follows:

- The short-term CO proposal is as stringent as the requirement in Subpart Eb;
- The 24-hour CO value is an additional requirement beyond those of Subpart Eb;

¹⁶ Brochures. Sud-Chemie and Johnson-Matthey.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

- The proposed CO values are in-line with most of the recent CO BACT determinations for renewable energy facilities;
- The SCR technology for NO_x provides the freedom to optimize operation of the grate and furnace so that low CO, VOC and organic HAP emissions can be achieved without installation of ox-cat; and
- The CI prior to the FF baghouse and the SCR system directly reduce VOC.

MWC-AG BACT Analysis

Discussion

SO₂ is a PSD-pollutant by itself as well as in conjunction with HCl as MWC-AG. Emissions of SO₂ from MWC are generally low before control except when burning higher sulfur materials such as tires.

After excluding “outliers”, EPA’s consultant evaluated SO₂ data for the GCP/SD/FF/CI/SNCR configuration during the development of the 2006 Subpart Eb MACT. The mean of the data retained was 6.4 ppmvd. EPA’s consultant estimated that 95 and 99% of data are less than 17 and 22 ppmvd respectively when assuming a “normal distribution”. The 2006 Subpart Eb MACT did not change the SO₂ limit of 30 ppmvd promulgated under the 1995 Subpart Eb MACT.

In 2006 the Department set a limit of 26 ppmvd for the new Hillsborough County WTE Unit 4 project using the strategy of GCP/SD/FF/ACI/SNCR (in particular the SD/FF part). In the technical evaluation, the Department stated “that typical emissions will likely be less than 10 ppmvd”.¹⁷ In fact, per Table 8, Hillsborough County WTE Unit 4 achieved 0.56 ppmvd of SO₂ and 99% removal across the control equipment.

HCl is not a PSD pollutant except in conjunction with SO₂ as MWC-AG. Emissions of HCl from MWC are generally very high in the absence of control due to the presence in MSW of chlorinated plastics and other compounds, salts, yard waste, etc.

After excluding “outliers”, EPA’s consultant evaluated HCl data for the GCP/SD/FF/ACI/SNCR configuration during the development of the 2006 Subpart Eb MACT. The mean of the data retained was 8.5 ppmvd. EPA’s consultant estimated that 95 and 99% of data are less than 19 and 24 ppmvd respectively when assuming a “normal distribution”. The 2006 Subpart Eb MACT did not change the SO₂ limit of 25 ppmvd promulgated under the 1995 Subpart Eb MACT.

In 2006 the Department set a HCl limit of 20 ppmvd for the new Hillsborough County WTE Unit 4 project using the strategy of GCP/SD/FF/CI/SNCR (in particular the SD/FF part). In the technical evaluation, the Department stated “it is likely the sum of the two pollutants (SO₂+HCl) will actually be on the order of 15 ppmvd”. In fact, per Table 8, Hillsborough County WTE Unit 4 achieved 11.5 ppmvd of HCl and 98.2% removal across the control equipment. The sum of the two pollutants was measured at 12.1 ppmvd (SO₂+HCl).

HF is not a PSD pollutant and is a HAP. It was not specifically regulated in Subpart Eb because SO₂ and HCl were directly regulated and designated as surrogates for other AG such as HF.

Applicant’s MWC-AG BACT Proposal

The applicant proposes the same values as BACT for MWC-AG that were determined for the Hillsborough County WTE Unit 4. These are the least stringent of 26 ppmvd of SO₂ or 80% reduction and the least stringent of 20 ppmvd of HCl or 95% reduction. The technology is the GCP/SD/FF/CI/SCR arrangement (specifically the SD/FF portion).

¹⁷ Report. Technical Evaluation and Preliminary Determination. Hillsborough County WTE Unit 4. May 24, 2006. www.dep.state.fl.us/Air/emission/construction/hillsborough/369TEBACT.pdf Page 27.

Department's MWC-AG BACT Determination

It is possible to conduct a “co-incident analysis” of (SO₂ + HCl) to set a BACT for MWC-AG that is less than the sum of the individual limits for SO₂ and HCl. However, the Department has determined that the individual limits for SO₂ and for HCl proposed by the applicant are adequate as BACT for SO₂ and MWC-AG and will not include a separate limit to track as MWC-AG. Furthermore, the Department notes that the inclusion of CI within the GCP/SD/FF/CI/SCR arrangement will further reduce SO₂ although this fact is not typically highlighted.

By now, it is clear based on the results at Hillsborough Unit 4, that it is not necessary to include an alternative control efficiency standard of 80% for SO₂. Otherwise, the Department accepts the rest of the applicant's proposal of 24 ppmvd of SO₂ on a 24-hour basis as BACT for SO₂. Compliance shall be determined by the SO₂-CEMS required by Subpart Eb.

HCl is probably the pollutant governing the actual design of the SD/FF part of the control technology. Based on the results at the Hillsborough County WTE Unit 4 (11.5 ppmvd and 98.1% reduction), the Department believes that 20 ppmvd is an appropriate limit for HCl. Although the 95% alternative limit is adequate as well, it would not provide an actual limit on emissions and will not be included. Compliance will be based on the annual test required by Subpart Eb. The overall rationale of the BACT determinations is as follows:

- The requirements are more stringent than the requirement in Subpart Eb; and
- Overall, the MWC-AG emission limits are more stringent than those determined as BACT for the most recent large projects in Ohio and Maryland.

Fluoride (F) BACT Analyses

Discussion

The applicant originally estimated annual fluoride emissions of 13.6 TPY, a value that exceeds the PSD significant emission rate threshold of 3 TPY. However, the applicant actually estimated F emissions as HF, which is HAP and not a PSD-pollutant.

The Department reviewed data from the existing NCRRF from 2005 to 2009 which indicated less than 2 TPY of F (non-HF) for a 2,000 TPD refuse-derived fuel facility with ESP particulate control. The future PBREF-2 will rely on FF baghouse which will be more effective in controlling PM/PM₁₀ of which F is a constituent.

The Department also reviewed F data (non-HF) from 2001 through 2005 from the Hillsborough County WTE facility which uses FF baghouses. Most if not all of the measured values were in the “non-detect” range using the standard EPA methods. The operator reported the values in a conservative manner such that the “limit of detectability” was used to estimate emissions. Assuming fulltime operation, the sum of emissions from the three units is less than 0.4 TPY of F.

There is no fluoride-limiting standard in the recent Subpart Eb update. The Department believes that the SD/FF/CI/SCR configuration as a work practice and the emission limitations for MWC Acid gases, and PM/PM₁₀, provides reasonable assurance that the proposed PBREF-2 project will not emit 3 or more TPY of F. It is unnecessary to set a BACT based limit for this pollutant or testing requirements given the history at the NCRRF or the testing at the Hillsborough County WTE facility.

SAM BACT Analyses

SAM is formed by the oxidation of SO₂ to sulfur trioxide (SO₃), which is rapidly converted to SAM. The proposed concentration limit of 5 ppmvd for SAM appears high in view of the fact that the limit for SO₂ is 24 ppmvd. Furthermore, the recently constructed Hillsborough WTE Unit 4 achieved only 0.56 ppmvd of SO₂. It is reasonable to expect that SAM emissions will be much less than SO₂ emissions.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

There will be a small amount of additional SAM formed due to the inclusion of SCR. The Department believes that SAM emissions will not exceed 1 ppmvd and that annual emissions will be much less than the 95.2 TPY value estimated by the applicant. Furthermore, inclusion of CI within the control technology arrangement will further suppress SAM.

Rather than specifying limits for SAM, the Department believes that the GCP/SD/FF/ACI/SCR configuration (specifically the SD/FF/CI portion) is appropriate as a work practice and that the emission limitations for MWC-AG, and PM/PM₁₀, provide reasonable assurance that emissions of SAM will be controlled to BACT levels and to levels less than the PSD threshold of 7 TPY.

The Department will require initial tests to quantify SAM.

PM/PM₁₀/PM_{2.5}, MWC metals and VE BACT Analyses

Discussion

For the purposes of this descriptive discussion, PM means all PM including PM₁₀, PM_{2.5} and MWC metals. MSW is a heterogeneous fuel that contains both combustible and non-combustible fractions. Heavier residual material forms slag and bottom ash that is removed from the bottom of the furnace grate.

The PM of interest is therefore the light ash that travels with the flue exhaust gas. Such PM consists of both the products of complete combustion and incomplete combustion. Vaporized inorganic material can condense on other particles and be carried out of the furnace. Organic material can be pyrolyzed and emitted as char if insufficient time is provided to insure complete burnout.

Additionally, reagents such as the lime, NH₃ and activate carbon used in the pollution control equipment contribute to PM. Acid gases and other fine PM and VE precursors react with various species to form alkali and ammoniated chlorides, sulfates, nitrates and other such species.

MWC metals as PM is a PSD category and requires a BACT determination. PM is the measured surrogate for MWC metals and has a greater PSD threshold of 25 TPY. PM limits are often set after determining BACT for PM₁₀. Typically applicants agree to lower values than BACT for PM to avoid conducting more difficult PM₁₀ fractionation and measurement. The Department will address the two components of MWC metals separately.

Applicant's PM/PM₁₀/PM_{2.5}, MWC metals and VE BACT Proposals

The applicant proposes a single limit of 12 mg/dscm for filterable PM, PM₁₀, PM_{2.5} and MWC metals as PM. The technology is the GCP/SD/FF/ACI/SCR arrangement. The applicant proposes a VE limit of 10% opacity. All features of the arrangement are involved whether by minimizing PM formation, reacting with fine PM precursors, adsorbing certain species, directly filtering PM and catalytically destroying fine PM precursors.

Department's PM/PM₁₀/PM_{2.5}, MWC metals and VE BACT Determinations

For reference, after excluding "outliers", EPA's consultant evaluated filterable PM data for the GCP/SD/FF/CI/SNCR configuration during the development of the new Subpart Eb. The mean of the data retained was 3.2 mg PM/dscm. EPA estimated that 95 and 99% of data are less than 7.6 and 9.5 mg/dscm respectively when assuming a normal distribution. The new Hillsborough County WTE Unit 4 achieved 1 mg/dscm of filterable PM which was much less than the BACT established for that project of 12 mg/dscm.

By now it is clear that a lower filterable PM limit than proposed is readily achievable. The value for the proposed Fairfield Maryland project is 10 mg/dscm of filterable PM.¹⁸ The Department will set a limit of 10 mg/dscm and believes this provides a wide margin of safety for the proposed project. The same value will be set for PM₁₀ and MWC metals as PM.

¹⁸ Initial Licensing Conditions. Energy Answers International, Inc. – Fairfield Renewable Energy Project. PSC Case No. 9199. May 10, 2010.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

The overall rationale for the PM/PM₁₀ and MWC metals as PM limit is as follows:

- The limit of 10 mg/dscm is more stringent than the standard of 20 mg/dscm in Subpart Eb MACT; and
- The limit is as stringent as the lowest known PM/PM₁₀ and MWC metals as PM limit for a WTE unit.

No PM_{2.5} limit will be set for this project since it is not a PSD-pollutant and there is no defined PM_{2.5} SER within Department rules. Also, condensable PM/PM₁₀/PM_{2.5} limits will not be set because the Department does not yet define such species and has not yet adopted associated test methods.

The Department will establish a NH₃ limit of 10 parts per million (ppm) at 7% O₂ to minimize direct NH₃ emissions that can form PM (including filterable and condensable PM₁₀ and PM_{2.5}) as ammoniated chlorides, sulfates and nitrates in the exhaust stream and in the environment. The limit will also provide reasonable assurance of proper control equipment operation. The NH₃ emission limit will be readily controlled by the SCR system. Compliance shall be demonstrated by initial and annual tests using EPA Method CTM-027.

The Department has reviewed PM_{2.5} and believes that measures have been incorporated into the overall BACT for the project that will adequately address this pollutant even though there is not a SER for PM_{2.5}. These measures include:

- BACT emission limits for surrogate PM/PM₁₀;
- BACT emission limits and add-on controls for precursors SO₂ and NO_x that tend to form PM_{2.5} in the environment;
- The VE limit that directly controls the fraction of PM_{2.5} that interferes with light transmission; and
- Limits on NH₃ and HCl.

Pb Analyses

Discussion

Pb is a semi-volatile metal and a PSD pollutant that is released in the furnace, manifested as PM/PM₁₀/PM_{2.5} and captured in the FF baghouse. The applicant estimates Pb emissions to be 0.65 TPY for the MWC units which is slightly greater than the SER of 0.6 TPY.

Applicant's Pb BACT Proposal

The SWA proposed to meet the Subpart Eb MACT limit for Pb of 140 µg/dscm as BACT for Pb. For reference, after excluding "outliers", EPA's consultant evaluated Pb data for the GCP/SD/FF/CI/SNCR configuration during the development of the new Subpart Eb. The mean of the data retained was 11.3 µg Pb/dscm. EPA estimated that 95 and 99% of data are less than 28.5 and 35.6 µg Pb/dscm respectively when assuming a normal distribution. The new Hillsborough County WTE Unit 4 achieved 18.3 µg Pb/dscm which was much less than the MACT (non-BACT) limit established for that project of 140 µg Pb/dscm.

Department's Pb Emission Limit Determination

The Department would set a limit for BACT that is much less than 140 µg Pb/dscm MACT limit and would result in annual emissions much less than the 0.6 TPY SER or the applicants estimate of 0.65 TPY. The Department will set a limit of 125 µg Pb/dscm that is sufficient to avoid PSD and with the expectation that actual emissions will be much less than the established Subpart Eb MACT limit for Pb.

The control strategy of GCP/SD/FF/CI/SCR (specifically the SD/FF/CI components) will provide reasonable assurance that the limit will be achieved. The initial stack test requirements are sufficient for the purposes of compliance. Annual tests will be required thereafter.

Cd Analyses

Discussion

Cd is a semi-volatile metal but is not a PSD pollutant. It is released in the furnace, manifested as PM/PM₁₀/PM_{2.5} and captured in the FF baghouse.

Applicant’s Cd Proposal

The SWA proposes to meet the Subpart Eb MACT limit for Cd of 10 µg/dscm. For reference, after excluding “outliers”, EPA’s consultant evaluated Cd data for the GCP/SD/FF/CI/SNCR configuration during the development of the new Subpart Eb. The mean of the data retained was 0.77 µg Pb/dscm. EPA estimated that 95 and 99% of data are less than 1.75 and 2.16 µg Cd/dscm respectively when assuming a normal distribution. The new Hillsborough County WTE Unit 4 achieved 0.2 µg Cd/dscm which was much less than the MACT (non-BACT) limit established for that project of 10 µg Cd/dscm.

Department’s Cd Emission Limit Determination

The Department will set a limit of 10 µg Cb/dscm with the expectation that actual emissions will be much less than the established Subpart Eb MACT limit for Cd.

The control strategy of GCP/SD/FF/CI/SCR (specifically the SD/FF/CI components) will provide reasonable assurance that the limit will be achieved. The initial stack test requirements are sufficient for the purposes of compliance. Annual tests will be required thereafter.

Hg Analysis

Discussion

Hg is a volatile metal and a PSD pollutant that is released in the furnace, manifested as PM/PM₁₀/PM_{2.5} and captured in the FF baghouse. The applicant estimates that Hg emissions will be approximately 0.056 TPY or 113 lb/yr which is less than the applicable SER of 0.1 TPY (200 lb/yr).

Refer back to Figure 16. Average emissions of Hg from large MWC in the U.S. have been reduced from approximately 15 µg/dscm in 1999 (by which time most MWC in the U.S. had been upgraded to comply with the original Subpart Eb) to 6 µg/dscm. This downward trend is likely from the addition of CI at some facilities where it had not been previously installed and by the modernization of others.

After excluding “outliers” EPA’s consultant evaluated Hg data for the SD/FF/CI/SNCR configuration in 2005 during the development of the new Subpart Eb. The mean of the data retained was 8 µg/dscm consistent with Figure 16. EPA’s consultant estimated that 95 and 99% of data are less than 22 and 27 µg Hg/dscm respectively when assuming a “normal distribution”.

Table 9 is a summary of the average emissions from a group of MWC in Florida representative of much of the installed capacity. The new Hillsborough County WTE Unit 4 achieved 1.5 µg Hg/dscm and 97.8% reduction which was superior to the limit established for that project of 28 µg Hg/dscm or 85% reduction.

Table 9 – Average of Hg Emissions Concentrations from MWC in Florida 1999 – 2010 (µg/dscm) ¹

Year	2007	2008	2009	2010
Average Emissions	12.34	9.69	6.17	5.41
1. Facilities included in the emission calculations are Broward County South, Bay County, Pasco County, Lee County, Lake County, Hillsborough County, and Tampa McKay Bay				

Applicant's Hg Proposal

The SWA proposes to meet a value of 25 µg/dscm which is half of the Subpart Eb MACT limit for Hg of 50 µg/dscm. However, 25 µg/dscm would actually trigger PSD and require a BACT determination because it equates to approximately 233 lb/yr. The SWA requested the option of 85% reduction if emissions are greater than 25 µg/dscm. This would further increase the annual emissions and make an annual limit difficult to enforce.

The SWA also proposes an annual limit of 113 lb/yr to be determined based on four stack tests per year, which would require that the average stack test result be much less than 25 µg/dscm. Finally, the SWA proposes to install and eventually rely upon Hg-CEMS to insure compliance with an annualized limit of 12 µg/dscm on a 12-month rolling basis.

Department's Hg Emission Limit Determination

The Department accepts the proposal by the SWA to comply with a limit of 25 µg Hg/dscm demonstrated by stack test. This value is less than the 50 µg Hg/dscm limitation per the Subpart Eb MACT. Quarterly testing is required for each flue stream. The Department also accepts the proposal by the SWA to limit annual emissions to 113 lb Hg/yr, which is less than the SER for Hg. This value is equivalent to 12 µg Hg/dscm.

To insure compliance with the annual limit such that the SER is not triggered, the Department will incorporate a requirement to conduct four tests per year per flue for the 25 µg Hg/dscm and 113 lb/yr based upon Hg-CEMS for compliance as described in the draft permit. During the first 12 months of testing, and emission factors shall be established for pounds of mercury per million tons of steam (lb-Hg/MTS) to account for missing data if and when the CEMS is not operational. The CEMS data shall have 80% availability in the first year and 85% every year thereafter.

3.3. BACT Review for Storage Silos (EU 027, 28, 29, 30)

Lime and carbon will be used in the air pollution control systems for the MWC and stored at the facility in three lime silos and one carbon silo. The lime will be utilized in the control of SO₂ emissions (spray dryer absorber) and the carbon will be used to control mercury emissions. The silos will be filled on an intermittent basis and PM emissions will be limited to the periods when the silos are being filled. Each silo will be equipped with a fabric filter system mounted on the roof of the silo to control PM emissions. The fabric filter system will be designed to discharge collected dust back into the silos. Emissions are estimated to be very low (less than 0.05 tons per year) due to the operation of the fabric filter system and limited number of filling events.

3.4. BACT Review for Emergency Equipment (EU 031, 32, 33)

Emergency Support Equipment

The proposed plant will also require:

- One 250 kW emergency electrical generator (or smaller); and
- Two 250 hp emergency fire water pumps (or smaller).

3.5. Applicable Standards under 40 CFR 60 and 63

The applicable standards pursuant to 40 CFR 60 and 63 were identified above and are summarized in the following three tables for the MWC units, the emergency generator and the emergency fire pump engines. By meeting the requirements of NSPS Subpart IIII, the requirements of NESHAP Subpart ZZZZ which is applicable to reciprocating internal combustion engines (RICE) are fulfilled.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Table 10 - NSPS Applicable to the Emergency Generator (40 CFR 60, Subpart IIII)

Emergency Generator (225 kW ≤ and < 450 kW)	CO (g/kW-hr) ¹	PM (g/kW-hr)	SO₂² (% S)	NMHC³+NO_x (g/kW-hr)
Subpart IIII (2007 and later)	3.5	0.20	0.0015	4.0
1. g/kW-hr means grams per kilowatt-hour. 2. SO ₂ emission standard will be met by using ULSD fuel oil in the emergency generator with fuel sulfur (S) content of 0.0015% by weight. 3. NMHC means Non-Methane Hydrocarbons.				

Table 11 - NSPS Applicable to the Emergency Fire Pump Engine (40 CFR 60, Subpart IIII)

Emergency Pump (175 ≤ hp and < 300 hp)	CO (g/hp-hr) ¹	PM (g/hp-hr)	SO₂² (% S)	NMHC+NO_x (g/hp-hr)
Subpart IIII (2009 and later)	2.6	0.15	0.0015	3.0
1. g/hp-hr means grams per horsepower-hour. 2. SO ₂ emission standard will be met by using ULSD fuel oil in the emergency fire pump engine with a fuel sulfur content of 0.0015% by weight. 3. NMHC means Non-Methane Hydrocarbons.				

The Department is adopting the requirements of 40 CFR 60, Subpart IIII as the minimum requirements emission standards for the emergency generator and emergency fire pumps. Each unit will be limited to 100 hours of operation annually for testing and maintenance. Subpart IIII will be considered BACT for each unit, and the manufacturer’s certification will meet or exceed the requirements of Subpart IIII.

3.6. BACT Review for the Ash Handling System and Building (EU 034)

The collected ash will be transferred from the boiler and the air pollution control buildings to the ash management building via enclosed conveyor. The collected ash will be combined and quenched with water. The ash management building will contain ash processing equipment including ferrous and non-ferrous recovery systems. Since the ash will be wetted to a moisture content level in the approximate range of 20 to 25 percent, fugitive particulate matter emissions for the ash handling building are expected to be negligible.

To further minimize PM emissions from the ash management building ventilation air will be routed to a fabric filter control device prior to discharge to the atmosphere. These emissions will also be expected to be minimal due to moisture content. The residual ash will be transferred from the ash management building in covered, leak resistant vehicles for disposal at the onsite landfill. All loading and preparation for ash transport will occur within the enclosed ash management building. Because the ash is moist, dust will not be generated during transportation and disposal.

4. AMBIENT AIR QUALITY

4.1. Introduction

Table 4 above lists the PSD-pollutants which according to the applicant will be emitted in excess of their respective SER. Of those pollutants, only the following have associated Florida ambient air quality standards (AAQS): SO₂, PM₁₀, (the inhalable component of PM) nitrogen dioxide (NO₂ – a component of NO_x), O₃ (formed by its precursors – VOC and NO_x) and Pb. Except for Pb (which will be limited to less than its respective SER) these pollutants require an ambient air impact analyses.

4.2. Major Stationary Sources in Palm Beach County

Tables 12 through 16 list the largest sources of the pollutants in PBC per annual operating reports (AOR) filed with the Department. The pollutants listed are those most directly related to the criteria pollutants for which there are AAQS. The summaries include the future contributions of the PBREF-2. The maximum expected future emissions in TPY from the proposed project expansion are also shown for comparison. The locations of the key facilities are shown in Figures 25 and 26.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Table 12. Major Sources of NO_x in Palm Beach County (2009)

Owner	Site Name	TPY
SWA of PBC	NCRRF (i.e. the existing facility)	1,330
New Hope Power Partnership (NHPP)	Okeelanta Cogeneration (CoGen)	801
Sugar Cane Growers Co-Op (SCGC)	SCGC	475
SWA of PBC	PBREF-2 (proposed)	402
Osceola Farms	Osceola Farms	364
Florida Power & Light (FP&L)	West County Energy Center (WCEC)	170
United Technologies Corp.	Pratt & Whitney Aircraft	155
FP&L	Riviera Power Plant	100

Table 13. Largest Sources of SO₂ in Palm Beach County (2009)

Owner	Site Name	TPY
FP&L	Riviera Power Plant	445
SCGC	SCGC	441
SWA of PBC	PBREF-2 (proposed)	299
SWA of PBC	NCRRF	252
NHPP	Okeelanta CoGeneration	202
PBC Water Utilities Department (WUD)	PBC S. Region Water Reclamation (SRWR)	108
Osceola Farms	Osceola Farms	28

Table 14. Largest Sources of PM₁₀ in Palm Beach County (2009)

Owner	Site Name	TPY
Osceola Farms	Osceola Farms	245
SCGC	SCGC	218
FP&L	WCEC	98
NHPP	Okeelanta CoGen	85
SWA of PBC	NCRRF	79
SWA of PBC	PBREF-2 (proposed)	56

Table 15. Largest Sources of CO in Palm Beach County (2009)

<u>Owner</u>	<u>Site Name</u>	TPY
Osceola Farms	Osceola Farms	9,926
SCGC	SCGC	9,533
NHPP	Okeelanta CoGen	1,598
SWA of PBC	NCRRF	786
SWA of PBC	PBREF-2 (proposed)	435
FP&L	WCEC	24
FP&L	Riviera Power Plant	14

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Table 16. Largest Sources of VOC in Palm Beach County (2009)

Owner	Site Name	TPY
Osceola Farms	Osceola Farms	574
Sugar Cane Growers Co-Op	Sugar Cane Growers Co-Op	414
SWA of PBC	PBREF-2 (proposed)	60
NHPP	Okeelanta CoGen	52
PBC WUD	PBC SRWR	36
SWA of PBC	NCRRF	23
FP&L	WCEC	11



Figure 25 – SWA Site including PBREF-2




Figure 26 – Major Stationary Sources in PBC




Figure 27 – Air Monitoring Network




Figure 28. Monitors in Palm Beach County

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

4.3. Air Quality and Monitoring in the Palm Beach County

The State ambient air monitoring network operated by the Department and its partners (local air pollution control programs) includes monitors in counties containing over 90% of the population. As Figure 27 above indicates, the ambient air monitoring sites are concentrated in areas of high population density, along the coasts and near major highways in the interior portion of the state. The Florida Sugar Cane League (FSCL) operates SO₂ and O₃ instruments in Belle Glade, Palm Beach County. The Palm Beach County Public Health Unit operates six monitoring sites for the measurement of SO₂, NO₂, PM₁₀, PM_{2.5} and ozone as shown in Figure 28.

These monitors are used to estimate the existing air quality in the area of the proposed facility. The monitors in Palm Beach and Royal Palm Beach are nearest and most representative of the proposed site. Air quality measurements from these monitors are summarized in Table 17 and compared with the applicable Department as well as National AAQS.

Table 17- Ambient Air Quality Measurements Nearest to the Project Site (2006-2009)

Pollutant	Location (Site Number)	Averaging Period	Ambient Concentration			
			Compliance Period	Value	Standard	Units ^a
PM ₁₀	Belle Glade (0990008)	24-hour ^b	2008	49	150	µg/m ³
		Annual ^c	2008	18.9	50	µg/m ³
PM _{2.5}	Royal Palm Beach (0990009)	24-hour ^d	2007-2009	15	35	µg/m ³
		Annual ^e	2007-2009	6.3	15	µg/m ³
SO ₂	FSCL Belle Glade (0992101)	1-hour ⁱ	2009	3	75	ppb
		3-hour ^f	2009	5.5	1300	µg/m ³
		24-hour ^f	2009	5.5	260	µg/m ³
		Annual ^c	2007-2009	2.6	60	µg/m ³
NO ₂	Palm Beach (0991004)	Annual ^c	2006-2008	8	53	ppb
		1-hour ^h	2006-2008	41	100	ppb
CO	West Palm Bch. Lantana (0991004)	1-hour ^f	2007	2	35	ppm
		8-hour ^f	2009	1	9	ppm
Ozone	Royal Palm Beach (0990009)	8-hour ^g	2009	0.065	0.075	ppm

- a. Units are in: micrograms per cubic meter (µg/m³); parts per billion (ppb); or parts per million (ppm).
- b. Not to be exceeded on more than an average of one day per year over a three-year period.
- c. Arithmetic mean.
- d. Three year average of the 98th percentile of maximum daily 24-hour concentrations with exceptional events excluded (as approved by EPA).
- e. Three year average of the arithmetic annual means with exceptional events excluded (per EPA).
- f. Not to be exceeded more than once per year.
- g. Three year average of the annual 4th highest daily 8-hour maximum.
- h. Three-year average of the annual 98th percentile maximum daily 1-hour value (design value).
- i. Three-year average of the annual 99th percentile maximum daily 1-hour value.

4.4. Existing Ambient Air Quality – PM_{2.5} and Ozone

O₃ is a key indicator of the overall state of regional air quality. It is not emitted directly from combustion processes. Rather it is formed from VOC and NO_x emitted primarily from regional industrial and transportation sources. VOC is also emitted from fires and vegetation (e.g. isoprene). These two precursors participate in photochemical reactions that occur on an area-wide basis and are highly dependent on meteorological factors.

O₃ limits and measurements are summarized on three year blocks, rolled annually. The reported ozone value was calculated by taking the maximum 8-hour readings recorded each day during the three years. The fourth highest of the recorded maxima were identified for each year and then the average of those three values was reported as the compliance value. These values are shown for each county in Figure 29.

PM_{2.5} (also known as PM_{fine}) is another key indicator of the overall state of regional air quality. The Department is in the process of adopting the AAQS and SER for this pollutant (but had not yet completed the process by the time this technical evaluation was prepared). Some PM_{2.5} is directly emitted as a product of combustion from transportation and industrial sources as well as fires. Much of it consists of particulate nitrates and sulfates formed through chemical reactions between gaseous precursors such as SO₂ and NO_x from combustion sources and NH₃ naturally present in the air or added by other industrial sources.




Figure 29 – Florida Ozone Compliance Values

Figure 30 – Florida PM_{2.5} Compliance Values

Federal PM_{2.5} limits and ambient measurements are summarized on three year blocks, rolled annually. The reported 24-hour compliance value for PM_{2.5} is 15 µg/m³, shown in Figure 30 for the Royal Palm Beach site, and was calculated by taking the average 24-hour readings recorded each day during the three years (2007-2009). The value for each year that exceeds 98% of all daily measurements within each given year was identified and then the average of those three numbers was reported as the 24-hour compliance value and compared with the standard of 35 µg/m³.

4.5. PM_{2.5} and O₃ Precursor Emissions from Power Plants in the Southeastern U.S.

There is a regional effort underway through the CAIR and other regulatory programs to reduce emissions of PM_{2.5} precursors including NO_x (also an O₃ precursor) and SO₂. Power plant VOC emissions are not as significant as NO_x as a precursor of O₃. Regional SO₂ emission reductions from existing power plants between 2007 and 2009 are listed in Table 18. SO₂ emissions from power plants in Florida were reduced by nearly 120,000 TPY and regional SO₂ emissions were reduced by over 1.25 million TPY.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Table 18 - SO₂ Emission Reductions from Power Plants in the Southeast between 2007 and 2009

State	2007 (TPY)	2009 (TPY)	Reduction (TPY)	Reduction (%)
Alabama	447,189	277,971	169,218	38
Florida	317,582	197,682	119,900	38
Georgia	635,484	262,258	373,226	59
Kentucky	379,837	252,001	127,836	34
Mississippi	69,796	40,160	29,636	43
North Carolina	370,826	110,948	259,878	70
South Carolina	172,726	97,940	74,786	43
Tennessee	237,231	108,042	129,189	12
Total	2,630,671	1,347,002	1,283,669	49

The simple average of all PM_{2.5} measurements within each three years (2007-2009) was also calculated and then the mean of the three averages (6.3 µg/m³) was reported as the annual compliance value and compared with the standard of 15 µg/m³. The results indicate that PBC is in attainment with the applicable O₃ and national PM_{2.5} AAQS.

The state and regional SO₂ reduction trends will continue as coal-fueled power plants continue to install scrubbers to control SO₂ emissions. Regional NO_x emission reductions from existing power plants between 2007 and 2009 are listed in Table 19.

Table 19 - NO_x Emission Reductions from Power Plants in the Southeast between 2007 and 2009

State	2007 (TPY)	2009 (TPY)	Reduction (TPY)	Reduction (%)
Alabama	122,374	49,610	72,764	59
Florida	184,171	84,252	99,919	54
Georgia	107,471	57,566	49,905	46
Kentucky	174,840	78,767	96,073	55
Mississippi	48,546	26,601	21,945	45
North Carolina	59,417	38,782	20,635	35
South Carolina	46,062	21,213	24,849	54
Tennessee	102,886	27,911	74,975	73
Total	845,767	384,702	461,065	55

In just two years, NO_x emissions from power plants in Florida were reduced by nearly 100,000 TPY and regional NO_x emissions were reduced by over 460,000 TPY. The state and regional NO_x reduction trends will continue as coal-fueled power plant operators throughout the southeastern states continue to install SCR systems to control NO_x.

4.6. SO₂ and NO_x Emission Trends from FPL Peninsular Facilities

FP&L facilities are among the largest sources of SO₂ and NO_x (precursors of PM_{2.5} and/or O₃) nearest to the proposed PBREF-2 site. To put emissions from the existing FP&L facilities and the future PBREF-2 into another perspective, the Department graphed the SO₂ and NO_x emission trends during the period 1998-2009 from FPL fossil-fueled plants located in the Florida peninsula. Most of the plants are in South Florida. The data source is the EPA Clean Markets Acid Rain database. The results are summarized in Figure 31.




Figure 31 – SO₂ and NO_x reductions in TPY at FPL Peninsular Facilities (1998-2009)

During the period 1998-2009 there was a *decrease* from 221,400 to 24,700 TPY (89%) in SO₂ emissions from the FP&L fossil fueled plants in peninsular Florida. Similarly, there was a *decrease* from 98,500 to 20,500 TPY (79%) in NO_x emissions. For comparison purposes, the future PBREF-2 expansion will emit 299 TPY of SO₂ and 402 TPY of NO_x.

The contribution of 299 TPY of SO₂ and 402 TPY of NO_x from the PBREF2 will not affect the general, overwhelming and continuing downward trends in PM_{2.5} and O₃ precursors. Similarly, it will not have an appreciable effect on local or regional PM_{2.5} and O₃ concentrations.

4.7. Ambient PM_{2.5} Trends in South Florida

The overall reduction in PM_{2.5} precursor emissions from stationary sources and the transportation sources (due to use of cleaner fuels) has contributed to the clear decline in ambient PM_{2.5} levels in South Florida during the same period as shown in Figure 32.




Figure 32 - South Florida Annual Average PM_{2.5} Trends in µg/m³ (1999 – 2009)

Basically the pronounced reductions in Miami are consistent with the above mentioned reductions in emissions from stationary and transportation sources. By and large, the values in Belle Glade (within the rural sugar cane growing area) have been the lowest. However, they have been more resistant to further declines most likely due to the nature of the sugar industry which is based on periodic burning followed by harvesting of sugar cane.

4.8. Air Quality Impact Analysis

Significant Impact Analysis

The first step in conducting an air quality impact analysis is to determine whether the emissions from the source of interest can contribute significantly to ground level concentrations of the given pollutant(s) of interest. Rule 62-210.200(275), F.A.C. defines “significant impact” as an impact of emissions on ambient air quality in excess of any of pollutant-specific concentration values listed therein. The levels are known as the significant impact levels (SIL) and are defined for SO₂ (3 and 24-hr), NO₂ (annual), PM₁₀ (24-hr and annual), CO (1 and 8-hr) and Pb (quarterly). Separate SIL are defined for Class I areas such as the Everglades National Park (ENP) and Class II areas; basically all other areas in the proximity of the project.

A significant impact analysis (SIA) is performed on each of these pollutants and associated averaging times (except for Pb in the case of the present project) to determine if the project can cause an increase in ground level concentration greater than the respective SIL for each pollutant.

The EPA-approved AERMOD modeling system was used by the applicant to address the significant impact on the PSD Class II area.

Although the Department has not yet adopted SER, AAQS or SIL for PM_{2.5}, the applicant modeled PM_{2.5} with respect to the federal maximum 24-hour and annual impacts as discussed further below. In conducting this analysis, the applicant conservatively assumed that all PM₁₀ is actually PM_{2.5}, and scaled the SIL for PM₁₀ in proportion to the ratio of the respective NAAQS to develop SIL applicable to PM_{2.5}. The rationale for the SIL used for PM_{2.5} is as follows:

- The promulgated annual SIL for PM₁₀ is 2.0% of the corresponding state/national AAQS;
- The project-specific annual SIL for PM_{2.5} is also 2.0% of the corresponding NAAQS;
- The promulgated 24-hour SIL for PM₁₀ is 3.3% of the state/national AAQS; and
- The project-specific SIL for PM_{2.5} is also 3.3% of the NAAQS.

The applicant believes this approach encompasses all meaningful PM_{2.5} sources capable of interacting with PBREF-2 for the purposes of determining impacts with respect to the 24-hour and annual PM_{2.5} NAAQS.

Although the Department has not yet adopted the NAAQS for 1-hour NO₂ and SO₂, the applicant modeled both parameters. To conduct that modeling applicant proposed project-specific SIL equal to 4% of the respective NAAQS for these two pollutants based on the fact that the 4% SIL is more conservative (less than) the 5% SIL applicable to the only other pollutant (CO) that has a 1-hour averaging time (Rule 62-204.200(29), F.A.C.).

In addition, for the 1-hour NO₂ multisource analysis:

- The applicant evaluated all facilities within 70 km of PBREF-2;
- The applicant included all sources (regardless of size) within the significant impact distance (SID) (2.7 km) of PBREF-2; and
- The applicant included all facilities greater than 500 TPY within 52.7 km of PBREF-2 (SID plus 50 km)

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

The applicant believes this approach encompasses all meaningful SO₂ and NO_x sources capable of interacting with PBREF-2 for the purposes of determining impacts with respect to the 1-hour SO₂ and NO₂ NAAQS.

In addition to the Class II SIL, the applicant conducted a modeling analysis for nearby Class I areas. Class I SIL have been proposed by EPA for SO₂, NO₂, and PM₁₀, and most recently promulgated for PM_{2.5}. In order to conduct a significant impact analysis, the applicant uses the proposed project's emissions at worst load conditions as inputs to the models. The models used in this analysis and any required subsequent modeling analyses are described below. The highest predicted short-term concentrations and highest predicted annual averages predicted by this modeling are compared to the appropriate SIL for the PSD Class I Everglades National Park (ENP) and the PSD Class II Area (everywhere except the ENP). Further, the Class II area analysis also includes a separate analysis for the Biscayne National Park (BNP).

For the Class II analysis, a combination of fence line, near-field and far-field receptors were chosen for predicting maximum concentrations in the vicinity of the project. The fence line receptors consisted of discrete Cartesian receptors spaced at 50-meter intervals around the facility fence line. The remaining receptor grid consisted of densely spaced Cartesian receptors at 100 meters apart extending to 3 kilometers. From 3 to 10 kilometers, Cartesian receptors with a spacing of 500 meters were used from the facility, followed by a coarser, 1000 meter spaced grid from 10 kilometers out to 30 kilometers.

Because the public will have limited access within the fence lines of both the existing PBREP and the proposed facility, (for example, at drop off areas and at visitor centers), grid receptors within the fence line were also included in the model.

If this modeling at worst-load conditions shows ground-level increases less than the SIL, the applicant is exempted from conducting any further modeling. If the modeled concentrations from the project equal or exceed the SIL for a pollutant, then additional modeling including emissions from all major facilities or projects in the region (multi-source modeling) is required to determine the proposed project's impacts compared to the AAQS and PSD increments.

The nearest PSD Class I area is the Everglades National Park (ENP) located about 118 km to the south of the project site. Maximum air quality impacts from the proposed project are summarized in the Table 21. The results of the initial PM/PM₁₀, NO₂ and SO₂ air quality impact analyses for this project indicated that maximum predicted impacts from SO₂, PM₁₀, and NO₂ are less than the applicable SIL for the Class I area. Therefore, no further detailed modeling efforts are required for these pollutants.

The results of applicant's SO₂, PM₁₀, NO₂, and CO air quality Class II significant impact analysis for this project are shown below in Table 20. The applicant used Tier 2 75% NO_x to NO₂ ambient ratio method (ARM) conversion for the 1-hour NO₂ modeling analysis. Maximum predicted impacts are greater than the applicable SIL for the Class II area for 1-hour NO₂ averaging times. Consequently, a full AAQS of NO₂ in which the PSD Increment analysis considering all sources of this pollutant in the area is required.

Preconstruction Ambient Monitoring Requirements

PSD regulations require up to one year of continuous ambient air monitoring prior to construction of any new PSD source. A preconstruction monitoring analysis is performed for those pollutants with listed de minimis impact levels. These are levels, which, if exceeded, would require pre-construction ambient monitoring. However, the regulations allow an exemption from this requirement for those sources whose air quality impacts fall below de minimis levels and where representative ambient monitoring data is available. For this analysis, AERMOD was used to identify if potential emissions from the site exceed de minimis levels using worst load conditions as inputs to the model. As shown in Table 22, all maximum predicted impact levels for PSD sources were below de minimis impact levels.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Table 20 - Maximum Predicted Air Quality Impacts from Palm Beach County Facility Renewable Energy Facility No. 2 for Comparison to the PSD Class II SIL

Pollutant	Averaging Time	Max Predicted Impact ($\mu\text{g}/\text{m}^3$)	Significant Impact Level ($\mu\text{g}/\text{m}^3$)	Ambient Air Standards ($\mu\text{g}/\text{m}^3$)	Significant Impact?
SO ₂	Annual	0.35	1	60	NO
	24-hour	3.61	5	260	NO
	3-hour	7.21	25	1300	NO
	1-hour	7.73	7.8 ^a	195	NO
PM _{10 (2.5)}	Annual	0.065	1 (0.3)	50 (15)	NO
	24-hour	0.68	5 (1.16)	150 (35)	NO
NO ₂ ^b	Annual	0.88	1	100	NO
	1-hour	8.67	7.6 ^a	189	YES
CO	1-hour	14.81	2,000	40,000	NO
	8-hour	12.04	500	10,000	NO

- a. Applicant's proposed SIL for this project.
 b. The annual NO₂ predicted impacts are based on the use of SNCR as a control technology. The proposed facility now incorporates SCR to control the NO_x emissions, and therefore, the predicted annual impacts are expected to be lower. The 1-hour NO₂ impacts incorporates the switch to SCR. Assumes 75% conversion of NO_x to NO₂, i.e., tier 2 modeling approach for the 1 hour average.

Table 21 - Maximum Predicted Air Quality Impacts from the Palm Beach County Renewable-Energy Facility No. 2 for Comparison to the PSD Class I SIL at ENP^a

Pollutant	Averaging Time	Max. Predicted Impact at Class I Area ($\mu\text{g}/\text{m}^3$)	Class I Significant Impact Level ($\mu\text{g}/\text{m}^3$)	Significant Impact?
PM _{10 (2.5)}	Annual	0.0007	0.2 (0.06)	NO
	24-hour	0.018	0.3 (0.07)	NO
NO ₂	Annual	0.0079	0.1	NO
SO ₂	Annual	0.0031	0.1	NO
	24-hour	0.091	0.2	NO
	3-hour	0.246	1	NO

- a. Using originally proposed emissions (since reduced) from the SNCR control technology scenario.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Table 22. - Maximum Air Quality Impacts for Comparison to the De Minimis Concentration Levels

Pollutant	Averaging Time	Max Predicted Impact ($\mu\text{g}/\text{m}^3$)	De Minimis Level ($\mu\text{g}/\text{m}^3$)	Impact Greater Than De Minimis?
NO ₂	Annual	0.88	14	NO
SO ₂	24-hour	3.6	13	NO
PM ₁₀	24-hour	0.68	10	NO
CO	8-hour	12.0	575	NO
Lead	3-month	0.009	0.1	NO
Fluorides	24-hour	0.06	0.25	NO

Based on the preceding discussions, the only additional detailed air quality analyses required by the PSD regulations for this project are the following:

- A preliminary analysis to determine if facility emissions will result in a significant impact on ambient air quality.
- A full impact, or multisource analysis of any pollutants that will result in a significant impact, including modeling emissions from the proposed source, other existing facilities, and the emissions due to the planned growth that accompanies the new source.
- An analysis of impacts on soils, vegetation, visibility, and of growth-related air quality modeling impacts.

Models and Meteorological Data Used in the Foregoing Air Quality Analysis

PSD Class II Area: The AERMOD modeling system was used to evaluate the pollutant emissions from the proposed project in the surrounding Class II Area. AERMOD was approved by the EPA in November 2005. The AERMOD modeling system incorporates air dispersion based on planetary boundary layer turbulence structure and scaling concepts, including the treatment of both surface and elevated sources, and both simple and complex terrain. AERMOD contains two input data processors, AERMET and AERMAP. AERMAP is the terrain processor and AERMET is the meteorological data processor.

A series of specific model features, recommended by the EPA, are referred to as the regulatory options. The applicant used the EPA recommended regulatory options. Direction specific downwash parameters were used for all sources for which downwash was considered. The stacks associated with this project all satisfied the good engineering practice (GEP) stack height criteria.

The AERMOD-ready meteorological data used for this analysis consisted of a concurrent 5-year period of hourly surface weather observations from the National Weather Service at the Palm Beach International Airport and upper air data from Florida International University, Miami. The 5-year period of meteorological data was from 2001 through 2005. The nearest National Weather Service (NWS) station at the Palm Beach International Airport is approximately 6.9 miles southeast of the site.

In reviewing this permit application, the Department has determined that the application complies with the applicable provisions of the stack height regulations as revised by EPA on July 8, 1985 (50 FR 27892). Portions of the regulations have been remanded by a panel of the U.S. Court of Appeals for the D.C. Circuit in NRDC v. Thomas, 838 F. 2d 1224 (D.C. Cir. 1988). Consequently, this permit may be subject to modification should EPA revise the regulation in response to the court decision. This may

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

result in revised emission limitations or may affect other actions taken by the source owners or operators. A more detailed discussion of the required analyses follows.

PSD Class I Area: The California Puff (CALPUFF) dispersion model was used to evaluate the pollutant emissions from the proposed project in the Class I ENP beyond 50 km from the proposed project. Meteorological MM4 and MM5 data used in this model was from 2001 to 2003.

CALPUFF is a non-steady state, Lagrangian, long-range transport model that incorporates Gaussian puff dispersion algorithms. This model determines ground-level concentrations of inert gases or small particles emitted into the atmosphere by point, line, area, and volume sources.

The CALPUFF model has the capability to treat time-varying sources, is suitable for modeling domains from tens of meters to hundreds of kilometers, and has mechanisms to handle rough or complex terrain situations. Finally, the CALPUFF model is applicable for inert pollutants as well as pollutants that are subject to linear removal and chemical conversion mechanism.

Multi-source PSD Class II Increment Analysis

The PSD increment represents the amount that new sources in an area may increase ambient ground level concentrations of a pollutant from a baseline concentration. Since the predicted impacts were below the SIL for all NAAQS with increments, a PSD increment analysis was not required for NO₂, SO₂ and PM₁₀, but have also been included by the applicant for informational purposes. The maximum predicted annual and maximum predicted high, second high short-term average PSD Class II area impacts from this project are shown in Table 23 below.

Table 23 - PSD Class II Increment Analysis

Pollutant	Averaging Time	Max Predicted Impact (µg/m ³)	Allowable Increment (µg/m ³)	Impact Greater Than Allowable Increment?
NO ₂	Annual	0.88	25	NO
SO ₂	Annual	0.34	20	NO
	24-hour	3.1	91	NO
	3-hour	6.8	512	NO
PM ₁₀	Annual	0.06	17	NO
	24-hour	0.59	30	NO

Note: These results are based on the highest, second-high annual values over the five modeling years for the 3-hour and 24-hour SO₂ and PM₁₀ averaging periods. The annual averages are based on the maximum of the five years for NO₂, SO₂ and PM₁₀.

AAQS Analysis

For pollutants subject to an AAQS review, the total impact on ambient air quality is obtained by adding a "background" concentration to the modeled concentration based on the averaging time for the standard. This "background" concentration is based on existing monitoring data for each pollutant and representative of the area of the proposed source. This background is intended to account for sources of a particular pollutant that are not explicitly modeled. Since no attempt is typically made to subtract out the impacts due to the explicitly modeled sources on these monitored values, there is some amount of double-counting reflected in the total concentration (modeled + background) used to compare with the appropriate AAQS.

The sources that are explicitly modeled include the subject facility and nearby sources that are judged to potentially have a significant interaction with the proposed facility. The appropriate calculations for the modeled and background values are different for each pollutant, but generally follow the form for

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

compliance with the AAQS. Table 24 shows the results of this analysis. The metrics used for the modeled impacts and the background concentrations are provided in the footnotes. As shown in this table, emissions from the proposed facility are not expected to cause or contribute to a violation of an AAQS.

Table 24 - Ambient Air Quality Impacts

Pollutant	Averaging Time	Major Sources Impact (µg/m ³)	Background Conc. (µg/m ³)	Total Impact (µg/m ³)	Total Impact Greater Than AAQS?	Florida AAQS (µg/m ³)
NO ₂	1-hour	32.4 ^a	108	140.4	NO	189
	Annual	0.88	18	18.9	NO	100
SO ₂	Annual	0.34	4	4.3	NO	60
	24-hour	3.1	5.5	8.6	NO	260
	3-hour	6.8	5.5	12.3	NO	1300
PM ₁₀	Annual	0.06	18.9	19.0	NO	50
	24-hour	0.45	49	49.5	NO	150
PM _{2.5}	Annual	0.06	6.3	6.4	NO	15
	24-hour	0.68	15	15.7	NO	35
CO	8-hour	9.2	2061	2070	NO	10,000
	1-hour	14.4	3206	3220	NO	40,000
Lead	Quarterly	0.009	0.01	0.019	NO	1.5
	3-month rolling	0.009	0.01	0.019	NO	0.15

a. Assumes 75% conversion of NO_x to NO₂, i.e., the Tier 2 modeling approach, for the 1-hour average.

An AAQS review was only required for the 1-hour NO₂ averaging period, but modeled impacts for SO₂, PM₁₀/PM_{2.5}, CO and Pb have also been included for informational purposes. Based on the results of the air quality modeling analysis, the operation of the new Palm Beach Renewable Energy Facility No. 2 will not cause or contribute to a violation of an ambient air quality standard or maximum allowable concentration increase (PSD increment).

O₃ Modeling

Projects with VOC and NO_x emissions greater than 100 TPY are required to perform an ambient impact analysis for ozone including the gathering of preconstruction ambient air quality data. The applicant estimated annual potential VOC and NO_x emissions from the project to be 60 and 402 TPY respectively. The applicant’s potential NO_x emissions were originally estimated to be 760 TPY under the SNCR system, but with the switch to the more efficient SCR system, estimated NO_x emissions have fallen more than 300 TPY or by 51% of the original proposal.

The O₃ monitoring data at Royal Palm Beach are sufficient for the purposes of background values at the PBREF-2 site. O₃ site-specific modeling is not typically completed for single source permitting because of its complexity. O₃ is a secondarily formed pollutant that is known to be caused by the regional emissions of VOC and NO_x in combination with meteorological parameters (temperature, rainfall, solar insolation, etc.).

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

To conclusively prove whether or not the 402 TPY of NO_x will not cause or contribute to a violation, a very sophisticated and expensive model would need to be run for the entire region. The key inputs to the model would be traffic, power plants throughout the region, other industrial sources, and meteorology. As previously discussed, the NO_x emission reductions in South Florida from FP&L projects alone have declined by nearly 80,000 TPY. The effects of the PBREF-2 on O₃ would not be measurable considering the overwhelming effects of the FP&L reductions and the climatological variability. The uncertainty in any regional ozone model would be greater than the contribution from this project.

4.9. Additional Impacts Analysis

Impact on Soils, Vegetation, and Wildlife

PSD regulations require an analysis of air quality impacts on sensitive vegetation types, with significant commercial or recreational value, and sensitive types of soil. According to the applicant, within Palm Beach County, the soils surface layer typically consists of very loose to medium dense, relatively clean to slightly silty, and occasionally silty fine to medium sands. The subsurface (depths less than about 125 feet) material consists predominantly of sand, shell, sandstone, and limestone while the materials within several thousand feet of the land surface are sedimentary rocks. The USEPA secondary NAAQS were used to evaluate whether soils and vegetation will experience any adverse effects from air pollution. The secondary NAAQS were developed to prevent unacceptable effects on the public welfare, including unacceptable damage to crops and vegetation. Table 25 presents a comparison of the proposed project’s impacts to the secondary NAAQS. As shown, the highest predicted impacts (including the existing background concentration) are all well below the secondary NAAQS for all pollutants and averaging times. Therefore, the proposed PBREF-2 will not have an adverse impact on soil and vegetation.

Table 25: Soils and Vegetation Impact Analysis

Pollutant	Averaging Time	NAAQS Secondary Standard $\mu\text{g}/\text{m}^3$	Modeled Impact ^a $\mu\text{g}/\text{m}^3$	% of Secondary NAAQS	Background Concentration $\mu\text{g}/\text{m}^3$	Total Impact $\mu\text{g}/\text{m}^3$
NO ₂	Annual	100	0.88 ^b	0.9%	18	18.9
SO ₂	Annual	80	0.34	0.4%	4	4.3
	24-hour	365	3.1	0.8%	5.5	8.1
	3-hour	1,300	6.8	0.5%	5.5	12.3
PM ₁₀	24-hour ^c	150	0.45	0.3%	49	49.5
PM _{2.5}	Annual	15	0.06	0.4%	6.3	6.4
	24-hour ^d	35	0.68	1.9%	15	15.7
Pb ^e	3-month rolling	0.15	0.009	6.0%	0.01	0.019
	Quarterly	1.5	0.009	0.6%	0.01	0.019

- a. Based on the modeled impact for the PBREF-2.
- b. Impact based on the SNCR NO_x control scenario.
- c. The 24-hour PM₁₀ modeled impacts are based on the highest sixth-highest concentration over five years to compare with the secondary standard.
- d. Maximum 24-hour modeled PM_{2.5} concentration was used to conservatively determine compliance with the secondary standard.
- e. Maximum 24-hour modeled concentrations were used to conservatively determine compliance with the lead standard.

TECHNICAL EVALUATION AND PRELIMINARY DETERMINATION

Class I Area Impacts - Air Quality Related Values (AQRV)

Everglades National Park is the nearest Class I area to the proposed project and is located 118 kilometers south of the project site. Sulfur and nitrogen deposition analyses and a visibility impairment analysis was performed by the applicant to determine if the proposed facility would have an adverse impact on the specific AQRVs and visibility for the Everglades National Park.

Table 26 shows the results of the visibility analysis under the SNCR NO_x control scenario. Visibility impacts are less than criterion of 5% with the more recent Method 8 (mode 5) calculation approach, but slightly exceeded the threshold with the more conservative “Method 2” at one single day at a single receptor location.

Table 26 - Maximum 24-hour Visibility Impairment Predicted from the Proposed Facility at the Everglades National Park Class I Area

<u>Background Extinction Calculation</u>	<u>Visibility Impairment (%)^a</u>	<u>Visibility Impairment Criterion (%)</u>
Method 2	6.26 ^b	5.0
Method 8 (mode 5)	2.77	5.0

a. Concentrations are highest predicted using CALPUFF V5.8, 4-km domain for 2001-2003.
 b. A single day at a single receptor location was predicted to exceed the threshold using Method 2 and proposed emissions from SNCR control technology scenario.

However, with the expected reduction of NO_x emissions under the current SCR controls scenario along with the fact that these reported impacts using the conservative Method 2 approach will be of the limited duration, frequency, and occurrence and combined with the fact that predicted impacts are well below SIL support the conclusion that proposed PBREF-2 emissions will not cause or contribute to an adverse impact to visibility at Everglades National Park. The proposed use of SCR is expected to reduce the nitrate portion of the change of visibility impairment found using Method 2. The federal land manager concurs that no adverse impacts on visibility are predicted to occur. There were no visibility concerns for the Class II areas.

Total nitrogen (N) and sulfur (S) deposition rates were predicted using the CALPUFF model. Deposition thresholds were developed by the Federal Land Managers that represent the additional amount of N or S deposition within a Class I area below which impacts from a new or modified source are considered insignificant. Table 27 provides the results of this analysis. Total deposition of both N and S are both an order of magnitude below the threshold of 0.01 kilograms per hectare per year (kg/ha/yr).

Table 27 - Maximum Annual Nitrogen and Sulfur Deposition from the Proposed Facility at the Everglades National Park Class I Area

<u>Species</u>	<u>Total Deposition</u>	<u>Deposition Analysis Threshold</u>
	kg/ha/yr	kg/ha/yr
Nitrogen (N) Deposition ^a	0.0031	0.01
Sulfur (S) Deposition	0.0028	0.01

a. Using proposed emissions from the SNCR control technology scenario.

Industrial and Commercial Growth-Related Impacts

Between 1998 and 2008, there was an approximate 21 percent increase in the labor force, from more than 519,000 persons in 1998 to over 628,000 by 2008. Of the 20 major employers in the County, at least six lie within 5 miles of the proposed PBREF-2, but not closer than 4 miles to the proposed PBREF-2. The projected employment in Palm Beach County from 2008 to 2016 is anticipated to increase by 16 percent.

A number of industrial parks exist within 5 miles of the proposed PBREF-2 which is indicative of potential and planned industrial growth near the project site. The expected commercial and industrial growth due to the new facility will be negligible. The majority of the operations associated with the PBREF-2 are relatively self-contained. Therefore, no significant air quality impacts due to associated industrial/commercial growth are expected.

Residential Growth Impact Analysis

Palm Beach County's population (including Palm Beach County cities and the unincorporated areas of the County), according to the 2000 US Census Bureau, was approximately 1,131,191 permanent residents with an estimated additional seasonal population of 123,725 residents. There are approximately 474,175 occupied households. Based on data from the US Census Bureau, the average population density for the county is 635 people per square mile.

Palm Beach County's population grew 31 percent between 1990 and 2000. The state population grew nearly 19 percent from 2000 to 2008. The municipality of West Palm Beach is the largest among the County's 37 municipalities, both in population and area. West Palm Beach has a population of 82,103 permanent residents with an estimated additional seasonal population of 4,652 residents. Based on data from the US Census Bureau, the average population density for the municipality of West Palm Beach is 1,564 people per square mile.

According to the University of Florida's Bureau of Economic and Business Research, the population as of 2008 for towns and cities at least partially within 5 miles of the proposed PBREF-2 was 212,960. Since the proposed facility will divert existing MSW from the landfill, residential growth as a direct result of the proposed PBREF-2 is expected to be negligible.

5. CONCLUSION

The Department makes a preliminary determination that the proposed project will comply with all applicable state and federal air pollution control regulations as conditioned by the Draft Permit.

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

Florida Department of Environmental Protection
Division of Air Resource Management, Bureau of Air Regulation

Draft Air Permit No. 0990234-017-AC (PSD-FL-413)
Solid Waste Authority of Palm Beach County
Palm Beach Renewable Energy Facility No. 2
Palm Beach County, Florida

Applicant: The applicant for this project is Solid Waste Authority of Palm Beach County (SWA). The applicant's authorized representative and mailing address is: Mark Hammond, Executive Director, Solid Waste Authority of Palm Beach County, Palm Beach Renewable Energy Park, 7501 North Jog Road, West Palm Beach, FL 33412.

Facility Location: The Palm Beach Renewable Energy Facility No. 2 (PBREF-2) will be located at the existing Palm Beach Renewable Energy Park in Palm Beach County at 7501 North Jog Road in West Palm Beach, Florida.

Project: The PBREF-2 project consists of the construction of three 1,000 tons per day mass-burn municipal waste combustors (MWC), a 90 to 100 megawatts steam turbine-electrical generator and ancillary equipment. The project is subject to the preconstruction review requirements of Rule 62-212.400, Florida Administrative Code (F.A.C.) for the Prevention of Significant Deterioration (PSD) of Air Quality requiring several best available control technology (BACT) determinations. The determination of maximum achievable control technology (MACT) was not required.

Each MWC will include a furnace/boiler with a maximum permitted capacity of 320,000 pounds per hour (lb/hr) of steam on a 4-hr basis. The project will also include: two 250 horsepower diesel fire pump engines; one 250 kilowatts emergency generator; four silos to store lime and activated carbon; and an ash handling system and building.

The project is subject to the requirements of 40 Code of Federal Regulations (CFR) Part 60, Subpart Eb - Standards of Performance for Large MWC, issued in May 2006. These requirements comprise the MACT applicable to the project.

The project will result in PSD-significant emissions for the following pollutants: nitrogen oxides (NO_x), carbon monoxide (CO), sulfur dioxide (SO₂), volatile organic compounds (VOC), particulate matter (PM), PM with a mean diameter of 10 micrometers or less (PM₁₀), MWC metals as PM, MWC acid gases as SO₂ and hydrogen chloride (HCl), fluoride (F), sulfuric acid mist (SAM) and MWC organics as dioxins and furans (D/F).

The BACT control equipment for multi-pollutant control for the project consists of good combustion practices (GCP), spray dryers (SD), fabric filter (FF) baghouses, activated carbon injection (CI) and selective catalytic reduction (SCR).

All of the BACT emission limits for the project are at least as stringent as the requirements of Subpart Eb MACT. In particular, the emission limitation for NO_x is much more stringent at 50 parts per million by volume, dry at 7 percent (%) oxygen (ppmvd) compared with the Subpart Eb limit of 150 ppmvd. The BACT technology to achieve the NO_x limit is specified as SCR rather than selective non-catalytic reduction (SNCR). SCR will also reduce emissions of ammonia (NH₃) and VOC, which (like NO_x and SO₂) are precursors in the formation of fine PM in the exhaust and the environment.

SCR is also specified as BACT for the control of MWC organics as D/F and the limitation of 10 nanograms per dry standard cubic meter (total D/F ng/dscm) is the lowest to date for a MWC project in the U.S. The Department included provisions to further reduce that limit based on the actual performance of the SCR system to a level between 0.75 and 10 total D/F ng/dscm (inclusive). This range equates to approximately 0.015 to 0.2 D/F toxic equivalent (TEQ) ng/dscm.

(Public Notice to be Published in the Newspaper)

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

The applicant proposed a mercury (Hg) limitation of 25 micrograms/dscm ($\mu\text{g}/\text{dscm}$) compared with the Subpart Eb MACT limit of 50 $\mu\text{g}/\text{dscm}$). Furthermore, the applicant proposed a limit of 113 pounds per year on a 12-month rolling basis to avoid triggering PSD for this pollutant. This additional limitation equates to 12 $\mu\text{g}/\text{dscm}$.

The permit will require installation of continuous emission monitoring systems (CEMS) for NO_x , CO, SO_2 , Hg and continuous opacity monitoring systems (COMS) for visible emissions. Emissions from emergency equipment at the PBREF No. 2 will be controlled by GCP and the use of ultra low sulfur distillate (ULSD) fuel oil. Emissions from the storage silos will be controlled by FF baghouses.

The details of the Department BACT determinations including all of the emissions limits are included in the Technical Evaluation and Preliminary determination document available at:

www.dep.state.fl.us/Air/emission/bioenergy/palm_beach.htm

According to the applicant, maximum predicted air quality impacts due to all pollutants emitted from the proposed project will be less than the respective significant impact levels (SIL) applicable to areas in the vicinity of the project (i.e. PSD Class II Areas) for all pollutants except for the project-specific 1-hour nitrogen dioxide (NO_2) SIL. Therefore, multi-source PSD modeling was required for NO_2 , which demonstrated that the project will not cause or contribute to a violation of the recently promulgated 1-hour national ambient air quality standard (NAAQS) for NO_2 . Furthermore, an analysis for increment consumption was not performed because an allowable increment has not yet been promulgated to accompany the 1-hour NO_2 NAAQS.

The nearest PSD-Class I area is the Everglades National Park (ENP) that straddles Monroe, Collier and Miami-Dade Counties. The nearest boundary point in the ENP is located approximately 118 kilometers (km) south of the project site. According to the applicant, maximum predicted air quality impacts due to all pollutants emitted from the proposed project will be less than the respective SIL applicable to the Class I ENP for all pollutants. Therefore, a detailed PSD-Class I multisource air quality analysis was not required.

The Department has concluded that emissions from the project will not cause or contribute to a violation of any state or federal ambient air quality standards. The details of the ambient air quality impact analyses are provided in the document referenced above.

Permitting Authority: Applications for air construction permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210 and 62-212, F.A.C. The proposed project is not exempt from air permitting requirements and an air permit is required to perform the proposed work. The Florida Department of Environmental Protection's Bureau of Air Regulation is the Permitting Authority responsible for making a permit determination for this project. The Bureau of Air Regulation's physical address is 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301 and the mailing address is 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Bureau of Air Regulation's phone number is 850/488-0114.

Project File: A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at address indicated above for the Permitting Authority. The complete project file includes the Draft Permit, the Technical Evaluation and Preliminary Determination, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address and phone number listed above. In addition, electronic copies of these documents are available at the link provided above.

Notice of Intent to Issue Air Permit: The Permitting Authority gives notice of its intent to issue an air permit to the applicant for the project described above. The applicant has provided reasonable assurance that operation of the proposed equipment will not adversely impact air quality and that the project will comply with all applicable provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a Final Permit in accordance with the conditions of the proposed Draft Permit unless a timely petition for an

(Public Notice to be Published in the Newspaper)

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

administrative hearing is filed under Sections 120.569 and 120.57, F.S. or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.

Comments: The Permitting Authority will accept written comments concerning the proposed Draft Permit and requests for a public meeting for a period of 30 days from the date of publication of the Public Notice. Written comments must be received by the Permitting Authority by close of business (5:00 p.m.) on or before the end of this 30-day period. In addition, if a public meeting is requested within the 30-day comment period and conducted by the Permitting Authority, any oral and written comments received during the public meeting will also be considered by the Permitting Authority. If timely received comments result in a significant change to the Draft Permit, the Permitting Authority shall revise the Draft Permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.

Petitions: A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 850/245-2241; Fax: 850/245-2303). Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within 14 days of publication of this Public Notice or receipt of a written notice, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of when and how each petitioner received notice of the agency action or proposed decision; (d) A statement of all disputed issues of material fact; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Public Notice of Intent to Issue Air Permit. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation: Mediation is not available in this proceeding.

(Public Notice to be Published in the Newspaper)

DRAFT PERMIT

PERMITTEE

Solid Waste Authority of Palm Beach County
7501 North Jog Road
West Palm Beach, FL 33412

Air Permit No. 0990234-017-AC (PSD-FL-413)
Palm Beach Renewable Energy Park
Palm Beach Renewable Energy Facility No. 2

Authorized Representative:
Mark Hammond, Executive Director

Expires: December 31, 2015
Palm Beach County

PROJECT

This is the final air construction permit authorizing the construction of three 1,000 tons per day (TPD) mass-burn municipal waste combustors (MWC), a 90 to 100 megawatts (MW) steam turbine-electrical generator (STG) and ancillary equipment. The proposed work will be conducted at the existing Palm Beach Renewable Energy Park (PBREP), which is a municipal solid waste (MSW) facility categorized under Standard Industrial Classification Number (No.) 4953. The existing facility is located in Palm Beach County at 7501 North Jog Road in West Palm Beach, Florida. The UTM coordinates are Zone 17, 585.3 kilometers (km) East, and 2961.7 km North.

This final permit is organized into the following sections: Section 1 (General Information); Section 2 (Administrative Requirements); Section 3 (Emissions Unit Specific Conditions); and Section 4 (Appendices). Because of the technical nature of the project, the permit contains numerous acronyms and abbreviations, which are defined in Appendix CF of Section 4 of this permit. As noted in the Final Determination provided with this final permit, only minor changes and clarifications were made to the draft permit.

STATEMENT OF BASIS

This air pollution construction permit is issued under the provisions of: Chapter 403 of the Florida Statutes (F.S.) and Chapters 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297 of the Florida Administrative Code (F.A.C.). The permittee is authorized to conduct the proposed work in accordance with the conditions of this permit. This project is subject to the general preconstruction review requirements in Rule 62-212.300, F.A.C. and the preconstruction review requirements for major stationary sources in Rule 62-212.400, F.A.C. for the Prevention of Significant Deterioration (PSD) of Air Quality and a corresponding best available control (BACT) determination.

Upon issuance of this final permit, any party to this order has the right to seek judicial review of it under Section 120.68 of the Florida Statutes by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within 30 days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida

(DRAFT)

Joseph Kahn, Director
Division of Air Resource Management

(Date)

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Final Air Permit package (including the Final Determination and Final Permit with Appendices) was sent by electronic mail, or a link to these documents made available electronically on a publicly accessible server, with received receipt requested before the close of business on _____ to the persons listed below.

- Mark Hammond, SWA, Executive Director: mhammond@swa.org
- Michael Halpin, DEP Siting: mike.halpin@dep.state.fl.us
- Kevin Claridge, DEP SED: kevin.claridge@dep.state.fl.us
- Jim Stormer, Palm Beach County Health Department: james_stormer@doh.state.fl.us
- Heather Abrams, EPA Region 4: abrams.heather@epa.gov
- Dee Morse, NPS: dee_morse@nps.gov
- Amit Chattopadhyay, P.E., Malcolm Pirnie: achattopadhyay@pirnie.com
- Vickie Gibson, DEP BAR Reading File: victoria.gibson@dep.state.fl.us

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

(Clerk)

(Date)

SECTION 1. GENERAL INFORMATION (DRAFT PERMIT)

FACILITY DESCRIPTION

The existing facility consists of the following emissions units (EU):

Facility ID No. 0990234	
EU ID No.	EU Description
001	Municipal Solid Waste Boiler No. 1
002	Municipal Solid Waste Boiler No. 2
004	Class III Landfill with Flare
005	Refuse Derived Fuel (RDF) Storage
007	RDF Processing Lines
008	Oversized Bulky Waste (OBW) Processing Lines
010	Sludge Dryer Train No. 1
011	Sludge Dryer Train No. 2
012	Recycle Material Bin and Pellet Storage Silo for Train No. 1
013	Cooling Tower Train No. 1
014	Recycle Material Bin and Pellet Storage Silo for Train No. 2
015	Cooling Tower Train No. 2
016	Emergency Generator
017	Woody Waste Facility Diesel Engine
018	Cooling Tower
019	Ash Building and Handling System
020	Class III Landfill Existing Flare - 1,800 standard cubic feet per minute (scfm), backup use only
021	Emergency Generator, 220 break-horsepower (hp), EPA Tier III Certified
023	Powdered Activated Carbon Silo with Baghouse

PROPOSED PROJECT

The permit authorizes the construction of the Palm Beach Renewable Energy Facility No. 2 (PBREF-2). This facility will consist of three 1,000 TPD mass-burn MWC units each with a maximum steam production rate of 320,100 pounds per hour (lb/hr) on a 4-hour average block basis. The project also includes a 90 to 100 MW STG; three lime storage silos; one carbon storage silo; two diesel fire pump engines; one emergency generator; and one ash handling system and building. The proposed work will be conducted at the existing PBREP.

The project will incorporate the following pollution control equipment and measures:

- For each MWC unit, good combustion practices (GCP), spray dryers (SD), fabric filter (FF) baghouses, activated carbon injection (CI), selective catalytic reduction (SCR), as an option selective non-catalytic reduction (SNCR) and use of inherently clean natural gas as a startup, shutdown and flame stabilization fuel.
- Use of inherently clean ultra low sulfur distillate (ULSD) fuel oil and GCP in the emergency generator and emergency fire pump engines; and
- Reasonable precautions and best management practices (BMP) to minimize fugitive particulate matter (PM)/(PM₁₀)/(PM_{2.5}) emissions from MSW handling and processing; ash (bottom and fly) handling, storage and shipment; lime handling, storage and processing; and activated carbon handling, storage and processing.

The project will incorporate continuous emission monitoring systems (CEMS) for CO, SO₂, NO_x and Hg and continuous opacity monitoring systems (COMS) for visible emissions (VE).

SECTION 1. GENERAL INFORMATION (DRAFT PERMIT)

This project will consist of the following EU:

Facility ID No. 0990234	
EU ID No.	EU Description
024	Municipal Solid Waste Combustor No. 1
025	Municipal Solid Waste Combustor No. 2
026	Municipal Solid Waste Combustor No. 3
027	Lime Storage Silo A
028	Lime Storage Silo B
029	Lime Storage Silo C
030	Activated Carbon Storage Silo
031	250 hp Diesel Fire Pump Engine A
032	250 hp Diesel Fire Pump Engine B
033	250 Kilowatt (kW) Emergency Generator
034	Ash Handling System and Building

FACILITY REGULATORY CLASSIFICATION

- The existing PBREP and the new PBREF-2 are major sources of HAP.
- The PBREP and the PBREF-2 are not subject to the acid rain provisions of the Clean Air Act (CAA).
- The PBREP is a Title V major source of air pollution in accordance with Chapter 213, F.A.C.
- The PBREP is a major stationary source in accordance with Rule 62-212.400 (PSD), F.A.C.
- The PBREF-2 is a modification of a major stationary source in accordance with Rule 62-212.400 (PSD), F.A.C.
- The PBREF-2 is subject to New Source Performance Standards (NSPS) under Section 111 of the CAA and National Emissions Standards for Hazardous Air Pollutants (NESHAP) under Section 112 of the CAA which are incorporated by reference in Chapter 62-204.800, F.A.C.

SECTION 2. ADMINISTRATIVE REQUIREMENTS (DRAFT PERMIT)

1. Permitting Authority: The Permitting Authority for this project is the Bureau of Air Regulation in the Division of Air Resource Management of the Department. The mailing address for the Bureau of Air Regulation is 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. All documents related to applications for permits shall be submitted to the Bureau of Air Regulation in the Division of Air Resource Management of the Department.
2. Compliance Authority: All documents related to compliance activities such as reports, tests, and notifications shall be submitted to the Department's Southeast District Office at: Air Resource Section, 400 North Congress Avenue, Suite 200, West Palm Beach, FL 33401.
3. Appendices: The following Appendices are attached as a part of this permit and the permittee must comply with the requirements of the appendices:

Appendix A	Identification of General Provisions - NSPS 40 CFR 60, Subpart A;
Appendix A1	General Provisions - NSPS 40 CFR 63, Subpart A;
Appendix CC	Common Conditions;
Appendix CEMS	Continuous Emissions Monitoring System (CEMS) Requirements;
Appendix CF	Citation Formats and Glossary of Common Terms;
Appendix CTR	Common Testing Requirements;
Appendix Eb	NSPS, 40 CFR 60, Subpart Eb - Standards of Performance for Large Municipal Waste Combustors;
Appendix GC	General Conditions;
Appendix IIII	NSPS, Subpart IIII – Stationary Compression Ignition Internal Combustion Engines;
Appendix XSE	Excess Emission Reporting Form; and,
Appendix ZZZZ	NESHAP, Subpart ZZZZ – Stationary Reciprocating Internal Combustion Engines (RICE).
4. Applicable Regulations, Forms and Application Procedures: Unless otherwise specified in this permit, the construction and operation of the subject emissions units shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of: Chapter 403, F.S.; and Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-296 and 62-297, F.A.C. Issuance of this permit does not relieve the permittee from compliance with any applicable federal, state, or local permitting or regulations.
5. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
6. Modifications: No emissions unit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification. [Rules 62-210.300(1) and 62-212.300(1)(a), F.A.C.]
7. Source Obligation:
 - (a) Authorization to construct shall expire if construction is not commenced within 18 months after receipt of the permit, if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time. This provision does not apply to the time period between construction of the approved phases of a phased construction project except that each phase must commence construction within 18 months of the commencement date established by the Department in the permit.

SECTION 2. ADMINISTRATIVE REQUIREMENTS (DRAFT PERMIT)

- (b) At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by virtue of a relaxation in any enforceable limitation which was established after August 7, 1980, on the capacity of the source or modification otherwise to emit a pollutant, such as a restriction on hours of operation, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.
- (c) At such time that a particular source or modification becomes a major stationary source or major modification (as these terms were defined at the time the source obtained the enforceable limitation) solely by exceeding its projected actual emissions, then the requirements of subsections 62-212.400(4) through (12), F.A.C., shall apply to the source or modification as though construction had not yet commenced on the source or modification.

[Rule 62-212.400(12), F.A.C.]

8. **Title V Permit:** This permit authorizes specific modifications and/or new construction on the affected emissions units as well as initial operation to determine compliance with conditions of this permit. A Title V operation permit is required for regular operation of the permitted emissions unit. The permittee shall apply for a Title V operation permit at least 90 days prior to expiration of this permit, but no later than 180 days after completing the required work and commencing operation. To apply for a Title V operation permit, the applicant shall submit the appropriate application form, compliance test results, and such additional information as the Department may by law require. The application shall be submitted to the appropriate Permitting Authority with copies to Southeast District of DEP. [Rules 62-4.030, 62-4.050, 62-4.220, and Chapter 62-213, F.A.C.]
9. **Objectionable Odors Prohibited:** No person shall cause, suffer, allow or permit the discharge of air pollutants which cause or contribute to an objectionable odor. [Rule 62-296.320(2), F.A.C.]
{Note: An objectionable odor is defined in Rule 62-210.200(Definitions), F.A.C., as any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance.}
10. **Unconfined Emissions of Particulate Matter:** No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction, alteration, demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. Any permit issued to a facility with emissions of unconfined particulate matter shall specify the reasonable precautions to be taken by that facility to control the emissions of unconfined particulate matter. General reasonable precautions include the following: a. Paving and maintenance of roads, parking areas and yards; b. Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing; c. Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar activities; d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the facility to prevent re-entrainment, and from buildings or work areas to prevent particulates from becoming airborne; e. Landscaping or planting of vegetation; f. Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter; g. Confining abrasive blasting where possible; and h. Enclosure or covering of conveyor systems.
[Rule 62-296.320(4)(c), F.A.C.]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

This section of the permit addresses the following EU.

EU ID Nos. 024, 025 and 026	EU Descriptions
	<p><i>Description:</i> These EU consist of three 1,000 TPD mass burn MWC units, each with a fossil fuel fired auxiliary burner system. The natural gas fired burner systems will be used during periods of startup, shutdown and for flame stabilization. Each MWC unit will produce high pressure, high temperature (HPHT) steam that will be used in a single STG to generate 90 to 100 MW of electrical power.</p> <p><i>Fuels:</i> The primary boiler fuel for each MWC unit will be MSW and the other fuels as specified in Specific Condition 12 of this subsection. Natural gas will be used as a startup, shutdown and flame stabilization fuel in the auxiliary burner system.</p> <p><i>Steam Capacity:</i> The maximum steam production limit per unit on a 4 hour block average basis is 320,100 lb steam/hr.</p> <p><i>Heat Input:</i> The heat input required to generate the maximum steam capacity is approximately 458 million British thermal units per hour (mmBtu/hr). The maximum heat input limit for the natural gas burner system for each MWC unit is 246 mmBtu/hr during periods of startup, shutdown and for flame stabilization.</p> <p><i>Controls for each MWC:</i> The air pollution control systems will consist of GCP, SD, FF, CI, SCR and use of inherently clean natural gas as a startup, shutdown and flame stabilization fuel in the MWC.</p> <p><i>Stack Parameters for each MWC:</i> Each of the MWC units will have a separate exhaust flue. The exhaust flues will be co-located and contained in a common outer stack. Each stack flue will be approximately 8.1 feet in diameter (maximum) and 310 feet tall (minimum). Exhaust from each flue will exit the stack at the following approximate conditions: an exit temperature of 285 °F and a volumetric flow rate of 184,310 actual cubic feet per minute (acfm).</p> <p><i>Continuous emissions and opacity monitoring systems (CEMS, COMS):</i> Emissions of CO, NO_x, SO₂ and Hg from each MWC unit will be monitored and recorded by CEMS. Opacity (VE) from each unit will be monitored and recorded by a COMS.</p> <p><i>Applicability of 40 CFR Subpart Eb (NSPS Subpart Eb):</i> Each MWC unit is subject to NSPS Subpart Eb - Standards of Performance for Large Municipal Waste Combustors.</p> <p><i>{Permitting Note: These emission units are subject to BACT determinations for NO_x, CO, SO₂, PM, VOC, SAM, MWC acid gases as SO₂+hydrogen chlorides (HCl), MWC organics as dioxin/furans (D/F), and MWC metals as PM.}</i></p> <p><i>{Permitting Note: Unless otherwise specified in a specific condition of this subsection, the descriptions above under Capacity and Steam Capacity are not operating limitations.}</i></p>

EQUIPMENT

1. **MWC Units:** The permittee is authorized to construct three MWC stoker boiler units each with a natural gas burner system, overfire air ports, steam drum, superheater, economizer, air heater, ash hoppers, ducts, fuel feeding equipment, dry cooling towers, air pollution control equipment and other associated equipment. [Application No. 0990234-017-AC]
2. **Air Pollution Control Equipment:** The permittee shall install the following add-on air pollution control equipment on each MWC unit.
 - a. **SD/FF Baghouse System:** The permittee shall design, install, operate and maintain a SD/FF baghouse system. The SD/FF baghouse system shall be brought on line in accordance with the manufacturer's procedures and guidelines and will be utilized whenever the MWC unit is in operation and burning MWC.
 - b. **SCR System:** The permittee shall design, install, operate, and maintain an ammonia (NH₃) or urea based SCR system including reagent storage tank, pumps, metering system, injection grid, reactor and catalyst to reduce NO_x emissions in the flue gas exhaust and achieve the NO_x emissions limit specified in this

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

subsection. The SCR shall be brought on line in accordance with the SCR manufacturer's procedures and guidelines and shall be utilized whenever the MWC unit is in operation and burning MWC. The SCR system also represents BACT for D/F emissions.

- c. SNCR System: The permittee may install, operate, and maintain an NH₃ or urea based SNCR system including reagent storage tank, pumps, metering system and injection equipment to reduce NO_x in the furnace prior to further downstream treatment by the SCR system.
- d. Activate CI System and FF Baghouse: The permittee shall install, operate and maintain an activated CI system and FF baghouse (same baghouse used for SD) to capture the spent carbon. The CI system and FF baghouse shall be designed, constructed and operated to achieve the Hg and other metals emission limits specified in this subsection. The CI system shall be brought on line in accordance with the manufacturer's procedures and guidelines and will be utilized whenever the MWC unit is in operation and burning MWC.

[Application No. 0990234-017-AC; NSPS Subpart Db; and Rule 62-4.070(3), 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.]

- e. Circumvention: The permittee shall not circumvent the air pollution control equipment or allow the emissions of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C.]

3. Aqueous Ammonia or Urea Storage Tank: The permittee is authorized to construct a nominal 30,000 gallon or smaller tank to store aqueous ammonia or urea for the SCR systems. In accordance with 40 CFR 60.130, the storage of aqueous ammonia or urea shall comply with all applicable requirements of the Chemical Accident Prevention Provisions in 40 CFR 68. The tank designed and fabricated in accordance with U.S. Department of Labor Chapter 29, Part 1910.111, Code of Federal Regulations (CFR), American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, ANSI K 61.1, and applicable requirements of Chapter 62-762, F.A.C., Above Ground Storage Tank (AST) Systems.
[Application No. 0990234-017-AC and Rule 62-4.070(3), F.A.C.]

PERFORMANCE REQUIREMENTS AND MONITORING OF MWC OPERATIONS

4. MWC Boiler Unit Fuels: Each MWC boiler unit is authorized to combust MSW and other fuels authorized in **Specific Condition 12** of this subsection. In addition, each MWC unit is authorized to combust natural gas as a startup, shutdown and flame stabilization fuel.
[Application No. 0990234-017-AC; Rules 62-4.070(3), 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.]
5. Steam Production Limits: For each MWC unit, the maximum allowable steam production rate is 320,100 lb/hr (4 hour block average basis).
[Application No. 0990234-017-AC; Rules 62-4.070(3), 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.]
6. Maximum Demonstrated MWC Unit Load: The maximum demonstrated MWC unit load shall be determined during the initial performance test for D/F and each subsequent performance test during which compliance with the D/F emission limit is achieved. The maximum demonstrated MWC unit load shall be the highest 4-hour arithmetic average load based on steam production achieved during four consecutive hours during the most recent test during which compliance with the dioxin/furan emission limit was achieved. Unit load means the steam load of the MWC measured as specified in 40 CFR 60.58b(I)(6). Each unit shall not operate at a load level greater than the steam production rate given in **Specific Condition 5** of this subsection or, if it is less, 110% of the unit's "maximum demonstrated unit load". Higher loads, within the limit in **Specific Condition 5** of this subsection, are allowed for testing purposes as specified in 40 CFR 60.53b(b). [40 CFR 60.34b(b), 60.51b, 60.53b(b), and 60.58b(I)(6)]
7. Steam Parameters: In accordance with the manufacturer's recommendations, the permittee shall install, calibrate, operate and maintain continuous monitoring and recording devices for the following parameters on each MWC unit: steam temperature (°F), steam pressure (psig) and steam production rate (lb/hour). Records shall be maintained on site and made available upon request.
[Rules 62-4.070(3) and 62-210.200(PTE), F.A.C.]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

8. Steam Monitoring: MWC unit load means the steam load of the MWC unit measured as specified in §60.58b(i)(6). The owner or operator shall install, calibrate, maintain, and operate a steam flow meter, shall measure steam flow in lb of steam/hr on a continuous basis, and record the output of the monitor (in accordance with the ASME method described in 40 CFR 60.58b(i)(6)). Steam flow shall be calculated in a 4 hour block arithmetic average. For each MWC unit, the maximum steam production limit corresponding to maximum demonstrated unit load is 320,100 lb/hr (4 hour block average basis). Higher unit loads are allowed for testing purposes pursuant to 40 CFR 60.53b(b). [Rules 62-204.800(8) and 62-4.070(1), and (3), F.A.C., and 40 CFR 60.53(a), and 60.58b(i)]
9. Heat Input from Fossil Fuels: The maximum heat input capacity from natural gas for each MWC unit on a steady state basis during boiler startup, shutdown and flame stabilization shall be limited to 246 mmBtu/hr. [Application No. 0990234-017-AC; Rules 62-4.070(3), 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.]
10. Operational Hours: The hours of operation of these MWC units are not restricted (8,760 hours/year). [Application No. 0990234-017-AC; Rules 62-4.070(3) and 62-210.200(PTE)]
11. Prohibited Fuels:
 - a. The facility shall not burn:
 - i. those materials that are prohibited by state or federal law;
 - ii. those materials that are prohibited by this permit;
 - iii. lead acid batteries;
 - iv. hazardous waste;
 - v. nuclear waste;
 - vi. radioactive waste;
 - vii. sewage sludge;
 - viii. explosives; and
 - ix. beryllium-containing waste, as defined in 40 CFR 61, Subpart C.
 - b. Further, the facility shall not knowingly burn:
 - i. nickel-cadmium batteries pursuant to Section 403.7192 (3);
 - ii. mercury containing devices and lamps pursuant to Sections 403.7186(2), and (3);
 - iii. untreated biomedical waste from biomedical waste generators regulated pursuant to Chapter 64E-16, F.A.C., and from similar generators (or sources);
 - iv. segregated loads of biological waste; and
 - v. Copper Chromated Arsenate (CCA) treated wood.
12. Authorized Fuels: The primary fuel for the facility is MSW, including the items and materials that fit within the definition of MSW contained in either 40 CFR 60.51b or Section 403.706(5), F.S. (1995). Subject to the limitations contained in this permit, the authorized fuels for the facility also include the other solid wastes that are not MSW which are described below:
 - a. Subject to the conditions and limitations contained in this permit, the following other solid waste may be used as fuel at the facility:
 - i. Confidential, proprietary or special documents (including but not limited to business records, lottery tickets, event tickets, coupons and microfilm);
 - ii. Contraband which is being destroyed at the request of appropriately authorized local, state or federal governmental agencies, provided that such material is not an explosive, a propellant, a hazardous waste, or otherwise prohibited at the facility. For the purposes of this section, contraband includes but is not limited to drugs, narcotics, fruits, vegetables, plants, counterfeit money, and counterfeit consumer goods;
 - iii. Wood pallets, clean wood, and land clearing debris;
 - iv. Packaging materials and containers;

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

- v. Clothing, natural and synthetic fibers, fabric remnants, and similar debris, including but not limited to aprons and gloves; or
 - vi. Rugs, carpets, and floor coverings, but not asbestos-containing materials or polyethylene or polyurethane vinyl floor coverings.
- b. Subject to the conditions and limitations contained in this permit, waste tires may be used as fuel at the facility. The total quantity of waste tires received as segregated loads and burned at the facility shall not exceed 3%, by weight, of the facility's total fuel. Compliance with this limitation shall be determined on a calendar month basis in accordance with **Specific Condition 35** of this subsection.
- c. Subject to the conditions and limitations contained in this permit, the following other solid waste materials may be used as fuel at the facility (i.e. the following are authorized fuels that are non-MSW material). The total quantity of the following non-MSW material received as segregated loads and burned at the facility shall not exceed 5%, by weight, of the facility's total fuel. Compliance with this limitation shall be determined on a calendar month basis in accordance with **Specific Condition 35** of this subsection.
- i. Construction and demolition debris.
 - ii. Oil spill debris from aquatic, coastal, estuarine or river environments. Such items or materials include but are not limited to rags, wipes, and absorbents.
 - iii. Items suitable for human, plant or domesticated animal use, consumption or application where the item's shelf-life has expired or the generator wishes to remove the items from the market. Such items or materials include but are not limited to off-specification or expired consumer products, pharmaceuticals, medications, health and personal care products, cosmetics, foodstuffs, nutritional supplements, returned goods, and controlled substances.
 - iv. Consumer-packaged products intended for human or domesticated animal use or application but not consumption. Such items or materials include but are not limited to carpet cleaners, household or bathroom cleaners, polishes, waxes and detergents.
 - v. Waste materials that:
 - (a) are generated in the manufacture of items in categories (iii) or (iv), above and are functionally or commercially useless (expired, rejected or spent); or
 - (b) are not yet formed or packaged for commercial distribution. Such items or materials must be substantially similar to other items or materials routinely found in MSW.
 - vi. Waste materials that contain oil from:
 - (a) the routine cleanup of industrial or commercial establishments and machinery; or
 - (b) spills of virgin or used petroleum products. Such items or materials include but are not limited to rags, wipes, and absorbents.
 - vii. Used oil and used oil filters. Used oil containing a polychlorinated biphenyls (PCB) concentration equal or greater than 50 parts per million (ppm) shall not be burned, pursuant to the limitations of 40 CFR 761.20(e).
{Permitting note: Waste materials specifically authorized above do not require Department approval.}
 - viii. Waste materials generated by manufacturing, industrial or agricultural activities, provided that these items or materials are substantially similar to items or materials that are found routinely in MSW.
[Rule 62-4.070(1), and (3), F.A.C.]
13. Segregated Loads: The fuel may be received either as a mixture or as a single-item stream (segregated load) of discarded materials. If the facility intends to use an authorized fuel that is a segregated non-MSW material, the fuel shall be either:
- a. well mixed with MSW in the refuse pit; or
 - b. alternately charged with MSW in the hopper.

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

14. Combustion Practices: To ensure that the facility’s fuel does not adversely affect the facility’s combustion process or emissions, the facility operator shall:
- comply with good combustion operating practices in accordance with 40 CFR 60.53b;
 - install, operate and maintain CEMS for oxygen, CO, SO₂, NO_x and temperature in accordance with 40 CFR 60.58b; and
 - record and maintain the CEMS data in accordance with 40 CFR 60.59b.

These steps shall be used to ensure and verify continuous compliance with the emissions limitations in this permit. Natural gas may be used as fuel during boiler startup, shutdown and flame stabilization, and at other times when necessary and consistent with good combustion practices.

NSPS APPLICABILITY

15. NSPS Subpart Eb and Subpart A Applicability: Each MWC unit, including the shared STG, are subject to all applicable requirements of 40 CFR 60, Subpart Eb which applies to Large Municipal Waste Combustors and Subpart A, General Provisions. The applicable conditions are given in Appendices A and Eb of this permit. [Rule 62-204.800(7)(b) and 40 CFR 60, NSPS-Subpart Eb and 40 CFR 60 Subpart A]

EMISSIONS STANDARDS

16. Emissions from each MWC unit (EU-024, EU-025 and EU-026) shall not exceed the following limits:

Pollutant	Emission Standard/Limit ¹	lb/hour ²	Basis
NO _x	50 ppmvd – 24 hour block arithmetic mean	37.4	BACT
	45 ppmvd – 12 month rolling average		BACT
CO	100 ppmvd – 4 hr block arithmetic mean	45.5	Subpart Eb
	80 ppmvd – 30-day rolling average		BACT
SO ₂	24 ppmvd – 24 hour geometric mean	25.0	BACT
HCl ³	20 ppmvd	11.9	BACT
VOC (as propane)	7 ppmvd	5.0	BACT
PM/PM ₁₀ /PM _{2.5}	12.0 mg/dscm	4.7	BACT
Lead (Pb)	125 µg/dscm	0.049	Avoid PSD
Hg ⁴	N/A ⁵	113 lb/yr ⁶	Avoid PSD
	25 µg/dscm	0.0098	Applicant Request
Cadmium (Cd)	10 µg/dscm	3.91E ⁻⁰³	Subpart Eb
D/F ⁷	13.0 ng/dscm		Subpart Eb
	10 ng/dscm during initial two years		Initial Test
	0.75 to 10 ng/dscm 3 rd year and thereafter		BACT
Opacity	10 % – 6 minute average	N/A	BACT Subpart Eb
Ammonia Slip	10 ppmvd	2.76	PM, Opacity

1 All concentration values are corrected to 7% O₂: µg/dscm = micrograms per dry standard cubic meter; mg/dscm = milligrams per dry standard cubic meter; ng/dscm = nanograms per dry standard cubic meter; and ppmvd = part per million dry volume.
 2 Mass emission limits reflect maximum values calculated at 110% of 24 hour steam production limit of 291,000 lb steam/hr for each MWC. The 110% steam limit is 320,100 lb steam/hr for each MWC.
 3 HCl is not a BACT pollutant. However, it must be limited together with SO₂ because they both comprise MWC-Acid Gases which has its own PSD threshold.
 4 Within 60 days after achieving the maximum production rate, but not later than 180 days after the initial startup, PBREF-2 shall commence quarterly performance Hg stack test events for each MWC exhaust flue to show compliance with the 25 µg/dscm emission limit. The 25 µg/dscm quarterly stack based standard is based on the applicant’s request. By meeting the quarterly stack test standard, PBREF-2 will show compliance with Subpart Eb Hg emission standard of 50 µg/dscm.

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

5	N/A = not applicable.
6	The 113 lb/yr emission limit is a 12 month rolled monthly average based on CEMS data. The Hg CEMS must become operational within 60 days after PBREF-2 achieves its maximum production rate, but not later than 180 days after the initial startup. During the first four quarters of Hg CEMS availability, the CEMS must achieve an 80% data availability rate. Subsequently, an 85% data availability rate is required. See Appendix CEMS for the procedures to be used for data replacement during time of Hg CEMS unavailability.
7	Dioxins/furans: Total tetra through octa-chlorinated dibenzo-p-dioxins and dibenzofurans. During the first year of the PBREF-2 operation of the 10 ng/dscm limit applies. Subsequently, the To Be Determined (TBD) limit will govern based on initial performance and efficiency tests at the inlet and outlet of the SCR as per Specific Conditions 19 and 20 of this subsection. Based on these tests a D/F limit between 10 ng/dscm and 0.75 ng/dscm will be selected by the Department. The pound per hour limit will correspond to TBD ng/dscm limit.

TEST METHODS AND PROCEDURES

17. Test Methods: Any required stack test shall be performed in accordance with the following methods.

EPA Method	Description of Method and Comments
1 - 4	Determination of Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content. Methods shall be performed as necessary to support other methods.
5	Determination of Particulate Emissions. The minimum sample volume shall be 30 dry standard cubic feet.
6C	Determination of SO ₂ Emissions (Instrumental).
7E	Determination of NO _x Emissions (Instrumental). NO _x emissions testing shall be conducted with the air heater operating at the highest heat input possible during the test.
8	Measurement of Sulfuric Acid Mist
9	Visual Determination of Opacity
10	Measurement of Carbon Monoxide Emissions (Instrumental). The method shall be based on a continuous sampling train.
13A or 13B	Measurement of Fluoride Emissions
18	Measurement of Gaseous Organic Compound Emissions (Gas Chromatography) <i>{Note: EPA Method 18 may be used (optional) concurrently with EPA Method 25A to deduct emissions of methane and ethane from the total hydrocarbons (THC) emissions measured by Method 25A.}</i>
23	Measurement of Dioxin/Furan Emissions
26 or 26A	Determination of Hydrogen Chloride Emissions
29	Determination of Metals Emissions from Stationary Sources (Hg, Cd, Pb)
CTM-027	Procedure for Collection and Analysis of Ammonia in Stationary Source <ul style="list-style-type: none"> • This is an EPA conditional test method. • The minimum detection limit shall be 1 ppm.

Method CTM-027 is published on EPA's Technology Transfer Network Web Site at "<http://www.epa.gov/ttn/emc/ctm.html>". The other methods are specified in Appendix A of 40 CFR 60, adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. Tests shall be conducted in accordance with the appropriate test method and the applicable requirements specified in this permit, and NSPS Subpart A in 40 CFR 60. [Rules 62-204.800, F.A.C. and 40 CFR 60, Appendix A]

18. Testing Requirements: Initial tests shall be conducted between 90% and 100% of permitted capacity; otherwise, this permit shall be modified to reflect the true maximum capacity as constructed. Subsequent

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

annual tests shall be conducted between 90% and 100% of permitted capacity in accordance with the requirements of Rule 62-297.310(2), F.A.C. [Rule 62-297.310(7)(a) and (b), F.A.C.; 40 CFR 60.8]

19. **Initial Compliance Demonstration:** Initial compliance stack tests shall be conducted within 60 days after achieving the maximum production rate, but not later than 180 days after the initial startup for each MWC unit. In accordance with the test methods specified in this permit, each units exhaust flue gas shall be tested to demonstrate compliance with the emission standards for NO_x, VOC, CO, SO₂, HCl, PM/PM₁₀/PM_{2.5}, Pb, Cd, Hg (quarterly), D/F (quarterly during first two years of operation at the inlet and outlet of the SCR and stack flue exhaust and annually thereafter), VE, and ammonia slip given in **Specific Condition 16** of this subsection. Relative Accuracy Test Audit (RATA) tests for CEMS can constitute initial stack tests for these pollutants. The permittee shall provide the Compliance Authority with any other initial emissions performance tests conducted to satisfy vendor guarantees.
[Rule 62-297.310(7)(a) and (b), F.A.C.; 40 CFR 60.8]
20. **Initial Tests for F and SAM Emission Rates:** Initial compliance stack tests shall be conducted on each units exhaust flue gas within 60 days after achieving the maximum production rate, but not later than 180 days after the initial startup to determine the emission rates of SAM and F.
Rules 62-4.070(3), 62-210.200 (BACT) and 62-212.400 (PSD), F.A.C.]
21. **Subsequent Compliance Testing:** Annual stack tests for each MWC units exhaust flue gas shall be conducted for VOC, HCl, PM/PM₁₀/PM_{2.5}, Pb, Cd, Hg (quarterly), D/F (quarterly during first two years of operation at the inlet and outlet of the SCR and stack flue exhaust and annually thereafter), VE and ammonia slip during each federal fiscal year (October 1st to September 30th) to show compliance with the emission limits given in **Specific Condition 16** of this subsection. Data collected from the reference method during the required RATA tests for CO, NO_x, SO₂ and Hg (one quarter of four) may be used to satisfy the annual testing requirement provided the notification requirements and emission testing requirements for performance and compliance tests of this permit are satisfied.
[Rules 62-297.310(7)(a) and (b), and 62-296.416, F.A.C., and 40 CFR 60.8 and 60.58b]
22. **Emissions Limit Subject to Revision D/F:** D/F emissions from each MWC shall not exceed the limitation stated **Specific Condition 16** of this subsection. Stack acceptance testing and SCR inlet/outlet D/F destruction testing shall be performed quarterly on each MWC exhaust flue gas during the first two years of operation. The permittee shall provide a protocol for the SCR efficiency testing for review and approval by the Department ninety days prior to the commencement of testing. The permittee shall provide the results to the Department within 45 days of completion of the eight D/F destruction efficiency and stack tests so that the Department can set a numerical BACT D/F limit based on the performance of the SCR technology.

The D/F emission limit standard will be between a maximum value of 10 ng/dscm and a minimum value of 0.75 ng/dscm. Between these upper and lower limit values, the limit will be ten times the average of the eight quarterly D/F SCR efficiency and stack test results conducted during the first two years of PBREF-2 operation. For example, if the average of these tests is 0.50 ng/dscm then the limit will be set by the Department at 5.0 ng/dscm, while if the average of the stack tests is 1.2 ng/dscm then the limit will be set at the upper limit value of 10.0 ng/dscm.

If the D/F average emissions based on the SCR efficiency and stack tests is 0.05 ng/dscm or less, then the D/F emission limit shall be set at 0.74 ng/dscm as a non-PSD/BACT limit. The D/F emission limit shall be established prior to incorporation of this air construction permit into the facility's Title V operating permit.
[40 CFR 60.52b(c); Rules 62-4.070(3), 62-210.200 (BACT) and 62-212.400 (PSD), F.A.C.]
23. **Continuous Compliance:** The permittee shall demonstrate continuous compliance with the CO, NO_x and SO₂ concentration and mass emission standards and the long-term Hg mass emissions standard based on data collected by the certified CEMS. The permittee shall demonstrate continuous compliance with the opacity limit based on data collected by the required COMS.
[Rule 62-210.200 (BACT), F.A.C. and 40 CFR 60, Subpart Eb]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

EXCESS EMISSIONS

{Permitting Note: Specific Conditions 24, 25 and 26 apply to the State Implementation Plan (SIP)-based emissions standards specified in Specific Condition 16 of this subsection. Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal provision of the NSPS, or Acid Rain programs.}

24. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.]
25. Emission Limit Compliance and Excess Emissions: Because of the long-term nature of the 12-month NO_x and 12-month Hg concentration limits as part of PSD and the associated BACT determination, all emissions data for these pollutants/averaging times, including periods of startup, shutdown and malfunction, shall be included in compliance determinations based on CEMS data. [Rule 62-210.700(4), 62-210.200(PTE); [Rule 62-212.400(10) (PSD), Control Technology Review; and Rule 62-4.070(3), F.A.C.]
26. Excess Emissions Allowed: As specified in this condition, excess emissions resulting from startup, shutdown and documented malfunctions are allowed for the 24-hour NO_x and 30-day CO rolling concentration and mass limit provided that operators employ the best operational practices to minimize the amount and duration of emissions during such incidents. NO_x and CO emission data exclusions resulting from startup, shutdown, or documented malfunctions shall not exceed three hours in any 24-hour period. A “documented malfunction” means a malfunction that is documented within one working day of detection by contacting the Compliance Authority by telephone, facsimile transmittal, or electronic mail.
27. Regulations Pursuant to 40 CFR 60, Subpart Eb: The following provisions apply to the emissions limits given in **Specific Condition 16** of this subsection that were specified pursuant to 40 CFR 60, Subpart Eb.
 - a. *The opacity standards* set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard. [40 CFR 60.11(c)]
 - b. *Startup, Shutdown and Malfunction*: Except as provided by 40 CFR 60.56b, the standards under 40 CFR 60, Subpart Eb, as incorporated in Rule 62-204.800(8)(b), F.A.C., apply at all times except during periods of startup, shutdown, or malfunction. Duration of startup or shutdown periods are limited to 3 hours per occurrence, except as provided in 40 CFR 60.58b(a)(1)(iii). During periods of startup, shutdown, or malfunction, monitoring data shall be dismissed or excluded from compliance calculations, but shall be recorded and reported in accordance with the provisions of 40 CFR 60.59b(d)(7).
 - i. The startup period commences when the affected facility begins the continuous burning of municipal solid waste and does not include any warm-up period when the affected facility is combusting fossil fuel or other non-municipal solid waste fuel, and no municipal solid waste is being fed to the combustor.
 - ii. Continuous burning is the continuous, semi-continuous, or batch feeding of municipal solid waste for purposes of waste disposal, energy production, or providing heat to the combustion system in preparation for waste disposal or energy production. The use of municipal solid waste solely to provide thermal protection of the grate or hearth during the startup period when municipal solid waste is not being fed to the grate is not considered to be continuous burning.
[40 CFR 60.58b(a)]
 - c. *Special Provisions for CO*: For the purpose of compliance with the carbon monoxide emission limits in 40 CFR 60.53b(a), if a loss of boiler water level control (e.g., loss of combustion air fan, induced draft fan, combustion grate bar failure) is determined to be a malfunction, the duration of the malfunction period is limited to 15 hours per occurrence. [40 CFR 60.58b(a)(1)(iii)]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

CONTINUOUS MONITORING REQUIREMENTS

28. **CEM Systems:** The permittee shall install, calibrate, maintain, and operate CEMS to measure and record the emissions of CO, NO_x, Hg and SO₂ from each MWC unit in a manner sufficient to demonstrate continuous compliance with the CEMS emission standards given in **Specific Condition 16** of this subsection. For additional details see Appendix CEMS of this permit.
- CO CEMS:** CO CEMS shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A and shall comply with all requirements of 40 CFR 60.58b. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, and reported semiannually to the Compliance Authority. The required RATA tests shall be performed using EPA Method 10 in Appendix A of 40 CFR 60 and shall be based on a continuous sampling train. The CO monitor span values shall be set appropriately, considering the allowable methods of operation and corresponding emission standards.
 - NO_x CEMS:** NO_x CEMS shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 2 and shall comply with all requirements of 40 CFR 60.58b. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, and reported semiannually to the Compliance Authority. The required RATA tests shall be performed using EPA Method 7E in Appendix A of 40 CFR 60. The NO_x monitor span values shall be set appropriately, considering the allowable methods of operation and corresponding emission standards.
 - SO₂ CEMS:** SO₂ CEMS shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 2 and shall comply with all requirements of 40 CFR 60.58b. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F. The required RATA tests shall be performed using EPA Method 6C in Appendix A of 40 CFR 60. The SO₂ monitor span values shall be set appropriately, considering the expected range of emissions and corresponding emission standards.
 - Hg CEMS:** Hg CEMS shall be certified pursuant to the requirements in Performance Specification 12A (PS-12A), "Specifications and Test Procedures for Total Vapor Phase Mercury Continuous Monitoring Systems in Stationary Sources," or that has passed verification tests conducted under the auspices of the U.S. Environmental Protection Agency's (EPA) Environmental Technology Verification (ETV) Program. Changes from these standards with regard to data availability of the Hg CEMS are given in Appendix CEMS, along with the method to fill in data during times of Hg CEMS unavailability. After certification the owner or operator will begin reporting Hg concentration emissions data. The owner or operator shall adhere to the calibration drift and quarterly performance evaluation procedures and ongoing data quality assurance procedures in 40 CFR Part 60, Appendix F or 40 CFR Part 75, Appendix B. The mass emissions shall be estimated based on the actual data collected no later than 30 days following the end of the month. The mercury monitoring data results shall be submitted quarterly. The CEMS shall only be used as the method of compliance for the annual mass emission rate.
 - Diluent Monitor:** A continuous emission monitoring system for measuring the oxygen content of the flue gas at each location where carbon monoxide, sulfur dioxide, nitrogen oxides emissions are monitored shall be installed, calibrated, maintained, and operated in accordance with the requirements of 40 CFR 60.58b.
29. **COMS:** A continuous opacity monitoring system (COMS) shall be installed, calibrated, operated, and maintained in exhaust flue of each MWC unit in a manner sufficient to demonstrate continuous compliance with the opacity standard specified in this section. Opacity shall be based on a 6-minute block average computed from at least one observation (measurement) every 15 seconds. For the COMS, the 6-minute block averages shall begin at the top of each hour. The COMS shall meet the applicable requirements of 40 CFR 60.58b(c)(8).
30. **Continuous Flow Monitor:** A continuous flow monitor shall be installed to determine the stack exhaust flow rate to be used in determining mass emission rates. The flow monitor shall be certified pursuant to 40 CFR

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

60, Appendix B, Performance Specification 6.

[Rules 62-210.200(BACT), 62-204.800(8), and 62-4.070(1) and (3), F.A.C.]

OTHER MONITORING REQUIREMENTS

31. **Pressure Drop:** The permittee shall maintain and calibrate a device which continuously measures and records the pressure drop across each baghouse compartment controlling the PM, sorbent and powdered activated carbon (PAC) emissions for each MWC unit. Records shall be maintained on site and made available upon request. [Rule 62-4.070(3), F.A.C.]
32. **Bag Leak Detection:** The permittee shall maintain continuous operation of bag leak detection systems on each baghouse for each MWC unit including keeping records of the systems measurements. Baghouse leak detection records shall be kept on site and made available upon request. [Rule 62-4.070(3), F.A.C.]
33. **SCR NH₃ or Urea Injection:** In accordance with the manufacturer's specifications, the permittee shall install, calibrate, operate and maintain a flow meter to measure and record the NH₃ or urea injection rate for the SCR system on each MWC unit. The permittee shall document the general range of NH₃ or urea flow rates required to meet the NO_x standard over the range of load conditions by comparing NO_x emissions with NH₃ or urea flow rates. During NO_x CEMS downtimes or malfunctions, the permittee shall operate at an NH₃ or urea flow rate that is consistent with the documented flow rate for the given load condition. Records shall be maintained on site and made available upon request. [Rule 62-4.070(3), F.A.C.]
34. **Activated CI:** In accordance with the manufacturer's specifications, the permittee shall install, calibrate, operate and maintain a mass flow meter to measure and record the activated CI rate (lb/hour) for each MWC unit. The permittee shall document the general range of activated CI mass flow rates required to meet the Hg standard over the range of load conditions by comparing Hg emissions with activated CI mass flow rates. During Hg CEMS downtimes or malfunctions, the permittee shall operate at the activated CI mass flow rate that is consistent with the documented flow rate for the given load condition. Records shall be maintained on site and made available upon request. [Rule 62-4.070(3), F.A.C.]

REPORTING AND RECORD KEEPING REQUIREMENTS

35. **Segregated Solid Waste Record Keeping:** The following records shall be made and kept to demonstrate compliance with the segregated non-MSW percentage limitations of **Specific Condition 12** of this subsection:
 - a. Each segregated load of non-MSW materials, subject to the percentage weight limitations of **Specific Condition 12** of this subsection, which is received for processing, shall be documented as to waste description and weight. The weight of all waste materials received for processing shall be measured and recorded using the facility truck scale.
 - b. Each day the total weight of segregated tires received shall be computed, and the daily total shall be added to the sum of the daily totals from the previous days in the current calendar month. At the end of each calendar month, the resultant monthly total weight of tires shall be divided by the total weight of all waste materials received in the same calendar month, and the resultant number shall be multiplied by 100 to express the ratio in percentage terms. The percentage computed shall be compared to the 3% limitation.
 - c. Each day the total weight of segregated non-MSW materials received that are subject to the 5% restriction shall be computed, and the daily total shall be added to the sum of the daily totals from the previous days in the current calendar month. At the end of each calendar month, the resultant monthly total weight of segregated non-MSW materials subject to the 5% restriction shall be divided by the total weight of all waste materials received in the same calendar month, and the resultant number shall be multiplied by 100 to express the ratio in percentage terms. The percentage computed shall be compared to the 5% limitation.

[Rules 62-4.070(1) and (3), and 62-210.200(BACT), F.A.C.]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT PERMIT)

A. Municipal Solid Waste Combustors (MWC) Units 1, 2, and 3 (EU Nos. 024, 025 and 026)

36. Stack Test Reports: The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Compliance Authority on the results of each such test. The required test report shall be filed with the Compliance Authority as soon as practical but no later than 45 days after the last sampling run of each test is completed. The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Compliance Authority to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the specified in Rule 62-297.310(8), F.A.C. [Rule 62-297.310(8), F.A.C.]
37. Malfunction Notifications: If temporarily unable to comply with any condition of the permit due to breakdown of equipment (malfunction) or destruction by hazard of fire, wind or by other cause, the permittee shall immediately (within one working day) notify the Compliance Authority. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules. If requested by the Compliance Authority, the owner or operator shall submit a quarterly written report describing the malfunction. [Rules 62-210.700(6) and 62-4.130, F.A.C.]
38. SIP Quarterly Permit Limits Excess Emissions Report: Within 30 days following the end of each calendar quarter, the permittee shall submit a report to the Compliance Authority summarizing periods of CO and NO_x emissions in excess of the BACT permit standards and the amounts of authorized data excluded following the format in Appendix XSE of this permit. Periods of startup, shutdown and malfunction shall be monitored and recorded at all times. In addition, the report shall summarize the CEMS systems monitor availability for the previous quarter.
39. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by April 1st of each year. [Rule 62-210.370, F.A.C.]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

B. Carbon and Lime Storage Silos (EU Nos. 027, 028, 029 and 030)

This section addresses the following EU.

E.U. ID No.	EU Descriptions
027	Lime Storage Silo #A
028	Lime Storage Silo #B
029	Lime Storage Silo #C
030	Activated Carbon Storage Silo

EQUIPMENT AND CONTROL TECHNOLOGY

1. Storage Silos: The permittee is authorized to construct three lime storage silos and one activated carbon storage silo. Each silo will have a volume of approximately 9,000 to 11,000 cubic feet.
2. FF Baghouses: Each storage silo will be equipped with its own FF baghouse to control PM emissions. Each baghouse shall be designed, operated and maintained to achieve a PM mass emission rate of 0.01 grains per dry standard cubic foot (gr/dscf) or less. The baghouses shall be operated during all silo filling operations.

PERFORMANCE REQUIREMENTS AND EMISSION STANDARDS

3. Hours of Operation: These EU may operate continuously (8,760 hours/year). [Rules 62-4.160(2) and 62-210.228(PTE), F.A.C.]
4. FF Baghouse PM Emission Standard: PM emissions from each storage silo baghouse shall not exceed 0.010 gr/dscf. [Application No. 0990234-017-AC; Rules 62-4.070(3), 62-212.400 (BACT), 62-210.200(PTE) and 62-4.070, F.A.C.]
5. FF Baghouse PM Standard by Opacity Measurement: A visible emission reading of 5% opacity or less may be used to demonstrate compliance with the PM emission standard in **Specific Condition 4** above. A visible emission reading greater than 5% opacity will require the permittee to perform a PM emissions stack test within 60 days to show compliance with the PM standard. [Application No. 0990234-017-AC; Rules 62-296.603; 62-296.712, 62-4.070 and 62-212.400 (BACT) F.A.C.; and 40 CFR 60.122(a)(2)]
{Permitting Note: The baghouses are designed to control PM emissions to 0.010 gr/dscf. The 5% opacity limitation is consistent with this design and provides reasonable assurance that annual emissions of PM/PM₁₀/PM_{2.5} for EU will be less than 0.1 TPY.}
6. Fugitive Emissions Limits: Fugitive emissions are limited to 10% opacity from any emissions point not controlled by a FF baghouse. [Rule 62-070(3), F.A.C.]
7. Best Management Practices to Control Unconfined Emissions of PM: To ensure the emission standards with regard to opacity and PM of this subsection are complied with, the procedures set forth in **Specific Condition 10** of **Section II** of this permit, "Unconfined Emissions of Particulate Matter," shall be adhered to where practical and cost effective. [Application No. 0990234-017-AC; Rules 62-4.070, 62-296.320 and 62-212.400 (BACT) F.A.C.]

TESTING AND MONITORING REQUIREMENTS

8. Compliance Demonstrations: Each emission point shall be tested to demonstrate initial compliance with the emission standards for visible emissions given in **Specific Conditions 5 and 6** of this subsection in accordance with EPA Method 9. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the initial startup. Thereafter, compliance with the visible emission limits for each emission point shall be demonstrated during each federal fiscal year (October 1st to September 30th). As specified in **Specific Condition 5** of this

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

B. Carbon and Lime Storage Silos (EU Nos. 027, 028, 029 and 030)

subsection, a PM test must be conducted on a FF baghouse of a storage silos with 60 days of its failure in meeting the VE standard. [Rules 62-4.070(3), and 62-297.310(7)(a), F.A.C.]

9. **Test Methods:** Any required tests shall be performed in accordance with the following reference methods and the applicable requirements of Appendix CTR of this permit.

EPA Method	Description of Method and Comments
5	Determination of Particulate Emissions. The minimum sample volume shall be 30 dry standard cubic feet.
9	Visual Determination of the Opacity of Emissions from Stationary Sources

REPORTING AND RECORD KEEPING

10. **Baghouse O&M Plan:** For each baghouse the permittee shall prepare an operation and maintenance (O&M) plan to address proper operation, parametric monitoring, and a schedule for conducting periodic inspections and preventive maintenance. Baghouse inspections and maintenance activities shall be recorded in a written log. The O&M plan shall be submitted to the Compliance Authority prior to the initial compliance tests for these EU. [Rule 62-4.070(3), F.A.C.]
11. **Test Reports:** The permittee shall prepare and submit reports for all required tests in accordance with the requirements specified in Appendix CTR (Common Testing Requirements) of this permit. For each test run, the report shall also indicate the operating rate. [Rule 62-297.310(8), F.A.C.]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

C. Diesel Fire Pump Engines (EU Nos. 031 and 032)

This section of the permit addresses the following EU.

EU ID No.	Emission Unit Description
031	One emergency diesel firewater pump engine with a maximum design rating of 250 hp
032	One emergency diesel firewater pump engine with a maximum design rating of 250 hp

NSPS AND NESHAP APPLICABILITY

1. **NSPS Subpart IIII Applicability:** Each pump engine is an Emergency Stationary Compression Ignition Internal Combustion Engine (Stationary ICE) and shall comply with applicable provisions of 40 CFR 60, Subpart IIII. [40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines]
2. **NESHAP Subpart ZZZZ Applicability:** The emergency pump engines are Liquid Fueled Reciprocating Internal Combustion Engines (RICE) and shall comply with applicable provisions of 40 CFR 63, Subpart ZZZZ. Pursuant to 40 CFR 63.6590(c) the engines must meet the requirements of Subpart ZZZZ by meeting the requirements of 40 CFR 60, Subpart IIII. [40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)]

EQUIPMENT SPECIFICATIONS

3. **Engine Driven Fire Pumps:** The permittee is authorized to install, operate, and maintain two emergency diesel fire pump engines. The pump engines will each have a maximum rating of 250 hp (186 kW) or smaller. [Application No. 0990234-017-AC and Rules 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.]
4. **ULSD Fuel Oil Storage Tank:** The permittee is authorized to construct a 1,000 gallon tank to store ULSD fuel oil for use in the emergency diesel firewater pump engines. [Rule 62-4.070(3), F.A.C.]
{Permitting Note: The ULSD fuel oil storage tank for the emergency diesel firewater pump engines at the PBREF2 facility is not subject to NSPS Subpart Kb because it stores a liquid (ULSD fuel oil) with a maximum true vapor pressure less than 3.5 kPa (0.51 pounds per square inch (psi)). Accordingly it is an unregulated emissions unit.}
[40 CFR 60.110b(a) and (c) and Rule 62-204.800(7)(b), F.A.C.]

PERFORMANCE RESTRICTIONS

5. **Hours of Operation:** Each fire pump engine may operate up to 100 hours per year for maintenance and testing purposes. The duration of each maintenance and testing event for each pump engine shall not exceed 30 minutes in any hour, and shall not be conducted concurrently with maintenance and testing of the other pump engine nor the emergency generator diesel engine. [Application No. 0990234-017-AC; Rules 62-210.200 (PTE) and 62-212.400 (BACT), F.A.C.]
6. **Authorized Fuel:** Each pump engine shall fire ULSD fuel oil. The ULSD fuel oil shall contain no more than 0.0015% sulfur by weight. [Application No. 0990234-017-AC; Rules 62-210.200 (PTE) and 62-212.400 (BACT), F.A.C.]

EMISSION STANDARDS

7. **Emissions Limits:** The emergency fire pump engines shall comply with the following emission limits and demonstrate compliance in accordance with the procedures given in 40 CFR 60, Subpart IIII. Manufacturer certification may be provided to the Department in lieu of actual testing. [40 CFR 60.4211 and Rule 62-4.070(3), F.A.C.]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

C. Diesel Fire Pump Engines (EU Nos. 031 and 032)

Emergency Pumps (175 hp ≤ and < 300 hp)	CO (g/hp-hr) ¹	PM (g/hp-hr)	SO₂ (% S) ²	NMHC³+NO_x (g/hp-hr)
Subpart IIII (2009 and later)	2.6	0.15	0.0015	3.0

1. g/hp-hr means grams per horsepower-hour.
2. SO₂ emission standard will be met by using ULSD fuel oil in the fire pump engines with fuel sulfur (S) content of 0.0015% by weight.
3. Non-Methane Hydrocarbons

[Application No. 0990234-017-AC; 40 CFR 60, NSPS Subpart IIII; and Rules 62-4.070(3) and 62-212.400 (BACT), F.A.C.]

RECORDS AND REPORTS

8. Notification, Recordkeeping and Reporting Requirements: The permittee shall adhere to the compliance testing and certification requirements listed in 40 CFR 60.4211 and maintain records demonstrating fuel usage and quality. [Rule 62-212.400 (BACT), F.A.C. and 40 CFR 60.4211]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

D. Emergency Generator (EU-033)

This section of the permit addresses the following emissions units.

EU ID No.	Emission Unit Description
033	One emergency diesel generator with a maximum design rating of 250 kW

NSPS AND NESHAP APPLICABILITY

1. NSPS Subpart III Applicability: This emergency generator is a Stationary Compression Ignition Internal Combustion Engine (Stationary ICE) and shall comply with applicable provisions of 40 CFR 60, Subpart III, including emission testing or certification. [40 CFR 60, Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines]
2. NESHAPS Subpart ZZZZ Applicability: The emergency generator is a Liquid Fueled Reciprocating Internal Combustion Engine (RICE) and shall comply with applicable provisions of 40 CFR 63, Subpart ZZZZ. Pursuant to 40 CFR 63.6590(c) the generators must meet the requirements of Subpart ZZZZ by meeting the requirements of 40 CFR 60, Subpart III. [40 CFR 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)]

EQUIPMENT

3. Emergency Generator: The permittee is authorized to install, operate and maintain one emergency generator with a maximum design rating of 250 kW (335 hp) or smaller. [Application No. 0990234-017-AC and Rules 62-210.200 (PTE) and 62-212.400 (BACT), F.A.C.]
4. ULSD Fuel Oil Storage Tank: The permittee is authorized to construct a 1,000 gallon tank to store ULSD fuel oil for use in the emergency diesel generator. [Rule 62-4.070(3), F.A.C.]

{Permitting Note: The ULSD fuel oil storage tank for the emergency diesel generator at PBREF No. 2 is not subject to NSPS Subpart Kb because it stores a liquid (ULSD fuel oil) with a maximum true vapor pressure less than 3.5 kPa (0.51 pounds per square inch (psi)). Accordingly it is an unregulated emissions unit.} [40 CFR 60.110b(a) and (c) and Rule 62-204.800(7)(b), F.A.C.]

PERFORMANCE RESTRICTIONS

5. Hours of Operation: The emergency generator may operate up to 100 hours per year for maintenance and testing purposes. The duration of each maintenance and testing event shall not exceed 30 minutes in any hour, and shall not be conducted concurrently with maintenance and testing of the emergency fire water pump diesel engines. [Application No. 0990234-017-AC and Rules 62-210.200 (PTE) and 62-212.400 (BACT), F.A.C.]
6. Authorized Fuel: The emergency generator shall fire ULSD fuel oil. The ULSD fuel oil shall contain no more than 0.0015% sulfur by weight. [Application No. 0990234-017-AC and Rules 62-210.200 (PTE) and 62-212.400 (BACT), F.A.C.]

EMISSION STANDARDS

7. Emissions Limits: The emergency generator shall comply with the following emission limits and demonstrate compliance in accordance with the procedures given in 40 CFR 60, Subpart III. Manufacturer certification can be provided to the Department in lieu of actual stack testing.

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

D. Emergency Generator (EU-033)

Emergency Generator (225 kW ≤ and < 450 kW)	CO (g/kW-hr)¹	PM (g/kW-hr)	SO₂² (% S)	NMHC³+NO_x (g/kW-hr)
Subpart III (2007 and later)	3.5	0.20	0.0015	4.0

1. g/kW-hr means grams per kilowatt-hour.
2. SO₂ emission standard will be met by using ULSD fuel oil in the emergency generator with fuel sulfur (S) content of 0.0015% by weight.
3. NMHC means Non-Methane Hydrocarbons.

[Application No. 0990234-017-AC, NSPS Subpart III; and Rules 62-4.070(3) and 62-212.400 (BACT), F.A.C.]

RECORDS AND REPORTS

8. Notification, Recordkeeping and Reporting Requirements: The permittee shall adhere to the compliance testing and certification requirements listed in 40 CFR 60.4211 and maintain records demonstrating fuel usage and quality. [40 CFR 60.4211]

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

E. Ash Handling System and Building (EU No. 034)

This section of the permit addresses the following EU.

EU ID No.	Emission Unit Description
034	Ash Handling System and Building

EQUIPMENT

1. Ash Handling Building: The permittee is authorized to install, operate, and maintain the ash handling system and building for handling bottom ash from the MWC units and fly ash from the FF baghouses.
2. Enclosed Conveyor System: The permittee is authorized to construct an enclosed conveyor system to transport collected ash from the boiler and air pollution control buildings to the ash management building.
3. Ash Processing Equipment: Within the ash handling building, the permittee is authorized to construct ash processing equipment including ferrous and non-ferrous recovery systems.
4. FF Baghouse: To minimize particulate matter emissions from the ash handling equipment, the permittee shall construct a FF baghouse through which air from the ash handling building will be routed to prior to discharge to the atmosphere.

{Permitting Note: To minimize fugitive particulate matter emissions from the ash handling equipment, ash (bottom and fly) will be wetted to a moisture content of approximate of 20 to 25 percent.}

[Applicant Request and Rule 62-210.200(PTE), F.A.C.]

EMISSIONS AND PERFORMANCE REQUIREMENTS

5. Fugitive Ash Emissions:
 - (a) On and after the date on which the initial performance test is completed or is required to be completed under 40 CFR 60.8 of Subpart A, no owner or operator of an affected facility shall cause to be discharged to the atmosphere visible emissions of combustion ash from an ash conveying system (including conveyor transfer points) in excess of 5 percent of the observation period (i.e., 9 minutes per 3-hour period), as determined by EPA Reference Method 22 observations as specified in 40 CFR 60.58b(k), except as provided in paragraphs (b) and (c) below.
 - (b) The emission limit specified in (a) above does not cover visible emissions discharged inside buildings or enclosures of ash conveying systems; however, the emission limit specified in (a) above does cover visible emissions discharged to the atmosphere from buildings or enclosures of ash conveying systems.
 - (c) The provisions of (a) above do not apply during maintenance and repair of ash conveying systems.[40 CFR 60.36b and 40 CFR 60.55b]
6. Testing for Fugitive Ash Emissions: The procedures specified in (1) through (4) below shall be used for determining compliance with the fugitive ash emission limit under 40 CFR 60.55b.
 - (1) The EPA Reference Method 22 shall be used for determining compliance with the fugitive ash emission limit under 40 CFR 60.55b. The minimum observation time shall be a series of three 1-hour observations. The observation period shall include times when the facility is transferring ash from the municipal waste combustor unit to the area where ash is stored or loaded into containers or trucks.
 - (2) The average duration of visible emissions per hour shall be calculated from the three 1-hour observations. The average shall be used to determine compliance with 40 CFR 60.55b.
 - (3) The owner or operator of an affected facility shall conduct an initial performance test for fugitive ash emissions as required under 40 CFR 60.8.
 - (4) Following the date that the initial performance test for fugitive ash emissions is completed or is required to be completed under Sec. 60.8 for an affected facility, the owner or operator shall conduct a

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

E. Ash Handling System and Building (EU No. 034)

performance test for fugitive ash emissions on an annual basis (no more than 12 calendar months following the previous performance test).

[40 CFR 60.38b and 40 CFR 60.58b(k)]

- 7. **Ash Handling FF Baghouse PM Emission Standard:** PM emissions from the baghouse of the ash handling building shall not exceed 0.010 gr/dscf. [Rules 62-4.070(3), 62-212.400 (BACT), 62-210.200(PTE) and 62-4.070, F.A.C.]
- 8. **Baghouse PM Standard by Opacity Measurement:** A visible emission reading of 5% opacity or less may be used to demonstrate compliance with the PM emission standard in **Specific Condition 7** above. A visible emission reading greater than 5% opacity will require the permittee to perform a PM emissions stack test within 60 days to show compliance with the PM standard.
[Rules 62-296.603; 62-296.712, 62-4.070 and 62-212.400 (BACT) F.A.C.; and 40 CFR 60.122(a)(2)]

TESTING AND MONITORING REQUIREMENTS

- 9. **Initial Compliance Tests:** The bottom and fly ash conveyors, transfer points, drop points, hoppers, chutes and dust collectors associated with this emission unit shall be tested to demonstrate initial compliance with the VE standards specified in **Specific Condition 5** of this subsection. The ash handling building FF baghouse shall be tested to demonstrate initial compliance with the VE standard specified in **Specific Condition 8** of this subsection. The initial tests shall be conducted within 180 days after initial operation.
[Rules 62-297.310(7)(a)1., F.A.C. and 62-4.070(3), F.A.C.]
- 10. **Annual Compliance Tests:** During each federal fiscal year (October 1st to September 30th), the bottom and fly ash conveyors, transfer points, drop points, hoppers, chutes and dust collectors associated with this emission unit shall be tested to demonstrate compliance with the VE emissions standards specified in **Specific Condition 5** of this subsection. During each federal fiscal year (October 1st to September 30th), the ash handling building FF baghouse shall be tested to demonstrate compliance with the VE emissions standard specified in **Specific Condition 8** of this subsection.
[Rules 62-297.310(7)(a)4, 62-212.400 (BACT) and 62-4.070(3), F.A.C.]
- 11. **Ash Handling Building FF Baghouse PM Compliance Test:** The initial and annual VE tests in **Specific Conditions 9 and 10** of this subsection with regard to the ash handling building FF baghouse shall serve as a surrogate for the PM emissions tests. If the VE emissions standard in **Specific Condition 8** of this subsection is not met for the ash handling building FF baghouse, a PM test utilizing EPA Method 5 must be conducted on the baghouse stack to show compliance with the PM emissions standard in **Specific Condition 7** of this subsection within 60 days. [Rule 62-297.620(4), F.A.C.]
- 12. **Bag Leak Detection:** The permittee shall maintain continuous operation of bag leak detection systems, including records, on the ash handling building FF baghouse. Baghouse leak detection records shall be kept on site and made available upon request. [Rule 62-4.070(3), F.A.C.]
- 13. **Test Methods:** Any required tests shall be performed in accordance with the following methods.

EPA Method	Description of Method and Comments
5	Determination of Particulate Emissions. The minimum sample volume shall be 30 dry standard cubic feet.
22	Fugitive Opacity

SECTION 3. EMISSIONS UNIT SPECIFIC CONDITIONS (DRAFT)

E. Ash Handling System and Building (EU No. 034)

RECORDS AND REPORTS

14. Test Reports: The permittee shall prepare and submit reports for all required tests in accordance with the requirements specified in Appendix CTR (Common Testing Requirements) of this permit. For each test run, the report shall also indicate the operating rate. [Rule 62-297.310(8), F.A.C.]

DRAFT

SECTION 4. APPENDICES

CONTENTS

The following Appendices are part of this permit and the permittee must comply with the requirements of each appendix.

Appendix A	Identification of General Provisions - NSPS 40 CFR 60, Subpart A;
Appendix A1	General Provisions - NSPS 40 CFR 63, Subpart A;
Appendix CC	Common Conditions;
Appendix CEMS	Continuous Emissions Monitoring System (CEMS) Requirements;
Appendix CF	Citation Formats and Glossary of Common Terms;
Appendix CTR	Common Testing Requirements;
Appendix Eb	NSPS, 40 CFR 60, Subpart Eb - Standards of Performance for Large Municipal Waste Combustors;
Appendix GC	General Conditions;
Appendix IIII	NSPS, 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines;
Appendix XSE	Excess Emission Reporting Form; and,
Appendix ZZZZ	NESHAP, 40 CFR 63, Subpart ZZZZ –Stationary Reciprocating Internal Combustion Engines.

SECTION 4. APPENDIX A
NSPS SUBPART A – GENERAL PROVISIONS

The owner or operator of PBREF-2 shall comply with all applicable provisions of 40 CFR 60 Subpart A, which is available at the following link:

[Link to NSPS Subpart A](#)

DRAFT

SECTION 4. APPENDIX A1
NESHAP SUBPART A – GENERAL PROVISIONS

The owner or operator of PBREF-2 shall comply with all applicable provisions of 40 CFR 63 Subpart A, which is available at the following link:

[Link to NESHAP Subpart A](#)

DRAFT

SECTION 4. APPENDIX CC

COMMON CONDITIONS

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at the PBREF-2.

EMISSIONS AND CONTROLS

1. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. [Rule 62-4.130, F.A.C.]
2. Circumvention: The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C.]
3. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed 2 hours in any 24-hour period unless specifically authorized by the Department for longer duration. Pursuant to Rule 62-210.700(5), F.A.C., the permit subsection may specify more or less stringent requirements for periods of excess emissions. Rule 62-210-700(Excess Emissions), F.A.C., cannot vary or supersede any federal NSPS or NESHAP provision. [Rule 62-210.700(1), F.A.C.]
4. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]
5. Excess Emissions - Notification: In case of excess emissions resulting from malfunctions, the permittee shall notify the Compliance Authority in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]
6. VOC or OS Emissions: No person shall store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]
7. Objectionable Odor Prohibited: No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rules 62-296.320(2) and 62-210.200(Definitions), F.A.C.]
8. General Visible Emissions: No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b)1, F.A.C.]
9. Unconfined Particulate Emissions: No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction, alteration, demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary.

SECTION 4. APPENDIX CC

COMMON CONDITIONS

[Rule 62-296.320(4)(c), F.A.C.]

RECORDS AND REPORTS

10. Records Retention: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least 5 years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request. [Rule 62-213.440(1)(b)2, F.A.C.]
11. Emissions Computation and Reporting:
 - a. *Applicability*. This rule sets forth required methodologies to be used by the owner or operator of a facility for computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for computing emissions for purposes of the reporting requirements of subsection 62-210.370(3) and paragraph 62-212.300(1)(e), F.A.C., or of any permit condition that requires emissions be computed in accordance with this rule. This rule is not intended to establish methodologies for determining compliance with the emission limitations of any air permit.
 - b. *Computation of Emissions*. For any of the purposes set forth in subsection 62-210.370(1), F.A.C., the owner or operator of a facility shall compute emissions in accordance with the requirements set forth in this subsection.
 - (1) *Basic Approach*. The owner or operator shall employ, on a pollutant-specific basis, the most accurate of the approaches set forth below to compute the emissions of a pollutant from an emissions unit; provided, however, that nothing in this rule shall be construed to require installation and operation of any continuous emissions monitoring system (CEMS), continuous parameter monitoring system (CPMS), or predictive emissions monitoring system (PEMS) not otherwise required by rule or permit, nor shall anything in this rule be construed to require performance of any stack testing not otherwise required by rule or permit.
 - (a) If the emissions unit is equipped with a CEMS meeting the requirements of paragraph 62-210.370(2)(b), F.A.C., the owner or operator shall use such CEMS to compute the emissions of the pollutant, unless the owner or operator demonstrates to the department that an alternative approach is more accurate because the CEMS represents still-emerging technology.
 - (b) If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C, but emissions of the pollutant can be computed pursuant to the mass balance methodology of paragraph 62-210.370(2)(c), F.A.C., the owner or operator shall use such methodology, unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
 - (c) If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., and emissions cannot be computed pursuant to the mass balance methodology, the owner or operator shall use an emission factor meeting the requirements of paragraph 62-210.370(2)(d), F.A.C., unless the owner or operator demonstrates to the department that an alternative approach is more accurate.
 - (2) *Continuous Emissions Monitoring System (CEMS)*.
 - (a) An owner or operator may use a CEMS to compute emissions of a pollutant for purposes of this rule provided:
 - 1) The CEMS complies with the applicable certification and quality assurance requirements of 40 CFR Part 60, Appendices B and F, or, for an acid rain unit, the certification and quality assurance requirements of 40 CFR Part 75, all adopted by reference at Rule 62-204.800, F.A.C.; or

SECTION 4. APPENDIX CC

COMMON CONDITIONS

- 2) The owner or operator demonstrates that the CEMS otherwise represents the most accurate means of computing emissions for purposes of this rule.
 - (b) Stack gas volumetric flow rates used with the CEMS to compute emissions shall be obtained by the most accurate of the following methods as demonstrated by the owner or operator:
 - 1) A calibrated flowmeter that records data on a continuous basis, if available; or
 - 2) The average flow rate of all valid stack tests conducted during a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
 - (c) The owner or operator may use CEMS data in combination with an appropriate f-factor, heat input data, and any other necessary parameters to compute emissions if such method is demonstrated by the owner or operator to be more accurate than using a stack gas volumetric flow rate as set forth at subparagraph 62-210.370(2)(b)2., F.A.C., above.
- (3) Mass Balance Calculations.
- (a) An owner or operator may use mass balance calculations to compute emissions of a pollutant for purposes of this rule provided the owner or operator:
 - 1) Demonstrates a means of validating the content of the pollutant that is contained in or created by all materials or fuels used in or at the emissions unit; and
 - 2) Assumes that the emissions unit emits all of the pollutant that is contained in or created by any material or fuel used in or at the emissions unit if it cannot otherwise be accounted for in the process or in the capture and destruction of the pollutant by the unit's air pollution control equipment.
 - (b) Where the vendor of a raw material or fuel which is used in or at the emissions unit publishes a range of pollutant content from such material or fuel, the owner or operator shall use the highest value of the range to compute the emissions, unless the owner or operator demonstrates using site-specific data that another content within the range is more accurate.
 - (c) In the case of an emissions unit using coatings or solvents, the owner or operator shall document, through purchase receipts, records and sales receipts, the beginning and ending VOC inventories, the amount of VOC purchased during the computational period, and the amount of VOC disposed of in the liquid phase during such period.
- (4) Emission Factors.
- a. An owner or operator may use an emission factor to compute emissions of a pollutant for purposes of this rule provided the emission factor is based on site-specific data such as stack test data, where available, unless the owner or operator demonstrates to the department that an alternative emission factor is more accurate. An owner or operator using site-specific data to derive an emission factor, or set of factors, shall meet the following requirements.
 - 1) If stack test data are used, the emission factor shall be based on the average emissions per unit of input, output, or gas volume, whichever is appropriate, of all valid stack tests conducted during at least a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
 - 2) Multiple emission factors shall be used as necessary to account for variations in emission rate associated with variations in the emissions unit's operating rate or operating conditions during the period over which emissions are computed.

SECTION 4. APPENDIX CC

COMMON CONDITIONS

- 3) The owner or operator shall compute emissions by multiplying the appropriate emission factor by the appropriate input, output or gas volume value for the period over which the emissions are computed. The owner or operator shall not compute emissions by converting an emission factor to pounds per hour and then multiplying by hours of operation, unless the owner or operator demonstrates that such computation is the most accurate method available.
- b. If site-specific data are not available to derive an emission factor, the owner or operator may use a published emission factor directly applicable to the process for which emissions are computed. If no directly-applicable emission factor is available, the owner or operator may use a factor based on a similar, but different, process.
- (5) Accounting for Emissions During Periods of Missing Data from CEMS, PEMS, or CPMS. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of missing data from CEMS, PEMS, or CPMS using other site-specific data to generate a reasonable estimate of such emissions.
- (6) Accounting for Emissions During Periods of Startup and Shutdown. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit.
- (7) Fugitive Emissions. In computing the emissions of a pollutant from a facility or emissions unit, the owner or operator shall account for the fugitive emissions of the pollutant, to the extent quantifiable, associated with such facility or emissions unit.
- (8) Recordkeeping. The owner or operator shall retain a copy of all records used to compute emissions pursuant to this rule for a period of five years from the date on which such emissions information is submitted to the department for any regulatory purpose.
- c. *Annual Operating Report for Air Pollutant Emitting Facility*
 - (1) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year for the following facilities:
 - (a) All Title V sources.
 - (b) All synthetic non-Title V sources.
 - (c) All facilities with the potential to emit ten (10) tons per year or more of volatile organic compounds or twenty-five (25) tons per year or more of nitrogen oxides and located in an ozone nonattainment area or ozone air quality maintenance area.
 - (d) All facilities for which an annual operating report is required by rule or permit.
 - (2) Notwithstanding paragraph 62-210.370(3)(a), F.A.C., no annual operating report shall be required for any facility operating under an air general permit.
 - (3) The annual operating report shall be submitted to the appropriate Department of Environmental Protection (DEP) division, district or DEP-approved local air pollution control program office by April 1 of the following year.
 - (4) Beginning with 2007 annual emissions, emissions shall be computed in accordance with the provisions of subsection 62-210.370(2), F.A.C., for purposes of the annual operating report.

[RULE 62-210.370, F.A.C.]

SECTION 4. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING (CEMS) REQUIREMENTS

The following conditions apply to all CEMS at the PBREF-2.

CEMS OPERATION PLAN

1. **CEMS Operation Plan:** The owner or operator shall create and implement a facility-wide plan for the proper installation, calibration, maintenance and operation of each CEMS required by this permit. The owner or operator shall submit the CEMS Operation Plan to the Bureau of Air Monitoring and Mobile Sources for approval at least 60 days prior to CEMS installation. The CEMS Operation Plan shall become effective 60 days after submittal or upon its approval. If the CEMS Operation Plan is not approved, the owner or operator shall submit a new or revised plan for approval.

{Permitting Note: The Department maintains both guidelines for developing a CEMS Operation Plan and example language that can be used as the basis for the facility-wide plan required by this permit. Contact the Emissions Monitoring Section of the Bureau of Air Monitoring and Mobile Sources at (850)488-0114.}

INSTALLATION, PERFORMANCE SPECIFICATIONS AND QUALITY ASSURANCE

2. **Timelines:**
 - a. **New and Existing Emission Units.** For new emission units, the owner or operator shall install each CEMS required by this permit prior to initial startup of the unit. The owner or operator shall conduct the appropriate performance specification for each CEMS within 90 operating days of achieving permitted capacity as defined in Rule 62-297.310(2), F.A.C., but no later than 180 calendar days after initial startup.
3. **Installation:** All CEMS shall be installed such that representative measurements of emissions or process parameters from the facility are obtained. The owner or operator shall locate the CEMS by following the procedures contained in the applicable performance specification of 40 CFR part 60, Appendix B.
4. **Span Values and Dual Range Monitors:** The owner or operator shall set appropriate span values for the CEMS. The owner or operator shall install dual range monitors if required by and in accordance with the CEMS Operation Plan.
5. **Continuous Flow Monitor:** For compliance with mass emission rate standards, the owner or operator shall install a continuous flow monitor to determine the stack exhaust flow rate. The flow monitor shall be certified pursuant to 40 CFR part 60, Appendix B, Performance Specification 6.
6. **Diluent Monitor:** If it is necessary to correct the CEMS output to the oxygen concentrations specified in this permit's emission standards, the owner or operator shall either install an oxygen monitor or install a carbon dioxide (CO₂) monitor and use an appropriate F-Factor computational approach.
7. **Moisture Correction:** If necessary, the owner or operator shall determine the moisture content of the exhaust gas and develop an algorithm to enable correction of the monitoring results to a dry basis (0% moisture).

{Permitting Note: The CEMS Operation Plan will contain additional CEMS-specific details and procedures for installation.}
8. **Performance Specifications:** The owner or operator shall evaluate the acceptability of each CEMS by conducting the appropriate performance specification, as follows. CEMS determined to be unacceptable shall not be considered installed for purposes of meeting the timelines of this permit.
 - a. **SO₂ CEMS:** The SO₂ CEMS shall be certified, operated, and maintained in accordance with the requirements of 40 CFR 60, Appendices A and F.
 - b. **CO Monitors:** For CO monitors, the owner or operator shall conduct Performance Specification 4 or 4A of 40 CFR part 60, Appendix B.

SECTION 4. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING (CEMS) REQUIREMENTS

- c. *NO_x Monitor*: For a NO_x monitor, the owner or operator shall conduct Performance Specification 2 of 40 CFR part 60, Appendix B.
 - d. *Hg Monitor*: The Hg CEMS shall be certified pursuant to the requirements in Performance Specification 12A (PS-12A), "Specifications and Test Procedures for Total Vapor phase Mercury Continuous Monitoring Systems in Stationary Sources," or that has passed verification tests conducted under the auspices of the U.S. Environmental Protection Agency's (EPA) Environmental Technology Verification (ETV) Program.
 - e. *COMS*: In accordance with 40 CFR 60.48b(a) the permittee shall install, calibrate, operate and maintain a continuous opacity monitor (COM) to continuously monitor and record opacity from the steam generating unit. The COMS shall be certified pursuant to 40 CFR 60 Appendix B, Performance Specification 1.
9. Quality Assurance: The owner or operator shall follow the quality assurance procedures of 40 CFR part 60, Appendix F.
- a. *CO Monitors*: The required relative accuracy test audit (RATA) tests shall be performed using EPA Method 10 in Appendix A of 40 CFR part 60 and shall be based on a continuous sampling train.
 - b. *NO_x Monitors*: The required RATA tests shall be performed using EPA Method 7E in Appendix A of 40 CFR part 60. NO_x shall be expressed "as NO₂."
 - c. *SO₂ Monitors*: The required RATA tests shall be performed using EPA Method 6C in Appendix A of 40 CFR part 60.
 - d. *Hg Monitors*: After certification the owner or operator will begin reporting Hg concentration emissions data. The owner or operator shall adhere to the calibration drift and quarterly performance evaluation procedures and ongoing data quality assurance procedures in 40 CFR Part 60, Appendix F or 40 CFR Part 75, Appendix B. The mass emissions shall be estimated based on the actual data collected no later than 10 days following the end of the month. The mercury monitoring data results shall be submitted quarterly. The CEMS shall only be used as the method of compliance if the owner or operator, at a minimum, meets the requirements of 40 CFR 60.58b(n). Prior to use of the Hg-CEMS as the method to demonstrate compliance, the owner or operator shall submit written notice to the Department, and receive approval for missing data substitution and a data calculation approach plans.
10. Substituting RATA Tests for Compliance Tests: Data collected during CEMS quality assurance RATA tests can substitute for annual stack tests, and vice versa, at the option of the owner or operator, provided the owner or operator indicates this intent in the submitted test protocol and follows the procedures outlined in the CEMS Operation Plan.

CALCULATION APPROACH

11. CEMS Used for Compliance: Once adherence to the applicable performance specification for each CEMS is demonstrated, the owner or operator shall use the CEMS to demonstrate compliance with the long term 12 month rolling mean emission limits for NO_x, SO₂, CO and Hg emission standards as specified by this permit.
12. CEMS Data: Each CEMS shall monitor and record emissions during all periods of operation and whenever emissions are being generated, including during episodes of startups, shutdowns, and malfunctions. All data shall be used, except for invalid measurements taken during monitor system breakdowns, repairs, calibration checks, zero adjustments and span adjustments, and except for allowable data exclusions/substitution as per **Specific Condition 19** of this appendix.

SECTION 4. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING (CEMS) REQUIREMENTS

13. Operating Hours and Operating Days: For purposes of this appendix, the following definitions shall apply. An hour is the 60-minute period beginning at the top of each hour. Any hour during which an emissions unit is in operation for more than 15 minutes is an operating hour for that emission unit. A day is the 24-hour period from midnight to midnight. Unless otherwise specified by this permit, any day with at least one operating hour for an emissions unit is an operating day for that emission unit.
14. Valid Hourly Averages: Each CEMS shall be designed and operated to sample, analyze and record data evenly spaced over the hour at a minimum of one measurement per minute. All valid measurements collected during an hour shall be used to calculate a 1-hour block average that begins at the top of each hour.
 - a. Hours that are not operating hours are not valid hours.
 - b. For each operating hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, there is insufficient data, the 1-hour block average is not valid, and the hour is considered as “monitor unavailable.”
15. Calculation Approaches: The owner or operator shall implement the calculation approach specified by this permit for each CEMS, as follows:
 - a. *Rolling 12-month average, rolled monthly*: Compliance shall be determined after each operating month by calculating the arithmetic average of all the valid hourly averages from that operating month and the prior 11 operating months.
 - b. *Rolling 30-day average*: Compliance shall be determined after each operating day by calculating the arithmetic average of all the valid hourly averages from that operating day and the prior 29 operating days.

MONITOR AVAILABILITY

16. NO_x, SO₂ and CO CEMS Availability: The quarterly excess emissions report shall identify monitor availability for each quarter in which the unit operated. Monitor availability for each CEMS, other than the Hg CEMS, shall be 95% or greater in any calendar quarter in which each unit operated for more than 760 hours. In the event the applicable availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit.
17. Initial Hg CEMS Availability: During the initial four quarters of operation, the quarterly excess emissions report shall identify Hg CEMS availability for each calendar quarter in which the unit is operated. Monitor availability for the Hg CEMS shall be 80% or greater in any of the initial four calendar quarters in which the unit operated for more than 760 hours. In the event the availability is not achieved, the permittee shall provide the Department with a report identifying the problems in achieving the required availability and a plan of corrective actions that will be taken to achieve 80% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit.
18. Subsequent Hg CEMS Availability: During subsequent calendar quarters of operation, the Hg CEMS availability shall be 85% or greater in any calendar quarter in which the unit is operated for more than 760 hours. The reporting and corrective actions along with actions that shall be considered violations of this permit are specified in **Specific Condition 17** of this appendix.

SECTION 4. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING (CEMS) REQUIREMENTS

19. Hg CEMS Unavailability Data Replacement: During times of Hg CEMS unavailability, emission data for mass emission compliance purposes shall be estimated from an Hg emission factor based on the steam production during the time of Hg CEMS availability. The pounds of Hg emitted during the time of Hg CEMS availability shall be divided by the million tons of steam produced during this same timeframe to develop an Hg emission factor of pounds Hg per million tons of steam (lb-Hg/MTS). This emission factor shall then be used during the time of Hg CEMS unavailability to estimate Hg emissions for mass emission limit compliance purposes. This emission factor shall be multiplied by the million tons of steam produced while the Hg CEMS was unavailable to estimate the mass of Hg emitted during this timeframe. The estimated Hg mass emission value shall then be added to the Hg mass emission value calculated during the time of Hg CEMS availability to determine if the Hg mass emission limit of 113 pounds on a 12 month rolling average basis has been met.

EXCESS EMISSIONS

20. Definitions:
- Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
 - Shutdown* means the cessation of the operation of an emissions unit for any purpose.
 - Malfunction* means any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.
21. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
22. Data Exclusion Procedures for SIP Compliance: As per the procedures in this condition, limited amounts of CEMS emissions data may be excluded from the corresponding compliance demonstration, provided that best operational practices to minimize emissions are adhered to and the duration of data excluded is minimized. The data exclusion procedures of this condition apply only to SIP-based emission limits.
- Excess Emissions*. Data in excess of the applicable emission standard may be excluded from compliance calculations if the data are collected during periods of permitted excess emissions (for example, during startup, shutdown or malfunction). The maximum duration of excluded data is 2 hours in any 24-hour period, unless some other duration is specified by this permit. For the CEMS on the thermal oxidizer (TO) stack, mass based excess emissions of NO_x, CO, SO₂ and Hg during periods of startup, shutdown and malfunction cannot be excluded. This is due to the long term nature (12 month rolling) of the emission limits.
 - Limited Data Exclusion*. If the compliance calculation using all valid CEMS emission data, as defined in Condition 12 of this appendix, indicates that the emission unit is in compliance, then no CEMS data shall be excluded from the compliance demonstration.
 - Event Driven Exclusion*. The underlying event (for example, the startup, shutdown or malfunction event) must precede the data exclusion. If there is no underlying event, then no data may be excluded. Only data collected during the event may be excluded.
 - Reporting Excluded Data*. The data exclusion procedures of this condition are not necessarily the same procedures used for excess emissions as defined by federal rules. Quarterly or semi-annual reports required by this permit shall indicate not only the duration of data excluded from SIP compliance calculations but also the number of excess emissions as defined by federal rules.

SECTION 4. APPENDIX CEMS

CONTINUOUS EMISSIONS MONITORING (CEMS) REQUIREMENTS

23. Notification Requirements: The owner or operator shall notify the Compliance Authority within one working day of discovering any emissions that demonstrate noncompliance for a given averaging period. Within one working day of occurrence, the owner or operator shall notify the Compliance Authority of any malfunction resulting in the exclusion of CEMS data. For malfunctions, notification is sufficient for the owner or operator to exclude CEMS data.

ANNUAL EMISSIONS

24. CEMS Used for Calculating Annual Emissions: All valid data, as defined in Condition 12 of this appendix, shall be used when calculating annual emissions.
- Annual emissions shall include data collected during startup, shutdown and malfunction periods.
 - Annual emissions shall include data collected during periods when the emission unit is not operating but emissions are being generated (for example, when firing fuel to warm up a process for some period of time prior to the emission unit's startup).
 - Annual emissions shall not include data from periods of time where the monitor was functioning properly but was unable to collect data while conducting a mandated quality assurance/quality control activity such as calibration error tests, RATA, calibration gas audit or relative accuracy audit (RAA). These periods of time shall be considered missing data for purposes of calculating annual emissions.
 - Annual emissions shall not include data from periods of time when emissions are in excess of the calibrated span of the CEMS. These periods of time shall be considered missing data for purposes of calculating annual emissions.
25. Accounting for Missing Data: All valid measurements collected during each hour shall be used to calculate a 1-hour block average. For each hour, the 1-hour block average shall be computed from at least two data points separated by a minimum of 15 minutes. If less than two such data points are available, the owner or operator shall account for emissions during that hour using site-specific data to generate a reasonable estimate of the 1-hour block average.
26. Emissions Calculation: Hourly emissions shall be calculated for each hour as the product of the 1-hour block average and the duration of pollutant emissions during that hour. Annual emissions shall be calculated as the sum of all hourly emissions occurring during the year.

SECTION 4. APPENDIX CF

CITATION FORMATS AND GLOSSARY OF COMMON TERMS

CITATION FORMATS

The following illustrate the formats used in the permit to identify applicable requirements from permits and regulations.

Old Permit Numbers

Example: Permit No. AC50-123456 or Permit No. AO50-123456

Where: “AC” identifies the permit as an Air Construction Permit
“AO” identifies the permit as an Air Operation Permit
“123456” identifies the specific permit project number

New Permit Numbers

Example: Permit Nos. 099-2222-001-AC, 099-2222-001-AF, 099-2222-001-AO, or 099-2222-001-AV

Where: “099” represents the specific county ID number in which the project is located
“2222” represents the specific facility ID number for that county
“001” identifies the specific permit project number
“AC” identifies the permit as an air construction permit
“AF” identifies the permit as a minor source federally enforceable state operation permit
“AO” identifies the permit as a minor source air operation permit
“AV” identifies the permit as a major Title V air operation permit

PSD Permit Numbers

Example: Permit No. PSD-FL-317

Where: “PSD” means issued pursuant to the preconstruction review requirements of the Prevention of Significant Deterioration of Air Quality
“FL” means that the permit was issued by the State of Florida
“317” identifies the specific permit project number

Florida Administrative Code (F.A.C.)

Example: [Rule 62-213.205, F.A.C.]

Means: Title 62, Chapter 213, Rule 205 of the Florida Administrative Code

Code of Federal Regulations (CFR)

Example: [40 CFR 60.7]

Means: Title 40, Part 60, Section 7

SECTION 4. APPENDIX CF

CITATION FORMATS AND GLOSSARY OF COMMON TERMS

GLOSSARY OF COMMON TERMS

° F: degrees Fahrenheit

acfm: actual cubic feet per minute

ARMS: Air Resource Management System
(Department's database)

BACT: best available control technology

Btu: British thermal units

CAM: compliance assurance monitoring

CEMS: continuous emissions monitoring system

cfm: cubic feet per minute

CFR: Code of Federal Regulations

CO: carbon monoxide

COMS: continuous opacity monitoring system

DEP: Department of Environmental Protection

Department: Department of Environmental
Protection

dscfm: dry standard cubic feet per minute

EPA: Environmental Protection Agency

ESP: electrostatic precipitator (control system for
reducing particulate matter)

EU: emissions unit

F.A.C.: Florida Administrative Code

F.D.: forced draft

F.S.: Florida Statutes

FGR: flue gas recirculation

F: fluoride

ft²: square feet

ft³: cubic feet

gpm: gallons per minute

gr: grains

HAP: hazardous air pollutant

Hg: mercury

I.D.: induced draft

ID: identification

kPa: kilopascals

lb: pound

MACT: maximum achievable technology

MMBtu: million British thermal units

MSDS: material safety data sheets

MW: megawatt

NESHAP: National Emissions Standards for
Hazardous Air Pollutants

NO_x: nitrogen oxides

NSPS: New Source Performance Standards

O&M: operation and maintenance

O₂: oxygen

Pb: lead

PM: particulate matter

PM₁₀: particulate matter with a mean aerodynamic
diameter of 10 microns or less

PSD: prevention of significant deterioration

psi: pounds per square inch

PTE: potential to emit

RACT: reasonably available control technology

RATA: relative accuracy test audit

SAM: sulfuric acid mist

scf: standard cubic feet

scfm: standard cubic feet per minute

SIC: standard industrial classification code

SNCR: selective non-catalytic reduction (control
system used for reducing emissions of nitrogen
oxides)

SO₂: sulfur dioxide

TPH: tons per hour

TPY: tons per year

UTM: Universal Transverse Mercator coordinate
system

VE: visible emissions

SECTION 4. APPENDIX CF

CITATION FORMATS AND GLOSSARY OF COMMON TERMS

VOC: volatile organic compounds

Application

PBREF-2: Palm beach Renewable Energy Facility Number 2

TO: Thermal Oxidizer

Snygas: synthetic gas

HRSG: heat recovery steam generators

STG: Steam Turbine Electrical Generator

CEMS: continuous emissions monitoring system

COMS: continuous opacity monitoring system

DRAFT

SECTION 4. APPENDIX CTR
COMMON TESTING REQUIREMENTS

Unless otherwise specified in the permit, the following testing requirements apply to all emissions units at the PBREF-2.

COMPLIANCE TESTING REQUIREMENTS

1. Operating Rate During Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. [Rule 62-297.310(2), F.A.C.]
2. Applicable Test Procedures - Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
 - a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.
 - b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.
 - c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

[Rule 62-297.310(4), F.A.C.]

3. Determination of Process Variables

- a. *Required Equipment*. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- b. *Accuracy of Equipment*. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

4. Frequency of Compliance Tests: The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

- a. *General Compliance Testing*.

SECTION 4. APPENDIX CTR
COMMON TESTING REQUIREMENTS

1. The owner or operator of a new or modified emissions unit that is subject to an emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining an operation permit for such emissions unit.
2. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision.

In renewing an air operation permit pursuant to sub-subparagraph 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit other than the emergency flare system (EU 003) that, during the year prior to renewal:

- (a) Did not operate; or
 - (b) In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours,
3. During each federal fiscal year (October 1 – September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for visible emissions, if there is an applicable standard.
 4. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
- b. *Special Compliance Tests.* When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

[Rule 62-297.310(7), F.A.C.]

RECORDS AND REPORTS

5. Test Reports: The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test. The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed. The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report shall provide the following information.
 - a. The type, location, and designation of the emissions unit tested.
 - b. The facility at which the emissions unit is located.
 - c. The owner or operator of the emissions unit.
 - d. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
 - e. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.

SECTION 4. APPENDIX CTR
COMMON TESTING REQUIREMENTS

- f. The date, starting time and end time of the observation.
- g. The test procedures used.
- h. The names of individuals who furnished the process variable data, conducted the test, and prepared the report.
- i. The applicable emission standard and the resulting maximum allowable emission rate for the emissions unit plus the test result in the same form and unit of measure.
- j. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

DRAFT

SECTION 4. APPENDIX Eb

NSPS, 40 CFR 60, SUBPART Eb – STANDARDS OF PERFORMANCE FOR LARGE MUNICIPAL WASTE COMBUSTORS STEAM GENERATING UNITS

Applicability of 40CFR60, Subpart Eb- Standards of Performance for Large Municipal Waste Combustors for Which Construction is Commenced After September 20, 1994 or for Which Modification or Reconstruction is Commenced After June 19, 1996.

The proposed PBREF-2 is a new Large Municipal Waste Combustor (Large MWC) because it is a waste combustion unit that is capable of combusting more than 250 tons per day (TPD) of municipal solid waste (MSW).

The rules applicable to Large MWC's are given at 40CFR60, Sections 60.50b through 60.59b. More specifically, the PBREF-2 utilizes combustion of MSW to generate electrical power. The emission limits applicable to this category of MWC are specified by in the relevant sections, paragraphs and tables that address individual pollutants including CO, NO_x, SO₂, HCl, PM, dioxin/furan, opacity, Cd, Hg, Pb, and various emission monitoring and operational parameters.

The Department has insured that the Permit is at least as stringent, and in several case much more stringent, than the requirements of Subpart Eb, including the use of Hg-CEMS.

A link to 40 CFR 60, Subpart Eb is available below.

[Link to NSPS Subpart Eb](#)

SECTION 4. APPENDIX GC

GENERAL CONDITIONS

The permittee shall comply with the following general conditions from Rule 62-4.160, F.A.C.

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
 - a. Have access to and copy and records that must be kept under the conditions of the permit;
 - b. Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
 - c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
 - a. A description of and cause of non-compliance; and
 - b. The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

SECTION 4. APPENDIX GC

GENERAL CONDITIONS

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
12. This permit or a copy thereof shall be kept at the work site of the permitted activity.
13. This permit also constitutes:
 - a. Determination of Best Available Control Technology ();
 - b. Determination of Prevention of Significant Deterioration (); and
 - c. Compliance with New Source Performance Standards (X).
14. The permittee shall comply with the following:
 - a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
 - b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
 - c. Records of monitoring information shall include:
 - 1) The date, exact place, and time of sampling or measurements;
 - 2) The person responsible for performing the sampling or measurements;
 - 3) The dates analyses were performed;
 - 4) The person responsible for performing the analyses;
 - 5) The analytical techniques or methods used; and
 - 6) The results of such analyses.
15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

SECTION 4. APPENDIX III

NSPS, 40 CFR 60, SUBPART III – STATIONARY COMPRESSION IGNITION INTERNAL COMBUSTION ENGINES

A 250 kW or less emergency generator (EU ID 033) and two 250 hp or less fire pump (EU IDs 031 and 032) are proposed for the PBREF-2 and are subject to the applicable requirements of 40 CFR 60, Subpart III--Standards of Performance for Stationary Compression Ignition Internal Combustion Engines. The provisions of this Subpart may be provided in full upon request and are also available at the following link:

[Link to NSPS Subpart III](#)

**SECTION 4. APPENDIX XSE
EXCESS EMISSIONS REPORTING FORM**

QUARTERLY EXCESS EMISSIONS AND MONITORING REPORT FOR SIP-ONLY STANDARDS

Company: _____
 Plant Name: _____
 Address: _____
 Emissions Unit No. ____ Description: _____
 Pollutant (check one): ___ CO ___ NOX Emission Limitation: _____
 Reporting period: ___ Q1 (Jan. – March) ___ Q2 (April – June) ___ Q3 (July – Sept.) ___ Q4 (Oct. – Dec.)
 Monitor Manufacturer: _____
 Model No.: _____
 Date of Latest CEMS Certification or Audit: _____
 Total emissions unit operating time in reporting period 1: _____ hours

Excluded Emission Data Summary ¹	CEMS Performance Summary ^{1, 5}
1. Duration of excluded emissions due to: a. ST Cold Startup ² _____ b. Shutdown _____ c. Documented Malfunction _____ d. Total Authorized Data Excluded _____ 2. <u>Total duration of excluded emissions x (100%)</u> [Total source operating time] _____ % 3. Number of Compliance Averages > Limit ³ _____	1. CEMS downtime due to: a. Monitor equipment malfunctions _____ b. Non-Monitor equipment malfunctions _____ c. Quality assurance calibration _____ d. Other known causes _____ e. Unknown causes _____ 2. Total CMS Downtime _____ 3. <u>Total CEMS Downtime x (100%)</u> [Total source operating time] _____ % ⁴

- 1 For the reporting period, record all times in hours.
- 2 "ST" means steam turbine.
- 3 If an exceedance occurs after excluding data as authorized by permit, the permittee shall also provide the hour-by-hour data for each compliance average greater than the permit limit and describe the circumstances causing the exceedance and the corrective actions taken.
- 4 If the total CEMS downtime is 5% or greater of the total operating time, the permittee shall also submit a report identifying the problems with maintaining a monitor availability of at least 95% and the corrective actions planned for the next quarter.
- 5 On a separate page, describe any changes in the CEMS, process equipment or control equipment since the last quarterly report.

I certify that the information contained in this report is true, accurate, and complete.

Name: _____
 Title: _____
 Signature: _____ Date: _____

SECTION 4. APPENDIX ZZZZ

NESHAP, 40 CFR 63, SUBPART ZZZZ – STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES

A 250 kW or less emergency generator (EU ID 033) and two 250 hp or less fire pump (EU IDs 031 and 032) are proposed for the PBREF-2 and are subject to the applicable requirements of 40 CFR 63, Subpart ZZZZ--National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. The complete provisions of Subpart ZZZZ may be provided in full upon request and are also available beginning at Section 63.6580 at:

[Link to NESHAP Subpart ZZZZ](#)

DRAFT