

Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400  
September 18, 2002

David B. Struhs  
Secretary

Mr. Gregg Worley, Chief  
Air, Radiation Technology Branch  
Preconstruction/HAP Section  
U.S. EPA, Region 4  
61 Forsyth Street  
Atlanta, Georgia 30303

RE: New Hope Power Partnership  
(formerly Okeelanta Power L.P.)  
DEP File No. 0990332-016-AC, PSD-FL-196N

Dear Mr. Worley:

Enclosed for your review and comment is an application submitted by New Hope Power Partnership to increase the heat input rate for the cogeneration boilers at their facility in Palm Beach County, Florida.

Your comments may be forwarded to my attention at the letterhead address or faxed to the Bureau of Air Regulation at 850/922-6979. If you have any questions, please contact Jeff Koerner, review engineer, at 850/921-9536.

Sincerely,

*Patricia Adams*  
*for* Al Linero, P.E.  
Administrator  
New Source Review Section

AAL/pa

Enclosure

Cc: Jeff Koerner

"More Protection, Less Process"

Printed on recycled paper.



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

September 18, 2002

Mr. John Bunyak, Chief  
Policy, Planning & Permit Review Branch  
NPS – Air Quality Division  
Post Office Box 25287  
Denver, Colorado 80225

RE: New Hope Power Partnership  
(formerly Okeelanta Power L.P.)  
DEP File No. 0990332-016-AC, PSD-FL-196N

Dear Mr. Bunyak:

Enclosed for your review and comment is an application submitted by New Hope Power Partnership to increase the heat input rate for the cogeneration boilers at their facility in Palm Beach County, Florida.

Your comments may be forwarded to my attention at the letterhead address or faxed to the Bureau of Air Regulation at 850/922-6979. If you have any questions, please contact Jeff Koerner, review engineer, at 850/921-9536.

Sincerely,

*Patty Adams*  
for Al Linero, P.E.  
Administrator  
New Source Review Section

AAL/pa

Enclosure

Cc: Jeff Koerner

"More Protection, Less Process"

Printed on recycled paper.

**Golder Associates Inc.**

6241 NW 23rd Street, Suite 500  
Gainesville, FL 32653-1500  
Telephone (352) 336-5600  
Fax (352) 336-6603



**TRANSMITTAL LETTER**

**To: Patty Adams**  
**FDEP, Tallahassee**

**Date: September 13, 2002**  
**Project No.: 0137520-0100**

**Sent by: ARZ**

- Mail
- Air Freight
- Hand Carried

- UPS
- Federal Express

**Per: D.Buff**

<b>Quantity</b>	<b>Item</b>	<b>Description</b>
3	Final Report	New Hope Power Partnership - Application to Increase the Heat Input Rate for the Cogeneration Boilers

**NEW HOPE POWER PARTNERSHIP**  
**OKEELANTA COGENERATION PLANT**  
**P.O. BOX 9**  
**8001 HWY 27 S.**  
**SOUTH BAY, FLORIDA 33493**  
**OFFICE (561) 993-1000 FAX (561) 992-7744**

September 4, 2002

Department of Environmental Protection  
Division of Air Resources Management  
New Source Review Section  
Twin Towers Office Building  
2600 Blair Stone Road  
MS #5505  
Tallahassee, FL 32399-2400

**RECEIVED**

SEP 06 2002

BUREAU OF AIR REGULATION


Attn: A.A. Linero, P.E.  
Administrator

Re: New Hope Power Partnership  
Okeelanta Cogeneration Plant  
Facility ID # 0990332

Dear Mr. Linero,

New Hope Power Partnership (formerly Okeelanta Power Limited Partnership) is hereby submitting four (4) signed and sealed copies of an "Application To Increase The Maximum Allowable Heat Input Rate For The Three Cogeneration Boilers". Check # 92681 in the amount of \$7,500 is also enclosed to pay the application fee. If you have any questions please contact me at the letterhead above or by telephone at (561) 993-1003 or you may alternately contact David Buff of Golder Associates at (352) 336-5600.

Sincerely,



James M. Meriwether  
Environmental and Safety Manager

cc: Rodney Williams  
Gus Cepero  
David Buff  
Bill Tarr  
David Dee

**NEW HOPE POWER PARTNERSHIP**  
OKEELANTA COGENERATION PLANT  
P.O. BOX 9  
8001 HWY 27 S.  
SOUTH BAY, FLORIDA 33493  
OFFICE (561) 993-1000 FAX (561) 992-7744

**RECEIVED**

JUL 29 2002

BUREAU OF AIR REGULATION

July 25, 2002

023-7568

Florida Department of Environmental Protection  
New Source Review Section  
2600 Blair Stone Road MS 5505  
Tallahassee, FL 32399-2400

Attention: Mr. Jeff Koerner

RE: New Hope Power Partnership, Permit No. 0990332-014-AC/PSD-FL-196M


Dear Mr. Koerner:

An administrative requirement of Permit No. 0990332-014-AC for New Hope Power Partnership is the requirement to submit a Title V revision within 180 days of January 31, 2002. David A. Buff, P.E., the engineer of record for this project, has recently had a heart attack and will be out of the office for 4 to 6 weeks. Therefore, Mr. Buff will not be able to prepare the application by the deadline of July 31, 2002. New Hope Power Partnership is, therefore, requesting a 60-day extension until September 31, 2002, to submit the required Title V revision application.

Please feel free to call James Meriwether, New Hope Power Partnership, at (561) 993-1003 or Fawn Howard, Golder Associates Inc., at (352) 336-5600 if you have any questions or comments.

Sincerely,

NEW HOPE POWER PARTNERSHIP

  
Rodney Williams  
Plant Manager

FH

Enclosures

cc: R. Blackburn, DEP  
M. Capone, Okeelanta Corp.  
F. Howard, Golder  
J. Meriwether, NHPP

**RECEIVED**

SEP 06 2002

BUREAU OF AIR REGULATION

**APPLICATION TO INCREASE THE  
HEAT INPUT RATE FOR THE  
COGENERATION BOILERS**

***NEW HOPE POWER PARTNERSHIP  
SOUTH BAY, FLORIDA***

**Prepared For:**

**New Hope Power Partnership  
8001 U.S. Highway 27 South  
South Bay, Florida 33493**

**Prepared By:**



**Golder Associates Inc.  
6241 NW 23rd Street, Suite 500  
Gainesville, Florida 32653-1500**


**August 2002  
0137520**

**DISTRIBUTION:**

**4 Copies - FDEP**

**5 Copies - NHPP**

**2 Copies - Golder Associates Inc.**



# Department of Environmental Protection

## Division of Air Resources Management

### APPLICATION FOR AIR PERMIT - TITLE V SOURCE

See Instructions for Form No. 62-210.900(1)

#### I. APPLICATION INFORMATION

RECEIVED  
SEP 06 2002  
BUREAU OF AIR REGULATION

#### Identification of Facility

1. Facility Owner/Company Name: <b>New Hope Power Partnership</b>	
2. Site Name: <b>New Hope Power Partnership</b>	
3. Facility Identification Number: <b>0990332</b> [ ] Unknown	
4. Facility Location: <b>6 Miles South of South Bay on US 27</b> Street Address or Other Locator: <b>8001 U.S. Highway 27 South</b> City: <b>South Bay</b> County: <b>Palm Beach</b> Zip Code: <b>33493</b>	
5. Relocatable Facility? [ ] Yes      [ <b>X</b> ] No	6. Existing Permitted Facility? [ <b>X</b> ] Yes      [ ] No

#### Application Contact

1. Name and Title of Application Contact: <b>James Meriwether, Environmental and Safety Manager</b>	
2. Application Contact Mailing Address: Organization/Firm: <b>New Hope Power Partnership</b> Street Address: <b>8001 U.S. Highway 27 South</b> City: <b>South Bay</b> State: <b>FL</b> Zip Code: <b>33493</b>	
3. Application Contact Telephone Numbers: Telephone: <b>( 561 ) 993 - 1003</b> Fax: <b>( 561 ) 996-6596</b>	

#### Application Processing Information (DEP Use)

1. Date of Receipt of Application:	<b>9-6-02</b>
2. Permit Number:	<b>0990332-016-AC</b>
3. PSD Number (if applicable):	<b>PSD-FL-196 N</b>
4. Siting Number (if applicable):	

**Purpose of Application**

**Air Operation Permit Application**

This Application for Air Permit is submitted to obtain: (Check one)

- Initial Title V air operation permit for an existing facility which is classified as a Title V source.
- Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.  
Current construction permit number: \_\_\_\_\_
- Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application.  
Current construction permit number: \_\_\_\_\_  
Operation permit number to be revised: \_\_\_\_\_
- Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.)  
Operation permit number to be revised/corrected: \_\_\_\_\_
- Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.  
Operation permit number to be revised: \_\_\_\_\_  
Reason for revision: \_\_\_\_\_


**Air Construction Permit Application**

This Application for Air Permit is submitted to obtain: (Check one)

- Air construction permit to construct or modify one or more emissions units.
- Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.
- Air construction permit for one or more existing, but unpermitted, emissions units.



**Owner/Authorized Representative or Responsible Official**

1. Name and Title of Owner/Authorized Representative or Responsible Official: <b>Rodney Williams - Plant Manager</b>
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: <b>New Hope Power Partnership</b> Street Address: <b>8001 U.S. Highway 27 South</b> City: <b>South Bay</b> State: <b>FL</b> Zip Code: <b>33493</b>
3. Application Contact Telephone Numbers: Telephone: <b>( 561 ) 993-1000</b> Fax: <b>( 561 ) 992-7744</b>
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative*(check here [ ] , if so) or the responsible official (check here [ ] , if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i>   Signature _____ Date <u>9/4/02</u>

\* Attach letter of authorization if not currently on file.

**Professional Engineer Certification**

1. Professional Engineer Name: <b>David A. Buff</b> Registration Number: <b>19011</b>
2. Professional Engineer Mailing Address: Organization/Firm: <b>Golder Associates Inc.*</b> Street Address: <b>6241 NW 23rd Street, Suite 500</b> City: <b>Gainesville</b> State: <b>FL</b> Zip Code: <b>32653-1500</b>
3. Professional Engineer Telephone Numbers: Telephone: <b>( 352 ) 336 - 5600</b> Fax: <b>( 352 ) 336 - 6603</b>

\* Board of Professional Engineers Certificate 03000018

4. Professional Engineer Statement:

*I, the undersigned, hereby certify, except as particularly noted herein\*, that:*

*(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and*

*(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.*

*If the purpose of this application is to obtain a Title V source air operation permit (check here [ ], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.*

*If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [X], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.*

*If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [ ], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.*

David A. Buff  
Signature

8/30/2002  
Date

(seal)

\* Attach any exception to certification statement.

**Scope of Application**

Emissions Unit ID	Description of Emissions Unit	Permit Type	Processing Fee
029	Materials Handling and Storage Operations	AC1A	
030	Cogen Boiler A	AC1A	
031	Cogen Boiler B	AC1A	
032	Cogen Boiler C	AC1A	

**Application Processing Fee**

Check one:  Attached - Amount: \$: 7,500         Not Applicable

**Construction/Modification Information**

1. Description of Proposed Project or Alterations:

Increase in maximum allowable heat input rates for the three (3) cogeneration boilers.

2. Projected or Actual Date of Commencement of Construction **01 DEC 2002**

3. Projected Date of Completion of Construction: **01 DEC 2003**

**Application Comment**

## II. FACILITY INFORMATION

### A. GENERAL FACILITY INFORMATION

#### Facility Location and Type

1. Facility UTM Coordinates: Zone: <b>17</b> East (km): <b>524.90</b> North (km): <b>2940.10</b>			
2. Facility Latitude/Longitude: Latitude (DD/MM/SS): / / Longitude (DD/MM/SS): / /			
3. Governmental Facility Code: <b>0</b>	4. Facility Status Code: <b>A</b>	5. Facility Major Group SIC Code: <b>49</b>	6. Facility SIC(s): <b>4911</b>
7. Facility Comment (limit to 500 characters):  <b>The New Hope Power Partnership (formerly Okeelanta Power L.P.) cogeneration facility consists of three boilers and all operations necessary to generate steam for the Okeelanta Corporation sugar mill, as well as generate electricity for sale to the grid.</b>			

#### Facility Contact

1. Name and Title of Facility Contact: <b>James Meriwether, Environmental and Safety Manager</b>
2. Facility Contact Mailing Address: Organization/Firm: <b>New Hope Power Partnership</b> Street Address: <b>8001 U.S. Highway 27 South</b> City: <b>South Bay</b> State: <b>FL</b> Zip Code: <b>33493</b>
3. Facility Contact Telephone Numbers: Telephone: <b>( 561 ) 993 - 1003</b> Fax: <b>( 561 ) 996 - 6596</b>

**Facility Regulatory Classifications**

**Check all that apply:**

1. <input type="checkbox"/> Small Business Stationary Source?	<input type="checkbox"/> Unknown
2. <input checked="" type="checkbox"/> Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)?	
3. <input type="checkbox"/> Synthetic Minor Source of Pollutants Other than HAPs?	
4. <input checked="" type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)?	
5. <input type="checkbox"/> Synthetic Minor Source of HAPs?	
6. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS?	
7. <input type="checkbox"/> One or More Emission Units Subject to NESHAP?	
8. <input type="checkbox"/> Title V Source by EPA Designation?	
9. Facility Regulatory Classifications Comment (limit to 200 characters):  <b>See Attachment NH-FI-A9.</b>	

**List of Applicable Regulations**

<b>Only those rules, regulations, and ordinances specifically identified herein apply to this facility.</b>	
See attached Title V Core List, effective 3/1/02.	

## Title V Core List

Effective: 03/01/02

[**Note:** The Title V Core List is meant to simplify the completion of the "List of Applicable Regulations" for DEP Form No. 62-210.900(1), Application for Air Permit - Long Form. The Title V Core List is a list of rules to which all Title V Sources are presumptively subject. The Title V Core List may be referenced in its entirety, or with specific exceptions. The Department may periodically update the Title V Core List.]

**Federal:** (description)

~~40 CFR 61: National Emission Standards for Hazardous Air Pollutants (NESHAP)~~  
~~40 CFR 61, Subpart M: NESHAP for Asbestos.~~  
40 CFR 64, Compliance Assurance Monitoring  
~~40 CFR 82: Protection of Stratospheric Ozone.~~  
~~40 CFR 82, Subpart B: Servicing of Motor Vehicle Air Conditioners (MVAC).~~  
~~40 CFR 82, Subpart F: Recycling and Emissions Reduction.~~

**State:** (description)

**CHAPTER 62-4, F.A.C.: PERMITS, effective 06-01-01**

62-4.030, F.A.C.: General Prohibition.  
62-4.040, F.A.C.: Exemptions.  
62-4.050, F.A.C.: Procedure to Obtain Permits; Application.  
62-4.060, F.A.C.: Consultation.  
62-4.070, F.A.C.: Standards for Issuing or Denying Permits; Issuance; Denial.  
62-4.080, F.A.C.: Modification of Permit Conditions.  
62-4.090, F.A.C.: Renewals.  
62-4.100, F.A.C.: Suspension and Revocation.  
62-4.110, F.A.C.: Financial Responsibility.  
62-4.120, F.A.C.: Transfer of Permits.  
62-4.130, F.A.C.: Plant Operation - Problems.  
62-4.150, F.A.C.: Review.  
62-4.160, F.A.C.: Permit Conditions.  
62-4.210, F.A.C.: Construction Permits.  
62-4.220, F.A.C.: Operation Permit for New Sources.

**CHAPTER 62-210, F.A.C.: STATIONARY SOURCES - GENERAL REQUIREMENTS, effective 06-21-01**

62-210.300, F.A.C.: Permits Required.  
62-210.300(1), F.A.C.: Air Construction Permits.  
62-210.300(2), F.A.C.: Air Operation Permits.  
62-210.300(3), F.A.C.: Exemptions.  
62-210.300(5), F.A.C.: Notification of Startup.  
62-210.300(6), F.A.C.: Emissions Unit Reclassification.  
62-210.300(7), F.A.C.: Transfer of Air Permits.

## Title V Core List

Effective: 03/01/02

- 62-210.350, F.A.C.: Public Notice and Comment.
- 62-210.350(1), F.A.C.: Public Notice of Proposed Agency Action.
- 62-210.350(2), F.A.C.: Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment-Area Preconstruction Review.
- 62-210.350(3), F.A.C.: Additional Public Notice Requirements for Sources Subject to Operation Permits for Title V Sources.

- 62-210.360, F.A.C.: Administrative Permit Corrections.
- 62-210.370(3), F.A.C.: Annual Operating Report for Air Pollutant Emitting Facility.
- 62-210.400, F.A.C.: Emission Estimates.
- 62-210.650, F.A.C.: Circumvention.
- 62-210.700, F.A.C.: Excess Emissions.

- 62-210.900, F.A.C.: Forms and Instructions.
- 62-210.900(1), F.A.C.: Application for Air Permit – Title V Source, Form and Instructions.
- 62-210.900(5), F.A.C.: Annual Operating Report for Air Pollutant Emitting Facility, Form and Instructions.
- 62-210.900(7), F.A.C.: Application for Transfer of Air Permit – Title V and Non-Title V Source.

### **CHAPTER 62-212, F.A.C.: STATIONARY SOURCES - PRECONSTRUCTION REVIEW, effective 08-17-00**

### **CHAPTER 62-213, F.A.C.: OPERATION PERMITS FOR MAJOR SOURCES OF AIR POLLUTION, effective 04-16-01**

- 62-213.205, F.A.C.: Annual Emissions Fee.
- 62-213.400, F.A.C.: Permits and Permit Revisions Required.
- 62-213.410, F.A.C.: Changes Without Permit Revision.
- 62-213.412, F.A.C.: Immediate Implementation Pending Revision Process.
- 62-213.415, F.A.C.: Trading of Emissions Within a Source.
- 62-213.420, F.A.C.: Permit Applications.
- 62-213.430, F.A.C.: Permit Issuance, Renewal, and Revision.
- 62-213.440, F.A.C.: Permit Content.
- 62-213.450, F.A.C.: Permit Review by EPA and Affected States
- 62-213.460, F.A.C.: Permit Shield.

- 62-213.900, F.A.C.: Forms and Instructions.
- 62-213.900(1), F.A.C.: Major Air Pollution Source Annual Emissions Fee Form.
- 62-213.900(7), F.A.C.: Statement of Compliance Form.



## Title V Core List

Effective: 03/01/02

~~CHAPTER 62-256, F.A.C.: OPEN BURNING AND FROST PROTECTION FIRES,~~  
effective ~~11-30-94~~

~~CHAPTER 62-257, F.A.C.: ASBESTOS NOTIFICATION AND FEE,~~  
effective ~~03-24-96~~

~~CHAPTER 62-281, F.A.C.: MOTOR VEHICLE AIR CONDITIONING~~  
~~REFRIGERANT RECOVERY AND RECYCLING,~~ effective ~~03-07-96~~

**CHAPTER 62-296, F.A.C.: STATIONARY SOURCES - EMISSION STANDARDS,**  
effective 03-02-99

62-296.320(4)(c), F.A.C.: Unconfined Emissions of Particulate Matter.

62-296.320(2), F.A.C.: Objectionable Odor Prohibited.

**CHAPTER 62-297, F.A.C.: STATIONARY SOURCES - EMISSIONS**  
**MONITORING,** effective 03-02-99

62-297.310, F.A.C.: General Test Requirements.

62-297.330, F.A.C.: Applicable Test Procedures.

62-297.340, F.A.C.: Frequency of Compliance Tests.

62-297.345, F.A.C.: Stack Sampling Facilities Provided by the Owner of an Emissions  
Unit.

62-297.350, F.A.C.: Determination of Process Variables.

62-297.570, F.A.C.: Test Report.

62-297.620, F.A.C.: Exceptions and Approval of Alternate Procedures and Requirements.

### Miscellaneous:

**CHAPTER 28-106, F.A.C.:** Decisions Determining Substantial Interests

**CHAPTER 62-110, F.A.C.:** Exception to the Uniform Rules of Procedure, effective  
07-01-98

~~CHAPTER 62-256, F.A.C.:~~ Open Burning and Frost Protection Fires, effective ~~11-30-94~~

~~CHAPTER 62-257, F.A.C.:~~ Asbestos Notification and Fee, effective ~~02-09-99~~

~~CHAPTER 62-281, F.A.C.:~~ Motor Vehicle Air Conditioning Refrigerant Recovery and  
Recycling, effective ~~09-10-96~~

## B. FACILITY POLLUTANTS

### List of Pollutants Emitted

1. Pollutant Emitted	2. Pollutant Classif.	3. Requested Emissions Cap		4. Basis for Emissions Cap	5. Pollutant Comment
		lb/hour	tons/year		
PM	A				Particulate Matter – Total
PM <sub>10</sub>	A				Particulate Matter – PM <sub>10</sub>
SO <sub>2</sub>	A				Sulfur Dioxide
NO <sub>x</sub>	A				Nitrogen Oxides
CO	A				Carbon Monoxide
VOC	A				Volatile Organic Compounds
PB	B				Lead
H114	B				Mercury
SAM	B				Sulfuric Acid Mist
HAPs	A				Hazardous Air Pollutants See Att. NH-FI-A9

### C. FACILITY SUPPLEMENTAL INFORMATION

#### Supplemental Requirements

1. Area Map Showing Facility Location: [ <b>X</b> ] Attached, Document ID: <u>NH-FI-C1</u> [ ] Not Applicable [ ] Waiver Requested
2. Facility Plot Plan: [ <b>X</b> ] Attached, Document ID: <u>NH-FI-C2</u> [ ] Not Applicable [ ] Waiver Requested
3. Process Flow Diagram(s): [ <b>X</b> ] Attached, Document ID: <u>NH-FI-C3</u> [ ] Not Applicable [ ] Waiver Requested
4. Precautions to Prevent Emissions of Unconfined Particulate Matter: [ ] Attached, Document ID: _____ [ <b>X</b> ] Not Applicable [ ] Waiver Requested
5. Fugitive Emissions Identification: [ ] Attached, Document ID: _____ [ <b>X</b> ] Not Applicable [ ] Waiver Requested
6. Supplemental Information for Construction Permit Application: [ <b>X</b> ] Attached, Document ID: <u>PSD Report</u> [ ] Not Applicable
7. Supplemental Requirements Comment:

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

8. List of Proposed Insignificant Activities: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
9. List of Equipment/Activities Regulated under Title VI: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Equipment/Activities On site but Not Required to be Individually Listed <input checked="" type="checkbox"/> Not Applicable
10. Alternative Methods of Operation: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Risk Management Plan Verification: <input type="checkbox"/> Plan previously submitted to Chemical Emergency Preparedness and Prevention Office (CEPPO). Verification of submittal attached (Document ID: _____) or previously submitted to DEP (Date and DEP Office: _____) <input type="checkbox"/> Plan to be submitted to CEPPO (Date required: _____) <input checked="" type="checkbox"/> Not Applicable
14. Compliance Report and Plan: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Compliance Certification (Hard-copy Required): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

**ATTACHMENT NH-FI-A9**


**FACILITY REGULATORY CLASSIFICATION COMMENT**

**ATTACHMENT NH-FI-A9**  
**FACILITY REGULATORY CLASSIFICATION COMMENT**

At this time, it is unclear whether New Hope Power Partnership should be classified as major for HAPs. New Hope Power Partnership has no emissions test data indicating significant HAP emissions from its boilers. Emissions test data from the Pulp and Paper Industry indicates that there are HAPs emissions from wood-fired boilers. However, these emissions data may not be representative of New Hope Power Partnership HAP emissions. In addition, recent sugar industry test data indicates that there are HAPs emissions from sugar industry bagasse fired boilers. However, New Hope Power Partnership believes the HAPs emissions from its boilers are much lower than the emissions from the older boilers in the sugar industry. Further, Okeelanta Corporation is currently not operating its sugar mill boilers, as steam is being supplied by New Hope Power Partnership.

**ATTACHMENT NH-FI-C1**

**AREA MAP SHOWING FACILITY LOCATION**



**Attachment NH-FI-C1**  
 Location of New Hope Power Partnership


Source: Golder Associates Inc., 2002.





**ATTACHMENT NH-FI-C2**

**FACILITY PLOT PLAN**




Attachment NH-FI-C2  
Plot Plan of New Hope Power Partnership Facility

Source: Bechtel, 1996; Golder, 2000.



**ATTACHMENT NH-FI-C3**

**PROCESS FLOW DIAGRAM**



### III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

#### A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

##### Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in This Section: (Check one)			
[ ] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
[ X ] This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
[ ] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
[ X ] The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
[ ] The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): <b>Biomass/ash handling system at New Hope Power Partnership</b>			
4. Emissions Unit Identification Number: ID: <b>029</b>		[ ] No ID [ ] ID Unknown	
5. Emissions Unit Status Code: <b>A</b>	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: <b>49</b>	8. Acid Rain Unit? [ ]
9. Emissions Unit Comment: (Limit to 500 Characters)			

**Emissions Unit Control Equipment**

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

**Baghouse**

**Enclosures**

2. Control Device or Method Code(s): **18, 54**

**Emissions Unit Details**

1. Package Unit:

Manufacturer:

Model Number:

2. Generator Nameplate Rating:

MW

3. Incinerator Information:

Dwell Temperature:

°F

Dwell Time:

seconds

Incinerator Afterburner Temperature:

°F

**B. EMISSIONS UNIT CAPACITY INFORMATION  
(Regulated Emissions Units Only)**

**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:		mmBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:	<b>3,761,731 TPY</b>	
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	<b>24</b> hours/day	<b>7</b> days/week
	<b>52</b> weeks/year	<b>8,760</b> hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):	<p><b>1,063,162 TPY woodwaste; 1,444,659 TPY bagasse; plus 50% additional for yearly variability.</b></p>	

**C. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

List of Applicable Regulations

62-296.320(4)(b)	
62-296.320(4)(c)	



**D. EMISSION POINT (STACK/VENT) INFORMATION**  
**(Regulated Emissions Units Only)**

**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? <b>Material Handling System</b>		2. Emission Point Type Code: <b>4</b>	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):  <b>Fly Ash Silo</b> <b>Conveyor Transfer Points</b> <b>Hogger</b> <b>Biomass Storage Pile</b>			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: <b>F</b>	6. Stack Height:  feet	7. Exit Diameter:  feet	
8. Exit Temperature:  <b>77 °F</b>	9. Actual Volumetric Flow Rate:  acfm	10. Water Vapor:  %	
11. Maximum Dry Standard Flow Rate:  dscfm		12. Nonstack Emission Point Height:  <b>10</b> feet	
13. Emission Point UTM Coordinates:  Zone: East (km): North (km):			
14. Emission Point Comment (limit to 200 characters):  <b>Fugitive emissions</b>			

**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
**(All Emissions Units)**

**Segment Description and Rate:** Segment 1 of 1

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Bulk materials open stockpiles: Biomass</b>		
2. Source Classification Code (SCC): <b>3-02-103-99</b>		3. SCC Units: <b>Tons used</b>
4. Maximum Hourly Rate:	5. Maximum Annual Rate: <b>3,761,731</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):  <b>Segment represents biomass handling and storage operations.</b>		

**Segment Description and Rate:** Segment      of     

1. Segment Description (Process/Fuel Type) (limit to 500 characters):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

**F. EMISSIONS UNIT POLLUTANTS**  
 (All Emissions Units)

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM			WP
PM <sub>10</sub>			WP

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour <b>9.07</b> tons/year		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):  <b>Refer to Table 2-4 in the PSD Report.</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:		4. Equivalent Allowable Emissions: lb/hour tons/year	
5. Method of Compliance (limit to 60 characters):			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM<sub>10</sub></b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour <b>3.50</b> tons/year		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):  <b>Refer to Table 2-4 in the PSD Report.</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:		4. Equivalent Allowable Emissions: lb/hour tons/year	
5. Method of Compliance (limit to 60 characters):			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):			

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation 1 of 1

1. Visible Emissions Subtype: <b>VE20</b>	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Requested Allowable Opacity: Normal Conditions: <b>20</b> %      Exceptional Conditions:      % Maximum Period of Excess Opacity Allowed:      min/hour	
4. Method of Compliance: <b>VE test using EPA Method 9</b>	
5. Visible Emissions Comment (limit to 200 characters):  <b>Rule 62-296.320(4)(b), F.A.C.</b>	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor \_\_\_\_\_ of \_\_\_\_\_.

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement:	<input type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information: Manufacturer: Model Number:      Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):	

**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)****Supplemental Requirements**

1. Process Flow Diagram <input checked="" type="checkbox"/> Attached, Document ID: <u>NH-EU1-J1</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Fuel Analysis or Specification <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input checked="" type="checkbox"/> Waiver Requested
3. Detailed Description of Control Equipment <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input checked="" type="checkbox"/> Waiver Requested
4. Description of Stack Sampling Facilities <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input checked="" type="checkbox"/> Waiver Requested
5. Compliance Test Report <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously submitted, Date: _____ <input checked="" type="checkbox"/> Not Applicable
6. Procedures for Startup and Shutdown <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
7. Operation and Maintenance Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
8. Supplemental Information for Construction Permit Application <input checked="" type="checkbox"/> Attached, Document ID: <u>PSD Report</u> <input type="checkbox"/> Not Applicable
9. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
10. Supplemental Requirements Comment:


**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable



**ATTACHMENT NH-EU1-J1**

**PROCESS FLOW DIAGRAM**



Attachment NH-EU1-J1. Materials Handling System  
 New Hope Power Partnership - South Bay, Florida



### III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

#### A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

##### Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in This Section: (Check one)			
[ X ] This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
[ ] This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
[ ] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
[ X ] The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
[ ] The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): <b>Cogen Boiler A fired by Biomass/No. 2 Fuel Oil/Natural Gas</b>			
4. Emissions Unit Identification Number:		[ ] No ID	
ID: <b>030</b>		[ ] ID Unknown	
5. Emissions Unit Status Code: <b>A</b>	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: <b>49</b>	8. Acid Rain Unit? [ ]
9. Emissions Unit Comment: (Limit to 500 Characters)  <b>74.9 MW net generating capacity for entire facility.</b>			

**Emissions Unit Control Equipment**

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

**ESP - Electrostatic Precipitator - High Efficiency**

**Selective Non-catalytic Reduction for NO<sub>x</sub>**

**Multiple Cyclone w/o Fly Ash Reinjection**

**Activated Carbon Injection System**

2. Control Device or Method Code(s): **010, 107, 076, 048**

**Emissions Unit Details**

1. Package Unit:	
Manufacturer:	Model Number:
2. Generator Nameplate Rating:	<b>75 MW</b>
3. Incinerator Information:	
Dwell Temperature:	°F
Dwell Time:	seconds
Incinerator Afterburner Temperature:	°F

**B. EMISSIONS UNIT CAPACITY INFORMATION  
(Regulated Emissions Units Only)**

**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	<b>760</b>	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:		tons/hr
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	<b>24</b> hours/day	<b>7</b> days/week
	<b>52</b> weeks/year	<b>8,760</b> hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):		
<p><b>Maximum heat input rates:</b>  <b>Biomass - 760 MMBtu/hr;</b>  <b>No. 2 Fuel Oil - 490 MMBtu/hr;</b>  <b>Natural Gas - 605 MMBtu/hr</b></p>		

**C. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

**List of Applicable Regulations**

See Attachment NH-EU2-C.	

**D. EMISSION POINT (STACK/VENT) INFORMATION  
(Regulated Emissions Units Only)**

**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? <b>BLR A</b>		2. Emission Point Type Code: <b>1</b>	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: <b>V</b>	6. Stack Height: <b>199</b> feet	7. Exit Diameter: <b>10.0</b> feet	
8. Exit Temperature: <b>352</b> °F	9. Actual Volumetric Flow Rate: <b>319,000</b> acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: East (km): North (km):			
14. Emission Point Comment (limit to 200 characters):  <b>Stack parameters based on biomass firing. See Table 2-5 in PSD Report for all boiler stack data.</b>			

**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
(All Emissions Units)

**Segment Description and Rate:** Segment 1 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Bagasse</b>		
2. Source Classification Code (SCC): <b>1-01-011-01</b>		3. SCC Units: <b>Tons Burned (all solid fuels)</b>
4. Maximum Hourly Rate: <b>105.56</b>	5. Maximum Annual Rate: <b>924,667</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash: <b>1.0</b>	9. Million Btu per SCC Unit: <b>7.2</b>
10. Segment Comment (limit to 200 characters):		

**Segment Description and Rate:** Segment 2 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Wood Fired Boiler</b>		
2. Source Classification Code (SCC): <b>1-01-009-03</b>		3. SCC Units: <b>Tons Burned (all solid fuels)</b>
4. Maximum Hourly Rate: <b>84.44</b>	5. Maximum Annual Rate: <b>739,733</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.3</b>	8. Maximum % Ash: <b>9.0</b>	9. Million Btu per SCC Unit: <b>9.0</b>
10. Segment Comment (limit to 200 characters):		



**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
(All Emissions Units)

**Segment Description and Rate:** Segment 3 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Distillate Oil - Grades 1 and 2 Oil</b>		
2. Source Classification Code (SCC): <b>1-01-005-01</b>		3. SCC Units: <b>Thousand Gallons Burned (all liquid fuels)</b>
4. Maximum Hourly Rate: <b>3.551</b>	5. Maximum Annual Rate: <b>11,309</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash:	9. Million Btu per SCC Unit: <b>138</b>
10. Segment Comment (limit to 200 characters):		

**Segment Description and Rate:** Segment 4 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Natural Gas</b>		
2. Source Classification Code (SCC): <b>1-01-006-01</b>		3. SCC Units: <b>MMscf Burned</b>
4. Maximum Hourly Rate: <b>0.605</b>	5. Maximum Annual Rate: <b>1,561</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: <b>1,000</b>
10. Segment Comment (limit to 200 characters):		

**F. EMISSIONS UNIT POLLUTANTS  
(All Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM	076	010	EL
PM <sub>10</sub>	076	010	EL
SO <sub>2</sub>			EL
NO <sub>x</sub>	107		EL
CO			EL
VOC			EL
PB	076	010	EL
SAM			NS
FL			NS
H114	048		EL

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>22.8</b> lb/hour <b>99.86</b> tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.03 lb/MMBtu</b> Reference: <b>40 CFR 60 Subpart Da</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>0.03 lb/MMBtu x 760 MMBtu/hr = 22.8 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>22.8</b> lb/hour <b>99.86</b> tons/year
5. Method of Compliance (limit to 60 characters):  <b>Annual Stack testing using EPA Method 5.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Basis for Allowable Emissions Code: NSPS. Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour _____ tons/year _____	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):  	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  	

**Allowable Emissions** Allowable Emissions 2 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>14.70 lb/hour 23.42 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Fuel Analysis.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Basis for Allowable Emissions Code: NSPS. Based on No. 2 fuel oil firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions  3  of  3

1. Basis for Allowable Emissions Code: <b>OTHER</b>		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>		4. Equivalent Allowable Emissions: <b>18.15 lb/hour      23.42 tons/year</b>	
5. Method of Compliance (limit to 60 characters):  <b>Good combustion practices and limit natural gas burning to 24.9 percent.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Basis for Allowable Emissions Code: NSPS. Based on natural gas firing. Hourly: 0.03 lb/MMBtu x 605 MMBtu/hr = 18.15 lb/hr; Annual: 0.03 lb/MMBtu x 1.561 x10<sup>12</sup> Btu/yr ÷ 2000 lb/ton = 23.42 TPY</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM<sub>10</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>22.8 lb/hour                      99.86 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.03 lb/MMBtu</b> Reference: <b>40 CFR 60 Subpart Da</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>0.03 lb/MMBtu x 760 MMBtu/hr = 22.8 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>22.8 lb/hour                      99.86 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Annual Stack testing using EPA Method 5.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: <b>PM<sub>10</sub></b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour  tons/year		4. Synthetically Limited? [    ]	
5. Range of Estimated Fugitive Emissions: [    ] 1            [    ] 2            [    ] 3            _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

Allowable Emissions Allowable Emissions  2  of  3

1. Basis for Allowable Emissions Code: <b>OTHER</b>		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>		4. Equivalent Allowable Emissions: <b>14.70 lb/hour      23.42 tons/year</b>	
5. Method of Compliance (limit to 60 characters):  <b>Fuel Analysis.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Basis for Allowable Emissions Code: NSPS. Based on No. 2 fuel oil firing.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM<sub>10</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour _____ tons/year _____	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 3 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>18.15 lb/hour 23.42 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Good combustion practices and limit natural gas burning to 24.9 percent.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Basis for Allowable Emissions Code: NSPS. Based on natural gas firing. Hourly: 0.03 lb/MMBtu x 605 MMBtu/hr = 18.15 lb/hr; Annual: 0.03 lb/MMBtu x 1.561 x 10<sup>12</sup> Btu/yr ÷ 2000 lb/ton = 23.42 TPY</b>	



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>SO<sub>2</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>228.0 lb/hour      199.7 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.30 lb/MMBtu</b> Reference: <b>CEM data</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>3-Hour average = 0.30 lb/MMBtu x 760 MMBtu/hr = 228.0 lb/hr</b> <b>24-Hour average = 0.20 lb/MMBtu x 760 MMBtu/hr = 152 lb/hr</b> <b>Annual average = 0.06 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 199.73 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.20 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>152.0 lb/hour      199.7 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous SO<sub>2</sub> monitor.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Requested Allowable Emissions: 0.20 lb/MMBtu 24-hr average; 0.06 lb/MMBtu annual average. Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>SO<sub>2</sub></b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour _____ tons/year _____		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>RULE</b>		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.05 lb/MMBtu</b>		4. Equivalent Allowable Emissions: <b>24.5 lb/hour 39.0 tons/year</b>	
5. Method of Compliance (limit to 60 characters): <b>Fuel analysis and limit fuel oil burning to 24.9 percent.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on No. 2 Fuel Oil firing and BACT.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NO<sub>x</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>152.0 lb/hour      499.3 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.15 lb/MMBtu</b> Reference: <b>Permit Limit</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  Short-term: <b>0.20 lb/MMBtu x 760 MMBtu/hr = 152.0 lb/hr</b> Annual: <b>0.15 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2000 lb/ton = 499.3 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>ESCPD</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>	4. Equivalent Allowable Emissions: <b>lb/hour      499.3 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous NO<sub>x</sub> monitor.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing, as a 30-day rolling average.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NO<sub>x</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <span style="margin-left: 150px;">lb/hour</span> <span style="margin-left: 150px;">tons/year</span>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 2 of 3

1. Basis for Allowable Emissions Code: <b>ESCPD</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>	4. Equivalent Allowable Emissions: <span style="margin-left: 100px;">lb/hour</span> <b>117.1 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous NO<sub>x</sub> monitor and limit fuel oil burning to 24.9 percent.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on No. 2 fuel oil firing, as a 30-day rolling average.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NO<sub>x</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour _____ tons/year _____	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 3 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>	4. Equivalent Allowable Emissions: lb/hour _____ 117.1 tons/year
5. Method of Compliance (limit to 60 characters): <b>Continuous NO<sub>x</sub> monitor and limit natural gas burning to 24.9 percent.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on natural gas firing, as a 30-day rolling average.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>CO</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>1,462.5 lb/hour</b> <b>1,165.1 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>6.5 lb/MMBtu</b> Reference: <b>CEM Data</b>	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):  <b>6.5 lb/MMBtu x 225 MMBtu/hr = 1,462.5 lb/hr</b> <b>0.35 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 1,165.08 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Maximum emissions occur under cold startup conditions. 0.35 lb/MMBtu is a 12-month rolling average. Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.35 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>lb/hour</b> <b>1,165.1 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous CO monitor.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>lb/MMBtu limit based on 12-month rolling average. Based on biomass firing.</b>	



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>VOC</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>45.6 lb/hour      199.7 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.06 lb/MMBtu</b> Reference: <b>Permit limit</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>0.06 lb/MMBtu x 760 MMBtu/hr = 45.6 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>ESCNA</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.06 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>45.6 lb/hour      199.7 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Annual stack test using EPA Method 25A/18.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>VOC</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour _____ tons/year _____	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>ESCNAA</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>14.7 lb/hour 23.4 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Limit No. 2 fuel oil burning to 24.9 percent for any single boiler.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on No. 2 fuel oil firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>Pb - Lead</b>	2. Total Percent Efficiency of Control:		
3. Potential Emissions: <b>0.11 lb/hour</b>	<b>0.50</b>	tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: <b><math>1.5 \times 10^{-4}</math> lb/MMBtu</b> Reference: <b>Permit limit</b>		7. Emissions Method Code: <b>0</b>	
8. Calculation of Emissions (limit to 600 characters):  <b><math>1.5 \times 10^{-4}</math> lb/MMBtu x 760 MMBtu/hr = 0.11 lb/hr</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>			

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: <b><math>1.5 \times 10^{-4}</math> lb/MMBtu</b>	<b>0.11</b>	lb/hour	<b>0.50</b> tons/year
5. Method of Compliance (limit to 60 characters):  <b>Stack test using EPA Method 12, once every 5 years.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>SAM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>13.7 lb/hour</b>	4. Synthetically Limited? [ ] <b>12.0 tons/year</b>
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: <b>0.018 lb/MMBtu</b> Reference: <b>AP-42</b>	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):  <b>0.018 lb/MMBtu x 760 MMBtu/hr = 13.68 lb/hr</b> <b>Annual average = 0.0036 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 11.98 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.018 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>13.7 lb/hour</b> <b>12.0 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>EPA Method 8, once every 5 years.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>FI - Fluorides</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>0.53</b> lb/hour <b>2.33</b> tons/year		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1            [ ] 2            [ ] 3            _____ to _____ tons/year			
6. Emission Factor: <b><math>7 \times 10^{-4}</math> lb/MMBtu</b> Reference: <b>Stack Test Data</b>		7. Emissions Method Code: <b>0</b>	
8. Calculation of Emissions (limit to 600 characters):  <b><math>7 \times 10^{-4}</math> lb/MMBtu x 760 MMBtu/hr = 0.53 lb/hr</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>			

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:		4. Equivalent Allowable Emissions:  lb/hour                      tons/year	
5. Method of Compliance (limit to 60 characters):			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>H114 - Mercury</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>0.0041 lb/hour      0.018 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b><math>5.4 \times 10^{-6}</math> lb/MMBtu</b> Reference: <b>Permit limit</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b><math>5.4 \times 10^{-6}</math> lb/MMBtu x 760 MMBtu/hr = 0.0041 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b><math>5.4 \times 10^{-6}</math> lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>0.0041 lb/hour      0.018 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Stack test using EPA Method 29, once every 5 years.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation 1 of 1

1. Visible Emissions Subtype: <b>VE20</b>	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Requested Allowable Opacity: Normal Conditions: <b>20</b> %      Exceptional Conditions: <b>27</b> % Maximum Period of Excess Opacity Allowed:      min/hour	
4. Method of Compliance: <b>EPA Method 9</b>	
5. Visible Emissions Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 1 of 5

1. Parameter Code: <b>VE</b>	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information: Manufacturer: <b>Durag</b> Model Number: <b>D-R281-31-AV</b> Serial Number: <b>31019</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**H. VISIBLE EMISSIONS INFORMATION**  
 (Only Regulated Emissions Units Subject to a VE Limitation)

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
 (Only Regulated Emissions Units Subject to Continuous Monitoring)

**Continuous Monitoring System:** Continuous Monitor  2  of  5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>NO<sub>x</sub></b>
3. CMS Requirement:	[ <input checked="" type="checkbox"/> ] Rule [ ] Other
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>42D</b> Serial Number: <b>42D-52618-292</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 3 of 5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>SO<sub>2</sub></b>
3. CMS Requirement:	[ ] Rule [ <b>X</b> ] Other
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>43B</b> Serial Number: <b>43B-51400-292</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	



**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 4 of 5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>CO</b>
3. CMS Requirement:	[ ] Rule [ <b>X</b> ] Other
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>48</b> Serial Number: <b>48-45334-273</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 5 of 5

1. Parameter Code:	2. Pollutant(s): <b>O<sub>2</sub></b>
3. CMS Requirement:	[ <input checked="" type="checkbox"/> ] Rule [ ] Other
4. Monitor Information: Manufacturer: <b>Yokogawa</b> Model Number: <b>ZA8C</b> Serial Number: <b>JJ113MA345</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)****Supplemental Requirements**

1. Process Flow Diagram [ <b>X</b> ] Attached, Document ID: <u>NH-FI-C3</u> [ ] Not Applicable [ ] Waiver Requested
2. Fuel Analysis or Specification [ <b>X</b> ] Attached, Document ID: <u>NH-EU2-J2</u> [ ] Not Applicable [ ] Waiver Requested
3. Detailed Description of Control Equipment [ <b>X</b> ] Attached, Document ID: <u>NH-EU2-J3</u> [ ] Not Applicable [ ] Waiver Requested
4. Description of Stack Sampling Facilities [ ] Attached, Document ID: _____ [ <b>X</b> ] Not Applicable [ ] Waiver Requested
5. Compliance Test Report [ ] Attached, Document ID: _____ [ ] Previously submitted, Date: _____ [ <b>X</b> ] Not Applicable
6. Procedures for Startup and Shutdown [ ] Attached, Document ID: _____ [ <b>X</b> ] Not Applicable [ ] Waiver Requested
7. Operation and Maintenance Plan [ ] Attached, Document ID: _____ [ <b>X</b> ] Not Applicable [ ] Waiver Requested
8. Supplemental Information for Construction Permit Application [ <b>X</b> ] Attached, Document ID: <u>PSD Report</u> [ ] Not Applicable
9. Other Information Required by Rule or Statute [ ] Attached, Document ID: _____ [ <b>X</b> ] Not Applicable
10. Supplemental Requirements Comment:

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

**ATTACHMENT NH-EU2-C**

**LIST OF APPLICABLE REGULATIONS**

## EU ID 030 : Cogen Boiler A Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	
APPLICABLE	60 Subpart A	40CFR60.7	Notification and Record Keeping	
APPLICABLE	60Subpart A	40CFR60.8	Performance Testing	
APPLICABLE	60 Subpart A	40CFR60.11	Compliance with standards and maintenance requirements.	
APPLICABLE	60 Subpart A	40CFR60.12	Circumvention.	
APPLICABLE	60 Subpart A	40CFR60.13	Monitoring requirements.	
APPLICABLE	60 Subpart A	40CFR60.19	General notification and reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.40a	Subpart Da - NSPS for Electric Utility Units for which construction commenced after Sept. 18, 1978.	
APPLICABLE	60 Subpart Da	40CFR60.42a	Standard for particulate matter	
APPLICABLE	60 Subpart Da	40CFR60.43a	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(a)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(b)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(d)(2)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(g)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(h)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.44a	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.44a(a)	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.44a(c)	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.46a	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(a)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(b)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(c)	Compliance provisions.	
NON-APPLICABLE	60 Subpart Da	40CFR60.46a(d)	Compliance provisions.	Cogen Boiler A does not have a flue gas desulfurization system.
APPLICABLE	60 Subpart Da	40CFR60.46a(e)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(f)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(g)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(h)	Compliance provisions.	
NON-APPLICABLE	60 Subpart Da	40CFR60.46a(i)	Compliance provisions.	Cogen Boiler A has not been modified after July 7, 1997.
APPLICABLE	60 Subpart Da	40CFR60.47a	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(a)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(b)(2)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(b)(3)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(c)(1)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(d)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(e)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(f)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(g)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(h)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(i)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(j)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.48a	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(a)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(b)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(c)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(d)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(e)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.49a	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(a)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(b)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(c)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(d)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(f)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(g)	Reporting requirements	

## EU ID 030 : Cogen Boiler A Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	60 Subpart Da	40CFR60.49a(h)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(i)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(j)	Reporting requirements	
APPLICABLE	60 Subpart Ea	40CFR60.50a(d)	Standards of performance for municipal waste combustors	
APPLICABLE	60 Subpart Ea	40CFR60.50b(j)	Standards of performance for municipal waste combustors	
APPLICABLE	62-204	62-204.800(7)2.	NSPS Subpart Da adopted by reference.	
APPLICABLE	62-296 <	62-296	STATIONARY SOURCES - EMISSION STANDARDS	
APPLICABLE	62-296 <	62-296.405(2)	Fossil Fuel Steam Generators with more than 250 million Btu per Hour Heat Input.	
NON-APPLICABLE	62-296 <	62-296.406	Fossil Fuel Steam Generators with less than 250 Million Btu per Hour Heat Input, New and Existing Em	Cogen Boiler A has a heat input of > 250 MMBtu/hr.
NON-APPLICABLE	62-296 <	62-296.410	Carbonaceous Fuel Burning Equipment.	Not more stringent or different than NSPS.
APPLICABLE	62-296 >	62-296.500	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.500(2)(a)	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.500(2)(c)	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.570	Reasonably Available Control Technology (RACT) - Requirements for Major VOC- and NOx-Emitting Facility.	
APPLICABLE	62-296 >	62-296.570(1)	Applicability.	
APPLICABLE	62-296 >	62-296.570(1)(a)	Applicability.	
APPLICABLE	62-296 >	62-296.570(2)	Compliance Requirements.	
APPLICABLE	62-296 >	62-296.570(3)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(a)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(b)6.	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(c)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.620		
NON-APPLICABLE	62-296 >	62-296.700	Reasonably Available Control Technology (RACT) Particulate Matter.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
NON-APPLICABLE	62-296 >	62-296.702	Fossil Fuel Steam Generators.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
NON-APPLICABLE	62-296 >	62-296.703	Carbonaceous Fuel Burners.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
APPLICABLE	62-297	62-297	STATIONARY SOURCES - EMISSIONS MONITORING	
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements	
APPLICABLE	62-297	62-297.401	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(1)(a)	EPA Method 1 - Sample and Velocity Traverses for Stationary sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(10)	EPA Method 10 - Determination of Carbon Monoxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(12)	EPA Method 12 - Determination of Inorganic Lead Emissions from Stationary Sources - 40 CFR 60 Append	
APPLICABLE	62-297	62-297.401(13)	EPA Methods 13A and 13B.	
APPLICABLE	62-297	62-297.401(18)	EPA Method 18 - Measurement of Gaseous Organic Compound Emissions by Gas Chromatography - 40 CFR 60	
APPLICABLE	62-297	62-297.401(19)	EPA Method 19 - Determination of Sulfur Dioxide Removal Efficiency and Particulate, Sulfur Dioxide a	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A	

## EU ID 030 : Cogen Boiler A Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-297	62-297.401(25)	EPA Method 25 - Determination of Total Gaseous Nonmethane Organic Emissions as Carbon - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CF	
APPLICABLE	62-297	62-297.401(32)	EPA Method 101 - Determination of Particulate and Gaseous Mercury Emissions from Chlor-Alkali Plants	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(41)	EPA Method 201 - Determination of PM10 Emissions (Exhaust Gas Recycle Procedure) - 40 CFR 51 Appendix	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(6)	EPA Method 6 - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(6)(c)	EPA Method 6C - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(7)	EPA Method 7 - Determination of Nitrogen Oxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(7)(e)	EPA Method 7E - Determination of Nitrogen Oxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(9)	EPA Test Method 9	



**ATTACHMENT NH-EU2-J2**

**FUEL ANALYSIS OR SPECIFICATION**

**ATTACHMENT NH-EU2-J2  
DESIGN FUEL SPECIFICATIONS<sup>a</sup> FOR THE  
NEW HOPE POWER PARTNERSHIP COGENERATION FACILITY**

Parameter	Biomass		No. 2 Fuel Oil	Natural Gas
	Bagasse	Wood Waste		
Specific Gravity	-	-	0.865	-
Heating Value (Btu/lb)	3,600	4,500	19,175	-
Heating Value (Btu/gal)	-	-	138,000	-
Heating Value (Btu/scf)				1,000
Ultimate Analysis (dry basis percentage):				
Carbon	48.93	49.58	87.01	82.96
Hydrogen	6.14	5.87	12.47	5.41
Nitrogen	0.25	0.40	0.02	1.58
Oxygen	43.84	40.90	0.00	5.72
Sulfur	0.03	0.07	0.05	0.67
Ash/Inorganic	1.0	9.0	0.00	3.66
Moisture	52	37	-	4.5

<sup>a</sup> Represents average fuel characteristics.

Sources: New Hope Power Partnership, 2000.  
Combustion Engineering, 1981.

**ATTACHMENT NH-EU2-J3**

**DETAILED DESCRIPTION OF CONTROL EQUIPMENT**

**ATTACHMENT NH-EU2-J3  
DETAILED DESCRIPTION OF CONTROL EQUIPMENT**

The cogeneration facility utilizes several emission control techniques to reduce emissions. A selective non-catalytic reduction (SNCR) system is used to reduce NO<sub>x</sub> emissions. Further, the cogeneration boilers minimize CO and VOC through proper furnace design and good combustion practices, including: control of combustion air and combustion temperature; distribution of fuel on the combustion grate; and controls over the furnace loads and transient conditions. Particulate emissions are controlled by an ESP. Multiple cyclones were installed during the 2000 calendar year to improve control of particulate emissions.

Electrostatic Precipitator

The EPS's for the New Hope Power Partnership facility are manufactured by Flakt, Inc. Design specifications for the ESP (one per boiler) are provided below:

- Chambers = 1
- Collecting Plate = 12.30 ft L x 39.37 ft H
- Fields/Chamber = 3
- Specific Collection Area = 200 ft<sup>2</sup>/1,000 acfm (minimum)
- Gas Velocity = <4 ft/s
- Pressure Drop = less than 2.8 inches H<sub>2</sub>O
- Operating Temperature = 350°F
- Ash Handling = Trough hopper with screw conveyor
- Particulate removal efficiency: >99.2%

NO<sub>x</sub> Control System

The NO<sub>x</sub> control system design employs a urea injection system manufactured by Nalco-Fueltech for NO<sub>x</sub> control. The technology is a selective non-catalytic reduction process, which reduces NO<sub>x</sub> emissions through chemical reaction with urea. In the process, urea is injected into the flue gas stream and reacts with nitrogen oxides to form nitrogen and water vapor.

The NO<sub>x</sub> control system includes the following major components:

- Carrier air compressors,
- Urea tank,
- Urea/air flow controls,
- Control panel,

- Injection manifolds and injectors, and
- Valves and instrumentation.

A single urea storage tank system is installed to supply urea to all three boilers. Urea for injection into the boilers is drawn from the tank. Two injection zones are used to provide injection at full and part load conditions. Each zone has six injectors. Zone switching valves will direct the urea/carrier mixture to the appropriate injection zone.

Specifications for the urea injection system to meet the NO<sub>x</sub> emission rate of 0.15 lb/MMBtu when firing biomass or No. 2 fuel oil are provided below (on a per boiler basis):

Urea injection rate - 65 gal/hr (max)

Ammonia Slip - Biomass, No. 2 fuel oil - 25 ppm (max)

#### Dust Control System

The cyclone dust collectors are supplied by Barron Industries, Model 460 Tube Base III 9K15-2023 AU. These are mechanical cyclone dust collectors which remove larger size particulate matter prior to the ESP. There are 460 Cyclone tubes in all.

**III. EMISSIONS UNIT INFORMATION**

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION**  
**(All Emissions Units)**

**Emissions Unit Description and Status**

1. Type of Emissions Unit Addressed in This Section: (Check one)			
<input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
<input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
<input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): <b>Cogen Boiler B fired by Biomass/No. 2 Fuel Oil/Natural Gas</b>			
4. Emissions Unit Identification Number: ID: <b>031</b>		<input type="checkbox"/> No ID <input type="checkbox"/> ID Unknown	
5. Emissions Unit Status Code: <b>A</b>	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: <b>49</b>	8. Acid Rain Unit? <input type="checkbox"/>
9. Emissions Unit Comment: (Limit to 500 Characters)  <b>74.9 MW net generating capacity for entire facility.</b>			

**Emissions Unit Control Equipment**

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

**ESP - Electrostatic Precipitator - High Efficiency**

**Selective Non-catalytic Reduction for NO<sub>x</sub>**

**Multiple Cyclone w/o Fly Ash Reinjection**

**Activated Carbon Injection System**

2. Control Device or Method Code(s): **010, 107, 076, 048**

**Emissions Unit Details**

1. Package Unit:	
Manufacturer:	Model Number:
2. Generator Nameplate Rating:	<b>75 MW</b>
3. Incinerator Information:	
Dwell Temperature:	°F
Dwell Time:	seconds
Incinerator Afterburner Temperature:	°F

**B. EMISSIONS UNIT CAPACITY INFORMATION**  
(Regulated Emissions Units Only)

**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	<b>760</b>	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:		tons/hr
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	<b>24</b> hours/day	<b>7</b> days/week
	<b>52</b> weeks/year	<b>8,760</b> hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):		
<p>Maximum heat input rates:            Biomass - 760 MMBtu/hr;            No. 2 Fuel Oil - 490 MMBtu/hr;            Natural Gas - 605 MMBtu/hr</p>		



**C. EMISSIONS UNIT REGULATIONS**  
**(Regulated Emissions Units Only)**

List of Applicable Regulations

See Attachment NH-EU3-C.	

**D. EMISSION POINT (STACK/VENT) INFORMATION  
(Regulated Emissions Units Only)**

**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? <b>BLR B</b>		2. Emission Point Type Code: <b>1</b>	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: <b>V</b>	6. Stack Height: <b>199</b> feet	7. Exit Diameter: <b>10.0</b> feet	
8. Exit Temperature: <b>352</b> °F	9. Actual Volumetric Flow Rate: <b>319,000</b> acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: East (km): North (km):			
14. Emission Point Comment (limit to 200 characters):  <b>Stack parameters based on biomass firing. See Table 2-5 in PSD Report for all boiler stack data.</b>			

**E. SEGMENT (PROCESS/FUEL) INFORMATION  
(All Emissions Units)**

**Segment Description and Rate:** Segment 1 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Bagasse</b>		
2. Source Classification Code (SCC): <b>1-01-011-01</b>		3. SCC Units: <b>Tons Burned (all solid fuels)</b>
4. Maximum Hourly Rate: <b>105.56</b>	5. Maximum Annual Rate: <b>924,667</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash: <b>1.0</b>	9. Million Btu per SCC Unit: <b>7.2</b>
10. Segment Comment (limit to 200 characters):		

**Segment Description and Rate:** Segment 2 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Wood Fired Boiler</b>		
2. Source Classification Code (SCC): <b>1-01-009-03</b>		3. SCC Units: <b>Tons Burned (all solid fuels)</b>
4. Maximum Hourly Rate: <b>84.44</b>	5. Maximum Annual Rate: <b>739,733</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.3</b>	8. Maximum % Ash: <b>9.0</b>	9. Million Btu per SCC Unit: <b>9.0</b>
10. Segment Comment (limit to 200 characters):		

**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
(All Emissions Units)

**Segment Description and Rate:** Segment 3 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Distillate Oil - Grades 1 and 2 Oil</b>		
2. Source Classification Code (SCC): <b>1-01-005-01</b>		3. SCC Units: <b>Thousand Gallons Burned (all liquid fuels)</b>
4. Maximum Hourly Rate: <b>3.551</b>	5. Maximum Annual Rate: <b>11,309</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash:	9. Million Btu per SCC Unit: <b>138</b>
10. Segment Comment (limit to 200 characters):		

**Segment Description and Rate:** Segment 4 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Natural Gas</b>		
2. Source Classification Code (SCC): <b>1-01-006-01</b>		3. SCC Units: <b>MMscf Burned</b>
4. Maximum Hourly Rate: <b>0.605</b>	5. Maximum Annual Rate: <b>1,561</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: <b>1,000</b>
10. Segment Comment (limit to 200 characters):		

**F. EMISSIONS UNIT POLLUTANTS  
(All Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM	076	010	EL
PM <sub>10</sub>	076	010	EL
SO <sub>2</sub>			EL
NO <sub>x</sub>	107		EL
CO			EL
VOC			EL
PB	076	010	EL
SAM			NS
FL			NS
H114	048		EL

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>22.8</b> lb/hour <b>99.86</b> tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.03 lb/MMBtu</b> Reference: <b>40 CFR 60 Subpart Da</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>0.03 lb/MMBtu x 760 MMBtu/hr = 22.8 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>22.8</b> lb/hour <b>99.86</b> tons/year
5. Method of Compliance (limit to 60 characters):  <b>Annual Stack testing using EPA Method 5.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Basis for Allowable Emissions Code: NSPS. Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour _____ tons/year _____	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 2 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>14.70 lb/hour 23.42 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Fuel Analysis.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Basis for Allowable Emissions Code: NSPS. Based on No. 2 fuel oil firing.</b>	





**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM<sub>10</sub></b>	2. Total Percent Efficiency of Control:		
3. Potential Emissions: <b>22.8 lb/hour</b>	<b>99.86</b>	tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: <b>0.03 lb/MMBtu</b> Reference: <b>40 CFR 60 Subpart Da</b>		7. Emissions Method Code: <b>0</b>	
8. Calculation of Emissions (limit to 600 characters):  <b>0.03 lb/MMBtu x 760 MMBtu/hr = 22.8 lb/hr</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>			

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	<b>22.8 lb/hour</b>	<b>99.86 tons/year</b>	4. Equivalent Allowable Emissions:
5. Method of Compliance (limit to 60 characters):  <b>Annual Stack testing using EPA Method 5.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM<sub>10</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour _____ tons/year _____	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 2 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>14.70 lb/hour 23.42 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Fuel Analysis.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Basis for Allowable Emissions Code: NSPS. Based on No. 2 fuel oil firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM<sub>10</sub></b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: . [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions 3 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>		4. Equivalent Allowable Emissions: <b>18.15 lb/hour 23.42 tons/year</b>	
5. Method of Compliance (limit to 60 characters):  <b>Good combustion practices and limit natural gas burning to 24.9 percent.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Basis for Allowable Emissions Code: NSPS. Based on natural gas firing. Hourly: 0.03 lb/MMBtu x 605 MMBtu/hr = 18.15 lb/hr; Annual: 0.03 lb/MMBtu x 1.561 x 10<sup>12</sup> Btu/yr ÷ 2000 lb/ton = 23.42 TPY</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: <b>SO<sub>2</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>228.0 lb/hour      199.7 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.30 lb/MMBtu</b> Reference: <b>CEM data</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>3-Hour average = 0.30 lb/MMBtu x 760 MMBtu/hr = 228.0 lb/hr</b> <b>24-Hour average = 0.20 lb/MMBtu x 760 MMBtu/hr = 152 lb/hr</b> <b>Annual average = 0.06 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 199.73 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.20 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>152.0 lb/hour      199.7 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous SO<sub>2</sub> monitor.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Requested Allowable Emissions: 0.20 lb/MMBtu 24-hr average; 0.06 lb/MMBtu annual average. Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>SO<sub>2</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour    tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1            [ ] 2            [ ] 3            _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>RULE</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.05 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>24.5 lb/hour            39.0 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Fuel analysis and limit fuel oil burning to 24.9 percent.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on No. 2 Fuel Oil firing and BACT.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NO<sub>x</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>152.0 lb/hour</b> <b>499.3 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.15 lb/MMBtu</b> Reference: <b>Permit Limit</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  Short-term: <b>0.20 lb/MMBtu x 760 MMBtu/hr = 152.0 lb/hr</b> Annual: <b>0.15 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2000 lb/ton = 499.3 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>ESCPSD</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>	4. Equivalent Allowable Emissions:  lb/hour <b>499.3 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous NO<sub>x</sub> monitor.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing, as a 30-day rolling average.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NO<sub>x</sub></b>	2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour	tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year		
6. Emission Factor: Reference:		7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):		
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):		

**Allowable Emissions** Allowable Emissions 2 of 3

1. Basis for Allowable Emissions Code: <b>ESCPD</b>	2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>	lb/hour	4. Equivalent Allowable Emissions: <b>117.1 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Continuous NO<sub>x</sub> monitor and limit fuel oil burning to 24.9 percent.</b>		
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on No. 2 fuel oil firing, as a 30-day rolling average.</b>		

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NO<sub>x</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <div style="display: flex; justify-content: space-between;"><span>lb/hour</span><span>tons/year</span></div>	4. Synthetically Limited? [ <input type="checkbox"/> ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions  3  of  3 

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>	4. Equivalent Allowable Emissions: <div style="display: flex; justify-content: space-between;"><span>lb/hour</span><span>117.1 tons/year</span></div>
5. Method of Compliance (limit to 60 characters):  <b>Continuous NO<sub>x</sub> monitor and limit natural gas burning to 24.9 percent.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on natural gas firing, as a 30-day rolling average.</b>	



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>CO</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>1,462.5 lb/hour</b>	4. Synthetically Limited? [ ] <b>1,165.1 tons/year</b>
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: <b>6.5 lb/MMBtu</b> Reference: <b>CEM Data</b>	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):  <b>6.5 lb/MMBtu x 225 MMBtu/hr = 1,462.5 lb/hr</b> <b>0.35 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 1,165.08 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Maximum emissions occur under cold startup conditions. 0.35 lb/MMBtu is a 12-month rolling average. Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.35 lb/MMBtu</b>	4. Equivalent Allowable Emissions:  <b>lb/hour 1,165.1 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous CO monitor.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>lb/MMBtu limit based on 12-month rolling average. Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: <b>CO</b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions:  lb/hour                                    tons/year		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1            [ ] 2            [ ] 3            _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.35 lb/MMBtu</b>		4. Equivalent Allowable Emissions:  lb/hour <b>273.2 tons/year</b>	
5. Method of Compliance (limit to 60 characters):  <b>Continuous CO monitor.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>lb/MMBtu limit based on 12-month rolling average. Based on No. 2 fuel oil firing.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>VOC</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>45.6</b> lb/hour <b>199.7</b> tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.06 lb/MMBtu</b> Reference: <b>Permit limit</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>0.06 lb/MMBtu x 760 MMBtu/hr = 45.6 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>ESCNA</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.06 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>45.6</b> lb/hour <b>199.7</b> tons/year
5. Method of Compliance (limit to 60 characters):  <b>Annual stack test using EPA Method 25A/18.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: <b>VOC</b>	2. Total Percent Efficiency of Control:	
3. Potential Emissions:  <p align="center">lb/hour                                  tons/year</p>	4. Synthetically Limited? [    ]	
5. Range of Estimated Fugitive Emissions: [    ] 1        [    ] 2        [    ] 3        _____ to _____ tons/year		
6. Emission Factor: Reference:	7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):		
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):		

Allowable Emissions Allowable Emissions  2  of  2 

1. Basis for Allowable Emissions Code: <b>ESCNAA</b>	2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>14.7 lb/hour        23.4 tons/year</b>	
5. Method of Compliance (limit to 60 characters): <b>Limit No. 2 fuel oil burning to 24.9 percent for any single boiler.</b>		
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on No. 2 fuel oil firing.</b>		

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>Pb - Lead</b>	2. Total Percent Efficiency of Control:		
3. Potential Emissions: <b>0.11 lb/hour</b>	<b>0.50 tons/year</b>	4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: <b><math>1.5 \times 10^{-4}</math> lb/MMBtu</b> Reference: <b>Permit limit</b>		7. Emissions Method Code: <b>0</b>	
8. Calculation of Emissions (limit to 600 characters):  <b><math>1.5 \times 10^{-4}</math> lb/MMBtu x 760 MMBtu/hr = 0.11 lb/hr</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>			

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: <b><math>1.5 \times 10^{-4}</math> lb/MMBtu</b>	<b>0.11 lb/hour</b>	<b>0.50 tons/year</b>	
5. Method of Compliance (limit to 60 characters):  <b>Stack test using EPA Method 12, once every 5 years.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: <b>SAM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>13.7 lb/hour</b>	4. Synthetically Limited? [ ] <b>12.0 tons/year</b>
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: <b>0.018 lb/MMBtu</b> Reference: <b>AP-42</b>	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):  <b>0.018 lb/MMBtu x 760 MMBtu/hr = 13.68 lb/hr</b> <b>Annual average = 0.0036 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 11.98 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.018 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>13.7 lb/hour</b> <b>12.0 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>EPA Method 8, once every 5 years.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>FI - Fluorides</b>	2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>0.53</b> lb/hour	<b>2.33</b> tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year		
6. Emission Factor: <b><math>7 \times 10^{-4}</math> lb/MMBtu</b> Reference: <b>Stack Test Data</b>		7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b><math>7 \times 10^{-4}</math> lb/MMBtu x 760 MMBtu/hr = 0.53 lb/hr</b>		
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>		

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:	lb/hour	tons/year
4. Equivalent Allowable Emissions:		
5. Method of Compliance (limit to 60 characters):		
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):		

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>H114 - Mercury</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>0.0041 lb/hour      0.018 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b><math>5.4 \times 10^{-6}</math> lb/MMBtu</b> Reference: <b>Permit limit</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b><math>5.4 \times 10^{-6}</math> lb/MMBtu x 760 MMBtu/hr = 0.0041 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b><math>5.4 \times 10^{-6}</math> lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>0.0041 lb/hour      0.018 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Stack test using EPA Method 29, once every 5 years.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	



**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation 1 of 1

1. Visible Emissions Subtype: <b>VE20</b>	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Requested Allowable Opacity: Normal Conditions: <b>20</b> %    Exceptional Conditions: <b>27</b> % Maximum Period of Excess Opacity Allowed:      min/hour	
4. Method of Compliance: <b>EPA Method 9</b>	
5. Visible Emissions Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 1 of 5

1. Parameter Code: <b>VE</b>	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information: Manufacturer: <b>Durag</b> Model Number: <b>D-R281-31-AV</b> Serial Number: <b>31019</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 2 of 5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>NO<sub>x</sub></b>
3. CMS Requirement:	[ <input checked="" type="checkbox"/> ] Rule [ ] Other
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>42D</b> Serial Number: <b>42D-52618-292</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 3 of 5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>SO<sub>2</sub></b>
3. CMS Requirement:	[ ] Rule [ <b>X</b> ] Other
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>43B</b> Serial Number: <b>43B-51400-292</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 4 of 5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>CO</b>
3. CMS Requirement:	[ ] Rule [ <b>X</b> ] Other
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>48</b> Serial Number: <b>48-45334-273</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 5 of 5

1. Parameter Code:	2. Pollutant(s): O <sub>2</sub>
3. CMS Requirement:	[ X ] Rule [ ] Other
4. Monitor Information: Manufacturer: <b>Yokogawa</b> Model Number: <b>ZA8C</b> Serial Number: <b>JJ113MA345</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)****Supplemental Requirements**

1. Process Flow Diagram <input checked="" type="checkbox"/> Attached, Document ID: <u>NH-FI-C3</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Fuel Analysis or Specification <input checked="" type="checkbox"/> Attached, Document ID: <u>NH-EU2-J2</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Detailed Description of Control Equipment <input checked="" type="checkbox"/> Attached, Document ID: <u>NH-EU2-J3</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Description of Stack Sampling Facilities <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
5. Compliance Test Report <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously submitted, Date: _____ <input checked="" type="checkbox"/> Not Applicable
6. Procedures for Startup and Shutdown <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
7. Operation and Maintenance Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
8. Supplemental Information for Construction Permit Application <input checked="" type="checkbox"/> Attached, Document ID: <u>PSD Report</u> <input type="checkbox"/> Not Applicable
9. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
10. Supplemental Requirements Comment:

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

**ATTACHMENT NH-EU3-C**

**LIST OF APPLICABLE REGULATIONS**



## EU ID 031 : Cogen Boiler B Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	
APPLICABLE	60 Subpart A	40CFR60.7	Notification and Record Keeping	
APPLICABLE	60 Subpart A	40CFR60.8	Performance Testing	
APPLICABLE	60 Subpart A	40CFR60.11	Compliance with standards and maintenance requirements.	
APPLICABLE	60 Subpart A	40CFR60.12	Circumvention.	
APPLICABLE	60 Subpart A	40CFR60.13	Monitoring requirements.	
APPLICABLE	60 Subpart A	40CFR60.19	General notification and reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.40a	Subpart Da - NSPS for Electric Utility Units for which construction commenced after Sept. 18, 1978.	
APPLICABLE	60 Subpart Da	40CFR60.42a	Standard for particulate matter	
APPLICABLE	60 Subpart Da	40CFR60.43a	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(a)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(b)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(d)(2)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(g)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(h)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.44a	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.44a(a)	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.44a(c)	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.46a	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(a)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(b)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(c)	Compliance provisions.	
NON-APPLICABLE	60 Subpart Da	40CFR60.46a(d)	Compliance provisions.	Cogen Boiler B does not have a flue gas desulfurization system.
APPLICABLE	60 Subpart Da	40CFR60.46a(e)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(f)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(g)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(h)	Compliance provisions.	
NON-APPLICABLE	60 Subpart Da	40CFR60.46a(i)	Compliance provisions.	Cogen Boiler B has not been modified after July 7, 1997.
APPLICABLE	60 Subpart Da	40CFR60.47a	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(a)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(b)(2)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(b)(3)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(c)(1)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(d)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(e)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(f)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(g)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(h)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(i)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(j)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.48a	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(a)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(b)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(c)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(d)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(e)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.49a	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(a)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(b)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(c)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(d)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(f)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(g)	Reporting requirements	

## EU ID 031 : Cogen Boiler B Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	60 Subpart Da	40CFR60.49a(h)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(i)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(j)	Reporting requirements	
APPLICABLE	60 Subpart Ea	40CFR60.50a(d)	Standards of performance for municipal waste combustors	
APPLICABLE	60 Subpart Ea	40CFR60.50b(j)	Standards of performance for municipal waste combustors	
APPLICABLE	62-204	62-204.800(7)2.	NSPS Subpart Da adopted by reference.	
APPLICABLE	62-296 <	62-296	STATIONARY SOURCES - EMISSION STANDARDS	
APPLICABLE	62-296 <	62-296.405(2)	Fossil Fuel Steam Generators with more than 250 million Btu per Hour Heat Input.	
NON-APPLICABLE	62-296 <	62-296.406	Fossil Fuel Steam Generators with less than 250 Million Btu per Hour Heat Input, New and Existing Em	Cogen Boiler B has a heat input of >250 MMBtu/hr.
NON-APPLICABLE	62-296 <	62-296.410	Carbonaceous Fuel Burning Equipment.	Not more stringent or different than NSPS.
APPLICABLE	62-296 >	62-296.500	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.500(2)(a)	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.500(2)(c)	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.570	Reasonably Available Control Technology (RACT) - Requirements for Major VOC- and NOx-Emitting Facility	
APPLICABLE	62-296 >	62-296.570(1)	Applicability.	
APPLICABLE	62-296 >	62-296.570(1)(a)	Applicability.	
APPLICABLE	62-296 >	62-296.570(2)	Compliance Requirements.	
APPLICABLE	62-296 >	62-296.570(3)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(a)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(b)6	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(c)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.620		
NON-APPLICABLE	62-296 >	62-296.700	Reasonably Available Control Technology (RACT) Particulate Matter.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
NON-APPLICABLE	62-296 >	62-296.702	Fossil Fuel Steam Generators.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
NON-APPLICABLE	62-296 >	62-296.703	Carbonaceous Fuel Burners.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
APPLICABLE	62-297	62-297	STATIONARY SOURCES - EMISSIONS MONITORING	
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401	Compliance Test Methods	
APPLICABLE	62-297	62-297.401(1)(a)	EPA Method 1 - Sample and Velocity Traverses for Stationary sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(10)	EPA Method 10 - Determination of Carbon Monoxide Emissions from Stationary Sources 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(12)	EPA Method 12 - Determination of Inorganic Lead Emissions from Stationary Sources - 40 CFR 60 Append	
APPLICABLE	62-297	62-297.401(13)	EPA Methods 13A and 13B.	
APPLICABLE	62-297	62-297.401(18)	EPA Method 18 - Measurement of Gaseous Organic Compound Emissions by Gas Chromatography - 40 CFR 60	
APPLICABLE	62-297	62-297.401(19)	EPA Method 19 - Determination of Sulfur Dioxide Removal Efficiency and Particulate, Sulfur Dioxide a	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A.	

## EU ID 031 : Cogen Boiler B Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-297	62-297.401(25)	EPA Method 25 - Determination of Total Gaseous Nonmethane Organic Emissions as Carbon - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CF	
APPLICABLE	62-297	62-297.401(32)	EPA Method 101 - Determination of Particulate and Gaseous Mercury Emissions from Chlor-Alkali Plants	
APPLICABLE	62-297	62-297.401(35)	EPA Method 104 - Determination of Beryllium Emissions from Stationary Sources - 40 CFR 61 Appendix B	
APPLICABLE	62-297	62-297.401(39)	EPA Method 108 - Determination of Particulate and Gaseous Arsenic Emissions - 40 CFR 61 Appendix B.	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(41)	EPA Method 201 - Determination of PM10 Emissions (Exhaust Gas Recycle Procedure) - 40 CFR 51 Appendix	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(6)	EPA Method 6 - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(6)(c)	EPA Method 6C - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(7)	EPA Method 7 - Determination of Nitrogen Oxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(7)(e)	EPA Method 7E - Determination of Nitrogen Oxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(8)	EPA Method 8 - Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sour	
APPLICABLE	62-297	62-297.401(9)	EPA Test Method 9	

**III. EMISSIONS UNIT INFORMATION**

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION**  
**(All Emissions Units)**

**Emissions Unit Description and Status**

1. Type of Emissions Unit Addressed in This Section: (Check one)			
<input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
<input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
<input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): <b>Cogen Boiler C fired by Biomass/No. 2 Fuel Oil/Natural Gas</b>			
4. Emissions Unit Identification Number:		[ ] No ID	
ID: <b>032</b>		[ ] ID Unknown	
5. Emissions Unit Status Code: <b>A</b>	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: <b>49</b>	8. Acid Rain Unit? [ ]
9. Emissions Unit Comment: (Limit to 500 Characters) <b>74.9 MW net generating capacity for entire facility.</b>			

**Emissions Unit Control Equipment**

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

**ESP - Electrostatic Precipitator - High Efficiency**

**Selective Non-catalytic Reduction for NO<sub>x</sub>**

**Multiple Cyclone w/o Fly Ash Reinjection**

**Activated Carbon Injection System**

2. Control Device or Method Code(s): **010, 107, 076, 048**

**Emissions Unit Details**

1. Package Unit:

Manufacturer:

Model Number:

2. Generator Nameplate Rating:

**75 MW**

3. Incinerator Information:

Dwell Temperature:

°F

Dwell Time:

seconds

Incinerator Afterburner Temperature:

°F

**B. EMISSIONS UNIT CAPACITY INFORMATION**  
**(Regulated Emissions Units Only)**

**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	<b>760</b>	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:		tons/hr
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	<b>24</b> hours/day	<b>7</b> days/week
	<b>52</b> weeks/year	<b>8,760</b> hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):		
<p><b>Maximum heat input rates:</b>  <b>Biomass - 760 MMBtu/hr;</b>  <b>No. 2 Fuel Oil - 490 MMBtu/hr;</b>  <b>Natural Gas - 605 MMBtu/hr</b></p>		

**C. EMISSIONS UNIT REGULATIONS  
(Regulated Emissions Units Only)**

**List of Applicable Regulations**

See Attachment NH-EU4-C.	

**D. EMISSION POINT (STACK/VENT) INFORMATION  
(Regulated Emissions Units Only)**

**Emission Point Description and Type**

1. Identification of Point on Plot Plan or Flow Diagram? <b>BLR C</b>		2. Emission Point Type Code: <b>1</b>	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: <b>V</b>	6. Stack Height: <b>199</b> feet	7. Exit Diameter: <b>10.0</b> feet	
8. Exit Temperature: <b>352</b> °F	9. Actual Volumetric Flow Rate: <b>319,000</b> acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: East (km): North (km):			
14. Emission Point Comment (limit to 200 characters):  <b>Stack parameters based on biomass firing. See Table 2-5 in PSD Report for all boiler stack data.</b>			



**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
(All Emissions Units)

**Segment Description and Rate:** Segment 1 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Bagasse</b>		
2. Source Classification Code (SCC): <b>1-01-011-01</b>		3. SCC Units: <b>Tons Burned (all solid fuels)</b>
4. Maximum Hourly Rate: <b>105.56</b>	5. Maximum Annual Rate: <b>924,667</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash: <b>1.0</b>	9. Million Btu per SCC Unit: <b>7.2</b>
10. Segment Comment (limit to 200 characters):		

**Segment Description and Rate:** Segment 2 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Wood Fired Boiler</b>		
2. Source Classification Code (SCC): <b>1-01-009-03</b>		3. SCC Units: <b>Tons Burned (all solid fuels)</b>
4. Maximum Hourly Rate: <b>84.44</b>	5. Maximum Annual Rate: <b>739,733</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.3</b>	8. Maximum % Ash: <b>9.0</b>	9. Million Btu per SCC Unit: <b>9.0</b>
10. Segment Comment (limit to 200 characters):		

**E. SEGMENT (PROCESS/FUEL) INFORMATION**  
(All Emissions Units)

**Segment Description and Rate:** Segment 3 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Distillate Oil - Grades 1 and 2 Oil</b>		
2. Source Classification Code (SCC): <b>1-01-005-01</b>		3. SCC Units: <b>Thousand Gallons Burned (all liquid fuels)</b>
4. Maximum Hourly Rate: <b>3.551</b>	5. Maximum Annual Rate: <b>11,309</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: <b>0.05</b>	8. Maximum % Ash:	9. Million Btu per SCC Unit: <b>138</b>
10. Segment Comment (limit to 200 characters):		

**Segment Description and Rate:** Segment 4 of 4

1. Segment Description (Process/Fuel Type) (limit to 500 characters):  <b>Electric Utility Boiler - Natural Gas</b>		
2. Source Classification Code (SCC): <b>1-01-006-01</b>		3. SCC Units: <b>MMscf Burned</b>
4. Maximum Hourly Rate: <b>0.605</b>	5. Maximum Annual Rate: <b>1,561</b>	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: <b>1,000</b>
10. Segment Comment (limit to 200 characters):		

**F. EMISSIONS UNIT POLLUTANTS  
(All Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM	076	010	EL
PM <sub>10</sub>	076	010	EL
SO <sub>2</sub>			EL
NO <sub>x</sub>	107		EL
CO			EL
VOC			EL
PB	076	010	EL
SAM			NS
FL			NS
H114	048		EL

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>22.8 lb/hour                      99.86 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.03 lb/MMBtu</b> Reference: <b>40 CFR 60 Subpart Da</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>0.03 lb/MMBtu x 760 MMBtu/hr = 22.8 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>22.8 lb/hour                      99.86 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Annual Stack testing using EPA Method 5.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Basis for Allowable Emissions Code: NSPS. Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: <b>PM</b>	2. Total Percent Efficiency of Control:		
3. Potential Emissions: lb/hour	tons/year	4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

Allowable Emissions Allowable Emissions 2 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>14.70 lb/hour 23.42 tons/year</b>		
5. Method of Compliance (limit to 60 characters): <b>Fuel Analysis.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Basis for Allowable Emissions Code: NSPS. Based on No. 2 fuel oil firing.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour _____ tons/year _____	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 3 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.030 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>18.15 lb/hour 23.42 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Good combustion practices and limit natural gas burning to 24.9 percent.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Basis for Allowable Emissions Code: NSPS. Based on natural gas firing. Hourly: 0.03 lb/MMBtu x 605 MMBtu/hr = 18.15 lb/hr; Annual: 0.03 lb/MMBtu x 1.561 x 10<sup>12</sup> Btu/yr ÷ 2000 lb/ton = 23.42 TPY</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM<sub>10</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>22.8 lb/hour                      99.86 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.03 lb/MMBtu</b> Reference: <b>40 CFR 60 Subpart Da</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>0.03 lb/MMBtu x 760 MMBtu/hr = 22.8 lb/hr</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>22.8 lb/hour                      99.86 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Annual Stack testing using EPA Method 5.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted:  <b>PM<sub>10</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions:  <div style="display: flex; justify-content: space-between;"> <span>lb/hour</span> <span>tons/year</span> </div>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions  2  of  3

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>14.70 lb/hour      23.42 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Fuel Analysis.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Basis for Allowable Emissions Code: NSPS. Based on No. 2 fuel oil firing.</b>	



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>PM<sub>10</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour                          tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions  3  of  3 

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>18.15 lb/hour      23.42 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Good combustion practices and limit natural gas burning to 24.9 percent.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Basis for Allowable Emissions Code: NSPS. Based on natural gas firing. Hourly: 0.03 lb/MMBtu x 605 MMBtu/hr = 18.15 lb/hr; Annual: 0.03 lb/MMBtu x 1.561 x 10<sup>12</sup> Btu/yr ÷ 2000 lb/ton = 23.42 TPY</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>SO<sub>2</sub></b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>228.0 lb/hour      199.7 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.30 lb/MMBtu</b> Reference: <b>CEM data</b>	7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>3-Hour average = 0.30 lb/MMBtu x 760 MMBtu/hr = 228.0 lb/hr</b> <b>24-Hour average = 0.20 lb/MMBtu x 760 MMBtu/hr = 152 lb/hr</b> <b>Annual average = 0.06 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 199.73 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.20 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>152.0 lb/hour      199.7 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous SO<sub>2</sub> monitor.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Requested Allowable Emissions: 0.20 lb/MMBtu 24-hr average; 0.06 lb/MMBtu annual average. Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>SO<sub>2</sub></b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>RULE</b>		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.05 lb/MMBtu</b>		4. Equivalent Allowable Emissions: <b>24.5 lb/hour 39.0 tons/year</b>	
5. Method of Compliance (limit to 60 characters): <b>Fuel analysis and limit fuel oil burning to 24.9 percent.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on No. 2 Fuel Oil firing and BACT.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NO<sub>x</sub></b>	2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>152.0 lb/hour</b>	<b>499.3 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year		
6. Emission Factor: <b>0.15 lb/MMBtu</b> Reference: <b>Permit Limit</b>		7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b>Short-term: 0.20 lb/MMBtu x 760 MMBtu/hr = 152.0 lb/hr</b> <b>Annual: 0.15 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2000 lb/ton = 499.3 TPY</b>		
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>		

**Allowable Emissions** Allowable Emissions 1 of 3

1. Basis for Allowable Emissions Code: <b>ESCPD</b>	2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>	<b>lb/hour</b>	<b>499.3 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous NO<sub>x</sub> monitor.</b>		
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing, as a 30-day rolling average.</b>		

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>NO<sub>x</sub></b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour _____ tons/year _____		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

**Allowable Emissions** Allowable Emissions 2 of 3

1. Basis for Allowable Emissions Code: <b>ESCPD</b>		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>		4. Equivalent Allowable Emissions: lb/hour _____ 117.1 tons/year	
5. Method of Compliance (limit to 60 characters): <b>Continuous NO<sub>x</sub> monitor and limit fuel oil burning to 24.9 percent.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on No. 2 fuel oil firing, as a 30-day rolling average.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION  
(Regulated Emissions Units -  
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: <b>NO<sub>x</sub></b>		2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour _____ tons/year _____		4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: Reference:		7. Emissions Method Code:	
8. Calculation of Emissions (limit to 600 characters):			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

Allowable Emissions Allowable Emissions 3 of 3

1. Basis for Allowable Emissions Code: <b>OTHER</b>		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.15 lb/MMBtu, 30-day rolling average</b>		4. Equivalent Allowable Emissions: lb/hour _____ 117.1 tons/year	
5. Method of Compliance (limit to 60 characters): <b>Continuous NO<sub>x</sub> monitor and limit natural gas burning to 24.9 percent.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on natural gas firing, as a 30-day rolling average.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>CO</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>1,462.5 lb/hour</b> <b>1,165.1 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>6.5 lb/MMBtu</b> Reference: <b>CEM Data</b>	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):  <b>6.5 lb/MMBtu x 225 MMBtu/hr = 1,462.5 lb/hr</b> <b>0.35 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 1,165.08 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Maximum emissions occur under cold startup conditions. 0.35 lb/MMBtu is a 12-month rolling average. Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.35 lb/MMBtu</b>	4. Equivalent Allowable Emissions:  lb/hour <b>1,165.1 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Continuous CO monitor.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>lb/MMBtu limit based on 12-month rolling average. Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>CO</b>	2. Total Percent Efficiency of Control:	
3. Potential Emissions: lb/hour	tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year		
6. Emission Factor: Reference:		7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):		
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):		

**Allowable Emissions** Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b>0.35 lb/MMBtu</b>	lb/hour	4. Equivalent Allowable Emissions: <b>273.2 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Continuous CO monitor.</b>		
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>lb/MMBtu limit based on 12-month rolling average. Based on No. 2 fuel oil firing.</b>		



**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>VOC</b>	2. Total Percent Efficiency of Control:		
3. Potential Emissions: <b>45.6 lb/hour</b>	<b>199.7 tons/year</b>	4. Synthetically Limited? [ ]	
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: <b>0.06 lb/MMBtu</b> Reference: <b>Permit limit</b>		7. Emissions Method Code: <b>0</b>	
8. Calculation of Emissions (limit to 600 characters):  <b>0.06 lb/MMBtu x 760 MMBtu/hr = 45.6 lb/hr</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>			

**Allowable Emissions** Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: <b>ESCNAA</b>	2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: <b>0.06 lb/MMBtu</b>	<b>45.6 lb/hour</b>	<b>199.7 tons/year</b>	
5. Method of Compliance (limit to 60 characters):  <b>Annual stack test using EPA Method 25A/18.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>			

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>VOC</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: lb/hour _____ tons/year _____	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

**Allowable Emissions** Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: <b>ESCNA</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.03 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>14.7 lb/hour 23.4 tons/year</b>
5. Method of Compliance (limit to 60 characters): <b>Limit No. 2 fuel oil burning to 24.9 percent for any single boiler.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): <b>Based on No. 2 fuel oil firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>Pb - Lead</b>	2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>0.11 lb/hour</b>	<b>0.50 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year		
6. Emission Factor: <b><math>1.5 \times 10^{-4}</math> lb/MMBtu</b> Reference: <b>Permit limit</b>		7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b><math>1.5 \times 10^{-4}</math> lb/MMBtu x 760 MMBtu/hr = 0.11 lb/hr</b>		
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>		

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: <b><math>1.5 \times 10^{-4}</math> lb/MMBtu</b>	<b>0.11 lb/hour</b>	<b>0.50 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Stack test using EPA Method 12, once every 5 years.</b>		
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>		

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>SAM</b>	2. Total Percent Efficiency of Control:
3. Potential Emissions: <b>13.7 lb/hour</b> <b>12.0 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1      [ ] 2      [ ] 3      _____ to _____ tons/year	
6. Emission Factor: <b>0.018 lb/MMBtu</b> Reference: <b>AP-42</b>	7. Emissions Method Code:
8. Calculation of Emissions (limit to 600 characters):  <b>0.018 lb/MMBtu x 760 MMBtu/hr = 13.68 lb/hr</b> <b>Annual average = 0.0036 lb/MMBtu x 760 MMBtu/hr x 8,760 hr/yr ÷ 2,000 lb/ton = 11.98 TPY</b>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>	

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: <b>0.018 lb/MMBtu</b>	4. Equivalent Allowable Emissions: <b>13.7 lb/hour</b> <b>12.0 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>EPA Method 8, once every 5 years.</b>	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>Fl - Fluorides</b>	2. Total Percent Efficiency of Control:	
3. Potential Emissions: <b>0.53</b> lb/hour	<b>2.33</b> tons/year	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year		
6. Emission Factor: <b><math>7 \times 10^{-4}</math> lb/MMBtu</b> Reference: <b>Stack Test Data</b>		7. Emissions Method Code: <b>0</b>
8. Calculation of Emissions (limit to 600 characters):  <b><math>7 \times 10^{-4}</math> lb/MMBtu x 760 MMBtu/hr = 0.53 lb/hr</b>		
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>		

**Allowable Emissions** Allowable Emissions \_\_\_\_\_ of \_\_\_\_\_

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units:	lb/hour	tons/year
4. Equivalent Allowable Emissions:		
5. Method of Compliance (limit to 60 characters):		
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):		

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION**  
**(Regulated Emissions Units -**  
**Emissions-Limited and Preconstruction Review Pollutants Only)**

**Potential/Fugitive Emissions**

1. Pollutant Emitted: <b>H114 - Mercury</b>	2. Total Percent Efficiency of Control:		
3. Potential Emissions: <b>0.0041 lb/hour</b>		<b>0.018 tons/year</b>	4. Synthetically Limited? [ ]
5. Range of Estimated Fugitive Emissions: [ ] 1 [ ] 2 [ ] 3 _____ to _____ tons/year			
6. Emission Factor: <b><math>5.4 \times 10^{-6}</math> lb/MMBtu</b> Reference: <b>Permit limit</b>		7. Emissions Method Code: <b>0</b>	
8. Calculation of Emissions (limit to 600 characters):  <b><math>5.4 \times 10^{-6}</math> lb/MMBtu x 760 MMBtu/hr = 0.0041 lb/hr</b>			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):  <b>Based on biomass firing.</b>			

**Allowable Emissions** Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: <b>OTHER</b>	2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: <b><math>5.4 \times 10^{-6}</math> lb/MMBtu</b>		<b>0.0041 lb/hour</b>	<b>0.018 tons/year</b>
5. Method of Compliance (limit to 60 characters):  <b>Stack test using EPA Method 29, once every 5 years.</b>			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):  <b>Based on biomass firing.</b>			

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation 1 of 1

1. Visible Emissions Subtype: <b>VE20</b>	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Requested Allowable Opacity: Normal Conditions: <b>20</b> %      Exceptional Conditions: <b>27</b> % Maximum Period of Excess Opacity Allowed:      min/hour	
4. Method of Compliance: <b>EPA Method 9</b>	
5. Visible Emissions Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 1 of 5

1. Parameter Code: <b>VE</b>	2. Pollutant(s):
3. CMS Requirement:	<input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
4. Monitor Information: Manufacturer: <b>Durag</b> Model Number: <b>D-R281-31-AV</b> Serial Number: <b>31019</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 2 of 5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>NO<sub>x</sub></b>
3. CMS Requirement:	[ <input checked="" type="checkbox"/> ] Rule [ ] Other
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>42D</b> Serial Number: <b>42D-52618-292</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	



**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 3 of 5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>SO<sub>2</sub></b>
3. CMS Requirement: [ ] Rule [ <b>X</b> ] Other	
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>43B</b> Serial Number: <b>43B-51400-292</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**H. VISIBLE EMISSIONS INFORMATION**  
 (Only Regulated Emissions Units Subject to a VE Limitation)

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
 (Only Regulated Emissions Units Subject to Continuous Monitoring)

**Continuous Monitoring System:** Continuous Monitor 4 of 5

1. Parameter Code: <b>EM</b>	2. Pollutant(s): <b>CO</b>
3. CMS Requirement:	[ ] Rule [ <b>X</b> ] Other
4. Monitor Information: Manufacturer: <b>Thermo Environmental Instruments</b> Model Number: <b>48</b> Serial Number: <b>48-45334-273</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):	

**H. VISIBLE EMISSIONS INFORMATION**  
**(Only Regulated Emissions Units Subject to a VE Limitation)**

**Visible Emissions Limitation:** Visible Emissions Limitation \_\_\_\_\_ of \_\_\_\_\_

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [ ] Rule [ ] Other
3. Requested Allowable Opacity: Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

**I. CONTINUOUS MONITOR INFORMATION**  
**(Only Regulated Emissions Units Subject to Continuous Monitoring)**

**Continuous Monitoring System:** Continuous Monitor 5 of 5

1. Parameter Code:	2. Pollutant(s): O <sub>2</sub>
3. CMS Requirement:	[ X ] Rule [ ] Other
4. Monitor Information: Manufacturer: <b>Yokogawa</b> Model Number: <b>ZA8C</b> Serial Number: <b>JJ113MA345</b>	
5. Installation Date: <b>01 OCT 1995</b>	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):  <b>40 CFR 60, Subpart Da.</b>	

**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION  
(Regulated Emissions Units Only)**

**Supplemental Requirements**

1. Process Flow Diagram <input checked="" type="checkbox"/> Attached, Document ID: <u>NH-FI-C3</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Fuel Analysis or Specification <input checked="" type="checkbox"/> Attached, Document ID: <u>NH-EU2-J2</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Detailed Description of Control Equipment <input checked="" type="checkbox"/> Attached, Document ID: <u>NH-EU2-J3</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Description of Stack Sampling Facilities <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
5. Compliance Test Report <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously submitted, Date: _____ <input checked="" type="checkbox"/> Not Applicable
6. Procedures for Startup and Shutdown <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
7. Operation and Maintenance Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
8. Supplemental Information for Construction Permit Application <input checked="" type="checkbox"/> Attached, Document ID: <u>PSD Report</u> <input type="checkbox"/> Not Applicable
9. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
10. Supplemental Requirements Comment:

**Additional Supplemental Requirements for Title V Air Operation Permit Applications**

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

**ATTACHMENT NH-EU4-C**

**LIST OF APPLICABLE REGULATIONS**

## EU ID 032 : Cogen Boiler C Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	60 Subpart A	40CFR60.1	Subpart A -- General Provisions	
APPLICABLE	60 Subpart A	40CFR60.7	Notification and Record Keeping	
APPLICABLE	60 Subpart A	40CFR60.8	Performance Testing	
APPLICABLE	60 Subpart A	40CFR60.11	Compliance with standards and maintenance requirements	
APPLICABLE	60 Subpart A	40CFR60.12	Circumvention.	
APPLICABLE	60 Subpart A	40CFR60.13	Monitoring requirements.	
APPLICABLE	60 Subpart A	40CFR60.19	General notification and reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.40a	Subpart Da - NSPS for Electric Utility Units for which construction commenced after Sept. 18, 1978.	
APPLICABLE	60 Subpart Da	40CFR60.42a	Standard for particulate matter	
APPLICABLE	60 Subpart Da	40CFR60.43a	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(a)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(b)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(d)(2)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(g)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.43a(h)	Standard for sulfur dioxide.	
APPLICABLE	60 Subpart Da	40CFR60.44a	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.44a(a)	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.44a(c)	Standard for nitrogen oxides	
APPLICABLE	60 Subpart Da	40CFR60.46a	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(a)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(b)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(c)	Compliance provisions.	
NON-APPLICABLE	60 Subpart Da	40CFR60.46a(d)	Compliance provisions.	Cogen Boiler C does not have a flue gas desulfurization system.
APPLICABLE	60 Subpart Da	40CFR60.46a(e)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(f)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(g)	Compliance provisions.	
APPLICABLE	60 Subpart Da	40CFR60.46a(h)	Compliance provisions.	
NON-APPLICABLE	60 Subpart Da	40CFR60.46a(i)	Compliance provisions.	Cogen Boiler C has not been modified after July 7, 1997.
APPLICABLE	60 Subpart Da	40CFR60.47a	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(a)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(b)(2)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(b)(3)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(c)(1)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(d)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(e)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(f)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(g)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(h)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(i)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.47a(j)	Emission monitoring	
APPLICABLE	60 Subpart Da	40CFR60.48a	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(a)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(b)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(c)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(d)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.48a(e)	Compliance determination procedures and methods.	
APPLICABLE	60 Subpart Da	40CFR60.49a	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(a)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(b)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(c)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(d)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(f)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(g)	Reporting requirements	

## EU ID 032 : Cogen Boiler C Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	60 Subpart Da	40CFR60.49a(h)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(i)	Reporting requirements	
APPLICABLE	60 Subpart Da	40CFR60.49a(j)	Reporting requirements	
APPLICABLE	60 Subpart Ea	40CFR60.50a(d)	Standards of performance for municipal waste combustors	
APPLICABLE	60 Subpart Ea	40CFR60.50b(j)	Standards of performance for municipal waste combustors	
APPLICABLE	62-204	62-204.800(7)2.	NSPS Subpart Da adopted by reference.	
APPLICABLE	62-296 <	62-296	STATIONARY SOURCES - EMISSION STANDARDS	
APPLICABLE	62-296 <	62-296.405(2)	Fossil Fuel Steam Generators with more than 250 million Btu per Hour Heat Input.	
NON-APPLICABLE	62-296 <	62-296.406	Fossil Fuel Steam Generators with less than 250 Million Btu per Hour Heat Input, New and Existing Em	Cogen Boiler C has a heat input of >250 MMBtu/hr.
NON-APPLICABLE	62-296 <	62-296.410	Carbonaceous Fuel Burning Equipment.	Not more stringent or different than NSPS.
APPLICABLE	62-296 >	62-296.500	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.500(2)(a)	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.500(2)(c)	Reasonably Available Control Technology (RACT) - Volatile Organic Compounds (VOC) and Nitrogen Oxide	
APPLICABLE	62-296 >	62-296.570	Reasonably Available Control Technology (RACT) - Requirements for Major VOC- and NOx-Emitting Facility	
APPLICABLE	62-296 >	62-296.570(1)	Applicability.	
APPLICABLE	62-296 >	62-296.570(1)(a)	Applicability.	
APPLICABLE	62-296 >	62-296.570(2)	Compliance Requirements.	
APPLICABLE	62-296 >	62-296.570(3)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(a)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(b)6.	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.570(4)(c)	Operation Permit Requirements.	
APPLICABLE	62-296 >	62-296.620		
NON-APPLICABLE	62-296 >	62-296.700	Reasonably Available Control Technology (RACT) Particulate Matter.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
NON-APPLICABLE	62-296 >	62-296.702	Fossil Fuel Steam Generators.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
NON-APPLICABLE	62-296 >	62-296.703	Carbonaceous Fuel Burners.	New Hope Power Partnership is located in Palm Beach County, which is not a nonattainment or maintenance area for particulate matter.
APPLICABLE	62-297	62-297	STATIONARY SOURCES - EMISSIONS MONITORING	
APPLICABLE	62-297	62-297.310	General Compliance Test Requirements.	
APPLICABLE	62-297	62-297.401	Compliance Test Methods.	
APPLICABLE	62-297	62-297.401(1)(a)	EPA Method 1 - Sample and Velocity Traverses for Stationary sources - 40 CFR 60 Appendix A.	
APPLICABLE	62-297	62-297.401(10)	EPA Method 10 - Determination of Carbon Monoxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(12)	EPA Method 12 - Determination of Inorganic Lead Emissions from Stationary Sources - 40 CFR 60 Append	
APPLICABLE	62-297	62-297.401(13)	EPA Methods 13A and 13B.	
APPLICABLE	62-297	62-297.401(18)	EPA Method 18 - Measurement of Gaseous Organic Compound Emissions by Gas Chromatography - 40 CFR 60	
APPLICABLE	62-297	62-297.401(19)	EPA Method 19 - Determination of Sulfur Dioxide Removal Efficiency and Particulate, Sulfur Dioxide a	
APPLICABLE	62-297	62-297.401(2)	EPA Method 2 - Determination of Stack Gas Velocity and Volumetric Flow Rate - 40 CFR 60 Appendix A.	



## EU ID 032 : Cogen Boiler C Rule Applicability for New Hope Power Partnership

APPLIC STAT	RULE DESCRIP	RULE NUMBER	RULE TITLE	RATIONALE FOR NON-APPLICABILITY
APPLICABLE	62-297	62-297.401(25)	EPA Method 25 - Determination of Total Gaseous Nonmethane Organic Emissions as Carbon - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(3)	EPA Method 3 - Gas Analysis for Carbon Dioxide, Oxygen, Excess Air, and Dry Molecular Weight - 40 CF	
APPLICABLE	62-297	62-297.401(32)	EPA Method 101 - Determination of Particulate and Gaseous Mercury Emissions from Chlor-Alkali Plants	
APPLICABLE	62-297	62-297.401(35)	EPA Method 104 - Determination of Beryllium Emissions from Stationary Sources - 40 CFR 61 Appendix B	
APPLICABLE	62-297	62-297.401(39)	EPA Method 108 - Determination of Particulate and Gaseous Arsenic Emissions - 40 CFR 61 Appendix B	
APPLICABLE	62-297	62-297.401(4)	EPA Method 4 - Determination of Moisture Content in Stack Gases - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(41)	EPA Method 201 - Determination of PM10 Emissions (Exhaust Gas Recycle Procedure) - 40 CFR 51 Appendix	
APPLICABLE	62-297	62-297.401(5)	EPA Method 5 - Determination of Particulate Emissions from Stationary Sources - 40 CFR 60 Appendix A	
APPLICABLE	62-297	62-297.401(6)	EPA Method 6 - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(6)(c)	EPA Method 6C - Determination of Sulfur Dioxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(7)	EPA Method 7 - Determination of Nitrogen Oxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(7)(c)	EPA Method 7E - Determination of Nitrogen Oxide Emissions from Stationary Sources - 40 CFR 60 Appendix	
APPLICABLE	62-297	62-297.401(8)	EPA Method 8 - Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sour	
APPLICABLE	62-297	62-297.401(9)	EPA Test Method 9	

**PSD REPORT**

## TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION .....	1-1
2.0 PROJECT DESCRIPTION.....	2-1
2.1 GENERAL.....	2-1
2.2 FACILITY DESCRIPTION.....	2-1
2.3 POLLUTION CONTROL EQUIPMENT AND AIR EMISSIONS .....	2-2
2.4 STACK DATA .....	2-3
3.0 AIR QUALITY REVIEW REQUIREMENTS.....	3-1
3.1 NATIONAL AND STATE AMBIENT AIR QUALITY STANDARDS (AAQs).....	3-1
3.2 PSD REQUIREMENTS .....	3-1
3.2.1 GENERAL REQUIREMENTS .....	3-1
3.2.2 CONTROL TECHNOLOGY REVIEW.....	3-2
3.2.3 SOURCE IMPACT ANALYSIS .....	3-4
3.2.4 AIR QUALITY MONITORING REQUIREMENTS.....	3-6
3.2.5 SOURCE INFORMATION/GEP STACK HEIGHT .....	3-7
3.2.6 ADDITIONAL IMPACT ANALYSIS .....	3-8
3.3 NONATTAINMENT RULES .....	3-8
3.4 EMISSION STANDARDS.....	3-8
3.4.1 NEW SOURCE PERFORMANCE STANDARDS .....	3-8
3.4.2 FLORIDA RULES.....	3-9
3.5 SOURCE APPLICABILITY .....	3-9
3.5.1 AREA CLASSIFICATION .....	3-9
3.5.2 PSD REVIEW.....	3-9
3.5.3 EMISSION STANDARDS.....	3-11
4.0 AMBIENT MONITORING ANALYSIS .....	4-1
4.1 MONITORING REQUIREMENTS .....	4-1
4.2 OZONE AMBIENT MONITORING ANALYSIS.....	4-2
4.3 SO <sub>2</sub> AMBIENT BACKGROUND CONCENTRATIONS.....	4-2
4.4 EVERGLADES NATIONAL PARK CLASS I AREA.....	4-3
5.0 BEST AVAILABLE CONTROL TECHNOLOGY ANALYSIS .....	5-1
5.1 REQUIREMENTS.....	5-1

## TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
5.2	PARTICULATE MATTER (PM/PM <sub>10</sub> )..... 5-1
5.2.1	EXISTING AND PROPOSED CONTROL TECHNOLOGY ..... 5-1
5.2.2	BACT ANALYSIS ..... 5-2
5.2.3	SUMMARY..... 5-3
5.3	SULFUR DIOXIDE..... 5-4
5.3.1	EXISTING AND PROPOSED CONTROL TECHNOLOGY ..... 5-4
5.3.2	BACT ANALYSIS ..... 5-5
5.3.3	SUMMARY..... 5-7
5.4	NITROGEN OXIDES ..... 5-8
5.4.1	EXISTING AND PROPOSED CONTROL TECHNOLOGY ..... 5-8
5.4.2	BACT ANALYSIS ..... 5-9
5.4.3	SUMMARY..... 5-14
5.5	CARBON MONOXIDE AND VOLATILE ORGANIC COMPOUNDS..... 5-15
5.5.1	EXISTING AND PROPOSED CONTROL TECHNOLOGY ..... 5-15
5.5.2	BACT ANALYSIS ..... 5-15
5.6	FLUORIDES..... 5-17
5.6.1	EXISTING AND PROPOSED CONTROL TECHNOLOGY ..... 5-17
5.6.2	BACT ANALYSIS ..... 5-17
5.6.3	SUMMARY..... 5-18
5.7	SULFURIC ACID MIST ..... 5-19
5.7.1	EXISTING AND PROPOSED CONTROL TECHNOLOGY ..... 5-19
5.7.2	BACT ANALYSIS ..... 5-19
5.8	LEAD..... 5-19
5.8.1	PROPOSED CONTROL TECHNOLOGY ..... 5-19
5.8.2	BACT ANALYSIS ..... 5-20
6.0	AIR QUALITY IMPACT ANALYSIS ..... 6-1
6.1	GENERAL APPROACH..... 6-1
6.2	SIGNIFICANT IMPACT ANALYSIS..... 6-3
6.3	AAQS AND PSD CLASS II ANALYSES ..... 6-3
6.4	PSD CLASS I ANALYSIS..... 6-4
6.5	MODEL SELECTION..... 6-4

## TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
6.6 METEOROLOGICAL DATA.....	6-5
6.7 EMISSION INVENTORY .....	6-5
6.7.1 SIGNIFICANT IMPACT ANALYSIS.....	6-5
6.7.2 AAQS AND PSD CLASS II ANALYSES.....	6-6
6.7.3 PSD CLASS I ANALYSIS.....	6-6
6.8 RECEPTOR LOCATIONS .....	6-7
6.8.1 SITE VICINITY .....	6-7
6.8.2 CLASS I AREA.....	6-7
6.9 BACKGROUND CONCENTRATIONS .....	6-8
6.10 BUILDING DOWNWASH EFFECTS .....	6-8
6.11 MODEL RESULTS.....	6-8
6.11.1 SIGNIFICANT IMPACT ANALYSIS.....	6-8
6.11.2 AAQS ANALYSIS.....	6-8
6.11.3 PSD CLASS II ANALYSIS .....	6-9
6.11.4 PSD CLASS I ANALYSIS.....	6-9
6.11.5 FLUORIDE IMPACTS .....	6-10
6.11.6 SAM IMPACTS .....	6-10
6.11.7 LEAD IMPACTS .....	6-10
7.0 ADDITIONAL IMPACT ANALYSIS .....	7-1
7.1 VICINITY OF NHPP.....	7-1
7.1.1 VEGETATION AND SOILS .....	7-1
7.1.2 VISIBILITY.....	7-1
7.1.3 IMPACTS DUE TO ASSOCIATED GROWTH.....	7-1
7.2 PSD CLASS I AREA.....	7-2
7.2.1 IMPACTS TO SOILS.....	7-3
7.2.2 IMPACTS TO VEGETATION .....	7-4
7.2.3 IMPACTS TO WILDLIFE .....	7-9
7.2.4 IMPACTS ON VISIBILITY.....	7-10
7.2.5 SULFUR AND NITROGEN DEPOSITION.....	7-13
REFERENCES .....	REF-1

## TABLE OF CONTENTS

### LIST OF TABLES

2-1	Maximum Fuel Usage and Heat Input Rates per Boiler.....	2-4
2-2	Maximum Short-Term Emissions for New Hope Power Partnership Cogeneration Facility (per boiler).....	2-5
2-3	Maximum Annual Emissions Per Boiler at New Hope Power Partnership Cogeneration Facility.....	2-6
2-4	New Hope Power Partnership Facility Maximum Annual Fugitive Dust Emissions.....	2-7
2-5	Stack Parameters for Each Boiler, New Hope Power Partnership. ....	2-8
3-1	National and State AAQS, Allowable PSD Increments, and Significant Impact Levels ( $\mu\text{g}/\text{m}^3$ ).....	3-12
3-2	PSD Significant Emission Rates and <i>De Minimis</i> Monitoring Concentrations.....	3-13
3-3	PSD Source Applicability Analysis, New Hope Power Partnership. ....	3-14
3-4	Increase in Impacts Due to Proposed Modification Compared to Class II Significant Impact Levels and Ambient Monitoring <i>De Minimis</i> Levels .....	3-15
4-1	Summary of Continuous Ozone Ambient Monitoring Data Collected Near South Bay .....	4-4
4-2	Summary of Continuous Sulfur Dioxide Ambient Monitoring Data Collected Near South Bay.....	4-5
4-3	Summary of Sulfur Dioxide, $\text{PM}_{10}$ , and $\text{NO}_2$ Monitoring Data, Everglades National Park .....	4-6
5-1	Cost Effectiveness of Lime Spray Drying FGD for $\text{SO}_2$ Control, NHPP Cogeneration Boiler (one Unit), Vendor: Wheelabrator APC.....	5-21
5-2	Cost Effectiveness of Lime Spray Drying FGD for $\text{SO}_2$ Control, NHPP Cogeneration Boiler (one Unit), Vendor: Hamon Research-Cottrell.....	5-22
5-3	Cost Effectiveness of SCR, NHPP Cogeneration Boilers .....	5-23
5-4	Cost Effectiveness of Using Increased Urea Injection in Osceola Power's Cogeneration Boilers .....	5-24
6-1	Major Features of the ISCST3 Model .....	6-11
6-2	Major Features of the CALPUFF model, Version 5.5 .....	6-12
6-3	Stack Parameters for New Hope Power Partnership Boilers.....	6-13
6-4	Cogeneration Boiler Emission Rates for New Hope Power Partnership: Total all Three Boilers .....	6-14
6-5	Fugitive Dust Emissions and Area Source Modeling Parameters for Biomass and Ash Handling System, New Hope Power Partnership.....	6-15
6-6	Summary of $\text{SO}_2$ Facilities Considered for Inclusion in the AAQS and PSD Class II Air Modeling Analyses.....	6-16
6-7	Summary of $\text{SO}_2$ Facilities Included in the PSD Class I Air Modeling Analysis .....	6-17

## TABLE OF CONTENTS

### LIST OF TABLES - continued

6-8	New Hope Power Partnership Property Boundary Receptors Used in the Modeling Analysis .....	6-18
6-9	Everglades National Park Receptors Used in the PSD Class I Modeling Analysis .....	6-21
6-10	New Hope Power Partnership Building Dimensions Used in the Modeling Analysis.....	6-22
6-11	Maximum Predicted Pollutant Impacts For the Proposed Project Only, New Hope Power Partnership.....	6-23
6-12	Maximum Predicted SO <sub>2</sub> Impacts for all Sources, AAQS Screening Analysis, New Hope Power Partnership.....	6-25
6-13	Maximum Predicted SO <sub>2</sub> Concentrations for all Sources Compared to the AAQS – Refined Analysis, New Hope Power Partnership.....	6-26
6-14	Maximum Predicted SO <sub>2</sub> Impacts for all Sources, PSD Class II Screening Analysis, New Hope Power Partnership.....	6-27
6-15	Maximum Predicted SO <sub>2</sub> Concentrations for all Sources Compared to the PSD Class II Increment Refined Analysis, New Hope Power Partnership.....	6-28
6-16	Summary of Maximum Pollutant Concentrations Predicted for the Project Only Compared to the EPA Class I Significant Impact Levels and PSD Class I Increments .....	6-29
6-17	Maximum Predicted SO <sub>2</sub> Concentrations for PSD Sources at the Everglades National Park .....	6-30
6-18	Maximum Predicted Fluoride Impacts for the Proposed Project Only in the Site Vicinity, New Hope Power Partnership.....	6-31
6-19	Maximum Predicted Sulfuric Acid Mist Impacts for the Proposed Project Only in the Site Vicinity, New Hope Power Partnership .....	6-32
6-20	Maximum Predicted Lead Impacts for the Proposed Project Only in the Site Vicinity, New Hope Power Partnership.....	6-33
7-1	Maximum Predicted Concentrations Due to the Project Only at the Class I Area of the Everglades National Park.....	7-15
7-2	SO <sub>2</sub> Effects Levels for Various Plant Species .....	7-16
7-3	Sensitivity Groupings of Vegetation Based on Visible Injury at Different SO <sub>2</sub> Exposures.....	7-17
7-4	Fluoride Effect Levels for Various Plant Species .....	7-18
7-5	Examples of Reported Effects of Air Pollutants on Animals at Concentrations Below National Secondary Ambient Air Quality Standards.....	7-19
7-6	Maximum Sulfur and Nitrogen Annual Deposition Predicted at the PSD Class I Area of the Everglades National Park, New Hope Power Partnership.....	7-20

**TABLE OF CONTENTS**

**LIST OF FIGURES**

6-1 New Hope Power Partnership; Building, Stack, Property Boundary, and Receptor Locations..... 6-34

6-2 New Hope Power Partnership; Building, Area Source, and Stack Locations ..... 6-35



**TABLE OF CONTENTS****LIST OF APPENDICES**

APPENDIX A	BASIS OF ACTUAL EMISSIONS
APPENDIX B	BASIS OF FUGITIVE EMISSIONS
APPENDIX C	SUMMARY OF NHPP STACK TESTS
APPENDIX D	SUMMARY OF PREVIOUS BACT DETERMINATIONS
APPENDIX E	SUMMARY OF CORRESPONDENCE AND SCR AND FGD VENDOR QUOTES & VENDOR CORRESPONDENCES
APPENDIX F	CO EMISSIONS DURING COLD STARTUP CONDITIONS
APPENDIX G	CALPUFF MODEL DESCRIPTION AND METHODOLOGY
APPENDIX H	SO2 AAQS, PSD CLASS I AND II INVENTORY

## 1.0 INTRODUCTION

New Hope Power Partnership (NHPP) (formerly Okeelanta Power L.P.) operates a 74.9 net megawatt electric (MWe) cogeneration facility located adjacent to the Okeelanta Corporation sugar mill, approximately 6 miles south of South Bay in Palm Beach County, Florida. The facility combusts primarily biomass (bagasse and wood) in three identical steam boilers to generate steam and electricity. The cogeneration facility supplies the adjacent sugar mill with process steam during the sugar cane grinding season, approximately October through March. The facility also supplies the Okeelanta sugar refinery with process steam year around.

NHPP is proposing to remove the current facility cap on heat input of  $11.5 \times 10^{12}$  British thermal units per year (Btu/yr) for the three cogeneration boilers combined. Due to increased reliability, the NHPP facility operated at a heat input rate of  $11.38 \times 10^{12}$  Btu/yr during 2000, and the current heat input cap could unnecessarily limit the facility operations in the future. The removal of this heat input cap will allow each of the three boilers to simultaneously operate at maximum steam rate for up to 8,760 hours per year (hr/yr), and provide the facility with additional flexibility in operations. The new total annual heat input for the facility will be  $19.97 \times 10^{12}$  Btu/yr. NHPP is also requesting an increase in the short-term heat input rate from 715 million British thermal units (MMBtu/hr) to 760 MMBtu/hr. No physical modifications or other changes to the facility are needed to accomplish the requested change.

Based on the potential increase in emissions of particulate matter (PM), particulate matter with aerodynamic diameter less than or equal to 10 micrometers ( $PM_{10}$ ), sulfur dioxide ( $SO_2$ ), nitrogen oxides ( $NO_x$ ), carbon monoxide (CO), volatile organic compounds (VOC), lead (Pb), fluorides, and sulfuric acid mist (SAM) due to the proposed heat input rate increase, the proposed project will constitute a major modification to a major source, and thus trigger new source review (NSR) under the provisions of the prevention of significant deterioration (PSD) regulations for these pollutants.

For each pollutant subject to PSD review, the following analyses are required:

1. Ambient monitoring analysis, unless the net increase in emissions due to the modification causes impacts that are below specified significant impact levels;
2. Application of best available control technology (BACT) for each new or modified emissions unit;

3. Air quality impact analysis, unless the net increase in emissions due to the modification causes impacts which are below specified significant impact levels; and
4. Additional impact analysis (impact on soils, vegetation, and visibility), including impacts on PSD Class I areas.

This PSD permit application addresses these requirements and is organized into six additional sections, followed by the appendices. A description of the project including air emission sources and pollution control equipment is presented in Section 2.0. The regulatory applicability analysis of the proposed project is presented in Section 3.0. The ambient air monitoring analysis is presented in Section 4.0, and the BACT analysis is presented in Section 5.0. The air quality impact analysis and additional impact analysis are presented in Sections 6.0 and 7.0, respectively. Supporting documentation is presented in the appendices.

## 2.0 PROJECT DESCRIPTION

### 2.1 GENERAL

NHPP operates a 74.9 net MWe cogeneration facility located adjacent to the Okeelanta Corporation sugar mill, approximately 6 miles south of South Bay in Palm Beach County, Florida. The facility is currently operating under Final Title V Permit No. 0990005-003-AV, issued January 19, 2001. The original construction permit for the facility was issued to Okeelanta Power L.P. on September 27, 1993 (Permit No. AC50-219413/PSD-FL-196). The original construction permit has been modified several times. The latest amendment was Permit No. 0990332-014-AC/PSD-FL-196M, issued February 1, 2002. This permit modified the CO and SO<sub>2</sub> emission limits for the cogeneration boilers.

Construction was completed on the NHPP facility in 1995, and initial operations began in late 1995. However, the facility was operated at less than design capacity during 1996-1998. Debugging continued during the 1998-1999 crop and the facility began operating as designed in early 1999. Calendar year 2000 operation was normal although the boilers experienced downtime due to installation of mechanical dust collectors. Calendar year 2001 operations were impacted by the loss of the turbogenerator, which required several months to repair.

A regional map showing the location of the site is presented in Attachment NH-FI-C1 of the application form. A plot plan of the NHPP cogeneration facility is presented in Attachment NH-FI-C2 of the application form.

### 2.2 FACILITY DESCRIPTION

The facility combusts biomass (bagasse and wood), No. 2 fuel oil, and natural gas in three steam boilers to generate steam and electricity. Each boiler is currently permitted to produce an average of 455,418 lb/hr of steam. The cogeneration facility supplies the adjacent Okeelanta sugar mill with process steam during the sugar cane grinding season, approximately October through March, and also supplies the associated Okeelanta sugar refinery with process steam year around. The fuel burned in the facility boilers to date has been primarily bagasse and wood. Only a relatively small amount of No. 2 fuel oil or natural gas has been combusted to date, since these fuels are used primarily as a backup fuels.

The Title V operating permit limits the maximum heat input to each of the three boilers to 715 MMBtu/hr when firing 100-percent biomass, and 490 MMBtu/hr when firing 100-percent fossil fuels (No. 2 fuel oil). Permit No. 0990332-013-AC limits the maximum heat input to each of the three boilers to 605 MMBtu/hr when firing natural gas.

NHPP is requesting to increase the maximum heat input rate to each of the three boilers to 760 MMBtu/hr when firing 100-percent biomass. In addition, the average steam rate will increase to 506,100 lb/hr of steam. No physical changes to the boilers will be required to implement these capacity increases. The maximum annual heat input to the entire facility is currently limited to  $11.5 \times 10^{12}$  Btu/yr. NHPP is requesting to remove this facility cap to allow the three cogeneration boilers to simultaneously operate up to the maximum steam rate for 8,760 hr/yr. This would increase the total facility annual heat input to  $19.97 \times 10^{12}$  Btu/yr. Due to increased reliability, the NHPP facility operated at a heat input rate of  $11.38 \times 10^{12}$  Btu/yr during 2000, and the current heat input cap may unnecessarily limit the facility's operations in the near future.

### **2.3 POLLUTION CONTROL EQUIPMENT AND AIR EMISSIONS**

Air pollution control equipment serving each boiler consists of mechanical dust collectors and an electrostatic precipitator (ESP) to control PM and heavy metal emissions, a selective non-catalytic reduction (SNCR) system for the control of  $\text{NO}_x$  emissions, and a carbon injection system for mercury (Hg) control. There will be no changes to this equipment as part of this project, although FDEP recently approved a request to eliminate the requirement to operate the carbon injection system. Historic data has shown that the carbon injection system has no effect on the Hg emissions from the boilers. The carbon injection system will be retained in the event that elevated Hg emissions are experienced in the future.

NHPP is requesting an increase in the hourly and annual emission rates for  $\text{SO}_2$ , PM,  $\text{PM}_{10}$ ,  $\text{NO}_x$ , CO, VOC, Hg, and Pb due to the proposed heat input increase. No change in the current lb/MMBtu emission limits is being requested.

The maximum fuel usage and heat input rates for each cogeneration boiler, including maximum short-term and annual averages for biomass, No. 2 fuel oil, and natural gas, are summarized in Table 2-1. No. 2 fuel oil and natural gas firing will be limited to less than 25 percent on a calendar quarter heat input basis.

The maximum short-term emissions for each cogeneration boiler for biomass, No. 2 fuel oil, and natural gas are presented in Table 2-2. The maximum short-term emissions for each fuel burned alone are shown.

The maximum annual emissions for each boiler for three fuel combinations, including 100 percent biomass, 75.1 percent biomass/24.9 percent No. 2 fuel oil, and 75.1 percent biomass/24.9 percent natural gas, are presented in Table 2-3. The maximum annual emissions for any fuel scenario are indicated by the footnote. As shown, the maximum annual emissions for each pollutant are due to biomass firing.

The emission factors used in Tables 2-2 and 2-3 are consistent with the permit limits and emission factors contained in Permit No. 0990332-014-AC/PSD-FL-196M.

Since the proposed project will result in increased potential annual biomass usage, the potential annual fugitive emissions from the biomass and ash handling systems will also increase. The maximum annual fugitive emissions based on the increased maximum biomass usage are shown in Table 2-4. The maximum amount of biomass burned in the boilers consists of 1,063,162 TPY of wood and 1,444,659 TPY bagasse. However, an additional 50 percent processed through the material handling system was added to account for year-to-year variability in biomass fuel deliveries.

#### **2.4 STACK DATA**

Stack geometry and operating data are presented in Table 2-5. The parameters reflect actual operating data based on compliance testing. Each of the three boilers are served by a separate stack. The top of each stack is 199 feet (ft) above ground. Each stack is 10.0 ft in diameter. The locations of the three stacks are shown in Attachment NH-FI-C2.

Table 2-1. Maximum Fuel Usage and Heat Input Rates per Boiler, New Hope Power Partnership

Fuel	Heat Input	Heat		Fuel Firing Rate
		Transfer Efficiency (%)	Output	
<u>Maximum Short-Term (per boiler)</u>				
	(MMBtu/hr)		(MMBtu/hr)	
Biomass - Bagasse	760	68	517	211,111 lb/hr <sup>a</sup>
- Wood	760	68	517	168,889 lb/hr <sup>b</sup>
No. 2 Fuel Oil	490	85	417	3,551 gal/hr
Natural Gas	605	85	514	605,000 scf/hr
<u>Annual Average (per boiler)</u>				
	(Btu/yr)		(Btu/yr)	
<u>NORMAL OPERATIONS (100% BIOMASS)</u>				
Biomass	6.658E+12	68	4.527E+12	924,667 TPY <sup>a</sup>
No. 2 Fuel Oil	0	85	0	0 gal/yr
Natural Gas	0	85	0	0 MMscf/yr
TOTAL	6.658E+12		4.527E+12	
<u>24.9% OIL FIRING</u>				
Biomass	4.707E+12	68	3.201E+12	653,750 TPY <sup>a</sup>
No. 2 Fuel Oil	1.561E+12	85	1.327E+12	11,309,008 gal/yr
Natural Gas	0	85	0	0 MMscf/yr
TOTAL	6.268E+12		4.527E+12	
<u>24.9% NATURAL GAS FIRING</u>				
Biomass	4.707E+12	68	3.201E+12	653,750 TPY <sup>a</sup>
No. 2 Fuel Oil	0	85	0	0 gal/yr
Natural Gas	1.561E+12	85	1.327E+12	1,561 MMscf/yr
TOTAL	6.268E+12		4.527E+12	

<sup>a</sup> Based on bagasse firing.<sup>b</sup> Based on wood firing.

Notes:

40 CFR 60, Subpart Da, limits fossil-fuel firing to less than 25% for each boiler (heat input basis).

Total heat output required = 4.527E+12 Btu/yr per boiler.

Fuels may be burned in combination, not to exceed total heat outputs.

Based on fuel heating values as follows:

Bagasse - 3,600 Btu/lb

Wood - 4,500 Btu/lb

No. 2 Fuel Oil - 138,000 Btu/gal

Natural gas - 1,000 Btu/scf

Table 2-2. Maximum Short-Term Emissions for New Hope Power Partnership Cogeneration Facility (per boiler)

Regulated Pollutant	Biomass			No. 2 Fuel Oil			Natural Gas			Maximum Emissions for any fuel (lb/hr)	Total All Three Boilers (lb/hr)
	Emission Factor (lb/MMBtu)	Activity Factor (MMBtu/hr)	Maximum Emissions (lb/hr)	Emission Factor (lb/MMBtu)	Activity Factor (MMBtu/hr)	Maximum Emissions (lb/hr)	Emission Factor (lb/MMBtu)	Activity Factor (MMBtu/hr)	Maximum Emissions (lb/hr)		
Particulate (PM)	0.03 (1)	760	22.8	0.03 (1)	490	14.70	0.0073 (2)	605	4.42	22.80	68.40
Particulate (PM <sub>10</sub> )	0.03 (1)	760	22.8	0.03 (1)	490	14.70	0.0073 (2)	605	4.42	22.80	68.40
Sulfur Dioxide--3-hr Average	0.30 (5)	760	228.0	--	--	--	--	--	--	228.0	684.0
--24-hr Average	0.20 (2)	760	152.0	0.05 (6)	490	24.50	0.0058 (2)	605	3.51	152.0	456.0
Carbon Monoxide--1-hr Average (cold-startup)	6.5 (5)	225 <sup>a</sup>	1,462.5	1.0 (2)	490	490.0	0.08 (2)	605	48.4	1,462.5	4,387.5
--1-hr Average (normal operation)	1.0 (5)	760	760.0	--	--	--	--	--	--	760.0	2,280.0
--8-hr Average (cold startup)	4.5 (5)	225 <sup>a</sup>	1,012.5	--	--	--	--	--	--	1,012.5	3,037.5
--8-hr Average (normal operation)	1.0 (5)	760	760.0	--	--	--	--	--	--	760.0	2,280.0
Nitrogen Oxides	0.20 (5)	760	152.00	0.20 (5)	490	98.00	0.20 (5)	605	121	152.00	456.0
VOC	0.06 (2)	760	45.6	0.03 (2)	490	14.70	0.0053 (2)	605	3.21	45.60	136.80
Lead	1.5E-04 (2)	760	0.11	8.9E-07 (2)	490	4.4E-04	4.8E-07 (2)	605	2.9E-04	0.11	0.34
Mercury	5.4E-06 (2)	760	4.10E-03	2.4E-06 (2)	490	1.2E-03	2.5E-07 (2)	605	1.5E-04	4.10E-03	0.0123
Fluorides	7.0E-04 (3)	760	0.53	6.27E-06 (2)	490	3.1E-03	--	--	--	0.53	1.60
Sulfuric Acid Mist	0.018 (4)	760	13.68	0.003 (4)	490	1.4700	3.48E-04 (4)	605	2.11E-01	13.68	41.04

<sup>a</sup> Under cold startup conditions, each boiler is limited to 150,000 lb/hr of steam. Heat input rate is based on this limited steam rate.

References:

1. NSPS, 40 CFR 60, Subpart Da
2. Based on Permit No. 0990332-014-AC.
3. Based on maximum of 3 most recent stack tests (1999-2001).
4. Based on 6% of the SO<sub>2</sub> emissions (Permit No. 0990332-014-AC).
5. Based on CEM data.
6. Based on use of No. 2 fuel oil with a maximum sulfur content of 0.05% sulfur.



Table 2-3. Maximum Annual Emissions Per Boiler, New Hope Power Partnership Cogeneration Facility

Regulated Pollutant	Biomass			Alternate Fuel			Total Annual Emissions Per Boiler (TPY)	Total Annual Emissions 3 Boilers (TPY)
	Emission Factor (lb/MMBtu)	Activity Factor (E12 Btu/yr)	Annual Emissions (TPY)	Emission Factor (lb/MMBtu)	Activity Factor (E12 Btu/yr)	Annual Emissions (TPY)		
<u>100% Biomass</u>								
Particulate (PM)	0.03	6.658	99.86	--	--	--	99.86 <sup>a</sup>	299.59
Particulate (PM <sub>10</sub> )	0.03	6.658	99.86	--	--	--	99.86 <sup>a</sup>	299.59
Sulfur dioxide <sup>b</sup>	0.06	6.658	199.73	--	--	--	199.73 <sup>a</sup>	599.18
Nitrogen oxides <sup>c</sup>	0.15	6.658	499.32	--	--	--	499.32 <sup>a</sup>	1,498.0
Carbon monoxide <sup>b</sup>	0.35	6.658	1165.08	--	--	--	1,165.08 <sup>a</sup>	3,495.2
VOC	0.06	6.658	199.73	--	--	--	199.73 <sup>a</sup>	599.18
Lead	1.5E-04	6.658	0.499	--	--	--	0.50 <sup>a</sup>	1.50
Mercury	5.4E-06	6.658	0.0180	--	--	--	0.018 <sup>a</sup>	0.054
Fluorides	7.0E-04	6.658	2.3302	--	--	--	2.33 <sup>a</sup>	6.99
Sulfuric acid mist	0.0036	6.658	11.98	--	--	--	11.98 <sup>a</sup>	36.0
<u>75.1% Biomass / 24.9% Fuel Oil</u>								
Particulate (PM)	0.03	4.707	70.61	0.03	1.561	23.42	94.02	282.06
Particulate (PM <sub>10</sub> )	0.03	4.707	70.61	0.03	1.561	23.42	94.02	282.06
Sulfur dioxide <sup>b</sup>	0.06	4.707	141.21	0.05	1.561	39.03	180.24	540.71
Nitrogen oxides <sup>c</sup>	0.15	4.707	353.03	0.15	1.561	117.08	470.10	1,410.3
Carbon monoxide <sup>b</sup>	0.35	4.707	823.73	0.35	1.561	273.18	1,096.90	3,290.7
VOC	0.06	4.707	141.21	0.03	1.561	23.42	164.63	493.88
Lead	1.5E-04	4.707	0.353	8.9E-07	1.561	6.95E-04	0.35	1.06
Mercury	5.4E-06	4.707	0.0127	2.4E-06	1.561	0.0019	0.015	0.044
Fluorides	7.0E-04	4.707	1.6475	6.27E-06	1.561	0.0049	1.65	4.96
Sulfuric acid mist	0.0036	4.707	8.47	0.003	1.561	2.34	10.81	32.4
<u>75.1% Biomass / 24.9% Natural Gas</u>								
Particulate (PM)	0.03	4.707	70.61	0.0073	1.561	5.70	76.30	228.91
Particulate (PM <sub>10</sub> )	0.03	4.707	70.61	0.0073	1.561	5.70	76.30	228.91
Sulfur dioxide <sup>b</sup>	0.06	4.707	141.21	0.0300	1.561	23.42	164.63	493.88
Nitrogen oxides <sup>c</sup>	0.15	4.707	353.03	0.15	1.561	117.08	470.10	1,410.3
Carbon monoxide <sup>b</sup>	0.35	4.707	823.73	0.08	1.561	62.44	886.17	2,658.5
VOC	0.06	4.707	141.21	0.0053	1.561	4.14	145.35	436.04
Lead	1.5E-04	4.707	0.353	4.8E-07	1.561	3.75E-04	0.35	1.06
Mercury	5.4E-06	4.707	0.0127	2.5E-07	1.561	1.95E-04	0.013	0.039
Fluorides	7.0E-04	4.707	1.6475	--	--	--	1.65	4.94
Sulfuric acid mist	0.0036	4.707	8.47	3.48E-04	1.561	0.27	8.74	26.2

<sup>a</sup> Denotes maximum annual emissions for any fuel scenario.<sup>b</sup> Based on 12-month rolling average.<sup>c</sup> Based on 30-day rolling average.

Note: No emissions of total reduced sulfur, asbestos, or vinyl chloride are expected.

Fuel type percentages are based on heat input.

Table 2-4. New Hope Power Partnership Facility Maximum Annual Fugitive Dust Emissions

SOURCE	TYPE OF OPERATION	M MOISTURE CONTENT (%)	U WIND SPEED (MPH)	UNCONTROLLED PM EMISSION FACTOR (LB/TON) <sup>a</sup>	UNCONTROLLED PM <sub>10</sub> EMISSION FACTOR (LB/TON) <sup>a</sup>	CONTROL	CONTROL EFFICIENCY (%)	CONTROLLED PM EMISSION FACTOR (LB/TON)	CONTROLLED PM <sub>10</sub> EMISSION FACTOR (LB/TON)	ACTIVITY FACTOR	MAXIMUM ANNUAL PM(TSP) EMISSIONS (TONS/YR)	MAXIMUM ANNUAL PM <sub>10</sub> EMISSIONS (TONS/YR)	
<b>BIOMASS HANDLING</b>													
TRUCK DUMPS (2)	BATCH DROP	37	9.4	0.0009	0.0004	NONE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
CHAIN CONVEYORS-TO-UNLOADING CONVEYOR (2)	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
UNLOADING CONVEYOR-TO-SCREEN	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
SCREEN	CONTINUOUS DROP	37	9.4	0.0009	0.0004	NONE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
SCREEN-TO-HOGGER	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
HOGGER	CRUSHING	--	--	0.02	0.01	ENCLOSED	95	0.0010	0.00047	3,761,731 TPY <sup>d</sup>	1.881	0.8896	
HOGGER-TO-STORAGE CONVEYOR	BATCH DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
SCREEN-TO-STORAGE CONVEYOR	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	0 TPY	0.000	0.0000	
SCREEN-TO-BOILER FEED CONVEYOR	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	0 TPY	0.000	0.0000	
STORAGE CONVEYOR-TO-RADIAL STACKER	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
RADIAL STACKER-TO-BIOMASS STORAGE PILE	CONTINUOUS DROP	37	9.4	0.0009	0.0004	NONE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
UNDERPILE RECLAIMERS (2)	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSED	90	0.0001	0.0000	3,761,731 TPY <sup>d</sup>	0.017	0.0081	
RECLAIMERS-TO-BOILER FEED CONVEYOR (2)	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
BOILER FEED CONVEYOR-TO-CHAIN DIST. CONVEYOR (2)	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
CHAIN DIST. CONVEYOR -TO-BOILER METER BINS (4)	BATCH DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	3,761,731 TPY <sup>d</sup>	0.170	0.0805	
BAGASSE CONVEYOR-TO-CHAIN DIST CONVEYOR (2)	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	0 TPY	0.000	0.0000	
BAGASSE CONVEYOR-TO-RECYCLE CONVEYOR	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	0 TPY	0.000	0.0000	
CHAIN DIST. CONVEYORS-TO-RECYCLE CONVEYOR (2)	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	376,173 TPY <sup>f</sup>	0.017	0.0081	
RECYCLE CONVEYOR-TO-RECYCLE STACKER	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	0 TPY	0.000	0.0000	
RECYCLE CONVEYOR-TO-STORAGE CONVEYOR	CONTINUOUS DROP	37	9.4	0.0009	0.0004	ENCLOSURE	0	0.0009	0.0004	376,173 TPY <sup>f</sup>	0.017	0.0081	
RECYCLE STACKER-TO-BIOMASS STORAGE PILE	CONTINUOUS DROP	37	9.4	0.0009	0.0004	NONE	0	0.0009	0.0004	0 TPY	0.000	0.0000	
BIOMASS STORAGE PILES (2)	WIND EROSION	--	--	--	--	NONE	0	--	--	--	0.175 <sup>d</sup>	0.0000 <sup>d</sup>	
BIOMASS STORAGE PILE MAINTENANCE	VEHICULAR TRAFFIC	--	--	0.75	0.23 lb/VMT <sup>b</sup>	WATERING	50	0.38	0.11 lb/VMT <sup>b</sup>	21,900 VMT <sup>c</sup>	4.110 <sup>d</sup>	1.2330 <sup>d</sup>	
<b>FLY ASH HANDLING</b>													
FLY ASH SILO FILTER	--	--	--	--	--	BAGHOUSE	99	0.01	0.0047	gt/acf	2,500 acfm	0.939	0.444
FLY ASH TRANSFER-TO-TRUCK	CONTINUOUS DROP	5.0	9.4	0.00149	0.00071	WETTING	50	0.00075	0.00035	110,131 TPY <sup>e</sup>	0.041	0.019	
<b>TOTAL</b>											9.069	3.496	

Notes/References:

<sup>a</sup> Batch Drop and Continuous Drop Emission Factors are computed from AP-42 (USEPA, 1995) Section 13.2.4:

$$E = k \times 0.0032 \times (U/5)^{1.3} / (M/2)^{1.4} \text{ lb/ton, where } k = 0.74 \text{ for PM and } 0.35 \text{ for PM}_{10}$$

<sup>b</sup> Pound per Vehicle Mile Travel (lb/VMT), see Appendix B, Table B-1 for derivation.

<sup>c</sup> Based on vehicle operating 12 hrs/day, 365 days/yr @ 5 mph.

<sup>d</sup> Refer to Appendix B for derivation.

<sup>e</sup> Based on 1,063,162 TPY woodwaste @ 9% ash and 1,444,659 TPY bagasse @ 1% ash. Assuming 100% is fly ash. See Appendix B, Table B-2 for derivation.

<sup>f</sup> Assuming 10% of biomass is overfeed and is returned to biomass storage pile.

<sup>g</sup> Activity Factor based on  $19.97 \times 10^{12}$  Btu/yr; 47.9% is from wood (4,500 Btu/lb) and the remaining 52.1% is from bagasse (3,600 Btu/lb) = 2,507,821 TPY; an additional 50% was added to account for year-to-year variations. See Appendix B, Table B-2 for derivation.

Table 2-5. Stack Parameters for Each Boiler, New Hope Power Partnership

Source	Heat Input Rate (MMBtu/hr)	Stack Height		Stack Diameter		Actual Gas Flowrate (acfm)	Gas Velocity		Gas Temperature	
		ft	m	ft	m		ft/s	m/s	°F	K
<u>Boilers (each)</u>										
Biomass	760	199	60.66	10	3.05	319,000 - 348,000	67.7 - 73.8	20.63 - 22.51	352-373	451-463
No. 2 Fuel Oil	490	199	60.66	10	3.05	140,000 - 150,000	29.7 - 31.8	9.06 - 9.70	295-350	419-450
Natural Gas	605	199	60.66	10	3.05	140,000 - 150,000	29.7 - 31.8	9.06 - 9.70	295-350	419-450

Note: acfm = actual cubic feet per minute  
 °F = degrees Fahrenheit  
 ft = feet  
 ft/s = feet per second  
 K = degrees Kelvin  
 m = meters  
 m/s = meters per second  
 MMBtu/hr = Million British thermal units per hour

### **3.0 AIR QUALITY REVIEW REQUIREMENTS**

Federal and state air regulatory requirements for a major new or modified source of air pollution are discussed in Sections 3.1 through 3.4. The applicability of these regulations to the proposed NHPP modification is presented in Section 3.5. These regulations must be satisfied before the proposed project can be approved.

#### **3.1 NATIONAL AND STATE AMBIENT AIR QUALITY STANDARDS (AAQS)**

The existing applicable national and Florida AAQS are presented in Table 3-1. Primary national AAQS were promulgated to protect the public health, and secondary national AAQS were promulgated to protect the public welfare from any known or anticipated adverse effects associated with the presence of pollutants in the ambient air. Areas of the country in violation of AAQS are designated as nonattainment areas, and new sources to be located in or near these areas may be subject to more stringent air permitting requirements.

Florida has adopted state AAQS in Rule 62-204.240, Florida Administrative Code (F.A.C.). These standards are the same as the national AAQS, except in the case of SO<sub>2</sub>. For SO<sub>2</sub>, Florida has adopted the former 24-hour secondary standard of 260 micrograms per cubic meter ( $\mu\text{g}/\text{m}^3$ ) and former annual average secondary standard of 60  $\mu\text{g}/\text{m}^3$ .

#### **3.2 PSD REQUIREMENTS**

##### **3.2.1 GENERAL REQUIREMENTS**

Under Federal and State of Florida PSD review requirements, all major new or modified sources of air pollutants regulated under the Clean Air Act (CAA) must be reviewed and a pre-construction permit issued. Florida's State Implementation Plan (SIP), which contains PSD regulations, has been approved by the EPA; therefore, PSD approval authority has been granted to the FDEP.

A "major facility" is defined as any one of 28 named source categories that have the potential to emit 100 TPY or more, or any other stationary facility that has the potential to emit 250 TPY or more, of any pollutant regulated under the CAA. "Potential to emit" means the capability, at maximum design capacity, to emit a pollutant after the application of control equipment. Once a new source is determined to be a "major facility" for a particular pollutant, any pollutant emitted in amounts greater than the PSD significant emission rates is subject to PSD review. For an existing source for which a

modification is proposed, the modification is subject to PSD review if the net increase in emissions due to the modification is greater than the PSD significant emission rates. The PSD significant emission rates are shown in Table 3-2.

The EPA class designation and allowable PSD increments are presented in Table 3-1. The magnitude of the allowable increment depends on the classification of the area in which a new source (or modification) will be located or have an impact. Three classifications are designated based on criteria established in the Clean Air Act Amendments. Congress promulgated areas as Class I (international parks, national wilderness areas, and memorial parks larger than 5,000 acres and national parks larger than 6,000 acres) or as Class II (all areas not designated as Class I). No Class III areas, which would be allowed greater deterioration than Class II areas, were designated. The State of Florida has adopted the EPA class designations and allowable PSD increments for SO<sub>2</sub>, PM<sub>10</sub>, and NO<sub>2</sub>.

PSD review is used to determine whether significant air quality deterioration will result from the new or modified facility. Federal PSD requirements are contained in Title 40 of the Code of Federal Regulations (CFR), Part 52.21, Prevention of Significant Deterioration of Air Quality. The State of Florida has adopted the federal PSD regulations by reference (Rule 62-212.400, F.A.C.). Major new facilities and major modifications are required to undergo the following analysis related to PSD for each pollutant emitted in significant amounts:

1. Control technology review,
2. Source impact analysis,
3. Air quality analysis (monitoring),
4. Source information, and
5. Additional impact analyses.

In addition to these analyses, a new facility must also be reviewed with respect to Good Engineering Practice (GEP) stack height regulations. Discussions concerning each of these requirements are presented in the following sections.

### **3.2.2 CONTROL TECHNOLOGY REVIEW**

The control technology review requirements of the federal and state PSD regulations require that all applicable federal and state emission-limiting standards be met, and that BACT be applied to control

emissions from the source. The BACT requirements are applicable to all regulated pollutants for which the increase in emissions from the facility exceeds the respective significant emission rate (see Table 3-2).

BACT is defined in 40 CFR 52.21 (b)(12), as:

An emissions limitation (including a visible emission standard) based on the maximum degree of reduction of each pollutant subject to regulation under the Act which would be emitted by any proposed major stationary source of major modification which the Administrator, on a case-by-case basis, taking into account energy, environmental, and economic impacts, and other costs, determination is achievable through application of production processes and available methods, systems, and techniques (including fuel cleaning or treatment or innovative fuel combustion techniques) for control of such pollutant. In no event shall application of best available control technology result in emissions of any pollutant, which would exceed the emissions allowed by any applicable standard under 40 CFR Parts 60 and 61. If the Administrator determines that technological or economic limitations on the application of measurement methodology to a particular part of a source or facility would make the imposition of an emission standard infeasible, a design, equipment, work practice, operational standard or combination thereof, may be prescribed instead to satisfy the requirement for the application of BACT. Such standard shall, to the degree possible, set forth the emissions reductions achievable by implementation of such design, equipment, work practice, or operation and shall provide for compliance by means, which achieve equivalent results.

BACT was promulgated within the framework of the PSD requirements in the 1977 amendments of the CAA [Public Law 95-95; Part C, Section 165(a)(4)]. The primary purpose of BACT is to optimize consumption of PSD air quality increments and thereby enlarge the potential for future economic growth without significantly degrading air quality (EPA, 1978; 1980). Guidelines for the evaluation of BACT can be found in the EPA's *Guidelines for Determining Best Available Control Technology (BACT)* (EPA, 1978) and in the *PSD Workshop Manual* (EPA, 1980). These guidelines were promulgated by the EPA to provide a consistent approach to BACT and to ensure that the impacts of alternative emission control systems are measured by the same set of parameters. In addition, through implementation of these guidelines, BACT in one area may not be identical to BACT in another area. According to the EPA (1980), "BACT analyses for the same types of emissions unit and the same pollutants in different locations or situations may determine that different control strategies should be applied to the different sites, depending on site-specific factors. Therefore, BACT analyses must be conducted on a case-by-case basis."

The BACT requirements are intended to ensure that the control systems incorporated in the design of a proposed facility reflect the latest in control technologies used in a particular industry and take into consideration existing and future air quality in the vicinity of the proposed facility. BACT must, as a minimum, demonstrate compliance with New Source Performance Standards (NSPS) for a source (if applicable). An evaluation of the air pollution control techniques and systems is required, including a cost-benefit analysis of alternative control technologies capable of achieving a higher degree of emission reduction than the proposed control technology. The cost-benefit analysis requires the documentation of the materials, energy, and economic penalties associated with the proposed and alternative control systems, as well as the environmental benefits derived from these systems. A decision on BACT is to be based on sound judgment, balancing environmental benefits with energy, economic, and other impacts (EPA, 1978).

### 3.2.3 SOURCE IMPACT ANALYSIS

A source impact analysis must be performed for a proposed major source or major modification subject to PSD review, and for each pollutant for which the increase in emissions exceeds the PSD significant emission rate (Table 3-2). The PSD regulations specifically provide for the use of atmospheric dispersion models in performing impact analyses, estimating baseline and future air quality levels, and determining compliance with AAQS and allowable PSD increments. Models designated by the EPA must normally be used in performing the impact analysis. Specific applications for other than the EPA-approved models require the EPA's consultation and prior approval. Guidance for the use and application of dispersion models is presented in the EPA publication *Guideline on Air Quality Models* (EPA, 1980).

To address compliance with AAQS and PSD Class II increments, a source impact analysis must be performed for the criteria pollutants. However, this analysis is not required for a specific pollutant if the net increase in impacts as a result of the new source or modification is below significant impact levels, as presented in Table 3-1. The significant impact levels are threshold levels that are used to determine the level of air impact analyses needed for the project. If the new or modified source's impacts are predicted to be less than significant, then the source's impacts will not have a significant adverse affect on air quality, and additional modeling with other sources is not required. However, if the source's impacts are predicted to be greater than the significant impact levels, additional modeling with other sources is required to demonstrate compliance with AAQS and PSD increments.

The EPA has proposed significant impact levels for Class I areas as follows:

SO <sub>2</sub>	3-hour	1 µg/m <sup>3</sup>
	24-hour	0.2 µg/m <sup>3</sup>
	Annual	0.1 µg/m <sup>3</sup>
PM <sub>10</sub>	24-hour	0.3 µg/m <sup>3</sup>
	Annual	0.2 µg/m <sup>3</sup>
NO <sub>2</sub>	Annual	0.1 µg/m <sup>3</sup>

Although these levels have not been officially promulgated as part of the PSD review process and may not be binding for states in performing PSD reviews, the proposed levels serve as a guideline in assessing a source's impact in a Class I area. The EPA action to incorporate Class I significant impact levels in the PSD process is part of implementing the NSR provisions of the 1990 CAA Amendments. Because the process of developing the regulations will be lengthy, the EPA believes that the proposed rules concerning the significant impact levels are appropriate in order to assist states in implementing the PSD permitting process.

Various lengths of record for meteorological data can be used for impact analysis. A 5-year period is normally used with corresponding evaluation of highest, second-highest (HSH) short-term concentrations for comparison to AAQS or PSD increments. The meteorological data are selected based on an evaluation of measured weather data from a nearby weather station that represents weather conditions at the project site. The criteria used in this evaluation include determining the distance of the project site to the weather station; comparing topographical and land use features between the locations; and determining availability of necessary weather parameters.

The term "highest, second-highest" (HSH) refers to the highest of the second-highest concentrations at all receptors (i.e., the highest concentration at each receptor is discarded). The second-highest concentration is important because short-term AAQS specify that the standard cannot be exceeded at any location more than once a year. If fewer than 5 years of meteorological data are used in the modeling analysis, the highest concentration at each receptor normally must be used for comparison to air quality standards.

The term "baseline concentration" evolves from federal and state PSD regulations and refers to a concentration level corresponding to a specified baseline date and certain additional baseline sources.



By definition, in the PSD regulations as amended August 7, 1980, baseline concentration means the ambient concentration level that exists in the baseline area at the time of the applicable baseline date. A baseline concentration is determined for each pollutant for which a baseline date is established and includes:

1. The actual emissions representative of facilities in existence on the applicable baseline date; and
2. The allowable emissions of major stationary facilities that commenced construction before January 6, 1975, for SO<sub>2</sub> and PM<sub>10</sub> concentrations, or February 8, 1988, for NO<sub>2</sub> concentrations, but that were not in operation by the applicable baseline date.

The following emissions are not included in the baseline concentration and therefore affect PSD increment consumption:

1. Actual emissions from any major stationary facility on which construction commenced after January 6, 1975, for SO<sub>2</sub> and PM<sub>10</sub> concentrations, and after February 8, 1988, for NO<sub>2</sub> concentrations; and
2. Actual emission increases and decreases at any stationary facility occurring after the baseline date.

In reference to the baseline concentration, the term "baseline date" actually includes three different dates:

1. The major facility baseline date, which is January 6, 1975, in the cases of SO<sub>2</sub> and PM<sub>10</sub>, and February 8, 1988, in the case of NO<sub>2</sub>.
2. The minor facility baseline date, which is the earliest date after the trigger date on which a major stationary facility or major modification subject to PSD regulations submits a complete PSD application.
3. The trigger date, which is August 7, 1977, for SO<sub>2</sub> and PM<sub>10</sub>, and February 8, 1988, for NO<sub>2</sub>.

### 3.2.4 AIR QUALITY MONITORING REQUIREMENTS

In accordance with requirements of 40 CFR 52.21(m), any application for a PSD permit must contain an analysis of continuous ambient air quality data in the area affected by the proposed major stationary facility or major modification. For a new major facility, the affected pollutants are those that the facility would potentially emit in significant amounts. For a major modification, the

pollutants are those for which the net emissions increase exceeds the significant emission rate (see Table 3-2).

Ambient air monitoring for a period of up to 1 year is generally appropriate to satisfy the PSD monitoring requirements. A minimum of 4 months of data is required. Existing data from the vicinity of the proposed source may be used if the data meet certain quality assurance requirements; otherwise, additional data may need to be gathered. Guidance in designing a PSD monitoring network is provided in the EPA's *Ambient Monitoring Guidelines for Prevention of Significant Deterioration* (EPA, 1987a).

The regulations include an exemption that excludes or limits the pollutants for which an air quality analysis must be conducted. This exemption states that the FDEP may exempt a proposed major stationary facility or major modification from the monitoring requirements, with respect to a particular pollutant, if the emissions increase of the pollutant from the facility or modification would cause, in any area, air quality impacts less than the *de minimis* levels presented in Table 3-2.

### 3.2.5 SOURCE INFORMATION/GEP STACK HEIGHT

Source information must be provided to adequately describe the proposed project. The general type of information required for this project is presented in Section 2.0.

The 1977 CAA Amendments require that the degree of emission limitation required for control of any pollutant not be affected by a stack height that exceeds GEP or any other dispersion technique. On July 8, 1985, the EPA promulgated final stack height regulations (EPA, 1985a). The FDEP has adopted identical regulations (Rule 62-210.550, F.A.C.). GEP stack height is defined as the highest of:

1. 65 meters (m); or
2. A height established by applying the formula:  
$$H_g = H + 1.5L$$
where:  $H_g$  = GEP stack height,  
 $H$  = Height of the structure or nearby structure, and  
 $L$  = Lesser dimension (height or projected width) of nearby structure(s); or
3. A height demonstrated by a fluid model or field study.

"Nearby" is defined as a distance up to five times the lesser of the height or width dimensions of a structure or terrain feature, but not greater than 0.8 kilometer. Although GEP stack height regulations require that the stack height used in modeling for determining compliance with AAQS and PSD increments not exceed the GEP stack height, the actual stack height may be greater.

The stack height regulations also allow increased GEP stack height beyond that resulting from the above formula in cases where plume impaction occurs. Plume impaction is defined as concentrations measured or predicted to occur when the plume interacts with elevated terrain. Elevated terrain is defined as terrain that exceeds the height calculated by the GEP stack height formula.

### **3.2.6 ADDITIONAL IMPACT ANALYSIS**

In addition to air quality impact analyses, federal and State of Florida regulations require analyses of the impairment to visibility and the impacts on soils and vegetation that would occur as a result of the proposed source [40 CFR 52.21(o) and Rule 62-212.400, F.A.C.]. These analyses are to be conducted primarily for PSD Class I areas. Impacts as a result of general commercial, residential, industrial, and other growth associated with the source also must be addressed. These analyses are required for each pollutant emitted in significant amounts (Table 3-2).

### **3.3 NONATTAINMENT RULES**

Based on the current nonattainment provisions, all major new facilities and modifications to existing major facilities located in a nonattainment area must undergo nonattainment review. A new major facility is required to undergo this review if the proposed pieces of equipment have the potential to emit 100 TPY or more of the nonattainment pollutant.

### **3.4 EMISSION STANDARDS**

#### **3.4.1 NEW SOURCE PERFORMANCE STANDARDS**

The NSPS are a set of national emission standards that apply to specific categories of new sources. As stated in the CAA Amendments of 1977, these standards "shall reflect the degree of emission limitation and the percentage reduction achievable through application of the best technological system of continuous emission reduction the Administrator determines has been adequately demonstrated."

Federal NSPS exist for electric utility steam generating units (40 CFR 60, Subpart Da). The NSPS applies to all units capable of combusting more than 73 megawatts (250 MMBtu/hr) heat input of fossil fuel (either alone or in combination with any other fuel) for which construction commenced after September 18, 1978.

### **3.4.2 FLORIDA RULES**

Several Florida emission limiting standards exist for steam generating units. Fossil fuel steam generating units with greater than 250 MMBtu/hr heat input are subject to the emission limitations of Rule 62-296.405(2), F.A.C. pertaining to PM, SO<sub>2</sub>, NO<sub>x</sub>, and visible emissions. Emissions limitations and visible emissions requirements for carbonaceous fuel-burning equipment are contained in Rule 62-296.410, F.A.C.

## **3.5 SOURCE APPLICABILITY**

### **3.5.1 AREA CLASSIFICATION**

The project site is located in Palm Beach County, which has been designated by the EPA and the FDEP as an attainment or maintenance area for all criteria pollutants. Palm Beach County and surrounding counties are designated as PSD Class II areas for SO<sub>2</sub>, PM<sub>10</sub>, and NO<sub>2</sub>. The nearest Class I area to the site is the Everglades National Park (ENP), located about 92 km (57 miles) south of the NHPP facility.

### **3.5.2 PSD REVIEW**

#### **3.5.2.1 Pollutant Applicability**

The NHPP facility is considered to be an existing major stationary facility because potential emissions of certain regulated pollutants exceed 100 TPY (for example, potential SO<sub>2</sub> emissions currently exceed 100 TPY). Therefore, PSD review is required for any pollutant for which the increase in emissions due to the modification is greater than the PSD significant emission rates (see Table 3-2).

The current actual emissions from the three cogeneration boilers are presented in Table 3-3. The current emissions are based on the 2-year period spanning calendar years 2000 and 2001 (see Appendix A, Table A-1). Actual stack test data and operations data were used in developing the current actual emissions.

Also presented in Table 3-3 are the future potential annual emissions from the NHPP facility, based on each of the three boilers operating at maximum heat input for 8,760 hr/yr (refer to Table 2-3). The net increase in emissions due to the proposed modification at the facility is shown in Table 3-3. As shown, the net increase exceeds the PSD significant emission rates for PM, PM<sub>10</sub>, SO<sub>2</sub>, NO<sub>x</sub>, CO, VOC, SAM, Pb, and fluorides. As a result, PSD review applies for these pollutants.

#### **3.5.2.2 Source Impact Analysis**

A source impact analysis was performed for PM<sub>10</sub>, SO<sub>2</sub>, NO<sub>x</sub>, CO, Pb, VOC, SAM, and fluoride emissions resulting from the proposed modification. This analysis is presented in Section 6.0. The results of that analysis are included herein, and additional impacts upon the PSD Class I are also addressed.

The pollutant impacts of the proposed project to the EPA Class II significant impact levels are compared to the *de minimis* monitoring concentrations in Table 3-4. As shown, the increase in impacts of PM<sub>10</sub>, NO<sub>x</sub>, and CO due to the proposed modification are below the significant impact levels. The increase in SO<sub>2</sub> impacts exceed significant impact levels, and therefore a full modeling analysis is required for SO<sub>2</sub>.

#### **3.5.2.3 Ambient Monitoring**

Based on the increase in emissions from the proposed modification (see Table 3-3), a pre-construction ambient monitoring analysis is required for PM<sub>10</sub>, SO<sub>2</sub>, NO<sub>x</sub>, CO, VOC, SAM, Pb, and fluorides, and monitoring data is required to be submitted as part of the application. However, if the net increase in impacts of a pollutant is less than the applicable *de minimis* monitoring concentration, then an exemption from submittal of pre-construction ambient monitoring data may be obtained [40 CFR 52.21(i)(8)]. In addition, if the EPA has not established an acceptable ambient monitoring method for the pollutant, monitoring is not required.

Pre-construction monitoring data for PM<sub>10</sub>, SO<sub>2</sub>, NO<sub>x</sub>, CO, Pb, and fluorides may be exempted for this project because, as shown in Table 3-4, the proposed modification's impacts are predicted to be below the applicable *de minimis* monitoring concentration for these pollutants. In addition, no acceptable air monitoring method has been established for SAM. Since the proposed project would result in an increase in potential VOC emissions of 100 TPY or more, a pre-construction ambient monitoring analysis is required for ozone. This analysis is presented in Section 4.0.

#### **3.5.2.4 GEP Stack Height Impact Analysis**

The NHPP cogeneration boiler stacks are 199 ft high and will not change as part of this project. This stack height does not exceed the *de minimis* good engineering practice (GEP) stack height of 65 meters (213 ft), and therefore the project is in compliance with the GEP stack height rules.

### **3.5.3 EMISSION STANDARDS**

#### **3.5.3.1 New Source Performance Standards**

The NHPP cogeneration boilers are currently subject to the NSPS for electric utility steam generating units, as contained in 40 CFR 60 Subpart Da. The NSPS applies to all steam generating units capable of combusting more than 250 MMBtu/hr heat input of fossil fuel (either alone or in combination with any other fuel). Since the NHPP cogeneration boilers combust biomass alone or in combination with No. 2 fuel oil or natural gas, the NSPS applies to combustion of No. 2 fuel oil, natural gas, and biomass, alone or in combination.

The applicable NSPS for fossil fuel steam generating units is 0.03 lb/MMBtu for PM and 1.2 lb/MMBtu for SO<sub>2</sub>. For NO<sub>x</sub>, the applicable limits are 0.15 lb/MMBtu when burning natural gas, 0.30 lb/MMBtu when burning fuel oil, and 0.60 lb/MMBtu when burning biomass. The cogeneration boilers will comply with the applicable emission limits.

#### **3.5.3.2 State of Florida Standards**

The applicable state of Florida emission limits for new fossil fuel steam generators with more than 250 MMBtu/hr heat input are the same as the applicable NSPS. For the cogeneration boilers, the applicable NSPS is 40 CFR 60 Subpart Da, as described in Section 3.5.3.1. For carbonaceous fuel-burning units, the standards are no more stringent than the NSPS. Therefore, the cogeneration boilers will comply with the Florida emission standards contained in Rules 62-296.405(2) and 62-296.410(2)(b)1, F.A.C.

Table 3-1. National and State AAQS, Allowable PSD Increments, and Significant Impact Levels ( $\mu\text{g}/\text{m}^3$ )

Pollutant	Averaging Time	AAQS			PSD Increments		Significant Impact Levels <sup>d</sup>
		National Primary Standard	National Secondary Standard	State of Florida	Class I	Class II	
Particulate Matter <sup>a</sup> (PM <sub>10</sub> )	Annual Arithmetic Mean	50	50	50	4	17	1
	24-Hour Maximum <sup>b</sup>	150 <sup>b</sup>	150 <sup>b</sup>	150 <sup>b</sup>	8	30	5
Sulfur Dioxide	Annual Arithmetic Mean	80	NA	60	2	20	1
	24-Hour Maximum <sup>c</sup>	365 <sup>b</sup>	NA	260 <sup>b</sup>	5	91	5
	3-Hour Maximum <sup>b</sup>	NA	1,300 <sup>b</sup>	1,300 <sup>b</sup>	25	512	25
Carbon Monoxide	8-Hour Maximum <sup>b</sup>	10,000 <sup>b</sup>	10,000 <sup>b</sup>	10,000 <sup>b</sup>	NA	NA	500
	1-Hour Maximum <sup>b</sup>	40,000 <sup>b</sup>	40,000 <sup>b</sup>	40,000 <sup>b</sup>	NA	NA	2,000
Nitrogen Dioxide	Annual Arithmetic Mean	100	100	100	2.5	25	1
Ozone <sup>a</sup>	1-Hour Maximum	235 <sup>c</sup>	235 <sup>c</sup>	235 <sup>c</sup>	NA	NA	NA
	1-Hour Maximum	235	235	NA	NA	NA	NA
Lead	Calendar Quarter Arithmetic Mean	1.5	1.5	1.5	NA	NA	NA

Note: NA = Not applicable, i.e., no standard exists.

PM<sub>10</sub> = particulate matter with aerodynamic diameter less than or equal to 10 micrometers.

<sup>a</sup> On July 18, 1997, the EPA promulgated revised AAQS for particulate matter and ozone. For particulate matter, PM<sub>2.5</sub> standards were introduced with a 24-hour standard of 65  $\mu\text{g}/\text{m}^3$  (3-year average of 98th percentile) and an annual standard of 15  $\mu\text{g}/\text{m}^3$  (3-year average at community monitors). Implementation of these standards has not yet occurred. The ozone standard was modified to be 0.08 ppm for 8-hour average; achieved when 3-year average of 99th percentile is 0.08 ppm or less. The FDEP has not yet adopted these standards.

<sup>b</sup> Short-term maximum concentrations are not to be exceeded more than once per year except for the PM<sub>10</sub> AAQS (these do not apply to significant impact levels). The PM<sub>10</sub> 24-hour AAQS is attained when the expected number of days per year with a 24-hour concentration above 150  $\mu\text{g}/\text{m}^3$  is equal to or less than 1. For modeling purposes, compliance is based on the sixth highest 24-hour average value over a 5-year period.

<sup>c</sup> Achieved when the expected number of days per year with concentrations above the standard is fewer than 1.

<sup>d</sup> Maximum concentrations.

Sources: Federal Register, Vol. 43, No. 118, June 19, 1978. 40 CFR 50. 40 CFR 52.21. Rule 62-204, F.A.C.

Table 3-2. PSD Significant Emission Rates and *De Minimis* Monitoring Concentrations

Pollutant	Regulated Under	Significant Emission Rate (TPY)	<i>De Minimis</i> Monitoring Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )
Sulfur Dioxide	NAAQS, NSPS	40	13, 24-hour
Particulate Matter [PM(TSP)]	NSPS	25	NA
Particulate Matter (PM <sub>10</sub> )	NAAQS	15	10, 24-hour
Nitrogen Dioxide	NAAQS, NSPS	40	14, annual
Carbon Monoxide	NAAQS, NSPS	100	575, 8-hour
Volatile Organic Compounds (Ozone)	NAAQS, NSPS	40	100 TPY <sup>b</sup>
Lead	NAAQS	0.6	0.1, 3-month
Sulfuric Acid Mist	NSPS	7	NM
Total Fluorides	NSPS	3	0.25, 24-hour
Total Reduced Sulfur	NSPS	10	10, 1-hour
Reduced Sulfur Compounds	NSPS	10	10, 1-hour
Hydrogen Sulfide	NSPS	10	0.2, 1-hour
Mercury	NESHAP	0.1	0.25, 24-hour
Beryllium	NESHAP	0.0004	0.001, 24-hour
Asbestos	NESHAP	0.007	NM
Vinyl Chloride	NESHAP	1	15, 24-hour
MWC Organics	NSPS	$3.5 \times 10^{-6}$	NM
MWC Metals	NSPS	15	NM
MWC Acid Gases	NSPS	40	NM
MSW Landfill Gases	NSPS	50	NM

Note: Ambient monitoring requirements for any pollutant may be exempted if the impact of the increase in emissions is below *de minimis* monitoring concentrations.

NA = Not applicable.

NAAQS = National Ambient Air Quality Standards.

NM = No ambient measurement method established; therefore, no *de minimis* concentration has been established.

NSPS = New Source Performance Standards.

NESHAP = National Emission Standards for Hazardous Air Pollutants.

$\mu\text{g}/\text{m}^3$  = micrograms per cubic meter.

MWC = Municipal waste combustor.

MSW = Municipal solid waste.

<sup>a</sup> Short-term concentrations are not to be exceeded.

<sup>b</sup> No *de minimis* concentration; an increase in VOC emissions of 100 TPY or more will require monitoring analysis for ozone.

Sources: 40 CFR 52.21.  
Rule 62-212.400.



Table 3-3. PSD Source Applicability Analysis, New Hope Power Partnership

Regulated Pollutant	Current Actual Emissions From Boilers A, B, C <sup>a</sup> (TPY)	Future Potential Emissions (TPY)		Net Change In Emissions Due to Proposed Project (TPY)	PSD Significant Emission Rate (TPY)	PSD Review Triggered?
		Boilers A, B, C	Fugitive Emissions <sup>b</sup>			
Particulate (PM)	127.96	299.59	9.07	180.71	25	Yes
Particulate (PM <sub>10</sub> )	108.02	299.59	3.50	195.07	15	Yes
Sulfur Dioxide	191.90	599.18	0	407.29	40	Yes
Nitrogen Oxides	756.60	1,498.0	0	741.36	40	Yes
Carbon Monoxide	1,335.4	3,495.2	0	2,159.8	100	Yes
VOC	43.93	599.18	0	555.26	40	Yes
Lead	0.098	1.50	0	1.40	0.6	Yes
Mercury	0.0035	0.054	0	0.050	0.1	No
Fluorides	2.16	6.99	0	4.83	3	Yes
Sulfuric Acid Mist	15.71	35.95	0	20.24	7	Yes

<sup>a</sup> Actual emissions based on the average emissions for 2000 and 2001.

<sup>b</sup> See Table 2-4 for fugitive emissions calculations.

Note: PM = Particulate Matter

PM<sub>10</sub> = Particulate Matter with aerodynamic diameter less than or equal to 10 microns

VOC = Volatile Organic Compound

Table 3-4. Increase in Impacts Due to Proposed Modification Compared to Class II Significant Impact Levels and Ambient Monitoring *De Minimis* Levels, New Hope Power Partnership

Pollutant	Averaging Time	Maximum Concentration <sup>a</sup> (µg/m <sup>3</sup> )	EPA Class II Significant Impact Levels (µg/m <sup>3</sup> )	Above EPA Class II Significant Impact Level?	<i>De Minimis</i> Monitoring Concentration (µg/m <sup>3</sup> )	Ambient Monitoring Review Applies?
Particulate (PM <sub>10</sub> )	Annual	0.16	1	No	NA	NA
	24-hour	1.20	5	No	10	No
Sulfur Dioxide	Annual	0.31	1	No	NA	NA
	24-hour	9.29	5	Yes	13	No
	3-hour	31.84	25	Yes	NA	NA
Nitrogen Oxides	Annual	0.55	1	No	14	No
Carbon Monoxide	8-hour	5.0	500	No	575	No
	1-hour	21.5	2000	No	NA	NA
VOC	Annual	NA	NA	NA	100 TPY	Yes <sup>b</sup>
Lead	3-month	0.0044 <sup>c</sup>	NA	NA	0.1	No
Fluorides	24-hour	0.017	NA	NA	0.25	No
Sulfuric Acid Mist	NA	NA	NA	NA	NA	NA

<sup>a</sup> Highest concentration from significant impact analysis (see Section 6.0).

<sup>b</sup> An increase in VOC emissions of 100 TPY or more requires monitoring analysis for ozone.

<sup>c</sup> Based on the annual average impact of 1.10E-03 µg/m<sup>3</sup> times four.

Note: NA = Not Applicable

## 4.0 AMBIENT MONITORING ANALYSIS

### 4.1 MONITORING REQUIREMENTS

In accordance with requirements of 40 CFR 52.21(m) and Rule 62-212.400(5)(f), F.A.C., any application for a PSD permit must contain an analysis of continuous ambient air quality data in the area affected by the proposed major stationary facility or major modification. For a new major facility, the affected pollutants are those that the facility would potentially emit in significant amounts. For a major modification, the pollutants are those for which the net emissions increase exceeds the significant emission rate (see Table 3-2). As discussed in Section 3.0, only ozone requires an air quality analysis to meet PSD pre-construction monitoring requirements for the proposed NHPP annual heat input rate increase.

Ambient air monitoring for a period of up to 1 year is generally appropriate to satisfy the PSD monitoring requirements. A minimum of 4 months of data is required. Existing data from the vicinity of the proposed source may be used if the data meet certain quality assurance requirements; otherwise, additional data may need to be gathered. Guidance in designing a PSD monitoring network is provided in the EPA's *Ambient Monitoring Guidelines for Prevention of Significant Deterioration* (1987).

An exemption from the preconstruction ambient monitoring requirements is available if certain criteria are met. If the predicted increase in ambient concentrations due to the proposed modification is less than specified *de minimis* concentrations, then the modification can be exempted from the pre-construction air monitoring requirements for that pollutant.

There is no PSD *de minimis* monitoring concentration established for VOC. However, an increase in VOC emissions of 100 TPY or more requires a preconstruction ambient monitoring analysis for ozone. This analysis is presented in the following section. In addition, existing ambient air quality data for the ENP Class I area is presented to support the AQRV analysis presented in Section 7.0.

The PSD ambient monitoring guidelines allow the use of existing data to satisfy preconstruction review requirements and to develop background concentrations. Background concentrations are necessary to determine total ambient air quality impacts to demonstrate compliance with AAQS. "Background concentrations" are defined as concentrations due to sources other than those

specifically included in the modeling analysis. For all pollutants, background would include other point sources not included in the modeling (i.e., faraway sources or small sources), fugitive emission sources, and natural background sources. Background concentrations for SO<sub>2</sub> are presented in this section to support the air impact analysis.

#### **4.2 OZONE AMBIENT MONITORING ANALYSIS**

Presented in Table 4-1 is a summary of existing continuous ambient ozone data for monitors located in the vicinity of NHPP. Data are presented for the last three years of record, 1999 to 2001. As shown, no ozone monitors were operational in the vicinity of NHPP during the period between 1999 and 2001. The nearest ozone monitoring station was located in Royal Palm Beach (just west of West Palm Beach).

The ozone monitors show that ambient ozone concentrations were below the ambient air quality standards of 0.12 ppm (235 µg/m<sup>3</sup>), maximum 1-hour average allowed to be exceeded on average one day per year. The monitor in Royal Palm Beach is considered to be representative of the NHPP facility area since it is relatively close to NHPP.

#### **4.3 SO<sub>2</sub> AMBIENT BACKGROUND CONCENTRATIONS**

Presented in Table 4-2 is a summary of existing continuous ambient SO<sub>2</sub> data for monitors located in the vicinity of NHPP. Data are presented for the last 5 years of record, 1997 to 2001. As shown, only one SO<sub>2</sub> monitor was operational in the vicinity of NHPP during this period. This station, located in South Bay, operated in 1997 but was shutdown in 1998. One station in Riviera Beach operated during 1997 through 2001, but is located over 60 km from NHPP.

The monitor at South Bay shows that ambient SO<sub>2</sub> concentrations were well below the ambient air quality standards of: 1,300 µg/m<sup>3</sup>, maximum 3-hour average; 260 µg/m<sup>3</sup>, maximum 24-hour average; and 60 µg/m<sup>3</sup>, annual average. The monitor in Riviera Beach is not considered to be representative of the NHPP mill site due to its distance from NHPP, and its urban location near a major power plant. The South Bay monitor is considered representative of the NHPP area, since it was located within 5 miles and in a similar rural setting.

For purposes of an ambient SO<sub>2</sub> background concentration for use in the modeling analysis, the annual average SO<sub>2</sub> concentration of 5 µg/m<sup>3</sup> recorded at the South Bay monitor during 1997 was

selected. Similarly, the concentrations used for the 3- and 24-hour background SO<sub>2</sub> concentrations in the air quality impact analysis were 47 and 13 µg/m<sup>3</sup>, respectively, which are the second-highest short-term concentrations measured at the site.

#### **4.4 EVERGLADES NATIONAL PARK CLASS I AREA**

Presented in Table 4-3 is a summary of existing ambient PM/PM<sub>10</sub>, SO<sub>2</sub>, and NO<sub>2</sub> monitoring data for monitors located in the vicinity of the ENP Class I area. One PM<sub>10</sub> monitor and one SO<sub>2</sub> monitor was located directly in the ENP in 1997 and 1998. The nearest NO<sub>2</sub> data is from a site located in downtown Miami.

The monitoring data show that ambient PM<sub>10</sub> concentrations were well below the ambient air quality standards of 150 µg/m<sup>3</sup>, maximum 24-hour average, and 50 µg/m<sup>3</sup>, annual average, and ambient SO<sub>2</sub> concentrations were extremely low and are representative of natural background concentrations.

Table 4-1. Summary of Continuous Ozone Ambient Monitoring Data Collected Near South Bay

County	Station ID	Monitor Location	Year	Number of Observations	Percent Data Recovery	Concentration (ppm)			
						Maximum 1-hour	2nd High 1-hour	3rd High 1-hour	4th High 1-hour
Palm Beach	12-099-0007	West Palm Beach 10999 Okeechobee Blvd.	1999	174	71	0.057	0.056	0.055	0.055
Palm Beach	12-099-2004	Delray Beach 210 NW 1st Avenue	1999	242	99	0.108	0.104	0.101	0.091
			2000	238	97	0.096	0.093	0.087	0.083
			2001	243	99	0.102	0.098	0.081	0.08
Palm Beach	12-099-0009	Royal Palm Beach 980 Crestwood Blvd.	2000	231	94	0.083	0.078	0.077	0.075
			2001	190	78	0.107	0.090	0.084	0.077

Note: ppm = parts per million.

Table 4-2. Summary of Continuous Sulfur Dioxide Ambient Monitoring Data Collected Near South Bay

County	Station ID	Monitor Location	Year	Number of Observations	Concentration ( $\mu\text{g}/\text{m}^3$ )				
					Maximum 3-hour	2nd High 3-hour	Maximum 24-hour	2nd High 24-hour	Annual Average
Palm Beach	4150-001-J02	South Bay-300 North US 27	1997	8,486	55	47	19	13	5
Palm Beach	12-099-3004	Riviera Beach-1050 15th Street	1997	8,274	165	154	50	37	4
			1998	8,299	177 (0.068 ppm)	31 (0.012 ppm)	24 (0.009 ppm)	10 (0.004 ppm)	3 (0.001 ppm)
			1999	8,221	45 (0.017 ppm)	37 (0.014 ppm)	34 (0.013 ppm)	34 (0.013 ppm)	5 (0.002 ppm)
			2000	8,404	34 (0.013 ppm)	31 (0.012 ppm)	26 (0.010 ppm)	21 (0.008 ppm)	5 (0.002 ppm)
			2001	6,361	13 (0.005 ppm)	10 (0.004 ppm)	8 (0.003 ppm)	8 (0.003 ppm)	3 (0.001 ppm)

Note:  $\mu\text{g}/\text{m}^3$  = micrograms per cubic meter  
ppm = parts per million

Table 4-3. Summary of Sulfur Dioxide, PM<sub>10</sub>, and NO<sub>2</sub> Monitoring Data, Everglades National Park

County	Station ID	Monitor Location	Year	Number of Observations	Concentration ( $\mu\text{g}/\text{m}^3$ )				
					Maximum 1-hour	2nd High 1-hour	Maximum 24-hour	2nd High 24-hour	Annual Average
<u>SO<sub>2</sub> Monitoring Data</u>									
Dade	National Park Service	Within Everglades National Park	1997	91	--	--	0.52	0.18	0.046
			1998	71	--	--	0.72	0.68	0.13
			1999	41	--	--	0.65	0.46	0.15
<u>PM<sub>10</sub> Monitoring Data</u>									
Dade	National Park Service	Within Everglades National Park	1990	89	--	--	79	44	20
			1991	53	--	--	38	37	18
<u>NO<sub>2</sub> Monitoring Data</u>									
Dade	12-025-4002	Miami-864 NW 3rd Street	1999	7,916	202	164	--	--	32
			2000	6,805	379	315	--	--	30 (0.016 ppm)
			2001	8,488	143	139	--	--	30 (0.016 ppm)
Dade	12-025-0027	Miami-Rosentiel School	1999	8,340	134	121	--	--	11
			2000	6,861	123	121	--	--	11 (0.006 ppm)
			2001	7,807	103	98	--	--	11 (0.006 ppm)

Note:  $\mu\text{g}/\text{m}^3$  = micrograms per cubic meter.  
ppm = parts per million.

Source: Improve, NPS for SO<sub>2</sub> and PM<sub>10</sub> data; Allsum, FDEP for NO<sub>2</sub> data.



## 5.0 BEST AVAILABLE CONTROL TECHNOLOGY ANALYSIS

### 5.1 REQUIREMENTS

The 1977 CAA Amendments established requirements for the approval of pre-construction permit applications under the PSD program. One of these requirements is that BACT be installed for applicable pollutants. BACT determinations must be made on a case-by-case basis considering technical, economic, energy, and environmental impacts for various BACT alternatives. To bring consistency to the BACT process, the EPA developed the "top-down" approach to BACT determinations.

The first step in a top-down BACT analysis is to determine, for each applicable pollutant, the most stringent control alternative available for a similar source or source category. If it can be shown that this level of control is not feasible on the basis of technical, economic, energy, or environmental impacts for the source in question, then the next most stringent level of control is identified and similarly evaluated. This process continues until the BACT level under consideration cannot be eliminated by any technical, economic, energy, or environmental consideration.

In the case of the proposed NHPP project, PM/PM<sub>10</sub>, SO<sub>2</sub>, NO<sub>x</sub>, CO, VOC, SAM, Pb, and fluorides require a BACT analysis. The BACT analysis is presented in the following sections.

### 5.2 PARTICULATE MATTER (PM/PM<sub>10</sub>)

#### 5.2.1 EXISTING AND PROPOSED CONTROL TECHNOLOGY

Particulate matter emissions are currently controlled by mechanical cyclone dust collectors and electrostatic precipitators (ESPs). The dust collectors were installed during the year 2000, and are located immediately following each boiler's air preheater, prior to the ESP. Based on ash generation, the dust collectors are removing about 80 percent of the particulate matter in the flue gases. The dust collectors remove larger size PM prior to the ESP. Each cogeneration boiler is vented through separate ESPs and stacks. The current PM/PM<sub>10</sub> permit limit for the NHPP boilers is 0.03 lb/MMBtu, equivalent to NSPS Subpart Da standards.

The proposed BACT for PM/PM<sub>10</sub> is based on the current control techniques: use of mechanical cyclone dust collectors followed by ESPs. The proposed PM/PM<sub>10</sub> emission limit is based on the current limit of 0.03 lb/MMBtu.

NHPP PM/PM<sub>10</sub> stack test results for wood firing, bagasse firing, and biomass firing, respectively performed in 1999, 2000, 2001, and 2002 (biomass), are presented in Appendix C. Since the dust collectors were installed in 2000, the two most recent stack tests reflect a decrease in PM emissions and compliance with the 0.03 lb/MMBtu limit. Only the most recent stack tests reflect the normal operating case of burning approximately a 50/50 combination of wood and bagasse. Since there is not enough stack test data for normal operation to support a lower limit, the proposed BACT is based on the current permit limit of 0.03 lb/MMBtu.

### **5.2.2 BACT ANALYSIS**

The proposed maximum PM/PM<sub>10</sub> emissions for the cogeneration boilers are 0.03 lb/MMBtu for firing of all fuels (biomass, fuel oil, and natural gas). These are the current limits for the boilers. Maximum PM/PM<sub>10</sub> emissions for all three (3) cogeneration boilers combined will be limited to 68.4 lb/hr and 299.59 TPY after the increase in facility heat input. The maximum emissions are due to biomass firing.

As part of the BACT analysis, a review was performed of previous PM/PM<sub>10</sub> BACT determinations for industrial and electric utility boilers listed in the RACT/BACT/LAER Clearinghouse on EPA's web page. A summary of BACT determinations for biomass-fired industrial and electric utility boilers from this review are presented in Appendix D, Table D-1. Determinations issued during the last ten years are shown in the table.

From the review of previous BACT determinations, it is evident that PM/PM<sub>10</sub> BACT determinations for biomass-fired industrial and electric utility boilers have typically been based on cyclone/ESP technology or baghouse technology. BACT determinations have been in the range of 0.02 lb/MMBtu to 0.15 lb/MMBtu of PM/PM<sub>10</sub> emissions. The most recent determinations are in the range of 0.03 to 0.15 lb/MMBtu.

#### **5.2.2.1 Control Technology Feasibility**

The technically feasible PM/PM<sub>10</sub> controls for the NHPP boilers consist of the following add-on PM/PM<sub>10</sub> control systems:

- Cyclones;
- Baghouses;
- ESPs; and
- Wet scrubbers.

NHPP already utilizes mechanical cyclone dust collectors and ESPs to control PM/PM<sub>10</sub> emissions. Baghouses and wet scrubbers are discussed in the following paragraphs.

Baghouses, or fabric filters, utilize porous fabric to clean an airstream. They includes types such as reverse-air, shaker, and pulse-jet baghouses. The dust that accumulates on the surface of the filter aids in the filtering of fine dust particles. PM/PM<sub>10</sub> control efficiencies for fabric filters are typically greater than 99 percent.

Wet scrubbers are systems that involve particle collection by contacting the particles to a liquid, usually water. The aerosol particles are transferred from the gaseous airstream to the surface of the liquid by several different mechanisms. Wet scrubbers create a liquid waste that must be treated prior to disposal. PM/PM<sub>10</sub> control efficiencies for wet scrubbing systems range from about 90 to 98 percent, depending on the type of scrubbing system used.

#### **5.2.2.2 Economic Analysis**

Since NHPP currently utilizes mechanical cyclone dust collectors and ESPs to control PM/PM<sub>10</sub>, any further add-on control equipment would not be appropriate. Additional PM/PM<sub>10</sub> control equipment would result in capital costs of several million dollars per cogeneration boiler. The mechanical dust collectors and ESPs have demonstrated efficient PM/PM<sub>10</sub> removal at NHPP. The NHPP stack test data demonstrate PM/PM<sub>10</sub> emission levels in the range of 0.01 to 0.02 lb/MMBtu, based on testing since the mechanical dust collectors were installed. These levels are already in the range achievable by a fabric filter system, and are lower than previous BACT determinations.

#### **5.2.3 SUMMARY**

In conclusion, NHPP's proposed PM/PM<sub>10</sub> emission limit is reasonable based on previous BACT determinations for similar facilities, existing information, and the highly efficient PM/PM<sub>10</sub> control of the existing dust collectors and ESPs.

Any additional or different add-on control PM/PM<sub>10</sub> control equipment is not appropriate for the cogeneration boilers. Such control equipment would result in significant capital costs for each boiler. The dust collectors and ESPs are already in operation and are demonstrating efficient

PM/PM<sub>10</sub> control. Therefore, the proposed PM/PM<sub>10</sub> BACT limit of 0.03 lb/MMBtu is based on the existing mechanical cyclone dust collectors and ESPs.

### 5.3 SULFUR DIOXIDE

#### 5.3.1 EXISTING AND PROPOSED CONTROL TECHNOLOGY

SO<sub>2</sub> emissions are currently controlled by burning biomass, low sulfur No. 2 distillate fuel oil (0.05 percent sulfur, maximum) and natural gas. All of these fuels are inherently very low in sulfur, and therefore produce low SO<sub>2</sub> emissions. The following table summarizes the expected biomass fuel sulfur content, based on historical fuel sampling at the NHPP cogeneration facility.

Wood (% by wt. Dry)	Bagasse (% by wt. Dry)
0.02%, low	0.02%, low
0.07%, avg.	0.03%, avg.
0.27%, high	0.05%, high

In addition, SO<sub>2</sub> removal is inherent to the process of combusting biomass. The fly ash produced during biomass firing is alkaline in nature and acts as a dry scrubbant, adsorbing SO<sub>2</sub> from the exhaust stream. The ash is then collected in the mechanical collectors and the ESP. Significant SO<sub>2</sub> removal has been demonstrated at NHPP. Based on fuel analysis and CEM data, daily SO<sub>2</sub> removal efficiencies at NHPP were estimated to range from 87 to 99 percent.

The proposed BACT for SO<sub>2</sub> is based on the existing control technique and the current permit limits: firing of low sulfur fuels. The proposed BACT emission limits for SO<sub>2</sub> for biomass firing are:

- 0.20 lb/MMBtu on a 24-hour average;
- 0.10 lb/MMBtu on a 30-day rolling average, and;
- 0.06 lb/MMBtu on a 12-month rolling average.

For fuel oil firing, the proposed BACT is burning low sulfur distillate oil with a maximum sulfur content of 0.05 percent. This is equivalent to SO<sub>2</sub> emissions of approximately 0.05 lb/MMBtu. No limit is proposed for natural gas firing; however, estimated SO<sub>2</sub> emissions are 0.0058 lb/MMBtu based on emission factors.

### 5.3.2 BACT ANALYSIS

#### 5.3.2.1 Control Technology Feasibility

The technically feasible SO<sub>2</sub> control alternatives for the NHPP boilers consist of the following add-on SO<sub>2</sub> control systems;

- Wet flue gas desulfurization (FGD);
- Dry FGD; and
- Regenerable FGD.

Wet FGD includes technologies such as lime, limestone forced or inhibited oxidation, and magnesium-enhanced lime FGD. These systems create solid and liquid waste streams, which must be treated before disposal. SO<sub>2</sub> control efficiencies for wet limestone FGD range from 50 to 98 percent, depending on the type of device and design, with an average of 90 percent.

Dry FGD systems include lime spray drying, dry lime furnace injection, and dry lime duct injection. These systems must be followed by a highly efficient PM control device, which is typically a fabric filter, although an electrostatic precipitator could also be used. The dominant dry FGD technique is spray drying. Lime spray drying efficiency ranges from 70 to 96 percent, with an average of 90 percent.

Regenerable FGD systems can be either wet or dry and result in a concentrated stream of SO<sub>2</sub>, which can then be sold. These systems include sodium sulfite, magnesium oxide, sodium carbonate, and amine.

#### 5.3.2.2 Economic Analysis

Wet, dry, and regenerable FGD systems can all achieve the same level of SO<sub>2</sub> control efficiency. To evaluate the cost effectiveness of FGD applied to the proposed NHPP, cost estimates for a lime spray drying system were developed. Spray drying systems are generally less expensive than the wet limestone FGD process and are therefore more economical. To develop costs, vendor quotes obtained for Palm Beach Power Corp.'s (PBPC's) proposed cogeneration boilers were used. PBPC will use boilers identical to NHPP's boilers, and will burn the same type fuel. Therefore, control equipment costs should be very similar for the two facilities, except that NHPP would represent a retrofit installation. One quote was from Hamon Research-Cottrell, Inc., and the other from Wheelabrator Air Pollution Control (refer to Appendix E for the complete quotes).

These quotes are for complete systems, based on two cogeneration boilers, including the spray dryer absorber, lime delivery system, pulse jet fabric filter, and ancillary equipment. To install a lime spray drying system on the existing cogeneration boilers, upgraded PM/PM<sub>10</sub> control equipment would be required due the increased particulate loading caused by the spray drying systems. SO<sub>2</sub> removal was specified as 90 percent. Fuel heating value and sulfur content were specified to result in uncontrolled SO<sub>2</sub> emissions of 0.06 lb/MMBtu, which is the proposed annual average limit for NHPP. A capacity factor of 90 percent was assumed for both baseline and future emissions, since it is not feasible for the NHPP boilers to operate at 100% load year-round. Capital recovery costs were based on 7-percent interest and a 20-year equipment life.

A project contingency of 25% of the purchased equipment cost was included to account for the fact that this would be a retrofit installation. Emissions of fluorides were also included in the cost effectiveness calculations since the FGD system will also control fluorides (refer to Section 5.6).

The cost analysis is presented in Tables 5-1 and 5-2. Based on the vendor quotes, the resulting capital costs range from \$9,900,000 to greater than \$12,000,000 per boiler. Based on uncontrolled emissions per boiler of SO<sub>2</sub> and HF of 181.9 tons per year, and assuming 90-percent removal, the total SO<sub>2</sub>/HF removed is 163.7 TPY. The resulting cost effectiveness ranges from \$10,000 to nearly \$12,000 per ton of SO<sub>2</sub>/HF removed.

Wet and regenerable FGD control systems would have higher capital and annual operating costs, with a resulting higher cost effectiveness, and therefore were not evaluated with a detailed cost estimate.

#### **5.3.2.3 Previous BACT Determinations**

A review was performed of previous SO<sub>2</sub> BACT determinations for similar biomass-fired industrial and electric utility boilers listed in the RACT/BACT/LAER Clearinghouse on EPA's web page. A summary of these BACT determinations for biomass-fired is presented in Appendix D, Table D-2. Only determinations issued within the last 10 years are shown. Note that one fluidized bed biomass boiler located in California (SAI Energy, Inc.) was not included in the table because of the distinct differences between NHPP's spreader stoker boilers and a fluidized bed boiler.

Previous BACT determinations have ranged from 0.016 to 0.46 lb/MMBtu SO<sub>2</sub>. Three of these determinations were for bagasse-fired boilers. Bagasse is a fuel that exhibits lower and less variable sulfur content than wood. Four projects were located at paper mills, which predominantly obtain biomass from dedicated forests, with a consistent fuel quality. It is noted that the Grayling Generating Station determination listed is likely not a BACT determination, because total SO<sub>2</sub> emissions from the plant were less than 40 TPY. However, it was provided due to the recent issuance of this permit and its similarity to the NHPP project.

From the review of these previous BACT determinations, it is evident that SO<sub>2</sub> BACT determinations for biomass-fired boilers have been based solely on fuel specifications (i.e., use of low sulfur-containing fuels). Therefore, the emission limits are based on the prospective or actual fuel supply.

It is noted that the NHPP facility is believed to be significantly different than the wood/bark burning facilities shown in Table D-2. NHPP obtains its wood materials from a number of suppliers and sources throughout south Florida. Most of the sources shown in Table D-2 are not located in south Florida, and many are believed to have a dedicated fuel supply source, which means that the fuel is much more homogenous than NHPP's fuel supply.

Nevertheless, the proposed BACT emission limits have been based on the historical fuel supply for the NHPP cogeneration facility. The proposed annual SO<sub>2</sub> limit is 0.06 lb/MMBtu, based on a 12-month rolling average. A 30-day rolling average limit of 0.10 lb/MMBtu is proposed. A 24-hour average limit of 0.20 lb/MMBtu is proposed to account for the demonstrated variability of biomass fuel. All these limits are the same as the existing permit limits for NHPP. These limits were determined to be BACT for NHPP in February, 2002.

### 5.3.3 SUMMARY

In conclusion, NHPP's request for SO<sub>2</sub> emissions standards is reasonable based on the existing information from the NHPP cogeneration facility, the low sulfur content of biomass fuels, and BACT determinations for similar biomass power plants. The SO<sub>2</sub> emissions are a direct function of the fuel sulfur content, but are difficult to minimize on a short-term basis because of fuel sulfur variation and the unquantified SO<sub>2</sub> removal mechanism. The uncontrolled SO<sub>2</sub> emissions from biomass, No. 2 fuel oil and natural gas are very low, which renders any add-on control equipment as too costly. Further,

there is inherent SO<sub>2</sub> removal in the boiler/PM control system, based on current operating and emissions data, in the range of 85 to 99 percent.

The retrofit of add-on flue gas desulfurization equipment is not appropriate for the existing units nor the requested heat input increase of the NHPP facility. Each of the alternative SO<sub>2</sub> control systems would result in significant capital and operating costs for NHPP. The cogeneration boilers and control equipment NHPP proposes to utilize are already in place and have been in use at the cogeneration site. The three cogeneration boilers would need to be "retrofitted" with these systems, substantially increasing costs. The cost effectiveness of an add-on lime spray drying system is estimated to range from \$10,000 to nearly \$12,000 per ton of SO<sub>2</sub>/HF removed.

In addition, NHPP just received a BACT determination for SO<sub>2</sub> in February 2002. These existing BACT limits for SO<sub>2</sub> are proposed as BACT for the proposed heat input increase. Therefore, the following BACT standards are proposed based on the firing of low sulfur fuels.

- 24-hour SO<sub>2</sub> standard of 0.20 lb/MMBtu when firing biomass.
- 30-day rolling average standard of 0.10 lb/MMBtu when firing biomass.
- Annual average SO<sub>2</sub> standard of 0.06 lb/MMBtu based on a 12-month rolling average when firing biomass.
- 24-hour and 12-month rolling SO<sub>2</sub> standard of 0.05 lb/MMBtu when firing fuel oil.

In summary, the proposed BACT for the NHPP cogeneration boilers is the continued use of very low sulfur fuels, i.e., biomass, No. 2 fuel oil, and natural gas.

## **5.4 NITROGEN OXIDES**

### **5.4.1 EXISTING AND PROPOSED CONTROL TECHNOLOGY**

The existing cogeneration boilers at the NHPP cogeneration facility utilize selective non-catalytic reduction (SNCR) systems to reduce NO<sub>x</sub> emissions. SNCR is a system that injects urea into the boiler to reduce NO<sub>x</sub> emissions. In this process, urea is injected into the flue gas stream in the boiler and reacts with NO<sub>x</sub> to form nitrogen and water vapor. For the NHPP cogeneration boilers, urea is injected into each boiler at average and maximum rates of 25 gallons per hour (gph) and 65 gph, respectively.



The proposed BACT for NO<sub>x</sub> is the continued use of the existing SNCR system. The proposed BACT emission limit for NO<sub>x</sub> is 0.15 lb/MMBtu based on a 30-day rolling average for biomass, No. 2 fuel oil, and natural gas. For each boiler, this limit is equivalent to 499.3 TPY of NO<sub>x</sub>.

#### **5.4.2 BACT ANALYSIS**

Two control alternatives, SCR and SNCR, have been determined to be technically feasible NO<sub>x</sub> control systems for the cogeneration boilers. NHPP already utilizes SNCR to control NO<sub>x</sub> emissions. SCR systems, as well as increased NO<sub>x</sub> removal using SNCR, are discussed in the following sections.

##### **5.4.2.1 Previous BACT Determinations**

A review was performed of previous BACT determinations for similar biomass-fired industrial and electric utility boilers listed in the RACT/BACT/LAER Clearinghouse on EPA's web page. From this information, BACT determinations issued within the last 10 years (i.e., since 1992) were identified. A summary of these BACT determinations is presented in Appendix D, Table D-3. Note that one fluidized bed biomass boiler located in California (SAI Energy, Inc.) was not included in the table because of the distinct differences between NHPP's proposed spreader stoker boilers and a fluidized bed boiler.

Aside from one exception, previous BACT determinations for NO<sub>x</sub> have ranged from 0.14 to 0.46 lb/MMBtu. The one exception is a limit of 0.10 lb/MMBtu limit for Multitrade Limited Partnership in Virginia. The Multitrade limit was issued over 10 years ago. In comparison to the NHPP cogeneration facility, Multitrade Limited Partnership operates as a peaking plant that burns 100-percent wood. The NHPP facility burns a mixture of bagasse and wood, No. 2 fuel oil, and natural gas, and operates at a very high capacity factor. Since Multitrade operates as a peaking plant with limited hours of operation per year, and higher generated revenue, higher urea usage is technically and economically feasible for this facility (see further discussion below).

##### **5.4.2.2 Selective Catalytic Reduction**

###### ***Technical Feasibility***

SCR is an add-on technology in which ammonia is injected into the exhaust gas stream in the presence of a catalyst. The ammonia combines with NO<sub>x</sub> in the gas stream in a reduction reaction, forming nitrogen and water. For the reaction to proceed satisfactorily, the exhaust gas temperature

must be maintained between 450°F and 850°F. SCR systems are stated to achieve from 70 to 90 percent NO<sub>x</sub> reduction.

Although SCR is commercially available, this technology has never been applied to a biomass boiler. As shown in Table D-3, SCR has never been specified as BACT for a biomass-fired boiler. In a paper presented at the 2001 AWMA Annual Conference on Orlando, it was reported that there are now ten coal-fired plants in the U.S. that employ SCR. In addition, there were an estimated 40 additional plants with SCR units either under construction or in the procurement process (A. Johnson and C. Lockert, 2002). Weaknesses in these conventional SCR units were reported to include lag time of feedback NO<sub>x</sub> signal from the stack CEM, and system response to step changes in NO<sub>x</sub> concentrations. Other issues include air heater fouling, catalyst poisoning, stack opacity, and flyash contamination.

Technical difficulties associated with applying SCR include no operating experience on bagasse or wood fuels, and likely premature catalyst deactivation due to chemical poisoning of the catalyst due to the alkali content of the ash. The high moisture content of wood fuels, and particularly bagasse (approx. 50-percent moisture), could also be a concern for catalyst operation. High particulate loading prior to the mechanical collectors would also be a concern. This could lead to catalyst fouling and reduced NO<sub>x</sub> removal efficiency. These technical difficulties are evidenced by the fact that only one supplier of SCR systems was willing to provide a cost quote on a biomass-fired boiler (see Economic Analysis below).

In addition, the SCR catalyst operating temperature range is between 600°F and 900°F, within which the NO<sub>x</sub> reduction process takes place. The cogeneration boiler outlet temperature is approximately 400°F. Placement of the SCR can only be after the ESP because of possible chemical poisoning of the catalyst due to the alkali content of the ash and due to the reaction of the ash with gaseous components in the flue gas that blind the catalyst. As a result, a heat exchanger will be required, located downstream of the ESP and prior to the SCR system, to increase the ESP exit temperature from 400°F to 700°F.

In comparison, SNCR has been proven to operate satisfactorily on the existing cogeneration boilers and other boilers similar to NHPP while burning the same fuels.

### *Economic Analysis*

One complete year 2002 SCR vendor quote was obtained from Hamon Research-Cottrell for PBPC's proposed cogeneration boilers. As discussed in Section 5.3, NHPP's boilers are identical to PBPC's proposed boilers, and will burn the same type fuels. A copy of the cost quote is provided in Appendix E. Attempts were made to obtain SCR cost quotes from various other vendors resulting in either no response or rejection of our request due to technical feasibility issues. A summary of correspondences with SCR vendors is provided in Appendix E.

The cost analysis for SCR is presented in Table 5-3. The total estimated capital cost of SCR for one NHPP cogeneration boiler is \$4,200,000. The total annualized cost of applying SCR is estimated at \$4,200,000 per year.

Uncontrolled baseline NO<sub>x</sub> emissions are based on published factors for wood-fired boilers of 0.36 lb/MMBtu and for bagasse-fired boilers of 0.17 lb/MMBtu. Based on firing approximately 50 percent wood and 50 percent bagasse, the average emission rate is 0.26 lb/MMBtu. A capacity factor of 90 percent was assumed for both baseline and maximum future emissions, since it is not feasible for the NHPP boilers to operate at 100 percent capacity factor year-around.

For maximum controlled emissions, a controlled NO<sub>x</sub> emission rate of 0.08 lb/MMBtu was assumed. The previously discussed technical issues and lack of operating experience make the SCR removal efficiency of 90 percent quoted by the SCR vendor highly questionable. Based on an uncontrolled NO<sub>x</sub> emission rate of 0.26 lb/MMBtu from the PBPC boilers, a 90 percent reduction would equate to a controlled NO<sub>x</sub> emission rate of 0.026 lb/MMBtu. This is an extremely low level of NO<sub>x</sub> emissions, which has not been demonstrated in practice.

For comparison, a review of BACT determinations for NO<sub>x</sub> emissions from coal-fired boilers was performed. The results of this review are shown in Appendix B. As shown, the lowest BACT determination was also the most recent: Kansas Power & Light- Hawthorn Station. This determination was for SCR and resulted in a NO<sub>x</sub> emissions limit of 0.08 lb/MMBtu.

For the NHPP boilers, this represents a 70 percent reduction in uncontrolled NO<sub>x</sub> emissions. It is questionable as to whether a NO<sub>x</sub> reduction efficiency of greater than 70 percent can be achieved in practice on a biomass-fired boiler.

The resulting cost effectiveness of adding SCR with this level of control is estimated at \$7,800 per ton of NO<sub>x</sub> removed. The existing SNCR system, using urea as the reactant, is much less costly than SCR.

From the review of these previous BACT determinations, it is evident that NO<sub>x</sub> BACT determinations for biomass-fired boilers have been based solely on combustion controls alone, or combustion controls with SNCR. SCR has never been specified as BACT for biomass-fired boilers.

### ***Energy Impacts***

Energy penalties occur with SCR. As discussed previously, placement of the SCR can only be after the ESP because of possible chemical poisoning of the catalyst. As a result, a heat exchanger will be required to increase the exit ESP temperature from 400°F to 700°F. The resulting reheat requirement is approximately 100 MMBtu/hr with an annual operating cost of approximately \$2.6 million.

### ***Environmental Impacts***

SCR will require the construction and maintenance of storage vessels for ammonia for use in the reaction. Ammonia has potential health effects, and the construction of ammonia storage facilities triggers the application of a least three major standards: Clean Air Act (section 112), Occupational Safety and Health Administration (OSHA) 29 CFR 1910.1000, and OSHA 29 CFR 1910.119.

#### **5.4.2.3 Enhanced SNCR**

As discussed previously, the SNCR control efficiency for the Multitrade facility is stated as 50 percent, requiring a very high urea injection rate of up to 130 gal/hr of 50-percent urea solution. To achieve the proposed NO<sub>x</sub> BACT of 0.15 lb/MMBtu, the NHPP SNCR control efficiency is approximately 42 percent, based on EPA AP-42 uncontrolled NO<sub>x</sub> emission factors for bagasse and wood-fired boilers. For NHPP to achieve a more effective use of SNCR, increased urea injection will be required.

Boiler experience at Osceola Power (now Palm Beach Power Corp.) and Okeelanta Power (now NHPP) indicates that higher urea injection rates accelerate superheater tube failure, resulting in lost electric generation and substantial repair costs. For example, the existing boilers at NHPP have not experienced nearly the degree of superheater tube replacement as the Osceola Power boilers when

operating. The Osceola Power boiler urea usage rates ranged from an average of approximately 35 gal/hr to peaks of 70 gal/hr per boiler. The NHPP boilers use approximately 25 gph of urea.

The NHPP boilers are identical in size to the Osceola Power boilers, burn the same fuels, and are operated in the same manner. The only significant difference in the operations was the lower NO<sub>x</sub> emission limit for the Osceola Power boilers, requiring higher urea injection rates. The increased urea usage was about 40 percent higher for Osceola Power's boilers to meet the NO<sub>x</sub> emission limit of 0.12 lb/MMBtu, compared to NHPP's boilers, which have an emission limit of 0.15 lb/MMBtu. Although many factors can contribute to superheater tube failure, the only significant difference in operation between the Osceola Power and NHPP facilities was the amount of urea injection required due to the different NO<sub>x</sub> limits. As a result, it is concluded that the superheater tube failures are accelerated by the higher urea injection rates.

A cost analysis was performed to evaluate higher urea injection rates for NHPP. The costs to Osceola Power of the higher injection rates include the cost of urea, repair of the superheater tubes, and loss of revenue due to lost electric generation. A detailed analysis is presented in Table 5-4. This analysis is based on actual costs incurred for two boilers over the period of December 1996 through March 1997 and were prorated to an annual basis. As shown in Table 5-4, the total annual cost of higher urea injection is estimated to be \$3.8 million per year. The reduction in NO<sub>x</sub> emissions due to the higher injection is calculated based upon the difference between limits of 0.12 and 0.15 lb/MMBtu. This results in an emission reduction of 150 TPY of NO<sub>x</sub>. Thus, the incremental cost effectiveness of the higher urea injection is over \$25,000/ton of NO<sub>x</sub> removed.

Higher urea usage would also result in increased emissions of urea's decomposition products, which include ammonia slip and carbon dioxide. High ammonia slip can lead to ammonium bisulfate formation, which can cause fouling of the air preheater and ESP. High ammonia slip can also combine with hydrogen chloride in the flue gas to form ammonium chloride. The ammonium chloride can form a detached plume of high opacity.

As described previously, Multitrade is operated as a peaking unit. As such, the typical operating factor is about 20 percent. Multitrade's limited hours of operation decreases the frequency of superheater failures compared to what would result if NHPP were required to meet a NO<sub>x</sub> emission limit of 0.10-0.12 lb/MMBtu on a continuous basis. In summary, the more effective use of SNCR as

demonstrated by Multitrade in Virginia is not appropriate for NHPP due to the associated technical problems associated with high urea injection rates over long-term operation, and associated economic impact.

In addition, the Multitrade boilers have a heat input rate of approximately 374 MMBtu/hr, approximately half the size of the NHPP boilers, which will have a maximum heat input rate of 760 MMBtu/hr. These differences in fuel use, boiler size, and operation methods demonstrate that the Multitrade facility is significantly different than the NHPP facility. As a result, the review of previous BACT determinations supports the proposed BACT limit of 0.15 lb/MMBtu NO<sub>x</sub> (30-day rolling average).

#### 5.4.3 SUMMARY

Aside from one exception, previous BACT determinations for NO<sub>x</sub> from biomass-fired boilers have ranged from 0.14 to 0.46 lb/MMBtu. This includes the most recent determination for Grayling Generating Station, which resulted in a BACT limit of 0.15 lb/MMBtu. Previous NO<sub>x</sub> BACT determinations for biomass-fired boilers have been based solely on combustion controls alone, or combustion controls with SNCR.

For NHPP, SNCR can achieve the maximum amount of emission reduction economically feasible, is technically feasible, and is demonstrated in practice. SCR should be rejected as BACT for the NHPP cogeneration boilers for the following reasons:

- SCR has never been applied to a biomass-fired boiler;
- SCR has never been specified as BACT for a biomass-fired boiler;
- SCR catalyst operating temperature range is between 600°F and 900°F within which the NO<sub>x</sub> reduction process takes place. The cogeneration boilers ESP outlet temperature is approximately 400°F. The implementation of SCR would require flue gas heating to 700°F through the use of a heat exchanger with a heat input requirement of approximately 100 MMBtu/hr;
- NO<sub>x</sub> removal efficiency obtained with an SCR system applied to a wood/bagasse boiler is uncertain due to lack of operating experience;
- Capital cost of SCR is estimated at \$4.2 million per cogeneration boiler, with annual operating costs of \$4.2 million/year;
- Cost effectiveness of SCR is estimated at over \$7,800 per ton of NO<sub>x</sub> removed.

- Due to technical difficulties, uncertainties, and the unproven nature of SCR as applied to biomass-fired boilers, only one SCR vendor would provide a quote.
- Catalyst life guaranteed for only 10,000 hours (Hamon Research-Cottrell). SCR vendors expressed concerns of catalyst poisoning from biomass-fired boilers. Short catalyst life results in high annual operation costs.

Therefore, the proposed NO<sub>x</sub> BACT limit for NHPP is based on the existing SNCR system and operating experience at the cogeneration facility: 30-day rolling NO<sub>x</sub> standard of 0.15 lb/MMBtu when firing any authorized fuel. This is consistent with the 30-day averaging period specified in NSPS Subpart Da and represents a much lower limit than the NSPS (0.60 lb/MMBtu for solid fuel and 0.20 lb/MMBtu for gas and oil firing). Use of the SNCR system and good combustion practices constitute BACT for the proposed NHPP cogeneration boilers.

## **5.5 CARBON MONOXIDE AND VOLATILE ORGANIC COMPOUNDS**

### **5.5.1 EXISTING AND PROPOSED CONTROL TECHNOLOGY**

CO and VOC emissions are currently controlled through proper furnace design and good combustion practices including control of combustion air and temperature, distribution of fuel on the combustion grate, and better controls over the furnace loads and transient conditions.

The proposed BACT for CO and VOC is based on the existing control techniques: proper furnace design and good combustion practices. The proposed CO emission limits for the cogeneration boilers are: 0.50 lb/MMBtu as a 30-day rolling average; and, 0.35 lb/MMBtu as a 12-month rolling average for biomass firing. The proposed VOC emission limit for the cogeneration boilers is 0.06 lb/MMBtu for biomass firing.

### **5.5.2 BACT ANALYSIS**

The proposed CO BACT limits of 0.50 lb/MMBtu as a 30-day rolling average and 0.35 lb/MMBtu as a 12-month rolling average were recently issued as BACT for NHPP on February 1, 2002 (PSD-FL-196M). Since NHPP has demonstrated compliance with these emission limits, and there are no physical changes to the cogeneration boilers as part of this project, the existing emission limits and controls of proper furnace design and good combustion practices constitute BACT for CO and VOC.

As part of the BACT analysis, a review was performed of previous CO and VOC BACT determinations for industrial and electric utility boilers listed in the RACT/BACT/LAER Clearinghouse on EPA's web page. A summary of the BACT determinations for biomass-fired industrial and electric utility boilers from this review are presented in Appendix D, Tables D-4 and D-5. The CO emission limits for biomass-fired industrial and electric utility boilers range from 0.03 to 6.5 lb/MMBtu. The VOC emission limits for biomass-fired industrial and electric utility boilers range from 0.02 to 2.62 lb/MMBtu. This rather large range of emissions is due to differences in boiler design and operation, as well as fuel variability. From the review of previous determinations, it is evident that CO and VOC BACT determinations for biomass-fired industrial and electric utility boilers have been good combustion practices and boiler design.

The NHPP proposed emission limits are within the range of previous determinations. The cogeneration boilers will minimize CO and VOC through proper furnace design and good combustion practices, including: control of combustion air and combustion temperature; controlled distribution of fuel on the combustion gate; and better controls over the furnace loads and transient conditions. This level of control is consistent with previous determinations.

Emission data during startup are variable and are not available in the form of guarantees from the vendor. For this reason cold startup emissions are based on CEM data from the cogeneration facility. The six cold startup events exhibiting the highest 1-hr and 8-hr CO emissions are shown in Appendix E. The New Hope Power Partnership has identical ABB/CE cogeneration units and combusts similar biomass fuel. Cold startups are expected to occur infrequently. However, experience with wood/bagasse boilers indicates that these events do occur and good combustion practice will be employed to minimize emissions during these events. The highest 1-hour average CEM CO levels from New Hope Power Partnership occurred during a cold startup with a maximum level of 6.5 lb/MMBtu. This was a one-time occurrence, and many other cold startups have resulted in much lower CO emissions, as shown in Appendix E.

Cold startup is defined in Permit No. 0990332-014-AC/PSD-FL-196M as a startup after the boiler has been shutdown for 24 hours or more. Shutdown is defined as the cessation of the operation of a boiler for any purpose after steam generation drops below 150,000 lb/hr. The current permit allows for CO emission data exclusions during periods of startup, shutdown, or documented malfunctions. No more than six hourly CO emission rate values can be excluded in a 24-hour period due to a cold



startup, and for each cogeneration boiler, no more than 183 hourly emission values can be excluded during any calendar quarter. NHPP proposes the current allowable CO emission data exclusions during periods of cold startup, shutdown and malfunction.

## **5.6 FLUORIDES**

### **5.6.1 EXISTING AND PROPOSED CONTROL TECHNOLOGY**

The existing and proposed control technology for fluorides for the NHPP cogeneration boilers is the use of biomass fuels with a mechanical collector and an ESP for PM control. The fuels burned in the NHPP cogeneration boilers may contain trace levels of F. Stack testing of both wood and bagasse fuels have indicated very low, although detectable, levels of F in the stack gases of the boilers. Fuel oil can also contain trace levels of F. F contained in the fuels is converted to hydrogen fluoride (HF) in the furnace. HF is an acid gas, and will behave similar to SO<sub>2</sub> in the furnace and downstream control equipment. Thus, as discussed for SO<sub>2</sub>, HF will be adsorbed onto the alkaline ash particles existing in the flue gas. The ash is then removed in the downstream mechanical collectors and electrostatic precipitator, resulting in inherent F control.

### **5.6.2 BACT ANALYSIS**

#### **5.6.2.1 Control Technology Feasibility**

Since HF is an acid gas, and will behave similar to SO<sub>2</sub> in the furnace and in downstream control equipment, FGD technologies are technically feasible fluoride control alternatives. FGD technologies for NHPP were discussed in Section 5.2.

#### **5.6.2.2 Economic Analysis**

To evaluate the cost effectiveness of FGD applied to the proposed NHPP, cost estimates for SO<sub>2</sub> control presented in Section 5.2 were utilized. Fluoride removal was assumed to be 90 percent with the FGD system. Based on these cost estimates, the resulting capital costs range from \$9,900,000 to greater than \$12,000,000. Annualized costs ranged from \$1,600,000 to \$2,000,000 per year.

The cost effectiveness is based on the combined removal of SO<sub>2</sub> and HF. Based on an uncontrolled emission rate of 181.9 TPY SO<sub>2</sub> and HF, the total SO<sub>2</sub>/HF removed is 163.7 TPY (90-percent removal). The resulting cost effectiveness ranges from \$10,000 to nearly \$12,000/ton of SO<sub>2</sub>/HF removed. See Tables 5-1 and 5-2 for detailed calculations.

### 5.6.2.3 Previous BACT Determinations

As part of the BACT analysis, a review was performed of previous F BACT determinations for biomass-fired industrial electric utility boilers listed in the RACT/BACT/LAER Clearinghouse on EPA's web page. A summary of the only BACT determination for biomass-fired industrial and electric utility boilers from this review is presented in Appendix D, Table D-6. The sole F emission limit for a biomass-fired electric utility boiler is 1.7E-03 lb/MMBtu. By comparison, measured F emissions for the NHPP boilers have been less than 7.0E-04 lb/MMBtu for both wood and bagasse (refer to Tables C-1 through C-3 for stack test data). These represent extremely low levels of F emissions. The same control techniques identified to control SO<sub>2</sub> emissions at NHPP also control F emissions.

### 5.6.3 SUMMARY

In conclusion, add-on fluoride removal equipment is not appropriate for the NHPP facility. HF control systems would result in significant capital and operating costs for NHPP. In addition to low fluoride fuel content, HF removal is inherent to the process of combustion biomass. The fly ash produced during firing is alkaline in nature and acts as a dry scrubber, absorbing HF from the exhaust stream.

It is also emphasized that the HF emission factor for NHPP (7.0E-04 lb/MMBtu) is based on the expected maximum emission rate, based on NHPP test data. The maximum expected emission rate is specified in the event that the FDEP sets an emission limit for HF. If an emission limit is set, NHPP must demonstrate compliance with the limit each and every time that compliance testing is required. Biomass fuels display variability, as witnessed from the NHPP test data. However, based on the test data shown in Appendix F, average HF levels at NHPP have actually been 3.1E-04 lb/MMBtu for wood firing; and 2.9E-04 for bagasse firing. Therefore, actual annual HF emissions for NHPP are expected to average about 3.0E-04 lb/MMBtu, resulting in actual annual emissions of less than 3.0 TPY, which is less than the PSD significant emission rate of 3.0 TPY.

The proposed control technology for fluorides for the NHPP cogeneration boilers is the use of biomass fuels with a mechanical collector and an ESP for PM control. Fluoride contained in the fuels is converted to HF in the furnace. HF is an acid gas, and will behave similar to SO<sub>2</sub> in the furnace and downstream control equipment. Thus, as discussed for SO<sub>2</sub>, HF will be absorbed onto

the alkaline ash particles existing in the flue gas. The ash is then removed in the downstream mechanical collectors and electrostatic precipitators, resulting in inherent F control.

## **5.7 SULFURIC ACID MIST**

### **5.7.1 EXISTING AND PROPOSED CONTROL TECHNOLOGY**

The proposed BACT for SAM emissions is the use of low sulfur fuels. Emissions of SAM are related to SO<sub>2</sub> emissions. SO<sub>2</sub> and SAM emissions will be controlled by burning low sulfur biomass fuel and low sulfur content fuel oil. Biomass fuel, low sulfur fuel oil, and natural gas are inherently low in sulfur, and therefore produce low SAM emissions.

### **5.7.2 BACT ANALYSIS**

Since emissions of SAM are related to SO<sub>2</sub> emissions, BACT for SO<sub>2</sub> also represents BACT for SAM. The maximum potential emissions for SAM emissions are 0.0036 lb/MMBtu (annual average basis) for biomass firing, 0.003 lb/MMBtu for No. 2 fuel oil, and 0.000348 lb/MMBtu for natural gas. This is equivalent to a maximum of 36.0 TPY of SAM emissions for all three cogeneration boilers combined.

Previous BACT determinations for SAM emissions from biomass-fired industrial and electric utility boilers are presented in Appendix D, Table D-7. Combustion control is the only control method employed in these boiler BACT determinations for SAM. Emission limits of 0.001 and 0.003 lb/MMBtu without any add-on control constitutes BACT for these previous determinations. Although there is no limit proposed for SAM, the estimated NHPP cogeneration boiler maximum emissions for SAM are consistent with these determinations.

## **5.8 LEAD**

### **5.8.1 PROPOSED CONTROL TECHNOLOGY**

The proposed BACT for Pb emissions is control by the existing mechanical dust collectors and ESPs. Pb emissions are emitted in the solid phase from the NHPP cogeneration boilers. Pb emissions are a function of the Pb content of the biomass fuels. Maximum Pb emissions from the three cogeneration boilers combined will be 1.5 TPY. The maximum emissions are due to biomass firing.

### 5.8.2 BACT ANALYSIS

As part of the BACT analysis, a review of previous Pb BACT determinations for biomass-fired industrial and electric utility boilers listed in the RACT/BACT/LAER Clearinghouse on EPA's web page was performed. A summary of the BACT determinations for biomass-fired industrial and electric utility boilers from this review is presented in Appendix D, Table D-8. The Pb emission limits for these determinations were in the range of 0.000038 lb/MMBtu to 0.0004 lb/MMBtu. From this review, it is evident that the Pb BACT determinations are typically based on cyclones, ESPs, and clean fuels.

The proposed emission limit for the NHPP cogeneration boilers is 1.5E-04 lb/MMBtu. This limit is based on actual stack test data (refer to Tables C-1 through C-3). This limit represents an upper limit based on the stack testing. Actual average emissions are expected to be lower than this limit. It would not be economical to install any add-on control equipment to decrease Pb emissions any further than what is achievable through burning clean fuels (i.e., biomass, natural gas, and No. 2 fuel oil with a maximum sulfur content of 0.05 percent). Therefore, clean fuels are proposed as BACT for Pb emissions.

It is also emphasized that the proposed Pb emission rate for NHPP (1.5E-04 lb/MMBtu) is based on the expected maximum emission rate, based on NHPP test data. The maximum expected emission rate is specified in the event that the FDEP sets emission limits for Pb. If an emission limit is set, NHPP must demonstrate compliance with the limit each and every time that compliance testing is required. Biomass fuels display variability, as witnessed from the NHPP test data. However, based on the test data from NHPP (see Appendix C), average Pb levels at NHPP have been 1.9E-05 lb/MMBtu for combination bagasse/wood burning; 3.6E-05 for wood firing; and 1.7E-05 for bagasse firing. Therefore, actual annual Pb emissions for NHPP are expected to average approximately 2.6E-05 lb/MMBtu. This would result in annual Pb emissions of less than 0.3 TPY for the NHPP facility, which is less than the PSD significant emission rate of 0.6 TPY.

Table 5-1. Cost Effectiveness of Lime Spray Drying FGD for SO<sub>2</sub> Control, NHPP Cogeneration Boiler (One Unit)

Vendor: Wheelabrator APC		
Cost Items	Cost Factors <sup>a</sup>	Cost per Cogen Boiler (\$)
<b>DIRECT CAPITAL COSTS (DCC):</b>		
<u>Purchased Equipment Cost (PEC)</u>		
Absorber + lime storage/delivery + Fabric Filter	Vendor quote <sup>b</sup>	3,960,000
Freight	5% of PEC	198,000
Taxes	Florida sales tax, 6%	237,600
<b>Total PEC:</b>		<b>4,395,600</b>
<u>Direct Installation</u>		
	Vendor quote <sup>b</sup>	2,900,000
Items Excluded From Vendor Quote:		
Ductwork	100 ft @ \$106/ft	10,000
FGD waste conveyors	Estimate	50,000
Foundations	12% of PEC	527,472
Water/air/electrical supply & piping	10% of PEC	439,560
Thermal insulation and lagging	Estimate	50,000
ID Fan	Estimate	100,000
<b>Total Direct Installation:</b>		<b>4,077,032</b>
<b>Total DCC (PEC + Direct Installation):</b>		<b>8,472,632</b>
<b>INDIRECT CAPITAL COSTS (ICC):</b>		
Engineering	2% of PEC (for excluded items)	87,912
Construction and field expenses	2% of PEC (for excluded items)	87,912
Contractor Fees	2% of PEC (for excluded items)	87,912
Startup	1% of PEC	43,956
Performance test	1% of PEC	43,956
Contingencies	25% of PEC (for retrofit application)	1,098,900
<b>Total ICC:</b>		<b>1,450,548</b>
<b>TOTAL CAPITAL INVESTMENT (TCI):</b>	<b>DCC + ICC</b>	<b>9,923,180</b>
<b>DIRECT OPERATING COSTS (DOC):</b>		
(1) Operating Labor		
Operator	0.5 hr/shift, \$16/hr, 8760 hrs/yr	8,760
Supervisor	15% of operator cost	1,314
(2) Maintenance		
Operator	0.5 hr/shift, \$16/hr, 8760 hrs/yr	8,760
Supervisor	15% of operator cost	1,314
(3) Operating Materials		
Reagent	48 lbs/hr, \$65/ton	13,666
(4) Electricity	700 KW, \$0.04/KW-hr	245,280
(5) Dry Waste Disposal	103 lbs/hour, \$30/ton	13,534
<b>Total DOC:</b>		<b>292,628</b>
<b>INDIRECT OPERATING COSTS (IOC):</b>		
Overhead	60% of oper. labor & maintenance	12,089
Property Taxes	1% of total capital investment	99,232
Insurance	1% of total capital investment	99,232
Administration	2% of total capital investment	198,464
<b>Total IOC:</b>		<b>409,016</b>
<b>CAPITAL RECOVERY COSTS (CRC):</b>	<b>CRF of 0.0944 times TCI (20 yrs @ 7%)</b>	<b>936,748</b>
<b>ANNUALIZED COSTS (AC):</b>	<b>DOC + IOC + CRC</b>	<b>1,638,392</b>
<b>BASELINE SO<sub>2</sub> AND HF EMISSIONS (TPY) :</b>	<b>0.06 (lb SO<sub>2</sub>)/MMBtu, 0.0007 (lb HF)/MMBtu;</b> <b>760 MMBtu/hr; 90% capacity factor</b>	<b>181.9</b>
<b>MAXIMUM SO<sub>2</sub> AND HF EMISSIONS (TPY) :</b>	<b>90% reduction</b>	<b>18.2</b>
<b>REDUCTION IN SO<sub>2</sub> AND HF EMISSIONS (TPY):</b>		<b>163.7</b>
<b>COST EFFECTIVENESS:</b>	<b>\$ per ton of SO<sub>2</sub> Removed</b>	<b>10,011</b>

## Footnotes:

<sup>a</sup> Unless otherwise specified, factors and cost estimates reflect OAQPS Cost Manual, Section 5, Fifth edition.

<sup>b</sup> 2002 Wheelabrator APC cost quote, 2 units \$7,920,000 material costs and \$5,800,000 installation cost.

Includes: Absorber, lime storage/delivery, fabric filter, ductwork from SDA to fabric filter, structural support, process piping and valves, and system control instrumentation.

Does not include excluded items shown below.

Table 5-2. Cost Effectiveness of Lime Spray Drying FGD for SO<sub>2</sub> Control, NHPP Cogeneration Boiler (One Unit)

Vendor: Hamon Research-Cottrell		Cost per Cogen Boiler (\$)
Cost Items	Cost Factors <sup>a</sup>	
<b>DIRECT CAPITAL COSTS (DCC):</b>		
<u>Purchased Equipment Cost (PEC)</u>		
Absorber + lime storage/delivery + Fabric Filter	Vendor quote <sup>b</sup>	5,375,000
Freight	5% of PEC	268,750
Taxes	Florida sales tax, 6%	322,500
<b>Total PEC:</b>		<b>5,966,250</b>
<u>Direct Installation</u>		
	Vendor quote <sup>b</sup>	3,200,000
Items Excluded From Vendor Quote:		
Ductwork	100 ft @ \$106/ft	10,000
FGD waste conveyors	Estimate	50,000
Foundations	12% of PEC	715,950
Water/air/electrical supply & piping	10% of PEC	596,625
Thermal insulation and lagging	Estimate	50,000
ID Fan	Estimate	100,000
<b>Total Direct Installation:</b>		<b>4,722,575</b>
<b>Total DCC (PEC + Direct Installation):</b>		<b>10,688,825</b>
<b>INDIRECT CAPITAL COSTS (ICC):</b>		
Engineering	2% of PEC (for excluded items)	119,325
Construction and field expenses	2% of PEC (for excluded items)	119,325
Contractor Fees	2% of PEC (for excluded items)	119,325
Startup	1% of PEC	47,226
Performance test	1% of PEC	47,226
Contingencies	25% of PEC (for retrofit installation)	1,180,644
<b>Total DCC:</b>		<b>1,633,070</b>
<b>TOTAL CAPITAL INVESTMENT (TCI):</b>	<b>DCC + ICC</b>	<b>12,321,895</b>
<b>DIRECT OPERATING COSTS (DOC):</b>		
(1) Operating Labor		
Operator	0.5 hr/shift, \$16/hr, 8760 hrs/yr	8,760
Supervisor	15% of operator cost	1,314
(2) Maintenance		
Operator	0.5 hr/shift, \$16/hr, 8760 hrs/yr	8,760
Supervisor	15% of operator cost	1,314
(3) Operating Marterials		
Reagent	48 lbs/hr, \$65/ton	13,666
(4) Electriciy	700 KW, \$0.04/KW-hr	245,280
(5) Dry Waste Disposal	103 lbs/hour, \$30/ton	13,534
<b>Total DOC:</b>		<b>292,628</b>
<b>INDIRECT OPERATING COSTS (IOC):</b>		
Overhead	60% of oper. labor & maintenance	12,089
Property Taxes	1% of total capital investment	123,219
Insurance	1% of total capital investment	123,219
Administration	2% of total capital investment	246,438
<b>Total IOC:</b>		<b>504,965</b>
<b>CAPITAL RECOVERY COSTS (CRC):</b>	<b>CRF of 0.0944 times TCI (20 yrs @ 7%)</b>	<b>1,163,187</b>
<b>ANNUALIZED COSTS (AC):</b>	<b>DOC + IOC + CRC</b>	<b>1,960,779</b>
<b>BASELINE SO<sub>2</sub> AND HF EMISSIONS (TPY) :</b>	<b>0.06 (lb SO<sub>2</sub>)/MMBtu, 0.0007 (lb HF)/MMBtu;</b>	<b>181.9</b>
<b>MAXIMUM SO<sub>2</sub> AND HF EMISSIONS (TPY) :</b>	<b>760 MMBtu/hr; 8,760 hr/yr</b>	<b>18.2</b>
<b>REDUCTION IN SO<sub>2</sub> AND HF EMISSIONS (TPY):</b>	<b>90% reduction</b>	<b>163.7</b>
<b>COST EFFECTIVENESS:</b>	<b>\$ per ton of SO<sub>2</sub> Removed</b>	<b>11,980</b>

## Footnotes:

<sup>a</sup> Unless otherwise specified, factors and cost estimates reflect OAQPS Cost Manual, Section 5, Fifth edition.<sup>b</sup> 2002 Hamon Research-Cottrell cost quote, 2 units \$10,750,000 material costs and \$6,400,000 installation cost.

Table 5-3. Cost Effectiveness of SCR, NHPP Cogeneration Boilers

Cost Items	Cost Factors <sup>a</sup>	Cost per Cogen Boiler (\$)
<b>DIRECT CAPITAL COSTS (DCC):</b>		
SCR Basic Process	Vendor quote <sup>b</sup>	1,700,000
Ammonia Storage System	Vendor quote <sup>c</sup> , 30,000 gallon storage tank + valves	160,864
Auxiliary Equipment (Reheat)	10% of SCR equipment cost	170,000
Emissions Monitoring	15% of SCR equipment cost	170,000
Foundation and Structure Support	8% of SCR equipment cost	136,000
Control Room and Enclosures	4% of SCR equipment cost, engineering estimate	68,000
Transition Ducts to and from SCR	4% of SCR equipment cost, engineering estimate	68,000
Wiring and Conduit	2% of SCR equipment cost, engineering estimate	34,000
Insulation	2% of SCR equipment cost, engineering estimate	34,000
Motor Control and Motor Starters	4% SCR of equipment cost, engineering estimate	68,000
SCR Bypass Duct	\$127 per MMBtu/hr	96,520
Taxes	Florida sales tax, 6%	102,000
<b>Total DCC:</b>		<b>2,807,384</b>
<b>INDIRECT CAPITAL COSTS (ICC):</b>		
General Facilities	5% of DCC	140,369
Engineering Fees	10% of DCC	280,738
Performance test	1% of DCC	28,074
Process Contingencies	5% of DCC	140,369
<b>Total ICC:</b>		<b>589,551</b>
Project Contingencies	25% of DCC + ICC (for retrofit installation)	849,234
<b>TOTAL CAPITAL INVESTMENT (TCI):</b>	<b>DCC + ICC + Project Contingencies</b>	<b>4,246,168</b>
<b>DIRECT OPERATING COSTS (DOC):</b>		
(1) Operating Labor		
Operator	24 hours/week, \$16/hr, 52 weeks/yr	\$19,968
Supervisor	15% of operator cost	2,995
(2) Maintenance	Engineering estimate, 5% of catalyst replacement cost	44,737
(3) SCR Energy Requirement	80 kW/hr for SCR @ \$0.04/kW-hr	28,032
(5) Ammonia Cost	\$580 per ton NH <sub>3</sub> , 19% Aqueous. NH <sub>3</sub> = NO <sub>x</sub> * 17/46 * 1.1 (110% of theoretical NH <sub>3</sub> )	183,660
(6) Catalyst Replacement and disposal <sup>d</sup>	10,000 hours; est. 1.14 years	894,737 <sup>d</sup>
(7) Reheat Energy Requirements	100 MMBtu/hr, 8760 hr/yr, \$3/MMBtu	2,636,332
<b>Total DOC:</b>		<b>3,810,461</b>
<b>CAPITAL RECOVERY COSTS (CRC):</b>	CRF of 0.0944 times TCI (20 yrs @ 7%)	400,838
<b>ANNUALIZED COSTS (AC):</b>	<b>DOC + CRC</b>	<b>4,211,300</b>
<b>BASELINE NO<sub>x</sub> EMISSIONS (TPY) :</b>	0.26 lb/MMBtu; 760 MMBtu/hr; 90% capacity factor	778.9 <sup>e</sup>
<b>MAXIMUM NO<sub>x</sub> EMISSIONS (TPY) :</b>	0.08 lb/MMBtu; 760 MMBtu/hr; 90% capacity factor	239.7
<b>REDUCTION IN NO<sub>x</sub> EMISSIONS (TPY):</b>		539.3
<b>COST EFFECTIVENESS:</b>	<b>\$ per ton of NO<sub>x</sub> Removed</b>	<b>7,809</b>

## Footnotes:

<sup>a</sup> Unless otherwise specified, factors and cost estimates reflect OAQPS Cost Manual, Section 4, Sixth edition.

<sup>b</sup> 2002 Hamon Research-Cottrell cost quote, 3 units = \$4,250,000, includes SCR, ammonia flow control unit, and ammonia injection system.  
1 cogeneration unit = \$1,700,000

<sup>c</sup> \$457 per ton of ammonia used per year (based on vendor quote).

<sup>d</sup> SCR catalyst replacement estimated to be 60% (based on experience with Englehard SCR systems) of the initial capital cost, with replacement every 1.14 years.

<sup>e</sup> Based on EPA AP-42, Fifth Edition, Volume 1, Bagasse and Wood Fired Boiler Emission Factors (50% Bagasse/50% Wood)

Table 5-4. Cost Effectiveness of Using Increased Urea Injection in Osceola Power's Cogeneration Boilers

Cost Item	Cost Factors	Estimated Cost (\$)
DIRECT OPERATING COSTS (DOC):		
(1) Maintenance (a)	\$600,000 maintenance cost over 4 months, prorated to annual basis	1,800,000
(2) Chemicals and Materials (b) Urea based chemical	10 gal/hr/boiler @ \$1.00/gal	175,200
(3) Lost Generation (c)	37,800 Mw-hrs lost over 4 months @ \$16.40/Mw-hr, prorated to annual basis	1,859,760
Total DOC:	(1) + (2) + (3)	3,834,960
CONTROLLED NO <sub>x</sub> EMISSIONS (TPY) @ 0.12 lb/MMBtu; two boilers		477
CONTROLLED NO <sub>x</sub> EMISSIONS (TPY) @ 0.15 lb/MMBtu; two boilers		627
TOTAL NO <sub>x</sub> REMOVED (TPY):		150
COST EFFECTIVENESS:	\$ per ton of NO <sub>x</sub> Removed	25,566

## Notes:

- (a) Based on actual contract labor and replacement boiler tubers incurred during 4 month period, projected to annual basis, for Osceola Power L. P.
- (b) Represents increased urea usage compared to NHPP (Okeelanta Power ). Based on actual urea usage for 4 month period.
- (c) Based on actual lost generation incurred during 4 month period, projected to annual basis,



## 6.0 AIR QUALITY IMPACT ANALYSIS

### 6.1 GENERAL APPROACH

The general modeling approach followed the EPA and the FDEP modeling guidelines for determining compliance with AAQS and PSD increments. For all criteria pollutants that will be emitted in excess of the PSD significant emission rate due to a proposed project, a significant impact analysis is performed to determine whether the emission and/or stack configuration changes due to the project alone will result in predicted impacts that are in excess of the EPA significant impact levels at any location beyond the plant's restricted boundaries.

Generally, if the facility undergoing the modification is within 200 kilometers of a PSD Class I area, then a significant impact analysis is also performed to evaluate the impact due to the project alone at the PSD Class I area. Because the ENP is a PSD Class I area that is located within 200 km of the proposed project, the maximum predicted impacts at the ENP are compared to the EPA's proposed significant impact levels for PSD Class I areas. These recommended levels have never been promulgated as rules but are the currently accepted criteria to determine whether a proposed project will result in a significant impact on a PSD Class I area.

If the project-only impacts are above the significant impact levels in the vicinity of the facility, then two additional and more detailed air modeling analyses are required. The first analysis demonstrates compliance with federal and Florida ambient air quality standards (AAQS), and the second analysis demonstrates compliance with allowable PSD Class II increments.

If the project-only impacts at the PSD Class I area are above the proposed the EPA PSD Class I significant impact levels, then an analysis is performed to demonstrate compliance with allowable PSD Class I impacts at the PSD Class I area. In addition, the proposed project's maximum emission increases are evaluated at the PSD Class I area to support the AQRV analysis, including evaluations of regional haze degradation and nitrogen and sulfur deposition.

Generally, when using five years of meteorological data for the analysis, the highest annual and the HSH short-term concentrations are compared to the applicable AAQS and allowable PSD increments. [Note that for determining compliance with the 24-hour AAQS for particulate matter

only, the sixth highest predicted concentration in 5 years (i.e., H6H), instead of the HSH, is used to compare to the applicable 24-hour AAQS.]

The HSH concentration is calculated for a receptor field by:

1. Eliminating the highest concentration predicted at each receptor,
2. Identifying the second-highest concentration at each receptor, and
3. Selecting the highest concentration among these second-highest concentrations.

The HSH approach is consistent with air quality standards and allowable PSD increments, which permit a short-term average concentration to be exceeded once per year at each receptor.

To develop the maximum short-term concentrations for the proposed project, the modeling approach was divided into screening and refined phases to reduce the computation time required to perform the modeling analysis. For this study, the only difference between the two modeling phases is the density of the receptor grid spacing employed when predicting concentrations. Concentrations are predicted for the screening phase using a coarse receptor grid and a 5-year meteorological data record.

If the original screening analysis indicates that the highest concentrations are occurring in selected area(s) of the grid, and if the area's total coverage is too vast to directly apply a refined receptor grid, then additional screening grid(s) will be used over that area. The additional screening grid(s) will employ a greater receptor density than the original screening grid.

Refinements of the maximum predicted concentrations are typically performed for the receptors of the screening receptor grid at which the highest and/or HSH concentrations occurred over the 5-year period. Generally, if the maximum concentrations from other years in the screening analysis are within 10 percent of the overall maximum concentration, then those other concentrations are refined as well. Typically, if the highest and HSH concentrations are in different locations, concentrations in both areas are refined.

A more detailed description of the model, along with the emission inventory, meteorological data, and screening receptor grids, is presented in the following sections.

## **6.2 SIGNIFICANT IMPACT ANALYSIS**

The FDEP policies stipulate that the highest annual average and highest short-term (i.e., 24 hours or less) concentrations are to be compared to the applicable significant impact levels both in the vicinity of the project and at the PSD Class I area. Based on the screening modeling analysis results in the vicinity of the project, additional modeling refinements are performed, if necessary, to obtain the maximum concentration with a receptor grid spacing of 100 meters (m) or less.

In this analysis, one source, representing the three NHPP cogeneration boilers and an area source representing the particulate fugitive emissions, was modeled to represent the proposed future case at NHPP. Current actual emissions and future maximum emissions were modeled to determine if the proposed project would have a significant impact on off-site receptors. The significant impact analysis is used to determine pollutants for which more detailed modeling analyses are required. This analysis is also used to determine the geographic area within which other background sources will be considered for inclusion in the modeling analysis. This area is referred to as "the screening area". The screening area extends 50 km beyond the significant impact distance, from the NHPP location.

## **6.3 AAQS AND PSD CLASS II ANALYSES**

For each pollutant for which a significant impact is predicted in the vicinity of the project, AAQS and PSD Class II analyses are required. The AAQS analysis is a cumulative source analysis that evaluates whether the post-project concentrations from all sources will comply with the AAQS. All sources include the post-project source configuration at the project site, the impacts from other sources within the significant impact area, and a background concentration to account for sources not included explicitly in the modeling analysis. Large sources (greater than 1,000 TPY emissions) outside of the significant impact area were also included in the modeling analysis.

The PSD Class II analysis is a cumulative source analysis that evaluates whether the post-project PSD increment concentrations due to all increment-affecting sources will comply with the allowable PSD Class II increments. All sources include the post-project PSD increment-affecting sources at the project site, plus the impacts from all other PSD increment-affecting sources located within the significant impact area.

#### **6.4 PSD CLASS I ANALYSIS**

For each pollutant for which a significant impact is predicted at the PSD Class I area, a PSD Class I analysis is required. The PSD Class I analysis is a cumulative source analysis that evaluates whether the post-project PSD increment concentrations for all increment-affecting sources located within the air shed domain of the PSD Class I area will comply with the allowable PSD Class I increments. All sources include the post-project PSD increment-affecting sources at the project site, plus the impacts from all PSD increment-affecting sources located within the air shed domain of the Class I area. Based on previous PSD modeling studies performed for South Florida, the domain for the ENP extends to the north of the ENP to include Martin, Lee, and Hendry counties.

#### **6.5 MODEL SELECTION**

The Industrial Source Complex Short-term (ISCST3, Version 00101) dispersion model (EPA, 2000) was used to evaluate the pollutant impacts due to the proposed project in areas within 50-km of the NHPP facility. This model is maintained by the EPA on its internet web site, Support Center for Regulatory Air Models (SCRAM), within the Technical Transfer Network (TTN). A listing of ISCST3 model features is presented in Table 6-1. The ISCST3 model is designed to calculate hourly concentrations based on hourly meteorological data (i.e., wind direction, wind speed, atmospheric stability, ambient temperature, and mixing heights). The ISCST3 model is applicable to sources located in either flat or rolling terrain where terrain heights do not exceed stack heights. These areas are referred to as simple terrain. The model can also be applied in areas where the terrain exceeds the stack heights. These areas are referred to as complex terrain.

In this analysis, the EPA regulatory default options were used to predict all maximum impacts. The ISCST3 model can be executed in the rural or urban land use mode. The mode affects stability dispersion coefficients, wind speed profiles, and mixing heights. Land use can be characterized based on a scheme recommended by the EPA (Auer, 1978). If more than 50 percent land use within a 3-km radius around a project site is classified as industrial, commercial, or high-density residential, then the urban option should be selected. Otherwise, the rural option is appropriate. Based on the land use within a 3-km radius of the NHPP plant site (see Attachment NH-FI-C1), the rural dispersion coefficients were used in the modeling analysis. Also, since the terrain around the facility is flat to gently rolling, the simple terrain feature of the model was selected. The ISCST3 model was used to provide maximum concentrations for the annual and 24-, 8-, 3-, and 1-hour averaging times.

For predicting maximum impacts at the ENP PSD Class I area, the California Puff (CALPUFF) modeling system was used. CALPUFF, Version 5.5 (EPA, 2001), is a Lagrangian puff model that is recommended by the FDEP, in coordination with the Federal Land Manager (FLM) for the ENP, for predicting pollutant impacts at PSD Class I areas that are beyond 50 km from a project site. A listing of CALPUFF model features is presented in Table 6-2.

## **6.6 METEOROLOGICAL DATA**

Meteorological data used in the ISCST3 model to determine air quality impacts consisted of a concurrent 5-year period of hourly surface weather observations and twice-daily upper air soundings from the National Weather Service (NWS) office located at the Palm Beach International Airport (PBI). The 5-year period of meteorological data was from 1987 through 1991. The NWS office at PBI is located approximately 64 km east of the site and is the closest primary weather station to the study area considered to have meteorological data representative of the project site. The PBI station meteorological data have been approved by the FDEP and used for numerous air modeling studies submitted as part of air construction permit application for sources located in Palm Beach County.

Meteorological data used with the CALPUFF model consist of a CALMET-developed wind field covering all of south Florida. A detailed description of the CALMET wind field is provided in Appendix G.

## **6.7 EMISSION INVENTORY**

### **6.7.1 SIGNIFICANT IMPACT ANALYSIS**

Stack parameters, emissions, and area source parameters used in the significant impact analysis for NHPP are shown in Tables 6-3, 6-4, and 6-5, respectively. The physical and operational stack parameters for each cogeneration boiler stack are summarized in Table 6-3. The current actual and future maximum emission rates for all three cogeneration boilers combined are summarized in Table 6-4. The emission rate, location, and dimensions of the source representing the fugitive dust emission sources are presented in Table 6-5. Those sources were modeled as a single area source. The future and current actual emissions for each pollutant were modeled. These tables are based on emissions and stack parameters presented in Section 2.0. The current actual short-term emissions are based on three boilers operating at 715 MMBtu/hr and stack test data, continuous emission monitoring (CEM) data, and current permit limits. The current actual annual emissions are based on 2000 and 2001 AOR data.

The current and future CO short-term emissions are based on normal operation since the cold-startup operation and emissions for the boilers are not changing as part of this project. The increase in heat input rate will only affect the normal operation emission rates.

NHPP cogeneration Boiler B stack was used as the modeling origin. This modeling origin has been used in previous PSD applications for NHPP.

Based on the results of the significant impact analysis, the proposed project was predicted to be significant for SO<sub>2</sub> only (refer to Section 6.11.1). It was further determined that the project was significant out to 11 km from the facility.

### **6.7.2 AAQS AND PSD CLASS II ANALYSES**

A listing of background SO<sub>2</sub> sources used in the AAQS and PSD Class II modeling analyses and their locations relative to NHPP is provided in Table 6-6. All facilities were evaluated using the North Carolina screening technique. Based on this technique, facilities whose annual (i.e., TPY) emissions are less than the threshold quantity, Q, are eliminated from the modeling analysis. Q is equal to  $20 \times (D-SIA)$ , where D is the distance in km from the facility to NHPP and SIA is the distance of the proposed project's SO<sub>2</sub> significant impact area (11 km). The SO<sub>2</sub> emitting facilities that were not eliminated in the screening analysis are available for inclusion in the AAQS and/or PSD Class II analyses. Large sources (greater than 1,000 TPY emissions) located outside the screening area were included in the modeling analysis.

Detailed SO<sub>2</sub> background source data that were used for the AAQS and/or PSD Class II analyses are presented in Appendix H. Non-NHPP SO<sub>2</sub> PSD sources were obtained from the FDEP and were supplemented with current and historical information available within Golder.

### **6.7.3 PSD CLASS I ANALYSIS**

A listing of background SO<sub>2</sub> sources that were used in the PSD Class I analysis and their locations relative to the ENP PSD Class I area is provided in Table 6-7. All PSD sources located within 200 km of the ENP were included in the PSD Class I modeling analysis. Detailed SO<sub>2</sub> background source data that were used for the PSD Class I analysis are presented in Appendix H.

## **6.8 RECEPTOR LOCATIONS**

### **6.8.1 SITE VICINITY**

To determine the SO<sub>2</sub> significant impact area for the proposed project, concentrations were predicted using polar receptor grids. The receptor grids were comprised of 36 radials, spaced at 10-degree intervals, that began at the plant property and extended out to 10 km. Additional receptors were located out to 35 km to identify the significant impact distance for the 3-hour and 24-hour SO<sub>2</sub> concentrations. An additional 393 Cartesian grid receptors, spaced at 100 m, were used to predict impacts along the fence line areas. A summary of the fence line receptors are presented in Table 6-8.

At the off-property areas between the fence line and the innermost ring distance of 4.0 km, 79 discrete polar receptors were used, spaced at 10-degree intervals and at distances of 4, 5, 6, 7, 8, 9, and 10 km from the origin. All receptor locations are relative to the cogeneration Boiler B (center stack) stack location, an origin which has been used for historical modeling analyses for NHPP.

Based on the results of the significant impact analysis, a maximum receptor distance of 11 km, based on the 24-hour and 3-hour emissions, was used for SO<sub>2</sub> for the screening grids for the AAQS and PSD Class II analyses. The receptor locations out to 11 km from the facility, along with the plant property boundary and the modeling origin, are shown in Figure 6-1.

Because the proposed project was determined to be insignificant for PM<sub>10</sub>, CO, and NO<sub>x</sub>, further modeling was not performed for these pollutants (refer to Section 6.11.1).

### **6.8.2 CLASS I AREA**

Maximum SO<sub>2</sub>, NO<sub>x</sub>, SAM, PM<sub>10</sub>, F, CO, and Pb concentrations were predicted at the ENP with the CALPUFF model using 126 discrete receptors located along the border of the ENP PSD Class I area. Impacts for the proposed project only were compared to both the proposed EPA Class I significance levels, the regional haze degradation criteria of 5 percent, and the nitrogen and sulfur deposition thresholds. The SO<sub>2</sub>, NO<sub>x</sub>, SAM, PM<sub>10</sub>, F, CO, and Pb impacts were used to assess the proposed project's impacts on the ENP AQRVs. A listing of Class I receptors used in the modeling analysis is provided in Table 6-9.

## **6.9 BACKGROUND CONCENTRATIONS**

To estimate total air quality concentrations in the site vicinity, a background concentration must be added to the AAQS modeling results. The background concentration is considered to be the air quality concentration contributed by sources not included in the modeling evaluation.

The derivation of the background concentration for the modeling analysis was presented in Section 4.0. Based on this analysis, the SO<sub>2</sub> background concentrations were determined to be 5, 13, and 47 µg/m<sup>3</sup> for the annual, 24-hour, and 3-hour averaging periods, respectively. These background levels were added to model-predicted concentrations to estimate total air quality levels for comparison to AAQS.

## **6.10 BUILDING DOWNWASH EFFECTS**

All significant building structures within NHPP's existing plant area were determined by a site plot plan. The plot plan of the proposed project was presented in the permit application (Attachment NH-FI-C2). All building structures were processed in the EPA Building Profile Input Program (BPIP, Version 95086) program to determine direction-specific building heights and widths for each 10-degree azimuth direction for each source that was included in the modeling analysis. A listing of dimensions for each structure is presented in Table 6-10. A plot plan of the facility, showing the major structures and stacks in relation to the modeling origin, is provided in Figure 6-2.

## **6.11 MODEL RESULTS**

### **6.11.1 SIGNIFICANT IMPACT ANALYSIS**

A summary of the predicted maximum SO<sub>2</sub>, PM<sub>10</sub>, NO<sub>2</sub>, and CO concentrations for the proposed project-only for the significant impact analysis is presented in Table 6-11. The modeling results indicated that maximum predicted concentrations due to the proposed project are above the significant impact levels for only SO<sub>2</sub>. It was further determined that the significant impact area for the proposed project's SO<sub>2</sub> emissions extends out approximately 11 km from NHPP. As a result, additional modeling analyses were performed for SO<sub>2</sub> to address compliance with AAQS and PSD increments.

### **6.11.2 AAQS ANALYSIS**

A summary of the maximum annual, HSH 24-hour, and HSH 3-hour average SO<sub>2</sub> concentrations predicted for all sources from the screening analysis is presented in Table 6-12. Based on the



screening analysis results, modeling refinements were performed. The results of the refined modeling analysis are presented in Table 6-13.

The maximum predicted annual, HSH 24-hour, and HSH 3-hour SO<sub>2</sub> concentrations are 25.1, 145, and 517 µg/m<sup>3</sup>, respectively. These concentrations include ambient non-modeled annual, 24-hour, and 3-hour concentrations of 5, 13, and 47 µg/m<sup>3</sup>, respectively. The maximum predicted annual, HSH 24-hour, and HSH 3-hour average SO<sub>2</sub> concentrations are below the Florida AAQS of 60, 260, and 1,300 µg/m<sup>3</sup>, respectively.

#### **6.11.3 PSD CLASS II ANALYSIS**

Summaries of the maximum SO<sub>2</sub> PSD increment consumption predicted for all sources for the screening analysis is presented in Table 6-14. Based on the screening analysis results, modeling refinements were performed. The results of the refined modeling analysis are presented in Table 6-15.

The maximum predicted annual, HSH 24-hour, and HSH 3-hour SO<sub>2</sub> increment consumption concentrations of 5.6, 62, and 218 µg/m<sup>3</sup>, respectively, are less than the allowable PSD Class II increments of 20, 91, and 512 µg/m<sup>3</sup>, respectively.

#### **6.11.4 PSD CLASS I ANALYSIS**

The maximum SO<sub>2</sub>, PM<sub>10</sub>, and NO<sub>2</sub> concentrations predicted for the proposed project only at the ENP PSD Class I area are compared with the EPA's proposed PSD Class I significance levels in Table 6-16. All maximum predicted impacts were below the significant impact levels except for SO<sub>2</sub>. The maximum 24-hour and 3-hour SO<sub>2</sub> impacts were 0.45 and 1.1 µg/m<sup>3</sup>, respectively, which are above the proposed Class I significant impact levels of 0.2 and 1.0 µg/m<sup>3</sup>, respectively. Therefore, a full PSD Class I incremental analysis was performed for SO<sub>2</sub>.

The maximum 24-hour and 3-hour SO<sub>2</sub> PSD Class I increment consumption, due to all increment affecting sources, is summarized in Table 6-17. The maximum predicted HSH 24-hour and HSH 3-hour SO<sub>2</sub> increment consumption concentrations of 3.99 and 12.2 µg/m<sup>3</sup>, respectively, are below the allowable PSD Class I increments of 5 and 25 µg/m<sup>3</sup>, respectively.

### 6.11.5 FLUORIDE IMPACTS

There are no AAQS or PSD increments for fluorides. However, fluoride impacts are required for the additional impact analysis. Maximum fluoride concentrations due to the proposed project in the site vicinity are presented in Table 6-18, for the annual, 24-, 8-, 3-, and 1-hour averaging times. In the site vicinity, the maximum predicted annual, 24-, 8-, 3-, and 1-hour fluoride concentrations are 0.0037, 0.017, 0.030, 0.046, and 0.09  $\mu\text{g}/\text{m}^3$ , respectively.

Fluoride impacts are also required for the AQRV analysis for the PSD Class I area. This analysis and fluoride impacts at the ENP are presented in Section 7.0.

### 6.11.6 SAM IMPACTS

There are no AAQS or PSD increments for SAM. However, SAM impacts are required for the additional impact analysis. Maximum SAM concentrations due to the proposed project in the site vicinity are presented in Table 6-19, for the annual, 24-, 8-, 3-, and 1-hour averaging times. In the site vicinity, the maximum predicted annual, 24-, 8-, 3-, and 1-hour SAM concentrations are 0.015, 0.57, 0.97, 1.50, and 2.92  $\mu\text{g}/\text{m}^3$ , respectively.

SAM impacts are also required for the AQRV analysis for the PSD Class I area. This analysis and SAM impacts at the ENP are presented in Section 7.0.

### 6.11.7 LEAD IMPACTS

There are no significant impact levels or PSD increments for Pb. Therefore, further AAQS and PSD increment modeling is not required. However, Pb impacts are required for the additional impact analysis. Maximum Pb concentrations due to the proposed project in the site vicinity are presented in Table 6-20, for the annual, 24-, 8-, 3-, and 1-hour averaging times. In the site vicinity, the maximum predicted annual, 24-, 8-, 3-, and 1-hour Pb concentrations are 0.0011, 0.007, 0.012, 0.018, and 0.035  $\mu\text{g}/\text{m}^3$ , respectively. The 3-month average predicted Pb concentration of 0.0044  $\mu\text{g}/\text{m}^3$  (refer to Table 3-4) is well below the AAQS of 15  $\mu\text{g}/\text{m}^3$ .

Pb impacts are also required for the AQRV analysis for the PSD Class I area. This analysis and Pb impacts at the ENP are presented in Section 7.0.

Table 6-1. Major Features of the ISCST3 Model

ISCST3 Model Features	
•	Polar or Cartesian coordinate systems for receptor locations
•	Rural or one of three urban options which affect wind speed profile exponent, dispersion rates, and mixing height calculations
•	Plume rise due to momentum and buoyancy as a function of downwind distance for stack emissions (Briggs, 1969, 1971, 1972, and 1975; Bowers, et al., 1979).
•	Procedures suggested by Huber and Snyder (1976); Huber (1977); and Schulman and Scire (1980) for evaluating building wake effects
•	Procedures suggested by Briggs (1974) for evaluating stack-tip downwash
•	Separation of multiple emission sources
•	Consideration of the effects of gravitational settling and dry deposition on ambient particulate concentrations
•	Capability of simulating point, line, volume, area, and open pit sources
•	Capability to calculate dry and wet deposition, including both gaseous and particulate precipitation scavenging for wet deposition
•	Variation of wind speed with height (wind speed-profile exponent law)
•	Concentration estimates for 1 hour to annual average times
•	Terrain-adjustment procedures for elevated terrain including a terrain truncation algorithm for ISCST3, a built-in algorithm for predicting concentrations in complex terrain
•	Consideration of time-dependent exponential decay of pollutants
•	The method of Pasquill (1976) to account for buoyancy-induced dispersion
•	A regulatory default option to set various model options and parameters to the EPA recommended values (see text for regulatory options used)
•	Procedure for calm-wind processing including setting wind speeds less than 1 m/s to 1 m/s.

Note: ISCST3 = Industrial Source Complex Short-Term.

References:

- Bowers, J.F., J.R. Bjorklund and C.S. Cheney. 1979. Industrial Source Complex (ISC) Dispersion Model User's Guide. Volume I, EPA-450/4-79-030; Volume II, EPA-450/4-79-031. U.S. Environmental Protection Agency, Research Triangle Park, North Carolina 27711.
- Briggs, G.A. 1969. Plume Rise, USAEC Critical Review Series, TID-25075. National Technical Information Service, Springfield, Virginia 22161.
- Briggs, G.A. 1972. Discussion on Chimney Plumes in Neutral and Stable Surroundings. *Atmos. Environ.*, Q, 507-510.
- Briggs, G.A. 1974. Diffusion Estimation for Small Emissions. In: ERL, ARL USAEC Report ATDL-106. U.S. Atomic Energy Commission, Oak Ridge, Tennessee.
- Briggs, G.A. 1975. Plume Rise Predictions. In Lectures on Air Pollution and Environmental Impact Analysis. American Meteorological Society, Boston, Massachusetts.
- Briggs, G.A. 1979. Some Recent Analyses of Plume Rise Observations. In: Proceedings of the Second International Clean Air Congress. Academic Press, New York.
- Huber, A.H. 1977. Incorporating Building/Terrain Wake Effects on Stack Effluents. Preprint Volume for the Joint Conference on Applications of Air Pollution Meteorology, American Meteorological Society, Boston, Massachusetts.
- Huber, A.H. and W.H. Snyder. 1976. Building Wake Effects on Short Stack Effluents. Preprint Volume for the Third Symposium on Atmospheric Diffusion and Air Quality, American Meteorological Society, Boston, Massachusetts.
- Pasquill, F. 1976. Atmospheric Dispersion Parameters in Gaussian Plume Modeling - Part II. Possible Requirements for Change in the Turner Workbook Values. EPA-600/4-76-030b, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina 27711.
- Schulman, L.L. and J.S. Scire. 1980. Buoyant Line and Point Source (BLP) Dispersion Model User's Guide. Document P-7304B, Environmental Research and Technology, Inc., Concord, MA.

Table 6-2. Major Features of the CALPUFF Model, Version 5.5

## CALPUFF Model Features

- Source types: Point, line (including buoyancy effects), volume, area (buoyant, non-buoyant)
- Non-steady-state emissions and meteorological conditions (time-dependent source and emission data; gridded 3-dimensional wind and temperature fields; spatially-variable fields of mixing heights, friction velocity, precipitation, Monin-Obukhov length; vertically and horizontally-varying turbulence and dispersion rates; time-dependent source and emission data for point, area, and volume sources; temporal or wind-dependent scaling factors for emission rates)
- Efficient sampling function [integrated puff formulation; elongated puff (slug) formation]
- Dispersion coefficient options (Pasquill-Gifford (PG) values for rural areas; McElroy-Pooler values (MP) for urban areas; CTDM values for neutral/stable; direct measurements or estimated values)
- Vertical wind shear (puff splitting; differential advection and dispersion)
- Plume rise (buoyant and momentum rise; stack-tip effects; building downwash effects; partial plume penetration above mixing layer)
- Building downwash effects (Huber-Snyder method; Schulman-Scire method)
- Complex terrain effects (steering effects in CALMET wind field; puff height adjustments using ISC model method or plume path coefficient; enhanced vertical dispersion used in CTDMPLUS)
- Subgrid scale complex terrain (CTSG option) (CTDM flow module; dividing streamline as in CTDMPLUS)
- Dry deposition (gases and particles; options for diurnal cycle per pollutant, space and time variations with a resistance model, or none)
- Overwater and coastal interaction effects (overwater boundary layer parameters; abrupt change in meteorological conditions, plume dispersion at coastal boundary; fumigation; option to use Thermal Internal Boundary Layers (TIBL) into coastal grid cells)
- Chemical transformation options (Pseudo-first-order chemical mechanisms for SO<sub>2</sub>, SO<sub>4</sub>, HNO<sub>3</sub>, and NO<sub>3</sub>; Pseudo-first-order chemical mechanisms for SO<sub>2</sub>, SO<sub>4</sub>, NO, NO<sub>2</sub>, HNO<sub>3</sub>, and NO<sub>3</sub> (RIVAD/ARM3 method); user-specified diurnal cycles of transformation rates; no chemical conversions)
- Wet removal (scavenging coefficient approach; removal rate as a function of precipitation intensity and type)
- Graphical user interface
- Interface utilities (scan ISCST3 and AUSPLUME meteorological data files for problems; translate ISCST3 and AUSPLUME input files to CALPUFF input files)

Note: CALPUFF = California Puff Model.

Source: EPA, 2001.

Table 6-3. Stack Parameters<sup>a</sup> for New Hope Power Partnership Boilers

ISCST ID	Heat Input Rate (MMBtu/hr)	Stack/Vent Release Height		Stack/Vent Diameter		Gas Flow Rate (acfm)	Gas Exit Temperature		Velocity	
		ft	m	ft	m		°F	K	ft/sec	m/sec
<b><u>Current</u></b>										
COGENC	715	199	60.66	10	3.05	300,000	352	450.93	63.6	19.39
<b><u>Future</u></b>										
COGENF	760	199	60.66	10	3.05	319,000	352	450.93	67.7	20.63

<sup>a</sup> Representative of all 3 boiler stacks.

Table 6-4. Cogeneration Boiler Emission Rates for New Hope Power Partnership--Total all Three Boilers

Pollutant	Current Total Heat Input Rate <sup>a</sup> (MMBtu/hr)	CURRENT ACTUAL EMISSIONS					FUTURE POTENTIAL EMISSIONS			
		Emission Factor (lb/MMBtu)	Short-Term Emissions		Annual Average Emissions <sup>f</sup>		Short-Term Emissions <sup>g</sup>		Annual Average Emissions <sup>h</sup>	
			lb/hr	g/sec	TPY	g/sec	lb/hr	g/sec	TPY	g/sec
Particulate (PM <sub>10</sub> )--24-hr Average	2,145	0.018 <sup>b</sup>	38.61	4.86	--	--	68.4	8.62	--	--
--Annual Average	--	--	--	--	108.02	3.11	--	--	299.6	8.62
Sulfur Dioxide--3-hr Average	2,145	0.17 <sup>c</sup>	364.65	45.95	--	--	684.0	86.18	--	--
--24-hr Average	2,145	0.10 <sup>c</sup>	214.50	27.03	--	--	456.0	57.46	--	--
--Annual Average	--	--	--	--	191.90	5.52	--	--	599.2	17.24
Nitrogen Oxides--24-hr Average	2,145	0.15 <sup>c</sup>	321.75	40.54	--	--	456.0	57.46	--	--
--Annual Average	--	--	--	--	756.60	21.76	--	--	1,498.0	43.09
Carbon Monoxide--1-hr Average	2,145	1.0 <sup>c</sup>	2,145.0	270.3	--	--	2,280.0	287.3	--	--
--8-hr Average	2,145	1.0 <sup>c</sup>	2,145.0	270.3	--	--	2,280.0	287.3	--	--
--Annual Average	--	--	--	--	1,335.4	38.42	--	--	3,495.2	100.55
Sulfuric Acid Mist--24-hr Average	2,145	0.012 <sup>d</sup>	25.74	3.24	--	--	41.04	5.17	--	--
--Annual Average	--	--	--	--	15.71	0.45	--	--	35.95	1.034
Fluorides--24-hr Average	2,145	5.3E-04 <sup>b</sup>	1.1369	0.1432	--	--	1.60	0.20	--	--
--Annual Average	--	--	--	--	2.163	0.062	--	--	6.99	0.201
Lead--24-hr Average	2,145	7.5E-05 <sup>b</sup>	0.1607	0.020	--	--	0.34	0.043	--	--
--Annual Average	--	--	--	--	0.098	0.0028	--	--	1.50	0.043

<sup>a</sup> Three boilers at the current heat input rate of 715 MMBtu/hr each.

<sup>b</sup> Based on 2001 stack test data.

<sup>c</sup> Based on CEM data.

<sup>d</sup> Based on current permit limit (30-day rolling average).

<sup>e</sup> Based on 6% of SO<sub>2</sub> emissions (Permit No. 0990332-014-AC).

<sup>f</sup> Actual annual emissions from Appendix A, Table A-1.

<sup>g</sup> Future potential emissions from Table 2-2.

<sup>h</sup> Future potential emissions from Table 2-3.

Table 6-5. Fugitive Dust Emissions and Area Source Modeling Parameters for Biomass and Ash Handling System, New Hope Power Partnership

ISCST3 Source ID	PM <sub>10</sub> Annual Emission Rate		Southwest Corner Location		Height (m)	Length		Area Source Size (m <sup>2</sup> )	Area Source Emission Rate (g/m <sup>2</sup> -s)
	TPY	g/s	X (m)	Y (m)		X dimension (m)	Y Dimension (m)		
MATHAND	3.496 <sup>a</sup>	0.101	110	-12	6.1	171	137	23,420	0.0000043

<sup>a</sup> Refer to Table 2-4 for derivation.

Table 6-6. Summary of SO<sub>2</sub> Facilities Considered for Inclusion in the AAQS and PSD Class II Air Modeling Analyses, New Hope Power Partnership013752044 4/4.4.1 NHPP/Table 6-6.xls/Class II Screen  
8/29/02

AIRS Number	Facility	County	UTM Coordinates		Relative to Palm Beach Power <sup>a</sup>				Maximum	Q <sub>1</sub>	Include in Modeling Analysis?
			East (km)	North (km)	X (km)	Y (km)	Distance (km)	Direction (deg)	SO <sub>2</sub> Emissions (TPY)	Emission Threshold <sup>b</sup> (Dist - SIA) x 20	
0990005	Okeelanta Corp.	Palm Beach	525.0	2937.4	0.1	-2.7	2.7	178	39	SIA	YES
0990086	Glades Correctional Institute	Palm Beach	523.4	2955.2	-1.5	15.1	15.2	354	98	83.5	YES
0990594	El Paso Belle Glade Generating Station	Palm Beach	533.5	2954.1	8.6	14.0	16.4	32	69	108.6	NO
0990026	Sugar Cane Growers	Palm Beach	534.9	2953.3	10.0	13.2	16.6	37	2,555	111.2	YES
0510001	Everglades Sugar	Hendry	509.6	2954.2	-15.3	14.1	20.8	313	1,216	196.1	YES
0510003	U.S. Sugar Clewiston	Hendry	506.1	2956.9	-18.8	16.8	25.2	312	7,806	284.3	YES
0990016	Atlantic Sugar	Palm Beach	532.9	2945.2	28.0	5.1	28.5	80	954	349.2	YES
0990349	South Florida WMD--Pump Stn. G-310/S-6	Palm Beach	554.2	2940.5	29.3	0.4	29.3	89	5	366.1	NO
0990061	U.S. Sugar -Bryant	Palm Beach	537.8	2969.2	12.9	29.1	31.8	24	2,698	415.9	YES
	Palm Beach Power Corp. (Osceola Power)	Palm Beach	544.4	2967.4	19.5	27.3	33.5	0	451	451.0	NO
0990019	Osceola Farms	Palm Beach	544.2	2968.0	19.3	27.9	33.9	0	1,467	458.5	YES
0510015	Southern Gardens Citrus	Hendry	487.6	2957.6	-37.3	17.5	41.2	295	409	604.0	NO
0990021	Pratt & Whitney (United Technologies)	Palm Beach	562.0	2960.0	37.1	19.9	42.1	62	504	622.0	NO
0850102	Bechtel IndianTown	Martin	545.6	2991.5	20.7	51.4	55.4	22	2,629	888.2	YES
0850001	FPL - Martin	Martin	543.1	2992.9	18.2	52.8	55.8	19	22,982	897.0	YES
0990234	Palm Beach Resource Recovery <sup>c</sup>	Palm Beach	585.8	2960.2	60.9	20.1	64.1	72	1,533	1062.6	YES
0990350	South Florida WMD--Pump Stn. S-9	Broward	555.9	2882.2	31.0	-57.9	65.7	152	2	1093.2	NO
0112534	Enron/Deerfield Beach Energy Center	Broward	583.1	2907.9	58.2	-32.2	66.5	119	166	1170.3	NO
0112545	El Paso Broward Energy Center	Broward	583.3	2908.0	58.4	-32.1	66.6	119	87	1112.8	NO
0110120	North Broward Resource Recovery	Broward	583.6	2907.6	58.7	-32.5	67.1	119	896	1121.9	NO
0990045	Lake Worth Utilities <sup>c</sup>	Palm Beach	592.8	2943.7	67.9	3.6	68.0	87	7,415	1139.9	YES
0990568	Lake Worth Generating	Palm Beach	592.8	2943.7	67.9	3.6	68.0	87	54	1139.9	NO
0112515	Enron/Pompano Energy Center	Broward	583.7	2905.5	58.8	-34.6	68.2	120	166	1144.5	NO
0990042	FPL -Riviera Beach <sup>c</sup>	Palm Beach	594.2	2960.6	69.3	20.5	72.3	74	73,475	1225.4	YES
0112119	South Broward Resource Recovery <sup>c</sup>	Broward	579.6	2883.3	54.7	-56.8	78.9	136	1,318	1357.1	YES
0110037	FPL -Lauderdale <sup>c</sup>	Broward	580.1	2883.3	55.2	-56.8	79.2	136	47,858	1364.1	YES
1110103	CPV Cana, LTD.	St. Lucie	550.9	3018.1	26.0	78.0	82.2	18	76	1424.4	NO
0110036	FPL -Port Everglades <sup>c</sup>	Broward	587.4	2885.3	62.5	-54.8	83.1	131	170,215	1442.4	YES
0850021	Stuart Contracting	Martin	575.2	3006.8	50.3	66.7	83.5	37	100	1450.8	NO
0250020	Tamac <sup>c</sup>	Dade	562.9	2861.7	38.0	-78.4	87.1	154	2,792	1522.5	YES
0250348	Dade Co. Resource Recovery	Dade	564.3	2857.4	39.4	-82.7	91.6	155	857	1612.1	NO
0710019	Lee County Resource Recovery	Lee	424.2	2945.7	-100.7	5.6	100.9	273	163	1797.1	NO
0710000	FPL - Fort Myers <sup>c</sup>	Lee	422.1	2952.9	-102.8	12.8	103.6	277	22,702	1851.9	YES
1110003	Fort Pierce Utilities <sup>c</sup>	St. Lucie	566.8	3036.3	41.9	96.2	104.9	24	1,497	1878.6	YES
0550018	TECO-Phillips <sup>c</sup>	Highlands	464.3	3035.4	-60.6	95.3	112.9	328	4,053	2038.7	YES
0550004	TECO-Sebring/Dinner Lake <sup>c</sup>	Highlands	456.8	3042.5	-68.1	102.4	123.0	326	1,313	2239.5	YES
0610029	Vero Beach Power <sup>c</sup>	St. Lucie	567.1	3056.5	42.2	116.4	123.8	20	10,274	2256.3	YES

Note: deg = degrees  
 km = kilometers  
 SIA = significant impact area  
 TPY = tons per year

<sup>a</sup> New Hope Power Partnership's East and North Coordinates (km) are: 524.9 and 2940.1, respectively.

<sup>b</sup> Based on North Carolina Screening Technique for annual average basis. "Dist" is the distance the facility is located from the project.

"SIA" is the significant impact area. The project's 24-hour, 3-hour, and annual SO<sub>2</sub> concentrations are predicted to be significant out to 11 km from the project.

<sup>c</sup> Large source with annual emissions greater than 1,000 TPY located beyond the screening area (61 km) that were included in the inventory.



Table 6-7. Summary of SO<sub>2</sub> Facilities Included in the PSD Class I Air Modeling Analysis. New Hope Power Partnership

AIRS Number	Facility	County	UTM Coordinates		Relative to Everglades National Park			
			East (km)	North (km)	x (km)	y (km)	Distance <sup>a</sup> (km)	Direction (deg)
0250348	Dade Co. Resource Recovery	Dade	564.3	2857.4	14.3	8.8	16.8	58
0250020	Tarmac	Dade	562.9	2861.7	12.9	13.1	18.4	45
0112119	South Broward Resource Recovery	Broward	579.6	2883.3	29.6	34.7	45.6	40
0110037	FPL -Lauderdale	Broward	580.1	2883.3	30.1	34.7	45.9	41
0112515	Enron/Pompano Energy Center	Broward	583.7	2905.5	33.7	56.9	66.1	31
0110120	North Broward Resource Recovery	Broward	583.6	2907.6	33.6	59.0	67.9	30
0112534	Enron/Deerfield Beach Energy Center	Broward	583.1	2907.9	33.1	59.3	67.9	29
0112545	El Paso Broward Energy Center	Broward	583.3	2908.0	33.3	59.4	68.1	29
0710019	Lee County Resource Recovery	Lee	424.0	2946.0	-30.0	82.8	88.1 <sup>b</sup>	340
0990005	Okeelanta Corp.	Palm Beach	525.0	2937.4	-25.0	88.8	92.3	344
0710000	FPL - Fort Myers	Lee	422.1	2952.9	-31.9	89.7	95.2 <sup>b</sup>	340
0990332	New Hope Power Partnership (Okeelanta)	Palm Beach	524.9	2940.1	-25.1	91.5	94.9	345
0990016	Atlantic Sugar	Palm Beach	552.9	2945.2	2.9	96.6	96.6	2
0990568	Lake Worth Utilities	Palm Beach	592.8	2943.7	42.8	95.1	104.3	24
0990568	Lake Worth Generating	Palm Beach	592.8	2943.7	42.8	95.1	104.3	24
0990026	Sugar Cane Growers Coop.	Palm Beach	534.9	2953.3	-15.1	104.7	105.8	352
0990594	El Paso Belle Glade Generating Station	Palm Beach	533.5	2954.1	-16.5	105.5	106.8	351
0510003	U.S. Sugar Clewiston	Hendry	506.1	2956.9	-43.9	108.3	116.9	338
0990234	Palm Beach Resource Recovery	Palm Beach	585.8	2960.2	35.8	111.6	117.2	18
	Palm Beach Power Corp.	Palm Beach	544.4	2967.4	-5.6	118.8	118.9	357
0990019	Osceola Farms	Palm Beach	544.2	2968.0	-5.8	119.4	119.5	357
0990061	U.S. Sugar -Bryant	Palm Beach	537.8	2969.2	-12.2	120.6	121.2	354
0510015	Southern Gardens Citrus	Hendry	487.6	2957.6	-62.4	109.0	125.6	330
0990021	Pratt & Whitney	Palm Beach	559.2	2978.3	9.2	129.7	130.0	4
0850102	Bechtel Indiantown	Martin	545.6	2991.5	-4.4	142.9	143.0	358
0850001	FPL -Martin	Martin	543.1	2992.9	-6.9	144.3	144.5	357

<sup>a</sup> Distance from the northeastern corner of the Everglades National Park, UTM East and North coordinates (km) of  
<sup>b</sup> Distance from the northwestern corner of the Everglades National Park, UTM East and North coordinates (km) of

550.0 and 2848.6, respectively, unless noted.  
 454.0 and 2863.2, respectively.

Table 6-8. New Hope Power Partnership (NHPP) Property Boundary Receptors<sup>a</sup> Used In the Modeling Analysis

Coordinates <sup>b</sup>		Coordinates <sup>b</sup>		Coordinates <sup>b</sup>		Coordinates <sup>b</sup>		Coordinates <sup>b</sup>	
X	Y	X	Y	X	Y	X	Y	X	Y
(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)
-9699.6	444.2	-9509.5	3738.7	-6259.5	3791.6	-2959.5	3791.6	340.5	3791.6
-9693.9	544.0	-9459.5	3791.6	-6159.5	3791.6	-2859.5	3791.6	440.5	3791.6
-9688.1	643.9	-9359.5	3791.6	-6059.5	3791.6	-2759.5	3791.6	540.5	3791.6
-9682.3	743.7	-9259.5	3791.6	-5959.5	3791.6	-2659.5	3791.6	640.5	3791.6
-9676.6	843.5	-9159.5	3791.6	-5859.5	3791.6	-2559.5	3791.6	740.5	3791.6
-9670.8	943.4	-9059.5	3791.6	-5759.5	3791.6	-2459.5	3791.6	840.5	3791.6
-9665.1	1043.2	-8959.5	3791.6	-5659.5	3791.6	-2359.5	3791.6	940.5	3791.6
-9659.3	1143.0	-8859.5	3791.6	-5559.5	3791.6	-2259.5	3791.6	1040.5	3791.6
-9653.5	1242.9	-8759.5	3791.6	-5459.5	3791.6	-2159.5	3791.6	1140.5	3791.6
-9647.8	1342.7	-8659.5	3791.6	-5359.5	3791.6	-2059.5	3791.6	1240.5	3791.6
-9642.0	1442.5	-8559.5	3791.6	-5259.5	3791.6	-1959.5	3791.6	1340.5	3791.6
-9636.3	1542.4	-8459.5	3791.6	-5159.5	3791.6	-1859.5	3791.6	1440.5	3791.6
-9630.5	1642.2	-8359.5	3791.6	-5059.5	3791.6	-1759.5	3791.6	1540.5	3791.6
-9624.7	1742.0	-8259.5	3791.6	-4959.5	3791.6	-1659.5	3791.6	1640.5	3791.6
-9619.0	1841.9	-8159.5	3791.6	-4859.5	3791.6	-1559.5	3791.6	1740.5	3791.6
-9613.2	1941.7	-8059.5	3791.6	-4759.5	3791.6	-1459.5	3791.6	1840.5	3791.6
-9607.5	2041.5	-7959.5	3791.6	-4659.5	3791.6	-1359.5	3791.6	1940.5	3791.6
-9601.7	2141.4	-7859.5	3791.6	-4559.5	3791.6	-1259.5	3791.6	2040.5	3791.6
-9595.9	2241.2	-7759.5	3791.6	-4459.5	3791.6	-1159.5	3791.6	2140.5	3791.6
-9590.2	2341.0	-7659.5	3791.6	-4359.5	3791.6	-1059.5	3791.6	2240.5	3791.6
-9584.4	2440.9	-7559.5	3791.6	-4259.5	3791.6	-959.5	3791.6	2306.1	3757.2
-9578.7	2540.7	-7459.5	3791.6	-4159.5	3791.6	-859.5	3791.6	2306.1	3657.2
-9572.9	2640.5	-7359.5	3791.6	-4059.5	3791.6	-759.5	3791.6	2306.1	3557.2
-9567.1	2740.4	-7259.5	3791.6	-3959.5	3791.6	-659.5	3791.6	2306.1	3457.2
-9561.4	2840.2	-7159.5	3791.6	-3859.5	3791.6	-559.5	3791.6	2306.1	3357.2
-9555.6	2940.0	-7059.5	3791.6	-3759.5	3791.6	-459.5	3791.6	2306.1	3257.2
-9549.9	3039.9	-6959.5	3791.6	-3659.5	3791.6	-359.5	3791.6	2306.1	3157.2
-9544.1	3139.7	-6859.5	3791.6	-3559.5	3791.6	-259.5	3791.6	2306.1	3057.2
-9538.3	3239.5	-6759.5	3791.6	-3459.5	3791.6	-159.5	3791.6	2306.1	2957.2
-9532.6	3339.4	-6659.5	3791.6	-3359.5	3791.6	-59.5	3791.6	2306.1	2857.2
-9526.8	3439.2	-6559.5	3791.6	-3259.5	3791.6	40.5	3791.6	2306.1	2757.2
-9521.1	3539.0	-6459.5	3791.6	-3159.5	3791.6	140.5	3791.6	2306.1	2657.2
-9515.3	3638.9	-6359.5	3791.6	-3059.5	3791.6	240.5	3791.6	2306.1	2557.2

<sup>a</sup> Receptors were selected at 100-meter spacing along property boundary.

<sup>b</sup> Distances are relative to the NHPP Boiler B stack.

Note: m = meter

Table 6-8. New Hope Power Partnership Property Boundary Receptors<sup>a</sup> Used In the Modeling Analysis (continued)

Coordinates <sup>b</sup>		Coordinates <sup>b</sup>		Coordinates <sup>b</sup>		Coordinates <sup>b</sup>		Coordinates <sup>b</sup>	
X	Y	X	Y	X	Y	X	Y	X	Y
(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)
2306.1	2457.2	3448.7	299.8	3696.1	-2838.9	396.1	-2838.9	-2903.9	-2838.9
2306.1	2357.2	3448.7	199.8	3596.1	-2838.9	296.1	-2838.9	-3003.9	-2838.9
2306.1	2257.2	3448.7	99.8	3496.1	-2838.9	196.1	-2838.9	-3103.9	-2838.9
2306.1	2157.2	3448.7	-0.2	3396.1	-2838.9	96.1	-2838.9	-3203.9	-2838.9
2366.8	2117.9	3448.7	-100.2	3296.1	-2838.9	-3.9	-2838.9	-3303.9	-2838.9
2466.8	2117.9	3448.7	-200.2	3196.1	-2838.9	-103.9	-2838.9	-3403.9	-2838.9
2566.8	2117.9	3448.7	-300.2	3096.1	-2838.9	-203.9	-2838.9	-3503.9	-2838.9
2666.8	2117.9	3448.7	-400.2	2996.1	-2838.9	-303.9	-2838.9	-3603.9	-2838.9
2766.8	2117.9	3448.7	-500.2	2896.1	-2838.9	-403.9	-2838.9	-3703.9	-2838.9
2866.8	2117.9	3448.7	-600.2	2796.1	-2838.9	-503.9	-2838.9	-3803.9	-2838.9
2966.8	2117.9	3448.7	-700.2	2696.1	-2838.9	-603.9	-2838.9	-3903.9	-2838.9
3066.8	2117.9	3448.7	-800.2	2596.1	-2838.9	-703.9	-2838.9	-4003.9	-2838.9
3166.8	2117.9	3448.7	-900.2	2496.1	-2838.9	-803.9	-2838.9	-4103.9	-2838.9
3266.8	2117.9	3448.7	-1000.2	2396.1	-2838.9	-903.9	-2838.9	-4203.9	-2838.9
3366.8	2117.9	3448.7	-1100.2	2296.1	-2838.9	-1003.9	-2838.9	-4303.9	-2838.9
3448.7	2099.8	3448.7	-1200.2	2196.1	-2838.9	-1103.9	-2838.9	-4403.9	-2838.9
3448.7	1999.8	3448.7	-1300.2	2096.1	-2838.9	-1203.9	-2838.9	-4503.9	-2838.9
3448.7	1899.8	3448.7	-1400.2	1996.1	-2838.9	-1303.9	-2838.9	-4603.9	-2838.9
3448.7	1799.8	3448.7	-1500.2	1896.1	-2838.9	-1403.9	-2838.9	-4703.9	-2838.9
3448.7	1699.8	3448.7	-1600.2	1796.1	-2838.9	-1503.9	-2838.9	-4803.9	-2838.9
3448.7	1599.8	3448.7	-1700.2	1696.1	-2838.9	-1603.9	-2838.9	-4903.9	-2838.9
3448.7	1499.8	3448.7	-1800.2	1596.1	-2838.9	-1703.9	-2838.9	-5003.9	-2838.9
3448.7	1399.8	3448.7	-1900.2	1496.1	-2838.9	-1803.9	-2838.9	-5103.9	-2838.9
3448.7	1299.8	3448.7	-2000.2	1396.1	-2838.9	-1903.9	-2838.9	-5203.9	-2838.9
3448.7	1199.8	3448.7	-2100.2	1296.1	-2838.9	-2003.9	-2838.9	-5303.9	-2838.9
3448.7	1099.8	3483.0	-2191.1	1196.1	-2838.9	-2103.9	-2838.9	-5403.9	-2838.9
3448.7	999.8	3532.4	-2278.0	1096.1	-2838.9	-2203.9	-2838.9	-5503.9	-2838.9
3448.7	899.8	3581.8	-2365.0	996.1	-2838.9	-2303.9	-2838.9	-5603.9	-2838.9
3448.7	799.8	3631.2	-2451.9	896.1	-2838.9	-2403.9	-2838.9	-5703.9	-2838.9
3448.7	699.8	3680.6	-2538.9	796.1	-2838.9	-2503.9	-2838.9	-5803.9	-2838.9
3448.7	599.8	3730.0	-2625.8	696.1	-2838.9	-2603.9	-2838.9	-5903.9	-2838.9
3448.7	499.8	3779.4	-2712.8	596.1	-2838.9	-2703.9	-2838.9	-6003.9	-2838.9
3448.7	399.8	3828.8	-2799.7	496.1	-2838.9	-2803.9	-2838.9	-6103.9	-2838.9

<sup>a</sup> Receptors were selected at 100-meter spacing along property boundary.<sup>b</sup> Distances are relative to the NHPP Boiler B stack.

Note: m = meter

Table 6-8. New Hope Power Partnership Property Boundary Receptors<sup>a</sup> Used In the Modeling Analysis (continued)

Coordinates <sup>b</sup>		Coordinates <sup>b</sup>	
X	Y	X	Y
(m)	(m)	(m)	(m)
-6203.9	-2838.9	-9120.5	-2368.5
-6303.9	-2838.9	-9140.7	-2270.6
-6403.9	-2838.9	-9160.9	-2172.6
-6503.9	-2838.9	-9181.0	-2074.7
-6603.9	-2838.9	-9201.2	-1976.7
-6703.9	-2838.9	-9221.4	-1878.8
-6803.9	-2838.9	-9241.5	-1780.9
-6903.9	-2838.9	-9261.7	-1682.9
-7003.9	-2838.9	-9281.9	-1585.0
-7103.9	-2838.9	-9302.0	-1487.0
-7203.9	-2838.9	-9322.2	-1389.1
-7303.9	-2838.9	-9342.3	-1291.1
-7403.9	-2838.9	-9362.5	-1193.2
-7503.9	-2838.9	-9382.7	-1095.2
-7603.9	-2838.9	-9402.8	-997.3
-7703.9	-2838.9	-9423.0	-899.3
-7803.9	-2838.9	-9443.2	-801.4
-7903.9	-2838.9	-9463.3	-703.5
-8003.9	-2838.9	-9483.5	-605.5
-8103.9	-2838.9	-9503.7	-507.6
-8203.9	-2838.9	-9523.8	-409.6
-8303.9	-2838.9	-9544.0	-311.7
-8403.9	-2838.9	-9564.2	-213.7
-8503.9	-2838.9	-9584.3	-115.8
-8603.9	-2838.9	-9604.5	-17.8
-8703.9	-2838.9	-9624.7	80.1
-8803.9	-2838.9	-9644.8	178.1
-8903.9	-2838.9	-9665.0	276.0
-9003.9	-2838.9	-9685.2	373.9
-9039.9	-2760.3		
-9060.0	-2662.4		
-9080.2	-2564.4		
-9100.4	-2466.5		

<sup>a</sup> Receptors were selected at 100-meter spacing along property boundary.

<sup>b</sup> Distances are relative to the NHPP Boiler B stack.

Note: m = meter

Table 6-9. Everglades National Park Receptors Used in the PSD Class I Modeling Analysis

UTM Coordinates (m)		UTM Coordinates (m)		UTM Coordinates (m)		UTM Coordinates (m)	
East	North	East	North	East	North	East	North
557000	2789000	538000	2848600	514500	2837000	470000	2860000
556600	2792000	537000	2848600	514500	2836000	469000	2860000
556000	2796000	536000	2848600	514500	2835000	468000	2860000
553000	2796500	535000	2848600	514500	2834000	467000	2860000
548000	2796500	534000	2848600	514500	2833000	466000	2860000
542700	2796500	533000	2848600	514500	2832500	465000	2860000
542700	2800000	532000	2848600	510000	2832500	464000	2860000
542700	2805000	531000	2848600	509000	2832500	463000	2860000
542700	2810000	530000	2848600	508000	2832500	462000	2860000
542000	2811000	529000	2848600	507000	2832500	461000	2860000
541300	2814000	528000	2848600	506000	2832500	460000	2860000
542700	2816000	527000	2848600	505000	2832500	459500	2863200
544100	2820000	526000	2848600	504000	2832500	459000	2863200
543500	2824600	525000	2848600	503000	2832500	458000	2863200
545000	2829000	524000	2848600	502000	2832500	457000	2863200
545700	2832200	523000	2848600	501000	2832500	456000	2863200
546200	2835700	522000	2848600	500000	2832500	455000	2863200
548600	2837500	521000	2848600	499000	2832500	454000	2863200
550300	2839000	520000	2848600	498000	2832500		
545000	2839000	519000	2848600	497000	2832500		
540000	2839000	518000	2848600	496000	2832500		
550500	2844000	517000	2848600	495000	2832500		
545000	2844000	516000	2848600	495000	2833000		
540000	2844000	515000	2848600	495000	2834000		
550300	2848600	514500	2848600	495000	2835000		
549000	2848600	514500	2848000	495000	2836000		
548000	2848600	514500	2847600	494500	2837000		
547000	2848600	514500	2846600	491500	2841000		
546000	2848600	514500	2845000	488500	2845500		
545000	2848600	514500	2844000	483000	2848500		
544000	2848600	514500	2843000	480000	2852500		
543000	2848600	514500	2842000	475000	2854000		
542000	2848600	514500	2841000	473500	2857000		
541000	2848600	514500	2840000	473000	2860000		
540000	2848600	514500	2839000	472000	2860000		
539000	2848600	514500	2838000	471000	2860000		

Note: New Hope Power Partnership's coordinates are 524900 m E, 2940100 m N.  
m = meter

Table 6-10. New Hope Power Partnership Building Dimensions Used in the Modeling Analysis

Structure	Height		Length		Width	
	ft	m	ft	m	ft	m
Boiler Building	139	42.44	207	63.12	114	34.84
Electrostatic Precipitator Building No. 1	107	32.54	50	15.24	71	21.76
Electrostatic Precipitator Building No. 2	107	32.54	50	15.24	71	21.76
Electrostatic Precipitator Building No. 3	107	32.54	50	15.24	71	21.76

Table 6-11. Maximum Predicted Pollutant Impacts For the Proposed Project Only,  
New Hope Power Partnership

Pollutant/ Averaging Time	Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)	EPA Significant Impact Level ( $\mu\text{g}/\text{m}^3$ )
		Direction (degrees)	Distance (m)		
<b><u>SO<sub>2</sub></u></b>					
Annual	0.25	311.7	5,703	87123124	
	0.22	313.8	5,482	88123124	
	0.31	316.8	5,201	89123124	1
	0.28	314.5	5,410	90123124	
	0.27	309.7	5,930	91123124	
Highest 24-Hour	9.29	229.3	4,356	87110724	
	8.71	337.6	4,100	88012024	
	8.40	316.8	5,201	89031524	5
	8.95	324.0	4,690	90101024	
	8.40	341.6	3,995	91030224	
Highest 3-Hour	31.84	216.5	3,534	87053018	
	29.15	162.5	2,977	88012712	
	28.43	157.2	3,081	89120312	25
	29.97	170.1	2,882	90011315	
	26.53	311.7	5,703	91032124	
<b><u>PM<sub>10</sub></u></b>					
Annual	0.13	136.5	3,915	87123124	
	0.14	153.8	3,164	88123124	
	0.16	317.6	5,133	89123124	1
	0.14	314.5	5,410	90123124	
	0.14	310.4	5,854	91123124	
Highest 24-Hour	1.20	229.3	4,356	87110724	
	1.14	338.9	4,063	88012024	
	1.14	316.8	5,201	89031524	5
	1.16	324.0	4,690	90101024	
	1.10	341.6	3,995	91030224	
<b><u>NO<sub>2</sub></u></b>					
Annual	0.44	311.7	5,703	87123124	
	0.39	313.8	5,482	88123124	
	0.55	316.8	5,201	89123124	1
	0.50	306.3	6,403	90123124	
	0.48	309.7	5,930	91123124	

Table 6-11. Maximum Predicted Pollutant Impacts For the Proposed Project Only,  
New Hope Power Partnership

Pollutant/ Averaging Time	Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)	EPA Significant Impact Level ( $\mu\text{g}/\text{m}^3$ )
		Direction	Distance		
		(degrees)	(m)		
<b>CO</b>					
Highest 8-Hour	4.6	51.5	3,406	87062716	500
	4.5	338.9	4,063	88030916	
	3.6	340.3	4,028	89050116	
	4.0	323.0	4,749	90101024	
	5.0	331.5	4,315	91021916	
Highest 1-Hour	18.7	155.5	3,121	87042607	2,000
	20.1	20.8	4,056	88012508	
	18.2	160.0	4,000	89112919	
	21.5	166.2	2,923	90012612	
	20.4	143.6	3,529	91121509	

<sup>a</sup> Based on 5-year meteorological record, West Palm Beach, 1987 to 1991.

<sup>b</sup> Relative to New Hope Power Partnership Boiler B stack.

Note: YYMMDDHH = Year, Month, Day, Hour Ending



Table 6-12. Maximum Predicted SO<sub>2</sub> Impacts For All Sources,  
AAQS Screening Analysis, New Hope Power Partnership

Averaging Time	Concentration <sup>a</sup> (µg/m <sup>3</sup> )	Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)
		Direction (degrees)	Distance (m)	
Annual	15.9	182.1	2,841	87123124
	18.8	360	11,000	88123124
	17.2	10	11,000	89123124
	18.1	182.1	2,841	90123124
	16.9	184.1	2,846	91123124
HSH 24-Hour	111.9	180.1	2,839	87100224
	130.1	360	11,000	88011424
	105.8	182.1	2,841	89041824
	105.0	182.1	2,841	90100824
	125.8	182.1	2,841	91061024
HSH 3-Hour	360.4	360	11,000	87032109
	351.8	360	10,000	88022621
	357.4	360	11,000	89041906
	351.7	360	11,000	90012306
	399.1	360	11,000	91100709

<sup>a</sup> Based on 5-year meteorological record, West Palm Beach, 1987 to 1991.

<sup>b</sup> Relative to New Hope Power Partnership Boiler B stack.

Note: YYMMDDHH = Year, Month, Day, Hour Ending

HSH = Highest, Second-Highest

Table 6-13. Maximum Predicted SO<sub>2</sub> Concentrations for All Sources Compared to the AAQS - Refined Analysis  
New Hope Power Partnership

Averaging Time	Concentration (µg/m <sup>3</sup> ) <sup>a</sup>			Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)	Florida AAQS (µg/m <sup>3</sup> )
	Total	Modeled Sources	Background	Direction (degree)	Distance (m)		
	Annual	25.1	20.1	5	2.0	11,000	88123124
	22.2	17.2	5	9.0	11,000	89123124	60
	23.1	18.1	5	182.1	2,841	90123124	
HSH 24-Hour	145	132.1	13	359.5	11,000	88011024	260
	139	125.8	13	182.1	2,841	91061024	
HSH 3-Hour	414	366.8	47	355.0	11,000	87010718	1,300
	517	470.3	47	360.0	11,000	91100709	

<sup>a</sup> Based on 5-year meteorological record, West Palm Beach, 1987 to 1991.

<sup>b</sup> Relative to New Hope Power Partnership Boiler B stack.

Note: YYMMDDHH = Year, Month, Day, Hour Ending  
HSH = Highest, Second-Highest

Table 6-14. Maximum Predicted SO<sub>2</sub> Impacts For All Sources.  
PSD Class II Screening Analysis, New Hope Power Partnership

Averaging Time	Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)
		Direction (degree)	Distance (m)	
<b>SO<sub>2</sub></b>				
Annual	4.0	10	11,000	87123124
	5.1	360	11,000	88123124
	4.2	10	11,000	89123124
	2.3	360	11,000	90123124
	3.8	360	11,000	91123124
HSH 24-Hour	44.9	360	11,000	87101824
	60.3	360	11,000	88011024
	44.4	10	11,000	89021224
	42.0	10	10,000	90030624
	52.9	360	11,000	91121924
HSH 3-Hour	201.1	360	11,000	87021821
	156.7	350	11,000	88022415
	161.7	360	11,000	89041906
	141.8	360	11,000	90012306
	213.1	360	11,000	91011803

<sup>a</sup> Based on 5-year meteorological record, West Palm Beach, 1987 to 1991.

<sup>b</sup> Relative to New Hope Power Partnership Boiler B stack.

<sup>c</sup> Maximum concentrations were predicted to be less than zero at all receptors.

Note: YYMMDDHH = Year, Month, Day, Hour Ending  
HSH = Highest, Second-Highest

Table 6-15. Maximum Predicted SO<sub>2</sub> Concentrations for All Sources Compared to the PSD Class II Increment  
Refined Analysis, New Hope Power Partnership

Averaging Time	Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)	PSD Increment ( $\mu\text{g}/\text{m}^3$ )
		Direction (degree)	Distance (m)		
Annual	5.6	2.0	11,000	88123124	20
HSH 24-Hour	62	359.5	11,000	88011024	91
HSH 3-Hour	201	359.5	11,000	87021821	512
	218	2.0	11,000	91111403	

<sup>a</sup> Based on 5-year meteorological record, West Palm Beach, 1987 to 1991.

<sup>b</sup> Relative to New Hope Power Partnership Boiler B stack.

Note: YYMMDDHH = Year, Month, Day, Hour Ending

HSH = Highest, Second-Highest

Table 6-16. Summary of Maximum Pollutant Concentrations Predicted for the Project Only  
Compared to the EPA Class I Significant Impact Levels and PSD Class I Increments  
New Hope Power Partnership

Pollutant	Averaging Time	Maximum Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	EPA Class I Significant Impact Levels ( $\mu\text{g}/\text{m}^3$ )	Allowable PSD Class I Increments ( $\mu\text{g}/\text{m}^3$ )
SO <sub>2</sub>	Annual	0.0044	0.1	2
	24-Hour	0.45	0.2	5
	3-Hour	1.10	1.0	25
PM <sub>10</sub>	Annual	0.0024	0.2	4
	24-Hour	0.064	0.3	8
NO <sub>2</sub>	Annual	0.0047	0.1	2.5

<sup>a</sup> Highest concentration predicted with CALPUFF model and CALMET South Florida Domain, 1990.

Table 6-17. Maximum Predicted SO<sub>2</sub> Concentrations for PSD Sources at the Everglades National Park

Averaging Time	Maximum Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	Receptor Location (m)		Period Ending (Julian day/ hour/year)	Allowable PSD Class I Increments ( $\mu\text{g}/\text{m}^3$ )
		UTM East	UTM North		
24-Hour	3.99	533000	2848600	(317/23/1990)	5
3-Hour	12.16	545000	2844000	(188/08/1990)	25

<sup>a</sup> Concentrations are second-highest predicted with CALPUFF model and CALMET South Florida Domain, 1990.

Note:

m = meter

UTM = Universal Transverse Mercator

$\mu\text{g}/\text{m}^3$  = micrograms per cubic meter

Table 6-18. Maximum Predicted Fluoride Impacts For the Proposed Project Only in the Site Vicinity,  
New Hope Power Partnership

Pollutant/ Averaging Time	Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)
		Direction (degrees)	Distance (m)	
Annual	0.0029	311.7	5,703	87123124
	0.0026	313.8	5,482	88123124
	0.0037	316.8	5,201	89123124
	0.0033	314.5	5,410	90123124
	0.0032	309.7	5,930	91123124
Highest 24-Hour	0.017	229.3	4,356	87110724
	0.016	337.6	4,100	88012024
	0.015	316.8	5,201	89031524
	0.017	324.0	4,690	90101024
	0.015	341.6	3,995	91030224
Highest 8-Hour	0.027	51.5	3,406	87062716
	0.026	330.3	4,363	88112716
	0.025	158.9	3,043	89120316
	0.030	322.0	4,810	90021608
	0.029	331.5	4,315	91021916
Highest 3-Hour	0.046	216.5	3,534	87053018
	0.040	162.5	2,977	88012712
	0.038	157.2	3,081	89120312
	0.041	170.1	2,882	90011315
	0.037	311.7	5,703	91032124
Highest 1-Hour	0.069	155.5	3,121	87042607
	0.077	20.8	4,056	88012508
	0.078	158.9	3,043	89112919
	0.090	166.2	2,923	90012612
	0.075	176.0	2,846	91101908

<sup>a</sup> Based on 5-year meteorological record, West Palm Beach, 1987 to 1991.

<sup>b</sup> Relative to New Hope Power Partnership Boiler B stack.

Note: YYMMDDHH = Year, Month, Day, Hour Ending

Table 6-19. Maximum Predicted Sulfuric Acid Mist Impacts For the Proposed Project Only in the Site Vicinity,  
New Hope Power Partnership

Pollutant/ Averaging Time	Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)
		Direction (degrees)	Distance (m)	
Annual	0.012	311.7	5,703	87123124
	0.011	313.8	5,482	88123124
	0.015	316.8	5,201	89123124
	0.014	314.5	5,410	90123124
	0.013	309.7	5,930	91123124
Highest 24-Hour	0.57	229.3	4,356	87110724
	0.53	337.6	4,100	88012024
	0.51	316.8	5,201	89031524
	0.56	324	4,690	90101024
	0.51	341.6	3,995	91030224
Highest 8-Hour	0.90	51.5	3,406	87062716
	0.87	330.3	4,363	88112716
	0.85	158.9	3,043	89120316
	0.97	322	4,810	90021608
	0.95	331.5	4,315	91021916
Highest 3-Hour	1.50	216.5	3,534	87053018
	1.35	162.5	2,977	88012712
	1.30	157.2	3,081	89120312
	1.39	170.1	2,882	90011315
	1.23	311.7	5,703	91032124
Highest 1-Hour	2.23	155.5	3,121	87042607
	2.50	20.8	4,056	88012508
	2.55	158.9	3,043	89112919
	2.92	166.2	2,923	90012612
	2.42	176	2,846	91101908

<sup>a</sup> Based on 5-year meteorological record, West Palm Beach, 1987 to 1991.

<sup>b</sup> Relative to New Hope Power Partnership Boiler B stack.

Note: YYMMDDHH = Year, Month, Day, Hour Ending



Table 6-20. Maximum Predicted Lead Impacts For the Proposed Project Only in the Site Vicinity,  
New Hope Power Partnership


Pollutant/ Averaging Time	Concentration <sup>a</sup> ( $\mu\text{g}/\text{m}^3$ )	Receptor Location <sup>b</sup>		Time Period (YYMMDDHH)
		Direction (degrees)	Distance (m)	
Annual	0.00086	311.7	5,703	87123124
	0.00077	313.8	5,482	88123124
	0.00110	316.8	5,201	89123124
	0.00099	314.5	5,410	90123124
	0.00095	309.7	5,930	91123124
Highest 24-Hour	0.0070	229.3	4,356	87110724
	0.0066	337.6	4,100	88012024
	0.0064	316.8	5,201	89031524
	0.0068	324.0	4,690	90101024
	0.0064	341.6	3,995	91030224
Highest 8-Hour	0.011	51.5	3,406	87062716
	0.011	153.8	3,164	88022508
	0.011	158.9	3,043	89120316
	0.012	322.0	4,810	90021608
	0.012	331.5	4,315	91021916
Highest 3-Hour	0.018	216.5	3,534	87053018
	0.017	162.5	2,977	88012712
	0.017	157.2	3,081	89120312
	0.017	170.1	2,882	90011315
	0.015	311.7	5,703	91032124
Highest 1-Hour	0.027	155.5	3,121	87042607
	0.030	20.8	4,056	88012508
	0.031	158.9	3,043	89112919
	0.035	166.2	2,923	90012612
	0.029	176.0	2,846	91101908

<sup>a</sup> Based on 5-year meteorological record, West Palm Beach, 1987 to 1991.


<sup>b</sup> Relative to New Hope Power Partnership Boiler B stack.

Note: YYMMDDHH = Year, Month, Day, Hour Ending

**Figure 6-1. New Hope Power Partnership  
Building, Stack, Property Boundary, and Receptor Locations**



**Figure 6-2. New Hope Power Partnership  
Building, Area Source, and Stack Locations**



## 7.0 ADDITIONAL IMPACT ANALYSIS

### 7.1 VICINITY OF NHPP

#### 7.1.1 VEGETATION AND SOILS

The primary vegetation, as well as agricultural crop, in the vicinity of NHPP is sugar cane. The mill is surrounded by sugar cane fields for a large distance in all directions. Some rice fields, vegetable farming, nurseries, and sod farms are also located in the general area. The Loxahatchee National Wildlife Refuge is located approximately 32 km to the east of the mill.

Soils in the area are primarily histosols, which are peat soils with high amounts of organic matter. The surrounding area is part of the Everglades Agricultural Area, which is noted for its "muck", i.e., rich, black soil which is very fertile.

As described in the air quality impact analysis (Section 6.0), the maximum predicted SO<sub>2</sub> concentrations in the vicinity of NHPP as a result of the proposed project are predicted to be below the AAQS. Since the AAQS are designed to protect the public welfare, including effects on soils and vegetation, no detrimental effects on soils or vegetation should occur in this area due to the proposed project.

No significant impacts on growth in the area are expected as a result of this project. The cogeneration boilers are existing boilers, and the proposed project is only to allow increased maximum heat input rates of the boilers. No new construction will occur.

#### 7.1.2 VISIBILITY

No new emission sources will be created by the proposed project. The NHPP boilers are currently controlled by ESPs and dust collectors, and therefore, the visible plume characteristics from these sources will not change. The NHPP boilers are in compliance with opacity regulations and should remain in compliance after increasing the maximum annual heat input rate of the boilers. As a result, no adverse impacts upon visibility in the vicinity of NHPP are expected.

#### 7.1.3 IMPACTS DUE TO ASSOCIATED GROWTH

Since the NHPP boilers are existing boilers and the proposed project does not require any physical modification to the boilers, there should be no increase in the number of workers. There will also be

no increase in the number of permanent employees at NHPP as a result of the proposed project. Therefore, there will be no anticipated impacts on air quality caused by associated growth.

The NHPP facility is in a remote part of western Palm Beach County, surrounded by sugar cane fields for many miles in all directions. The extent of the sugar cane fields has not changed significantly since 1977. Therefore, there has been no commercial, residential, industrial or other growth in the immediate vicinity of NHPP during this time. NHPP will "affect" an area of approximately 10 km surrounding the facility, based on the significant impact analysis results. At the outer edge of the affected area are the towns of South Bay and Belle Glade. None of these towns has experienced significant growth since 1977. Based on this discussion, it is concluded that no significant growth has occurred in the area of the NHPP site that would affect air quality impacts. It is also noted that the conservative background concentrations used in the modeling analysis already account for any such changes.

The potential impacts of SO<sub>2</sub>, NO<sub>2</sub>, PM, CO, Pb, F, and SAM on soils, vegetation, wildlife, and visibility in the Everglades National Park Class I area are addressed in the following sections.

## **7.2 PSD CLASS I AREA**

This section focuses on the ecological effects of the proposed facility modification on Air Quality Related Values (AQRV), as defined under PSD regulations, in the Everglades National Park (ENP). The ENP is the closest Class I area to NHPP, and is located approximately 92 km south of NHPP. The AQRVs are defined as being:

All those values possessed by an area except those that are not affected by changes in air quality and include all those assets of an area whose vitality, significance, or integrity is dependent in some way on the air environment. These values include visibility and those scenic, cultural, biological, and recreational resources of an area that are affected by air quality. Important attributes of an area are those values or assets that make an area significant as a monument, preserve, or primitive area. They are the assets that are to be preserved if the area is to achieve the purposes for which it was set aside (Federal Register, 1978).

The AQRVs include freshwater and coastal wetlands, dominant plant communities, unique and rare plant communities, soils and associated periphyton, and the wildlife dependent on these communities

for habitat. Rare, endemic, threatened, and endangered species of the national park and bioindicators of air pollution (e.g., lichens) are also evaluated.

The maximum predicted atmospheric concentrations due to the increase in emissions resulting from the proposed project are presented in Table 7-1. As shown, the predicted increase in impacts is very low for all pollutants considered.

### 7.2.1 IMPACTS TO SOILS

For soils, the potential and hypothesized effects of atmospheric deposition include:

- Increased soil acidification,
- Alteration in cation exchange,
- Loss of base cations, and
- Mobilization of trace metals.

The potential sensitivity of specific soils to atmospheric inputs is related to two factors. First, the physical ability of a soil to conduct water vertically through the soil profile is important in influencing the interaction with deposition. Second, the ability of the soil to resist chemical changes, as measured in terms of pH and soil cation exchange capacity (CEC), is important in determining how a soil responds to atmospheric inputs.

The soils of the Everglades National Park are generally classified as histosols or entisols. Histosols (peat soils) are organic and have extremely high buffering capacities based on their CEC, base saturation, and bulk density. Therefore, they would be relatively insensitive to atmospheric inputs. The entisols are shallow sandy soils overlying limestone, such as the soils found in the pinelands. The direct connection of these soils with subsurface limestone tends to neutralize any acidic inputs. Moreover, the groundwater table is highly buffered due to the interaction with subsurface limestone formations, which results in high alkalinity (as  $\text{CaCO}_3$ ).

The relatively low sensitivity of the soils to acid inputs coupled with the extremely low ground-level concentrations of contaminants projected for the Everglades National Park from the NHPP facility emissions precludes any significant impact on soils.

## 7.2.2 IMPACTS TO VEGETATION

The maximum predicted gaseous concentrations ( $\mu\text{g}/\text{m}^3$ ) of  $\text{SO}_2$ ,  $\text{NO}_2$ , PM, CO, Pb, F, and SAM were used in the determination of impacts on vegetation. These compounds are believed to interact predominantly with foliage and this is considered the major route of entry into plants. In this assessment, 100 percent of the compound of interest was assumed to interact with the vegetation.

### 7.2.2.1 Sulfur Dioxide

Sulfur is an essential plant nutrient usually taken up as sulfate ions by the roots from the soil solution. When sulfur dioxide in the atmosphere enters the foliage through pores in the leaves, it reacts with water in the leaf interior to form sulfite ions. Sulfite ions are highly toxic. They interact with enzymes, compete with normal metabolites, and interfere with a variety of cellular functions (Horsman and Wellburn, 1976). However, within the leaf, sulfite is oxidized to sulfate ions, which can then be used by the plant as a nutrient. Small amounts of sulfite may be oxidized before they prove harmful.

$\text{SO}_2$  gas at elevated levels has long been known to cause injury to plants. Acute  $\text{SO}_2$  injury usually develops within a few hours or days of exposure, and symptoms include marginal, flecked, and/or intercostal necrotic areas that appear water-soaked and dullish green initially. This injury generally occurs to younger leaves. Chronic injury usually is evident by signs of chlorosis, bronzing, premature senescence, reduced growth, and possible tissue necrosis (EPA, 1982). Background levels of  $\text{SO}_2$  range from 2.5 to 25  $\mu\text{g}/\text{m}^3$ . Observed  $\text{SO}_2$  effect levels for several plant species and plant sensitivity groupings are presented in Tables 7-2 and 7-3, respectively.

Many studies have been conducted to determine the effects of high-concentration, short-term  $\text{SO}_2$  exposure on natural community vegetation. Sensitive plants include ragweed, legumes, blackberry, southern pine, and red and black oak. These species are injured by exposure to 3-hour  $\text{SO}_2$  concentrations of 790 to 1,570  $\mu\text{g}/\text{m}^3$ . Intermediate plants include locust and sweetgum. These species are injured by exposure to 3-hour  $\text{SO}_2$  concentrations of 1,570 to 2,100  $\mu\text{g}/\text{m}^3$ . Resistant species (injured at concentrations above 2,100  $\mu\text{g}/\text{m}^3$  for 3 hours) include white oak and dogwood (EPA, 1982).

A study of native Floridian species (Woltz and Howe, 1981) demonstrated that cypress, slash pine, live oak, and mangrove exposed to 1,300  $\mu\text{g}/\text{m}^3$   $\text{SO}_2$  for 8 hours were not visibly damaged. This

finding supports the levels cited by other researchers on the effects of SO<sub>2</sub> on vegetation. A corroborative study (McLaughlin and Lee, 1974) demonstrated that approximately 20 percent of a cross-section of plants ranging from sensitive to tolerant was visibly injured at 3-hour SO<sub>2</sub> concentrations of 920 µg/m<sup>3</sup>.

Two lichen species indigenous to the park area exhibited signs of SO<sub>2</sub> damage in the form of decreased biomass gain and photosynthetic rate as well as membrane leakage when exposed to concentrations of 200 to 400 µg/m<sup>3</sup> for 6 hours/week for 10 weeks (Hart *et al.*, 1988).

When the 8-hour modeled incremental SO<sub>2</sub> increase from the proposed modification (0.73 µg/m<sup>3</sup>) is added to the upper range of background SO<sub>2</sub> concentrations (0.72 µg/m<sup>3</sup>; refer to Section 4.5), a maximum of 1.45 µg/m<sup>3</sup> of SO<sub>2</sub> would be expected at the point of maximum impact in the Everglades National Park. On comparison of this concentration to those causing injury to native species, it is evident that SO<sub>2</sub>-sensitive species (or more tolerant species) would not be damaged by the predicted concentrations. By comparing the SO<sub>2</sub> concentration of 1.45 µg/m<sup>3</sup> with the concentrations that cause plant injury, it can be shown that the amount of SO<sub>2</sub> in the park area is less than 1 percent of the most conservative concentration (200 µg/m<sup>3</sup>) that caused injury to SO<sub>2</sub>-sensitive species.

The 24-hour and annual SO<sub>2</sub> concentrations predicted within the park due to the project only (0.45 and 0.0044 µg/m<sup>3</sup>, respectively) when added to background concentrations of 0.72 and 0.13 µg/m<sup>3</sup>, respectively, result in total SO<sub>2</sub> impacts of 1.17 and 0.13 µg/m<sup>3</sup>, respectively. These levels are much lower than those known to cause damage to test species. Jack pine seedlings exposed to SO<sub>2</sub> concentrations of 470 to 520 µg/m<sup>3</sup> for 24 hours demonstrated inhibition of foliar lipid synthesis; however, this inhibition was reversible (Malhotra and Kahn, 1978). Black oak exposed to 1,310 µg/m<sup>3</sup> SO<sub>2</sub> for 24 hours a day for 1 week demonstrated a 48 percent reduction in photosynthesis (Carlson, 1979). By comparison of these levels, it is apparent that the modeled 24-hour incremental increase of SO<sub>2</sub> is well below (i.e., less than 2 percent) the concentrations that caused damage in SO<sub>2</sub>-sensitive plants. The modeled annual incremental increase in SO<sub>2</sub> (0.0044 µg/m<sup>3</sup>) adds slightly to background levels of this gas and poses no threat to area vegetation.



### **7.2.2.2 Nitrogen Dioxide**

Nitrogen dioxide (NO<sub>2</sub>) is another emission of concern for the proposed plant expansion. This compound can injure plant tissue with symptoms usually appearing as irregular white to brown collapsed lesions between the leaf veins and near the margins. Conversely, non-injurious levels of NO<sub>2</sub> can be absorbed by plants, enzymatically transformed into ammonia, and incorporated into plant constituents such as amino acids (Matsumaru *et al.*, 1979).

Plant damage can occur through either acute (short-term, high concentration) or chronic (long-term, relatively low concentration) exposure. For plants that have been determined to be more sensitive to NO<sub>2</sub> exposure than others, acute (1, 4, 8 hours) exposure caused 5 percent predicted foliar injury at concentrations ranging from 3,800 to 15,000 µg/m<sup>3</sup> (Heck and Tingey, 1979). Chronic exposure of selected plants (some considered NO<sub>2</sub>-sensitive) to NO<sub>2</sub> concentrations of 2,000 to 4,000 µg/m<sup>3</sup> for 213 to 1,900 hours caused reductions in yield of up to 37 percent and some chlorosis (Zahn, 1975).

By comparison of published toxicity values for NO<sub>2</sub> exposure to short-term (i.e., 1-, 3-, and 8-hour averaging times) and long-term (annual averaging time) modeled concentrations, the possibility of plant damage in the park can be examined for both acute and chronic exposure situations, respectively. The 1-, 3-, and 8-hour estimated NO<sub>2</sub> concentrations due to the project only at the point of maximum impact in the park area are 0.52, 0.43, and 0.37 µg/m<sup>3</sup>, respectively. These concentrations are approximately 0.002 to 0.01 percent of the levels that could potentially injure 5 percent of the plant foliage. For a chronic exposure, the annual estimated NO<sub>2</sub> concentration due to the project only at the point of maximum impact in the park (0.0047 µg/m<sup>3</sup>) is 0.0001 to 0.0003 percent of the levels that caused minimal yield loss and chlorosis in plant tissue.

Although it has been shown that simultaneous exposure to SO<sub>2</sub> and NO<sub>2</sub> results in synergistic plant injury (Ashenden and Williams, 1980), the magnitude of this response is generally only 3 to 4 times greater than either gas alone and usually occurs at unnaturally high levels of each gas. Therefore, the concentrations within the park are still far below the levels that potentially cause plant injury for either acute or chronic exposure.

### **7.2.2.3 Particulate Matter**

Although information pertaining to the effects of PM on plants is scarce, baseline concentrations are available (Mandoli and Dubey, 1988). Ten species of native Indian plants were exposed to levels of

PM that ranged from 210 to 366  $\mu\text{g}/\text{m}^3$  for an 8-hour averaging period. Damage in the form of a higher leaf area/dry weight ratio was observed at varying degrees for most plants tested. Concentrations of PM lower than 163  $\mu\text{g}/\text{m}^3$  did not appear to be injurious to the tested plants.

By comparison of published toxicity values for PM exposure (i.e., 8-hour averaging time) concentrations, the possibility of plant damage in the park due to the project can be determined. The 8-hour estimated PM concentration due to the project only at the point of maximum impact in the park area is 0.10  $\mu\text{g}/\text{m}^3$ . This concentration is approximately 0.03 to 0.05 percent of the values that affected plant foliage. The extremely small additional impact the proposed project is predicted to have on the ENP will not cause any adverse affects to vegetation.

#### **7.2.2.4 Carbon Monoxide**

As with PM, information pertaining to the effects of CO on plants is scarce. The main effect of high concentrations of CO is the inhibition of cytochrome *c* oxidase, the terminal oxidase in the mitochondrial electron transfer chain. Inhibition of cytochrome *c* oxidase depletes the supply of ATP, the principal donor of free energy required for cell functions. However, this inhibition only occurs at extremely high concentrations of CO. Pollok *et al.* (1989) reported that exposure to CO:O<sub>2</sub> ratio of 25 (equivalent to an ambient CO concentration of  $6.85 \times 10^6 \mu\text{g}/\text{m}^3$ ) resulted in stomatal closure in the leaves of the sunflower (*Helianthus annuus*). Naik *et al.* (1992) reported cytochrome *c* oxidase inhibition in corn, sorghum, millet, and Guinea grass at CO:O<sub>2</sub> ratios of 2.5 (equivalent to an ambient CO concentration of  $6.85 \times 10^5 \mu\text{g}/\text{m}^3$ ). These plants were considered the species most sensitive to CO-induced inhibition of cytochrome *c* oxidase. The predicted annual average CO impact due to the proposed project only at the ENP ( $0.032 \mu\text{g}/\text{m}^3$ ) is well below these published effects levels.

#### **7.2.2.5 Fluoride**

Fluoride is an inhibitor of plant metabolism. As fluoride accumulates in plants, it causes an inhibition of plant metabolism and chlorosis (a yellowing of the leaf). With further increases in accumulation of fluoride, the cells die and necrosis is observed. Leaf tips and margins accumulate the highest concentrations of fluoride and are the sites of initial visible injury. Gaseous fluoride is taken up primarily through the stomata of transpiring plants. There is negligible contribution to leaf fluoride content by uptake by roots (Applied Sciences Associates, Inc., 1978).

The sensitivity of plants varies widely. Presented in Table 7-4 are fluoride effect levels for various plant species. Gladiolus are considered the most sensitive. Visible symptoms are reported to occur when gladiolus have been exposed to concentrations  $>0.5 \mu\text{g}/\text{m}^3$  for 5 to 10 days. More tolerant fruit tree species and conifers first showed symptoms at around  $1 \mu\text{g}/\text{m}^3$  at 10-day exposures (Treshow and Anderson, 1989). Plant sensitivities can range from  $16 \mu\text{g}/\text{m}^3$  of fluoride in sensitive plants to  $500 \mu\text{g}/\text{m}^3$  of fluoride in tolerant plants for 3-hour exposures. The lowest observed effect levels for sensitive plants are reported to be as follows (Applied Sciences Associates, Inc., 1978):

- $50 \mu\text{g}/\text{m}^3$  for 1-hour exposures,
- $16 \mu\text{g}/\text{m}^3$  for 3-hour exposures, and
- $1.6 \mu\text{g}/\text{m}^3$  for 24-hour exposures.

Data suggest that a fluoride accumulation factor might be calculated under fumigation conditions with an uncertainty factor of less than 2. One study indicated that hydrogen fluoride concentrations of  $0.3 \mu\text{g}/\text{m}^3$  would lead to an accumulation of up to 20 ppm of fluoride in conifer foliage after 2 years of exposure (Treshow and Anderson, 1989).

The predicted maximum 1-hour, 3-hour, 8-hour, 24-hour, and annual incremental fluoride concentrations in the ENP due to the proposed project are 0.0021, 0.0017, 0.0015, 0.00094,  $0.000072 \mu\text{g}/\text{m}^3$ , respectively (refer to Table 7-1). These predicted values are well below the lowest observed effect levels for sensitive vegetation. No significant adverse effects are predicted to occur to the vegetative AQRVs of ENP. Since the predicted annual concentration is very low, no measurable accumulation of fluoride will occur in vegetation that would be the prime forage of wildlife. Therefore, no significant adverse effects to wildlife AQRVs will occur (see also Section 7.2.3).

#### **7.2.2.6 Sulfuric Acid Mist**

Acidic precipitation or acid rain is coupled to  $\text{SO}_2$  emissions mainly formed during the burning of fossil fuels. This pollutant is oxidized in the atmosphere and dissolves in rain forming sulfuric acid mist which falls as acidic precipitation (Ravera, 1989). Although concentration data are not available, sulfuric acid mist has been reported to yield necrotic spotting on the upper surfaces of leaves (Middleton *et al.*, 1950).

No significant adverse effects on vegetation are expected from the project's emissions because SO<sub>2</sub> concentrations, which lead directly to the formation of sulfuric acid mist concentrations, are predicted to be well below levels which have been documented as negatively affecting vegetation. During the last decade, much attention has been focused on acid rain. Acidic deposition is an ecosystem-level problem that affects vegetation because of some alterations of soil conditions such as increased leaching of essential base cations or elevated concentrations of aluminum in the soil water (Goldstein *et al.*, 1985). Although effects of acid rain in eastern North America have been well published and publicized, detrimental effects of acid rain on Florida vegetation are lacking documentation.

#### **7.2.2.7 Lead**

The maximum increase in 24-hour average ambient Pb concentrations due to the proposed project is predicted to be 0.00038 µg/m<sup>3</sup>. Naturally occurring levels of Pb in plants range from 0.1 to 10 µg/g, with an average of 2 µg/g (Kabata-Pendias and Pendias, 1984). A Pb soil concentration of 30 to 100 µg/g generally retards the growth of plants (Gough *et al.*, 1979). By comparison of these effects levels with the maximum predicted impacts due to the proposed project, it is concluded that the low levels of the Pb predicted from the proposed project are not expected to adversely affect vegetation.

#### **7.2.2.8 Summary**

In summary, the phytotoxic effects on the ENP from proposed increase in the NHPP boilers' emissions are expected to be minimal. It is important to note that the substances were evaluated with the assumption that 100 percent was available for plant uptake. This is rarely the case in a natural ecosystem.

### **7.2.3 IMPACTS TO WILDLIFE**

A wide range of physiological and ecological effects to fauna has been reported for gaseous and particulate pollutants (Newman, 1981; Newman and Schreiber, 1988). The most severe of these effects have been observed at concentrations above the secondary ambient air quality standards. Physiological and behavioral effects have been observed in experimental animals at or below these standards. No observable effects to fauna are expected at concentrations below the values reported in Table 7-5.

The major air quality risk to wildlife in the United States is from continuous exposure to pollutants above the National Ambient Air Quality Standards. This occurs in non-attainment areas, e.g., Los Angeles Basin. Risks to wildlife also may occur for wildlife living in the vicinity of an emission source that experiences frequent upsets or episodic conditions resulting from malfunctioning equipment, unique meteorological conditions, or startup operations (Newman and Schreiber, 1988). Under these conditions, chronic effects (e.g., particulate contamination) and acute effects (e.g., injury to health) have been observed (Newman, 1981).

For impacts on wildlife, the lowest threshold values of SO<sub>2</sub>, NO<sub>x</sub>, and particulates which are reported to cause physiological changes are shown in Table 7-5. These values are up to orders of magnitude larger than maximum predicted concentrations for the Class I area.

No effects on wildlife AQRVs from SO<sub>2</sub>, NO<sub>x</sub>, CO, Pb, SAM, F, and PM emissions are expected due to the proposed project. These results are considered indications of the risk of other air pollutant emissions predicted from the facility.

#### **7.2.4 IMPACTS ON VISIBILITY**

##### **Introduction**

The CAA Amendments of 1977 provide for implementation of guidelines to prevent visibility impairment in mandatory Class I areas. The guidelines are intended to protect the aesthetic quality of these pristine areas from reduction in visual range and atmospheric discoloration due to various pollutants. Sources of air pollution can cause visible plumes due to emissions of PM<sub>10</sub> and NO<sub>x</sub>. A plume can be visible if its constituents scatter or absorb sufficient light so that the plume is brighter or darker than its viewing background (e.g., the sky or a terrain feature, such as a mountain). PSD Class I areas, such as national parks and wilderness areas, are afforded special visibility protection designed to prevent plume visual impacts to observers within a Class I area.

Visibility is an AQRV for the Everglades NP. Visibility can take the form of plume blight for nearby areas or regional haze for long distances (e.g., distances beyond 50 km). Because the Everglades NP is more than 50 km from the NHPP project site, the change in visibility is analyzed as regional haze. Currently, there are several air quality modeling approaches recommended by the Interagency Workgroup on Air Quality Models (IWAQM) to perform these analyses. The IWAQM consists of EPA and FLM of Class I areas who are responsible for ensuring that AQRVs are not adversely

impacted by new and existing sources. These recommendations have been summarized in two documents:

- *Interagency Workgroup on Air Quality Models (IWAQM), Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts* (EPA, 1998), referred to as the IWAQM Phase 2 report; and
- *Federal Land Managers' Air Quality Related Values Workgroup (FLAG), Phase I Report*, USFS, NPS, USFWS (December, 2000), referred to as the FLAG document.

The methods and assumptions recommended in these documents were used to assess visibility impairment due to the proposed NHPP project.

### **Analysis Methodology**

#### **General**

Based on the FLAG document, current regional haze guidelines characterize a change in visibility by the change in the light-extinction coefficient ( $b_{ext}$ ). The  $b_{ext}$  is the attenuation of light per unit distance due to the scattering and absorption by gases and particles in the atmosphere. A change in the extinction coefficient produces a perceived visual change. An index that simply quantifies the percent change in visibility due to the operation of a source is calculated as:

$$\Delta\% = (b_{exts} / b_{extb}) \times 100$$

where:  $b_{exts}$  is the extinction coefficient calculated for the source, and  
 $b_{extb}$  is the background extinction coefficient.

The purpose of the visibility analysis is to calculate the extinction at each receptor for each day (24-hour period) of the year due to the proposed project. The criteria to determine if the project's impacts are potentially significant are based on a change in extinction of 5 percent or greater for any day of the year.

Processing of visibility impairment for this study was performed with the CALPUFF model (see Appendix G) and the CALPUFF post-processing program CALPOST. The analysis was conducted in accordance with the most recent guidance from the FLAG report (December 2000). The CALPUFF postprocessor model CALPOST is used to calculate the combined visibility effects from

the different pollutants that are emitted from the project. Daily background extinction coefficients are calculated on a hour-by-hour basis using hourly relative humidity data from CALMET and hygroscopic and non-hygroscopic extinction components specified in the FLAG document. CALPOST then predicts the percent extinction change for each day of the year.

### **Emission Inventory**

Based on recommendations of the FLAG Phase I Report (December 2000), the regional haze analysis considered only the maximum 24-hour increase in emissions due to the NHPP cogeneration boilers. The emission rates and source parameters used in the regional haze analysis are presented in Section 6.0, Tables 6-3 through 6-5.

### **Building Wake Effects**

The air modeling analysis included the same building structure dimensions to account for the effects of building-induced downwash on the emission sources as was used in the ISCST3 modeling analysis. Dimensions for all significant building structures were processed with the Building Profile Input Program (BPIP), Version 95086, and were included in the CALPUFF model.

### **Receptor Locations**

Receptors for the refined analysis included 126 discrete receptors located at the ENP PSD Class I area, as described in Section 6.0. Because the area's terrain is flat, all receptors were assumed to be at zero elevation.

### **Background Visual Ranges and Relative Humidity Factors**

The regional haze analysis was performed using the latest regulatory guidance as provided in the FLAG Phase I report. Using the hourly meteorological and relative humidity data used with the CALPUFF model, the daily change in background extinction is computed. The hygroscopic and dry non-hygroscopic components used for calculating the daily background extinction coefficients for the ENP were obtained from the FLAG report. For this analysis, the hygroscopic and dry non-hygroscopic values were 0.9 and 8.5 inverse millimeters ( $Mm^{-1}$ ), respectively.

### **Meteorological Data**

A CALMET wind field for the south Florida domain was used for this analysis. The year of data is 1990. A detailed description of the data used to develop the wind field is presented in Appendix G.

## **Chemical Transformation**

The air modeling analysis included all chemical transformation processes that occur for the emitted species.

### **7.2.4.1 Results**

A refined regional haze analysis was performed for the proposed project. The maximum predicted 24-hour visibility degradation is 3.52 percent. As this percentage is below the criteria value of 5 percent, it is concluded that proposed project poses no threat to visibility degradation in the Class I area.

## **7.2.5 SULFUR AND NITROGEN DEPOSITION**

### **General Methods**

As part of the AQRV analyses, total nitrogen (N) and sulfur (S) deposition rates were predicted at the Everglades NP Class I area. The deposition analysis thresholds (DAT) are based on the annual averaging period. The total deposition is estimated in units of kilogram per hectare per year (kg/ha/yr) of nitrogen or sulfur. The CALPUFF model is used to predict wet and dry deposition fluxes of various oxides of these elements.

For N deposition, the species include:

- Particulate ammonium nitrate (from species  $\text{NO}_3$ ), wet and dry deposition;
- Nitric acid (species  $\text{HNO}_3$ ), wet and dry deposition;
- $\text{NO}_x$ , dry deposition; and
- Ammonium sulfate (species  $\text{SO}_4$ ), wet and dry deposition.

For S deposition, the species include:

- $\text{SO}_2$ , wet and dry deposition; and
- $\text{SO}_4$ , wet and dry deposition.

The CALPUFF model produces results in units of  $\mu\text{g}/\text{m}^2/\text{s}$ . The modeled deposition rates are then converted to N or S deposition in kg/ha respectively, by using a multiplier equal to the ratio of the molecular weights of the substances (IWAQM Phase II report Section 3.3).



DAT for nitrogen and sulfur deposition of 0.01 kg/ha/yr were provided by the U.S. Fish and Wildlife Service (January 2002). A DAT is the additional amount of N or S deposition within a Class I area, below which estimated impacts from a proposed new or modified source are considered insignificant. The maximum N and S depositions predicted for the NHPP project are, therefore, compared to these DAT or significant impact levels.

### **Results**

The maximum predicted N and S depositions predicted for the project in the PSD Class I area of the Everglades NP are summarized in Table 7-6. The total N and S deposition rates are predicted to be 0.0023 and 0.0039 kg/ha/yr, respectively. These maximum deposition rates are below the deposition threshold levels for N and S of 0.01 kg/ha/yr. As a result, the NHPP project is not expected to have a significant adverse effect on N and S deposition in the Class I area.

Table 7-1. Maximum Predicted Concentrations Due to the Project Only at the Class I  
Area of the Everglades National Park, New Hope Power Partnership

Pollutant	Concentrations <sup>a</sup> (ug/m <sup>3</sup> ) for Averaging Times				
	Annual	24-Hour	8-Hour	3-Hour	1-Hour
Sulfur Dioxide (SO <sub>2</sub> )	0.0044	0.45	0.73	1.10	1.40
Nitrogen Dioxide (NO <sub>2</sub> )	0.0047	0.20	0.37	0.43	0.52
Particulates (PM <sub>10</sub> )	0.0024	0.064	0.10	0.11	0.15
Carbon Monoxide (CO)	0.032	1.04	1.62	1.85	2.33
Fluorides (F)	0.000072	0.00094	0.0015	0.0017	0.0021
Sulfuric Acid Mist (SAM)	0.00030	0.032	0.050	0.057	0.071
Lead (Pb)	0.000021	0.00038	0.00060	0.00068	0.00086

<sup>a</sup> Highest Predicted with CALPUFF model and South Florida CALMET Windfield, 1990.

Table 7-2. SO<sub>2</sub> Effects Levels for Various Plant Species

Plant Species	Observed Effect Level ( $\mu\text{g}/\text{m}^3$ )	Exposure (Time)	Reference
Sensitive to tolerant	920 (20 percent displayed visible injury)	3 hours	McLaughlin and Lee, 1974
Lichens	200-400	6 hr/wk for 10 weeks	Hart <i>et al.</i> , 1988
Cypress, slash pine, live oak, mangrove	1,300	8 hours	Woltz and Howe, 1981
Jack pine seedlings	470-520	24 hours	Malhotra and Kahn, 1978
Black oak	1,310	Continuously for 1 week	Carlson, 1979

Table 7-3. Sensitivity Groupings of Vegetation Based on Visible Injury at Different SO<sub>2</sub> Exposures<sup>a</sup>

Sensitivity Grouping	SO <sub>2</sub> Concentration		Plants
	1-Hour	3-Hour	
Sensitive	1,310 - 2,620 µg/m <sup>3</sup> (0.5 - 1.0 ppm)	790 - 1,570 µg/m <sup>3</sup> (0.3 - 0.6 ppm)	Ragweed Legumes Blackberry Southern pines Red and black oaks White ash Sumacs
Intermediate	2,620 - 5,240 µg/m <sup>3</sup> (1.0 - 2.0 ppm)	1,570 - 2,100 µg/m <sup>3</sup> (0.6 - 0.8 ppm)	Maples Locust Sweetgum Cherry Elms Tuliptree Many crop and garden species
Resistant	>5,240 µg/m <sup>3</sup> (>2.0 ppm)	>2,100 µg/m <sup>3</sup> (>0.8 ppm)	White oaks Potato Upland cotton Corn Dogwood Peach

<sup>a</sup> Based on observations over a 20-year period of visible injury occurring on over 120 species growing in the vicinities of coal-fired power plants in the southeastern United States.

Source: EPA, 1982a.

Table 7-4. Fluoride Effect Levels for Various Plant Species

Plant Species	Observed Effect Level ( $\mu\text{g}/\text{m}^3$ )	Exposure Time	Reference
Sensitive to Tolerant Species	16-500	3-Hour	Applied Sciences Associates, Inc., 1978
Sensitive Species (represents the lowest observed effect level known)	50	1-Hour	Applied Sciences Associates, Inc., 1978
	16	3-Hour	
	1.6	24-Hour	
Gladiolus	0.5	5-10 days	Treshow and Anderson, 1989
Tolerant fruit tree species and conifers	1	10 day	Treshow and Anderson, 1989

Table 7-5. Examples of Reported Effects of Air Pollutants on Animals at Concentrations Below National Secondary Ambient Air Quality Standards

Pollutant	Reported Effect	Concentration ( $\mu\text{g}/\text{m}^3$ )	Exposure
Sulfur Dioxide <sup>1</sup>	Respiratory stress in guinea pigs	427 to 854	1 hour
	Respiratory stress in rats	267	7 hours/day; 5 day/week for 10 weeks
	Decreased abundance in deer mice	13 to 157	continually for 5 months
Nitrogen Dioxide <sup>2,3</sup>	Respiratory stress in mice	1,917	3 hours
	Respiratory stress in guinea pigs	96 to 958	8 hours/day for 122 days
Particulates <sup>1</sup>	Respiratory stress, reduced respiratory disease defenses	120 PbO <sub>3</sub>	continually for 2 months
	Decreased respiratory disease defenses in rats, same with hamsters	100 NiCl <sub>2</sub>	2 hours

Source: <sup>1</sup>Newman and Schreiber, 1988.

<sup>2</sup>Gardner and Graham, 1976.

<sup>3</sup>Trzeciak et al., 1977.

Table 7-6. Maximum Sulfur and Nitrogen Annual Deposition Predicted at the PSD  
Class I Area of the Everglades National Park, New Hope Power Partnership

Species/Operating Mode	Total Deposition (Wet & Dry)		Deposition Analysis
	( $\mu\text{g}/\text{m}^2/\text{s}$ )	( $\text{kg}/\text{ha}/\text{yr}$ ) <sup>b</sup>	Threshold
Nitrogen (N) Deposition	7.33E-06	2.31E-03	0.01
Sulfur (S) Deposition	1.24E-05	3.90E-03	0.01

<sup>a</sup> Conversion factor is used to convert  $\mu\text{g}/\text{m}^2/\text{s}$  to  $\text{kg}/\text{hectare (ha)}/\text{yr}$  using following units:

$$\begin{array}{l}
 \mu\text{g}/\text{m}^2/\text{s} \times 0.000001 \text{ g}/\mu\text{g} \\
 \times 0.001 \text{ kg}/\text{g} \\
 \times 10000 \text{ m}^2/\text{hectare} \\
 \times 3600 \text{ sec}/\text{hr} \\
 \times 8760 \text{ hr}/\text{yr} = \text{kg}/\text{ha}/\text{yr} \\
 \text{or} \\
 \mu\text{g}/\text{m}^2/\text{s} \times 315.36 = \text{kg}/\text{ha}/\text{yr}
 \end{array}$$

<sup>b</sup> Deposition analysis thresholds (DAT) for nitrogen and sulfur deposition provided by the U.S. Fish and Wildlife Service, January 2002. DAT is the additional amount of N or S deposition within a Class I area, below which estimated impacts from a proposed new or modified source are considered insignificant.

## REFERENCES

- Ashenden, T.W. and I.A.D. Williams. 1980. Growth Reductions on *Lolium multiflorum* Lam. and *Phleum pratense* L. as a Result of SO<sub>2</sub> and NO<sub>2</sub> pollution. Environ. Pollut. Ser. A. 21:131-139.
- Carlson, R.W. 1979. Reduction in the Photosynthetic Rate of *Acer quercus* and *Fraxinus* Species Caused by Sulphur Dioxide and Ozone. Environ. Pollut. 18:159-170.
- Coen Company, Inc. 1991. Introduction to Coen Low-NO<sub>x</sub> Burner Technologies.
- Engelhard Corporation. 1991. Catalyst Technology for Cleaner Air.
- Florida Department of Environmental Protection. 1995. Florida Air Toxics Working List (Version 4.0).
- Gough, L.P., Shacklette, H.T., and A.A. Case. 1979. Element concentrations toxic to plants, animals, and man. U.S. Geological Survey Bulletin 1466. U.S. Government Printing Office, Washington, DC.
- Hart, R., P.G. Webb, R.H. Biggs, and K.M. Portier. 1988. The Use of Lichen Fumigation Studies to Evaluate the Effects of New Emission Sources on Class I Areas. J. Air Poll. Cont. Assoc. 38:144-147.
- Heck, W.W. and D.T. Tingey. 1979. Nitrogen Dioxide: Time-Concentration Model to Predict Acute Foliar Injury. EPA-600/3-79-057, U.S. Environmental Protection Agency, Corvallis, OR.
- Horsman, D.C. and Wellburn, A.R.. 1976. Guide to Metabolic and Biochemical Effects of Air Pollutants in Higher Plants (Appendix II). Editor T.A. Mansfield. Cambridge University Press, Cambridge, England.
- Johnson, A. and Lockert, C. 2002. Cost-Competitive NO<sub>x</sub> compliance for Coal-Fired Boilers
- Johnson-Matthey Catalyst Systems Division. 1990. Standard Technical Sales Literature.
- Malhotra, S.S. and A.A. Kahn. 1978. Effect of Sulfur Dioxide Fumigation on Lipid Biosynthesis in Pine Needles. Phytochemistry 17:241-244.
- Matsumaru, T., T. Yoneyama, T. Totsuka, and K. Shiratori. 1979. Absorption of Atmospheric NO<sub>2</sub> by Plants and Soils. Soil Sci. Plant Nutr. 25:255-265.
- McLaughlin, S.B. and N.T. Lee. 1974. Botanical Studies in the Vicinity of the Widows Creek Steam Plant. Review of Air Pollution Effects Studies, 1952-1972, and Results of 1973 Surveys. Internal Report I-EB-74-1, TVA.
- Newman, J.R. 1981. Effects of Air Pollution on Animals at Concentrations at or Below Ambient Air Standards. Performed for Denver Air Quality Office, National Park Service, U.S. Department of the Interior. Denver, Colorado.



- Newman, J.R. 1975. Fluoride Standards Predicting Wildlife Effects, *Fluoride* 17:41-47.
- Newman, J.R. and R.K. Schreiber. 1988. Air Pollution and Wildlife Toxicology. *Environmental Toxicology and Chemistry*. 7:381-390.
- Pollok, M., U. Hever, and M.S. Naik. 1989. Inhibition of stomatal opening in sunflower leaves by carbon monoxide and reversal of inhibition by light. *Planta* 178:223-230.
- Treshow and Anderson. 1989. *Plant Stress from Air Pollution*. John Wiley and Sons. New York.
- Woltz, S.S. and T.K. Howe. 1981. Effects of Coal Burning Emissions on Florida Agriculture. In: *The Impact of Increased Coal Use in Florida*. Interdisciplinary Center for Aeronomy and (other) Atmospheric Sciences. University of Florida, Gainesville, Florida.
- Zahn, R. 1975. Gassing Experiments with NO<sub>2</sub> in Small Greenhouses. *Staub Reinhalt. Luft* 35:194-196.

**APPENDIX A**

**BASIS OF ACTUAL EMISSIONS**

Table A-1. Current Actual Emissions (January 2000 through December 2001), New Hope Power Partnership

Boiler	Operating Hours	Heat Input (MMBtu/yr)	Actual Annual Emissions (tons) <sup>c</sup>									
			PM	PM <sub>10</sub>	SO <sub>2</sub>	NO <sub>x</sub>	CO	VOC	Pb	Hg	F	SAM
<u>Calendar Year 2000<sup>a</sup></u>												
Boiler A	6,602	3,785,865	289.77	52.34	73.62	276.36	376.69	20.92	0.0134	0.0007	0.5751	5.655
Boiler B	6,312	3,640,829	77.88	21.91	72.81	265.77	500.61	12.15	0.0129	0.0006	0.5471	5.438
Boiler C	6,788	3,957,456	272.63	51.17	72.60	288.88	417.50	18.23	0.0250	0.0011	0.6851	5.907
Total--2000	19,702	11,384,150	172.50 <sup>c</sup>	125.42	219.03	831.01	1,294.80	51.30	0.0513	0.0024	1.8072	17.000
<u>Calendar Year 2001<sup>b</sup></u>												
Boiler A	5,455	3,056,969	28.62	30.07	55.02	217.04	360.71	7.43	0.0590	0.0016	0.9810	4.570
Boiler B	5,982	3,394,860	29.48	31.89	44.12	241.02	541.45	18.33	0.0440	0.0018	0.8310	5.078
Boiler C	6,321	3,202,078	25.31	28.65	65.63	224.14	473.89	10.79	0.0420	0.0013	0.7060	4.780
Total--2001	17,758	9,653,907	83.4	90.61	164.77	682.20	1,376.05	36.55	0.1450	0.0046	2.5181	14.427
<u>Average</u>												
Boiler A	6,029	3,421,417	159.19	41.20	64.32	246.70	368.70	14.17	0.0362	0.0011	0.7781	5.112
Boiler B	6,147	3,517,845	53.68	26.90	58.47	253.40	521.03	15.24	0.0285	0.0012	0.6891	5.258
Boiler C	6,555	3,579,767	148.97	39.91	69.12	256.51	445.70	14.51	0.0335	0.0012	0.6956	5.344
Average (Tons Per Year)	18,730	10,519,029	127.96	108.02	191.90	756.60	1,335.43	43.93	0.0982	0.0035	2.1627	15.714

<sup>a</sup> Obtained from 2000 Annual Operating Report.<sup>b</sup> Obtained from 2001 Annual Operating Report.<sup>c</sup> Annual emissions exceeded permit limit, therefore, permit limit was used.

**APPENDIX B**

**BASIS OF FUGITIVE EMISSIONS**

Table B-1. Estimation of Emission Factors and Rates For Vehicle  
Traffic on Unpaved Roads, New Hope Power Partnership

<i>General Data</i>	Pile Maintenance Front-end Loader
<b>Vehicle Data</b>	
Description	Biomass
Vehicle weight (W), tons- Loaded	27
- Unloaded	9
- Average	18
Vehicle miles traveled (VMT)- Annual	21,900 <sup>a</sup>
Speed (S), mph	5
<b>General/ Site Characteristics</b>	
Days of precipitation greater than or equal to 0.01 inch (p)- Annual	120
Silt content (s), %	5
Moisture Content Under Dry Conditions (M <sub>dr</sub> ), %	5.0
Particle size multiplier, PM (k), lb/VMT	10
Particle size multiplier, PM <sub>10</sub> (k), lb/VMT	2.6
<b>Emission Control Data</b>	
Emission control method	Watering
Emission control removal efficiency, %	50
<b>Calculated PM Emission Factor (EF)</b>	
Uncontrolled EF, lb/VMT - Annual	0.75
Controlled (Final) EF,lb/VMT- Annual	0.38
<b>Calculated PM<sub>10</sub> Emission Factor (EF)</b>	
Uncontrolled EF, lb/VMT - Annual	0.23
Controlled (Final) EF,lb/VMT- Annual	0.11
<b>Estimated Emission Rate (ER)</b>	
PM ER, lb/hr	1.88
TPY	4,110
PM <sub>10</sub> ER, lb/hr	0.56
TPY	1,233

**Emission Factor (EF) Equations**

Uncontrolled EF (UEF) Equation:

$$UEF(lb/VMT) = [(k \times (s/12)^a \times (W/3)^b) / (M_{dr}/0.2)^c] \times [(365-p)/365] \times [S/15]$$

Where constants a, b, c equal:

	PM	PM <sub>10</sub>
a	0.8	0.8
b	0.5	0.4
c	0.4	0.3

Controlled (Final) EF (CEF) Equation:

$$CEF(lb/VMT) = UEF (lb/ton) \times (100 - \text{Removal efficiency} (\%))$$

<sup>a</sup> Based on vehicle operating 12 hrs/day, 365 days/yr at 5 mph.

Table B-2. 2000 and 2001 Woodwaste and Bagasse Usage<sup>a</sup>  
New Hope Power Partnership

Unit	<u>Woodwaste</u>		<u>Bagasse</u>		<u>TOTAL</u>	
	Tons	MMBtu	Tons	MMBtu	Tons	MMBtu
Boiler A	189,603	1,763,308	277,682	1,999,310	467,285	3,762,618
Boiler B	188,786	1,755,710	258,337	1,860,026	447,123	3,615,736
Boiler C	204,465	1,901,525	282,382	2,033,150	486,847	3,934,675
TOTAL	582,854	5,420,543	818,401	5,892,486	1,401,255	11,313,029
AVG Btu/lb	4,500		3,600			

Percent Heating Value from Wood = 47.9  
Percent Heating Value from Bagasse = 52.1

New Hope Power Partnership Maximum Heat Input (3 boilers) =  $19.97 \times 10^{12}$  Btu/yr  
Estimated Heat Input Due to Wood =  $9.57 \times 10^{12}$   
Estimated Heat Input Due to Bagasse =  $1.04 \times 10^{13}$   
Wood Usage (TPY) = 1,063,162  
Bagasse Usage (TPY) = 1,444,659  
Total Usage (TPY) = 2,507,821  
Total Usage + 50% (TPY) = 3,761,731

fly ash =  $[(0.09 \times 1,063,162) + (0.01 \times 1,444,659)] \times 0.20$   
= 110,131 TPY

<sup>a</sup> Represents maximum of either 2000 or 2001 data.

Spreadsheet as of 11:57:11 on 03-28-1995

Output filename: bagpile.epc

Inventory area: Osceola Power L.P.

Source ID: Bagpile Filename: A:\Bagpile.EPC

Emissions estimate year: 94

Based on wind data year: 94

Fastest mile filename: westp94.met

System of units: English

Source life (inclusive days of year)

Start day: 1

End day: 365

F=flat area, PC=conical pile, PO=oval pile: PC

Pile height (ft): 30

Pile diameter (ft): 566

Area (sq ft): 252888.5

Material description: Bagasse/WW

Percent moisture content: 37

Percent silt content: 2.2

Threshold friction velocity,  $U^*t$ , (cm/sec): 112

Roughness height (cm): 0.3

Mode (mm) of size distribution 3.533677# (# denotes calculated value)

Lc value (cf. Fig. 6-3 of reference manual):

Frequency of disturbance information:

$J_r$  = .9 -- subarea # 1 -- 20 % of regime disturbed every 1 day(s)

$U_r$  = .6 -- subarea # 1 -- 20 % of regime disturbed every 1 day(s)

$U_s/U_r$  = .2 -- subarea # 1 -- 20 % of regime disturbed every 1 day(s)

Total emissions emitted over the period: 79243.23 g

Threshold velocity = 112 cm/s

Control: Effective windspeed ratio = 1

-----  
 $U_s/U_r$  = .9 Disturbance interval = 1 days

Period 9 - 10	high on 10	1.2069 m/s	735.9493 g emitted
Period 10 - 11	high on 10	1.2069 m/s	735.9493 g emitted
Period 15 - 16	high on 16	1.12644 m/s	46.0676 g emitted
Period 16 - 17	high on 16	1.12644 m/s	46.0676 g emitted
Period 33 - 34	high on 34	1.16667 m/s	364.5446 g emitted
Period 34 - 35	high on 34	1.16667 m/s	364.5446 g emitted
Period 44 - 45	high on 45	1.32759 m/s	2167.734 g emitted
Period 45 - 46	high on 46	1.40805 m/s	3386.895 g emitted
Period 46 - 47	high on 46	1.40805 m/s	3386.895 g emitted
Period 61 - 62	high on 62	1.85058 m/s	13876.62 g emitted
Period 62 - 63	high on 62	1.85058 m/s	13876.62 g emitted
Period 67 - 68	high on 68	1.24713 m/s	1160.283 g emitted
Period 68 - 69	high on 68	1.24713 m/s	1160.283 g emitted
Period 76 - 77	high on 77	1.16667 m/s	364.5446 g emitted
Period 77 - 78	high on 77	1.16667 m/s	364.5446 g emitted
Period 87 - 88	high on 88	1.12644 m/s	46.0676 g emitted

Period 88 - 89 high on 88 1.12644 m/s 46.0676 g emitted  
 Period 92 - 93 high on 93 1.24713 m/s 1160.283 g emitted  
 Period 93 - 94 high on 93 1.24713 m/s 1160.283 g emitted  
 Period 94 - 95 high on 94 1.16667 m/s 364.5446 g emitted  
 Period 139 - 140 high on 140 1.2069 m/s 735.9493 g emitted  
 Period 140 - 141 high on 141 1.24713 m/s 1160.283 g emitted  
 Period 141 - 142 high on 141 1.24713 m/s 1160.283 g emitted  
 Period 142 - 143 high on 142 1.2069 m/s 735.9493 g emitted  
 Period 167 - 168 high on 168 1.16667 m/s 364.5446 g emitted  
 Period 168 - 169 high on 168 1.16667 m/s 364.5446 g emitted  
 Period 191 - 192 high on 192 1.2069 m/s 735.9493 g emitted  
 Period 192 - 193 high on 193 1.56897 m/s 6460.352 g emitted  
 Period 193 - 194 high on 193 1.56897 m/s 6460.352 g emitted  
 Period 206 - 207 high on 207 1.2069 m/s 735.9493 g emitted  
 Period 207 - 208 high on 207 1.2069 m/s 735.9493 g emitted  
 Period 211 - 212 high on 212 1.32759 m/s 2167.734 g emitted  
 Period 212 - 213 high on 212 1.32759 m/s 2167.734 g emitted  
 Period 322 - 323 high on 323 1.2069 m/s 735.9493 g emitted  
 Period 323 - 324 high on 323 1.2069 m/s 735.9493 g emitted  
 Period 332 - 333 high on 333 1.12644 m/s 46.0676 g emitted  
 Period 333 - 334 high on 333 1.12644 m/s 46.0676 g emitted  
 Period 352 - 353 high on 353 1.16667 m/s 364.5446 g emitted  
 Period 353 - 354 high on 353 1.16667 m/s 364.5446 g emitted  
 Period 354 - 355 high on 354 1.12644 m/s 46.0676 g emitted

Summary for Us/Ur = .9 Disturbance Interval = 1  
 71139.55 Total g emitted over 1 - 365

-----  
 Us/Ur = .6 Disturbance interval = 1 days

Period 61 - 62 high on 62 1.23372 m/s 4051.837 g emitted  
 Period 62 - 63 high on 62 1.23372 m/s 4051.837 g emitted

Summary for Us/Ur = .6 Disturbance Interval = 1  
 8103.673 Total g emitted over 1 - 365

-----  
 Us/Ur = .2 Disturbance interval = 1 days

Summary for Us/Ur = .2 Disturbance Interval = 1  
 0 Total g emitted over 1 - 365

-----  
 Summary for entire source: 79243.23 g emitted over period 1 - 365

NOTE: For a variety of reasons given in the user manual, the erosion estimates presented above may be considered as CONSERVATIVELY HIGH. See the user manual for more information.



**APPENDIX C**

**SUMMARY OF NHPP STACK TESTS**

Table C-1. Summary of New Hope Power Stack Tests - Biomass Firing

Pollutant	Stack Testing: 02/12/02 - 02/14/02 Post-Mechanical Dust Collectors		
	Unit A Biomass (lb/MMBtu)	Unit B Biomass (lb/MMBtu)	Unit C Biomass (lb/MMBtu)
Particulate (TSP)	0.008	0.010	0.011
Particulate (PM <sub>10</sub> )	0.008	0.010	0.011
VOCs	0.007	0.036	0.020
Lead	2.08E-05	1.41E-05	2.09E-05
Mercury	1.65E-06	9.70E-07	3.68E-06

Sources: Air Consulting Engineering, Inc., 2002; Golder, 2002

Note: Biomass firing consisted of approximately 50% wood  
and 50% bagasse.

Table C-2. Okeelanta Power/New Hope Power Stack Tests - Wood Firing

Pollutant	Stack Testing: 01/99-02/99 Pre-Mechanical Dust Collectors			Stack Testing: 12/99-01/00 Pre-Mechanical Dust Collectors			Stack Testing: 01/3/01-01/23/01 Post-Mechanical Dust Collectors		
	Unit A Wood (lb/MMBtu)	Unit B Wood (lb/MMBtu)	Unit C Wood (lb/MMBtu)	Unit A Wood (lb/MMBtu)	Unit B Wood (lb/MMBtu)	Unit C Wood (lb/MMBtu)	Unit A Wood (lb/MMBtu)	Unit B Wood (lb/MMBtu)	Unit C Wood (lb/MMBtu)
Particulate (TSP)	0.14	0.08	0.43	0.138	0.053	0.078	0.022	0.013	0.022
Particulate (PM <sub>10</sub> )	0.02	0.02	0.05	0.0266	0.0148	0.0158	0.025	0.0135	0.023
Sulfur Dioxide	0.03	0	0	0.031	0.0217	0.0357	0.032	0.019	0.03
Nitrogen Oxides	0.13	0.117	0.14	0.152	0.15	0.161	0.18	0.15	0.15
Carbon Monoxide	0.14	0.34	0.35	0.130	0.290	0.267	0.16	0.31	0.22
VOCs	0.004	0.005	0.006	0.012	0.006	0.006	0.002	0.014	0.003
Arsenic	4.80E-05	9.92E-05	4.88E-04*	1.53E-05	9.05E-06	1.60E-05	1.13E-04	2.50E-05	3.78E-05
Beryllium	<4.28E-07	5.09E-07	6.09E-07*	<2.56E-07	<2.61E-07	<2.68E-07	<1.16E-07	<1.10E-07	<1.05E-07
Chromium	2.36E-05	4.35E-05	3.11E-04*	8.72E-06	2.12E-05	1.11E-05	4.12E-05	2.04E-05	2.71E-05
Copper	4.78E-05	7.31E-05	2.89E-04*	2.60E-05	1.61E-05	3.08E-05	3.76E-05	1.42E-05	2.13E-05
Lead	3.00E-05	8.40E-05	4.00E-04*	1.19E-05	7.97E-06	1.75E-05	7.49E-05	1.97E-05	3.91E-05
Mercury	1.20E-06	1.50E-06	3.60E-06	6.25E-07	4.28E-07	6.52E-07	8.07E-07	8.09E-07	7.41E-07
Fluorides	9.38E-05	5.07E-05	1.13E-04	1.50E-04	1.60E-04	3.10E-04	7.00E-04	6.00E-04	6.00E-04
Sulfuric Acid Mist									

Sources: Air Consulting Engineering, Inc., 2001; Golder, 2001

\* Results may not be representative due to high PM emissions.

Table C-3. Summary of Okeelanta Power/New Hope Power Stack Tests - Bagasse Firing

Pollutant	Stack Testing: 1/22/99-2/5/99 Pre-Mechanical Dust Collectors			Stack Testing: 12/99 - 01/00 Pre-Mechanical Dust Collectors			Stack Testing: 01/3/01-01/23/01 Post-Mechanical Dust Collectors		
	Unit A (lb/MMBtu)	Unit B (lb/MMBtu)	Unit C (lb/MMBtu)	Unit A (lb/MMBtu)	Unit B (lb/MMBtu)	Unit C (lb/MMBtu)	Unit A (lb/MMBtu)	Unit B (lb/MMBtu)	Unit C (lb/MMBtu)
Particulate (TSP)	0.27	0.12	0.20	0.221	0.039	0.230	0.016	0.021	0.010
Particulate (PM <sub>10</sub> )	0.02	0.01	0.02	0.0282	0.0092	0.0308	0.0153	0.0232	0.0131
Sulfur Dioxide	0.02	0	0	0.0011	0.0080	0.0143	0.022	0.019	0.014
Nitrogen Oxides	0.13	0.12	0.13	0.138	0.142	0.179	0.19	0.17	0.17
Carbon Monoxide	0.16	0.26	0.28	0.377	0.354	0.299	0.24	0.21	0.24
Volatile Organic Compounds	0.01	0.02	0.007	0.010	0.007	0.012	0.007	0.008	0.01
Arsenic	3.18E-05	6.50E-06	4.92E-06	1.40E-06	5.42E-06	8.46E-06	6.34E-05	4.17E-05	4.40E-05
Beryllium	<3.77E-07	<3.94E-07	<1.25E-07	<2.22E-07	<2.34E-07	<2.52E-07	<1.10E-07	<1.07E-07	1.76E-07
Chromium	9.33E-06	5.85E-06	5.40E-06	2.15E-06	4.54E-06	6.57E-06	5.22E-05	2.91E-05	2.41E-05
Copper	2.55E-05	1.03E-05	1.33E-05	8.67E-06	1.43E-05	2.67E-05	2.38E-05	2.23E-05	1.18E-05
Lead	2.00E-05	7.30E-06	6.30E-06	3.41E-06	6.68E-06	9.77E-06	3.81E-05	4.76E-05	1.63E-05
Mercury	4.41E-07	3.83E-07	5.41E-07	1.26E-07	1.68E-07	5.34E-07	1.29E-06	1.41E-06	8.38E-07
Fluorides	7.06E-05	4.07E-05	3.04E-05	3.70E-04	4.40E-04	3.90E-04	6.00E-04	4.00E-04	3.00E-04

Sources: Air Consulting Engineering, Inc., 2001; Golder, 2001

**APPENDIX D**

**SUMMARY OF PREVIOUS  
BACT DETERMINATIONS**

Table D-1. BACT Determinations for PM/PM<sub>10</sub> for Biomass-Fired Industrial and Electric Utility Boilers

Company	State	RBLC ID	Permit Date	Throughput	Emission Limits		Control Equipment Description	% Efficiency
					As Provided in LAER/BACT Clearinghouse	Converted to lb/MMBtu <sup>a</sup>		
<b>Industrial Boilers</b>								
ATLANTIC SUGAR ASSOCIATION	FL	PSD-FL-078B <sup>b</sup>	6/7/01	255.3 MMBtu/hr	0.15 lb/MMBtu	0.15	Wet scrubbers/Good Combustion Practices	--
US Sugar Corp.--Clewiston Bfr No. 4	FL	PSD-FL-272A <sup>b</sup>	5/18/01	633 MMBtu/hr	0.15 lb/MMBtu	0.15	Wet scrubber; Good combustion practices	--
Newman Paper Co	PA	PA-0093	10/14/98	129 MMBtu/hr	0.1 lb/MMBtu	0.1	Baghouse	--
GULF STATES PAPER CORP	AL	AL-0122	10/14/98	98 MMBtu/hr	0.1 lb/MMBtu	0.1	Multicyclone and ESP	99
Sierra Pacific Industries--Quincy	CA	CA-0930	5/13/98	245.3 MMBtu/hr	0.035 lb/MMBtu	0.035	Multicyclone and ESP	--
Champion International	AL	AL-0112	12/9/97	710 MMBtu/hr	0.03 lb/MMBtu	0.03	ESP	--
Vaughan Furniture Company	VA	VA-0237	8/28/96	28 MMBtu/hr	36.8 TPY <sup>a</sup>	0.3	Multicyclones, equip. w/ device to cont. measure differ. press. drop	90
Willamette Industries - Marlboro Mill	SC	SC-0045	4/17/96	470 MMBtu/hr	0.05 lb/MMBtu	0.05	ESP	--
U.S. SUGAR CORP.--Clewiston	FL	FL-0094	1/31/95	738 MMBtu/hr	0.03 lb/MMBtu	0.03	ESP	--
Weverhacuser Co.	AL	AL-0079	12/23/94	91 MMBtu/hr	0.15 lb/MMBtu	0.15	Venturi Scrubber (Zurn Ind. Model MTSA-35-11.5 CVTA-STD)	--
KES CHATEAUGAY PROJECT	NY	NY-0055	12/19/94	275 MMBtu/hr	0.038 lb/MMBtu	0.038	ZURN MULTICLONE, ESP	99
Gulf States Paper Corp	AL	AL-0122	10/28/94	98 MMBtu/hr	0.1 lb/MMBtu	0.1	Multicyclone and ESP	--
WEYERHAEUSER CO.	AL	AL-0079	10/28/94	91 MMBtu/hr	0.15 lb/MMBtu	0.15	Venturi Scrubber (Zurn Ind. Model MTSA-35-11.5 CVTA-STD)	97
Scott Paper Company	WA	WA-0276	7/1/93	718 MMBtu/hr	0.0084 gr/dscf @ 7% O <sub>2</sub> for PM <sub>10</sub>	--	Baghouse	--
NEWMAN PAPER CO	PA	PA-0093	4/24/92	129 MMBtu/hr	0.1 lb/MMBtu	0.1	BAGHOUSE	99
Scott Paper Company	WA	WA-0276	4/24/92	718 MMBtu/hr	0.011 gr/dscf @ 7% O <sub>2</sub> for PM	--	Baghouse	--
<b>Electric Utility Boilers</b>								
New Hope Power Partnership	FL	FL-0069	1/31/02	715 MMBtu/hr	0.03 lb/MMBtu	0.03	Good combustion practices, ESP	--
MEAD CONTAINERBOARD	AL	AL-0099	1/15/97	620 MMBtu/hr	0.03 lb/MMBtu	0.03	Multicyclone and ESP	99.2
Multitrade Limited Partnership	VA	VA-0183	2/21/92	373.7 MMBtu/hr	0.02 lb/MMBtu	0.02	Multicyclone and ESP	99.7

Reference: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2001.

<sup>a</sup> To convert from lb/hr, the emission limit was divided by the throughput rate.<sup>b</sup> This information obtained from actual PSD permit, not Clearinghouse.

Table D-2. BACT Determinations for SO<sub>2</sub> and SO<sub>x</sub> for Biomass-Fired Industrial and Electric Utility Boilers

Company	State	RBLC ID	Permit Date	Throughput	Emission Limits		Control Equipment Description	% Efficiency
					As Provided in LAER/BACT Clearinghouse	Converted to lb/MMBtu <sup>a</sup>		
<b>Industrial Boilers</b>								
US Sugar Corp.--Clewiston Bjr No. 4	FL	PSD-FL-272A <sup>c</sup>	5/18/01	633 MMBtu/hr	0.06 lb/MMBtu	0.06	Fuel oil S limit; bagasse firing	--
GULF STATES PAPER CORPORATION	AL	AL-0116	12/10/97	775 MMBtu/hr	355.7 lb/hr	0.46	Proper design & oper. Wood ash alkalinity acts as scrubbing media.	--
Champion International	AL	AL-0112	12/9/97	710 MMBtu/hr	0.03 lb/MMBtu	0.03	Wet scrubber with soda ash	95
Vaughan Furniture Company	VA	VA-0237	8/28/96	28 MMBtu/hr	66,599 TPY <sup>b</sup>	0.54	Fuel spec: 0.75% sulfur coal and throughput limit	--
Willamette Industries - Marlboro Mill	SC	SC-0045	4/17/96	470 MMBtu/hr	0.1 lb/MMBtu	0.1	No controls feasible	--
Scott Paper Company	WA	WA-0276	3/9/95	718 MMBtu/hr	70 lb/hr 12 mo. avg.	0.10	Fuel spec: backup fuel limited to 0.05% sulfur distillate	--
KES CHATEAUGAY PROJECT	NY	NY-0055	12/19/94	275 MMBtu/hr	0.03 lb/MMBtu	0.03	Fuel spec. oil less than 0.08% by wgt sulfur content	--
<b>Electric Utility Boilers</b>								
New Hope Power Partnership	FL	FL-0069	1/31/02	715 MMBtu/hr	0.20 lb/MMBtu (24-hr avg.)	0.20	Low S suppl. Fuel; ESP; SNCR; carbon injection	--
					0.06 lb/MMBtu (Annual avg.)	0.06	Low S suppl. Fuel; ESP; SNCR; carbon injection	--
Grayling Generating Station L.P.	MI	MI-882-89E	9/18/01	523 MMBtu/hr	11.2 lb/hr (24-hr avg.)	0.02	Multicyclones, ESP, SNCR	--
MEAD CONTAINERBOARD	AL	AL-0099	1/15/97	620 MMBtu/hr	0.02 lb/MMBtu	0.02	Combustion control	--
OKEELANTA POWER LIMITED PARTNERSHIP	FL	FL-0069	9/27/93	715 MMBtu/hr	0.02 lb/MMBtu 30-day avg.	0.02	FUEL SPEC: LOW S SUPP. FUEL. APCE INCLUDES ESP, SNCR, AND CARBON INJECTION.	--
OSCEOLA POWER LIMITED PARTNERSHIP	FL	FL-0070	9/27/93	665 MMBtu/hr	0.02 lb/MMBtu 30-day avg.	0.02	FUEL SPEC: LOW SULFUR SUPPLEMENTAL FUEL	--
Wheelabrator Ridge Energy Inc.	FL	FL-0198	9/29/92	630 MMBtu/hr	0.1 lb/MMBtu	0.1	Limespray dryer absorber	--
Multitrade Limited Partnership	VA	VA-0183	2/21/92	373.7 MMBtu/hr	0.016 lb/MMBtu	0.016	No controls feasible	--

Reference: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2001.

<sup>a</sup> To convert from lb/hr, the emission limit was divided by the throughput rate. To convert from lb/day, assumed 24 hr/day operation.<sup>b</sup> Assumed 8,760 hr/yr.<sup>c</sup> This information obtained from actual PSD permit, not Clearinghouse.

Table D-3. BACT Determinations for NO<sub>x</sub> and NO<sub>2</sub> for Biomass-Fired Industrial and Electric Utility Boilers

Company	State	RBLC ID	Permit Date	Throughput	Emission Limits		Control Equipment Description	% Efficiency
					As Provided in LAER/BACT Clearinghouse	Converted to lb/MMBtu <sup>a</sup>		
<b>Industrial Boilers</b>								
US Sugar Corp.--Clewiston Blr No. 4	FL	PSD-FL-272A <sup>c</sup>	5/18/01	633 MMBtu/hr	0.20 lb/MMBtu	0.20	Bagasse firing	--
Atlantic Sugar Association	FL	PSD-FL-078B <sup>c</sup>	6/7/01	255.3 MMBTU/HR	0.16 lb/MMBtu	0.16	Wet Scrubbers/Good Combustion Practices	--
GULF STATES PAPER CORP	AL	AL-0122	10/14/98	98 MMBTU/HR	0.3 lb/MMBtu	0.3		--
POTLATCH CORPORATION	MN	MN-0033	6/24/98	140 MMBTU/HR	0.3 lb/MMBtu	0.3	Water vapor inj. & staged combustion	--
WELLBORN CABINET INC	AL	AL-0107	2/3/98	29.5 MMBTU/HR	13.57 lb/hr	0.46	Boiler design & comb. Control: oxygen trim, staged comb., steam injection, & overfire air.	31
GULF STATES PAPER CORPORATION	AL	AL-0116	12/10/97	775 MMBTU/HR	0.3 lb/MMBtu	0.3	Low Nox natural gas & fuel oil burner	50
Champion International	AL	AL-0112	12/9/97	710 MMBtu/hr	0.25 lb/MMBtu	0.25	Addition of tertiary air system	30
PLUM CREEK MFG - EVERGREEN FACILITY	MT	MT-0007	2/15/97	225 MMBTU/HR	104 lb/hr	0.46		--
Vaughan Furniture Company	VA	VA-0237	8/28/96	28 MMBtu/hr	24 TPY <sup>b</sup>	0.20	No controls feasible	--
Willamette Industries - Marlboro Mill	SC	SC-0045	4/17/96	470 MMBtu/hr	0.3 lb/MMBtu	0.3	Good combustion control	--
U.S. SUGAR CORP--Clewiston	FL	FL-0094	1/31/95	738 MMBTU/HR	0.25 lb/MMBtu	0.25	LOW NOX BURNERS	--
Scott Paper Company	WA	WA-0276	12/21/94	718 MMBtu/hr	150 ppm @ 7% O <sub>2</sub> 30/day avg	--	Combustion controls	--
KES CHATEAUGAY PROJECT	NY	NY-0055	12/19/94	275 MMBTU/HR	0.23 lb/MMBtu	0.23	NO CONTROLS	--
WEYERHAEUSER CO.	AL	AL-0079	10/28/94	91 MMBTU/HR	0.23 lb/MMBtu	0.23		--
NEWMAN PAPER CO.	PA	PA-0093	4/24/92	129 MMBTU/HR	0.3 lb/MMBtu	0.3	LOW NOX BURNERS	--
<b>Electric Utility Boilers</b>								
Grayling Generating Station L.P.	MI	882-89E	9/18/01	523 MMBTU/HR	78.5 lb/hr (24-hr avg.)	0.15	Multicyclones, ESP, SNCR	--
MEAD CONTAINERBOARD	AL	AL-0099	1/15/97	620 MMBTU/HR	0.25 lb/MMBtu	0.25	COMBUSTION CONTROL	--
WEYERHAEUSER COMPANY	MS	MS-0026	5/9/95	90 MMBTU HR	0.23 lb/MMBtu	0.23	COMBUSTION CONTROLS	--
GEORGIA PACIFIC CORP. - GLOSTEE FACILITY	MS	MS-0023	4/11/95	244 MMBTU/HR	0.3 lb/MMBtu	0.3		--
Wheelabrator Ridge Energy Inc.	FL	FL-0198	9/29/92	630 MMBtu/hr	0.14 lb/MMBtu	0.14	SNCR	--
Multitrade Limited Partnership	VA	VA-0183	2/21/92	373.7 MMBtu/hr	0.1 lb/MMBtu	0.1	SNCR, Urea injection system	50

Reference: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2001.

<sup>a</sup> To convert from lb/hr, the emission limit was divided by the throughput rate. To convert from lb/day, assumed 24 hr/day operation.<sup>b</sup> Assuming 8,760 hr/yr.<sup>c</sup> This information obtained from actual PSD permit, not Clearinghouse.



Table D-4. BACT Determinations for CO for Biomass-Fired Industrial and Electric Utility Boilers

Company	State	RBLC ID	Permit Date	Throughput	Emission Limits		Control Equipment Description
					As Provided in LAER/BACT Clearinghouse	Converted to lb/MMBtu <sup>a</sup>	
<b>Industrial Boilers</b>							
US Sugar Corp.--Clewiston Blr No. 4	FL	PSD-FL-272A <sup>c</sup>	5/18/01	633 MMBtu/hr	6.5 lb/MMBtu	6.5	Good combustion practices
Atlantic Sugar Association	FL	PSD-FL-078B <sup>c</sup>	6/7/01	255.3 MMBtu/hr	6.5 lb/MMBtu	6.5	Wet Scrubbers/Good Combustion Practices
GULF STATES PAPER CORP	AL	AL-0122	10/14/98	98 MMBtu/hr	0.5 lb/MMBtu	0.5	
WELLBORN CABINET INC	AL	AL-0107	2/3/98	29.5 MMBtu/hr	23.6 lb/hr	0.8	Boiler design & comb. Control: oxygen trim, staged comb., steam injections, & overfire air.
Champion International	AL	AL-0112	12/9/97	710 MMBtu/hr	0.03 lb/MMBtu	0.03	Proper design and good combustion practices
PLUM CREEK MFG - EVERGREEN FACILITY	MT	MT-0007	2/15/97	225 MMBtu/hr	506 lb/hr	2.25	GOOD COMBUSTION
Vaughan Furniture Company	VA	VA-0237	8/28/96	28 MMBtu/hr	104.2 TPY <sup>b</sup>	0.85	No controls feasible
Sugar Cane Growers Coop.	FL	FL-0220	6/4/96	504 MMBtu/hr	5.5 lb/MMBtu	5.5	Good combustion practices.
Willamette Industries - Marlboro Mill	SC	SC-0045	4/17/96	470 MMBtu/hr	0.3 lb/MMBtu	0.3	Good combustion control
PLUM CREEK MFG LP-COLUMBIA FALLS OP'N	MT	MT-0005	7/26/95	292.4 MMBtu/hr	468 lb/hr	1.60	Good combustion controls
WEYERHAEUSER COMPANY	MS	MS-0026	5/9/95	90 MMBtu/hr	0.4 lb/MMBtu	0.4	Good combustion controls
U.S. SUGAR CORP.--Clewiston	FL	FL-0094	1/31/95	738 MMBtu/hr	6.5 lb/MMBtu	6.5	Good combustion practices.
KES CHATEAUGAY PROJECT	NY	NY-0055	12/19/94	275 MMBtu/hr	0.35 lb/MMBtu	0.35	NO CONTROLS
Scott Paper Company	WA	WA-0276	7/1/93	718 MMBtu/hr	511 ppm @ 7% O <sub>2</sub>	--	Combustion control, boiler design
NEWMAN PAPER CO.	PA	PA-0093	4/24/92	129 MMBtu/hr	0.3 lb/MMBtu	0.3	Good combustion practices.
<b>Electric Utility Boilers</b>							
New Hope Power Partnership	FL	FL-0069	1/31/02	715 MMBtu/hr	0.5 lb/MMBtu, 30-day avg.	0.5	Good combustion practices
MEAD CONTAINERBOARD	AL	AL-0099	1/15/97	620 MMBtu/hr	0.4 lb/MMBtu	0.4	COMBUSTION CONTROL
WEYERHAEUSER CO.	AL	AL-0079	10/28/94	91 MMBtu/hr	1.4 lb/MMBtu	1.4	
Wheelabrator Ridge Energy Inc.	FL	FL-0198	9/29/92	630 MMBtu/hr	0.32 lb/MMBtu	0.32	Good combustion practices
Multitrade Limited Partnership	VA	VA-0183	2/21/92	373.7 MMBtu/hr	0.35 lb/MMBtu	0.4	Boiler design

Reference: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2001.

<sup>a</sup> To convert from lb/hr, the emission limit was divided by the throughput rate.<sup>b</sup> Assuming 8,760 hr/yr.<sup>c</sup> This information obtained from actual PSD permit, not Clearinghouse.

Table D-5. BACT Determinations for VOC for Biomass-Fired Industrial and Electric Utility Boilers

Company	State	RBLC ID	Permit Date	Throughput	Emission Limits		Control Equipment Description
					As Provided in LAER/BACT Clearinghouse	Converted to lb/MMBtu <sup>d</sup>	
<b>Industrial Boilers</b>							
US Sugar Corp.--Clewiston Bir No. 4	FL	PSD-FL-272A <sup>b</sup>	5/18/01	633 MMBtu/hr	0.50 lb/MMBtu	0.50	Good combustion practices
Atlantic Sugar Association	FL	PSD-FL-078B <sup>b</sup>	6/7/01	255.3 MMBtu/hr	0.25 lb/MMBtu	0.25	Wet Scrubbers/Good Combustion Practices
Scott Paper Company	WA	WA-0276	10/14/98	718 MMBtu/hr	34.5 lb/hr	0.05	Combustion control, boiler design
GULF STATES PAPER CORP	AL	AL-0122	10/14/98	98 MMBtu/hr	0.1 lb/MMBtu	0.1	Multicyclone and ESP
Sierra Pacific Industries--Quincy	CA	CA-0930	5/13/98	245.3 MMBtu/hr	12.3 lb/hr	0.05	High pressure overfire air
GULF STATES PAPER CORPORATION	AL	AL-0116	12/10/97	775 MMBtu/hr	0.03 lb/MMBtu	0.03	Proper boiler design and operation
Champion International	AL	AL-0112	12/9/97	710 MMBtu/hr	0.03 lb/MMBtu	0.03	Good design and operation
Vaughan Furniture Company	VA	VA-0237	8/28/96	28 MMBtu/hr	1.7 TPY	--	Combustion control, boiler design
Willamette Industries - Marlboro Mill	SC	SC-0045	4/17/96	470 MMBtu/hr	0.1 lb/MMBtu	0.1	Good combustion control
SOUTHERN SOYA CORPORATION	SC	SC-0035	10/2/95	58.2 MMBtu/hr	0.05 lb/MMBtu	0.05	Good combustion practices
PLUM CREEK MFG LP-COLUMBIA FALLS OP'n	MT	MT-0004	7/26/95	50 MMBtu/hr	131.1 lb/hr	2.62	Good combustion practices
KES CHATEAUGAY PROJECT	NY	NY-0055	12/19/94	275 MMBtu/hr	0.1 lb/MMBtu	0.1	NO CONTROLS
Plum Creek MFG LP-Columbia Falls Op'n	MT	MT-0004	10/28/94	50 MMBtu/hr	131.1 lb/hr	2.6	Good combustion practices
WEYERHAEUSER CO.	AL	AL-0079	10/28/94	91 MMBtu/hr	0.05 lb/MMBtu	0.05	
Weyerhaeuser Co.	AL	AL-0079	7/1/93	91 MMBtu/hr	0.05 lb/MMBtu	0.05	--
Gulf States Paper Corp	AL	AL-0122	7/1/93	98 MMBtu/hr	0.1 lb/MMBtu	0.1	Multicyclone and ESP
<b>Electric Utility Boilers</b>							
New Hope Power Partnership	FL	FL-0069	1/31/02	715 MMBtu/hr	0.06 lb/MMBtu, 30-day avg.	0.06	Clean fuels
MEAD CONTAINERBOARD	AL	AL-0099	1/15/97	620 MMBtu/hr	0.03 lb/MMBtu	0.03	COMBUSTION CONTROL
GEORGIA PACIFIC CORP. - GLOSTEE FACILITY	MS	MS-0023	4/11/95	244 MMBtu/hr	0.02 lb/MMBtu	0.02	
Wheelabrator Ridge Energy Inc.	FL	FL-0198	9/29/92	630 MMBtu/hr	0.035 lb/MMBtu	0.035	Good combustion practices
Multitrade Limited Partnership	VA	VA-0183	2/21/92	373.7 MMBtu/hr	0.07 lb/MMBtu	0.07	Boiler Design

Reference: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2001.

<sup>d</sup> To convert from lb/hr, the emission limit was divided by the throughput rate.<sup>b</sup> This information obtained from actual PSD permit, not Clearinghouse.

Table D-6. Summary of BACT Determinations for Fluorides Emissions from Biomass-Fired Electric Utility Boilers

Company Name	State	RBLC ID	Permit Issue Date	Throughput Per Unit	Emission Limits		Control Technology/Comment
					As provided in BACT/LAER Clearinghouse	Converted to lb/MMBtu	
Multitrade Limited Partnership	VA	VA-0183	2/21/92	373.7 MMBtu/hr	0.64 lb/hr	1.7E-03	No controls feasible

Reference: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2001

<sup>a</sup> Assumed 8,760 hr/yr.

Table D-7. BACT Determinations for Sulfuric Acid Mist for Biomass-Fired Electric Utility Boilers

Company	State	RBLC ID	Permit Date	Throughput	Emission Limits		Control Equipment Description
					As Provided in LAER/BACT Clearinghouse	Converted to lb/MMBtu <sup>a</sup>	
Grayling Generating Station L.P.	MI	882-89E	9/18/01	523 MMBtu/hr	0.003 lb/MMBtu	0.003	Multicyclones, ESP, SNCR
MEAD CONTAINERBOARD	AL	AL-0099	1/15/97	620 MMBtu/hr	0.001 lb/MMBtu	0.001	COMBUSTION CONTROL

Reference: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2001.

<sup>a</sup> To convert from lb/hr, the emission limit was divided by the throughput rate.

Table D-8. BACT Determinations for Lead for Biomass-Fired Electric Utility Boilers

Company	State	RBLC ID	Permit Date	Throughput	Emission Limits		Control Equipment Description	% Efficiency
					As Provided in LAER/BACT Clearinghouse	Converted to lb/MMBtu <sup>d</sup>		
New Hope Power Partnership	FL	FL-0069	1/31/02	715 MMBtu/hr	0.00015 lb/MMBtu, 30-	0.00015	Clean fuels, ESP	--
GRAYLING GENERATING STATION	MI	882-89E	9/18/01	523 MMBtu/hr	0.02 lb/hr (3-hr avg.)	3.8E-05	MULTICYCLONE, ESP, SNCR	--
Wheelabrator Ridge Energy Inc.	FL	FL-0198	9/29/92	630 MMBtu/hr	0.25 lb/hr	0.0004	--	--

Reference: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2001.

<sup>d</sup> To convert from lb/hr, the emission limit was divided by the throughput rate.

<sup>b</sup> Assuming 8,760 hr/yr.

Table D-9. Summary of BACT Determinations for Nitrogen Oxide Emissions from Coal-Fired Boilers

Company Name	State	RBLC ID	Permit Issue Date	No. of Units	Throughput Per Unit	Emission Limits		Control Technology/Comment	Efficiency %
						As Provided in BACT/LAER Clearinghouse	Converted to lb/MMBtu		
Kansas City Power & Light Company - Hawthorn Station	MO	MO-0050	8/17/99	1	384 TPH	0.08 lb/MMBtu 30 day avg.	0.08	SCR and Good Combustion Practice	--
Deseret Generation and Transmission Company	UT	UT-0053	3/16/98	1	500 MW	0.55 lb/MMBtu 30 day avg.	0.55	Boiler Design	99.599
Two Elk Generation Partners, Limited Partnership	WY	WY-0039	2/27/98	1	250 MW	0.15 lb/MMBtu 30 day roll avg.	0.15	Low NO <sub>x</sub> Burners with Overfire Air and SCR	75
Encoal Corporation - Encoal North Rochelle Facility	WY	WY-0047	10/10/97	1	240 MW	0.15 lb/MMBtu	0.15	Low NO <sub>x</sub> Burners with Overfire Air and SCR	60
Encoal Corporation - Encoal North Rochelle Facility	WY	WY-0047	10/10/97	1	3960 MMBtu/hr	0.16 lb/MMBtu	0.16	Low NO <sub>x</sub> Burners with Flue Gas Recirculation.	--
Wygen, Inc. - Wygen Unit One	WY	WY-0048	9/6/96	1	1014 MMBtu/hr	0.22 lb/MMBtu 30 day roll avg.	0.22	Low NO <sub>x</sub> Burners and Overfire Air	56
Sonoco Products Company	SC	SC-0043	11/2/95	1	173.4 MMBtu/hr	0.3 lb/MMBtu	0.3	SNCR	--
Mon Valley Energy Limited Partnership	PA	PA-0133	8/8/95	1	966 MMBtu/hr	0.15 lb/MMBtu	0.15	SCR with Low NO <sub>x</sub> Burners	50
International Paper Co. Hammermill Papers Div.	PA	PA-0101	12/27/94	2	350 MMBtu/hr	0.7 lb/MMBtu	0.7	Annual Tune-up	--
VPI & State University	VA	VA-0225	12/12/94	1	146.7 MMBtu/hr	75.7 TPY	0.12	Low Excess Air/Staged Combustion	--
Fort Drum HTW Cogen Facility	NY	NY-0070	3/1/94	3	651 MMBtu/hr	0.6 lb/MMBtu	0.6	No Controls	--
Crown/Vista Energy Project (CVEP)	NJ	NJ-0019	10/1/93	2	1789 MMBtu/hr	0.17 lb/MMBtu	0.17	SCR with Low NO <sub>x</sub> Burners	48
Seminole Kraft	FL	FL-0077	7/7/93	1	174.7 MMBtu/hr	0.2 lb/MMBtu	0.2	Good Combustion	--
Black Hills Power and Light Company - Neil Simpson U	WY	WY-0046	4/14/93	1	1013 MMBtu/hr	0.23 lb/MMBtu 30 day roll avg.	0.23	Combustion Control	--
Indelk Energy Services of Otsego	MI	MI-0228	3/16/93	1	778 MMBtu/hr	0.25 lb/MMBtu	0.25	SNCR/Dry Control	50
Roanoke Valley Project II	NC	NC-0057	11/20/92	1	517 MMBtu/hr	0.17 lb/MMBtu	0.17	Low NO <sub>x</sub> , AOF, SNCR	--
South Carolina Electric and Gas Company	SC	SC-0027	7/15/92	3	385 MW	0.32 lb/MMBtu	0.32	Low NO <sub>x</sub> Burners with Overfire Air	--
Cogentrix of Dinwiddie	VA	VA-0185	4/16/92	8	375 MMBtu/hr	0.25 lb/MMBtu	0.25	SCR	58.3
Energy New Bedford Cogeneration Facility	MA	MA-0009		2	1671 MMBtu/hr	0.15 lb/MMBtu	0.15	SNCR	--
Milwaukee County Power Plant	WI	WI-0061		1	157 MMBtu/hr	0.16 lb/MMBtu	0.16	Ammonia Injection	60
						AVERAGE:	0.25		
						MAXIMUM:	0.7		
						MINIMUM:	0.08		

Source: RACT/BACT/LAER Clearinghouse on EPA's Webpage, 2002

Note: The boilers included in this table may be commercial, industrial or utility.

**APPENDIX E**

**SUMMARY OF CORRESPONDENCE AND  
SCR AND FGD VENDOR QUOTES**

**SCR Vendor Correspondences**

- Spoke with Frederick Booth of Engelhard Corp. (410-569-0297) on May 20, 2002. Mr. Booth stated that Engelhard does not provide SCR for biomass-fired boilers.
- Spoke with Phil Blazer of Babcock & Wilcox (B&W) (704-334-4742) on May 23, 2002. Mr. Blazer told me that B&W does provide SCR, but that SCR is not feasible for biomass-fired equipment. He further stated that B&W was not interested in preparing a quotation for this type of fuel burning boiler since B&W concentrates on SCR for CTs.
- Called Durr Environmental/Crawford Equipment and Engineering (407-851-0993) and left several messages. Was not able to reach anyone or to get anyone to return phone calls.
- Spoke with Mr. Mukund Kavia and corresponded through emails with Mrs. Kusum Kavia of Combustion Associates Inc. (909-272-6999). Initial email to Mr. Kavia was sent on May 23, 2002. Mrs. Kavia responded to the email requesting further information on May 28. In that email Mrs. Kavia stated that once all of the information was received, I would receive a price quote within two days. An email was sent back to Mrs. Kavia containing all of the requested information the same day. After not receiving the price quote phone calls were placed to Mr. Kavia on June 4, June 6, June 21, June 22, and June 27, 2002. Mr. Kavia returned my phone call on June 6 and June 22 stating that the quote was almost complete and that he would send it the following day. Mr. Kavia did not return my phone call of June 27 after not receiving a price quote.
- Spoke with Mike Sandel of Wheelabrator A.P.C. (412-562-7630) on May 24, 2002. Mr. Sandel declined to bid on the SCR since Wheelabrator only provides SCR for utility industry.
- Spoke with Flemming Hansen of Haldor Topsoe (281-228-5120) on May 24, 2002. Mr. Hansen stated that Haldor Topsoe may be able to help, but that he was concerned with the fact that SCR does not work well with biomass-fired equipment due to problems with potassium and sodium poisoning the catalyst. Mr. Hansen requested the equipment and operating parameters. A fax was sent out on May 24 with the requested information to Mr. Hansen. On May 31 Mr. Hansen called back stating that Haldor Topsoe would not be able to guarantee the life of the catalyst since the catalyst could die within a few thousand hours. To follow-up the phone conversation, Mr. Hansen sent an email on June 7, recommending that the SCR be installed downstream of the ESP, due to the likely potassium catalyst poisoning.
- Spoke with Mario Gialanella of Hamon Research-Cottrell, Inc. (770-844-1072) on May 23, 2002. Sent an email and fax with requested information to Mr. Gialanella on May 23. Mr. Gialanella stated that the quote would be ready in about two weeks. Called Mr. Gialanella on June 10 to check status of the quote, and was told that it should be sent out by June 14. Called Mr. Gialanella back on June 18 after not receiving quote, and was told that it should be sent out by June 21. Quote was received on June 21—see attached quote.



**FGD/SO<sub>2</sub> Control Vendor Correspondences**

- Called AirPol (973-599-4400) on May 20, May 23, and May 24, 2002, and left messages. Could not reach anyone or get anyone to return my phone calls regarding SO<sub>2</sub> control.
- Spoke with Mike Sandel of Wheelabrator A.P.C. (412-562-7630) on May 24, 2002. Mr. Sandel referred me to John Jones, Regional Sales Manager (678-513-4555) for assistance with SO<sub>2</sub> control. Sent email to Mr. Jones with boiler and operating information and requested a quote on May 24. Jerry Parks, the Florida sales representative, left a message stating that he was working on the price quote. Did not hear back from Mr. Parks and did not have the phone number for him, so called John Jones back on June 18 and June 21, leaving a message for him to call back. On June 21, Mr. Jones left a message stating that it was not feasible for Wheelabrator to take the time to provide a price quote since the installation of FGD would require a complete retrofit of the existing system that would cost at \$2.5-\$3.5 million. Since the ESP was built by another company Wheelabrator could not guarantee the performance of the FGD. On July 19, received quote, see attached.
- Spoke with Neil Dahlberg of Hamon Research-Cottrell, Inc. (617-244-5613) on May 23, 2002. Mr. Dahlberg returned the phone call and on June 4 the requested boiler and other operating parameters were emailed and faxed to him. Mr. Dahlberg stated that he may be able to provide the quote in about two weeks. Called Mr. Dahlberg back on June 10 and June 18 to check status and was told that he would try to send the quote by June 21. Called Mr. Dahlberg back on June 21 and June 27, but have not been able to reach him. The price quote was never received.
- Spoke with Jerry Childers of McGill Air Clean Corp. (614-542-2505) on May 17, 2002. Mr. Childers faxed a list of necessary information to provide a quote on May 17. The fax was returned to Mr. Childers on May 23 containing all of the requested information. Mr. Childers stated that a full proposal should be completed in 2 weeks. On June 10 Mr. Childers called with additional questions, which were answered. Mr. Childers passed project along to Matt Lawrence (614-443-0192), who was supposed to finish the quote and send it out by June 14. Called Matt Lawrence on June 21 after not receiving the quote. Mr. Lawrence stated that he was referring it back to Mr. Childers and he would have it out by July 1. Called Mr. Childers back on July 9 after not receiving the quote. Mr. Childers stated that he would try to get it out on July 9. Still have not received quote.


**VENDOR CORRESPONDENCES**

SCR VENDOR QUOTES

**BUDGETARY  
PROPOSAL**

**Florida Crystal**

**SELECTIVE CATALYTIC REDUCTION  
SYSTEMS**



**HAMON RESEARCH-COTTRELL  
PROPOSAL NO. P-6171  
June 20, 2002**



**TABLE OF CONTENTS**

<b>1.0</b>	<b>DESCRIPTIVE NARRATIVE</b>	<b>2</b>
<b>2.0</b>	<b>INTRODUCTION</b>	<b>3</b>
<b>3.0</b>	<b>SYSTEM DESCRIPTION</b>	<b>7</b>
<b>4.0</b>	<b>SCOPE OF SUPPLY BY HRC</b>	<b>10</b>
<b>5.0</b>	<b>SCOPE OF SUPPLY BY OTHERS</b>	<b>10</b>
<b>6.0</b>	<b>PERFORMANCE PARAMETERS</b>	<b>12</b>
<b>7.0</b>	<b>DESIGN PARAMETERS</b>	<b>13</b>
<b>8.0</b>	<b>MATERIALS OF CONSTRUCTION</b>	<b>14</b>
<b>9.0</b>	<b>PAINTING SYSTEM</b>	<b>14</b>
<b>10.0</b>	<b>SCHEDULE</b>	<b>15</b>
<b>11.0</b>	<b>COMMERCIAL</b>	<b>16</b>
<b>12.0</b>	<b>DISCUSSION OF BID</b>	<b>17</b>

**Appendices**

<b>1</b>	<b>SCOPE OF SUPPLY MATRIX</b>	<b>18</b>
<b>2</b>	<b>CODES AND STANDARDS</b>	<b>21</b>
<b>3</b>	<b>CONDITIONS FOR FIELD SERVICES</b>	<b>22</b>
<b>4</b>	<b>TERMS AND CONDITIONS</b>	<b>25</b>



## **1.0 DESCRIPTIVE NARRATIVE**

This descriptive narrative is presented to provide Florida Crystal with an overview of the offering submitted by Hamon Research-Cottrell, the descriptions of the components of the entire SCR system, and the additional information required for a complete evaluation of our offering. The engineering criteria, parameters and methodology for the design of the entire SCR system are set out separately in the Design Parameters section.

Each SCR consists of the following major components:

- **One (1)- Selective Catalytic Reduction (SCR)**
- **One (1)- Aqueous Ammonia Flow Control Unit (skid mounted) and ammonia injection system**
- **Engineering, Project Management, 10 days of Startup Support**
- **One sootblower**



## 2.0 INTRODUCTION

### Selective Catalytic Reduction


The Selective Catalytic Reduction (SCR) system is based on proven performance of the selected catalyst with many operating units in similar applications. Long term reliable operation and catalyst reactivity has been demonstrated in these plants. The system will incorporate automatic control features to minimize ammonia slip while maintaining the required NOx removal efficiency.

### SCR Process Description

The most effective method of controlling NOx from combustion sources is Selective Catalytic Reduction (SCR). It is the only commercially available flue gas treatment technology that has been demonstrated to remove over 90% of the NOx contained in combustion system exhaust gas. SCR is widely used for different types of combustion systems. Most experience is with base-metal catalysts using trace amounts of vanadium, molybdenum, and tungsten, and formulations using combinations of these.

### Chemistry

SCR technology involves reaction of ammonia with NOx in the presence of oxygen and a catalyst to form nitrogen and water. The major chemical reactions are:



It is important to note that oxygen is necessary for this reaction to occur. Below about 0.5% oxygen concentration, the SCR reaction becomes much less effective. Depending upon the catalyst used, the technology can be operated from about 400°F to over 1000°F. Oxides of vanadium, titanium, and tungsten (V<sub>2</sub>O<sub>5</sub>, TiO<sub>2</sub>, and WO<sub>3</sub>) are widely used as commercial catalysts for ceramic monolith and composite catalysts.

When sulfur-bearing fuels are used, the control of oxidation of SO<sub>2</sub> to SO<sub>3</sub> becomes an important performance characteristic. Unreacted ammonia reagent can react with SO<sub>3</sub> to form ammonium bisulfate, which could reduce catalyst activity by deposition on active surfaces. It can also cause corrosion and plugging of downstream heat-exchange equipment. This problem has been addressed by formulating the catalysts to minimize the use of vanadium while maintaining high catalyst activity for NOx removal.



Other causes of catalyst deactivation include erosion of catalyst washcoat, plugging with particulate matter, poisoning by arsenic and other metal compounds, and acidic decomposition. The most challenging conditions for a catalyst are in the high dust, high acid conditions that exist in some coal-fired power stations and downstream of waste incinerators. In general, however, experience with SCR has shown that catalysts have adequate lifetimes and good resistance to deactivation.

Experience has shown that the ability to properly distribute ammonia in the exhaust gas stream and the ability to properly distribute the exhaust gas across the catalyst face are key elements in the achievement of good process performance. Design of the ammonia distribution system, catalyst chamber, transitions, and the catalyst ductwork are effectively addressed through computer analysis or physical flow modeling of the system.

### **Technical Approach**

The major aspects of SCR system design are the following:

- Catalyst Selection and Sizing
- Gas Flow Modeling
- Reagent Injection System Design
- Structural Design
- Control System Design

The following paragraphs describe our design philosophy for SCR systems.

### **Catalyst Selection and Sizing**

Hamon Research-Cottrell's philosophy regarding catalyst selection is to use the most appropriate catalyst for a given application. Because different SCR applications can have a wide range of constraints, the best catalyst for one application may not be the best for another application. SCR catalysts come in several varieties and can be composed of a range of materials. The catalyst reactors can also be configured in many different ways.

For most applications there are two primary configurations - plate and honeycomb. Plate catalysts are constructed by coating a catalytic material onto a thin sheet-metal substrate. The metal sheets are configured in a parallel and/or corrugated fashion. Honeycomb catalysts are formed by the coating of a honeycomb metal plate or by extrusion of a ceramic material into a honeycomb matrix. The honeycomb ceramic matrix may be made entirely of catalyst (homogeneous) or it can be made from an inert ceramic material that is coated





with catalyst. The catalytic coatings of coated catalysts have been known to wear off in some applications. Honeycomb catalysts offer the advantage of higher catalytic surface area in a given volume than plate catalysts, often allowing less catalyst to be used. The ceramic honeycomb catalysts also weigh less than metal plate catalysts, reducing structural support requirements.

Both catalyst types have seen wide use on coal, gas, and oil-fired applications. The cleanliness of the fuel will dictate the plate spacing or cell pitch. In general, the dirtier the application, the larger the plate spacing or cell pitch.

### Catalyst Formulations

SCR catalyst materials include base metals, precious metals, and zeolites. Precious metal catalysts are rarely used because of their high cost and their tendency to be poisoned. Catalysts composed of base metal oxides are most often used. Base metals that are commonly used include vanadium, molybdenum, and titanium. The formulation selected depends largely upon the temperature range where the catalyst will be used. Base metal catalysts are commonly used in the temperature range of 550F to 850F.

Of particular concern in selecting the proper catalyst formulation is presence of SO<sub>2</sub> and metals such as vanadium or arsenic in the flue gas. Vanadium catalysts are particularly susceptible to enhancing oxidation of SO<sub>2</sub> to SO<sub>3</sub>, which is undesirable because it can react with ammonia to form ammonium salts that can plug catalyst sites and render the catalyst inactive. This can impose operating or design limitations for some systems with high sulfur fuels. For such systems, it is preferred to operate the SCR at temperatures well above 600 F to minimize the use of vanadium.

### Space Velocity

Space Velocity (SV) is a characteristic that represents the treatment time for the flue gas in the SCR reactor. A high value for SV relates to a low treatment time. SV is defined as:

$$SV = \frac{\text{Total Gas Flow (ft}^3\text{/hour)}}{\text{Catalyst Volume (ft}^3\text{)}}$$

Although the SV selected for a particular application will depend upon many variables, including the catalyst formulation and catalyst type, the following generalizations are true. High NO<sub>x</sub> reductions and low ammonia slips require low SV's. Because of the need for catalysts with large spacing and less catalytic area per volume, dirty fuels such as coal require lower SV's than clean fuels like gas.



### Reagent Injection

Proper distribution of ammonia reagent is essential for achieving good performance from an SCR system. This is especially true in cases requiring high levels of NOx reduction. Poor distribution can result in low NOx reduction and/or high ammonia slip.

A cardinal point in SCR system design is the proper location of the ammonia injection grid (AIG). This must be located the proper distance upstream of the catalyst to enable even mixing of ammonia with the flue gas. The AIG is designed to allow complete manual adjustment during system start-up and optimization.

Ammonia is normally injected in the gaseous form and is diluted with a carrier gas. Hamon Research-Cottrell employs flow modeling for the design of the reagent injection system. This design methodology has been used to design flue gas conditioning systems and other gas treatment systems for numerous applications.

### Gas Flow

In SCR systems, it is essential to minimize flow mal-distribution and distribute the gas flow evenly through the catalyst. Otherwise, a portion of the gas will have inadequate treatment time which may result in poor NOx reduction and/or high ammonia slip. Uniform gas flow is achieved by carefully designed ductwork that may include guide vanes and flow straighteners. For large reactors a flow straightener is used immediately upstream of the catalyst.

Hamon Research-Cottrell performs computer modeling and/or physical modeling in the laboratory to develop design of the gas flow distribution devices. HRC has its own in-house fluid dynamics group with these capabilities.

The benefits of this modeling capability include:

- Proper design of the system for high reduction and low ammonia slip.
- Accurate prediction of pressure drops.

This laboratory has world-renowned recognition and is frequently utilized by A&E's, Universities, and private concerns.



### **Temperature Considerations**

In some applications the temperature of the flue gas is sufficiently high to prevent utilization of conventional catalysts. When this occurs, either a high temperature catalyst may be employed or air may be introduced into the flue gas stream to provide cooling. In this latter case, Hamon Research-Cottrell utilizes an ungula system to introduce cooling air. This system minimizes the pressure drop while at the same time maximizing the mixing of the cooling air with the hot flue gas.

### **Structural Design**

The catalyst for a large SCR system can weight hundreds of thousands of pounds. It must be supported by a structure designed to operate at the high temperatures encountered in these systems. The catalyst modules are supported by a gridwork of horizontal "I" or box beams. Stiffener beams span between the major horizontal support steel. The horizontal support beams and stiffener beams are configured to frame and support the catalyst modules, sealing the gas around them. Ceramic fiber material seals the space between the catalyst module and the frame. These horizontal beams and the catalyst reactor casing are support by outer and inner intermediate vertical supports. The reactor casing is of A-36; steel exposed to flue gas temperature is all of grade ASTM – A 242.

### **Controls**

Control of each SCR system is performed by a Programmable Logic Controller (PLC) which modulates ammonia flow based upon several monitored signals. The control systems can operate in either a Forward Control Mode, where the ammonia injection rate is primarily controlled on a feed-forward basis using the inlet NOx concentration signal, or in a Feed Back "Trim" Mode, where the ammonia rate is trimmed using outlet NOx concentration signal. The NOx analyzers are to be provided by the Purchaser.



### 3.0 SCOPE OF SUPPLY

#### SCOPE OF SUPPLY BY HRC

The scope of supply provided by HRC is outlined below. A detailed matrix is provided in Appendix 1 in the "Scope of Supply" Table.

- SCR Catalyst
- SCR Catalyst Housing
- Ammonia Vaporizer
- Ammonia Flow Control Skid
- Ammonia Injection Grid (AIG)
- Reactor Box
- PLC
- Instrumentation as indicated herein
- Flow Modeling
- Project Management
- Engineering
- QA/QC
- Field Service/Erection Consultant – on a per diem basis
- Start-up assistance – 10 days (additional available on a per diem basis)
- Freight – FOB Jobsite

#### SCOPE OF SUPPLY BY OTHERS

Equipment and services, which shall be provided by others, are generally assumed as indicated below. A more complete scope of supply by Others matrix is provided in Appendix 1.

- Installation material, labor, and supervision.
- Demolition of Existing Equipment (if required).
- Foundations and anchor bolts
- All Field wiring and conduit
- All Field piping and pipe hangers, unless otherwise stated herein
- Ammonia, water, air, calibration gas, compressed air, steam, or other consumables required for system start-up and system operation
- Motor Control Centers, motor starters, etc.
- NOx analyzers upstream of Catalyst
- CEMS System
- Performance and/or Acceptance Testing - per diem (except as otherwise provided herein)
- Ammonia Storage Tank



- Control room and any other enclosures
- Flow Straighteners
- Expansion Joints
- Transition Duct to and from the SCR
- Structural Support
- Insulation



## 6.0 PERFORMANCE PARAMETERS

The proposed NOx system design and performance is based on the information provided by Golder Associates. The system is designed to meet the NOx removal requirements as indicated in this technical specification description. A summary is provided in Table 1 below.

TABLE 1

<b>Emissions Source</b>	<b>Cogen Boiler</b>	<b>Package Boiler</b>
<b>Number of Boilers</b>	2	1
<b>Fuel</b>	Biomass	Biomass
<b>Gas Conditions at Inlet to SCR</b>		
Gas Flow, acfm	326,000	88,200
Gas Temp. at SCR catalyst, °F	700	700
NOx at SCR Inlet, ppmvd @ 15% O <sub>2</sub>	210	210
<b>Design Requirements</b>		
SCR Catalyst – NOx Conversion (%)	90	90
System Pressure Drop inches w.c.	5	5
<b>Catalyst Performance</b>		
NOx at Outlet, ppmvd @ 15% O <sub>2</sub> –Max	21	21
Ammonia Slip, ppmvd @ 15% O <sub>2</sub> -Max	5	5
Catalyst Life	10,000 hrs	10,000 hrs
Approximate NOx Catalyst Volume (m3)	30	10
SCR Dimensions, Ft, LxWxH	20x20x20	10x12x20
Flue Gas Flow Direction	Down	Down



### 7.0 DESIGN PARAMETERS

The following Table 2 represents expected operating design parameters for the HRC supplied SCRs.

TABLE 2

PARAMETER	UNITS	VALUE
Structural Design Temperature	Deg F	900
Structural Design Pressure	Inches W.C.	-12 / +14
Wind Load	Mph	100
Snow Load	Psf	0
Input Voltage	Volts/Phase/Hz	480/3/60
Electrical Classification	Type	Non Hazardous



**8.0 MATERIALS OF CONSTRUCTION**

The following Table 3 represents the anticipated materials of construction for the HRC supplied SCRs.

**TABLE 3**

ITEM DESCRIPTION	MATERIAL	Inch Thick	PAINT SYSTEM
Vessel	ASTM A-36	1/4	B
Access Steel Framing	ASTM A-36	Shapes	B
A.I.G. Internal Piping	ASTM A-304	To suit	D
A.I.G. External Manifolds	ASTM A-36	To suit	B
NOx Catalyst Support Frame	ASTM A-242	Shapes	D

**9.0 PAINTING SYSTEM**

The following Table 4 represents the anticipated painting system for the HRC supplied SCRs.

**TABLE 4**

Category (From Above)	Surface Prep. SSPC	Prime Coat	Finish Coat
A	SP-3	3 mils Red Oxide 1side	None
B	SP-6	3 mils Zinc Rich	None
C	SP-6	Galvanized	N/A
D	SP-1	None	None





## 10.0 SCHEDULE

The following schedule listed in Table 5 is anticipated as part of this proposal. HRC will work with the buyer to optimize this schedule based on specific needs of the project.

**Table 5**

Item	Weeks ARO
General Arrangement	4
Loads	6
Electrical One-Line	8
Design Drawings	16
Start SCR ship	32
End SCR ship	40
Start Catalyst Delivery	40
End Catalyst Delivery	42



## 11.0 PRICING AND COMMERCIAL TERMS

Pricing for the supply of three SCR NOx removal with the scope of supply outlined herein is as follows:

**\$ 4,250,000**  
**FOB Jobsite**

- The above price does not include taxes of any kind.
- This price is submitted based on Hamon Research-Cottrell's standard warranty, which is 12 months from operation or 18 months from date of shipment, whichever is shorter.
- This proposal is submitted based on Hamon Research-Cottrell's Standard Terms and Conditions as outlined in Appendix 4. HRC is prepared to review these terms in conjunction with the Buyer at the appropriate time prior to award.
- This proposal is submitted based on Hamon Research-Cottrell's standard payment terms, which include 10% of the contract value upon receipt of purchase order and the balance in progress payments based on agreed upon milestones. Invoice payments will be based on net 30 days.

LaRocca, David

From: Howard, Fawn  
Sent: Tuesday, July 30, 2002 11:21 AM  
To: LaRocca, David  
Subject: FW: Florida Crystal, P-6171, Price Breakout

Fawn Howard  
Staff Engineer  
Golder Associates Inc.  
Gainesville, FL  
(352) 224-1141 direct  
(352) 336-5600 main  
(352) 336-6603 fax  
email: FHoward@golder.com

PRIVILEGED AND CONFIDENTIAL  
ATTORNEY/CLIENT COMMUNICATION OR WORK PRODUCT

Disclaimer Notice:

This email message is intended solely for the use of the individual to whom it is addressed and may contain information that is privileged, confidential, or otherwise exempt from disclosure under applicable law. If the reader of this email is not the intended recipient, you are hereby notified that any dissemination, distribution, or copying of this communication is strictly prohibited. If you have received this communication in error, please immediately notify us by sending this message back to us and delete the original message. Thank you.

-----Original Message-----

From: DRABNIS Alfred [mailto:alfred.drabnis@hamon.com]  
Sent: Thursday, June 27, 2002 1:26 PM  
To: 'fhoward@golder.com'  
Cc: GIALANELLA Mario  
Subject: Florida Crystal, P-6171, Price Breakout

Ms. Howard,

Breakout price for the SCR for the package boiler is \$850,000. Let me know if I can help in any other way.

Regards,

Al Drabnis



## 12.0 DISCUSSION OF BID

12.1 The price quoted in this proposal is based upon the current market conditions for carbon steel, stainless & nickel alloys. Due to the volatility in stainless alloys and the possibility of significant import tariffs being imposed by the U.S. government on certain carbon steel products, we reserve the right to adjust our price in the event there is a material increase in steel prices. In the event of a change in steel prices, we will fully document the change in price to the customer and re-price accordingly.

12.2 Note that transitions from existing ductwork to each SCR shall be by Others.

12.3 CO Catalyst is not included.



13.0 Appendix 1

SCOPE OF SUPPLY SHEET

ITEM	BY HAMON		BY OTHERS	NOT REQ'D
	BASE	OPTION		

1. DESIGN

1.1 BASIC DESIGN	X			
1.2 DETAIL DESIGN FOR CATALYST MODULES	X			
1.3 DETAIL DESIGN FOR SCR HOUSING	X			
1.4 DETAIL DESIGN FOR NH3 INJECTION SYSTEM	X			
1.5 DETAIL DESIGN FOR AMMONIA STORAGE SYSTEM		X		
1.6 CONTROL LOGIC (narrative description)	X			
1.7 INSTRUCTION and O&M MANUALS	X			

2. CATALYST

2.1 SCR CATALYST MODULES	X			
2.2 FUTURE CATALYST MODULES			X	
2.3 DISPOSAL OF SPENT CATALYST MODULES			X	

3. SCR HOUSING

3.1 SCR HOUSING	X			
3.2 INLET & OUTLET TRANSITIONS w/ EXTERNAL INSULATION			X	
3.3 CATALYST SUPPORT FRAMES w/ SEAL DEVICES	X			
3.4 SPACE FOR FUTURE CATALYST MODULES	X			
3.5 HOIST & MONORAIL w/ SUPPORT STRUCTURES				X
3.6 INTERNAL PLATFORM w/ LADDERS			X	
3.7 EXTERNAL PLATFORM FOR CATALYST LOADING HATCH			X	
3.8 ACCESS DOORS	X			
3.9 INSTRUMENT and SAMPLING TAPS	X			
3.10 SLIDE PLATES FOR FOUNDATION			X	
3.11 FOUNDATION BOLTS			X	
3.12 THERMOCOUPLES (1 SET)	X			
3.13 DIFFERENTIAL PRESSURE TRANSMITTER (1 SET)	X			
3.14 EXPANSION JOINTS			X	



**4. AMMONIA INJECTION GRID-AIG**

**BASE    OPTION    BY    NOT  
OTHERS    REQ'D**

5.1 HEADER w/ CONNECTION PIPES	X			
5.2 FLOW CONTROL DAMPERS (MANUAL)	X			
5.3 FLOW ORIFICES	X			
5.4 MANOMETERS or PDIS w/ ISOLATION VALVES	X			
5.5 PRESSURE INDICATOR	X			
5.6 TEMPERATURE INDICATOR	X			
5.7 THERMOCOUPLE	X			
5.8 DRAIN VALVE	X			
5.9 INSULATION			X	
5.10 SUPPORT LEGS	X			

**6. AQUEOUS AMMONIA FLOW CONTROL SKID**

6.1 DILUTION AIR FANS w/ MOTORS, FILTERS & SILENCERS (100% CAPACITY X 2)	X			
6.2 DILUTION FLUE GAS PIPING & DAMPERS (shipped loose)	X			
6.3 DILUTION FLUE GAS FLOW ELEMENT & TRANSMITTER	X			
6.4 NH3/FLUE GAS VAPORIZER/MIXER	X			
6.5 DILUTION FLUE GAS PIPING PURGE CONTROLS	X			
6.6 LIQUID NH3 PIPING & VALVES (integral to skid)	X			
6.7 NH3 FLOW SHUT-OFF VALVE (integral to skid)	X			
6.8 NH3 FLOW SPRAY ORIFICE & TRANSMITTER	X			
6.9 NH3 PRESSURE INDICATOR	X			
6.10 NH3 PRESSURE TRANSMITTER	X			
6.11 NH3 TEMPERATURE TRANSMITTER	X			
6.12 NH3 STRAINER	X			
6.13 INSTRUMENT AIR PIPING & VALVES	X			
6.14 INSTRUMENT AIR PRESSURE SWITCH	X			

**7. AQUEOUS AMMONIA STORAGE FACILITY**

7.1 AQUEOUS AMMONIA STORAGE FACILITY			X	
7.2 TANK TRUCK LOADING STATION			X	
7.3 LIQUID NH3 PIPING & VALVES			X	
7.4 NH3 CONTROL PANEL			X	
7.5 NH3 ACCUMULATOR w/ PRV			X	



	BASE	OPTION	BY OTHERS	NOT REQ'D
<b>8. EXTERNAL PIPE (shipped loose)</b>				
8.3 DISTRIBUTION NH <sub>3</sub> /DILUTION AIR PIPE (HEADER & AIG)	X			
8.4 SUPPORTS FOR DISTRIBUTION PIPE	X			
8.5 AQUEOUS AMMONIA PIPE (TANK-VAPORIZER-TANK)			X	
8.6 AQUEOUS AMMONIA PIPE (UNLOADING STATION-TANK)			X	
8.7 AQUEOUS AMMONIA PIPE (TANK-FLOW CONTROL SKID)			X	
8.8 SUPPORTS FOR AQUEOUS AMMONIA PIPE			X	
<b>9. CONTROL &amp; ELECTRICAL SYSTEM</b>				
9.1 MOTOR CONTROL CENTER			X	
9.2 POWER SUPPLY OF ELECTRICAL EQUIPMENT			X	
9.3 PLC	X			
<b>10. SCR INLET NO<sub>x</sub>/O<sub>2</sub>/CO ANALYZER</b>				
10.1 ANALYZER			X	
10.2 CEM SYSTEM			X	
<b>11. SCR OUTLET NO<sub>x</sub>/NH<sub>3</sub>/CO ANALYZER</b>				
11.1 ANALYZER W/ PROBE			X	
11.2 CEM SYSTEM			X	
<b>12. SURFACE TREATMENT</b>				
12.1 SURFACE PREP SSPC-SP6	X			
12.2 SHOP PRIME	X			
12.3 FINISH PAINT			X	
<b>13. FIELD WORK</b>				
13.1 FOUNDATIONS AND ANCHOR BOLTS			X	
13.2 ERECTION			X	
13.3 SETTING CATALYST MODULES			X	
13.4 START-UP SCR SYSTEM			X	
13.5 PERFORMANCE TEST			X	
13.6 FIELD PAINT & TOUCH-UP PAINTING			X	
<b>14. SUPERVISORY SERVICE</b>				
14.1 INSTALLATION (10 days)	X			



## Appendix 2

### CODES AND STANDARDS

Following are the codes and standards that Hamon Research-Cottrell Inc. will use in the design and fabrication of all equipment. Applicable portions of the latest issue of these codes will be used.

ANSI -	American National Standards Institute, Building Code Requirements for Minimum Design Loads, A58.1
AWS -	American Welding Society, Structural Welding Code
AISC -	American Institute of Steel Construction specifications for Design, Fabrication and Erection of Structural Steel Buildings
UBC -	Uniform Building Code
NEC -	National Electric Code
ASME -	American Society of Mechanical Engineers
OSHA -	Federal Occupational Safety and Health Administration
NBS -	National Bureau of Standards
NFPA -	National Fire Protection Association
IGCI -	Industrial Gas Cleaning Institute
SBC -	Standard Building Code
ASTM -	American Society for Testing and Materials
EPA -	Environmental Protection Agency
NEMA -	National Electrical Manufacturer's Association
ISA -	Instrument Society of America
IEEE -	Institute of Electrical and Electronic Engineers

Hamon Research-Cottrell Inc. takes exception to compliance with any inconsistent or differing codes, including foreign government, province, state or local codes. In addition the IBC-2000 code is not being utilized. If in the design, fabrication, or erection of this equipment, Hamon Research-Cottrell Inc. is required to comply with any codes differing from or inconsistent with the aforementioned, Hamon Research-Cottrell Inc. shall be entitled to an equitable adjustment in both schedule and price to reflect increased costs incurred thereby, and a reasonable overhead and profit. Responsibility for investigating code requirements will be by Purchaser.





### Appendix 3

## Conditions of Sale For Field Services

All Field Services shall be furnished by Hamon Research-Cottrell, Inc. (hereinafter referred to as Contractor) to act in an advisory capacity in accordance with the following terms and conditions of sale and any contract made by and between Contractor and (hereinafter referred to as "Purchaser") includes as a part thereof these conditions of sale:

#### 1.0 RATES

##### 1.1 On-Site Activities:

- a. From the hour the representative leaves his basing point up to and including the hour of his return to his basing point, payment shall be made at the U.S. fund rates listed below.
- b. A work day is defined as any day, Monday through Friday, whether actual work is performed or not. Also, any travel time from the base point to the job site location or from the job site location to the base point is considered a work day. The work day is to be 8 hours and the work week 40 hours, Monday through Friday for which the straight time rate of \$110 per hour will be charged. All hours worked in excess of 8 hours per day or on Saturday will be charged at the rate of \$165 per hour. For work performed on Sundays and holidays the rate of \$220 per hour will be charged.

The minimum work day charge where work is performed will be based on a full eight (8) hour day. For "toldover" days where the representative is required to be on standby, but no actual work is performed, a charge of \$ 500 per day will apply.

##### 1.2 Service Reports

A detailed field inspection report (including photos, drawings, sketches, etc., where applicable) will be prepared after the completion of on-site work. Since this work will occur offsite, standard billing rates will be charged for this activity. The rates for report preparation are:

<u>On-site Service Days</u>	<u>Charge</u>
1 - 2	4 hours x \$110
3 - 5	6 hours x \$110
6 - 10	8 hours x \$110
10 - 20	12 hours x \$110

This report will be issued within 10 days of the completion of the on-site visit.

##### 1.3 Export

- a. From the day the representative leaves his basing point up to and including the day of his return to his basing point, payment shall be made, in U.S. funds at the rates below.
  - Straight time rate: \$137.50
  - Overtime rate: \$200.00
  - Sundays & Holidays: \$287.50
- b. The hours of work shall be mutually agreed upon by the Purchaser and the representative and shall not be in excess of the hours of work described for domestic rates unless mutually agreed upon by Contractor at it's main office.
- c. International air travel in excess of 12 hours shall be business class.

#### 2.0 EXPENSES

##### 2.1 Transportation

Round trip transportation to and from the job-site location will be billed at cost.

##### 2.2 Room, Board and Local Transportation

Meals will be billed at \$35/day. Living expenses, such as lodging, laundry, etc., will be billed at cost. Local car rental will be billed at cost.

#### 3.0 MISCELLANEOUS

##### 3.1 Rate Adjustments

Rates will be adjusted to those in effect at the time the service is performed, unless otherwise specified in the proposal.

##### 3.2 Lay-Over Expense

Where circumstances require that a service representative be held over on weekends, during which no work is performed charges



for living expenses will be billed per section 2.

**3.3 Cancellation**

In the event a service requirement is canceled less than three (3) working days from a previously agreed upon start date, a cancellation fee of one day's service will be charged.

**3.4 Engineering Services Charges**

Services requiring investigation, research or Engineering services will be billed at \$90/hour.

**4.0 INDEPENDENT CONTRACTOR**

Contractor shall be considered an independent contractor in respect to all work herein provided. No actions taken hereunder are intended to establish any relationship of agency, partnership or joint venture between Contractor and Purchaser.

**5.0 DISCLAIMER OF CONSEQUENTIAL DAMAGES**

The Contractor SHALL NOT be liable to Purchaser for indirect or consequential damages including, but not limited to, loss of profits or revenue, loss of use of equipment, costs of replacement power, additional expenses incurred in the use of equipment or facilities, or the claims of third parties. This disclaimer shall apply to consequential damages based upon any cause of action whatsoever asserted against Contractor, including one arising out of any breach of warranty, express or implied, guarantees, products liability, negligence, tort, or any other cause pertaining to performance or non-performance of this proposal or contract by Contractor.

**6.0 IMPLIED WARRANTIES DISCLAIMER**

The Warranties furnished by Contractor as expressly included herein constitute Contractor's sole obligation hereunder and are in lieu of any other warranties or guarantees, express or implied, including warranties of merchantability or fitness for a particular purpose.

**7.0 INDEMNITY**

Contractor SHALL NOT be responsible for losses or damages arising out of the negligence of the Purchaser, its employees, agents or assigns or for losses for which the Purchaser has agreed to provide insurance. Contractor specifically disclaims responsibility for damages, injury or other costs resulting from the efforts performed by others including the manner of erection and safe execution thereof, and to which Contractor is providing direction and assistance. Purchaser shall indemnify Contractor with respect to any and all claims, suits or actions arising out of the work performed hereunder, except for those which under a final and unappealable order of a court with jurisdiction are determined to be the result of the sole negligence of Contractor. Both the Contractor and the purchaser hereby agree to mutually waive any rights which each may have against the other with respect to subrogation under any policy of insurance relating to the equipment or services provided under this contract.

**8.0 TERMS OF PAYMENT**

Unless otherwise agreed, payment shall be made within thirty (30) days of presentation of an invoice which shall be issued upon the completion of the assignment or at the end of each month if the assignment duration is in excess of the one month period. All payments not received by the due date shall be subject to a monthly interest charge at the rate of 2% per month or the maximum allowed by law, whichever is less, due and payable until the payment is received.

**9.0 FORCE MAJEURE**

Contractor shall not be liable for any loss or damage arising out of delay in performance under this contract due to causes beyond its reasonable control such as, but not limited to, acts of God, acts of purchaser, acts of civil or military authorities, priorities, fire, smoke interference, strikes, floods, epidemics, quarantine restrictions, war, riot, delays in transportation, car shortages, work stoppages or Contractor's inability to obtain necessary labor. In the event of such delay, the date of performance shall be extended for a period equal to the time lost by reason of such delay. Contractor shall be entitled to an equitable adjustment in the contract price for increased costs incurred due to the aforementioned causes.

**10.0 LIMITATION ON LIABILITY OF CONTRACTOR**

In no event will Contractor's liability to the Purchaser for any and all claims, including property damage and personal injury claims, allegedly resulting from breach of contract, tort, or any other theory of liability exceed the amount paid hereunder to Contractor.

**11.0 HAZARDOUS MATERIALS**

The Purchaser's facilities may contain hazardous materials, including asbestos bearing materials. Contractor's services do not include directly or indirectly performing or arranging for the detection, monitoring, handling, storage, removal, transportation, disposal or treatment of petroleum or petroleum products (collectively called "Oil") or of any hazardous, toxic, radioactive or infectious substances, including any substances regulated under RCRA or any other Federal or State environmental laws (collectively called "Hazardous Materials"). If any such materials are encountered, Contractor shall have no obligation to remove or remediate them in the absence of a separate agreement (including separate consideration to Contractor) for such work. If Contractor's representative is required to perform work within or immediately adjacent to any facilities that are determined to contain hazardous materials and/or asbestos, and the said work must be interrupted to allow for the remediation or removal of such materials by others, Contractor shall be entitled to any and all costs and other expenses associated with such interruption in



work. Purchaser shall fully defend, hold harmless and indemnify Contractor and its agents from and against any claims arising out of exposure to such hazardous and/or asbestos bearing material.

**12.0 SAFETY**

Contractor shall not be responsible for health or safety programs or precautions related to Purchaser's activities or operations, Purchaser's other contractors, the work of any other person or entity, or Purchaser's site conditions. Contractor shall not be responsible for inspecting or correcting health or safety conditions or deficiencies of Purchaser or others at Purchaser's site, and Purchaser agrees to indemnify, hold harmless, and defend Contractor against any claims arising out of such conditions or deficiencies. So as not to discourage Contractor from voluntarily addressing health or safety issues by making observations, reports, suggestions, or otherwise, it is understood and agreed that Contractor shall nevertheless have no liability or responsibility arising on account thereof.

**13.0 CONTRACT INTERPRETATION**

If any of the provisions of these Conditions of Sale (including the proposal) conflict with any provisions in the Purchaser's documents, the former shall govern unless Contractor expressly agrees to the contrary in writing. No changes in or modifications of these Conditions of Sale which form part of the contract between Contractor and Purchaser shall be binding upon the parties unless accepted by Contractor in writing.

**14.0 SEVERABILITY**

Should any part of this Agreement be declared invalid or unenforceable, such decision shall not affect the validity of any remaining portion, which remaining portion, shall remain in full force and effect, and Seller shall have the right to replace the part declared invalid or unenforceable with a provision which serves as much as validly possible the same commercial purpose as the part determined to be invalid or unenforceable.

**15.0 SERVICES EXCLUDED**

Services not expressly set forth in writing in this Agreement are excluded from Contractor's services, and Contractor assumes no duty to the Purchaser to perform such duties.

**16.0 SUSPENSION**

Failure by Purchaser to make timely payments of Contractor invoice shall entitle Contractor to suspend performance of services under this Agreement. Unless payment in full is received by Contractor within seven (7) days of the date of the suspension is mailed to the Purchaser by Contractor, the suspension shall take effect without further notice. Contractor shall not be liable for any damages or delays caused by such suspension.

**17.0 TERMINATION**

Contractor may terminate this Agreement, in whole or in part, at its election upon seven (7) days written notice to the Purchaser upon one or more of the following events: (1) invoices for services remain unpaid for over thirty (30) days, (2) an "unexpected contingency" occurs which shall mean (a) strikes, lockouts, riots, unavoidable accidents, acts of God or of the public enemy, or unavailability of transportation; (b) any lawful order issued by the United States, state or local governmental authority; (c) the purchaser becomes bankrupt or insolvent or goes or is put into liquidation or dissolution, either voluntarily or involuntarily, or petitions for an arrangement or reorganization under the Bankruptcy Act, or makes a general assignment for the benefit of creditors or otherwise acknowledges insolvency; or (d) any other cause beyond Contractor's reasonable ability to carry out its obligations herein. Upon termination of this Agreement by Contractor under this section, Contractor shall be compensated for its services performed prior to the date of such termination, and for other expenses reasonably or necessarily incurred in connection with such termination.

**18.0 LAWS**

This Agreement and all rights and obligations of the parties hereunder, and any disputes hereunder, shall be construed and governed by the state of New Jersey.



## Appendix 4

### STANDARD TERMS AND CONDITIONS

The following terms and conditions form part of each proposal submitted by (SELLER) hereinafter called "Contractor" for the sale of equipment or services to a Client/Customer hereinafter called "Purchaser" and any contract made by and between the parties includes as a part thereof these terms and conditions.

#### MATERIAL WARRANTY

##### 1.1 Warranty

Contractor warrants to Purchaser that the equipment manufactured by it is free from defects in material, workmanship and design under normal use and service for a period of eighteen (18) months after shipment or twelve (12) months after initial operation, whichever occurs first. Initial operation is defined as the date of first heat load of the equipment. All auxiliary equipment not manufactured by Contractor carries such warranty as given by the manufacturer thereof and which is hereby assigned to Purchaser.

##### 1.2 Terms

Contractor's obligation under this warranty is to supply, pursuant to the delivery terms of the proposal, at Contractor's sole option repaired or replacement parts for those parts which are shown to Contractor's satisfaction to have been defective as to material, workmanship or design, provided that:

- a. Written notice of such defect is given to Contractor within thirty (30) calendar days of discovery thereof;
- b. The equipment has been operated in accordance with the operating and maintenance instructions provided by Contractor; and
- c. No alterations or substitutions have been made in the equipment without the express written authorization of Contractor.

##### 1.0 PURCHASER'S ACTS VOIDING WARRANTIES

2.1 The warranty furnished by Contractor herein will be rendered void and of no further force or effect by the Purchaser's use and operation of the equipment in a manner which, in Contractor's reasonable judgment is inconsistent with recommendations contained in Contractor's Operation and Maintenance manual issued for the equipment including but not limited to improper erection, damage caused by abrasion, corrosion or excess temperature or other operational causes. Additionally, the warranty is voided by the Purchaser's unauthorized alteration of, or making of substitutions to the equipment herein supplied. The Purchaser shall defend, hold harmless and indemnify Contractor and its officers, directors, employees and agents from and against any liability for personal injury or property damage arising out of the above-mentioned causes as well as from any fires internal to the equipment supplied under this contract.

##### 3.0 PATENT WARRANTY

Contractor shall defend at its expense any suit or proceeding brought against Purchaser based on any claim that the equipment covered herein, except for equipment/material manufactured and/or designed to Purchaser's specifications, infringes any United States patent issued as of the date of this proposal and pay any court imposed damages and costs finally awarded against Purchaser, but not to exceed the amount theretofore paid to Contractor by Purchaser hereunder provided:

- a. Contractor is promptly notified by Purchaser in writing of such claim; and
- b. Contractor is given full authority, information, and assistance by Purchaser which Contractor deems necessary for the conduct of such defense.

Contractor shall have the right and option at any time in order to avoid such claims or actions and minimize potential liability to:

- a. Procure for the Purchaser the right to use the equipment; or
- b. modify the equipment so that it no longer infringes; or replace the equipment with non-infringing equipment

##### 4.0 DELAYS AND DAMAGES - FORCE MAJEURE

In the event of delays or damages due to conditions beyond Contractor's reasonable control, including, but not limited to, Acts of God, Acts of Purchaser or Purchaser's Customer or of other Contractor's employed by Purchaser, Acts of Civil or Military Authority, priorities, fire, strikes, floods, epidemics, quarantine restrictions, war, riot, delays in transportation, car shortages, and Contractor's inability to obtain necessary labor, materials or manufacturing facilities. In the event of such delay, the Contract dates shall be extended by an equitable period of time and Contractor shall be entitled to an equitable adjustment in the Contract price.

##### 5.0 PERFORMANCE GUARANTEE

Contractor's sole guarantees are those contained in its proposal to Purchaser. These guarantees are contingent upon the correctness and accuracy of the information provided by the Purchaser and are based upon the operating conditions specified in Contractor's proposal. These guarantees will be deemed satisfied by successful completion of performance tests in accordance



with applicable standard procedures as specified in the proposal and in effect on the date of this proposal. Performance tests shall be conducted by the Purchaser and witnessed by Contractor within 90 days of the date of initial operation of the equipment. In the event the said tests are not conducted within 90 days of initial operation or within six (6) months of shipment whichever is earlier and through no fault of the Contractor, the equipment shall be deemed accepted by the Purchaser and in compliance with all contractual requirements. In the event the equipment fails to meet the contract performance guarantees as verified by certified test results, Contractor will supply, at its sole option, repaired or replacement parts pursuant to the delivery terms of the proposal subject to the limitations stated in Article

**6.0 IMPLIED WARRANTIES DISCLAIMER**

The warranties furnished by Contractor as expressly included herein constitute Contractor's sole obligation hereunder and are in lieu of any other warranties or guarantees, express or implied, including warranties of merchantability or fitness for a particular purpose.

**7.0 DISCLAIMER OF CONSEQUENTIAL DAMAGES**

The Contractor shall not be liable to Purchaser for indirect or consequential damages including, but not limited to, loss of profits or revenue, loss of use of equipment, costs of replacement power, or product, additional expenses incurred in the use of equipment or facilities, or the claims of third parties. This disclaimer shall apply to consequential damages based upon any cause of action whatsoever asserted against Contractor, including one arising out of any Breach of Warranty or Guarantee, Products Liability, Negligence, Tort, or any other cause of action.

**8.0 PURCHASER'S NEGLIGENCE AND INSURANCE**

Contractor shall not be responsible for losses or damages arising out of the negligence of the Purchaser, its employees, agents or architects or losses for which the Purchaser has agreed to provide insurance. In the event that both the Contractor and the Purchaser are negligent and the negligence of both is proximate cause of the accident, then in such event each party will be responsible for their portion of the liability or damages (excluding consequential or indirect damages which are disclaimed by the Contractor) resulting therefrom equal to such party's comparative share of the total negligence. Both the Contractor and the Purchaser hereby agree to mutually waive any rights which each may have against the other with respect to subrogation under any policy of insurance relating to the equipment or services provided under this contract.

**9.0 LIMITATION OF LIABILITY**

In no event will Contractor's liability to the Purchaser for any and all claims, including property damage and personal injury claims, allegedly resulting from breach of contract, tort, or any other theory of liability exceed the amount of the initial purchase price paid to the Contractor.

**10.0 PRICE ADJUSTMENT - EQUIPMENT, MATERIALS & LABOR**

Unless otherwise noted in the Contractor's proposal, equipment and material prices set forth in the proposal are firm for delivery in accordance with the Schedule therein. In the event the Schedule is modified due to acts of Purchaser or conditions beyond Purchaser's control and contract costs escalate, an equitable adjustment to the Contract price shall be granted to Purchaser.

**11.0 TAXES**

Sales Tax, Personal Property Tax, Use Tax, Excise Tax, or other taxes imposed by Federal, State or municipal authority and incurred by Contractor through performance on the contract shall be to the Purchaser's account and are in addition to the prices quoted in the proposal. Contractor shall not be responsible for any additional costs associated with the Purchaser's tax exemption certificate and the governing body's acceptance of same.

**12.0 DELIVERY**

**12.1 Title**

Title to all equipment shall pass to Purchaser at the FOB point or points of shipment and risk of loss will thereafter be borne by Purchaser.

**12.2 Storage**

If the Purchaser declines or is unable to take delivery at the time(s) specified in the proposal or contract, Contractor will have the equipment stored for Purchaser at Purchaser's risk and account, and the materials shall be considered "shipped".

**13.0 PAYMENT**

**13.1 Terms of Payment**

Unless otherwise agreed, the payment schedule shall be as outlined herein and payments shall be made within thirty (30) days of presentation of an invoice. Payments not received by the due date shall be subject to a monthly interest charge at the rate of 2% per month or the maximum allowed by law, whichever is less, due and payable until the payment is received.

**13.2 Payment Schedule**

- a. 10% down with the order
- b. Engineering progress payments (monthly, based upon percent completed)
- c. Material & Equipment delivered to project (monthly, based upon percent shipped)



In the event a retention value is required and agreed, it shall accrue interest at the rate of 1% per month on the outstanding balance until exchanged for a letter of credit or paid to Contractor. Contractor retains the unqualified option to provide Purchaser with a letter of credit in lieu of retention at any time during the performance of the contract.

**13.3 Default in Payment**

- a. If any payment due to Contractor is more than thirty (30) days past due, Contractor shall have the right at its sole option to accelerate the payment of all outstanding amounts, including, but not limited to, amounts previously retained pursuant to the agreement, by notifying Purchaser in writing that all outstanding amounts are immediately due and presenting Purchaser with an invoice for said amount. Contractor shall also have the right in such event to discontinue all work on the project without incurring any liability to Purchaser for such action.
- b. In the event the total aggregate amount of delinquent payments exceeds at any point during the term of the agreement ten (10%) of the total contract amount, Purchaser shall provide at Contractor's request, additional collateral, including but not limited to irrevocable letters of credit, sufficient to secure payment of all contract amounts.
- c. The foregoing remedies of Contractor are in addition to all other remedies Contractor may have at law or in equity, including but not limited to the right to obtain liens on Purchaser's assets through legal or equitable proceedings.

**13.4 Payment of Retained Amounts**

- a. If this contract permits Purchaser to withhold final payment, and acceptance is not based upon performance tests, such final payments shall be due and payable within thirty (30) days after the equipment is ready for operation.
- b. If such deferred payment is contingent upon tests and such tests are delayed through no fault of Contractor for more than thirty (30) days after the equipment is first ready for operation, final payment shall be due and payable upon expiration of such thirty (30) day period.

**14.0 CANCELLATION**

Purchaser's cancellation of the contract is subject to a cancellation charge of 10% of the total price of the contract, plus Contractor's actual expenses and expenses to which Contractor has become committed for fulfillment of the contract before notice of cancellation is received.

**15.0 SUSPENSION**

In the event Purchaser suspends the execution of work on this contract, Purchaser shall reimburse Contractor for all costs incurred by Contractor as a result of such suspension, including, without limitation, all borrowing and opportunity costs. In the event the suspension exceeds 180 days in duration, in addition to being entitled to full reimbursement of costs as aforesaid, Contractor shall have the unqualified right to cancel the unfinished portion of the contract without liability to Purchaser of any kind. Should the contract be canceled the provisions of Article 13.0 shall apply.

**16.0 OSHA - FEDERAL, STATE AND LOCAL**

Contractor agrees to comply with the Federal OSHA requirements in effect as of the date of this proposal relative to the design of the equipment furnished within its scope of supply as defined in this proposal. Where state or local safety and health requirements differ from the Federal OSHA requirements, modifications or changes in design to meet state or local safety and health requirements will be incorporated at Purchaser's request. Additional costs arising from such requests and from erection procedures required by state or local safety and health regulations which deviate from Federal OSHA requirements will be for Purchaser's account.

**17.0 PROPRIETARY AND CONFIDENTIAL MATERIALS**

All drawings, patterns, specifications and information included in Contractor's proposal or contract and all other information otherwise supplied by Contractor as to design, manufacture, erection, operation and maintenance of the equipment shall be the proprietary and confidential property of Contractor and shall be returned to Contractor at its request. Purchaser shall have no rights in Contractor's proprietary and confidential property and shall not disclose such proprietary and confidential property to others or allow others to use such property, except as required for the Purchaser to obtain service, maintenance, and installation for the equipment purchased from the Contractor. This clause shall survive the termination of this contract and be in effect as long as the Purchaser has possession of any of the Contractor's proprietary or confidential property.

**18.0 ASSIGNMENT**

Contractor retains the right to assign this contract to any subsidiary or affiliated company of Contractor without the Purchaser's prior approval. All other assignments by either Contractor or Purchaser require the prior written consent of the other party.

**19.0 HAZARDOUS MATERIALS**

The Purchaser's facilities may contain hazardous materials, including asbestos bearing materials. Contractor's services do not include directly or indirectly performing or arranging for the detection, monitoring, handling, storage, removal, transportation, disposal or treatment of petroleum or petroleum products (collectively called "Oil") or of any hazardous, toxic, radioactive or infectious substances, including any substances regulated under RCRA or any other Federal or State environmental laws (collectively called "Hazardous Materials"). If any such materials are encountered, Contractor shall have no obligation to remove or remediate them in the absence of a separate agreement which includes separate consideration to Contractor for such work. If Contractor or any of its subcontractors is required to perform work within or immediately adjacent to any facilities that are determined to contain hazardous materials and/or asbestos, and the said work must be interrupted to allow for the remediation or



removal of such materials by others, Contractor shall be entitled to any and all costs and other expenses associated with such interruption in work. Purchaser shall fully defend, hold harmless and indemnify Contractor and its agents from and against any claims arising out of exposure to such hazardous and/or asbestos bearing materials.

**20.0 SAFETY**

Contractor shall not be responsible for health or safety programs or precautions related to Purchaser's activities or operations, Purchaser's other contractors, the work of any other person or entity, or Purchaser's site conditions. Contractor shall not be responsible for inspecting or correcting health or safety conditions or deficiencies of Purchaser or others at Purchaser's site, and Purchaser agrees to indemnify, hold harmless, and defend Contractor against any claims arising out of such conditions or deficiencies. So as not to discourage Contractor from voluntarily addressing health or safety issues by making observations, reports, suggestions, or otherwise, it is understood and agreed that Contractor shall nevertheless have no liability or responsibility arising on account thereof.

**21.0 DISPUTES**

In the event of a dispute arising hereunder, the parties will attempt to amicably resolve the dispute. If after good faith negotiations, the parties cannot reach agreement, then the matter shall be resolved in a court having jurisdiction.

**22.0 CONTRACT INTERPRETATION**

**22.1** If any of the provisions of these Standard Conditions of Sale (including statements made in the proposal) conflict with any provisions in the Purchaser's documents, the former shall govern unless Contractor expressly agrees to the contrary in writing. Any contract resulting from this proposal shall be construed, and the legal regulations of the Contractor and Purchaser shall be determined in accordance with the laws of the State of New Jersey, U.S.A.

**22.2** All communications, written and verbal, between the parties hereto with reference to the subject of this proposal prior to the date of its acceptance are merged herein and this proposal, when duly accepted and approved, shall constitute the sole and entire agreement and contract between the parties as to the subject matter thereof. No changes in or modifications of said agreement shall be binding upon the parties of either of them, unless they shall be in writing duly accepted by the Purchaser and approved in writing by Contractor.

**23.0 ACCEPTANCE**

This proposal is subject to acceptance by the Purchaser within thirty (30) days and shall constitute a binding agreement with Contractor only when thereafter approved by Contractor and signed by an authorized officer.

**24.0 SEVERABILITY**

Should any part of this Agreement be declared invalid or unenforceable, such decision shall not affect the validity of any remaining portion, which remaining portion, shall remain in full force and effect, and Seller shall have the right to replace the part declared invalid or unenforceable with a provision which serves as much as validly possible the same commercial purpose as the part determined to be invalid or unenforceable.

**25.0 CHANGES/ADDITIONAL WORK**

Contractor is not obligated to incur any expense or do any work in excess of that reasonably anticipated unless the Purchaser issues a Change Order for such expense or work with mutually acceptable terms and conditions.

RM Technologies  
Aqueous Ammonia Storage Tank Vendor Budget Estimate

Vendor: RM Technologies  
Laurel Corporate Center  
8000 Midlantic Drive, Suite 110S  
Mt. Laurel, NJ 08054-1548

Date: 7/31/02

Storage Tank Type:

Stainless Steel, Horizontal, includes valves and transfer station.

Budget Estimates:

Size	Budget Estimate
10,000 Gallon	\$160,000 - \$170,000
30,000 Gallon	\$210,000 - \$220,000




- Home
- Services
- Products
- Power Plants
- Refrigeration
- Water Treatment
- Chemical Plants
- Heat Treatment
- Feedback
- Contents
- Search
- Our Mission
- Info Request
- Affiliations
- Ammonia Library

### Aqua Storage Tanks

Aqua ammonia storage tanks are of the above ground, horizontal type, with spherical heads, having capacities ranging from 8,000 to 30,000-water gallon. They are constructed of 304 Stainless Steel and are built in accordance with the latest edition of the ASME Code for Unfired Pressure Vessels, Section VIII, Division 1, rated for 30 psi. and are registered with National Board. The tanks can be supplied completely fitted in accordance with industry and regulatory standards. Typical tank fittings include a 2" vapor fill connection with dip tube, 2" liquid fill connection, 2" service to point of use connection, 1/2" pressure gauge connection, 2 1/2" level gauge connection, 1/2" thermowell connection, 2" safety relief connection, 2" vacuum breaker connection, 2" liquid drain connection, manway, 2" spare vapor connection, 2" liquid return connection with dip tube, 2" level probe connection with dip tube, 2" level probe connection with dip tube, and 10" high saddles. Tanks can be supplied with all necessary trim as per customers' requirements.

#### Typical Aqua Storage



**Tan**

Send mail to [rmtech@bellatlantic.net](mailto:rmtech@bellatlantic.net) with questions or comments about

this web site or Contact us at 609-702-8260.

Last modified: March 19, 2000

Abstract - May 2002 DOE/NETL Pittsburgh Conference on SNCR and SCR

## SNCR System - Design, Installation, and Operating Experience

David L. Wojichowski

De-NOx Technologies LLC, 22 Partridge Lane, East Hampstead, NH 03826

E-Mail: dwojichowski@de-nox.com, Telephone (978) 828-4321, Fax (605) 238-4450

### Summary

SNCR is a mature technology for moderate, i.e. 40-60% reduction, of uncontrolled NOx in high temperature combustion gasses. The technique was originally pioneered by Exxon using ammonia as the reagent. The patents on this technology expired in the late 80's. In the early 1980's, EPRI received two process patents for the same basic techniques, only using urea instead. One was for the oxygen rich environment and the other for fuel rich at even higher temperatures. These basic patents have now also expired. The mechanics of the two techniques differ mainly in that ammonia injection is gaseous and urea is liquid. Otherwise, both use very similar fluid injection and control techniques.

SNCR systems are often the technology of choice for applications requiring moderate, i.e., 40-60% NOx reduction and has been proven many times over. Broken down into its most basic chemistry, the technique requires thorough mixing of the reagent into the furnace chamber with at least 0.5 seconds of residence time at a temperature above 1600F and below 2100F. Optimally, the reagent is usually injected into the furnace at approximately 1900 - 1950F which is a good tradeoff between the competing reaction of oxidation of ammonia to NOx and maximizing the residence time prior to the low temperature limit. Hence the location, design, and atomization characteristics of the injectors are critical considerations.

Under laboratory conditions, NOx reductions in excess of 90% has been demonstrated. Unfortunately, these conditions are never observed in reality. The closest approach to these ideals are seen in waste incinerators, wood fired units, and some CFB's. These units have in common ample residence time

above the minimum reaction temperature, base loaded conditions, and furnace dimensions which allow for effective dispersion of the reactant through the entire furnace cross section. In broad terms, these units routinely demonstrate 50% NO<sub>x</sub> reduction at a Normalized Stoichiometric Ratio (NSR) of 1.0 with less than 10 ppm ammonia slip.

Larger utility boilers have reported lower performance mainly due to the size of the units, inaccessible areas for injection, and load following control issues. NO<sub>x</sub> reductions in the range of 25 - 50% are common.

The most common side effects of SNCR are injector burn-out, localized boiler corrosion, and plume formation. At solid waste incinerators, a combination of high temperatures, high chlorides, and slagging operation have been known to reduce injector lifespans to 6-10 weeks. The net result on Operations has been frequent tip replacement and operation with a fraction of the optimum number of injectors. Often 25 MW boilers operate with as few as four wall injectors and accept the lower performance/higher slip which result. Alternate designs are now being used which improve on this situation by using higher classes of metallurgy with greater wall thickness and easily replaceable lances.

Localized boiler corrosion is most noted with liquid reagents. In particular, waterwall thinning is common in the immediate vicinity of the injectors. This is suspected to be caused by droplet impingement on the unprotected tubes from localized eddies. The operating solution is to overlay the immediate areas with Inconel, further extend the injection tips into the furnace, and higher energy atomization. This concern also applies to convective surfaces located within 0.1 - 0.2 seconds of an injection nozzle.

The key to minimizing plume formation is to reduce the amount of ammonia slip. This requires a thorough knowledge of the boiler temperature profile and should be the first thing checked. Nozzles placed too high in the boiler will operate on the left side of the effective temperature curve and results in high slip. Nozzles arranged non-symmetrically will tend to overdose parts of the gas stream and under dose others. Low carrier air or steam flows can create droplets which are too large to evaporate quick enough as well as poor penetration into the middle of the furnace cavity. Prior to the availability of accurate and inexpensive in-situ ammonia monitors, on-going process detective work was limited to reagent consumption and controlled NO<sub>x</sub> concentrations from a CEM. This only told half of the story and limited the certainty in any optimization evaluation. With them installed, the operator can better correlate

cause and effect as well as better manage reagent consumption and plume formation.

The life cycle cost of an SNCR system is one of the better values associated with NOx controls, especially on existing units. The capital cost could be as low as \$5 per kW on very large facilities, or those base-loaded facilities not in need of sophisticated controls. More typical is a capital cost in the range of \$10 - 20/kW. The system can be installed in 6-8 weeks with minimal boiler down-time - often tying in during scheduled 3 day outages. An operating cost in the neighborhood of \$500 per ton of NOx removed is typical, due almost exclusively to reagent cost. This is cheaper than the installation of low-NOx burners and OFA injection, and achieves the approximate same end result.

Lately, there has been very promising results from combining SNCR with combustion modifications to achieve high NOx reduction without committing to the high capital cost of an SCR system. In most cases, SNCR and combustion modifications are quite compatible, yielding a combined NOx removal of 70-75 % NOx reduction at a capital cost of approximately \$50/kW. This technique, in combination with NOx credits, will have broad appeal to medium power boilers in pursuit of NOx compliance at the minimum cost.



# **NOx Control for Power Generation Overview**

---

---

Presented to TCET

**May 21<sup>th</sup>, 2002**

**Tony Facchiano, Program Manager  
Boiler Performance and NOx Control**



# **NOx Destruction**

**(e.g., Post-Combustion)**

## **Technologies**

<b>Technology</b>	<b>NOx Reduction (%)</b>	<b>Cost (\$/kW)</b>
<b>Reburning</b>	<b>25-40 (lean) 45-65 (conv.)</b>	<b>3-6 (lean) 15-30 (conv.)</b>
<b>SNCR</b>	<b>15-40</b>	<b>10-20</b>
<b>SCR</b>	<b>50-95</b>	<b>60-140</b>
<b>Hybrids</b>	<b>50-95</b>	<b>SNCR&lt;hybrid&lt;SCR</b>

**FGD VENDOR QUOTES**

**GOLDER ASSOCIATES  
GAINSVILLE, FLORIDA**

**FOR**

**FLORIDA CRYSTALS**

**FGD BAGHOUSE SUPPLY & INSTALLATION**

**HAMON RESEARCH-COTTRELL, INC.**

**BUDGET PROPOSAL NO. P- 9030**

**JULY 9, 2002**

**The following proposal contains confidential and proprietary information of Hamon Research-Cottrell, Inc. (the "Company") and is not to be disclosed to any third parties without the express prior written consent of the Company. This proposal is submitted solely for the purpose of enabling client to evaluate the Company's bid on the within project and shall be returned to the Company or destroyed if so requested by the Company**





# HAMON RESEARCH-COTTRELL, INC

## TABLE OF CONTENTS

- I HAMON RESEARCH-COTTRELL INTRODUCTION
- II FGD SYSTEM SCOPE OF SUPPLY
- III DRY SCRUBBER DESCRIPTION
  - 1.0 TECHNICAL PARAMETERS
    - 1.1 Process Description
  - 2.0 EQUIPMENT DESCRIPTION
    - 2.1 System design Feature Highlights
      - 2.1.1 SDA Vessel Design
      - 2.1.2 Inlet Gas Distributor
      - 2.1.3 Atomizer Lubrication System
      - 2.1.4 Rotary Atomizer Design
    - 2.2 Spray Dryer Absorbers
      - 2.2.1 Spray Dryer Absorber
        - 2.2.1.1 Hopper
        - 2.2.1.2 Cylindrical and Lower Conical Section
        - 2.2.1.3 Inlet Gas Distributor
        - 2.2.1.4 Rotary Atomizer
        - 2.2.1.5 Atomizer Parts and Tools
        - 2.2.1.6 Atomizer Maintenance Removal System
    - 2.3 Miscellaneous Components
      - 2.3.1 Ductwork and Expansion Joints and Dampers
      - 2.3.2 Stairs, Walkways and Platforms
      - 2.3.3 Support Steel
      - 2.3.4 System Piping
      - 2.3.5 Instrumentation and Control System Hardware
      - 2.3.6 Electrical Equipment
      - 2.3.7 Surface Preparation and Painting
    - 2.4 Lime Storage and Preparation System
      - 2.4.1 Lime Storage
        - 2.4.1.1 Storage Silo
      - 2.4.2 Lime Slaking equipment
        - 2.4.2.1 Volumetric Screw Feeder
        - 2.4.2.2 Lime Slakers
        - 2.4.2.3 Covered Slurry Storage Tank
        - 2.4.2.4 Pump Station
        - 2.4.2.5 Local Control System
        - 2.4.2.6 Miscellaneous



## HAMON RESEARCH-COTTRELL, INC

### TABLE OF CONTENTS (CONTINUED)

- 2.5 Technical Services
  - 2.5.1 Erection Advisory Services
  - 2.5.2 System Start-up Service
  - 2.5.3 Operator Training Program

#### IV FABRIC FILTER

- 1.0 FABRIC FILTER TYPE
- 2.0 DESIGN CONDITIONS
- 3.0 CONFIGURATION
- 4.0 MATERIALS OF CONSTRUCTION
- 5.0 SYSTEM DESCRIPTION
  - 5.1 Description of operation
  - 5.2 Filter bags
  - 5.3 Filter bag support arrangement
  - 5.4 Casing
  - 5.5 Hoppers
  - 5.6 Tube sheet
  - 5.7 Dampers
  - 5.8 Support steel
  - 5.9 Slide plates
  - 5.10 Access doors
  - 5.11 Access system
  - 5.12 Compartment ventilation system
  - 5.13 Instrumentation and control
  - 5.14 Paint
  - 5.15 Model study
  - 5.16 Commissioning
  - 5.17 Training program
  - 5.18 Field erection consultant



## HAMON RESEARCH-COTTRELL, INC

### TABLE OF CONTENTS (CONTINUED)

- V TECHNICAL SERVICES
- VI TERMINATION POINTS
- VII ITEMS TO BE FURNISHED AND INSTALLED BY OTHERS
- VII BUDGET PRICING



## HAMON RESEARCH-COTTRELL, INC

### I HAMON RESEARCH-COTTRELL INTRODUCTION

Hamon Research-Cottrell's professionals are air pollution control specialists. Our regional technical service representatives, our engineering and technical support staff, as well as international license affiliates and research and development engineers all work together to provide our clients with optimal solutions that work.

Other important features of the Hamon Research-Cottrell offering include:

Hamon Research-Cottrell Design and Engineering - Hamon Research-Cottrell has a significant number of APC system installations around the world, on both industrial as well as utility combustion applications. Hamon Research-Cottrell is one of the most recognized industry leaders in air pollution control, accommodating stringent particulate control needs by providing both complete new systems and retrofit of existing systems with both ESP and Fabric Filtration Systems.

Project Management - The project team will be led by a Project Manager who will be the primary contact between the Buyer and Hamon Research-Cottrell. He will be assisted by a Project Engineer and the various department heads of Engineering, Purchasing, Construction, Health and Safety, and Finance.

Field Services - The success of any project lies not only with the proper design and engineering of the baghouse and associated equipment, but also with the completion of commissioning in a timely matter. Hamon Research-Cottrell will provide the services of a Field Service Representative who will conduct specialized training of Owner's operating and maintenance personnel and who will also check out and start up the fabric filter equipment.

Quality Assurance/Quality Control - Hamon Research-Cottrell also recognizes the importance of quality assurance and quality control in each of our projects and is committed to the implementation of an effective quality assurance program to control the production and inspection of all of the products and services we provide.

The purpose of Hamon Research-Cottrell's QA program is to provide, by means of planned and systematic actions, adequate confidence that materials and workmanship, during all stages of design and procurement, are in compliance with contract specifications. Hamon Research-Cottrell is an ISO 9000 Certified Company.

#### *Conclusion*

With our large scale utility fabric filter, electrostatic precipitator and FGD experience, the Hamon Research-Cottrell team stands ready to work with all parties involved in the implementation of an air pollution control strategy for this facility. We can assure you of a team effort with focus on technical proficiency, fiscal accountability and professional integrity. With our extensive utility fabric filter operating experience, our aim is not simply to satisfy your expectations in all aspects of job performance, but to exceed them and, by



## HAMON RESEARCH-COTTRELL, INC

doing so, to demonstrate to you and your clients our corporate commitment to excellence and the ultimate success of this important project.

We as a company stand alone amongst our competitors and are uniquely qualified in our understanding of what is required to make this emissions reduction project successful.

### II SYSTEM SCOPE OF SUPPLY

Hamon Research-Cottrell has developed a Dry Flue Gas Desulfurization (DFGD) proposal based on Marsulex Environmental Technologies' spray dryer absorber (SDA) and Hamon Research-Cottrell's fabric filter (PJFF) technology.

The scope of work included in this proposal includes the design, detailed engineering, procurement, manufacture and delivery of one (1) 100% capacity DFGD system for each boiler with common auxiliary subsystems as noted herein. A summary of the equipment scope is as follows otherwise unless noted:

- Two (2) 100% capacity Spray Dryer Absorber (SDA) vessels featuring rotary atomization
- One (1) common lime storage/preparation/slurry delivery system with dedicated slurry preparation trains for each boiler unit
- Two (2) 100% capacity Low Pressure/High Volume Pulse Jet Fabric Filter
- Connecting ductwork from SDA outlets to fabric filter inlets
- Structural support steel for the scope
- Stairs, ladders, platforms and walkways for the scope
- Process piping and valves
- DFGD system control instrumentation
- On-site training
- Site start-up advisory services (per diem)



## HAMON RESEARCH-COTTRELL, INC

### III. DRY SCRUBBER DESCRIPTION

#### 1.0 TECHNICAL PARAMETERS

##### 1.1 Process Description

HRC's Dry FGD system will be designed to treat the total flue gas stream being discharged from two (2) cogeneration biomass burning boilers. One hundred percent of each boiler flue gas is introduced into one (1) SDA vessel, sized to treat 100% of the maximum gas flow through specially designed inlet gas distributors. Upon entering the reaction chamber, the flue gas comes into intimate contact with finely atomized droplets of fresh lime reagent and by-product recycle slurries which absorb and neutralize the SO<sub>2</sub> and other acid gases contained in the flue gas stream. The fresh lime and by-product recycle slurries are atomized to the desired droplet size by rugged and reliable rotary atomizer units. The atomizer system proposed for this project is an APV Anhydro direct drive design that is based on over 40 years of spray drying experience and 3,000 atomizer units in operation. Through contacting the atomized sprays, the hot flue gas is cooled to a pre-set temperature due to the evaporation of the precisely controlled water quantity input with the reagent and by-product slurries. This pre-set temperature is 30°F above the approach to adiabatic saturation temperature of the flue gas stream.

The scrubbed flue gas and 85% to 90% of the resulting particulate matter exit each SDA vessel through a single outlet duct that connects to the fabric filter inlet manifold. Upon entering the fabric filter inlet manifold, the flue gas is distributed between the operating fabric filter compartments where final particulate removal is performed along with additional SO<sub>2</sub> removal as the gas passes through the collected dust layer. The cleaned flue gas enters the fabric filter outlet manifold where it is conveyed to the ID fans and then discharged to the stack inlet.

The spray dryer absorbers are designed as a single atomizer system per vessel for highest system reliability and minimum operating components. Recognizing the difficulties in operating with lime slurries in a hot flue gas environment, it is normal preventative maintenance practice to perform atomizer rotation on a scheduled frequency of two to four weeks between inspections.

During this time period, the atomizer scheduled for inspection is removed from operation and the standby atomizer installed and immediately placed into service. This one vessel out of service time is typically less than one hour during which the overall DFGD system SO<sub>2</sub> removal performance drops below the design removal efficiency. However, once the standby atomizer begins operation, SO<sub>2</sub> removal performance returns to the specified levels.



## HAMON RESEARCH-COTTRELL, INC

### 2.0 EQUIPMENT DESCRIPTION

#### 2.1 System Design Feature Highlights

The DFGD System incorporates several unique design features, which should be considered in evaluating the reliability and cost effectiveness of a flue gas desulfurization plant. The following is a brief summary of these features.

##### 2.1.1 SDA Vessel Design

The MET spray dryer absorber design incorporates a single rotary atomizer and a specially designed inlet gas distributor. The cyclonic inlet gas distributor with internal directional vanes is designed for uniform mixing of the entering flue gas with the atomized slurry spray pattern. Due to the symmetrical spray pattern and absence of internal ducts projecting into the reaction zone, the potential for material build-up inside the vessel is greatly reduced. Since all the flue gas enters at the top of the absorber vessel, the full cylindrical vertical height is available to provide sufficient drying of reaction products prior to entering the downstream fabric filter. With the sectionalized gas inlet arrangements, optimized gas/slurry mixing can be maintained at flow rates as low as 25% of the design operation point while also meeting performance requirements at all load ranges. Operation below the 25% load point is also easily accommodated albeit at a less efficient lime utilization rate.

##### 2.1.2 Inlet Gas Distributor

The MET spray dryer absorber design incorporates a single rotary atomizer and a specially designed, scroll type inlet gas distributor. The rotary atomizer is mounted on the centerline axis of the absorber with the complete flue gas flow introduced concentrically to the atomizer wheel. Internal adjustable guide vanes and directional vanes located at the discharge of the inlet gas distributor provide uniform mixing of the flue gas with the atomized slurry immediately upon entering the reaction zone. These vanes are critical in maintaining proper gas/slurry mixing as well as constraining the reaction zone within the vessel diameter and preventing wall and ceiling buildup and deposits.

The gas distributor is tapered in cross-section to provide a relatively constant gas velocity around the circumference of the vessel inlet gas passages. An optimized operating turndown ratio is efficiently accomplished by dividing the inlet gas distributor into separate flow paths. A louver type damper is installed to control flow through each of the separate flow paths. As process load varies, the pneumatically operated louver blades are sequentially closed or opened to maintain appropriate flue gas velocities through the inlet gas distributor. The annular entry opening closest to the atomizer wheel is always open and discharging flue gas into the SDA vessel.



## HAMON RESEARCH-COTTRELL, INC

The separate path inlet gas distributor and the control distinction between increasing and decreasing flue gas flow conditions allows for optimization of the MET spray dryer absorber performance throughout the design operating range. MET's inlet gas distributor design and control technology improves operation at all boiler load ranges along with minimizing lime consumption rates. Automatic control by the DFGD control system integrates operation of these damper blades with the actual operation of the upstream process.

### 2.1.3 Atomizer Lubrication System

The atomizer spindle and motor bearings are lubricated by an automatic lubrication system. The system operates with volumetric dosing of a very small flow of lubricating oil from a central storage reservoir by a proportioning dosing valve directly to the bearings. After passing through the bearings, the oil is collected in a small reservoir in the atomizer body, from where it is pumped back to a waste oil storage tank for eventual disposal.

The lubrication system includes all necessary controls to ensure safe and continuous atomizer operation, as well as provisions for automatic atomizer shutdown for low oil pressure or lubrication component malfunction. The lubrication system is designed to provide lubrication service in the event of atomizer shutdown or emergency trip. The atomizer also includes provisions for manual lubrication in the event of a lubrication system malfunction.

### 2.1.4 Rotary Atomizer Design

The Anhydro DFGD atomizer design uses a direct drive system for atomizers rated at 200 HP and above. This approach was chosen to increase component life, improve operating reliability, and reduce power transmission losses, which are encountered in conventional gear-driven units. As an added benefit, the use of a variable frequency drive provides a low inrush current to the atomizer motor, resulting in reduced motor thermal stresses.

The Direct Drive Atomizer System consists of a variable frequency drive unit powering an AC induction motor, which is directly coupled via a flexible diaphragm coupling to the rotary atomizer drive spindle.

The variable frequency drive (VFD) unit controls the motor speed up through 7,800 rpm to achieve the proper slurry atomization tip speed at the atomizer wheel discharge point. During normal operation, the atomizer unit operates at a constant rotation speed of 7,800 RPM, regardless of boiler load or inlet gas conditions.





## HAMON RESEARCH-COTTRELL, INC

### 2.2 Spray Dryer Absorbers

The following numbered items comprise a description of the major equipment and services provided for each boiler for this project unless noted.

#### 2.2.1 Spray Dryer Absorber

One (1) 100% capacity spray dryer absorber (SDA) vessel will be furnished with the following features described on a per absorber basis

##### 2.2.1.1 Hopper

One (1) conical section hopper with a 60° internal cone angle

- Fabricated from 3/8" A-36 steel plate
- One (1) outlet duct
- One (1) 24" diameter quick opening access door
- Two (2) poke holes and strike plates, rodding device
- Hopper heaters with thermostatic control

##### 2.2.1.2 Cylindrical and Lower Conical Section

- Fabricated from minimum 1/4" A-36 steel plate.
- 37'-0" diameter x 50'-0" high cylindrical section
- One (1) 2' x 4' bolted access door

##### 2.2.1.3 Inlet Gas Distributor

- Specially designed scrolled configuration to provide initial pre-swirling of inlet flue gas.
- Manually adjustable inlet gas disperser vanes at the point of flue gas entry to optimize the gas flow pattern in the reaction chamber during mixing with the atomized spray.
- One (1) 2' x 4' bolted access door.

##### 2.2.1.4 Rotary Atomizer

Each SDA vessel will be supplied with one (1) Anhydro rotary atomizer with the following features:

- Stainless steel construction for components coming in contact with the scrubbing liquid.
- Center rotating spindle assembly drive.



## HAMON RESEARCH-COTTRELL, INC

- Specially designed heat dissipating bearings providing two (2) point spindle support.
- Replaceable bearing cartridge design for rapid maintenance
- Automatic oil lubrication system servicing the upper and lower spindle bearings.
- Statically and dynamically balanced atomizer wheel machined from stainless steel with integral silicon carbide wear tiles and nozzles.
- Vertically mounted, high speed AC induction drive motor.
- Variable frequency drive system.
- Integral lifting bracket for complete atomizer removal.
- Maintenance stand for atomizer placement when removed from service.
- One (1) standby rotary atomizer unit complete with motors will be provided to serve as a reserve standby for two operating atomizer, i.e. one (1) per two (2) SDA vessels.

### 2.2.1.5 Atomizer Parts and Tools

- One (1) set of special tools for servicing the rotary atomizer unit

### 2.2.1.6 Atomizer Maintenance Removal System

- Checker plate service platform on top of the spray absorber gas distributor.
- Monorail beams supported from the building enclosure will be provided for mounting the atomizer maintenance and removal hoists
- One (1) common atomizer removal hoist electrically operated with motorized trolley to service each SDA.
- One (1) common electric hoist with motorized trolley providing atomizer unit lift-to-grade capacity.

## 2.3 Miscellaneous Components

### 2.3.1 Ductwork and Expansion Joints and Dampers

The following ductwork will be provided for each DFGD Subsystem:

SDA outlets to PJFF inlet manifolds

All ductwork will be fabricated from 3/16" minimum thickness ASTM A-36 steel plate with ASTM A-36 stiffeners. Fabric bellows-type expansion joints as required will be provided for the supplied ductwork



## HAMON RESEARCH-COTTRELL, INC

### 2.3.2 Stairs, Walkways and Platforms

Stairway access common to the SDA and PJFF as required for SDA and PJFF maintenance will be provided. Platforms will be provided to access instrument taps, and compartment inspection doors. Ladder and platform access to inlet ductwork test ports and lower access door will be provided.

Access facilities with the following features:

- ASTM A-36 structural steel walkway, framing and stringer support steel.
- 1-1/2" OD standard pipe handrailing, Schedule 40 pipe.
- Steel grating 1-1/4" x 3/16".
- Spray dryer absorber roof access platforms.

### 2.3.3 Support Steel

Structural support steel for the SDA, particulate collector, system ductwork, silos, miscellaneous equipment and access systems will be ASTM A-36 material.

### 2.3.4 System Piping

Carbon steel piping will be furnished to convey the lime slurry and service water to the SDA roof level areas.

### 2.3.5 Instrumentation and Control System Hardware

HRC will supply control logic information for the Owner to program his DCS unit which will be capable of operation and control of the spray dryer absorbers and fabric filter system interfacing with the lime preparation systems. Control and equipment status will be available from the Owner's DCS in the plant's main control room via the Owner's high-speed data highway.

Local instrumentation for operation and control of the DFGD system will be provided including field-mounted instrument racks as required.

### 2.3.6 Electrical Equipment

The motor control centers or power distribution equipment required to operate the proposed DFGD equipment are to be provided by others.

### 2.3.7 Surface Preparation and Painting

Un-insulated surface areas of the absorber, ductwork, access steel, support steel, ladders, walkways, and railing will receive surface preparation and cleaning and shop primer coating in accordance with HRC's standard specifications. Off the shelf equipment including electrical equipment will receive the manufacturer's standard paint system.



## HAMON RESEARCH-COTTRELL, INC

### 2.4 Lime Storage and Preparation System

One (1) complete system for receiving and storing bulk pebble lime, lime slurry preparation and storage equipment and pump station to pump the lime slurry to the SDA roof penthouses and rotary atomizers will be furnished to serve the FGD system needs of both boilers. This common system will serve all SDA vessels. This equipment will be arranged as a cylindrical self supporting structure beginning with the lime slurry storage tank and pump station at grade elevation; slakers, vibrating screens and lime feeders on the second level; and the integral lime storage silo above this point. This system will include the following basic features subject to the selected system supplier's standard package, except as noted:

#### 2.4.1 Lime Storage

##### 2.4.1.1 Storage Silo

- One (1) welded silo for pebble lime storage. Storage time is normally twenty-four (24) hours at the BMCR design conditions.
- 20" diameter combination manhole and pressure relief valve in the roof.
- High and low level indicators.
- 60° cone bottom with a manually operated knife gate.
- Electrical bin activator discharges to Y-chute with pneumatic slide gate valve at the inlet of each volumetric feeder.
- Roof access including ladder with cage from grade, roof handrail with toe plate and necessary transfer and service platforms.
- 4" diameter Schedule 40 fill pipe including truck connection, dust cap and limit switch on end of pipe.
- Roof-mounted vent filter.
- Shop prime painting of un-insulated surfaces.

#### 2.4.2 Lime Slaking Equipment

##### 2.4.2.1 Volumetric Screw Feeder

- Two (2) 120% capacity screw feeders
- Manually adjustable SCR drive and chute to slaker.



## HAMON RESEARCH-COTTRELL, INC

### 2.4.2.2 Lime Slakers

- Two (2) 120% vertical lime slakers (one to serve each boiler unit). Slaked milk of lime product will discharge to a vibrating screen (one per slaker) to facilitate grit removal prior to feeding into the common lime slurry storage tank.

### 2.4.2.3 Covered Slurry Storage Tank

- One (1) common 130,000-gallon slurry storage tank.
- Top mounted slow speed vertical mechanical mixer
- One (1) ultrasonic level sensor
- Inlet/outlet/drain connections.
- Access manhole in top.

### 2.4.2.4 Pump Station

- Four (4) 100% capacity 75 HP centrifugal 350 gpm slurry feed pumps, one (1) operating and one (1) standby for each boiler unit.
- Manual flush valves for pump and line flushing.
- Connecting piping internal to lime preparation system.

### 2.4.2.5 Local Control System

- Suppliers standard NEMA 4 lime slaker control panel with starters, PLC, switches, indicating lights and other components required for operation.

### 2.4.2.6 Miscellaneous

- Interior light fixtures.
- Wall mounted exhaust fans with automatic shutter.
- Heavy-duty electric heater for enclosure heating.



**HAMON RESEARCH-COTTRELL, INC**

**IV FABRIC FILTER**

**1.0 FABRIC FILTER TYPE**

Hamon Research-Cottrell is proposing our patented, Low Pressure/High Volume (LPHV) Pulse jet fabric filter technology. The following describes the fabric filter and accessories offered for each boiler unless noted.

**2.0 DESIGN CONDITIONS**

Specific conditions which will be incorporated into the design are:

Flue Gas volumetric flow rate	326,000 acfm at actual conditions
Flue gas volume from spray absorbers	310,000 acfm
Operating temperature	160° F at spray absorber outlet
Design temperature	370°F
Excursion temperature	400°F for up to thirty (30) minutes
Operating pressure	-18" w.c. at air heater outlet
Design pressure	+35"/-35" w.c.
Transient pressure	+15/-35" w.c.
Inlet particulate loading	5.00 gr/acf



## HAMON RESEARCH-COTTRELL, INC

### 3.0 CONFIGURATION

Salient features of the fabric filter configuration are as indicated below:

Number of fabric filters	2
Number of compartments/fabric filter	6
No. bag bundles/compartiment	1
No. of cleaning arms/bundle	3
No. bags/compartiment	544
No. bags/fabric filter	3264
Bag length	23'-0"
Equivalent bag diameter (nominal)	4.9" Oval (approximately 2 1/2" x 6")
Effective cloth area (sq. ft.): (with seams and cuffs deducted)	
Per bag	27.59
Per compartment	15,008
Per fabric filter	90,050
Air-to-Cloth Ratio:	
Gross (on-line cleaning)	3.44
Net (1 compartment off for maintenance)	4.13
No. of pulse valves/compartiment	1
No. of bags/pulse valve	544
Cleaning air blower system:	
No. of blowers	3 operating plus 1 spare per fabric filter
Blower capacity	1,000 icfm/blower
Blower design pressure	16.2 psig



## HAMON RESEARCH-COTTRELL, INC

### 4.0 MATERIALS OF CONSTRUCTION

The materials of construction for the major components are shown below:

Fabric filter casing & partition walls	3/16" ASTM A36 plate with A-36 stiffeners
Fabric filter hoppers	3/16" ASTM A36 plate with A-36 stiffeners
Fabric filter tube sheet	1/4" ASTM A36 plate with A-36 stiffeners
Fabric filter manifolds	3/16" ASTM A36 plate with A-36 stiffeners
Fabric filter inlet elbows	3/16" ASTM A36 plate with A-36 stiffeners
Bag material	18 oz. PPS
Bag cages	9 gauge mild steel, two piece construction with 10 vertical wires
Handrail and posts	1 1/2" Sch. 40 pipe
Toe plates	1/4" x 4" C.Q.M.S.
Grating & stair treads	1-1/4" x 3/16"





## HAMON RESEARCH-COTTRELL, INC

### 5.0 SYSTEM DESCRIPTION

Hamon Research-Cottrell is proposing its **Low Pressure High Volume (LPHV)** fabric filtration technology to collect particulate from the flue gas exiting the spray absorbers. One (1) independent fabric filter casing, containing six (6) compartments is proposed. The filter bag cleaning system is designed for on-line cleaning which allows any one of the six (6) compartments to be isolated for maintenance. The proposed LPHV pulse jet cleaning system has successfully been utilized on many conventional baghouse installations. The general arrangement drawings of our proposed offering are attached.

#### 5.1 Description of Operation

Our Low Pressure-High Volume pulse jet fabric filter utilizes a unique cleaning mechanism which provides on-line cleaning with the cleaning manifold continuously rotating at approximately 1 R.P.M. above the tube sheet.

The bags are oblong in shape and are arranged in concentric circles with regular spacing specific to each circle. The compactness of this arrangement is only possible with non-alignment of the bags in the radial direction. In the circumferential direction, the bag spacing is regular but specific to each row.

To more fully understand the low pressure, pulse jet system, you must realize that almost the full complement of the powerful cleaning flow is derived from the compartment's air reservoir. Figure 1 depicts an integral tank mounted design. For this proposal, we will be either offering a side mounted tank or an integral design. The low pressure system's nozzle can be




Figure 1



## HAMON RESEARCH-COTTRELL, INC

### 5.0 EQUIPMENT DESCRIPTION (CONTINUED)

#### 5.1 Description of Operation (Continued)

located anywhere on the lengthwise centerline of the bag top, with some degree of "blockage" with the cage top, without detriment to the cleaning effectiveness. Unlike conventional pulse jets, relative position of the LPHV nozzle to bag is not critical. The cleaning air can be released from the reservoir, either by a preset timer, pressure drop initiated, or filter cake drag basis, (preferred) and directed to the manifold via a quick opening pilot assisted diaphragm valve.

The rotating manifold is supported on the tube sheet by a heavy duty, sealed thrust type bearing, designed for long life and low maintenance. The cleaning air distribution pipe and rotating manifold/nozzle assembly is designed such that pressure losses are kept to a minimum and stored energy in the reservoir is utilized to the fullest.

In addition to the primary cleaning action which is produced by an initial rapid fabric deceleration and dust cake dislodgment, the LPHV Pulse jet incorporates an additional feature which enhances fabric cleaning. The high volume of stored cleaning air flowing to the bags in the reverse direction provides a "Back-Flush", or reverse air cleaning effect, which augments the dynamic cleaning of the "pulse" itself. The cleaning air volume includes an extra margin for those cases where the nozzle may be located between bags.

The flue gas enters each compartment through the hopper. Entrance velocities are kept low, approximately 2,000 fpm in the NET condition, to minimize mechanical pressure drop and to also allow larger particulate to fall out into the hopper. This compartment entrance design, along with low can velocities, promotes reduced cleaning frequency, extending bag life and improving filtration efficiency.

Cleaning air will be delivered to each baghouse via two (2) 50% capacity, low pressure positive displacement blowers. A total of three (3) blowers will be provided, two (2) operating plus a spare.

The blowers for the fabric filter are connected by a common piping manifold system which feeds the clean air manifold reservoir tanks located at the baghouse roof level. The air reservoir tanks are sized to deliver a total air volume of 45.0 cu.ft. per pulse of cleaning air. The blowers will be located at grade.



## HAMON RESEARCH-COTTRELL, INC

### 5.0 EQUIPMENT DESCRIPTION (CONTINUED)

#### 5.1 Description of Operation (Continued)

The use of low pressure positive displacement blowers is a major improvement over the use of air compressors and dryers which are required for high pressure pulse jet designs. Air dryers are not required with positive displacement blowers because of the relatively low pressure. In addition, the cleaning air piping is not subject to freezing and/or condensation which can occur in high pressure compressed air lines in locations which are subject to cold ambient temperatures.

*Blowers are more efficient and require less maintenance than compressor and air dryer systems.*

A particular benefit of this unique technology is the requirement for fewer pulse cleaning air diaphragm valves. The LPHV technology requires only one "heavy duty" valve to clean 544 filter bags per bag bundle in each compartment. For this project, only six (6) diaphragm valves are required, that is, one per compartment. In contrast, a conventional pulse jet design could require at least 27 valves per compartment assuming a maximum of 20 bags per valve, equating to 162 valves. This would mean 162 high pressure pulse valves to inspect and maintain as opposed to only 6 valves with our low pressure design. In addition, the LPHV diaphragm valve, located outside the gas stream, is designed to last longer than conventional valves. A silencer is included over each diaphragm valve.

The volume of each cleaning air pulse is derived from theoretical gas laws as well as the number and length of bags being cleaned. The frequency of cleaning, and therefore the required flow rate of cleaning air, is determined from formulae derived from empirical data that has been gathered from an extensive amount of testing carried out at many pilot and full scale pulse jet installations.

#### Bag Inspection and Replacement

A significant benefit of this cleaning method is the absence of blow pipes in the tube sheet area. This allows the bags and cages to be easily accessed for inspection or replacement. Only a single, trifurcated rotating manifold arm is located over each bundle of bags. This manifold arm can be easily moved should it happen to be stopped over the top of a failed bag. With only three rotating cleaning manifold arms in each compartment, inspection and maintenance costs in locating and replacing a potentially failed bag are greatly reduced.

**HAMON RESEARCH-COTTRELL, INC****5.0 EQUIPMENT DESCRIPTION (CONTINUED)****5.2 Filter Bags**


Each compartment will contain one cylindrical bag bundle, with 544 filter bags installed plus an additional 33 (1%) bags supplied as spares. The filter bags for this project will be fabricated from heavy weight 18 oz/yd<sup>2</sup> nominal weight PPS.

The bags have an elongated cross section, which is essentially oblong with rounded ends to promote better movement and release of the dust. The bag/cage fixing method has been designed for ease of installation and maintenance. The bags are secured in the tube sheet by means of a stainless steel snap band that is sewn into the cuff of the bag. No tools are necessary for installation of the bags and/or cages.

**5.3 Filter Bag Support Arrangement**

The filter bag support cages correspond in cross section to the "oblong" shape of the bags and tube sheet openings. The outside dimensions of the cage are slightly smaller than the inside dimensions of the bag along with a tapered lower section to facilitate cage insertion into the bag and help promote more efficient bag cleaning.

Cages are constructed of heavy 9 gauge mild steel wires for rigidity, durability and long life. There are 10 vertical wires, secured by horizontal wires spaced at a minimum of 8" intervals. Cages are supplied in two (2) sections to reduce the need for inordinately high headroom in the roof weather enclosure or clean air plenum, thus reducing steel and weight. The cage sections are firmly held together by an interlocking clip arrangement and internal guide plates at the joint to achieve a smooth, rigid, and perfectly aligned connection. This cage design has been successfully used on similar pulse jet boiler applications. In addition to those cages required for the initial installation, an additional 33 cages (1%) are included as spares.





## HAMON RESEARCH-COTTRELL, INC

### 5.0 EQUIPMENT DESCRIPTION (CONTINUED)

#### 5.4 Casing

The fabric filter casing will include the following design features and components:

- 3/16" A-36 steel
- Walk in plenum design for ease in bag inspections/replacements.
- Tube sheet of welded 1/4" A-36 steel, suitably reinforced
- Two (2) 24" x 60" mild steel access doors/compartment

#### 5.5 Hoppers

Each fabric filter compartment will have a pyramidal hopper equipped with the following auxiliaries:

- Reinforced to support 3,500 lbs. of ash handling equipment.
- Flanged outlet opening, 12", 150 lb. shipped loose.
- One 24" mild steel access door with safety latch to prevent rapid full door opening.
- One (1) 4" diameter angled poke holes located near the hopper outlet.
- Two (2) 6" square strike plates.
- One (1) capacitance type hopper level detector, as manufactured by Drexel Brook or equal. An annunciation alarm will be provided to the control system.
- One (1) Eriez 55-P or equal vibrators. One NEMA 12 relay panel will be provided to accept signals from the ash handling system. Sequencing by others.



## HAMON RESEARCH-COTTRELL, INC

### 5.0 EQUIPMENT DESCRIPTION (CONTINUED)

#### 5.5 Hoppers (Continued)

- Hopper heater system will include the following:
  - ✓ Modular type heaters, as manufactured by HotFoil, Heat Trace, Thermon or equal. The heaters will be distributed on the bottom 1/3 of the hopper height.
  - ✓ Throat heaters and poke hole heaters will be provided.
  - ✓ NEMA 4 control panel will be provided in the hopper area for hopper heater control. The panel will contain feed circuit breakers, individual heater contactors, readout of hopper skin temperature and high/low temperature alarm.

#### 5.6 Tube Sheet

The tube sheet for each compartment, complete with all stiffeners, will be shop fabricated from 1/4" thick plate to minimize deflection and insure that the highest standards of quality are maintained. Experience has shown that 3/16" thick tube sheets are not sufficient to prevent excessive deflection.

#### 5.7 Dampers

The following dampers will be provided:

- One (1) pneumatically operated, low leak inlet louver damper per compartment with two limit switches for indication of damper open/closed position.
- One (1) pneumatically operated, low leak single disc outlet poppet damper per compartment, complete with two limit switches for indication of damper open/closed position.
- Four (4) pneumatically operated, double disc bypass poppet dampers per fabric filter, complete with two limit switches for indication of damper open/closed position.



## HAMON RESEARCH-COTTRELL, INC

### 5.0 EQUIPMENT DESCRIPTION (CONTINUED)

#### 5.8 Support Steel

Support steel will be provided and installed for the fabric filter, as required. The fabric filter support structure will provide a clearance of approximately 6'-0" from the bottom of the hopper outlet flange to grade.

#### 5.9 Slide Plates

Flat slide plates, as manufactured by Amscot or equal, will be provided between the fabric filter and support steel to accommodate thermal movement.

#### 5.10 Access Doors

Mild steel access doors, 24" x 60", will be provided as follows:

- For entry into the walk in plenum

#### 5.11 Access

Hamon Research-Cottrell will furnish the following access system:

- One walkway, 36" wide from common SDA/FF stairway to one end of the fabric filter.
- As a second means of egress, two caged ladders will be provided from grade to the fabric filter roof on the opposite end of the fabric filter.
- A platform will be provided for the full length of each fabric filter to allow access to the inlet damper actuators.
- A walkway will be provided above outlet manifold to the walk in plenum doors.

#### 5.13 Instrumentation and Control

The baghouse will be controlled via the Owner's DCS system. HRC will provide a PLC and the instrumentation to allow the DCS to control the following

- Cleaning air blowers, spare blower will automatically start and alarm to the DCS if the primary blower fails
- Gear box drives for cleaning air manifold
- Inlet damper open/closed status
- Outlet poppet damper open/closed status
- Bypass poppet damper open/closed status
- Compartment ventilation system poppet damper open/closed status
- Cleaning air pressure control
- Baghouse on-line pulse-cleaning sequence
- Monitoring baghouse inlet and outlet temperature, overall differential pressure, blower and manifold drive motor starter status, manifold drive speed switch, and cleaning air pressure



## HAMON RESEARCH-COTTRELL, INC

### 5.0 EQUIPMENT DESCRIPTION (CONTINUED)

- Fabric filter inlet and outlet temperature.
- Fabric filter inlet and outlet pressure.

#### 5.14 Paint

All surfaces which are exposed to flue gas or covered by insulation will not be painted.

The following surfaces will be cleaned per SSPC-SP6 and given one (1) shop coat of an inorganic zinc primer:

- access framing
- Ladders and cages
- Handrails
- monorail beam
- support steel

The following surfaces will be galvanized:

- grating and stair treads

The following manufactured components will be supplied with manufactures standard paint system:

- dampers & actuators
- PLC
- hoist
- instrumentation
- cleaning blowers

#### 5.15 Model Study

A three dimensional model to 1:12 scale will be constructed of the AQC system. The scope will be from the spray dryer inlet to he fabric filter outlet.

The model study will identify pressure drop in the ductwork and AQS system and will be used to minimize dust drop out and to determine turning vane location in the ductwork. It will also be used to determine the optimal design of the internal flow control devices to provide good flow distribution to the bags, minimize pressure loss and undesirable dust buildups and to ensure that the baghouse hoppers have low velocity flow behavior to prevent dust re-entrainment. The model results will be displayed in a wide range of tabular and graphical formats including percent deviation maps, contour maps and histograms.





## HAMON RESEARCH-COTTRELL, INC

### V TECHNICAL SERVICES

#### 2.5.1 Erection Advisory Services

Erection advisory services will be made available on-site on a regular 8-hour day, 5-day workweek to advise on the recommended installation and erection procedures for the overall DFGD/Baghouse system. These services will be supplied on a per diem basis with the rates in effect at the time the service is provided.

#### 2.5.1 System Start-up Service

Services of a startup engineer will be provided to start up and adjust the Hamon Research-Cottrell supplied equipment, witness performance tests and to instruct the operating personnel in the operation and maintenance of the equipment. This service can include:

- Visual inspection of erected system for general conformance with erection procedures and instruction.
- I&C checkout relative to proper operation and control of applicable components.
- Atomizer assembly direction.
- Basic startup inspection by lime and byproduct recycle preparation system suppliers.

These services will be supplied on a per diem basis with the rates in effect at the time the service is provided.

#### 2.5.2 Operator Training Program

A formal training program will be conducted at the site to instruct the plant operators and maintenance personnel in the proper operation and maintenance procedures for the Hamon Research-Cottrell DFGD/Baghouse Systems and auxiliary equipment supplied. This service is included in price quoted.



## HAMON RESEARCH-COTTRELL, INC

### VI TERMINATION POINTS

HRC will furnish equipment, materials, and services as described in the "Equipment Description" sections of this proposal. HRC's scope of supply terminates as follows:

- Spray dryer inlet flange connection as indicated on drawing number P-9030-001-002-B (Expansion joints by others).
- Fabric filter outlet duct connection as shown on drawing number P-9030-001-002-B (ID fan inlet. Expansion joints by others)
- Miscellaneous mechanical and electrical equipment - (i.e., control panel, structural steel base plate) - at the manufacturer's or MET's standard mounting base provisions.
- Access facilities at grade.
- Electrical connections at each component.
- Support steel at grade.
- Water - One main tie-in point for water near the lime slurry preparation plant.
- Hopper outlet flanges of fabric filter compartments.
- Delumper outlet flange on each SDA hopper outlet.
- Flange on top of recycle storage silo.
- Fill connection on lime storage silo.



## HAMON RESEARCH-COTTRELL, INC

### **VII ITEMS TO BE FURNISHED AND INSTALLED BY OTHERS**

Hamon Research-Cottrell's scope of supply for materials and services is as described in this proposal. Equipment, materials, and services which are not included but are to be provided by others include the following. This list is not inclusive.

- Connecting ductwork except as noted above.
- Ductwork expansion joints as noted in the proposal.
- ID fans
- Stack.
- Permanent internal and external lighting.
- Byproduct removal, conveying and waste disposal storage system.
- Foundations and anchor bolts.
- Erection of all HRC supplied equipment and materials including erection labor, supervision, tools and required field construction equipment.
- Site demolition of existing equipment
- Field run power and I&C wiring, conduit, etc.
- Thermal insulation and lagging system.
- SDA & baghouse penthouse enclosure siding and roofing.
- Field finish painting.
- Start-up labor.
- Electrical power source.
- Electrical power distribution equipment and motor control centers
- Continuous emissions monitoring system.
- Site utilities including: water, power, lime, compressed air, and instrument air.
- Electrical/control equipment building.
- General plant control system(s).
- Other miscellaneous equipment or services required to complete the work.
- Licenses and permits.
- Precoat of filter bags prior to start up



## HAMON RESEARCH-COTTRELL, INC

### VIII BUDGETARY PRICING

Material Unit 1 & 2 (F.O.B. jobsite, freight prepaid) .....\$ 10,750,000

#### Optional Pricing

Installation/Erection Unit 1 & 2 .....\$ 6,400,000

#### NOTES:

- The prices shown do not include any sales, use or gross receipts taxes. If these taxes become applicable, they are to be in addition to the above prices and to the account of Purchaser who shall indemnify Hamon Research-Cottrell for any taxes and additionally incurred costs due to Purchaser's failure to satisfy his tax obligations.
- Prices are budgetary.
- Installation/Erection budget price includes mechanical erection, control field wiring, field insulation, roof and hopper enclosure siding installation.



## Wheelabrator Air Pollution Control Inc.

202 Canton Road, Suite 204  
Cumming, GA 30040  
USA

Phone 678.513.4555  
Fax 678.513.4777  
E-mail [jjones@wapc.com](mailto:jjones@wapc.com)

Jonathan P. Jones  
Southern Regional Sales Manager

July 19, 2002

Golder Associates, Inc.

Attention: Ms. Fawn Howard  
Staff Engineer

Subject: District Energy of St. Paul, Minnesota  
WAPC Budget Proposal No. 02-5240-JJV

Dear Ms. Howard:

Thank you for considering Wheelabrator Air Pollution Control for your upcoming gas-scrubbing project.

Based on the data provided in your May 24, 2002 email, we offer the following budget and planning information. If available in the future, additional flue gas characterization data would be helpful to improve the accuracy of this estimate.

A two-fluid nozzle spray dryer absorber is utilized to atomize a lime slurry into the flue gas from your process. The slurry absorbs SO<sub>2</sub> and other acid gases from the flue gas while the heat of the flue gas evaporates the slurry water. The evaporation of the water cools the flue gas. The cooled flue gas is ducted to a pulse jet fabric filter where the dried reaction products and post-combustion particulate are collected. Some solid materials are also discharged from the spray dryer absorber.

Two (2) spray dryer absorbers (SDA) and two (2) fabric filter (FF) are proposed for the project. A slurry preparation system is provided including a storage silo mixing tank and pumps.

Attachment A summarizes the process parameters for the proposed equipment. Attachment B is a summary of the equipment and services to be offered.

WAPC estimate to design and supply a SDA/FF System:	\$7,920,000
WAPC estimate for optional installation of above:	\$5,800,000

The above price is provided for budget purposes only and is subject to the terms and conditions

Golder Associates, Inc.

July 19, 2002

Page 2

contained herein.

We trust that this information will assist you with your evaluation. Please contact me at the number above if you have any questions. We look forward to hearing from you.

Sincerely,

Jon Jones

*sw5240.doc/cem*

**ATTACHMENT A - PROCESS PARAMETERS**

1.	System Inlet Data (per boiler)		
1.1	Gas Flow Rate	326,000	ACFM
		213,000	SCFM
		960,000	lb/hr
1.2	Gas Temperature	340	°F
1.3	Mass Flow Rates		
	SO <sub>2</sub>	152	lb/hr
1.4	Concentration		
	CO <sub>2</sub>	17.8	vol % (estimated)
	O <sub>2</sub>	4.5	vol % (estimated)
	N <sub>2</sub>	71.4	vol % (estimated)
	H <sub>2</sub> O	6.2	vol % (estimated)
	Pollutant Concentrations		
	SO <sub>2</sub>	72	ppmv
2.	Expected Removal	90%	
2.1	Acid Gases	Outlet Residual	
	SO <sub>2</sub>	7	ppm @ 7% O <sub>2</sub>
2.2	Solid Particulate		lb/hr

---

ATTACHMENT B – DETAIL OF SUPPLY

---

1.0 Battery Limits

1.1 Flue Gas

Flue gas will enter the equipment at the spray dryer absorber inlet and be discharged at the fabric filter outlet flange. WAPC to provide expansion joints at the interface points.

1.2 Absorbent

Purchaser's self-unloading lime slurry truck will connect to WAPC's (dual) 4" storage silo tube connection.

1.3 Ash Disposal

Ash will be discharged from each of WAPC's spray dryer absorber live bin bottom discharges and from the fabric filter compartment hopper discharge flanges.

1.4 Structural Support and Foundations

WAPC to provide structural supports for supplied equipment. All equipment to be supported on Purchaser supplied foundations. Unless otherwise noted herein, WAPC's design assumes no loads will be transmitted to the WAPC supplied equipment from equipment supplied by Others.

1.5 Water

Purchaser will supply water and piping, both material and labor, at the following locations:

- city/process water for flushing at a flanged connection within slurry preparation silo
- dilution water process within slurry preparation silo
- potable water within slurry preparation silo
- potable water at base of spray dryer absorber

1.6 Instrument Air

Purchaser will supply instrument air (-30°F dew point) at a single point within 3 ft. of the lime slurry prep building at 80 PSIG.

1.7 Atomizing Air

WAPC will supply atomizing air the spray dryer absorber nozzle level.

1.8 Electrical

Purchaser to supply 480 V power to all WAPC-supplied panels and motor starters.



---

**ATTACHMENT B – DETAIL OF SUPPLY**

---

Purchaser to provide 110 V power to all panels.

**1.9 Thermal Insulation and Lagging**

All thermal insulation and lagging for fabric filter, spray dryer absorber, ductwork and piping (insulation and lagging), and installation labor is supplied by the Purchaser.

All insulated and non-insulated siding for the spray dryer/ absorber nozzle level enclosure and the absorbent preparation silo is supplied by Others.

**1.10 Piping**

All automatically actuated valves are provided by WAPC. All piping, manual valves, and fittings are provided by others.

**1.11 Wiring and Lighting**

All wiring and lighting installation labor and materials are provided by Others. Wiring materials include cable, conduit, tray, local disconnects, and enclosures.

**1.12 Instrumentation and Control**

WAPC will supply all local instrumentation for the equipment. The Purchaser will supply Continuous Emission Monitors (CEM's) to measure SO<sub>2</sub>, O<sub>2</sub>, and opacity at system inlet and outlet.

The equipment will be controlled from the WAPC supplied Microprocessor based control system.

---

**ATTACHMENT B – DETAIL OF SUPPLY**

---

**2.0 Spray Dryer Absorber**

Two (2) Wheelabrator Air Pollution Control Two-Fluid Nozzle Spray Dryer Absorber (SDA). SDA includes the following features:

**2.1 Atomization Equipment per SDA**

- Six (6) operating WAPC 5 x 6 mm two-fluid nozzles complete with shrouded lance assembly and hose connections
- one (1) spare nozzle and lance assembly
- atomizing air flow controllers and low flow switches
- liquid shutoff valves (solenoid activated)
- nozzle view ports
- nozzle silencers

**2.1.1 Additional Equipment**

final filter (plate type with motorized continuous cleaning)

**2.2 Accessories**

- nozzle level access doors (24" diameter)
- hopper access doors (24" diameter)
- hopper impactors (air operated)
- hopper hammer anvils and poke holes
- hopper heaters
- local instrumentation and control valves
- hopper level detector
- hopper discharge live bin bottom

**2.3 Supports and Access**

**A. Support Steel**

All equipment within the battery limits described above to be supported from WAPC designed and supplied support steel. Minimum hopper flange clearances will be 12' above grade.

**B. Doors**

- One (1) 24" dia. nozzle level inspection doors
- One (1) 20" x 54" hinged lower chamber inspection doors
- One (1) 24" dia. hinged hopper inspection doors
- One (1) 24" dia. outlet duct inspection doors

---

**ATTACHMENT B – DETAIL OF SUPPLY**

---

**C. Access Walkways and Platforms**

- 6' wide nozzle inspection platform, 360° around perimeter of vessel. (Platform constructed of 1/4" checkered floor plate with gutter at inside perimeter.)
- Lower chamber door access walkway.
- Hopper access platform.
- Hopper access platform.

**D. Stairs**

A common stair tower will be provided for access to both SDAs.

**E. Caged Ladders**

Caged ladders where required for emergency egress.

Caged ladders from following points:

- nozzle inspection platform to chamber access platform
- chamber access door to hopper platform
- hopper access platform to grade

**F. Enclosures**

Enclosures for the following areas:

- nozzle access platform (insulated)  
Enclosures to be constructed of structural steel framing with siding and roofing. Siding and roofing are supplied as part of the insulation and lagging subcontract.

Additional equipment provided includes:

- ventilation louvers
- ventilation fans
- man-door
- electric convection heaters
- eyewash station and safety shower

---

**ATTACHMENT B - DETAIL OF SUPPLY**

---

**3.0 Fabric Filter (Pulse Jet)**

Two (2) WAPC Jet III Pulse-Jet Fabric Filters complete as follows:

- Carbon steel construction- 10 ga housing, 3/16" - A-36 hoppers
- tubesheet for bag installation
- access at tubesheet/outlet damper level
- inlet/outlet plenums and dampers
- PPS felt bags
- cleaning system including pulse headers, pulse valves, manifolds, venturi, and timers
- local differential pressure gauges
- hopper level detectors
- hopper doors (24" diameter)
- housing doors (20" x 48" hinged)
- hopper heaters
- hopper impactors and poke tubes

**4.0 Absorbent Preparation Equipment**

One (1) Slurry Preparation and Delivery System designed to store and pump lime slurry slurry, complete with storage silo, storage tank, pumps, slakers and control panel. Silo and tank are preassembled in a 12 ft. dia. tube and shipped in two (2) major pieces; external equipment to the tube is shipped loose for field assembly. Pumps are shipped loose for field assembly (skid mounted and prepiped) for installation in a separate modular equipment building. Customer-supplied grit bin to be located outside enclosure. Purchaser will supply dilution water for the tank.

Equipment includes:

- paste type pug mill slaker
- lime slurry storage silo
- agitated slurry tank
- slurry pumps
- local instrumentation and control valves

Golder Associates, Inc.  
South Florida Cogeneration Client

WAPC Budget Proposal No.02-5240-JJV  
July 19, 2002

---

**ATTACHMENT B – DETAIL OF SUPPLY**

---

**5.0 Duct System**

**5.1 Ductwork**

Constructed of 3/16" ASTM A-36 steel plate properly stiffened for +/- 35" WG static pressure. Ductwork to connect from spray dryer absorber outlets to inlet plenum of fabric filters.

**5.2 Expansion Joints**

Fabric-type expansion joints where determined necessary by WAPC including:

- spray dryer absorber outlet
- fabric filter inlet

**6.0 Control System**

Microprocessor board programmable logic controller for overall control of system including:

- Redundant processors
- Ethernet communication card
- Touchscreen panelview operator interface
- I/O modules with 20% spares
- Programming software
- NEMA 12 enclosure

All continuous emission monitoring (SO<sub>2</sub>, opacity) will be provided by Others. WAPC will provide all local instrumentation for the equipment.

The following systems/components will be controlled from local panels:

- storage and slaking system (silo, tank)
- slurry pumps

---

**ATTACHMENT B – DETAIL OF SUPPLY**

---

**7.0 Erection Services (Option)**

**7.1 Structural Erection**

Structural erection of components supplied by WAPC including slurry preparation system spray dryer absorbers, fabric filters, ductwork, access walkways, and support steel.

**7.2 Mechanical Installation**

Installation of all mechanical items, including damper valves, mixing equipment and setting of all pumps, motors, and instrumentation.

**7.3 Thermal Insulation**

Thermal insulation and lagging of spray dryer absorbers, fabric filters and ductwork, including labor and materials. Insulated siding for all enclosures.

**7.4 Piping**

Labor and materials to install all slurry and water piping.

**7.5 Electrical Wiring, Lighting and Heat Tracing**

Labor and materials to install all electrical equipment and provide lighting within WAPC's Detail of Supply. Materials include cable, conduit, cable tray, lights, enclosures, lighting transformers and distribution panels.

Labor and materials to heat trace all external piping. Materials include electrical heat tracing, thermostats and local distribution panels.

TERMS AND CONDITIONS OF EQUIPMENT AND ERECTION SALES

---

1. ACCEPTANCE

These Terms and Conditions of Sales form part of each Proposal submitted by Wheelabrator Air Pollution Control (WAPC) for the sale of Equipment described herein (Equipment) and Erection Services to Buyer. ANY CONTRACT MADE BY AND BETWEEN THE PARTIES IS EXPRESSLY CONDITIONED ON BUYER'S ASSENT TO THESE TERMS AND CONDITIONS AND TO WAPC'S REVIEW AND APPROVAL OF BUYER'S CREDIT. Unless otherwise stated herein, Buyer has thirty (30) days from the date of the Proposal to notify WAPC in writing of Buyer's offer to enter into a contract on the basis of this Proposal. Upon notification by WAPC from its office in Pittsburgh, Pennsylvania that it has accepted such offer by Buyer, this Proposal shall become a contract between Buyer and WAPC.

2. WARRANTY

WAPC warrants for a period equal to the lesser of (i) twelve (12) months after completion of the Work or (ii) eighteen (18) months after delivery of the Equipment (the "Warranty Period") that the Equipment and Work described herein will be free from defects in material and workmanship, will be of the kind and quality herein designated or described, and will conform to the specifications herein set forth. If within the Warranty Period, WAPC receives written notice promptly after the discovery of any nonconformance to the above warranties, WAPC shall correct each such defect, at its option, either by repairing or replacing any defective part(s). The liability of WAPC to Buyer arising out of the foregoing, whether under warranty, tort, contract, negligence, strict liability or otherwise, shall not in any case exceed the cost of correcting defects in the Equipment or Work and upon the expiration of said warranty, all such liability shall terminate. Except as otherwise expressly set forth herein, THERE ARE NO OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING THE WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. Liability of WAPC under this warranty is conditioned upon the Equipment being handled, operated, and maintained in accordance with the written instructions provided or approved in writing by WAPC. The warranties specified above do not cover and WAPC makes no warranties which extend to damage due to deterioration or wear or failure occasioned by chemicals, abrasion, corrosion or erosion; Buyer's misapplication; abnormal conditions of temperature or dirt; or operation of the Equipment other than as instructed in writing. WAPC's sole responsibility, and Buyer's exclusive remedy hereunder, shall be limited to such repair or replacement as above provided.

3. TAXES

In addition to the price specified herein, Buyer shall pay any tax imposed by any governmental body on the sale, delivery, use or other handling of Equipment sold hereunder, the performance of the Work, or in connection with this Proposal or any transactions contemplated hereby.

4. FORCE MAJEURE

WAPC shall not be responsible for losses or damages to Buyer (or any third person) occasioned by delays in the performance or the nonperformance of any of WAPC's obligations or by loss of or damage to any of the Equipment specified in the Proposal when caused directly or indirectly by acts of God, acts of government or military authority, casualty, riot, acts of Buyer, strikes or other labor difficulties, shortages of labor, supplies, and transportation facilities or any other cause beyond WAPC's control. The schedule shall be adjusted in accordance with the impact of any such delay or postponement and the price shall be equitably adjusted to include all additional costs, including overheads, plus a reasonable profit thereon.

TERMS AND CONDITIONS OF EQUIPMENT AND ERECTION SALES

---

5. CANCELLATION

Buyer may cancel any contract resulting from this Proposal only upon written notice to WAPC and only upon such terms as will indemnify and reimburse WAPC for all loss or damage resulting therefrom, including, without limitation, WAPC's direct costs incurred, overhead, reasonable contract profits, costs, and expenses to which WAPC has become committed for fulfillment of the contract prior to cancellation, plus reasonable settlement expenses.

6. LAWS AND REGULATIONS

WAPC does not assume responsibility for compliance with federal, state, and local laws and regulations unless expressly set forth in WAPC's Proposal. All laws and regulations expressly referenced herein shall refer only to those editions or versions thereof in effect on the date of this Proposal. In the event of revisions or changes thereto subsequent to the date of this Proposal, WAPC assumes no responsibility or liability for compliance therewith. If Buyer desires a modification to the Equipment as a result of a revision or change in such laws or regulations, such modification shall be treated as a Change Order.

7. CHANGE ORDERS

The Buyer may make minor changes within the general scope of Work, to the plans or equipment specifications included in this Proposal by giving WAPC written notification thereof in a Change Order. WAPC shall submit to the Buyer in writing the changes required to the contract price and to the fabrication and erection schedule and other obligations resulting from such Change Order. WAPC shall have no obligation to proceed with such Change Order until WAPC and Buyer agree in writing to such changes in the contract provisions.

8. LIMITATION ON LIABILITY

Whether attributable to contract, tort, warranty, negligence, strict liability or otherwise, WAPC's responsibility for any claims, damages, losses or liabilities arising out of or related to its performance of this Proposal or the Equipment covered hereunder, including but not limited to any correction of Equipment defects under the Warranty or any applicable performance guarantees, shall not exceed the purchase price. IN NO EVENT SHALL WAPC BE LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL, CONSEQUENTIAL, OR PUNITIVE DAMAGES OF ANY CHARACTER, INCLUDING BUT NOT LIMITED TO, LOSS OF USE OF PRODUCTIVE FACILITIES OR EQUIPMENT, LOST PROFITS, GOVERNMENTAL FINES OR PENALTIES, PROPERTY DAMAGES, PERSONAL INJURIES OR LOST PRODUCTION, WHETHER SUFFERED BY BUYER OR ANY THIRD PARTY, IRRESPECTIVE OF WHETHER CLAIMS OR ACTIONS FOR SUCH DAMAGES ARE BASED UPON CONTRACT, TORT, WARRANTY, NEGLIGENCE, STRICT LIABILITY OR OTHERWISE.

9. PATENTS

WAPC assumes the expenses involved in the defense of suits brought in the U.S., (plus damages, profits and costs awarded against Buyer in such a suit,) on the charge that Equipment delivered hereunder and manufactured by WAPC and used in the manner for which it was sold constitutes in and of itself an infringement of a U.S. patent, in an amount not to exceed in the aggregate purchase price of the items or parts thereof found to directly infringe any such patent. If, as a result of any such suit, the use of the Equipment is enjoined, WAPC shall either procure for Buyer the right to use the Equipment or modify it so that it no longer infringes or replace it with non-infringing Equipment. WAPC's patent obligation is conditional upon Buyer notifying WAPC promptly in writing when such suit is brought or threatened and giving WAPC full authority, information and assistance for the defense of the suit



Golder Associates, Inc.  
South Florida Cogeneration Client

WAPC Budget Proposal No.02-5240-JJV  
July 19, 2002

TERMS AND CONDITIONS OF EQUIPMENT AND ERECTION SALES

and such patent obligation does not apply to any item, or part thereof, manufactured to Buyer's specifications, or to any product manufactured by use of WAPC Equipment and, as to such item or product, WAPC assumes no liability for patent infringement. Except as herein expressly set forth, WAPC does not assume any other obligation or liability in connection with patent infringement suits brought against Buyer or the user of the Equipment which may be delivered hereunder.

**10. PROPRIETARY MATERIAL**

All drawings, patterns, specifications and information included in this Proposal, and all information otherwise supplied by WAPC relating to the design, erection, operation, and maintenance of the Equipment is the proprietary and/or confidential material or information of WAPC. Buyer shall not disclose such material or information to others or allow others to use such material or information except as required for Buyer to obtain service for the Equipment.

**11. LICENSES AND PERMITS**

WAPC shall obtain required contractors' licenses. All other licenses and/or permits shall be supplied by Buyer.

**12. INSURANCE**

WAPC shall maintain the following insurance coverage during the erection schedule:

Workmen's Compensation as required by statute; and Employer's Liability with a limit of liability of \$100,000.

Comprehensive General Liability including Completed Operations with the following limits:

Bodily Injury \$1,000,000 Each Occurrence  
\$1,000,000 Aggregate

Property Damage \$1,000,000 Each Occurrence  
\$1,000,000 Aggregate

Automobile Liability on all owned, leased and hired automobiles with the following limits:

Bodily Injury \$ 500,000 Each Person  
\$1,000,000 Each Occurrence

Property Damage \$ 500,000 Each Occurrence

"All Risk" Builder's Risk Insurance on the entire Work including all equipment, material and supplies. This insurance shall include the interest of WAPC, the Buyer and all Subcontractors. WAPC's responsibility under this insurance shall cease and such coverage shall be cancelled upon WAPC's decision, in its sole discretion, that the Work is complete for the purpose of Builder's Risk Insurance Coverage. A Certificate of Insurance shall be furnished at the start of work.

**13. WAIVER OF SUBROGATION**

WAPC and Buyer shall waive their rights and their respective insurance carriers subrogation rights against each other with respect to property damage. In the event that the Buyer is not the Owner of the facilities where the Equipment is being erected, the Buyer agrees to include a provision in its contract with the Owner of such facilities requiring the Owner to supply WAPC with a written waiver of its rights of recovery and its insurance carrier's right of subrogation against WAPC as specified in this Article.

**Golder Associates, Inc.**  
**South Florida Cogeneration Client**

**WAPC Budget Proposal No.02-5240-JJV**  
**July 19, 2002**

**TERMS AND CONDITIONS OF EQUIPMENT AND ERECTION SALES**

---

---

**14. ASSIGNMENT/SUBCONTRACT**

WAPC may assign/subcontract all or any portion of the contract included in its Proposal.

**15. ERECTION LABOR**

All erection labor included in this Proposal is based on the labor working the first shift of the established working day, Monday through Friday (excluding holidays), and upon paying the local prevailing rates for the labor which is to be used for the erection of the proposed equipment.

**16. INTERPRETATION AND ENFORCEMENT**

Any contract resulting from this Proposal, shall be construed according to the laws of the Commonwealth of Pennsylvania without giving effect to the conflict of law provisions thereof and suit may be instituted for the enforcement thereof in any state or federal court situate in Pennsylvania.

**17. BUYER'S SERVICES**

**APPENDIX F**

**CO EMISSIONS DURING COLD STARTUP CONDITIONS**

<b>Okeelanta Cogeneration Facility</b>						
Summary of CO Emissions - Maximum 8-hour Average (lbs/MMBtu)						
<b>Boiler B</b>			<b>Boiler A</b>			
Date:	Time:	CO	Date:	Time:	CO	
12/27/1999	04:00	4.880	10/16/1999	04:00	1.027	
12/27/1999	05:00	5.800	10/16/1999	05:00	1.388	
12/27/1999	06:00	5.886	10/16/1999	06:00	1.835	
12/27/1999	07:00	5.934	10/16/1999	07:00	1.294	
12/27/1999	08:00	6.012	10/16/1999	08:00	0.520	
12/27/1999	09:00	4.090	10/16/1999	09:00	0.259	
12/27/1999	10:00	1.104	10/16/1999	10:00	1.120	
12/27/1999	11:00	0.538	10/16/1999	11:00	0.791	
Average		4.280	Average		1.029	
<b>Boiler A</b>			<b>Boiler C</b>			
Date:	Time:	CO	Date:	Time:	CO	
8/25/1999	09:00	3.265	11/10/1999	08:00	0.734	
8/25/1999	10:00	3.064	11/10/1999	09:00	0.817	
8/25/1999	11:00	2.938	11/10/1999	10:00	0.698	
8/25/1999	12:00	2.618	11/10/1999	11:00	0.596	
8/25/1999	13:00	2.758	11/10/1999	12:00	0.814	
8/25/1999	14:00	2.749	11/10/1999	13:00	0.781	
8/25/1999	15:00	2.480	11/10/1999	14:00	0.798	
8/25/1999	16:00	1.657	11/10/1999	15:00	0.837	
Average		2.691	Average		0.759	
<b>Boiler C</b>			<b>Boiler C</b>			
Date:	Time:	CO	Date:	Time:	CO	
9/20/1999	05:00	6.497	10/29/1999	12:00	0.859	
9/20/1999	06:00	6.327	10/29/1999	13:00	0.888	
9/20/1999	07:00	0.865	10/29/1999	14:00	0.884	
9/20/1999	08:00	0.207	10/29/1999	15:00	0.554	
9/20/1999	09:00	0.154	10/29/1999	16:00	0.494	
9/20/1999	10:00	0.329	10/29/1999	17:00	0.689	
9/20/1999	11:00	0.385	10/29/1999	18:00	0.822	
9/20/1999	12:00	0.307	10/29/1999	19:00	0.849	
Average		1.883	Average		0.754	

**APPENDIX G**

**CALPUFF MODEL DESCRIPTION AND METHODOLOGY**

## CALPUFF MODEL DESCRIPTION AND METHODOLOGY

### G.1 INTRODUCTION

As part of the new source review requirements under Prevention of Significant Deterioration (PSD) regulations, new sources are required to address air quality impacts at PSD Class I areas. As part of the PSD analysis report submitted to the Florida Department of Environmental Protection (FDEP), the air quality impacts due to the potential emissions of the proposed New Hope Power Partnership project are required to be addressed at the PSD Class I area of the Everglades National Park (ENP). The ENP is located approximately 92.3 km south of the facility site and is the nearest Class I area to the facility.

The evaluation of air quality impacts are not only concerned with determining compliance with PSD Class I increments, but also assessing a source's impact on Air Quality Related Values (AQRVs), such as regional haze. Further, compliance with PSD Class I increments can be evaluated by determining if the source's impacts are less than the proposed U.S. Environmental Protection Agency (EPA) Class I significant impact levels. The significant impact levels are threshold levels that are used to determine the type of air impact analyses needed for the facility. If the new source's impacts are predicted to be less than significant, then the source's impacts are assumed not to have a significant adverse affect on air quality and additional modeling with other sources is not required. However, if the source's impacts are predicted to be greater than the significant impact levels, additional modeling with other sources is required to demonstrate compliance with Class I increments.

Currently there are several air quality modeling approaches recommended by the Interagency Workgroup on Air Quality Models (IWAQM) to perform these analyses. The IWAQM consists of the EPA and the Federal Land Managers (FLM) of Class I areas who are responsible for ensuring that AQRVs are not adversely impacted by new and existing sources. These recommendations have been summarized in two documents:

- *Interagency Workgroup on Air Quality Models (IWAQM), Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts* (EPA, 1998), referred to as the IWAQM Phase 2 report.
- *Federal Land Managers' Air Quality Related Values Workgroup (FLAG), Phase I Report*, USFS, NPS, USFWS (12/00), referred to as the FLAG document.

For the Proposed Project, air quality analyses were performed that assess the facility's impacts in the PSD Class I area of the ENP using the refined modeling approach from the IWAQM Phase 2 report for:

- Significant impact analysis;
- SO<sub>2</sub> PSD Class I increment analysis;
- Regional haze analysis; and
- Sulfur (S) and nitrogen (N) deposit analysis.

The refined analysis approach was used instead of the screening analysis approach since the air quality impacts are based on generally more realistic assumptions, including more detailed meteorological data, and are estimated at locations at the Class I area.

## **G.2 GENERAL AIR MODELING APPROACH**

The general modeling approach was based on using the long-range transport model, California Puff model (CALPUFF, Version 5.5). At distances beyond 50 km, the ISCST3 model is considered to over-predict air quality impacts, because it is a steady-state model. At those distances, the CALPUFF model is recommended for use. Recently, the FLM have requested that air quality impacts, such as for regional haze, for a source located more than 50 km from a Class I area be predicted using the CALPUFF model. The FDEP has also recommended that the CALPUFF model be used to assess if the source has a significant impact at a Class I area located beyond 50 km from the source. As a result, a significant impact, regional haze, SO<sub>2</sub> PSD Class I increment, and S and N deposition analyses were performed using the CALPUFF model to assess the facility's impacts at the ENP.

The methods and assumptions used in the CALPUFF model were based on the latest recommendations for a refined analysis as presented in the IWAQM Phase 2 Summary Report and the FLAG documents.

A regional haze analysis was performed to determine the affect that the facility's emissions will have on background regional haze levels at the ENP. In the regional haze analysis, the change in visual range, as calculated by a deciview change, was estimated for the facility in accordance with the IWAQM recommendations. Based on those recommendations, the CALPUFF model is used to predict the maximum 24-hour average sulfate (SO<sub>4</sub>), nitrate (NO<sub>3</sub>), and fine particulate (PM<sub>10</sub>) concentrations as well as ammonium sulfate [(NH<sub>4</sub>)<sub>2</sub>SO<sub>4</sub>] and ammonium nitrate (NH<sub>4</sub>NO<sub>3</sub>) concentrations. The change in visibility due to a source, estimated as a percentage, is then calculated based on the change from background data.

The following sections present the methods and assumptions used to assess the refined significant impact and regional haze analyses performed for the proposed Project. The results of these analyses are presented in Sections 6.0 and 7.0 of the PSD report.

### **G.3 MODEL SELECTION AND SETTINGS**

The California Puff (CALPUFF, version 5.5) air modeling system was used to model and assess the proposed Project's impacts at the PSD Class I area for comparison to the PSD Class I significant impact levels and to the regional haze visibility criteria. CALPUFF is a non-steady state Lagrangian Gaussian puff long-range transport model that includes algorithms for building downwash effects as well as chemical transformations (important for visibility controlling pollutants), and wet/dry deposition. The CALPUFF meteorological and geophysical data preprocessor (CALMET, Version 5.2), a preprocessor to CALPUFF, is a diagnostic meteorological model that produces a three-dimensional field of wind and temperature and a two-dimensional field of other meteorological parameters. CALMET was designed to process raw meteorological, terrain, and land-use databases to be used in the air modeling analysis. The CALPUFF modeling system uses a number of FORTRAN preprocessor programs that extract data from large databases and converts the data into formats suitable for input to CALMET. The processed data produced from CALMET was input to CALPUFF to assess the pollutant specific impact. Both CALMET and CALPUFF were used in a manner that is recommended by the IWAQM Phase 2 and FLAG reports.

#### **G.3.1 CALPUFF MODEL APPROACHES AND SETTINGS**

The IWAQM has recommended approaches for performing Phase 2 refined modeling analyses that are presented in Table 1. These approaches involve the use of meteorological data, selection of receptors and dispersion conditions, and processing of model output.

The specific settings used in the CALPUFF model are presented in Table 2.

#### **G.3.2 EMISSION INVENTORY AND BUILDING WAKE EFFECTS**

The CALPUFF model included the facility's emission, stack, and operating data as well as building dimensions to account for the effects of building-induced downwash on the emission sources. Dimensions for all significant building structures were processed with the Building Profile Input Program (BPIP), Version 95086, and were included in the CALPUFF model input. The PSD Report presents a listing of the facility's emissions and structures included in the analysis.



#### **G.4 RECEPTOR LOCATIONS**

For the refined analyses, pollutant concentrations were predicted in an array of 126 discrete receptors located at the ENP area. These receptors are the same as those used in the PSD Class I analysis performed for the PSD Report.

#### **G.5 METEOROLOGICAL DATA**

##### **G.5.1 REFINED ANALYSIS**

CALMET was used to develop the gridded parameter fields required for the refined modeling analyses. The follow sections discuss the specific data used and processed in the CALMET model.

##### **G.5.2 CALMET SETTINGS**

The CALMET settings contained in Table 3 were used for the refined modeling analysis. With the exception of hourly precipitation data files, all input data files needed for CALMET were developed by the FDEP staff.

##### **G.5.3 MODELING DOMAIN**

A rectangular modeling domain extending 450 km in the east-west (x) direction and 470 km in the north-south (y) direction was used for the refined modeling analysis. The southwest corner of the domain is the origin and is located at 23.8 degrees north latitude and 83.5 degrees west longitude. This location is in the Gulf of Mexico approximately 110 km west of Venice, Florida. For the processing of meteorological and geophysical data, the domain contains 90 grid cells in the x-direction and 94 grid cells in the y-direction. The domain grid resolution is 5 km. The air modeling analysis was performed in the UTM coordinate system.

##### **G.5.4 MESOSCALE MODEL – GENERATION 4 (MM4) DATA**

Pennsylvania State University in conjunction with the NCAR Assessment Laboratory developed the MM4 data set, a prognostic wind field or “guess” field, for the United States. The hourly meteorological variables used to create this data set (wind, temperature, dew point depression, and geopotential height for eight standard levels and up to 15 significant levels) are extensive and only allow for one data base set for the year 1990. The analysis used the MM4 data to initialize the CALMET wind field. The MM4 data have a horizontal spacing of 80 km and are used to simulate atmospheric variables within the modeling domain.

The MM4 subset domain was provided by FDEP and consisted of a 7 x 7- cell rectangle, with 80 km grid resolution, extending from the MM4 grid points (50,6) to (57,13). These data were processed to create a MM4.DAT file, for input to the CALMET model.

The MM4 data set used in the CALMET, although advanced, lacks the fine detail of specific temporal and spatial meteorological variables and geophysical data. These variables were processed into the appropriate format and introduced into the CALMET model through the additional data files obtained from the following sources.

#### **G.5.5 SURFACE DATA STATIONS AND PROCESSING**

The surface station data processed for the CALPUFF analyses consisted of data from eight NWS stations or Federal Aviation Administration (FAA) Flight Service stations for Orlando, Fort Myers, Daytona Beach, Vero Beach, Key West, Miami, Tampa, and West Palm Beach. A summary of the surface station information and locations are presented in Table 4. The surface station parameters include wind speed, wind direction, cloud ceiling height, opaque cloud cover, dry bulb temperature, relative humidity, station pressure, and a precipitation code that is based on current weather conditions. The surface station data were processed by FDEP into a SURF.DAT file format for CALMET input.

Because the modeling domain extends largely over water, C-Man station data from Venice, Sombrero Key, and Lake Worth was obtained. These data were processed by Florida DEP into an over-water surface station format (i.e., SEA\*.DAT) for input to CALMET. The over-water station data include wind direction, wind speed and air temperature.

#### **G.5.6 UPPER AIR DATA STATIONS AND PROCESSING**

The analysis included three upper air NWS stations located in Ruskin, Key West, and West Palm Beach. Data for each station were obtained from the Florida DEP in a format for CALMET input.

The data and locations for the upper air stations are presented in Table 4.

#### **G.5.7 PRECIPITATION DATA STATIONS AND PROCESSING**

Precipitation data were processed from a network of hourly precipitation data files collected from primary and secondary NWS precipitation-recording stations located within the latitude and longitudinal limits of the modeling domain. Data for 23 stations were obtained in NCDC TD-3240 variable format and converted into a fixed-length format. The utility programs PEXTRACT and PMERGE were then used to

process the data into the format for the PRECIP.DAT file that is used by CALMET. A listing of the precipitation stations used for the modeling analysis is presented in Table 5.

#### **G.5.8 GEOPHYSICAL DATA PROCESSING**

The land-use and terrain information data were developed by the FDEP for the modeling domain and were provided in a GEO.DAT file format for input to CALMET. Terrain elevations for each grid cell of the modeling domain were obtained from Digital Elevation Model (DEM) files obtained from US Geographical Survey (USGS). The DEM data was extracted for the modeling domain grid using the utility extraction program LCELEV. Land-use data were obtained from the USGS GIS.DAT which is based on the ARM3 data. The resolution of the GIS.DAT file is one-eighth of a degree in the east-west direction and one-twelfth of a degree in the north-south direction. Land-use values for the domain grid were obtained with the utility program CAL-LAND. Other parameters processed for the modeling domain by CAL-LAND include surface roughness, surface Albedo, Bowen ratio, soil heat flux, and leaf index field. The land-use parameter values were based on annual averaged values.

Table 1. Refined Modeling Analyses Recommendations <sup>a</sup>

Model Input/Output	Description
Meteorology	Use CALMET (minimum 6 to 10 layers in the vertical; top layer must extend above the maximum mixing depth expected); horizontal domain extends 50 to 80 km beyond outer receptors and sources being modeled; terrain elevation and land-use data is resolved for the situation.
Receptors	Within Class I area(s) of concern; obtain regulatory concurrence on coverage.
Dispersion	<ol style="list-style-type: none"> <li>1. CALPUFF with default dispersion settings.</li> <li>2. Use MESOPUFF II chemistry with wet and dry deposition.</li> <li>3. Define background values for ozone and ammonia for area.</li> </ol>
Processing	<ol style="list-style-type: none"> <li>1. For PSD increments: use highest, second highest 3-hour and 24-hour average SO<sub>2</sub> concentrations; highest, second highest 24-hour average PM<sub>10</sub> concentrations; and highest annual average SO<sub>2</sub>, PM<sub>10</sub> and NO<sub>x</sub> concentrations.</li> <li>2. For haze: process, on a 24-hour basis, compute the source extinction from the maximum increase in emissions of SO<sub>2</sub>, NO<sub>x</sub> and PM<sub>10</sub>; compute the daily relative humidity factor [f(RH)], provided from an external disk file; and compute the maximum percent change in extinction using the FLM supplied background extinction data in the FLAG document.</li> <li>3. For significant impact analysis: use highest annual and highest short-term averaging time concentrations for SO<sub>2</sub>, PM<sub>10</sub>, and NO<sub>x</sub>.</li> </ol>

<sup>a</sup> IWAQM Phase II report (12/98) and FLAG document (12/00)

Table 2. CALPUFF Model Settings

Parameter	Setting
Pollutant Species	SO <sub>2</sub> , SO <sub>4</sub> , NO <sub>x</sub> , HNO <sub>3</sub> , and NO <sub>3</sub> , PM <sub>10</sub> , CO, Pb and F
Chemical Transformation	MESOPUFF II scheme, hourly ozone data
Deposition	Include both dry and wet deposition, plume depletion
Meteorological/Land Use Input	CALMET
Plume Rise	Transitional, Stack-tip downwash, Partial plume penetration
Dispersion	Puff plume element, PG /MP coefficients, rural mode, ISC building downwash scheme
Terrain Effects	Partial plume path adjustment
Output	Create binary concentration file including output species for SO <sub>4</sub> , NO <sub>3</sub> , PM <sub>10</sub> , SO <sub>2</sub> , NO <sub>x</sub> , F, Pb, and CO
Model Processing	For haze: highest predicted 24-hour extinction change (%) for the year
	For significant impact analysis: highest predicted annual and highest short-term averaging time concentrations for SO <sub>2</sub> , NO <sub>x</sub> , and PM <sub>10</sub>
Background Values <sup>a</sup>	Ozone: 80 ppb; Ammonia: 0.5 ppb

<sup>a</sup> Recommended values by the Florida DEP.

Table 3. CALMET Settings

Parameter	Setting
Horizontal Grid Dimensions	450 by 470 km, 5 km grid resolution
Vertical Grid	9 layers
Weather Station Data Inputs	8 surface, 3 upper air, 23 precipitation stations
Wind model options	Diagnostic wind model, no kinematic effects
Prognostic wind field model	MM4 data, 80 km resolution, 7 x 7 grid, used for wind field initialization
Output	Binary hourly gridded meteorological data file for CALPUFF input

Table 4. Surface and Upper Air Stations Used in the CALPUFF Analysis

Station Name	Station Symbol	WBAN Number	UTM Coordinates			Anemometer Height (m)
			Easting (km)	Northing (km)	Zone	
<u>Surface Stations</u>						
Tampa	TPA	12842	349.20	3094.25	17	6.7
Daytona Beach	DAB	12834	495.14	3228.05	17	9.1
Orlando	ORL	12815	468.96	3146.88	17	10.1
Vero Beach	VER	12843	557.52	3058.36	17	6.7
Fort Myers	FMY	12835	413.65	2940.38	17	6.1
Miami	MIA	12839	566.82	2857.20	17	7.0
Key West	EYW	12836	424.03	2715.14	17	18.3
West Palm Beach	PBI	12844	587.87	2951.43	17	10.1
<u>Upper Air Stations</u>						
Ruskin	TBW	12842	349.20	3094.28	17	NA
West Palm Beach	PBI	12844	587.87	2951.42	17	NA
Key West	EYW	12836	424.03	2715.14	17	NA

Table 5. Hourly Precipitation Stations Used in the CALPUFF Analysis

Station Name	Station Number	UTM Coordinate		Zone
		Easting (km)	Northing (km)	
Belle Glade HRCN GT 4	80616	528.19	2953.03	17
Boca Raton	80845	588.75	2916.52	17
Canal Point Gate 5	81271	536.43	2971.51	17
Clewiston US Engineers	81654	546.19	2912.73	17
Fort Myers FAA/AP	83186	413.99	2940.71	17
Homestead Exp Stn	84091	550.26	2820.21	17
Key West Intl AP	84570	423.67	2715.51	17
Miami WSCMO Airport	85663	570.20	2856.17	17
Moore Haven Lock 1	85895	491.61	2967.80	17
North New River Canal #	86323	546.58	2912.48	17
Ortona Lock 2	86657	470.17	2962.27	17
Parrish	86880	366.99	3054.39	17
Pennsuco 5 WNW	86988	554.70	2867.81	17
Port Mayaca S I Canal	87293	538.04	2984.44	17
St Lucie New Lock 1	87859	571.04	2999.35	17
St Petersburg	87886	339.61	3071.99	17
Tamiami Trail 40 Mi BEN	88780	517.64	2849.04	17
Tampa WSCMO AP	88788	348.48	3093.67	17
Trail Glade Ranges	89010	551.57	2849.99	17
Venice	89176	357.59	2998.18	17
Venus	89184	467.27	3001.22	17
Vero Beach 4 W	89219	554.27	3056.50	17
West Palm Beach Int AP	89525	589.61	2951.63	17



**APPENDIX H**

**SO<sub>2</sub> AAQS, PSD CLASS I AND II INVENTORY**

Table H-1. Summary of SO<sub>2</sub> Sources Included in the Air Modeling Analysis, New Hope Power Partnership

AIRS Number	Facility	Units	Modeling ID Name	Relative Location		Stack and Operating Parameters				Emission Rate(g/s)		PSD Source? (EXP/CON)	Modeled in				
				X (m)	Y (m)	Height (m)	Diameter (m)	Temper. (K)	Velocity (m/s)	.3-Hour	24-Hour		AAQS	Class II	Class I		
0990005	Okeelanta Corp <sup>a</sup>	Boiler 4 PSD Baseline	OKBLR4B	-201	58	22.9	2.29	333.0	7.36	-10.95	-10.95	EXP	No	Yes	Yes		
		Boiler 5 PSD Baseline	OKBLR5B	-201	37	22.9	2.29	333.0	12.07	-15.64	-15.64	EXP	No	Yes	Yes		
		Boiler 6 PSD Baseline	OKBLR6B	-201	23	22.9	2.29	334.0	8.74	-15.64	-15.64	EXP	No	Yes	Yes		
		Boiler 10 PSD Baseline	OKBLR10B	-201	9	22.9	2.29	334.0	10.35	-17.15	-17.15	EXP	No	Yes	Yes		
		Boiler 11 PSD Baseline	OKBLR11B	-201	67	22.9	2.29	342.0	9.89	-16.79	-16.79	EXP	No	Yes	Yes		
		Boiler 16 PSD	OKBLR16	-223	18	22.9	1.52	483.0	22.86	1.47	1.47	CON	Yes	Yes	Yes		
0990086	Glades Correctional Institute		GLADCORR	525,000	2,937,400	9.8	0.40	389.0	11.28	2.82	2.82	NO	Yes	No	No		
0990026	Sugar Cane Growers <sup>a</sup>	Unit 1&2	SUGCN12	533,500	2,954,100	45.7	1.87	339.0	21.75	41.20	41.20	CON	Yes	Yes	Yes		
		Unit 3	SUGCN3	533,500	2,954,100	27.4	1.52	339.0	22.25	16.20	16.20	CON	Yes	Yes	Yes		
		Unit 4 PSD	SUGCN4	533,500	2,954,100	54.9	2.44	339.0	21.73	38.20	38.20	CON	Yes	Yes	Yes		
		Unit 5	SUGCN5	533,500	2,954,100	45.7	2.30	339.0	15.94	27.90	27.90	CON	Yes	Yes	Yes		
		Unit 8 PSD	SUGCN8	533,500	2,954,100	47.2	2.90	339.0	13.62	23.50	23.50	CON	Yes	Yes	Yes		
		Unit 1&2 PSD Baseline	SUGCN12B	533,500	2,954,100	24.4	1.40	344.0	11.40	-24.20	-24.20	EXP	No	Yes	Yes		
		Unit 3 PSD Baseline	SUGCN3B	533,500	2,954,100	24.4	1.60	344.0	15.60	-4.40	-4.40	EXP	No	Yes	Yes		
		Unit 4 PSD Baseline	SUGCN4B	533,500	2,954,100	25.9	1.63	344.0	11.20	-24.20	-24.20	EXP	No	Yes	Yes		
		Unit 5 PSD Baseline	SUGCN5B	533,500	2,954,100	24.4	1.40	344.0	15.20	-16.20	-16.20	EXP	No	Yes	Yes		
		Unit 6&7 PSD Baseline	SUGCN67B	533,500	2,954,100	12.2	1.52	606.0	11.20	-51.00	-51.00	EXP	No	Yes	Yes		
0510001	Everglades Sugar <sup>b</sup> Main Boiler		EVERGLAD	562,000	2,960,000	21.9	1.10	477.0	10.10	34.90	34.90	NO	Yes	No	No		
0510003	US Sugar - Clewiston <sup>d</sup>	<u>PSD Baseline (On-crop season only)</u>															
		Unit 1 PSD Baseline	USSBRL1B	545,600	2,991,500	23.1	1.86	344.0	30.20	-79.86	-58.21	EXP	No	Yes	Yes		
		Unit 2 PSD Baseline	USSBLR2B	545,600	2,991,500	23.1	1.86	343.0	35.70	-79.86	-58.21	EXP	No	Yes	Yes		
		Unit 3 PSD Baseline	USSBLR3B	545,600	2,991,500	27.4	2.29	342.0	14.70	-48.30	-33.20	EXP	No	Yes	Yes		
		East Pellet Plant PSD Baseline	EPELLET	545,600	2,991,500	12.2	1.52	347.0	8.54	-10.30	-10.30	EXP	No	Yes	Yes		
		West Pellet Plant PSD Baseline	WPELLET	545,600	2,991,500	15.7	1.52	347.0	8.54	-10.30	-10.30	EXP	No	Yes	Yes		
		<u>On-crop season future</u>															
		Unit 1	USSBRL1N	545,600	2,991,500	65.0	2.44	347.0	15.36	78.79	73.73	CON	Yes	Yes	Yes		
		Unit 2	USSBLR2N	545,600	2,991,500	65.0	2.44	338.0	13.86	78.49	73.44	CON	Yes	Yes	Yes		
		Unit 3	USSBLR3N	545,600	2,991,500	65.0	2.44	333.2	6.78	47.08	47.08	CON	Yes	Yes	Yes		
Unit 4	USSBLR4N	545,600	2,991,500	45.7	2.51	344.3	20.28	21.53	3.68	CON	Yes	Yes	Yes				
Unit 7	USSBLR7N	545,600	2,991,500	68.6	2.59	405.4	20.77	13.91	12.65	CON	Yes	Yes	Yes				

Table H-1. Summary of SO<sub>2</sub> Sources Included in the Air Modeling Analysis, New Hope Power Partnership

AIRS Number	Facility	Units	Modeling ID Name	Relative Location		Stack and Operating Parameters				Emission Rate(g/s)		PSD Source? (EXP/CON)	Modeled in		
				X (m)	Y (m)	Height (m)	Diameter (m)	Temper. (K)	Velocity (m/s)	3-Hour	24-Hour		AAQS	Class II	Class I
		<u>Off-crop season future</u>													
		Unit 1	USSBRL1F	545,600	2,991,500	65.0	2.44	347.0	14.05	51.64	24.29	CON	Yes	Yes	Yes
		Unit 2	USSBLR2F	545,600	2,991,500	65.0	2.44	338.0	12.68	51.27	24.02	CON	Yes	Yes	Yes
		Unit 3	USSBLR3F	545,600	2,991,500	65.0	2.44	333.2	6.20	30.74	30.20	CON	Yes	Yes	Yes
		Unit 4	USSBLR4F	545,600	2,991,500	45.7	2.51	344.3	0.00	0.00	0.00	CON	Yes	Yes	Yes
		Unit 7	USSBLR7F	545,600	2,991,500	68.6	2.59	405.4	23.60	17.39	15.81	CON	Yes	Yes	Yes
0990016	Atlantic Sugar *														
		Unit 1	ATLSUG1	552,900	2,945,200	27.4	1.83	346.0	17.97	16.28	16.28	CON	Yes	Yes	Yes
		Unit 2	ATLSUG2	552,900	2,945,200	27.4	1.83	350.0	23.36	16.28	16.28	CON	Yes	Yes	Yes
		Unit 3	ATLSUG3	552,900	2,945,200	27.4	1.83	350.0	21.56	16.02	16.02	CON	Yes	Yes	Yes
		Unit 4	ATLSUG4	552,900	2,945,200	27.4	1.83	344.0	25.16	16.21	16.21	CON	Yes	Yes	Yes
		Unit 5 PSD <sup>b</sup>	ATLSUG5	552,900	2,945,200	27.4	1.68	339.0	19.24	8.41	8.04	CON	Yes	Yes	Yes
		Unit 1 PSD Baseline	ATLSUG1B	552,900	2,945,200	18.9	1.92	506.0	12.71	-17.24	-17.24	EXP	No	Yes	Yes
		Unit 2 PSD Baseline	ATLSUG2B	552,900	2,945,200	18.9	1.92	511.0	10.89	-22.52	-22.52	EXP	No	Yes	Yes
		Unit 3 PSD Baseline	ATLSUG3B	552,900	2,945,200	21.9	1.83	522.0	17.52	-16.88	-16.88	EXP	No	Yes	Yes
		Unit 4 PSD Baseline	ATLSUG4B	552,900	2,945,200	18.3	1.83	344.0	15.03	-16.88	-16.88	EXP	No	Yes	Yes
0990061	US Sugar-Bryant *														
		Unit 5 PSD	USSBRY5	523,400	2,955,200	45.7	2.90	334.3	14.80	62.40	62.40	CON	No	Yes	Yes
		Unit 5 AAQS	USSBRY5	523,400	2,955,200	45.7	2.90	334.3	14.80	77.25	77.25	CON	No	Yes	No
		Unit 1,2&3 PSD	USBRY123	523,400	2,955,200	19.8	1.64	344.3	34.60	160.68	160.68	CON	No	Yes	Yes
		Unit 1,2&3 AAQS	USBRY123	523,400	2,955,200	19.8	1.64	344.3	34.60	199.71	199.71	CON	No	Yes	No
		Unit 1 PSD Baseline	USSBRY1B	523,400	2,955,200	19.8	1.68	494.0	44.30	-36.50	-36.50	EXP	No	Yes	Yes
		Unit 2&3 PSD Baseline	USBRY23B	523,400	2,955,200	19.8	1.68	344.0	37.90	-73.00	-73.00	EXP	No	Yes	Yes
0990019	Osceola Farms PSD Baseline *														
		Unit 2	OSBLR2	544,200	2,968,000	27.4	1.52	341.0	15.82	12.58	11.43	CON	Yes	Yes	Yes
		Unit 3	OSBLR3	544,200	2,968,000	27.4	1.91	342.0	16.86	9.82	2.00	CON	Yes	Yes	Yes
		Unit 4	OSBLR4	544,200	2,968,000	27.4	1.83	340.0	16.67	9.73	1.92	CON	Yes	Yes	Yes
		Unit 5	OSBLR5	544,200	2,968,000	27.4	1.52	341.0	15.50	12.96	11.79	CON	Yes	Yes	Yes
		Unit 6	OSBLR6	544,200	2,968,000	27.4	1.88	341.0	18.19	2.87	2.59	CON	Yes	Yes	Yes
		Unit 1 PSD Baseline	OSBLR1B	544,200	2,968,000	22.0	1.52	342.0	8.98	-5.07	-5.07	EXP	No	Yes	Yes
		Unit 2 PSD Baseline	OSBLR2B	544,200	2,968,000	22.0	1.52	342.0	14.22	-16.32	-16.32	EXP	No	Yes	Yes
		Unit 3 PSD Baseline	OSBLR3B	544,200	2,968,000	22.0	1.93	342.0	11.23	-7.26	-7.26	EXP	No	Yes	Yes
		Unit 4 PSD Baseline	OSBLR4B	544,200	2,968,000	22.0	1.83	342.0	13.35	-13.61	-13.61	EXP	No	Yes	Yes
0850102	Bechtel Indiantown PSD		BECHTIND	506,100	2,956,900	150.9	4.88	333.2	30.50	75.64	75.64	CON	Yes	Yes	Yes

Table H-1. Summary of SO<sub>2</sub> Sources Included in the Air Modeling Analysis, New Hope Power Partnership

AIRS Number	Facility	Units	Modeling ID Name	Relative Location		Stack and Operating Parameters				Emission Rate(g/s)		PSD Source? (EXP/CON)	Modeled in		
				X (m)	Y (m)	Height (m)	Diameter (m)	Temper. (K)	Velocity (m/s)	3-Hour	24-Hour		AAQS	Class II	Class I
0850001	FPL Martin	Units 1&2	MART12	537,800	2,969,160	152.1	7.99	420.9	21.03	1743.79	1743.79	NO	Yes	No	No
		Aux Blr PSD	MARTAU	537,800	2,969,160	18.3	1.10	535.4	15.24	12.90	12.90	CON	Yes	Yes	Yes
		Diesel Gens PSD	MARTGEN	537,800	2,969,160	7.6	0.30	785.9	39.62	0.51	0.51	CON	Yes	Yes	Yes
		Units 3&4 PSD	MART34	537,800	2,969,160	64.9	6.10	410.9	18.90	470.40	470.40	CON	Yes	Yes	Yes
		Unit 8	MART8	537,800	2,969,160	36.6	5.79	397.6	13.59	12.99	12.99	CON	Yes	Yes	Yes
0990234	Palm Beach Co Resource Recovery <sup>c</sup>	1&2 PSD	PBCRRF	543,100	2,992,900	76.2	2.04	505.2	24.90	85.05	85.05	CON	Yes	Yes	Yes
0990568	Lake Worth Utilities <sup>c</sup>	Unit 3	LAKWTHU3	583,300	2,908,000	38.1	2.13	408.2	7.71	103.95	103.95	NO	Yes	No	No
		Unit 4	LAKWTHU4	583,300	2,908,000	35.1	2.29	418.2	17.00	129.85	129.85	NO	Yes	No	No
		Unit 5	LAKWTHU5	583,300	2,908,000	22.9	0.94	450.4	18.29	11.59	11.59	NO	Yes	No	No
		HRSG	LAKWTHHR	583,300	2,908,000	45.7	5.49	377.6	13.74	12.79	12.79	CON	Yes	Yes	Yes
0990042	FPL Riviera <sup>c</sup>	Units 3&4 at 2.5% fuel oil	RIVU34	555,860	2,882,200	90.8	4.88	401.5	18.90	2113.65	2113.65	NO	Yes	No	No
0112119	South Broward RRF PSD <sup>c</sup>		SBCRRF	575,200	3,006,800	59.4	3.96	381.0	18.01	37.91	37.91	CON	Yes	Yes	Yes
0110037	FPL - Lauderdale <sup>c</sup>	CTs 1-4 PSD	LAUDU45	562,900	2,861,700	45.7	5.49	438.7	14.60	271.15	271.15	CON	Yes	Yes	Yes
		GT 1-12 (0.5% fuel oil)	LDGT1_12	562,900	2,861,700	13.7	2.37	733.2	114.31	552.80	552.80	NO	Yes	No	No
		GT 13-24 (0.5% fuel oil)	LDGT1324	562,900	2,861,700	13.4	4.75	733.2	28.43	552.80	552.80	NO	Yes	No	No
		4&5 PSD Baseline	FTLAU45B	562,900	2,861,700	46.0	4.27	422.0	14.63	-457.00	-457.00	EXP	No	Yes	Yes
0110036	FPL Port Everglades <sup>c</sup>	Units 1&2 at 2.5% fuel oil	PTEVU12	564,300	2,857,400	104.5	4.27	415.9	26.72	1593.90	1593.90	NO	Yes	No	No
		Units 3&4 at 2.5% fuel oil	PTEVU34	564,300	2,857,400	104.5	5.52	414.8	23.88	2772.00	2772.00	NO	Yes	No	No
		GT 1-12 (0.5% fuel oil)	PTEVGTS	564,300	2,857,400	13.4	4.75	733.2	28.43	530.70	530.70	NO	Yes	No	No
0250020	Tarmac <sup>c</sup>	Kiln 1 PSD Baseline	TARMC1	422,100	2,952,900	61.0	2.44	465.0	12.84	-5.71	-5.71	EXP	No	Yes	Yes
		Kiln 2 PSD Baseline	TARMC2B	422,100	2,952,900	61.0	2.44	465.0	12.84	-5.71	-5.71	EXP	No	Yes	Yes
		Kiln 3 PSD Baseline	TARMC3B	422,100	2,952,900	61.0	4.57	472.0	10.78	-2.76	-2.76	EXP	No	Yes	Yes
		Kiln 2 PSD	TABMC2P	422,100	2,952,900	61.0	2.44	422.0	9.10	24.57	24.57	CON	Yes	Yes	Yes
		Kiln 3 PSD	TARMC3P	422,100	2,952,900	61.0	4.57	450.0	11.04	51.43	51.43	CON	Yes	Yes	Yes

Table H-1. Summary of SO<sub>2</sub> Sources Included in the Air Modeling Analysis, New Hope Power Partnership

AIRS Number	Facility	Units	Modeling ID Name	Relative Location		Stack and Operating Parameters				Emission Rate(g/s)		PSD Source? (EXP/CON)	Modeled in		
				X (m)	Y (m)	Height (m)	Diameter (m)	Temper. (K)	Velocity (m/s)	3-Hour	24-Hour		AAQS	Class II	Class I
0710000	FPL Fort Myers <sup>c</sup>	Unit 1 PSD	FMU1	567,100	3,056,500	91.8	2.90	422.0	29.90	-585.50	-585.50	EXP	No	Yes	Yes
		Unit 2 PSD	FMU2	567,100	3,056,500	121.2	5.52	408.0	19.20	-1334	-1334.0	EXP	No	Yes	Yes
		HRSGs 1 - 6	FMYHR1_6	567,100	3,056,500	38.1	5.79	377.6	14.2	3.86	3.9	CON	Yes	Yes	Yes
		Gas Turbines 1 -12	FMYGT112	567,100	3,056,500	9.75	4.42	797.0	35.7	649.2	649.2	NO	Yes	No	No
1110003	Fort Pierce Utilities <sup>c</sup>	Units 6&7	FTPIER67	594,200	2,960,600	45.7	2.19	408.2	12.50	77.87	77.87	NO	Yes	No	No
0550018	TECO-Phillips <sup>c</sup>	Steam Boiler	TECOSB	424,200	2,945,700	18.90	0.67	ND	ND	0.7	0.7	NO	No	No	No
		Diesel Generator Unit 1	TECO1	424,200	2,945,700	45.72	1.83	441.0	24.1	58.0	29.0	NO	Yes	No	No
		Diesel Generator Unit 2	TECO2	424,200	2,945,700	45.72	1.83	450.0	24.1	58.0	29.0	NO	Yes	No	No
0550004	TECO-Sebring/Dinner Lake <sup>c</sup>	Steam Boiler	DINNSB	464,300	3,035,400	22.9	1.83	394.3	5.79	37.78	37.78	CON	Yes	Yes	No
0610029	Vero Beach Power <sup>c</sup>	Unit 1	VERBU1	587,400	2,885,300	60.96	1.07	437.0	32.42	28.77	28.77	NO	Yes	No	No
		Unit 2	VERBU2	587,400	2,885,300	60.96	1.07	434.3	37.57	84.21	84.21	NO	Yes	No	No
		Unit 3	VERBU3	587,400	2,885,300	60.96	1.83	440.4	19.93	142.07	142.07	NO	Yes	No	No
		Unit 4	VERBU4	587,400	2,885,300	60.96	2.13	425.4	24.36	69.05	69.05	NO	Yes	No	No
		Unit 5 Simple Cycle CT	VERBU5	587,400	2,885,300	38.10	3.35	416.5	19.56	15.50	15.50	CON	Yes	Yes	No
0250348	Dade County RRF PSD	Units 1&2	DCRRF12	566,800	3,036,300	76.2	3.66	405.4	15.86	26.41	12.32	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Units 3&4	DCRRF34	566,800	3,036,300	76.2	3.66	405.4	15.86	26.41	12.32	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
0112515	Enron Pompano Beach Energy Center	3-170 MW CTs	ENPMPCT	580,100	2,883,300	24.4	5.49	847.0	47.06	39.16	39.16	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
0110120	North Broward RRF PSD		NBCRRF	579,600	2,883,300	58.5	3.96	381.0	18.01	35.40	35.40	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
0112534	Enron Deerfield Beach Energy Center	3-170 MW CTs	ENDFCT	592,800	2,943,700	24.4	5.49	847.0	47.06	39.16	39.16	CON	No <sup>e</sup>	No <sup>e</sup>	Yes

Table H-1. Summary of SO<sub>2</sub> Sources Included in the Air Modeling Analysis, New Hope Power Partnership

AIRS Number	Facility	Units	Modeling ID Name	Relative Location		Stack and Operating Parameters				Emission Rate(g/s)		PSD Source? (EXP/CON)	Modeled in		
				X (m)	Y (m)	Height (m)	Diameter (m)	Temper. (K)	Velocity (m/s)	3-Hour	24-Hour		AAQS	Class II	Class I
0112545	El Paso Broward	Combined Cycle CT CC-1	EPBRCT1	583,700	2,905,500	41.1	5.79	359.3	61.13	0.46	0.46	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Simple Cycle SC-1	EPBRSC1	583,700	2,905,500	41.1	5.79	862.0	146.96	0.46	0.46	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Simple Cycle SC-2	EPBRSC2	583,700	2,905,500	41.1	5.79	862.0	146.96	0.46	0.46	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Simple Cycle SC-3	EPBRSC3	583,700	2,905,500	41.1	5.79	862.0	146.96	0.46	0.46	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
0710019	Lee County RRF PSD		LEECORRF	456,800	3,042,500	83.8	1.88	388.5	19.81	14.00	14.00	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
0990568	Lake Worth Generating	4-GE Frame 7FA CTs & HRSG	LWGENCT	583,600	2,907,600	45.7	5.49	377.6	24.29	51.16	51.16	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
0990594	El Paso Belle Glade	Combined Cycle CT CC-1	EPBGLCT	534,900	2,953,300	41.1	5.79	359.3	61.13	0.46	0.46	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Simple Cycle SC-1	EPBGSC1	534,900	2,953,300	41.1	5.79	862.0	146.96	0.46	0.46	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Simple Cycle SC-2	EPBGSC2	534,900	2,953,300	41.1	5.79	862.0	146.96	0.46	0.46	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Simple Cycle SC-3	EPBGSC3	534,900	2,953,300	41.1	5.79	862.0	146.96	0.46	0.46	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
	Palm Beach Power Corp.	Cogen Boiler 1	PBPCBLR1	544,400	2,967,400	60.7	2.44	419.3	24.87	28.73	19.15	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Cogen Boiler 2	PBPCBLR2	544,400	2,967,400	60.7	2.44	419.3	24.87	28.73	19.15	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Package Boiler	PACKBLR	544,400	2,967,400	22.9	1.52	483.2	22.86	1.47	1.47	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
0510015	Southern Gardens Citrus - PSD	Peel Dryer	SGARDDRY	488	2,958	38.1	1.73	316.0	7.45	5.29	5.29	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Boilers 1-3	SGARDBLR	488	2,958	16.8	1.22	478.0	14.22	6.88	6.88	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
990021	Pratt & Whitney (United Technologies)	Heater	PRATARCH	509,600	2,954,200	15.2	0.91	810.9	143.73	13.99	13.99	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		Boiler BO-12	PRATBO12	509,600	2,954,200	4.6	0.76	533.2	6.92	0.51	0.51	CON	No <sup>e</sup>	No <sup>e</sup>	Yes
		A-10 Test Stand	PRATA10	509,600	2,954,200	5.8	4.17	410.9	106.68	0.55	0.55	No	Yes	No	No

Note: EXP = PSD expanding source  
CON = PSD consuming source  
NO = Source does not affect PSD increment  
ND = No data available

<sup>a</sup> Facilities or sources within facilities that operate only during the October 1 through April 31 crop season.

<sup>b</sup> Sugar mill sources that operate all year.

<sup>c</sup> Large source with emissions greater than 1,000 TPY included in the AAQS or PSD Class II modeling even though the source is located outside of the screening area.

<sup>d</sup> Represents worst case emissions for May 1 through September 31 off-crop season operation, and October 1-April 30 for on-crop season.

Updated from PSD modeling information, Golder Associates (7/18/00). Baseline data represents November 1 through April 30.

<sup>e</sup> Not included in AAQS or Class II modeling analyses because they screened out.