




# Department of Environmental Protection



Lawton Chiles  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

April 16, 1997

**CERTIFIED MAIL - RETURN RECEIPT REQUESTED**

Mr. Dennis V. Space, General Manager  
Okeelanta Power Limited Partnership  
Post Office Box 8  
South Bay, Florida 33493

Re: FINAL Permit Modification No. 0990332-004-AC  
PSD-FL-196D

Dear Mr. Space:

The Department has reviewed Okeelanta Power's December 5, 1996 and March 25, 1997 letters requesting that the sulfuric acid mist emission standard and EPA Method 8 testing requirement be removed from the construction permit for your new cogeneration boilers located near South Bay in Palm Beach County.

In response to this request, the Department is retaining the sulfuric acid mist emission standard and adopting the modified Method 8 test procedure as described in the memorandum of December 19, 1995 from Jim Wright of Clean Air Engineering to Michelle Griffin. The permit is hereby amended as follows:

Specific Condition No. 20.b.

From:

EPA Method \*

8

For Determination of

Sulfuric Acid Mist

To:

EPA Method \*

8 (modified) \*\*

For Determination of

Sulfuric Acid Mist

---

\*\* As described in Clean Air Engineering memo dated December 19, 1995, Wright to Griffin