

RECEIVED

MAY 03 1997

BUREAU OF
AIR REGULATION

**OKEELANTA POWER
LIMITED PARTNERSHIP**

**APPLICATION FOR AIR PERMIT
APRIL 1997**

Prepared For:

**Okeelanta Power Limited Partnership
Six Miles South of South Bay
South Bay, Florida 33493**

Prepared By:

**Golder Associates Inc.
6241 NW 23rd Street, Suite 500
Gainesville, Florida 32653-1500**

9737509Y/F3

**OKEELANTA POWER
LIMITED PARTNERSHIP**

**APPLICATION FOR AIR PERMIT
APRIL 1997**

Prepared For:

**Okeelanta Power Limited Partnership
Six Miles South of South Bay
South Bay, Florida 33493**

Prepared By:

**Golder Associates Inc.
6241 NW 23rd Street, Suite 500
Gainesville, Florida 32653-1500**

9737509Y/F3

TABLE OF CONTENTS

PART A

APPLICATION FOR AIR PERMIT

PART B

1.0	INTRODUCTION	1-1
2.0	PROJECT DESCRIPTION	2-1
2.1	<u>GENERAL</u>	2-1
2.2	<u>COGENERATION FACILITY DESIGN INFORMATION</u>	2-2
2.2.1	FUELS	2-2
2.2.3	FACILITY PLOT PLAN	2-4
2.2.4	CONTROL EQUIPMENT INFORMATION	2-4
2.2.5	STACK PARAMETERS	2-5
2.3	<u>REVISIONS TO PERMITTED BOILER EMISSION LIMITS</u>	2-5
2.3.1	LIMITS FOR CRITERIA/DESIGNATED POLLUTANTS	2-5
2.7	<u>COMPLIANCE DEMONSTRATION</u>	2-9
3.0	AIR QUALITY REVIEW REQUIREMENTS AND SOURCE APPLICABILITY	3-1
4.0	AIR TOXICS MODELING ANALYSIS	4-1
4.1	<u>INTRODUCTION</u>	4-1
4.2	<u>METHODOLOGY</u>	4-1
4.3	<u>MODELING RESULTS</u>	4-3

Department of Environmental Protection

DIVISION OF AIR RESOURCES MANAGEMENT

APPLICATION FOR AIR PERMIT - LONG FORM

See Instructions for Form No. 62-210.900(1)

I. APPLICATION INFORMATION

This section of the Application for Air Permit form identifies the facility and provides general information on the scope and purpose of this application. This section also includes information on the owner or authorized representative of the facility (or the responsible official in the case of a Title V source) and the necessary statements for the applicant and professional engineer, where required, to sign and date for formal submittal of the Application for Air Permit to the Department. If the application form is submitted to the Department using ELSA, this section of the Application for Air Permit must also be submitted in hard-copy.

Identification of Facility Addressed in This Application

Enter the name of the corporation, business, governmental entity, or individual that has ownership or control of the facility; the facility site name, if any; and the facility's physical location. If known, also enter the facility identification number.

1. Facility Owner/Company Name: Okeelanta Power Limited Partnership	
2. Site Name: Okeelanta Power L.P.	
3. Facility Identification Number: 0990332 [] Unknown	
4. Facility Location Information: Street Address or Other Locator: Six Miles South of South Bay City: South Bay County: Palm Beach Zip Code: 33493	
5. Relocatable Facility? [] Yes [X] No	6. Existing Permitted Facility? [X] Yes [] No

Application Processing Information (DEP Use)

1. Date of Receipt of Application:	
2. Permit Number:	
3. PSD Number (if applicable):	
4. Siting Number (if applicable):	

Owner/Authorized Representative or Responsible Official

*James T. Carlton,
Authorized Representative*

1. Name and Title of Owner/Authorized Representative or Responsible Official: Ricardo A. Lima, Vice-President/General Manager
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: Okeelanta Power Limited Partnership Street Address: P.O. Box 8 City: South Bay State: FL Zip Code: 33493
3. Owner/Authorized Representative or Responsible Official Telephone Numbers: Telephone: (561) 993-1000 Fax: (561) 996-6596
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative* of the non-Title V source addressed in this Application for Air Permit or the responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i> Signature: <u><i>R. A. Lima</i></u> Date: <u><i>4-28-97</i></u>

* Attach letter of authorization if not currently on file.

Scope of Application

This Application for Air Permit addresses the following emissions unit(s) at the facility. An Emissions Unit Information Section (a Section III of the form) must be included for each emissions unit listed.

Emissions Unit ID **Description of Emissions Unit** **Permit Type**

Unit #	Unit ID	Description of Emissions Unit	Permit Type
1R	001	Boiler A fired by Biomass/No.2 oil/coal/TDF	AC1F
2R	002	Boiler B fired by Biomass/No.2 oil/coal/TDF	AC1F
3R	003	Boiler C fired by Biomass/No.2 oil/coal/TDF	AC1F

See individual Emissions Unit (EU) sections for more detailed descriptions.
Multiple EU IDs indicated with an asterisk (*). Regulated EU indicated with an "R".

Purpose of Application and Category

Check one (except as otherwise indicated):

Category I: All Air Operation Permit Applications Subject to Processing Under Chapter 62-213, F.A.C.

This Application for Air Permit is submitted to obtain:

-] Initial air operation permit under Chapter 62-213, F.A.C., for an existing facility which is classified as a Title V source.

-] Initial air operation permit under Chapter 62-213, F.A.C., for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number: _____

-] Air operation permit renewal under Chapter 62-213, F.A.C., for a Title V source.

Operation permit to be renewed: _____

-] Air operation permit revision for a Title V source to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number: _____

Operation permit to be renewed: _____

-] Air operation permit revision or administrative correction for a Title V source to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. Also check Category III.

Operation permit to be revised/corrected: _____

-] Air operation permit revision for a Title V source for reasons other than construction or modification of an emissions unit. Give reason for the revision e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.

Operation permit to be revised: _____

Reason for revision: _____

Category II: All Air Construction Permit Applications Subject to Processing Under Rule 62-210.300(2)(b), F.A.C.

This Application for Air Permit is submitted to obtain:

- Initial air operation permit under Rule 62-210.300(2)(b), F.A.C., for an existing facility seeking classification as a synthetic non-Title V source.

Current operation/construction permit number(s): _____

- Renewal air operation permit under Rule 62-210.300(2)(b), F.A.C., for a synthetic non-Title V source.

Operation permit to be renewed: _____

- Air operation permit revision for a synthetic non-Title V source. Give reason for revision; e.g., to address one or more newly constructed or modified emissions units.

Operation permit to be revised: _____

Reason for revision: _____

Category III: All Air Construction Permit Applications for All Facilities and Emissions Units.

This Application for Air Permit is submitted to obtain:

- Air construction permit to construct or modify one or more emissions units within a facility (including any facility classified as a Title V source).

Current operation permit number(s), if any: _____
AC50-219413; PSD-FL-196

- Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.

Current operation permit number(s): _____

- Air construction permit for one or more existing, but unpermitted, emissions units.

Application Processing Fee

Check one:

Attached - Amount: \$ \$ 250.00

Not Applicable.

Construction/Modification Information

1. Description of Proposed Project or Alterations: This application proposes revisions to the current construction permit for the 74.9 MW Biomass fired cogeneration facility. This application requests revised permit limits for SO2, Pb, and Hg when burning wood waste. In addition, the averaging time associated with the CO emissions limit is being changed to a 24-hour average. These revisions are based on actual stack test data and fuel quality of biomass fuel.
2. Projected or Actual Date of Commencement of Construction : 1 Jun 1997
3. Projected Date of Completion of Construction : 31 Dec 1998

Professional Engineer Certification

1. Professional Engineer Name: David A. Buff Registration Number: 19011
2. Professional Engineer Mailing Address: Organization/Firm: Golder Associates Inc. Street Address: 6241 NW 23rd Street, Suite 500 City: Gainesville State: FL Zip Code: 32653-1500
3. Professional Engineer Telephone Numbers: Telephone: (352) 336-5600 Fax: (352) 336-6603

4. Professional Engineer's Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [] if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [X] if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [] if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.



David A. Buff

4/23/97

Date

* Attach any exception to certification statement.

Application Contact

1. Name and Title of Application Contact: James Meriwether, Environmental Manager
2. Application Contact Mailing Address: Organization/Firm: Okeelanta Power Limited Partnership Street Address: P.O. Box 8 City: South Bay State: FL Zip Code: 33493
3. Application Contact Telephone Numbers: Telephone: (561) 993-1003 Fax: (561) 996-6596

Application Comment

Organization/Firm Official Mailing Address: P.O. Box 8; 6 Miles South of South Bay, Highway 27

II. FACILITY INFORMATION

A. GENERAL FACILITY INFORMATION

Facility Location and Type

1. Facility UTM Coordinates: Zone: 17 East (km): 524.9 North (km): 2940.1			
2. Facility Latitude/Longitude: Latitude (DD/MM/SS): 26 / 35 / 0 Longitude: (DD/MM/SS): 80 / 45 / 0			
3. Governmental Facility Code: 0	4. Facility Status Code: A	5. Facility Major Group SIC Code: 49	6. Facility SIC(s): 4911
7. Facility Comment (limit to 500 characters): Facility Street Address: Six Miles South of South Bay on Highway 27. Facility consists of 74.9 MW electricity generating Cogen firing biomass, oil, coal or tire-derived fuel.			

Facility Contact

1. Name and Title of Facility Contact: James M. Meriwether, Environmental Manager
2. Facility Contact Mailing Address: Organization/Firm: Okeelanta Power Limited Partnership Street Address: P.O. Box 8 City: South Bay State: FL Zip Code: 33493
3. Facility Contact Telephone Numbers: Telephone: (561) 993-1003 Fax: (561) 996-6596

B. FACILITY REGULATIONS

Rule Applicability Analysis (Required for Category II applications and Category III applications involving non Title-V sources. See Instructions.)

Not Applicable

List of Applicable Regulations (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

62-210.300
62-212.300

C. FACILITY POLLUTANTS

Facility Pollutant Information

1. Pollutant Emitted	2. Pollutant Classification
PM Particulate Matter - Total	A
PM10 Particulate Matter - PM10	A
SO2 Sulfur Dioxide	A
NOx Nitrogen Oxides	A
CO Carbon Monoxide	A
VOC Volatile Organic Compounds	A
PB Lead - Total	B
H114 Mercury Compounds	B
H021 Beryllium Compounds	B
FL Fluorides - Total	B
SAM Sulfuric Acid Mist	B
HAPS Total Hazardous Air Pollutants	A
T006 Ammonia (anhydrous)	A
H106 Hydrochloric acid	A
H107 Hydrogen fluoride [Hydrofluoric aci	A

D. FACILITY POLLUTANT DETAIL INFORMATION

Facility Pollutant Detail Information:

1. Pollutant Emitted:		
2. Requested Emissions Cap:	(lb/hr)	(tons/yr)
3. Basis for Emissions Cap Code:		
4. Facility Pollutant Comment (limit to 400 characters):		

Facility Pollutant Detail Information:

1. Pollutant Emitted:		
2. Requested Emissions Cap:	(lb/hr)	(tons/yr)
3. Basis for Emissions Cap Code:		
4. Facility Pollutant Comment (limit to 400 characters):		

E. FACILITY SUPPLEMENTAL INFORMATION

Supplemental Requirements for All Applications

1. Area Map Showing Facility Location: <input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Facility Plot Plan: <input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Process Flow Diagram(s): <input checked="" type="checkbox"/> Attached, Document ID(s): <u>PART B</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Precautions to Prevent Emissions of Unconfined Particulate Matter: <input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
5. Fugitive Emissions Identification: <input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
6. Supplemental Information for Construction Permit Application: <input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u> <input type="checkbox"/> Not Applicable

Additional Supplemental Requirements for Category I Applications Only

7. List of Proposed Exempt Activities: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
8. List of Equipment/Activities Regulated under Title VI: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Equipment/Activities On site but Not Required to be Individually Listed <input checked="" type="checkbox"/> Not Applicable
9. Alternative Methods of Operation: <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
10. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

<p>11. Identification of Additional Applicable Requirements:</p> <p><input type="checkbox"/> Attached, Document ID: _____</p> <p><input checked="" type="checkbox"/> Not Applicable</p>
<p>12. Compliance Assurance Monitoring Plan:</p> <p><input type="checkbox"/> Attached, Document ID: _____</p> <p><input checked="" type="checkbox"/> Not Applicable</p>
<p>13. Risk Management Plan Verification:</p> <p><input type="checkbox"/> Plan Submitted to Implementing Agency - Verification Attached Document ID: _____</p> <p><input type="checkbox"/> Plan to be Submitted to Implementing Agency by Required Date</p> <p><input checked="" type="checkbox"/> Not Applicable</p>
<p>14. Compliance Report and Plan</p> <p><input type="checkbox"/> Attached, Document ID: _____</p> <p><input checked="" type="checkbox"/> Not Applicable</p>
<p>15. Compliance Statement (Hard-copy Required)</p> <p><input type="checkbox"/> Attached, Document ID: _____</p> <p><input checked="" type="checkbox"/> Not Applicable</p>

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through L as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application. Some of the subsections comprising the Emissions Unit Information Section of the form are intended for regulated emissions units only. Others are intended for both regulated and unregulated emissions units. Each subsection is appropriately marked.

**A. TYPE OF EMISSIONS UNIT
(Regulated and Unregulated Emissions Units)****Type of Emissions Unit Addressed in This Section**

1. Regulated or Unregulated Emissions Unit? Check one:

The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.

The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

2. Single Process, Group of Processes, or Fugitive Only? Check one:

This Emissions Unit information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).

This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.

This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

**B. GENERAL EMISSIONS UNIT INFORMATION
(Regulated and Unregulated Emissions Units)**

Emissions Unit Description and Status

1. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Boiler A fired by Biomass/No.2 oil/coal/TDF		
2. Emissions Unit Identification Number: [] No Corresponding ID [] Unknown 001		
3. Emissions Unit Status Code: A	4. Acid Rain Unit? [] Yes [x] No	5. Emissions Unit Major Group SIC Code: 49
6. Emissions Unit Comment (limit to 500 characters): 74.9 MW gross generating capacity for entire facility.		

Emissions Unit Control Equipment Information

A.

1. Description (limit to 200 characters): ESP - Electrostatic Precipitator
2. Control Device or Method Code: 10

B.

1. Description (limit to 200 characters): Selective Non-Catalytic reduction for NOx
2. Control Device or Method Code: 107

C.

1. Description (limit to 200 characters): Activated Carbon injection system.
2. Control Device or Method Code: 48

**C. EMISSIONS UNIT DETAIL INFORMATION
(Regulated Emissions Units Only)**

Emissions Unit Details

1. Initial Startup Date:		
2. Long-term Reserve Shutdown Date:		
3. Package Unit: Manufacturer:	Model Number:	
4. Generator Nameplate Rating:	75 MW	
5. Incinerator Information:		
	Dwell Temperature:	°F
	Dwell Time:	seconds
	Incinerator Afterburner Temperature:	°F

Emissions Unit Operating Capacity


1. Maximum Heat Input Rate:	715	mmBtu/hr
2. Maximum Incineration Rate:	lbs/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Operating Capacity Comment (limit to 200 characters):		
Maximum heat input rates: Biomass - 715 MMBtu/hr; No.2 Fuel Oil - 490 MMBtu/hr; Coal - 490 MMBtu/hr; Tire-derived fuel - 340 MMBtu/hr		

Emissions Unit Operating Schedule

1. Requested Maximum Operating Schedule:		
	24 hours/day	7 days/week
	52 weeks/yr	8,760 hours/yr

**D. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)**

Rule Applicability Analysis (Required for Category II Applications and Category III applications involving non Title-V sources. See Instructions.)



List of Applicable Regulations (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

40 CFR 60, Subpart Da
40 CFR 60, Subpart Ea and Cb (record keeping only)
62-296.570 Reasonably Avail. Control Technology

**E. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)**

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram: BLR A	
2. Emission Point Type Code: <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4	
3. Descriptions of Emissions Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):	
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:	
5. Discharge Type Code: <input type="checkbox"/> D <input type="checkbox"/> F <input type="checkbox"/> H <input type="checkbox"/> P <input type="checkbox"/> R <input checked="" type="checkbox"/> V <input type="checkbox"/> W	
6. Stack Height:	225 feet
7. Exit Diameter:	10 feet
8. Exit Temperature:	330 °F

9. Actual Volumetric Flow Rate:	270,000 acfm	
10. Percent Water Vapor:	%	
11. Maximum Dry Standard Flow Rate:	dscfm	
12. Nonstack Emission Point Height:	feet	
13. Emission Point UTM Coordinates:		
Zone:	East (km):	North (km):
14. Emission Point Comment (limit to 200 characters):	Stack parameters based on biomass firing.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility boiler - bagasse	
2. Source Classification Code (SCC): 1-01-011-01	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 84.118	5. Maximum Annual Rate: 736,874
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.05	8. Maximum Percent Ash:
9. Million Btu per SCC Unit:	
10. Segment Comment (limit to 200 characters): Maximum percent Sulfur: 0.05. Maximum Percent Ash: 0.42. Million Btu per SCC Unit: 8.5. Total biomass all three boilers = 1,352,941 TPY.	

Segment Description and Rate: Segment 2 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Wood Fired Boiler	
2. Source Classification Code (SCC): 1-01-009-03	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 65	5. Maximum Annual Rate: 569,400
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.11	8. Maximum Percent Ash: 3.2
9. Million Btu per SCC Unit: 11	
10. Segment Comment (limit to 200 characters): Maximum Percent Sulfur: 0.11. Total biomass all three boilers = 1,352,941 TPY.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 3 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Distillate Oil - Grades 1 and 2 oil	
2. Source Classification Code (SCC): 1-01-005-01	
3. SCC Units: Thousand Gallons Burned	
4. Maximum Hourly Rate: 3.551	5. Maximum Annual Rate: 7,745
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.05	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 138	
10. Segment Comment (limit to 200 characters): Maximum Annual Rate: 7,745,000. This represents 24.9% oil firing on a heat input basis. Total No.2 Fuel Oil all three boilers = 19,533,086 gal/yr.	

Segment Description and Rate: Segment 4 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility boiler - Butiminous Coal - Spreader Stoker	
2. Source Classification Code (SCC): 1-01-002-04	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 20.417	5. Maximum Annual Rate: 61,172
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.7	8. Maximum Percent Ash: 3.7
9. Million Btu per SCC Unit: 24	
10. Segment Comment (limit to 200 characters): Total coal all three boilers = 69,720 TPY (15.1% coal burning on a heat input basis). The combined heat input for coal and oil <25% on a calendar quarter basis.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 5 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Solid Waste - Tire Derived Fuel	
2. Source Classification Code (SCC): 1-01-012-01	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 11	5. Maximum Annual Rate: 81,246
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 1.2	8. Maximum Percent Ash: 5
9. Million Btu per SCC Unit: 31	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on 340 MMBtu/hr TDF. Total TDF all three boilers = 81,246 TPY. This represents 9.0% TDF burning on a weight basis.	

Segment Description and Rate: Segment _____ of _____

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters):	
2. Source Classification Code (SCC):	
3. SCC Units:	
4. Maximum Hourly Rate:	5. Maximum Annual Rate:
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit:	
10. Segment Comment (limit to 200 characters):	

**G. EMISSIONS UNIT POLLUTANTS
(Regulated and Unregulated Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM	010		EL
PM10	010		EL
SO2			EL
NOx	107		EL
CO			EL
VOC			EL
PB	010		EL
SAM			EL
FL			EL
H114	048		EL
H021			EL
HAPS			NS
H106			NS
H107			NS

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)

Pollutant Detail Information:

1. Pollutant Emitted: PM	
2. Total Percent Efficiency of Control:	99 %
3. Potential Emissions:	21.5 lb/hour 94.17 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor: 0.03 lb/MMBtu Reference: 40 CFR 60 Subpart Da	
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 0.03 lb/MMBtu x 715 MMBtu/hr = 21.5 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 172.5 TPY total for all boilers	

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

Particulate Matter - Total

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	21.5 lb/hour	94.17 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 5.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Maximum lb/hr based on biomass firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: PM10		
2. Total Percent Efficiency of Control:		99 %
3. Potential Emissions:	21.5 lb/hour	94.17 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.03 lb/MMBtu
Reference: 40 CFR 60 Subpart Da		
7. Emissions Method Code:		
<input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters):		
0.03 lb/MMBtu x 715 MMBtu/hr = 21.5 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
172.5 TPY total for all boilers		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	21.5 lb/hour	94.17 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack testing using EPA Method 5.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Maximum lb/hr based on biomass firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**Pollutant Detail Information:**

1. Pollutant Emitted: SO2		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	588 lb/hour	1,067.5 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
[] 1 [] 2 [] 3 _____ to _____ tons/yr		
6. Emission Factor:		1.2 lb/MMBtu
Reference: 40 CFR 60 Subpart Da		
7. Emissions Method Code:		
[] 0 [] 1 [] 2 [] 3 [] 4 <input checked="" type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters):		
1.2 lb/MMBtu x 490 MMBtu/hr = 588.0 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
1,154.3 TPY total for all three boilers.		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.1 lb/MMBtu <i>SO₂</i>		
4. Equivalent Allowable Emissions:	71.5 lb/hour	100.2 tons/year
5. Method of Compliance (limit to 60 characters): Continuous SO₂ monitor		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions: 0.1 lb/MMBtu 24-hr avg; Annual- 0.02 lb/MMBtu for bagasse, 0.05 lb/MMBtu for wood. Based on biomass firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 1.2 lb/MMBtu <i>CSW</i>		
4. Equivalent Allowable Emissions:	408 lb/hour	1,008 tons/year
5. Method of Compliance (limit to 60 characters): Continuous SO₂ monitor.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions: 1.2 lb/MMBtu, 24-hr avg.; 0.8 lb/MMBtu, annual avg. Based on tire-derived fuel firing. Annual TPY: 81,246 TPY TDF x 15,500-Btu/lb.x.0.8.lb/MMBtu = 1,007.6 TPY		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 12 lb/MMBtu		
4. Equivalent Allowable Emissions:	588 lb/hour	880.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Based on coal firing.		

B.

1. Basis for Allowable Emissions Code: RULE		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.05 lb/MMBtu <i>SDR</i>		
4. Equivalent Allowable Emissions:	22.5 lb/hour	36.7 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No. 1 2 fuel oil firing and BACT.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)****Pollutant Detail Information:**

1. Pollutant Emitted: NO_x	
2. Total Percent Efficiency of Control:	40 %
3. Potential Emissions:	107.3 lb/hour 470 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor:	0.15 lb/MMBtu Reference: NO_x control system
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 0.15 lb/MMBtu x 715 MMBtu/hr = 107.3 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 862.5 TPY total for all boilers	

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	107.3 lb/hour	470 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 7 or 7E.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing		

B.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	67.5 lb/hour	110.1 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.17 lb/MMBtu		
4. Equivalent Allowable Emissions:	83.3 lb/hour	124.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	51 lb/hour	188.9 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 7 or 7E.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. Limit TDF firing to 40.2% on a heat input basis.		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**Pollutant Detail Information:**

1. Pollutant Emitted: CO		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	250.3 lb/hour	1,096 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
[] 1 [] 2 [] 3 _____ to _____ tons/yr		
6. Emission Factor:		0.35 lb/MMBtu
Reference: Boiler Design		
7. Emissions Method Code:		
[] 0 [] 1 <input checked="" type="checkbox"/> 2 [] 3 [] 4 [] 5		
8. Calculation of Emissions (limit to 600 characters):		
0.35 lb/MMBtu x 715 MMBtu/hr = 250.3 lb/hr. Limit based on 24-hour average.		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
2,012.5 TPY total for all boilers		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.2 lb/MMBtu <i>CO</i> <i>Coal</i>
4. Equivalent Allowable Emissions: 98 lb/hour 146.8 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually.
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing. Limit coal burning to 24.9% each boiler. Limit based on <u>24-hour average.</u>

B.

1. Basis for Allowable Emissions Code: OTHER
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.35 lb/MMBtu <i>TDF</i>
4. Equivalent Allowable Emissions: 63 lb/hour 440.8 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually.
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. Limit based on 24-hour average. TDF firing limited to 40.2% for each boiler, heat input basis.

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.35 lb/MMBtu <i>[Signature]</i>
4. Equivalent Allowable Emissions: 250.3 lb/hour 1,096.3 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually.
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing. Limit based on 24-hour average.

B.

1. Basis for Allowable Emissions Code: OTHER
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.2 lb/MMBtu <i>[Signature]</i>
4. Equivalent Allowable Emissions: 90 lb/hour 146.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing. Limit based on 24-hour average.

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: VOC		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	429 lb/hour	187.9 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.06 lb/MMBtu
Reference: Boiler Design		<i>Boiler Design</i>
7. Emissions Method Code:		
<input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters):		
<p>0.06 lb/MMBtu x 715 MMBtu/hr = 42.9 lb/hr</p>		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
<p>Based on biomass firing. Total for all three boilers = 345.0 TPY</p>		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

Volatile Organic Compounds

A.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.06 lb/MMBtu <i>permits</i>		
4. Equivalent Allowable Emissions:	42.9 lb/hour	187.9 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 25 or 25A		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing.		

B.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu <i>oil</i>		
4. Equivalent Allowable Emissions:	13.5 lb/hour	22 tons/year
5. Method of Compliance (limit to 60 characters): See Comment		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing. Limit No.2 fuel oil burning to 24.9% for any single boiler.		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

Volatile Organic Compounds

A.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	14.7 lb/hour	22 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.06 lb/MMBtu		
4. Equivalent Allowable Emissions:	10.8 lb/hour	75.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 25 or 25A annually		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. TDF firing limited to 40.2% for any single boiler (heat input basis).		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**Pollutant Detail Information:**

1. Pollutant Emitted: PB	
2. Total Percent Efficiency of Control:	99 %
3. Potential Emissions:	0.114 lb/hour 0.454 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor:	1.6 E-04 lb/MMBtu Reference: See Part B
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 1.6 E-04 lb/MMBtu x 715 MMBtu/hr = 0.114 lb/hr.	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Maximum emissions due to coal firing. Facility emissions are 0.454 TPY total all boilers.	

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 1.6 E-04 lb/MMBtu <i>pb</i> <i>lb/mm</i>		
4. Equivalent Allowable Emissions:	0.114 lb/hour	0.067 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Biomass Firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 8.9 E-07 lb/MMBtu <i>pb</i> <i>oil</i>		
4. Equivalent Allowable Emissions:	0.0004 lb/hour	0.0007 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): No.2 fuel oil firing		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 64 E-05 lb/MMBtu <i>Pb Lead</i>		
4. Equivalent Allowable Emissions:	0.031 lb/hour	0.047 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Coal Firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 42 E-05 lb/MMBtu <i>Pb TDF</i>		
4. Equivalent Allowable Emissions:	0.0143 lb/hour	0.053 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): TDF firing		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: SAM		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	17.6 lb/hour	27.8 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.036 lb/MMBtu
Reference: See Part B		
7. Emissions Method Code:		
<input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters):		
<p>0.036 lb/MMBtu x 490 MMBtu/hr = 17.6 lb/hr</p>		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
<p>Based on coal firing, 34.6 TPY total for all boilers.</p>		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.003 lb/MMBtu <i>SAM</i> <i>burner</i>		
4. Equivalent Allowable Emissions:	22 lb/hour	1.9 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.0015 lb/MMBtu <i>SAM</i> <i>oil</i>		
4. Equivalent Allowable Emissions:	0.74 lb/hour	1.1 tons/year
5. Method of Compliance (limit to 60 characters): <i>Method 8</i> EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

Emissions Unit Information Section 1 of 3Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.01 lb/MMBtu <i>5PM load</i>		
4. Equivalent Allowable Emissions:	17.6 lb/hour	26.4 tons/year
5. Method of Compliance (limit to 60 characters): <i>modified</i> EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.01 lb/MMBtu		
4. Equivalent Allowable Emissions:	3.4 lb/hour	8.7 tons/year
5. Method of Compliance (limit to 60 characters): <i>modified</i> EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: FL		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	11.8 lb/hour	17.6 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.024 lb/MMBtu
Reference: See Part B		
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): 0.024 lb/MMBtu x 490 MMBtu/hr = 11.8 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Based on coal firing. Total emissions from all three boilers limited to 21.23 TPY.		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.3 E-06 lb/MMBtu <i>PC</i> <i>out</i>		
4. Equivalent Allowable Emissions:	0.0031 lb/hour	0.0046 tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.024 lb/MMBtu <i>PC</i> <i>coal</i>		
4. Equivalent Allowable Emissions:	11.8 lb/hour	17.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 13A or 13B once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing.		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.5 E-04 lb/MMBtu <i>TU</i> <i>TDF</i>		
4. Equivalent Allowable Emissions:	0.22 lb/hour	0.82 tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)

Pollutant Detail Information:

1. Pollutant Emitted: H114 <i>Hy</i>		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	0.0041 lb/hour	0.0173 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		See Part B
Reference: See Part B		
7. Emissions Method Code: <input checked="" type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): Annual TPY limited by permit condition.		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Total emissions all three boilers 0.030 TPY.		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 4 E-06 lb/MMBtu <i>Hy Wood</i>
4. Equivalent Allowable Emissions: 0.0029 lb/hour 0.0152 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on wood waste firing.

B.

1. Basis for Allowable Emissions Code: OTHER
2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 543 E-06 lb/MMBtu <i>Hy Bagasse</i>
4. Equivalent Allowable Emissions: 0.0045 lb/hour 0.0152 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA method 101A.
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on bagasse firing. Limit subject to revision based on stack testing.

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 24 E-06 lb/MMBtu <i>Hog</i>		
4. Equivalent Allowable Emissions:	0.0012 lb/hour	0.0018 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 8.4 E-06 lb/MMBtu <i>Hog</i>		
4. Equivalent Allowable Emissions:	0.0041 lb/hour	0.0062 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing.		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.5 E-06 lb/MMBtu <i>Hg</i> <i>TDF</i>		
4. Equivalent Allowable Emissions:	0.0022 lb/hour	0.0082 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)

Pollutant Detail Information:

1. Pollutant Emitted: H021 <i>BS</i>	
2. Total Percent Efficiency of Control:	99 %
3. Potential Emissions:	0.0029 lb/hour 0.0043 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor: Reference: See Part B	
7. Emissions Method Code: <input checked="" type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 490 MMBtu/hr x 5.9 E-06 lb/MMBtu = 0.0029 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Max lb/hr based on coal firing. Total emissions all three boilers limited to 0.0052 TPY.	

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 5.9 E-06 lb/MMBtu 		
4. Equivalent Allowable Emissions:	0.0029 lb/hour	0.0043 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 3.5 E-07 lb/MMBtu 		
4. Equivalent Allowable Emissions:	0.0002 lb/hour	0.0003 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

Emissions Unit Information Section 1 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 4.5 E-07 lb/MMBtu 		
4. Equivalent Allowable Emissions:	0.0002 lb/hour	0.0006 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

**I. VISIBLE EMISSIONS INFORMATION
(Regulated Emissions Units Only)**

Visible Emissions Limitations: Visible Emissions Limitation 1 of 1

1.	Visible Emissions Subtype: VE20
2.	Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: 20 % Exceptional Conditions: 27 % Maximum Period of Excess Opacity Allowed: 6 min/hour
4.	Method of Compliance: EPA Method 9
5.	Visible Emissions Comment (limit to 200 characters):

Visible Emissions Limitations: Visible Emissions Limitation _____ of _____

1.	Visible Emissions Subtype:
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour
4.	Method of Compliance:
5.	Visible Emissions Comment (limit to 200 characters):

**J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)**

Continuous Monitoring System Continuous Monitor 1 of 5

1. Parameter Code: VE	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Durag Model Number: D-R281AV Serial Number: 31019	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor 2 of 5

1. Parameter Code: NOx	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 42D Serial Number: 42D-52618-292	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)

Continuous Monitoring System Continuous Monitor 3 of 5

1. Parameter Code: SO2	2. Pollutant(s):
3. CMS Requirement: [] Rule [<input checked="" type="checkbox"/>] Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 43B Serial Number: 43B-51400-292	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor 4 of 5

1. Parameter Code: CO	2. Pollutant(s):
3. CMS Requirement: [] Rule [<input checked="" type="checkbox"/>] Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 48 Serial Number: 48-45334-273	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters):	

**J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)**

Continuous Monitoring System Continuous Monitor 5 of 5

1. Parameter Code: O2	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Yokogawa Model Number: ZA8C Serial Number: JJ113MA345	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement: <input type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Model Number: Serial Number:	
5. Installation Date:	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters):	

**K. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT
TRACKING INFORMATION
(Regulated and Unregulated Emissions Units)**

PSD Increment Consumption Determination

1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

If the emissions unit addressed in this section emits particulate matter or sulfur dioxide, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for particulate matter or sulfur dioxide. Check the first statement, if any, that applies and skip remaining statements.

-] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. If so, emissions unit consumes increment.
- []] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. If so, baseline emissions are zero, and the emissions unit consumes increment.
- []] The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. If so, baseline emissions are zero, and the emissions unit consumes increment.
- []] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
- []] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

If the emissions unit addressed in this section emits nitrogen oxides, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for nitrogen dioxide. Check first statement, if any, that applies and skip remaining statements.

-] The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. If so, emissions unit consumes increment.
-] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. If so, baseline emissions are zero, and the source consumes increment.
-] The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. If so, baseline emissions are zero, and the source consumes increment.
-] For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. If so, baseline emissions are zero, and the emissions unit consumes increment.
-] None of the above apply. If so, baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3.	Increment Consuming/Expanding Code:		
	PM	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E <input type="checkbox"/>] Unknown
	SO ₂	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E <input type="checkbox"/>] Unknown
	NO ₂	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E <input type="checkbox"/>] Unknown
4.	Baseline Emissions:		
	PM	0 lb/hour	0 tons/year
	SO ₂	0 lb/hour	0 tons/year
	NO ₂		0 tons/year
5.	PSD Comment (limit to 200 characters):		

**L. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**

Supplemental Requirements for All Applications

1.	Process Flow Diagram	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
2.	Fuel Analysis or Specification	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
3.	Detailed Description of Control Equipment	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
4.	Description of Stack Sampling Facilities	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
5.	Compliance Test Report	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
		<input type="checkbox"/> Previously Submitted, Date: _____	
6.	Procedures for Startup and Shutdown	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
7.	Operation and Maintenance Plan	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
8.	Supplemental Information for Construction Permit Application	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Not Applicable
9.	Other Information Required by Rule or Statute	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Not Applicable

Additional Supplemental Requirements for Category I Applications Only

10. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Acid Rain Permit Application (Hard Copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through L as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application. Some of the subsections comprising the Emissions Unit Information Section of the form are intended for regulated emissions units only. Others are intended for both regulated and unregulated emissions units. Each subsection is appropriately marked.

**A. TYPE OF EMISSIONS UNIT
(Regulated and Unregulated Emissions Units)****Type of Emissions Unit Addressed in This Section**

1. Regulated or Unregulated Emissions Unit? Check one:

] The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.

] The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

2. Single Process, Group of Processes, or Fugitive Only? Check one:

] This Emissions Unit information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).

] This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.

] This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

B. GENERAL EMISSIONS UNIT INFORMATION
(Regulated and Unregulated Emissions Units)

Emissions Unit Description and Status

1. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Boiler B fired by Biomass/No.2 oil/coal/TDF		
2. Emissions Unit Identification Number: [] No Corresponding ID [] Unknown 002		
3. Emissions Unit Status Code: A	4. Acid Rain Unit? [] Yes [x] No	5. Emissions Unit Major Group SIC Code: 49
6. Emissions Unit Comment (limit to 500 characters): 74.9 MW gross generating capacity for entire facility.		

Emissions Unit Control Equipment Information

A.

1. Description (limit to 200 characters): ESP - Electrostatic Precipitator
2. Control Device or Method Code: 10

B.

1. Description (limit to 200 characters): Selective Non-Catalytic Reduction for NOx
2. Control Device or Method Code: 107

C.

1. Description (limit to 200 characters): Activated Carbon injection system.
2. Control Device or Method Code: 48

C. EMISSIONS UNIT DETAIL INFORMATION
(Regulated Emissions Units Only)

Emissions Unit Details

1. Initial Startup Date:		
2. Long-term Reserve Shutdown Date:		
3. Package Unit: Manufacturer:	Model Number:	
4. Generator Nameplate Rating:	75 MW	
5. Incinerator Information:		
	Dwell Temperature:	°F
	Dwell Time:	seconds
	Incinerator Afterburner Temperature:	°F

Emissions Unit Operating Capacity

1. Maximum Heat Input Rate:	715	mmBtu/hr
2. Maximum Incineration Rate:	lbs/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Operating Capacity Comment (limit to 200 characters):		
<p>Maximum heat input rates: Biomass - 715 MMBtu/hr; No.2 Fuel Oil - 490 MMBtu/hr; Coal - 490 MMBtu/hr; Tire-derived fuel - 340 MMBtu/hr</p>		

Emissions Unit Operating Schedule

1. Requested Maximum Operating Schedule:		
	24 hours/day	7 days/week
	52 weeks/yr	8,760 hours/yr

**D. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)**

Rule Applicability Analysis (Required for Category II Applications and Category III applications involving non Title-V sources. See Instructions.)

A large, empty rectangular box with a black border, intended for the user to provide a Rule Applicability Analysis. The box is currently blank.

List of Applicable Regulations (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

40 CFR 60, Subpart Da
40 CFR 60, Subpart Ea and Cb (record keeping only)
62-296.570 Reasonably Avail. Control Technology

**E. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)**

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram: BLR B	
2. Emission Point Type Code: <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4	
3. Descriptions of Emissions Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):	
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:	
5. Discharge Type Code: <input type="checkbox"/> D <input type="checkbox"/> F <input type="checkbox"/> H <input type="checkbox"/> P <input type="checkbox"/> R <input checked="" type="checkbox"/> V <input type="checkbox"/> W	
6. Stack Height:	225 feet
7. Exit Diameter:	10 feet
8. Exit Temperature:	330 °F

9. Actual Volumetric Flow Rate:	270,000 acfm	
10. Percent Water Vapor:	%	
11. Maximum Dry Standard Flow Rate:	dscfm	
12. Nonstack Emission Point Height:	feet	
13. Emission Point UTM Coordinates:		
Zone:	East (km):	North (km):
14. Emission Point Comment (limit to 200 characters):		
Stack parameters based on biomass firing.		

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility boiler - bagasse	
2. Source Classification Code (SCC): 1-01-011-01	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 84.118	5. Maximum Annual Rate: 736,874
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.05	8. Maximum Percent Ash:
9. Million Btu per SCC Unit:	
10. Segment Comment (limit to 200 characters): Maximum percent Sulfur: 0.05. Maximum Percent Ash: 0.42. Million Btu per SCC Unit: 8.5. Total biomass all three boilers = 1,352,941 TPY.	

Segment Description and Rate: Segment 2 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Wood Fired Boiler	
2. Source Classification Code (SCC): 1-01-009-03	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 65	5. Maximum Annual Rate: 569,400
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.11	8. Maximum Percent Ash: 3.2
9. Million Btu per SCC Unit: 11	
10. Segment Comment (limit to 200 characters): Maximum Percent Sulfur: 0.11. Total biomass all three boilers = 1,352,941 TPY.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 3 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Distillate Oil - Grades 1 and 2 oil	
2. Source Classification Code (SCC): 1-01-005-01	
3. SCC Units: Thousand Gallons Burned	
4. Maximum Hourly Rate: 3.551	5. Maximum Annual Rate: 7,745
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.05	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 138	
10. Segment Comment (limit to 200 characters): Maximum Annual Rate: 7,745,000. This represents 24.9% oil firing on a heat input basis. Total No.2 Fuel Oil all three boilers = 19,533,086 gal/yr.	

Segment Description and Rate: Segment 4 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility boiler - Butiminous Coal - Spreader Stoker	
2. Source Classification Code (SCC): 1-01-002-04	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 20.417	5. Maximum Annual Rate: 61,172
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.7	8. Maximum Percent Ash: 3.7
9. Million Btu per SCC Unit: 24	
10. Segment Comment (limit to 200 characters): Total coal all three boilers = 69,720 TPY (15.1% coal burning on a heat input basis). The combined heat input for coal and oil <25% on a calendar quarter basis.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 5 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Solid Waste - Tire Derived Fuel	
2. Source Classification Code (SCC): 1-01-012-01	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 11	5. Maximum Annual Rate: 81,246
6. Estimated Annual Activity Factor: 	
7. Maximum Percent Sulfur: 1.2	8. Maximum Percent Ash: 5
9. Million Btu per SCC Unit: 31	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on 340 MMBtu/hr TDF. Total TDF all three boilers = 81,246 TPY. This represents 9.0% TDF burning on a weight basis.	

Segment Description and Rate: Segment of

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters):	
2. Source Classification Code (SCC):	
3. SCC Units:	
4. Maximum Hourly Rate:	5. Maximum Annual Rate:
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit:	
10. Segment Comment (limit to 200 characters):	

**G. EMISSIONS UNIT POLLUTANTS
(Regulated and Unregulated Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM	010		EL
PM10	010		EL
SO2			EL
NOx			EL
CO			EL
VOC			EL
PB	010		EL
SAM			EL
FL			EL
H114	048		EL
H021			EL
HAPS			NS
H106			NS
H107			NS

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: PM		
2. Total Percent Efficiency of Control:		99 %
3. Potential Emissions:	21.5 lb/hour	94.17 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.03 lb/MMBtu
Reference: 40 CFR 60 Subpart Da		
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): 0.03 lb/MMBtu x 715 MMBtu/hr = 21.5 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 172.5 TPY total for all boilers		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

Particulate Matter - Total

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	21.5 lb/hour	94.17 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 5		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Maximum lb/hr based on biomass firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: PM10	
2. Total Percent Efficiency of Control:	99 %
3. Potential Emissions:	21.5 lb/hour 94.17 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor: 0.03 lb/MMBtu Reference: 40 CFR 60 Subpart Da	
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 0.03 lb/MMBtu x 715 MMBtu/hr = 21.5 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 172.5 TPY total for all boilers	

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	21.5 lb/hour	94.17 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack testing using EPA Method 5.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Maximum lb/hr based on biomass firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)****Pollutant Detail Information:**

1. Pollutant Emitted: SO₂	
2. Total Percent Efficiency of Control:	%
3. Potential Emissions:	588 lb/hour 1,067.5 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor:	1.2 lb/MMBtu
Reference: 40 CFR 60 Subpart Da	
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 1.2 lb/MMBtu x 490 MMBtu/hr = 588.0 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 1,154.3 TPY total for all three boilers.	

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

Boiler B
Sulfur Dioxide

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.1 lb/MMBtu		
4. Equivalent Allowable Emissions:	71.5 lb/hour	100.2 tons/year
5. Method of Compliance (limit to 60 characters): Continuous SO2 monitor		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions: 0.1 lb/MMBtu 24-hr avg; Annual- 0.02 lb/MMBtu for bagasse, 0.05 lb/MMBtu for wood. Based on biomass firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 1.2 lb/MMBtu		
4. Equivalent Allowable Emissions:	408 lb/hour	1,008 tons/year
5. Method of Compliance (limit to 60 characters): Continuous SO2 monitor.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions: 1.2 lb/MMBtu, 24-hr avg.; 0.8 lb/MMBtu, annual avg. Based on tire-derived fuel firing. Annual TPY: 81,246 TPY TDF x 15,500 Btu/lb x 0.8 lb/MMBtu = 1,007.6 TPY		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

Boiler B
 Sulfur Dioxide

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 12 lb/MMBtu		
4. Equivalent Allowable Emissions:	588 lb/hour	880.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Based on coal firing.		

B.

1. Basis for Allowable Emissions Code: RULE		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.05 lb/MMBtu		
4. Equivalent Allowable Emissions:	22.5 lb/hour	36.7 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing and BACT.		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**Pollutant Detail Information:**

1. Pollutant Emitted: NOx	
2. Total Percent Efficiency of Control:	40 %
3. Potential Emissions:	107.3 lb/hour 470 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor:	0.15 lb/MMBtu
Reference: NOx control system	
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 0.15 lb/MMBtu x 715 MMBtu/hr = 107.3 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 862.5 TPY total for all boilers	

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	107.3 lb/hour	470 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 7 or 7E		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing		

B.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	67.5 lb/hour	110.1 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.17 lb/MMBtu		
4. Equivalent Allowable Emissions:	83.3 lb/hour	124.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	51 lb/hour	188.9 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 7 or 7E.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. Limit TDF firing to 40.2% on a heat input basis.		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**Pollutant Detail Information:**

1. Pollutant Emitted: CO		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	250.3 lb/hour	1,096 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
[] 1 [] 2 [] 3 _____ to _____ tons/yr		
6. Emission Factor:		0.35 lb/MMBtu
Reference: Boiler Design		
7. Emissions Method Code:		
[] 0 [] 1 <input checked="" type="checkbox"/> 2 [] 3 [] 4 [] 5		
8. Calculation of Emissions (limit to 600 characters):		
0.35 lb/MMBtu x 715 MMBtu/hr = 250.3 lb/hr. Limit based on 24-hour average.		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
2,012.5 TPY total for all boilers		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.2 lb/MMBtu		
4. Equivalent Allowable Emissions:	98 lb/hour	146.8 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing. Limit coal burning to 24.9% each boiler. Limit based on 24-hour average.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.35 lb/MMBtu		
4. Equivalent Allowable Emissions:	63 lb/hour	440.8 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. Limit based on 24-hour average. TDF firing limited to 40.2% for each boiler, heat input basis.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.35 lb/MMBtu		
4. Equivalent Allowable Emissions:	250.3 lb/hour	1,096.3 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing. Limit based on 24-hour average.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.2 lb/MMBtu		
4. Equivalent Allowable Emissions:	90 lb/hour	146.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing. Limit based on 24-hour average.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: VOC		
2. Total Percent Efficiency of Control:	%	
3. Potential Emissions:	429 lb/hour	187.9 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:	0.06 lb/MMBtu	
Reference: Boiler Design		
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): 0.06 lb/MMBtu x 715 MMBtu/hr = 42.9 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Based on biomass firing. Total for all three boilers = 345.0 TPY		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

Volatile Organic Compounds

A.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.06 lb/MMBtu		
4. Equivalent Allowable Emissions:	42.9 lb/hour	187.9 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 25 or 25A		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing.		

B.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	13.5 lb/hour	22 tons/year
5. Method of Compliance (limit to 60 characters): See Comment		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing. Limit No.2 fuel oil burning to 24.9% entire facility and for any single boiler.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

Volatile Organic Compounds

A.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	14.7 lb/hour	22 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.06 lb/MMBtu		
4. Equivalent Allowable Emissions:	10.8 lb/hour	75.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 25 or 25A annually		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. TDF firing limited to 40.2% for any single boiler (heat input basis).		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: PB	
2. Total Percent Efficiency of Control:	99 %
3. Potential Emissions:	0.114 lb/hour 0.454 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor:	1.6 E-04 lb/MMBtu Reference: See Part B
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 1.6 E-04 lb/MMBtu x 715 MMBtu/hr = 0.114 lb/hr.	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Maximum emissions due to coal firing. Facility emissions are 0.454 TPY total all boilers.	

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 1.6 E-04 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.114 lb/hour	0.067 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Biomass Firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 8.9 E-07 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0004 lb/hour	0.0007 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): No.2 fuel oil firing		

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 64 E-05 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.031 lb/hour	0.047 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Coal Firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 42 E-05 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0143 lb/hour	0.053 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): TDF firing		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: SAM		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	17.6 lb/hour	27.8 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.036 lb/MMBtu
Reference: See Part B		
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): 0.036 lb/MMBtu x 490 MMBtu/hr = 17.6 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Based on coal firing, 34.6 TPY total for all boilers.		

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.003 lb/MMBtu		
4. Equivalent Allowable Emissions:	2.2 lb/hour	1.9 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.0015 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.74 lb/hour	1.1 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.01 lb/MMBtu		
4. Equivalent Allowable Emissions:	17.6 lb/hour	26.4 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.01 lb/MMBtu		
4. Equivalent Allowable Emissions:	3.4 lb/hour	8.7 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: FL		
2. Total Percent Efficiency of Control:	%	
3. Potential Emissions:	11.8 lb/hour	17.6 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:	0.024 lb/MMBtu	
Reference: See Part B		
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): 0.024 lb/MMBtu x 490 MMBtu/hr = 11.8 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Based on coal firing. Total emissions from all three boilers limited to 21.23 TPY.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.3 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0031 lb/hour	0.0046 tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.024 lb/MMBtu		
4. Equivalent Allowable Emissions:	11.8 lb/hour	17.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 13A or 13B once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.5 E-04 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.22 lb/hour	0.82 tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)

Pollutant Detail Information:

1. Pollutant Emitted: H114		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	0.0041 lb/hour	0.0173 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		See Part B
Reference: See Part B		
7. Emissions Method Code:		
<input checked="" type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters):		
Annual TPY limited by permit condition.		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
Total emissions all three boilers 0.030 TPY.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 4 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0029 lb/hour	0.0152 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on wood waste firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 543 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0045 lb/hour	0.0152 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on bagasse firing. Limit subject to revision based on stack testing.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 24 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0012 lb/hour	0.0018 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 oil firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 84 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0041 lb/hour	0.0062 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.5 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0022 lb/hour	0.0082 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: H021	
2. Total Percent Efficiency of Control:	99 %
3. Potential Emissions:	0.0029 lb/hour 0.0043 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor: Reference: See Part B	
7. Emissions Method Code: <input checked="" type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 490 MMBtu/hr x 5.9 E-06 lb/MMBtu = 0.0029 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Max lb/hr based on coal firing. Total emissions all three boilers limited to 0.0052 TPY.	

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 5.9 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0029 lb/hour	0.0043 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 3.5 E-07 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0002 lb/hour	0.0003 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

Emissions Unit Information Section 2 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 4.5 E-07 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0002 lb/hour	0.0006 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

I. VISIBLE EMISSIONS INFORMATION
(Regulated Emissions Units Only)

Visible Emissions Limitations: Visible Emissions Limitation 1 of 1

1.	Visible Emissions Subtype: VE20
2.	Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: 20 % Exceptional Conditions: 27 % Maximum Period of Excess Opacity Allowed: 6 min/hour
4.	Method of Compliance: EPA Method 9
5.	Visible Emissions Comment (limit to 200 characters):

Visible Emissions Limitations: Visible Emissions Limitation _____ of _____

1.	Visible Emissions Subtype:
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour
4.	Method of Compliance:
5.	Visible Emissions Comment (limit to 200 characters):

**J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)**

Continuous Monitoring System Continuous Monitor 1 of 5

1. Parameter Code: VE	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Durag Model Number: D-R281AV Serial Number: 31015	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor 2 of 5

1. Parameter Code: NOx	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 42D Serial Number: 42D-51082-292	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

**J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)**

Continuous Monitoring System Continuous Monitor 3 of 5

1. Parameter Code: SO2	2. Pollutant(s):
3. CMS Requirement: [] Rule [<input checked="" type="checkbox"/>] Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 43B Serial Number: 43B-49519-292	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor 4 of 5

1. Parameter Code: CO	2. Pollutant(s):
3. CMS Requirement: [] Rule [<input checked="" type="checkbox"/>] Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 48 Serial Number: 48-45334-273	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters):	

**J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)**

Continuous Monitoring System Continuous Monitor 5 of 5

1. Parameter Code: O2	2. Pollutant(s):
3. CMS Requirement: [<input checked="" type="checkbox"/>] Rule [<input type="checkbox"/>] Other	
4. Monitor Information: Monitor Manufacturer: Yokogawa Model Number: ZA8C Serial Number: JJ113PA133	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement: [<input type="checkbox"/>] Rule [<input type="checkbox"/>] Other	
4. Monitor Information: Monitor Manufacturer: Model Number: Serial Number:	
5. Installation Date:	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters):	

**K. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT
TRACKING INFORMATION
(Regulated and Unregulated Emissions Units)**

PSD Increment Consumption Determination

1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

If the emissions unit addressed in this section emits particulate matter or sulfur dioxide, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for particulate matter or sulfur dioxide. Check the first statement, if any, that applies and skip remaining statements.

-] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. If so, emissions unit consumes increment.
-] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. If so, baseline emissions are zero, and the emissions unit consumes increment.
-] The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. If so, baseline emissions are zero, and the emissions unit consumes increment.
-] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
-] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

If the emissions unit addressed in this section emits nitrogen oxides, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for nitrogen dioxide. Check first statement, if any, that applies and skip remaining statements.

-] The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. If so, emissions unit consumes increment.

-] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. If so, baseline emissions are zero, and the source consumes increment.

-] The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. If so, baseline emissions are zero, and the source consumes increment.

-] For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. If so, baseline emissions are zero, and the emissions unit consumes increment.

-] None of the above apply. If so, baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3.	Increment Consuming/Expanding Code:			
	PM	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E	<input type="checkbox"/>] Unknown
	SO ₂	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E	<input type="checkbox"/>] Unknown
	NO ₂	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E	<input type="checkbox"/>] Unknown
4.	Baseline Emissions:			
	PM	0 lb/hour		0 tons/year
	SO ₂	0 lb/hour		0 tons/year
	NO ₂			0 tons/year
5.	PSD Comment (limit to 200 characters):			

**L. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**

Supplemental Requirements for All Applications

1.	Process Flow Diagram	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
2.	Fuel Analysis or Specification	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
3.	Detailed Description of Control Equipment	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
4.	Description of Stack Sampling Facilities	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
5.	Compliance Test Report	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
		<input type="checkbox"/> Previously Submitted, Date: _____	
6.	Procedures for Startup and Shutdown	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
7.	Operation and Maintenance Plan	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
8.	Supplemental Information for Construction Permit Application	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Not Applicable
9.	Other Information Required by Rule or Statute	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Not Applicable

Additional Supplemental Requirements for Category I Applications Only

10. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Acid Rain Permit Application (Hard Copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through L as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application. Some of the subsections comprising the Emissions Unit Information Section of the form are intended for regulated emissions units only. Others are intended for both regulated and unregulated emissions units. Each subsection is appropriately marked.

**A. TYPE OF EMISSIONS UNIT
(Regulated and Unregulated Emissions Units)****Type of Emissions Unit Addressed in This Section**

1. Regulated or Unregulated Emissions Unit? Check one:

The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.

The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.

2. Single Process, Group of Processes, or Fugitive Only? Check one:

This Emissions Unit information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).

This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.

This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.

**B. GENERAL EMISSIONS UNIT INFORMATION
(Regulated and Unregulated Emissions Units)**

Emissions Unit Description and Status

1. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Boiler C fired by Biomass/No.2 oil/coal/TDF		
2. Emissions Unit Identification Number: <input type="checkbox"/> No Corresponding ID <input type="checkbox"/> Unknown 003		
3. Emissions Unit Status Code: A	4. Acid Rain Unit? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	5. Emissions Unit Major Group SIC Code: 49
6. Emissions Unit Comment (limit to 500 characters): 74.9 MW gross generating capacity for entire facility.		

Emissions Unit Control Equipment Information

A.

1. Description (limit to 200 characters): ESP - Electrostatic Precipitator
2. Control Device or Method Code: 10

B.

1. Description (limit to 200 characters): Selective Non-Catalytic Reduction for NOx
2. Control Device or Method Code: 107

C.

1. Description (limit to 200 characters): Activated Carbon injection system.
2. Control Device or Method Code: 48

**C. EMISSIONS UNIT DETAIL INFORMATION
(Regulated Emissions Units Only)**

Emissions Unit Details

1. Initial Startup Date:		
2. Long-term Reserve Shutdown Date:		
3. Package Unit: Manufacturer:	Model Number:	
4. Generator Nameplate Rating:	MW	
5. Incinerator Information:		
	Dwell Temperature:	°F
	Dwell Time:	seconds
	Incinerator Afterburner Temperature:	°F

Emissions Unit Operating Capacity


1. Maximum Heat Input Rate:	715	mmBtu/hr
2. Maximum Incineration Rate:	lbs/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Operating Capacity Comment (limit to 200 characters):		
Maximum heat input rates: Biomass - 715 MMBtu/hr; No.2 Fuel Oil - 490 MMBtu/hr; Coal - 490 MMBtu/hr; Tire-derived fuel - 340 MMBtu/hr		

Emissions Unit Operating Schedule

1. Requested Maximum Operating Schedule:		
	24 hours/day	7 days/week
	52 weeks/yr	8,760 hours/yr

**D. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)**

Rule Applicability Analysis (Required for Category II Applications and Category III applications involving non Title-V sources. See Instructions.)



List of Applicable Regulations (Required for Category I applications and Category III applications involving Title-V sources. See Instructions.)

40 CFR 60, Subpart Da
40 CFR 60, Subpart Ea and Cd (record keeping only)
62-296.570 Reasonably Avail. Control Technology

E. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram: BLR C	
2. Emission Point Type Code: <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4	
3. Descriptions of Emissions Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):	
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:	
5. Discharge Type Code: <input type="checkbox"/> D <input type="checkbox"/> F <input type="checkbox"/> H <input type="checkbox"/> P <input type="checkbox"/> R <input checked="" type="checkbox"/> V <input type="checkbox"/> W	
6. Stack Height:	225 feet
7. Exit Diameter:	10 feet
8. Exit Temperature:	330 °F

9. Actual Volumetric Flow Rate:	270,000 acfm
10. Percent Water Vapor:	%
11. Maximum Dry Standard Flow Rate:	dscfm
12. Nonstack Emission Point Height:	feet
13. Emission Point UTM Coordinates:	
Zone:	East (km): North (km):
14. Emission Point Comment (limit to 200 characters):	
<p>Stack parameters based on biomass firing.</p>	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility boiler - bagasse	
2. Source Classification Code (SCC): 1-01-011-01	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 84.118	5. Maximum Annual Rate: 736,874
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.05	8. Maximum Percent Ash:
9. Million Btu per SCC Unit:	
10. Segment Comment (limit to 200 characters): Maximum percent Sulfur: 0.05. Maximum Percent Ash: 0.42. Million Btu per SCC Unit: 8.5. Total biomass all three boilers = 1,352,941 TPY.	

Segment Description and Rate: Segment 2 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Wood Fired Boiler	
2. Source Classification Code (SCC): 1-01-009-03	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 65	5. Maximum Annual Rate: 569,400
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.11	8. Maximum Percent Ash: 3.2
9. Million Btu per SCC Unit: 11	
10. Segment Comment (limit to 200 characters): Maximum Percent Sulfur: 0.11. Total biomass all three boilers = 1,352,941 TPY.	

**F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)**

Segment Description and Rate: Segment 3 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Distillate Oil - Grades 1 and 2 oil	
2. Source Classification Code (SCC): 1-01-005-01	
3. SCC Units: Thousand Gallons Burned	
4. Maximum Hourly Rate: 3.551	5. Maximum Annual Rate: 7,745
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.05	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 138	
10. Segment Comment (limit to 200 characters): Maximum Annual Rate: 7,745,000. This represents 24.9% oil firing on a heat input basis. Total No.2 Fuel Oil all three boilers = 19,533,086 gal/yr.	

Segment Description and Rate: Segment 4 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility boiler - Butiminous Coal - Spreader Stoker	
2. Source Classification Code (SCC): 1-01-002-04	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 20,417	5. Maximum Annual Rate: 61,172
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.7	8. Maximum Percent Ash: 3.7
9. Million Btu per SCC Unit: 24	
10. Segment Comment (limit to 200 characters): Total coal all three boilers = 69,720 TPY (15.1% coal burning on a heat input basis). The combined heat input for coal and oil <25% on a calendar quarter basis.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 5 of 5

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Electric Utility Boiler - Solid Waste - Tire Derived Fuel	
2. Source Classification Code (SCC): 1-01-012-01	
3. SCC Units: Tons Burned	
4. Maximum Hourly Rate: 11	5. Maximum Annual Rate: 81,246
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 1.2	8. Maximum Percent Ash: 5
9. Million Btu per SCC Unit: 31	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on 340 MMBtu/hr TDF. Total TDF all three boilers = 81,246 TPY. This represents 9.0% TDF burning on a weight basis.	

Segment Description and Rate: Segment of

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters):	
2. Source Classification Code (SCC):	
3. SCC Units:	
4. Maximum Hourly Rate:	5. Maximum Annual Rate:
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit:	
10. Segment Comment (limit to 200 characters):	

**G. EMISSIONS UNIT POLLUTANTS
(Regulated and Unregulated Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM	010		EL
PM10	010		EL
SO2			EL
NOx	107		EL
CO			EL
VOC			EL
PB	010		EL
SAM			EL
FL			EL
H114	048		EL
H021			EL
HAPS			NS
H106			NS
H107			NS

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: PM		
2. Total Percent Efficiency of Control:		99 %
3. Potential Emissions:	21.5 lb/hour	94.17 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.03 lb/MMBtu
Reference: 40 CFR 60 Subpart Da		
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): 0.03 lb/MMBtu x 715 MMBtu/hr = 21.5 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 172.5 TPY total for all boilers		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

Particulate Matter - Total

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	21.5 lb/hour	94.17 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 5		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Maximum lb/hr based on biomass firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)

Pollutant Detail Information:

1. Pollutant Emitted: PM10		
2. Total Percent Efficiency of Control:		99 %
3. Potential Emissions:	21.5 lb/hour	94.17 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.03 lb/MMBtu
Reference: 40 CFR 60 Subpart Da		
7. Emissions Method Code:		
<input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters):		
0.03 lb/MMBtu x 715 MMBtu/hr = 21.5 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
172.5 TPY total for all boilers		

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	21.5 lb/hour	94.17 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack testing using EPA Method 5.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Maximum lb/hr based on biomass firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: SO2	
2. Total Percent Efficiency of Control:	%
3. Potential Emissions:	588 lb/hour 1,067.5 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor:	1.2 lb/MMBtu
Reference: 40 CFR 60 Subpart Da	
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 1.2 lb/MMBtu x 490 MMBtu/hr = 588.0 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 1,154.3 TPY total for all three boilers.	

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.1 lb/MMBtu		
4. Equivalent Allowable Emissions:	71.5 lb/hour	100.2 tons/year
5. Method of Compliance (limit to 60 characters): Continuous SO2 monitor		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions: 0.1 lb/MMBtu 24-hr avg; Annual- 0.02 lb/MMBtu for bagasse, 0.05 lb/MMBtu for wood. Based on biomass firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 1.2 lb/MMBtu		
4. Equivalent Allowable Emissions:	408 lb/hour	1,008 tons/year
5. Method of Compliance (limit to 60 characters): Continuous SO2 monitor.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Requested Allowable Emissions: 1.2 lb/MMBtu, 24-hr avg.; 0.8 lb/MMBtu, annual avg. Based on tire-derived fuel firing. Annual TPY: 81,246 TPY TDF x 15,500 Btu/lb x 0.8 lb/MMBtu = 1,007.6 TPY		

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 1.2 lb/MMBtu		
4. Equivalent Allowable Emissions:	588 lb/hour	880.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Basis for Allowable Emissions Code: NSPS. Based on coal firing.		

B.

1. Basis for Allowable Emissions Code: RULE		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.05 lb/MMBtu		
4. Equivalent Allowable Emissions:	22.5 lb/hour	36.7 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing and BACT.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: NOx	
2. Total Percent Efficiency of Control:	40 %
3. Potential Emissions:	107.3 lb/hour 470 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor: 0.15 lb/MMBtu Reference: NOx control system	
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 0.15 lb/MMBtu x 715 MMBtu/hr = 107.3 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 862.5 TPY total for all boilers	

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: ESCPD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	107.3 lb/hour	470 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 7 or 7E		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing		

B.

1. Basis for Allowable Emissions Code: ESCPD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	67.5 lb/hour	110.1 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing		

A.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.17 lb/MMBtu		
4. Equivalent Allowable Emissions:	83.3 lb/hour	124.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: ESCPSD		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.15 lb/MMBtu		
4. Equivalent Allowable Emissions:	51 lb/hour	188.9 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 7 or 7E.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. Limit TDF firing to 40.2% on a heat input basis.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: CO		
2. Total Percent Efficiency of Control:	%	
3. Potential Emissions:	250.3 lb/hour	1,096 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:	0.35 lb/MMBtu	
Reference: Boiler Design		
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): 0.35 lb/MMBtu x 715 MMBtu/hr = 250.3 lb/hr. Limit based on 24-hour average.		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): 2,012.5 TPY total for all boilers		

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.2 lb/MMBtu		
4. Equivalent Allowable Emissions:	98 lb/hour	146.8 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing. Limit coal burning to 24.9% each boiler. Limit based on 24-hour average.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.35 lb/MMBtu		
4. Equivalent Allowable Emissions:	63 lb/hour	440.8 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. Limit based on 24-hour average. TDF firing limited to 40.2% for each boiler, heat input basis.		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.35 lb/MMBtu		
4. Equivalent Allowable Emissions:	250.3 lb/hour	1,096.3 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 10 annually		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing. Limit based on 24-hour average.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.2 lb/MMBtu		
4. Equivalent Allowable Emissions:	90 lb/hour	146.8 tons/year
5. Method of Compliance (limit to 60 characters): Limit fuel oil burning to 24.9% for any single boiler.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing. Limit based on 24-hour average.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: VOC		
2. Total Percent Efficiency of Control:	%	
3. Potential Emissions:	42.9 lb/hour	187.9 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:	0.06 lb/MMBtu	
Reference: Boiler Design		
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters): 0.06 lb/MMBtu x 715 MMBtu/hr = 42.9 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Based on biomass firing. Total for all three boilers = 345.0 TPY		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

Volatile Organic Compounds

A.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.06 lb/MMBtu		
4. Equivalent Allowable Emissions:	429 lb/hour	187.9 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test using EPA Method 25 or 25A		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing.		

B.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	13.5 lb/hour	22 tons/year
5. Method of Compliance (limit to 60 characters): See Comment		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing. Limit No.2 fuel oil burning to 24.9% entire facility and for any single boiler.		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.03 lb/MMBtu		
4. Equivalent Allowable Emissions:	14.7 lb/hour	22 tons/year
5. Method of Compliance (limit to 60 characters): Limit coal burning to 24.9% for any single boiler		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: ESCNAA		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.06 lb/MMBtu		
4. Equivalent Allowable Emissions:	10.8 lb/hour	75.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 25 or 25A annually		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing. TDF firing limited to 40.2% for any single boiler (heat input basis).		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)****Pollutant Detail Information:**

1. Pollutant Emitted: PB	
2. Total Percent Efficiency of Control:	99 %
3. Potential Emissions:	0.114 lb/hour 0.454 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor:	1.6 E-04 lb/MMBtu Reference: See Part B
7. Emissions Method Code: <input type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input checked="" type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 1.6 E-04 lb/MMBtu x 715 MMBtu/hr = 0.114 lb/hr.	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Maximum emissions due to coal firing. Facility emissions are 0.454 TPY total all boilers.	

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

Boiler C
Lead - Total

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 1.6 E-04 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.114 lb/hour	0.067 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Biomass Firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 8.9 E-07 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0004 lb/hour	0.0007 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): No.2 fuel oil firing		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 64 E-05 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.031 lb/hour	0.047 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Coal Firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 4.2 E-05 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0143 lb/hour	0.053 tons/year
5. Method of Compliance (limit to 60 characters): Stack test using EPA Method 12 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): TDF firing		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)****Pollutant Detail Information:**

1. Pollutant Emitted: SAM		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	17.6 lb/hour	27.8 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
[] 1 [] 2 [] 3 _____ to _____ tons/yr		
6. Emission Factor:		0.036 lb/MMBtu
Reference: See Part B		
7. Emissions Method Code:		
[] 0 [] 1 [] 2 <input checked="" type="checkbox"/> 3 [] 4 [] 5		
8. Calculation of Emissions (limit to 600 characters):		
0.036 lb/MMBtu x 490 MMBtu/hr = 17.6 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
Based on coal firing, 34.6 TPY total for all boilers.		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.003 lb/MMBtu		
4. Equivalent Allowable Emissions:	22 lb/hour	1.9 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on biomass firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.0015 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.74 lb/hour	1.1 tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.01 lb/MMBtu		
4. Equivalent Allowable Emissions:	17.6 lb/hour	26.4 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.01 lb/MMBtu		
4. Equivalent Allowable Emissions:	3.4 lb/hour	8.7 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 8 once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on tire-derived fuel firing.		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**

Pollutant Detail Information:

1. Pollutant Emitted: FL		
2. Total Percent Efficiency of Control:		%
3. Potential Emissions:	11.8 lb/hour	17.6 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
5. Range of Estimated Fugitive/Other Emissions:		
<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr		
6. Emission Factor:		0.024 lb/MMBtu
Reference: See Part B		
7. Emissions Method Code:		
<input type="checkbox"/> 0 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5		
8. Calculation of Emissions (limit to 600 characters):		
0.024 lb/MMBtu x 490 MMBtu/hr = 11.8 lb/hr		
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters):		
Based on coal firing. Total emissions from all three boilers limited to 21.23 TPY.		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.3 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0031 lb/hour	0.0046 tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 0.024 lb/MMBtu		
4. Equivalent Allowable Emissions:	11.8 lb/hour	17.6 tons/year
5. Method of Compliance (limit to 60 characters): EPA Method 13A or 13B once every 5 years.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.5 E-04 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.22 lb/hour	0.82 tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)**Pollutant Detail Information:**

1. Pollutant Emitted: H114	
2. Total Percent Efficiency of Control:	%
3. Potential Emissions:	0.0041 lb/hour 0.0173 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor: See Part B Reference: See Part B	
7. Emissions Method Code: <input checked="" type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): Annual TPY limited by permit condition.	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Total emissions all three boilers cannot exceed 0.030 TPY.	

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 4 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0029 lb/hour	0.0152 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on wood waste firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 5.43 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0045 lb/hour	0.0152 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on bagasse firing. Limit subject to revision based on stack testing.		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 24 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0012 lb/hour	0.0018 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 oil firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 8.4 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0041 lb/hour	0.0062 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing. Limit subject to revision based on stack testing.		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 6.5 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0022 lb/hour	0.0082 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 101A.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

**H. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units Only - Emissions Limited Pollutants Only)****Pollutant Detail Information:**

1. Pollutant Emitted: H021	
2. Total Percent Efficiency of Control:	99 %
3. Potential Emissions:	0.0029 lb/hour 0.0043 tons/year
4. Synthetically Limited? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
5. Range of Estimated Fugitive/Other Emissions: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 _____ to _____ tons/yr	
6. Emission Factor: Reference: See Part B	
7. Emissions Method Code: <input checked="" type="checkbox"/> 0 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5	
8. Calculation of Emissions (limit to 600 characters): 490 MMBtu/hr x 5.9 E-06 lb/MMBtu = 0.0029 lb/hr	
9. Pollutant Potential/Estimated Emissions Comment (limit to 200 characters): Max lb/hr based on coal firing. Total emissions all three boilers limited to 0.0052 TPY.	

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 5.9 E-06 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0029 lb/hour	0.0043 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on coal firing.		

B.

1. Basis for Allowable Emissions Code: OTHER		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 3.5 E-07 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0002 lb/hour	0.0003 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on No.2 fuel oil firing.		

Emissions Unit Information Section 3 of 3
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 4.5 E-07 lb/MMBtu		
4. Equivalent Allowable Emissions:	0.0002 lb/hour	0.0006 tons/year
5. Method of Compliance (limit to 60 characters): Stack testing using EPA Method 104.		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Based on TDF firing.		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

**I. VISIBLE EMISSIONS INFORMATION
(Regulated Emissions Units Only)**

Visible Emissions Limitations: Visible Emissions Limitation 1 of 1

1.	Visible Emissions Subtype: VE20
2.	Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: 20 % Exceptional Conditions: 27 % Maximum Period of Excess Opacity Allowed: 6 min/hour
4.	Method of Compliance: EPA Method 9
5.	Visible Emissions Comment (limit to 200 characters):

Visible Emissions Limitations: Visible Emissions Limitation _____ of _____

1.	Visible Emissions Subtype:
2.	Basis for Allowable Opacity: <input type="checkbox"/> Rule <input type="checkbox"/> Other
3.	Requested Allowable Opacity Normal Conditions: _____ % Exceptional Conditions: _____ % Maximum Period of Excess Opacity Allowed: _____ min/hour
4.	Method of Compliance:
5.	Visible Emissions Comment (limit to 200 characters):

J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)

Continuous Monitoring System Continuous Monitor 1 of 5

1. Parameter Code: VE	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Durag Model Number: D-R281AV Serial Number: 31018	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor 2 of 5

1. Parameter Code: NOx	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 42D Serial Number: 42D-51031-292	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

**J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)**

Continuous Monitoring System Continuous Monitor 3 of 5

1. Parameter Code: SO2	2. Pollutant(s):
3. CMS Requirement: [] Rule [<input checked="" type="checkbox"/>] Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 43B Serial Number: 43B-48524-292	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor 4 of 5

1. Parameter Code: CO	2. Pollutant(s):
3. CMS Requirement: [] Rule [<input checked="" type="checkbox"/>] Other	
4. Monitor Information: Monitor Manufacturer: Thermo Environmental Instruments Model Number: 48 Serial Number: 48-52605-292	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters):	

**J. CONTINUOUS MONITOR INFORMATION
(Regulated Emissions Units Only)**

Continuous Monitoring System Continuous Monitor 5 of 5

1. Parameter Code: O2	2. Pollutant(s):
3. CMS Requirement: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Yokogawa Model Number: ZA8C Serial Number: JJ113PA135	
5. Installation Date: 01 Oct 1995	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters): 40 CFR 60, Subpart Da	

Continuous Monitoring System Continuous Monitor _____ of _____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement: <input type="checkbox"/> Rule <input type="checkbox"/> Other	
4. Monitor Information: Monitor Manufacturer: Model Number: Serial Number:	
5. Installation Date:	
6. Performance Specification Test Date:	
7. Continuous Monitor Comment (limit to 200 characters):	

**K. PREVENTION OF SIGNIFICANT DETERIORATION (PSD) INCREMENT
TRACKING INFORMATION
(Regulated and Unregulated Emissions Units)**

PSD Increment Consumption Determination

1. Increment Consuming for Particulate Matter or Sulfur Dioxide?

If the emissions unit addressed in this section emits particulate matter or sulfur dioxide, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for particulate matter or sulfur dioxide. Check the first statement, if any, that applies and skip remaining statements.

-] The emissions unit is undergoing PSD review as part of this application, or has undergone PSD review previously, for particulate matter or sulfur dioxide. If so, emissions unit consumes increment.
-] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after January 6, 1975. If so, baseline emissions are zero, and the emissions unit consumes increment.
-] The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after January 6, 1975, but before December 27, 1977. If so, baseline emissions are zero, and the emissions unit consumes increment.
-] For any facility, the emissions unit began (or will begin) initial operation after December 27, 1977. If so, baseline emissions are zero, and emissions unit consumes increment.
-] None of the above apply. If so, the baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

2. Increment Consuming for Nitrogen Dioxide?

If the emissions unit addressed in this section emits nitrogen oxides, answer the following series of questions to make a preliminary determination as to whether or not the emissions unit consumes PSD increment for nitrogen dioxide. Check first statement, if any, that applies and skip remaining statements.

-] The emissions unit addressed in this section is undergoing PSD review as part of this application, or has undergone PSD review previously, for nitrogen dioxide. If so, emissions unit consumes increment.
-] The facility addressed in this application is classified as an EPA major source pursuant to paragraph (c) of the definition of "major source of air pollution" in Chapter 62-213, F.A.C., and the emissions unit addressed in this section commenced (or will commence) construction after February 8, 1988. If so, baseline emissions are zero, and the source consumes increment.
-] The facility addressed in this application is classified as an EPA major source and the emissions unit began initial operation after February 8, 1988, but before March 28, 1988. If so, baseline emissions are zero, and the source consumes increment.
-] For any facility, the emissions unit began (or will begin) initial operation after March 28, 1988. If so, baseline emissions are zero, and the emissions unit consumes increment.
-] None of the above apply. If so, baseline emissions of the emissions unit are nonzero. In such case, additional analysis, beyond the scope of this application, is needed to determine whether changes in emissions have occurred (or will occur) after the baseline date that may consume or expand increment.

3.	Increment Consuming/Expanding Code:		
PM	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E	<input type="checkbox"/>] Unknown
SO ₂	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E	<input type="checkbox"/>] Unknown
NO ₂	<input checked="" type="checkbox"/>] C	<input type="checkbox"/>] E	<input type="checkbox"/>] Unknown
4.	Baseline Emissions:		
PM	0 lb/hour	0	tons/year
SO ₂	0 lb/hour	0	tons/year
NO ₂		0	tons/year
5.	PSD Comment (limit to 200 characters):		

**L. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**

Supplemental Requirements for All Applications

1.	Process Flow Diagram	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
2.	Fuel Analysis or Specification	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
3.	Detailed Description of Control Equipment	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Waiver Requested
		<input type="checkbox"/> Not Applicable	
4.	Description of Stack Sampling Facilities	<input type="checkbox"/> Attached, Document ID: _____	<input type="checkbox"/> Waiver Requested
		<input checked="" type="checkbox"/> Not Applicable	
5.	Compliance Test Report	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
		<input type="checkbox"/> Previously Submitted, Date: _____	
6.	Procedures for Startup and Shutdown	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
7.	Operation and Maintenance Plan	<input type="checkbox"/> Attached, Document ID: _____	<input checked="" type="checkbox"/> Not Applicable
8.	Supplemental Information for Construction Permit Application	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Not Applicable
9.	Other Information Required by Rule or Statute	<input checked="" type="checkbox"/> Attached, Document ID: <u>PART B</u>	<input type="checkbox"/> Not Applicable

Additional Supplemental Requirements for Category I Applications Only

10. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Acid Rain Permit Application (Hard Copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

PART B
SUPPLEMENTAL INFORMATION FOR PERMIT APPLICATION
OKEELANTA POWER LIMITED PARTNERSHIP

1.0 INTRODUCTION

Okeelanta Power Limited Partnership (OkPLP) was issued a prevention of significant deterioration (PSD) permit in 1993 for construction of a 74.9 megawatt electric (MWe) cogeneration facility (Permit No. AC50-219413; PSD-FL-196). The cogeneration facility is located at the site of the existing Okeelanta Corporation sugar mill, south of South Bay, Florida. The facility was designed to combust primarily biomass (bagasse and wood waste materials) in three steam boilers to generate steam and electricity. The facility was also designed to supply the adjacent sugar mill with process steam during the sugar cane grinding season, approximately November through March.

Construction was completed on the facility in 1995, and initial operations began in late 1995. Due to technical and operational difficulties and periods of facility shutdown, the facility was operated at less than design capacity during 1996. Almost all fuel burned in the facility boilers has been wood waste and No. 2 fuel oil. Only a small amount of bagasse has been combusted.

To date, the cogeneration facility has been unable to successfully connect to the sugar mill. Once the facility successfully connects to the sugar mill, the existing sugar mill boilers will be shutdown and will only operate when one or more of the cogeneration units are shutdown. The existing boilers will be permanently shutdown and rendered incapable of operation no later than January 1, 1999.

The cogeneration facility will provide enough steam energy to generate electricity and to meet the needs of the Okeelanta sugar mill. Excess electricity will be sold to Florida Power & Light Company (FPL). Further, the facility will reduce overall air emissions and water consumption compared to the existing sugar mill facility while generating approximately 18 times more electric energy than the existing facility.

The state construction permit (AC50-219413) and federal PSD permit (PSD-FL-196) were issued to Okeelanta Power on September 27, 1993. In 1996, OkPLP submitted an application to burn tire-derived fuel (TDF) as a supplemental fuel to biomass. This application is currently being held in abeyance pending the results of a TDF trial burn at the facility.

Initial compliance testing was performed at OkPLP during May and December of 1996.

According to the air construction permit, Specific Condition No. 22, compliance tests are to be conducted every 6 months for a period of 2 years in order to confirm the emission limits for certain pollutants in the permit. Based on the results of these tests, emission limits can be revised

as long as a fuel management plan is submitted to demonstrate that annual emission limits (in tons per year) for the facility will not be exceeded.

Test data gathered from the facility to date, which include the compliance test data as well as data from the continuous emission monitoring system (CEMS), indicates that the emission limits for sulfur dioxide (SO₂), lead (Pb), and mercury (Hg) need to be revised. In addition, it is requested that the averaging time associated with the emission limit for carbon monoxide (CO) be increased.

The requested changes in the permit limits will not increase total permitted annual emissions to the atmosphere of any PSD regulated pollutants, except for a small increase in the annual emissions of Pb. The changes do not require PSD or nonattainment new source review.

This report presents a description of the proposed emission limit changes, and the rational and supporting information for such changes. A complete description of the requested changes, including air emission rates, is presented in Section 2.0. The air quality review requirements for the project and new source review applicability are discussed in Section 3.0. An updated air modeling analysis for air toxics is presented in Section 4.0. Supportive information is contained in the appendices.

2.0 PROJECT DESCRIPTION

2.1 GENERAL

OkPLP was issued a state construction permit (AC50-219413) and federal PSD permit (PSD-FL-196) on September 27, 1993, for the construction of a 74.9 MWe (gross) capacity biomass/coal-fired cogeneration facility. Each boiler is capable of producing up to an average of 455,418 lbs/hr steam. During the sugar processing season, the cogeneration facility is to provide steam to the existing Okeelanta sugar mill by burning primarily bagasse, which is the residual cellulose fiber resulting from the sugar cane grinding process, while also generating electricity. During the off-season, the cogeneration facility will burn primarily wood waste to generate electricity.

The construction permit limits the maximum heat input to each of the three boilers to 715 million British thermal units per hour (MMBtu/hr) when firing biomass, and 490 MMBtu/hr when firing fossil fuels (No. 2 fuel oil or low sulfur coal). Maximum annual heat input to the entire facility is limited to 11.5×10^{12} Btu/yr, and maximum coal burning is limited to 73,714 tons per year (TPY), which is approximately 16 percent of the total annual heat input.

In addition to the currently permitted fuels, it has been proposed by OkPLP (in June 1996) to permit TDF as a supplemental fuel to be used primarily in the off-season when bagasse is not available. TDF may also be burned during the crop season in order to extend the bagasse supply. TDF will be fired in combination with biomass. The proposed maximum TDF input was 25 percent on a weight basis (22,000 lb/hr or 11.0 TPH, maximum) on a short-term basis, and not exceeding 9.1 percent (weight basis) on a facility-wide annual average basis (81,600 TPY total TDF).

The changes to the facility operating and emission limits now being proposed by OkPLP consist of the following:

1. Adjustment of the SO₂, Pb, and Hg emission limits for wood waste fuel, *up up*
2. Adjustment of the Hg emission limit for bagasse burning, *(down)*
3. Adjustment in the expected mix of bagasse and wood waste fuels, *10% 20%*
4. Adjustment of the averaging time associated with the facility CO emission limits, and *24.00*
5. Slight adjustment of annual coal and TDF firing rates to not exceed facility emission caps.

The three new boilers are subject to the federal new source performance standards (NSPS) for electric utility boilers (40 CFR 60, Subpart Da). The boilers are also subject to a reporting and recordkeeping requirement under the NSPS for municipal waste combustors (MWCs) (40 CFR 60, Subparts Ea and Cb). The boilers are subject to these requirements because they will potentially burn woodwaste and TDF originating from residential, commercial and/or institutional sources. Such fuels are defined as municipal solid waste (MSW) under the NSPS. However, because OkPLP has accepted a limit restricting the amount of MSW burned in each boiler to less than 30 percent (by weight) on a calendar quarter basis (permit amendment issued February 20, 1996), the boilers will be exempt from the Subpart Ea and Cb standards, and only subject to recordkeeping and reporting requirements.

Air pollution control equipment serving each boiler consists of an electrostatic precipitator (ESP) to control particulate matter (PM) and heavy metal emissions, a selective non-catalytic reduction (SNCR) system for the control of NO_x emissions, and a carbon injection system for mercury control.

A regional map showing the location of the site is presented in Figure 2-1. A location map showing the existing sugar mill, cogeneration site, and plant property boundaries is presented in Figure 2-2.

2.2 COGENERATION FACILITY DESIGN INFORMATION

Updated design and operating information concerning the cogeneration facility was presented in the application for TDF submitted in May, 1996. Most of this information has not changed; where there are changes, the information is presented in the following sections. A simplified process flow diagram of the cogeneration facility is presented in Figure 2-3.

2.2.1 FUELS

OkPLP is planning on burning 100 percent biomass fuels. It is planned that the bagasse from the sugar grinding operation will provide approximately two-thirds of the annual fuel requirements of the facility. The remaining fuel requirements will be provided by wood waste materials, which could include clean construction and demolition wood debris, yard trimmings, land clearing debris, and other clean cellulose and vegetative matter. However, because wood waste materials are not commodity fuels and the supply of wood waste may fluctuate, it is necessary to have the

ability to burn limited amounts of fossil fuel and TDF in the event that the supply of biomass fuel is not adequate. Therefore, each combustion unit has the capability to burn biomass, biomass/TDF, very low sulfur fuel oil, and coal.

Fuel specifications for each fuel that may be utilized by the cogeneration facility are presented in Table 2-1. Based on these fuel specifications, maximum hourly firing rates are shown in Table 2-2 for each fuel when fired alone. The maximum heat input to each boiler due to biomass fuels will be 715 MMBtu/hr. Due to limitations of the fuel oil firing system, maximum heat input of No. 2 fuel oil will be limited to 490 MMBtu/hr. Maximum heat input due to coal will be 490 MMBtu/hr. Biomass and fossil fuels may also be burned in combination, not to exceed a total heat input of 715 MMBtu/hr per boiler. These maximum heat input rates are the same as the current permitted rates.

TDF will always be burned in combination with biomass. Maximum TDF input for each boiler will not exceed 25 percent on a weight basis (approximately 48 percent on a heat input basis), up to a maximum of 22,000 lb/hr (11.0 TPH and 340 MMBtu/hr). Biomass and TDF, burned in combination, will not exceed a total heat input of 715 MMBtu/hr.

On an annual basis, the total heat input to all three boilers will not exceed 11.50×10^{12} Btu/yr. Burning of No. 2 fuel oil will be limited to a total of 24.9 percent of the total annual heat input. Coal burning will be limited to 15.1 percent annually on a heat input basis, or to 69,720 TPY. Total fossil fuel burning will also be limited to 24.9 percent on a calendar quarter basis. TDF burning will be limited to 21.9 percent annually on a facility-wide basis (heat input basis), or to 81,246 TPY.

Four cases are shown in Table 2-2 to document the anticipated scenario of firing 100 percent biomass fuel and the potential cases of firing the maximum amount of fuel oil, coal, or TDF, with the remaining heat input due to biomass. When only biomass is fired, the annual heat input requirement is 11.5×10^{12} Btu/yr for the entire facility (total all three boilers). On an annual basis, it is expected that bagasse will provide 60 percent of the biomass heat input, with wood waste providing 40 percent.

$1.6 \times 10^{-4} \frac{\text{# of}}{\text{mmBtu}} \times 715 \frac{\text{mmBtu}}{\text{hr}} = 0.1144 \frac{\text{#}}{\text{hr}}$
 $0.1144 \times 4.38 \times 0.501 = 0.249$
 $1.6 \times 10^{-4} \times 11.5 \times 10^{12} \text{ mmBtu} = 1.84 \times 10^9$
 $= 0.927 \times 10^9$

Under the worst-case fuel oil burning case of firing No. 2 fuel oil at 24.9 percent of the total annual heat input, the annual heat input requirement for the entire facility becomes 10.83×10^{12} Btu/yr, due to the different heat transfer efficiency for No. 2 fuel oil versus biomass. Similarly, under the worst-case coal firing scenario of firing coal at 15.1 percent of the total annual heat input, the annual heat input requirement for the entire facility becomes 11.08×10^{12} Btu/yr. Under the worst-case TDF firing scenario of 21.9 percent of the total annual heat input (9.0 percent on a weight basis), the annual heat input requirement for the entire facility is 11.50×10^{12} Btu/yr.

2.2.3 FACILITY PLOT PLAN

A plot plan of the OkPLP cogeneration facility is presented in Figure 2-4. The major structure at the site is the boiler building. This building has a height of approximately 121 feet above ground.

2.2.4 CONTROL EQUIPMENT INFORMATION

The cogeneration facility will utilize several emission control techniques to reduce emissions. A selective non-catalytic reduction (SNCR) system will be used to reduce NO_x emissions. SNCR is a system which injects urea into the boiler to reduce NO_x emissions. Further, the cogeneration boilers will minimize CO and VOC through proper furnace design and good combustion practices, including: control of combustion air and combustion temperature; distribution of fuel on the combustion grate; and better controls over the furnace loads and transient conditions. Particulate emissions will be controlled by an ESP. Mercury emissions will be controlled through a carbon injection system and the ESP system.

Mercury Control System

The mercury control system is supplied by ABB Environmental Systems and Chemco, Inc. A volumetric feeder with integral supply hopper meters activated carbon for injection at a point in the ductwork between the furnace and the ESP. This promotes turbulent mixing and provide adequate residence time. A blower system transports the carbon to the injection point. The ESP will effectively capture the activated carbon particles along with the boiler fly ash (which also contains some carbon). The system is designed to inject up to 32 lb/hr of carbon into the flue gases of each boiler.

2.2.5 STACK PARAMETERS

Stack parameters for the cogeneration facility are presented in Table 2-3. The parameters reflect actual operating data based on the compliance testing. Each of the three boilers are served by a separate stack. The top of each stack is 225 feet (ft) above ground. Each stack is 10.0 ft in diameter. The locations of the three stacks are shown in Figure 2-4.

2.3 REVISIONS TO PERMITTED BOILER EMISSION LIMITS

2.3.1 LIMITS FOR CRITERIA/DESIGNATED POLLUTANTS

The emission limits for all criteria/designated pollutants emitted by the OkPLP boilers are presented in Table 2-4. The emission limits in terms of lb/MMBtu are the same as currently permitted, except in the case of SO₂, Pb and Hg emissions due to wood waste firing. These revisions are being requested due to higher than expected levels of sulfur, lead and mercury in the wood waste fuel. The basis for these permit revisions are described below. A change in the averaging time associated with the CO emission limit for all fuels is also requested. 8 → 24 hr

2.3.1.1 Sulfur Dioxide

The current permit limits for SO₂ emissions for biomass fuel are 0.1 lb/MMBtu for a 24-hour average, and 0.02 lb/MMBtu as a 30-day rolling average. Thus, the limits for bagasse and wood waste are the same. At the time of the original permit application, very little information was available regarding the sulfur content of wood wastes. Based on limited data from the Okeelanta sugar mill, it was concluded that the sulfur contents of the two fuels were similar. The limits were based on sulfur contents of 0.045% (max) and 0.009% (avg.), wet basis. Although inherent SO₂ removal in the boiler system due to the alkaline nature of wood and bagasse ash was expected, no removal was considered in calculating the equivalent SO₂ emissions.

Based on analysis of the wood waste OkPLP is receiving, the sulfur content of the wood waste is higher than anticipated. OkPLP obtains fuel analysis data on the wood waste delivered to the facility. The data show a wide range of sulfur contents, depending on the source and/or supplier of the wood waste. Data from different suppliers are summarized in Table 2-5. As shown, the average sulfur content of wood waste from specific suppliers can range from 0.02% to 0.17% sulfur (dry basis), equivalent to 0.05 to 0.44 lb/MMBtu SO₂ emissions. However, the overall average of all deliveries cannot be estimated because the frequency of deliveries and quantity of wood waste delivered varies considerably for each supplier.

0.05# / MMBtu / M₂ - MMBtu

Data obtained to date from OkPLP's and OsPLP's compliance test data shows that SO₂ emissions due to wood waste firing are in the range of 0.02 to 0.08 lb/MMBtu, and average 0.05 lb/MMBtu (see Table 2-6). CEMS data for SO₂ from January-March 1997 are summarized in Table 2-7. These data indicate that significant SO₂ removal is indeed occurring in the boiler system. Although significant SO₂ capture in the alkaline fly ash is indicated, the current annual average SO₂ emission limit of 0.02 lb/MMBtu may not be achievable for wood waste. Based on the compliance testing and CEMS results, an annual average SO₂ emission limit of 0.05 lb/MMBtu is proposed for wood waste. The current limit of 0.02 lb/MMBtu for bagasse is being retained at this time. This limit, however, may be subject to revision based upon further testing with bagasse.

2.3.1.2 CARBON MONOXIDE

The current limit for CO emissions from biomass burning is 0.35 lb/MMBtu based on an 8-hour averaging time. This limit was based on the boiler manufacturer's design. CO emissions data obtained to date from OkPLP's and OsPLP's compliance testing are presented in Table 2-6. These data indicate that the emission limit has been achieved during the compliance tests. However, data from OkPLP's CEMS for CO indicates that CO emissions due to wood waste firing can exceed the emission limit based on an 8-hour averaging time. During January - April 1997, the boilers at OkPLP experienced several excursions of the emission limit, with 8-hour CO averages up to 0.7 lb/MMBtu. Most of these excursions were attributed to unusually wet wood waste or bagasse fuel. Wood waste fuel is by nature high in moisture (30-50%). Abnormally wet biomass fuel is usually due to a heavy rain event which causes the fuel to become wetter than normal.

0.7 lb/MMBtu - 8hr
0.35 lb/MMBtu - 24hr

Based on review of the CEMS data, OkPLP believes that the current CO limit is achievable if it is based on a 24-hour averaging time basis. The longer averaging time will allow fluctuations in fuel quality (and therefore CO emissions) to occur on a short-term basis, but will not increase daily or annual CO emissions. Thus, it is requested that the averaging time for the CO emissions limit be revised to reflect a 24-hour averaging time. In order to be consistent, it is requested that the averaging time for the CO limits for No. 2 fuel oil, coal, and TDF also be specified as a 24-hour basis.

2.3.1.3 LEAD

The **current emission** limit for Pb for biomass fuel is 2.5×10^{-5} lb/MMBtu. The limits for bagasse and wood waste are the same. At the time of the original permit application, very little information was available regarding the lead content of wood wastes or emissions of lead from wood-fired boilers. The emission limit of 2.5×10^{-5} lb/MMBtu was based on the average emissions from three wood-fired boilers controlled by an ESP, as reported by Sassenrath (1991).

OkPLP has conducted analysis of wood wastes for Pb content. The results of these analysis are presented in Table 2-8. As shown, the Pb content of the wood waste has ranged between 0.5 and 350 ppm. The high value of 350 ppm appears to be an outlier, as the next highest value is only 37.8 ppm. Excluding the high value, the average Pb content is 7.9 ppm. This is equivalent to uncontrolled Pb emissions of 1.0×10^{-3} lb/MMBtu, assuming 8,000 Btu/lb (dry) for wood waste.

Data obtained to date from OkPLP's and OsPLP's compliance test data shows that Pb emissions due to wood waste firing are in the range of 1.23×10^{-5} to 13.6×10^{-5} lb/MMBtu, with an average of 5.25×10^{-5} lb/MMBtu (see Table 2-6). Compared to the Pb levels measured in the wood waste fuel, these data indicate that significant Pb removal is occurring in the ESP system. Based on the average Pb levels in the fuel, the average Pb removal efficiency is calculated to be 97 percent.

Although significant Pb capture in the ESP system is indicated, the current Pb emission limit of 2.5×10^{-5} lb/MMBtu may not be achievable for wood waste. Based on the compliance testing results, an emission limit of 1.6×10^{-4} lb/MMBtu is proposed for wood waste. This value represents the upper 95% confidence level of the compliance test data (i.e., there is 95% confidence that this value will not be exceeded during a compliance test; refer to Table 2-6).

The current 2.5×10^{-5} lb/MMBtu limit for bagasse is being retained at this time. This limit, however, may be subject to revision based upon further testing with bagasse.

95% higher + 1.6e-4 max 1.36e-4

bagasse stay same

2.3.1.4 MERCURY

The current emission limit for Hg for bagasse fuel is 6.3×10^{-6} lb/MMBtu, and for wood waste, is 0.29×10^{-6} lb/MMBtu. Thus, the limits for bagasse and wood waste are different. At the time of the original permit application, very little information was available regarding the Hg content of wood wastes or emissions of Hg from wood-fired boilers. The original emission limit of 0.29×10^{-6} lb/MMBtu for wood waste was based on the average emissions from three wood fired

boilers controlled by an ESP, as reported by Sassenrath (1991). A control efficiency of 30% was then applied to this emission rate based on the use of a carbon injection system for Hg control.

OkPLP has conducted analysis of wood wastes for Hg content, and these analysis are presented in Table 2-8. As shown, the Hg content of the wood waste has ranged between 0.025 and 1.00 ppm, with an average of 0.095 ppm. This average is equivalent to uncontrolled emissions of Hg of 1.2×10^{-5} lb/MMBtu, assuming 8,000 Btu/lb (dry) for wood waste.

Data obtained to date from OkPLP's and OsPLP's compliance test data, presented in Table 2-9, shows that Hg emissions due to wood waste firing are in the range of 0.95×10^{-6} to 3.23×10^{-6} lb/MMBtu, with an average of 1.90×10^{-6} lb/MMBtu. Compared to the Hg levels measured in the wood waste fuel, these data indicate that significant Hg removal is occurring in the ESP system. Based on the average Hg levels in the fuel, the average Hg removal efficiency is calculated to be 84%.

OkPLP has conducted several Hg emission tests for the purposing of better quantifying Hg emissions, as well as the effectiveness of the Hg removal system (carbon injection system). The results of these tests are shown in Table 2-10. As shown, three tests were conducted at each of three carbon injection rates. The amount of fuel burned and the Hg content of the fuel were utilized to calculate the Hg input to the boiler. The stack tests results were then used to calculate the amount of Hg emitted to the atmosphere. This calculation shows that the Hg removal efficiency of the system ranged from 17% to 93%, with an average of 69%. This removal efficiency is well above the 30% removal which formed the basis of the original air permit for the OkPLP facility. The test data also show that the level of Hg emissions or calculated removal efficiency does not appear to be related to the amount of carbon injection.

Although significant Hg capture in the ESP system is indicated, the current Hg emission limit of 0.29×10^{-6} lb/MMBtu for wood waste appears to be too low. Based on the compliance testing results, an emission limit of 4.0×10^{-6} lb/MMBtu is proposed for wood waste. This limit represents a value somewhat greater than the highest measured Hg emission rate of 3.23×10^{-6} lb/MMBtu (refer to Table 2-9).

The current Hg limit of 6.3×10^{-6} lb/MMBtu limit for bagasse is being lowered slightly at this time (to 5.43×10^{-6} lb/MMBtu) in order to maintain total annual Hg emissions from the facility at 0.0300 TPY. This limit, however, may be subject to revision based upon further testing with bagasse.

2.4 EMISSION RATES FOR REGULATED POLLUTANTS

Maximum hourly emissions from each of the OkPLP boilers for each fuel are presented in Table 2-11. This table reflects the proposed SO₂, CO, Pb and Hg emission limits for wood waste firing. Since TDF will always be burned in combination with biomass, with up to 25 percent TDF on a weight basis, emission rates are also presented for 25 percent TDF/75 percent biomass firing (weight basis). As shown, the maximum hourly emissions occur when burning either biomass, biomass/TDF, or coal. The maximum hourly emissions are the same as currently permitted emissions, except in the case of Pb.

The total annual emissions from all three boilers for each fuel scenario, including the proposed TDF firing, are presented in Table 2-12. These are based upon the same emission factors as presented in Table 2-4, including the revised limits for SO₂, Pb and Hg. The total maximum annual emission rate for each pollutant is based upon the worst-case fuel operating scenario and is identified in the far right column of Table 2-12. The maximum annual emissions for all of the criteria/designated pollutants are the same as currently permitted, except for the case of Pb. For Pb, annual emissions are slightly higher than currently permitted. As described in the TDF application, although maximum annual emissions of beryllium, fluorides, and sulfuric acid mist are all lower than permitted due to the reduction in coal firing to 15.1 percent coal burning in any one year, it is requested that the current permit limits be retained to allow flexibility in fuel mix in the future.

Maximum annual emissions per boiler for the OkPLP facility are presented in Attachment A.

2.7 COMPLIANCE DEMONSTRATION

OkPLP will continue to demonstrate compliance with the maximum heat input limits for the facility by monitoring fuel input rates and fuel characteristics on a periodic basis. Steam production parameters (i.e., steam quantity, pressure, and temperature) and feedwater parameters will be continuously monitored to allow calculation of heat input by use of an assumed heat

transfer efficiency for each fuel. In addition, per the zoning conditions recommended by Palm Beach County and agreed to by OkPLP, stack testing will be performed for PM, NO_x, CO, SO₂, lead, mercury, and VOC every 6 months during the first 2 years of operation. If these tests show compliance with the permitted emission limits, the stack testing frequency will be reduced to that typically required by FDEP (i.e., once every year or once every 5 years, depending upon pollutant). Based on these tests, additional revisions of permit limitations may be required. Any such revisions will be submitted to the Department for approval.

Table 2-1. Design Fuel Specifications^a for the OkPLP Facility

Parameter	Biomass		No. 2 Fuel Oil	Bituminous Coal	Tire-Derived Fuel
	Bagasse	Wood Waste			
Specific Gravity	—	—	0.865	—	—
Heating Value (Btu/lb)	4,250	5,500	19,175	12,000	15,500
Heating Value (Btu/gal)	—	—	138,000	—	—
Ultimate Analysis (dry basis percentage):					
Carbon	48.93	49.58	87.01	82.96	84.4
Hydrogen	6.14	5.87	12.47	5.41	7.1
Nitrogen	0.25	0.40	0.02	1.58	0.24
Oxygen	43.84	40.90	0.00	5.72	2.18
Sulfur	0.02 - 0.10	0.02 - 0.17	0.50	0.67	1.23
Ash/Inorganic	0.83	3.24	0.00	3.66	4.9
Moisture	52	37	—	4.5	0.6

^a Represents average fuel characteristics.

Sources: Okeelanta Corp., 1992.
Combustion Engineering, 1981.
Waste Recovery, Inc., 1986.
Okeelanta Power Limited Partnership, 1997.

100
-37

63

63 # Wood 15 0.17% S
(dry)
100 # Wood 15
(WET)

$\frac{(63)(.17)}{100} = .1071$

Potential SO₂ #/MMBtu = $\frac{0.1071 \text{ #S}}{100 \text{ # Wood}} \times \frac{\text{# Wood}}{5,500 \text{ Btu}} \times \frac{2 \text{ # SO}_2}{\text{#S}} \times 100$

$= 0.389 \text{ # SO}_2 / \text{MMBtu}$

Table 2-2. Maximum Fuel Usage and Heat Input Rates, Okeelanta Power Limited Partnership

Fuel	Heat Input	Heat Transfer Efficiency (%)	Heat Output	Fuel Firing Rate
<u>Maximum Short-Term (per boiler)</u>				
Biomass: Bagasse	715 MMBtu/hr	68	486 MMBtu/hr	168,235 lb/hr ^a
Wood Waste	715 MMBtu/hr	68	486 MMBtu/hr	130,000 lb/hr ^b
No. 2 Oil	490 MMBtu/hr	85	417 MMBtu/hr	3,551 gal/hr
Coal	490 MMBtu/hr	85	417 MMBtu/hr	40,833 lb/hr
Tire-Derived Fuel	340 MMBtu/hr	68	231 MMBtu/hr	21,935 lb/hr
<u>Annual Average (total all three boilers)</u>				
NORMAL OPERATIONS				
Biomass	1.150E+13 Btu/yr	68	7.820E+12 Btu/yr	1,352,941 TPY ^a
No. 2 Oil	0 Btu/yr	85	0 Btu/yr	0 gal/yr
Coal	0 Btu/yr	85	0 Btu/yr	0 TPY
Tire-Derived Fuel	0 Btu/yr	68	0 Btu/yr	0 TPY
TOTAL	1.150E+13 Btu/yr		7.820E+12 Btu/yr	
24.9% OIL FIRING				
Biomass	8.130E+12 Btu/yr	68	5.528E+12 Btu/yr	956,471 TPY
No. 2 Oil	2.696E+12 Btu/yr	85	2.291E+12 Btu/yr	19,533,086 gal/yr
Coal	0 Btu/yr	85	0 Btu/yr	0 TPY
Tire-Derived Fuel	0 Btu/yr	68	0 Btu/yr	0 TPY
TOTAL	1.083E+13 Btu/yr		7.820E+12 Btu/yr	
15.1% COAL FIRING				
Biomass	9.408E+12 Btu/yr	68	6.397E+12 Btu/yr	1,106,824 TPY
No. 2 Oil	0 Btu/yr	85	0 Btu/yr	0 gal/yr
Coal	1.673E+12 Btu/yr	85	1.422E+12 Btu/yr	69,720 TPY
Tire-Derived Fuel	0 Btu/yr	68	0 Btu/yr	0 TPY
TOTAL	1.108E+13 Btu/yr		7.820E+12 Btu/yr	
21.9% TIRE-DERIVED FUEL FIRING (9.0% TDF, weight basis)				
Biomass	8.982E+12 Btu/yr	68	6.108E+12 Btu/yr	816,545 TPY ^b
No. 2 Oil	0 Btu/yr	85	0 Btu/yr	0 gal/yr
Coal	0 Btu/yr	85	0 Btu/yr	0 TPY
Tire-Derived Fuel	2.519E+12 Btu/yr	68	1.713E+12 Btu/yr	81,246 TPY
TOTAL	1.150E+13 Btu/yr		7.820E+12 Btu/yr	

Note: Total heat output required = 486 MMBtu/hr each boiler, and
7.820E+12 Btu/yr total all boilers.

Fuels may be burned in combination, not to exceed indicated total heat outputs.

^a Based on heating value for bagasse of 4,250 Btu/lb, wet basis.

^b Based on heating value for wood waste of 5,500 Btu/lb.

Handwritten notes:
Total heat = 11.5 x 10¹² Btu/yr
4.6 x 10¹² MMBtu/yr from wood
Amount wood = 4.6 x 10¹² / 5,500 = 836,364 TPY wood

TDF
↓

Table 2-3. Stack Parameters for the OKPLP Facility

	Boilers (each)				Boiler House Baghouse	Fly Ash Silo Filter	Carbon Silo Filter
	Biomass	Oil	Coal	TDF/Biomass			
Heat Input Rate (MMBtu/hr)	715	490	490	715	—	—	—
Stack Height (ft)	225	225	225	225	10	110	24
Stack Diam. (ft)	10.0	10.0	10.0	10.0	4.0 x 4.0	2.0 x 2.0	2.0 x 2.0
Gas Flowrate (acfm)	246,000 - 326,000	140,000 - 150,000	211,000 - 227,000	246,000 - 326,000	30,000	1,000	1,000
Gas Velocity (ft/s)	52.2 - 69.2	29.7 - 31.8	44.8 - 48.2	52.2 - 69.2	31.3	4.2	4.2
Gas Temperature (°F)	295 - 340	295 - 350	295 - 350	295 - 350	80	100	80

Note: acfm = actual cubic feet per minute.
 °F = degrees Fahrenheit.
 ft = feet.
 ft/s = feet per second.

may include proposed steel
Pb, Hg, Se, Co
[Commitment due to specific]
TDF

Table 2-4. Emission Limits for the OkPLP Facility

Pollutant	Emission Limit ^d (per boiler)								Total All Three Boilers ^e (TPY)	
	Biomass		No. 2 Oil		Bit. Coal		Tire-Derived Fuel			
	(lb/MMBtu)	(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/MMBtu)	(lb/hr)		
Particulate (TSP)	0.03 0.03	21.5	0.03	14.7	0.03	14.7	0.03	10.2	172.5	
Particulate (PM10)	0.03 0.03	21.5	0.03	14.7	0.03	14.7	0.03	10.2	172.5	
Sulfur Dioxide										
3-Hour Average	—	—	—	—	1.2	588.0	—	—	—	
24-Hour Average	0.10	71.5	0.05	24.5	1.2	588.0	1.2	408.0	—	
Annual Average										
Bagasse	0.02 ^{a,b}	—	—	—	1.2 ^a	—	0.8 ^a	—	1,154.3 ^f	
Woodwaste	0.05 ^c	—	—	—	—	—	—	—	—	
Nitrogen Oxides										
Annual Average	0.15 ^a	107.3 ^a	0.15 ^a	73.5 ^a	0.17 ^a	83.3 ^a	0.15 ^a	51.0 ^a	862.5	
Carbon Monoxide										
24-Hour Average	0.35	250.3	0.2	98.0	0.2	98.0	0.35	119.0	2,012.5	
VOCs	0.06	42.9	0.03	14.7	0.03	14.7	0.06	20.4	345.0	
Lead										
Bagasse	2.5 x 10 ^{-5b}	0.0179 ^b	8.9 x 10 ⁻⁷	0.00044	6.4 x 10 ⁻⁵	0.031	4.2 x 10 ⁻⁵	0.0143	0.454	
Wood Waste	1.6 x 10 ^{-4c}	0.1144 ^c	—	—	—	—	—	—	—	
Mercury										
Bagasse	5.43 x 10 ^{-6b}	0.0039 ^b	2.4 x 10 ⁻⁶	0.00118	8.4 x 10 ⁻⁶	0.0041	6.5 x 10 ⁻⁶	0.0022	0.0300	
Wood Waste	4.0 x 10 ^{-6c}	0.0029 ^c	—	—	—	—	—	—	—	
Beryllium	—	—	3.5 x 10 ⁻⁷	0.00017	5.9 x 10 ⁻⁶	0.0029	4.5 x 10 ⁻⁷	1.5 x 10 ⁻⁴	0.0052	
Fluorides	—	—	6.3 x 10 ⁻⁶	0.0031	0.024	11.8	6.5 x 10 ⁻⁴	0.22	21.2	
Sulfuric Acid Mist	0.003	2.15	0.0015	0.74	0.036	17.6	0.010	3.40	34.6	

^a Compliance based on 30-day rolling average, per 40 CFR 60, Subpart Da.

^b Emission limit for bagasse. Subject to revision after testing pursuant to Specific Conditions Nos. 24 and 25.

^c Emission limit for wood waste.

^d The emission limit shall be prorated when more than one type of fuel is burned in a boiler.

^e Limit heat input from No. 2 fuel to less than 25 percent of total heat input on a calendar quarter basis, coal to 69,720 tons and TDF to 81,246 TPY during any 12-month period, and the combination of oil and coal to less than 25 percent of the total heat input on a calendar quarter basis.

^f Compliance based on a 12-month rolling average.

2-14

Table 2-5. Sulfur Analysis of Wood Waste, OKPLP, January 1997

Supplier	Sulfur Content (%S, dry)	Heating Value (Btu/lb, dry)	Equilivent SO2 Emissions (lb/MMBtu)
Supplier A	0.07	7,531	0.186
Supplier B	0.06	8,283	0.145
Supplier C	0.08	7,471	0.214
Supplier D	0.08	7,320	0.219
Supplier E	0.07	7,130	0.196
Supplier F	0.08	7,486	0.214
Supplier G	0.04	8,405	0.095
Supplier H	0.05	8,447	0.118
Supplier I	0.11	8,074	0.272
Supplier J	0.05	8,557	0.117
Supplier K	0.07	7,752	0.181
Supplier L	0.02	8,591	0.047
Supplier M	0.06	8,214	0.146
Supplier N	0.15	8,338	0.360
Supplier O	0.05	8,349	0.120
Supplier P	0.13	8,542	0.304
Supplier Q	0.07	6,994	0.200
Supplier R	0.12	8,213	0.292
Supplier S	0.03	7,999	0.075
Supplier T	0.11	7,987	0.275
Supplier U	0.13	7,560	0.344
Supplier V	0.11	8,042	0.274
Supplier W	0.17	7,670	0.443
Minimum	0.02	6,994	0.047
Maximum	0.17	8,591	0.443

Check Calc
OK

$$\frac{\# \text{SO}_2}{\text{MMBtu}} = \frac{0.17 \# \text{S}}{100 \# \text{Wood}} \times \frac{2 \# \text{SO}_2}{\# \text{S}} \times \frac{\# \text{Wood}}{7,670 \text{ Btu}} \times 10^6 \frac{\text{Btu}}{\text{MMBtu}} = 0.443 \# / \text{MMBtu}$$

Table 2-6. Stack Test Data for OkPLP and OsPLP Cogeneration Units Burning Wood Waste - SO₂, CO, Pb

Boiler/Run	Sulfur Dioxide (SO ₂)				Carbon Monoxide (CO)				Lead (Pb)			
	Test Date	(ppmvd @ 7 % O ₂)	(lb/hr)	(lb/MMBtu)	Test Date	(ppmvd @ 7 % O ₂)	(lb/hr)	(lb/MMBtu)	Test Date	(mg/dscm @ 7 % O ₂)	(lb/hr)	(lb/MMBtu)
<u>Okeelanta Unit A</u>												
1	5/11/96	24.2	35.64	0.0514	5/10/96	268.5	166.38	0.249	5/10/96	0.0436	2.46E-02	3.48E-05
2	5/12/96	27.6	40.07	0.0586	5/10/96	181.4	118.89	0.168	5/11/96	0.0215	1.29E-02	1.71E-05
3	5/12/96	34.1	49.89	0.0723	5/10/96	168.7	110.59	0.157	5/11/96	0.0264	1.46E-02	2.10E-05
Average		28.6	41.87 ✓	0.0608		206.2	131.95 ✓	0.191		0.0305	1.74E-02	2.43E-05
4	5/29/96	29.2	44.97	0.0620	---	---	---	---	---	---	---	---
5	5/30/96	32.9	51.03	0.0700	---	---	---	---	---	---	---	---
6	5/30/96	30.9	50.60	0.0660	---	---	---	---	---	---	---	---
Average		29.6	44.87 ✓	0.0630		---	---	---		---	---	---
<u>Okeelanta Unit B</u>												
1	5/15/96	30.0	49.97	0.0691	5/14/96	198.5	138.33	0.183	5/15/96	0.0163 ?	9.13E-03	1.30E-05
2	5/16/96	36.8	63.92	0.0862	5/14/96	218.9	152.84	0.203	5/15/96	0.2505	8.75E-03	1.29E-05
3	5/16/96	37.5	59.41	0.0856	5/14/96	168.2	116.11	0.156	5/15/96	0.2159	7.57E-03	1.11E-05
Average		34.7	57.77 ✓	0.0803		195.2	135.76 ✓	0.181		0.1609	8.48E-03	1.23E-05
<u>Okeelanta Unit C</u>												
1	6/3/96	19.7	31.13	0.0470	5/22/96	172.9	112.37	0.181	5/22/96	0.0274	1.63E-02	2.46E-05
2	6/3/96	9.7	15.78	0.0240	5/22/96	194.6	129.74	0.203	5/23/96	0.0283	1.59E-02	2.54E-05
3	6/3/96	18.7	28.81	0.0447	5/22/96	214.1	139.00	0.224	5/23/96	0.0368	2.05E-02	3.30E-05
Average		16.1	25.24 ✓	0.039		193.8	127.04 ✓	0.203		0.0308	1.76E-02	2.77E-05
<u>Osceola Unit A</u>												
A-1	12/15/96	17.3	26.5	0.038	12/14/96	208.3	144.4	0.22	12/15/96	0.0780	4.77E-02	7.04E-05
A-2	12/15/96	14.4	21.5	0.032	12/14/96	171.0	104.4	0.18	12/15/96	0.0644	3.69E-02	5.82E-05
A-3	12/15/96	4.6	7.3 X	0.010	12/14/96	203.8	134.9 ✓	0.21	12/15/96	0.0635	3.60E-02	5.74E-05
Average		12.1	18.4 X	0.027		194.4	127.9	0.20		0.0686	4.02E-02	6.20E-05
<u>Osceola Unit B</u>												
B-1	12/18/96	4.1	6.4 X	0.009	12/18/96	100.7	70.0	0.11	12/17/96	0.116	6.93E-02	1.05E-04
B-2	12/18/96	23.1	36.9 ?	0.056	12/18/96	152.4	103.3 ✓	0.16	12/18/96	0.132	7.72E-02	1.22E-04
B-3	12/18/96	1.6	2.4 X	0.004	12/18/96	131.4	89.6	0.14	12/18/96	0.197	1.23E-01	1.81E-04
Average		9.6	15.2	0.023		128.1	87.6	0.14		0.148	8.98E-02	1.36E-04
Compliance Test Minimum		9.6	15.2	0.023		128.1	87.6	0.14		0.031	8.48E-03	1.23E-05
Compliance Test Average		21.8	33.9	0.049		183.5	122.1	0.18		0.088	3.47E-02	5.25E-05
Compliance Test Maximum		34.7	57.8	0.080		206.2	135.8	0.20		0.161	8.98E-02	1.36E-04
Standard Deviation				0.023				0.027				5.02E-05
t-statistic				2.105				2.132				2.132
95% Upper Confidence Limit				0.097				0.242				1.60E-04
Permit Limit				0.100				0.350				2.5E-5 Okeelanta 2.7E-6 Osceola

Table 2-7. Summary of CEMS Data for SO₂, OkPLP, 1997

Boiler	Month	No. of Hours	Daily Average SO ₂ Emissions (lb/MMBtu)		
			Min.	Avg.	Max.
A	January	408 ^{Jan 8} 17	0.0470	0.0494	0.0510
	February	320 13.3	0.0170	0.0347	0.0520
	March (a)	23 1	0.0350	0.0350	0.0350
B	January	523 ^{21.8}	0.0180	0.0497	0.0780
	February	522 ^{21.8}	0.0110	0.0308	0.0550
	March	322 13.4	0.0180	0.0412	0.0620
C	January	384 ¹⁶	0.0590	0.0601	0.0620
	February	434 ^{18.1}	0.0150	0.0280	0.0500
	March	575 ²⁴	0.0220	0.0424	0.0740
	Total hours =	3,511 ^{146.3} / ₂₇₀	~ 54% TIME		
	Minimum =		0.0110		
	Average =			0.0419	
	Maximum =				0.0780

(a) Average consists of only one set of data.

.011 → .078
7X

Table 2-8. Mercury and Lead Content (mg/kg wet) of Wood Waste Received at OkPLP

Test Date	Lead	Mercury	Test Date	Lead	Mercury
07/15/96	4.2	0.065 (a)	09/16/96	5.4	0.029 (a)
07/16/96	4.1	0.060 (a)	09/23/96	28.0	0.066
07/21/96 (b)	6.9	0.062 (c)	10/05/96	3.5	0.029 (a)
07/25/96	11.0	0.260	11/25/96	3.9	0.025 (a)
07/29/96	10.0	0.160	12/02/96	4.7	0.029 (a)
07/29/96	6.3	0.025 (a)	12/09/96	5.1	0.091
07/31/96	4.0	0.090	12/13/96	2.3	0.029 (a)
08/5/96	2.0	0.025 (a)	12/17/96	18.0	0.029 (a)
08/7/96	0.5 (a)	0.025 (a)	12/18/96	22.0	0.087
08/9/96	4.7	0.025 (a)	12/20/96	5.0 (a)	0.025 (a)
08/12/96	0.5 (a)	0.200	01/14/97	3.2	0.025 (a)
08/15/96	4.0	0.025 (a)	01/20/97	5.4	1.000
08/16/96 (b)		0.530	01/22/97	16.0	0.025 (a)
08/20/96 (b)	7.7	0.041 (c)	01/24/97	7.8	0.062
08/21/96 (b)	37.8	0.078 (c)	01/28/97	350.0	0.050 (a)
08/23/96	16.0	0.029 (a)	01/29/97 (b)	3.1	0.038
08/27/96	2.8	0.029 (a)	02/03/97	2.8	0.025
08/29/96	8.0	0.029 (a)	02/05/97	0.5 (a)	0.050 (a)
09/04/96 (b)	16.5	0.045 (c)	02/07/97	1.4	0.050 (a)
09/06/96	9.5	0.029 (a)			
09/11/96	7.2	0.029 (a)	Minimum	0.5	0.025
09/13/96	5.9	0.250	Average	7.9	0.095
			Maximum	37.8	1.000

VARIAION!
HIGH

Note:

- (a) Value represents 50% of detection limit
- (b) Value is an average of multiple analysis on the given day.
- (c) Value includes one analysis that represents 50% of detection limit.

Table 2-9. Mercury Stack Test Data for OkPLP and OsPLP Burning Wood Waste

Boiler/Run	Test Date	Mercury (Hg)		
		(mg/dscm @ 7% O ₂)	(lb/hr)	(lb/MMBtu)
Okeelanta Unit A				
1	5/11/96	1.86E-03	1.04E-03	1.48E-06
2	5/11/96	9.55E-04	5.13E-04	7.62E-07
3	5/11/96	8.59E-04	4.69E-04	6.84E-07
Average		1.22E-03	6.74E-04	9.75E-07
Okeelanta Unit B				
1	5/14/96	1.26E-03	6.95E-04	1.00E-06
2	5/14/96	1.21E-03	6.75E-04	9.65E-07
3	5/14/96	1.13E-03	6.39E-04	8.97E-07
Average		1.20E-03	6.70E-04	9.54E-07
1	12/09/96	2.63E-03	1.38E-03	2.09E-06
2	12/09/96	2.52E-03	1.34E-03	2.00E-06
3	12/10/96	2.98E-03	1.54E-03	2.38E-06
Average		2.71E-03	1.42E-03	2.16E-06
4	12/10/96	1.84E-03	1.08E-03	1.46E-06
5	12/10/96	1.84E-03	1.04E-03	1.46E-06
6	12/10/96	1.66E-03	9.90E-04	1.32E-06
Average		1.78E-03	1.04E-03	1.41E-06
7	12/11/96	1.94E-03	1.03E-03	1.54E-06
8	12/12/96	2.46E-03	1.35E-03	1.95E-06
9	12/12/96	2.51E-03	1.24E-03	1.99E-06
Average		2.30E-03	1.21E-03	1.83E-06
Okeelanta Unit C				
1	5/23/96	2.21E-03	1.30E-03	1.98E-06
2	5/23/96	2.23E-03	1.24E-03	1.90E-06
3	5/23/96	1.25E-03	7.13E-04	1.12E-06
Average		1.89E-03	1.09E-03	1.66E-06
2	12/13/96	3.43E-03	1.95E-03	2.72E-06
3	12/13/96	2.85E-03	1.63E-03	2.26E-06
4	12/13/96	3.31E-03	1.84E-03	2.63E-06
Average		3.20E-03	1.81E-03	2.54E-06
5	12/14/96	2.46E-03	1.37E-03	1.96E-06
6	12/14/96	2.29E-03	1.25E-03	1.82E-06
7	12/14/96	2.32E-03	1.28E-03	1.85E-06
Average		2.36E-03	1.30E-03	1.88E-06
8	12/15/96	2.18E-03	1.24E-03	1.74E-06
9	12/15/96	2.37E-03	1.25E-03	1.88E-06
10	12/15/96	1.85E-03	1.01E-03	1.48E-06
Average		2.14E-03	1.17E-03	1.70E-06
Osceola Unit A				
A -1	12/15/96	3.12E-03	1.91E-03	2.82E-06
A -2	12/15/96	3.22E-03	1.84E-03	2.91E-06
A -3	12/15/96	2.00E-03	1.13E-03	1.81E-06
Average		2.78E-03	1.63E-03	2.51E-06
Osceola Unit B				
B -1	12/17/96	3.33E-03	1.20E-03	3.02E-06
B -2	12/18/96	3.69E-03	2.15E-03	3.39E-06
B -3	12/18/96	3.59E-03	2.24E-03	3.29E-06
Average		3.54E-03	1.86E-03	3.23E-06
Compliance Test Minimum		1.20E-03	6.70E-04	9.54E-07
Compliance Test Average		2.28E-03	1.26E-03	1.90E-06
Compliance Test Maximum		3.54E-03	1.86E-03	3.23E-06
Standard Deviation				6.87E-07
t-statistic				1.812
95% Upper Confidence Limit				3.14E-06
Permit Limit				2.9E-7

Table 2-10. Calculated Mercury Removal Efficiency at OkPLP

Test Date	Carbon Injection Setting(a) (Hertz)	Run	Run Time (hrs)	Fuel Usage (tons - wet)	Fuel Analysis			Hg Stack Emissions		Calculated Hg Removal Efficiency	
					Hg Conc. (mg/kg,dry)	Moisture Content (%)	Hg Conc. (mg/kg,wet)	Hg Content (lbs)	(lbs/hr)		(lbs)
Boiler B											
12/09/96	15	1	2.10	124.36	0.230	26	0.170	0.0423	1.38E-03	2.90E-03	93.15%
12/09/96	15	2	2.05	100.71	0.064	36	0.041	0.0083	1.34E-03	2.75E-03	66.70%
12/10/96	15	3	2.07	115.37	0.080	29	0.057	0.0131	1.54E-03	3.18E-03	75.72%
12/10/96	30	4	2.07	128.05	0.075	34	0.050	0.0127	1.08E-03	2.23E-03	82.39%
12/10/96	30	5	2.22	123.50	0.015 (b)	25	0.011	0.0028	1.04E-03	2.31E-03	17.04%
12/10/96	30	6	2.05	121.76	0.049	30	0.034	0.0084	9.90E-04	2.03E-03	75.70%
12/11/96	45	7	2.03	104.48	0.043	28	0.031	0.0065	1.03E-03	2.09E-03	67.63%
12/12/96	45	8	2.03	100.24	0.055	26	0.041	0.0082	1.35E-03	2.75E-03	66.36%
12/12/96	45	9	2.03	99.54	0.066	28	0.048	0.0095	1.24E-03	2.52E-03	73.35%
Average =										68.67%	

79.93%

- (a) Hertz settings represent approximately the following:
 15 Hertz - 25% of max. injection rate or 7 lb/hr
 30 Hertz - 50% of max. injection rate or 16 lb/hr
 45 Hertz - 75% of max. injection rate or 23 lb/hr

(b) Below detectable level. Value represents one-half the detectable level.

Table 2-11. Maximum Short-Term Emissions for OkPLP Cogeneration Facility (per boiler)

Regulated Pollutant	Biomass			No. 2 Fuel Oil			Coal			Tire-Derived Fuel			25%TDF/ 75% Biomass (d) (lb/hr)	Maximum Emissions for any fuel (lb/hr)
	Emission Factor (lb/MMBtu)	Activity Factor (MMBtu/hr)	Maximum Emissions (lb/hr)	Emission Factor (lb/MMBtu)	Activity Factor (MMBtu/hr)	Maximum Emissions (lb/hr)	Emission Factor (lb/MMBtu)	Activity Factor (MMBtu/hr)	Maximum Emissions (lb/hr)	Emission Factor (lb/MMBtu)	Activity Factor (MMBtu/hr)	Maximum Emissions (lb/hr)		
Particulate (TSP)	0.03	715	21.5	0.03	490	14.7	0.03	490	14.7	0.03	340	10.2	21.5	21.5
Particulate (PM10)	0.03	715	21.5	0.03	490	14.7	0.03	490	14.7	0.03	340	10.2	21.5	21.5
Sulfur dioxide (c)	0.10	715	71.5	0.05	490	24.5	1.2	490	588.0	1.2	340	408.0	445.5	588.0
Nitrogen oxides (a)	0.15	715	107.3	0.15	490	73.5	0.17	490	83.3	0.15	340	51.0	107.3	107.3
Carbon monoxide (b)	0.35	715	250.3	0.2	490	98.0	0.2	490	98.0	0.35	340	119.0	250.3	250.3
Volatile organic compds.	0.06	715	42.9	0.03	490	14.7	0.03	490	14.7	0.06	340	20.4	42.9	42.9
Lead - Bagasse	2.5E-05	715	0.0179	8.9E-07	490	0.00044	6.4E-05	490	0.031	4.2E-05	340	0.0143	0.0743	0.1144
- Wood Waste	1.6E-04	715	0.1144											
Mercury - Bagasse	5.43E-06	715	0.0039	2.4E-06	490	0.00118	8.4E-06	490	0.0041	6.5E-06	340	0.0022	0.0042	0.0042
- Wood Waste	4.0E-06	715	0.0029											
Beryllium	--	715	--	3.5E-07	490	0.00017	5.9E-06	490	0.0029	4.5E-07	340	1.5E-04	0.00015	0.0029
Fluorides	--	715	--	6.3E-06	490	0.0031	0.024	490	11.8	6.5E-04	340	0.22	0.22	11.8
Sulfuric acid mist (c)	0.003	715	2.15	0.0015	490	0.74	0.036	490	17.64	0.010	340	3.40	4.53	17.64

- (a) 30-day rolling average.
- (b) 24-hour average.
- (c) 24-hour average.
- (d) Weight basis: 340 MMBtu/hr TDF and 375 MMBtu/hr biomass.

MAX

Table 2-12. Maximum Annual Emissions for Okeelanta Power Cogeneration Facility (total all boilers)


Regulated Pollutant	Biomass			Alternate Fuel			Total Annual Emissions (TPY)
	Emission Factor (lb/MMBtu)	Activity Factor (E12 Btu/yr)	Annual Emissions (TPY)	Emission Factor (lb/MMBtu)	Activity Factor (E12 Btu/yr)	Annual Emissions (TPY)	
<u>100% Biomass</u>							
Particulate (TSP)	0.03	11.500	172.50	--	--	--	172.50 ^(K)
Particulate (PM10)	0.03	11.500	172.50	--	--	--	172.50 ^(K)
Sulfur dioxide - Bagasse	0.02	6.900 b	69.00	--	--	--	184.00
- Wood Waste	0.05	4.600 c	115.00	--	--	--	
Nitrogen oxides	0.15	11.500	862.50	--	--	--	862.50
Carbon monoxide	0.35	11.500	2,012.50	--	--	--	2,012.50
VOC	0.06	11.500	345.00	--	--	--	345.00
Lead - Bagasse	2.5E-05	6.900 b	0.086	--	--	--	0.454 a
- Wood Waste	1.6E-04	4.600 c	0.368	--	--	--	
Mercury - Bagasse	5.43E-06	6.900 b	0.0187	--	--	--	0.0279
- Wood Waste	4.00E-06	4.600 c	0.00920	--	--	--	
Beryllium	--	--	--	--	--	--	--
Fluorides	--	--	--	--	--	--	--
Sulfuric acid mist	0.0006	11.500	3.45	--	--	--	3.45
<u>75.1% Biomass / 24.9% Fuel Oil</u>							
Particulate (TSP)	0.03	8.130	121.95	0.03	2.696	40.44	162.39
Particulate (PM10)	0.03	8.130	121.95	0.03	2.696	40.44	162.39
Sulfur dioxide - Bagasse	0.02	4.878 b	48.78	0.05	2.696	67.40	197.48
- Wood Waste	0.05	3.252 c	81.30	--	--	--	
Nitrogen oxides	0.15	8.130	609.75	0.15	2.696	202.20	811.95
Carbon monoxide	0.35	8.130	1,422.75	0.2	2.696	269.60	1,692.35
VOC	0.06	8.130	243.90	0.03	2.696	40.44	284.34
Lead - Bagasse	2.5E-05	4.878 b	0.061	8.9E-07	2.696	0.0012	0.322
- Wood Waste	1.6E-04	3.252 c	0.260	--	--	--	
Mercury - Bagasse	5.43E-06	4.878 b	0.0132	2.4E-06	2.696	0.0032	0.0230
- Wood Waste	4.00E-06	3.252 c	0.00650	--	--	--	
Beryllium	--	--	--	3.5E-07	2.696	0.00047	0.00047
Fluorides	--	--	--	6.27E-06	2.696	0.0085	0.0085
Sulfuric acid mist	0.0006	8.130	2.44	0.0015	2.696	2.02	4.46
<u>84.9% Biomass / 15.1% Coal</u>							
Particulate (TSP)	0.03	9.408	141.12	0.03	1.673	25.10	166.22
Particulate (PM10)	0.03	9.408	141.12	0.03	1.673	25.10	166.22
Sulfur dioxide - Bagasse	0.02	5.645 b	56.45	1.2	1.673	1,003.80	1,154.33 a
- Wood Waste	0.05	3.763 c	94.08	--	--	--	
Nitrogen oxides	0.15	9.408	705.60	0.17	1.673	142.21	847.81
Carbon monoxide	0.35	9.408	1,646.40	0.2	1.673	167.30	1,813.70
VOC	0.06	9.408	282.24	0.03	1.673	25.10	307.34
Lead - Bagasse	2.5E-05	5.645 b	0.071	6.4E-05	1.673	0.0535	0.425
- Wood Waste	1.6E-04	3.763 c	0.301	--	--	--	
Mercury - Bagasse	5.43E-06	5.645 b	0.0153	8.4E-06	1.673	0.0070	0.0299
- Wood Waste	4.00E-06	3.763 c	0.00753	--	--	--	
Beryllium	--	--	--	5.9E-06	1.673	0.0049	0.0049 a
Fluorides	--	--	--	0.024	1.673	20.08	20.08 a
Sulfuric acid mist	0.0006	9.408	2.82	0.036	1.673	30.11	32.94 a
<u>78.1% Biomass / 21.9% Tire-Derived Fuel (9.0% TDF, weight basis)</u>							
Particulate (TSP)	0.03	8.982	134.73	0.03	2.519	37.79	172.52 a ^(K)
Particulate (PM10)	0.03	8.982	134.73	0.03	2.519	37.79	172.52 a ^(K)
Sulfur dioxide - Bagasse	0.02	5.389 b	53.89	0.8	2.519	1,007.60	1,151.31
- Wood Waste	0.05	3.593 c	89.82	--	--	--	
Nitrogen oxides	0.15	8.982	673.65	0.15	2.519	188.93	862.58 a
Carbon monoxide	0.35	8.982	1,571.85	0.35	2.519	440.83	2,012.68 a
VOC	0.06	8.982	269.46	0.06	2.519	75.57	345.03 a
Lead - Bagasse	2.5E-05	5.389 b	0.067	4.2E-05	2.519	0.0529	0.408
- Wood Waste	1.6E-04	3.593 c	0.287	--	--	--	
Mercury - Bagasse	5.43E-06	5.389 b	0.0146	6.5E-06	2.519	0.0082	0.0300 a
- Wood Waste	4.00E-06	3.593 c	0.00719	--	--	--	
Beryllium	--	--	--	4.5E-07	2.519	0.00057	0.00057
Fluorides	--	--	--	6.5E-04	2.519	0.82	0.8187
Sulfuric acid mist	0.0006	8.982	2.69	0.0069	2.519	8.69	11.39

a Denotes maximum annual emissions for any fuel scenario.

b Represents 60% of total heat input.

c Represents 40% of total heat input.



Note: No emissions of total reduced sulfur, asbestos, or vinyl chloride are expected.



2-23

Figure 2-1
Regional Site Map





2-24

Figure 2-2
Location of Existing Sugar Mill and Cogeneration Facility






Figure 2-3
Simplified Flow Diagram for Okeelanta Power Cogeneration Facility






Figure 2-4
Plot Plan of Okeelanta Power

Source: Bechtel, 1995.



3.0 AIR QUALITY REVIEW REQUIREMENTS AND SOURCE APPLICABILITY

OkPLP received a state and federal PSD construction permit in 1993. PSD review was triggered for SO₂, beryllium, and fluorides. The facility is now operating and has conducted initial compliance testing on wood waste. Compliance testing on bagasse has not yet been conducted. OkPLP is now proposing changes to the emission limits of three pollutants for wood waste firing and desires to amend the PSD construction permit. The averaging time specified for the CO emissions limit for all fuels is also being revised. The requested emissions from the boilers are not greater than the currently permitted emissions, except in regards to annual emissions of Pb.

A revised PSD source applicability analysis for OkPLP, incorporating these changes, is provided in Table 3-1. The emissions also reflect a request to burn TDF. Although the emissions for all PSD pollutants are shown in Table 3-1, only the annual Pb emissions are being revised at this time. Since the facility does not yet have a two-year operational history, the original baseline emission rates presented in the PSD application in 1993 were used. As shown, based on the permit limits and the OkPLP maximum annual emissions, PSD review will not be triggered by this request.

Although PSD review is not being triggered by the proposed modification, changes are occurring in some air emission rates for Pb. As a result, the previous air toxics modeling analysis has been updated. This analysis is presented in Section 4.0.

Table 3-1. PSD Source Applicability Analysis for the OKPLP Facility

Regulated Pollutant	Cogeneration Facility Emissions (TPY)			Significant Emission Rate (TPY)	Current Permit Limit (TPY)	PSD Applies ?	Permit Amendment Required ?
	Baseline ^a	Requested Limits	Net Change				
Particulate (TSP)	473.7	200.0 ^b	-273.7	25	172.5 ^d	No	No
Particulate (PM10)	426.3	190.8 ^c	-235.5	15	172.5 ^d	No	No
Sulfur Dioxide	748.3	1,154.3	406.0	40	1,154.3	No	No
Nitrogen Oxides	888.7	862.5	-26.2	40	862.5	No	No
Carbon Monoxide	10,388.0	2,012.5	-8,375.5	100	2,012.5	No	No
VOC	401.9	345.0	-56.9	40	345.0	No	No
Lead	0.28	0.454	+0.174	0.6	0.17	No	Yes
Mercury	0.0292	0.0300	0.0008	0.1	0.0300	No	No
Beryllium	0.0004	0.0049	0.0045	0.0004	0.0052	No	No
Fluorides	0.04	20.1	20.1	3	21.2	No	No
Sulfuric Acid Mist	22.4	32.9	10.5	7	34.6	No	No
Total Reduced Sulfur	--	--	0	10	--	No	No
Asbestos	--	--	0	0.007	--	No	No
Vinyl Chloride	--	--	0	0	--	No	No

^a Emission offsets to be achieved by shutdown of existing Okeelanta Sugar Mill boilers.

^b Includes 172.5 TPY from boilers and 27.5 TPY from fugitive dust sources.

^c Includes 172.5 TPY from boilers and 18.3 TPY from fugitive dust sources.

^d PM/PM10 emissions from boilers only; does not included fugitive dust sources.

4.0 AIR TOXICS MODELING ANALYSIS

4.1 INTRODUCTION

In support of the request to burn TDF as a supplemental fuel, OkPLP submitted a revised air modeling analysis for HAPs/toxics to the FDEP in May 1996. Based on the current request to increase emissions limits for Pb and Hg, an updated air modeling analysis is presented for all pollutants. This analysis incorporates revised stack parameters, as shown in Table 2-3.

4.2 METHODOLOGY

The procedure used in the analysis followed the recommendations in the U.S. Environmental Protection Agency's (EPA's) modeling guidelines, which are approved by FDEP for general use. The recommendations are related to specific models and options that are preferred for use in particular situations. The guidelines provide recommendations for predicting impacts in both flat or gently rolling terrain by the use of simple terrain models (i.e., terrain less than stack height). These models are applicable to the OkPLP facility.

The Industrial Source Complex Short-Term (ISCST) dispersion model, Version 95250 (ISCST3; EPA, 1995) is preferred because EPA and FDEP have specifically recommended this model to provide refined air quality impacts in simple terrain. The ISCST3 model is a Gaussian plume model that can be used to assess the air quality impact of emissions from a wide variety of sources associated with an industrial facility.

The ISCST3 model is designed to calculate hour-by-hour concentrations or deposition values and provide averages for time periods of 2-, 3-, 4-, 6-, 8-, 12-, and 24-hours and 1 year. The ISCST3 model has rural and urban options that affect the wind speed profile exponent law, dispersion rates, and mixing-height formulations used in calculating ground-level concentrations. Concentrations are readily obtainable from the model output for comparison to the Florida ambient reference concentrations (FARCs) developed by FDEP. A list of ISCST3 model features is presented in Table 4-1.

For the application of the ISCST3 model, the general modeling approach followed EPA and FDEP modeling guidelines for determining compliance with regulatory standards, such as FARCs.

One source, representing the Okeelanta cogeneration facility's three boilers, was modeled in the ISCST3 model with a generic emission rate of 10.0 grams per second (g/sec) (i.e., 79.365 lb/hr). The selected averaging times were for 8-hours, 24-hours, and annual average. The highest predicted 8-hour, 24-hour, and annual concentrations in 5 years were selected for comparison to the FARCs.

Short-term (i.e., maximum pound per hour) and annual averaged (i.e., tons per year) emission rates were determined for the OkPLP facility for each HAP and air toxic pollutant emitted. The emission rates for these compounds are provided in Section 2.0. The short-term emission rates for each pollutant were used for determining compliance with the 8-hour and 24-hour FARCs, while the annual averaged emissions were used for determining compliance with the annual FARC. The maximum pollutant-specific impact for each averaging time was determined by multiplying the maximum predicted generic concentration by the pollutant-specific emission rate and dividing the product by the generic emission rate.

Meteorological data used in the ISCST3 model to determine air quality impacts consisted of 5 years of coincident hourly surface weather observations and twice-daily upper-air soundings from the National Weather Service (NWS) station at the West Palm Beach International Airport. The 5-year period of meteorological data was from 1982 through 1986. These data have been recommended by FDEP for projects in the sugar mill area.

For the screening analysis, 36 receptors were located at 10-degree increments along the plant property boundary. A listing of these receptors is presented in Table 4-2. Modeling refinements were performed by using a 2-degree angular spacing along the plant property boundary. The refined receptor grid was centered on the screening analysis receptor that produced the highest impact and extended to and included the adjacent screening grid receptors.

Direction-specific building heights and widths that were used for these sources in the original modeling analysis for the cogeneration facility were also used in the toxic model analysis. The only significant structure near the cogeneration facility stacks is the cogeneration facility boiler structure (see Figure 2-5). The dimensions of this structure are 120 ft high, 180 ft long, and 75 ft wide.

Stack parameters used in the modeling analysis are shown in Table 2-3. To be conservative, the lowest stack gas flow rate, velocity, and temperature shown for biomass were used to result in the highest predicted impacts.

4.3 MODELING RESULTS

The maximum predicted concentrations for the 8-hour, 24-hour, and annual averaging periods for each HAP and air toxic pollutant are presented in Table 4-3. Table 4-3 indicates the maximum short-term and annual emission rates and the maximum impacts for each compound emitted. As shown, all compounds have maximum impacts that are below the FARC for the 8-hour, 24-hour, and annual averaging times, respectively.

Table 4-1. Major Features of the ISCST3 Model

ISCST3 Model Features
<ul style="list-style-type: none">• Polar or Cartesian coordinate systems for receptor locations• Rural or one of three urban options which affect wind speed profile exponent, dispersion rates, and mixing height calculations• Plume rise due to momentum and buoyancy as a function of downwind distance for stack emissions (Briggs, 1969, 1971, 1972, and 1975; Bowers, et al., 1979).• Procedures suggested by Huber and Snyder (1976); Huber (1977); and Schulman and Scire (1980) for evaluating building wake effects• Procedures suggested by Briggs (1974) for evaluating stack-tip downwash• Separation of multiple emission sources• Consideration of the effects of gravitational settling and dry deposition on ambient particulate concentrations• Capability of simulating point, line, volume, area, and open pit sources• Capability to calculate dry and wet deposition, including both gaseous and particulate precipitation scavenging for wet deposition• Variation of wind speed with height (wind speed-profile exponent law)• Concentration estimates for 1-hour to annual average times• Terrain-adjustment procedures for elevated terrain including a terrain truncation algorithm for ISCST3; a built-in algorithm for predicting concentrations in complex terrain• Consideration of time-dependent exponential decay of pollutants• The method of Pasquill (1976) to account for buoyancy-induced dispersion• A regulatory default option to set various model options and parameters to EPA recommended values (see text for regulatory options used)• Procedure for calm-wind processing including setting wind speeds less than 1 m/s to 1 m/s.

Note: ISCST3 = Industrial Source Complex Short-Term.

Source: EPA, 1995.

Table 4-2. Property Boundary Receptors Used in the Modeling Analysis

Direction (deg)	Distance (m)	Direction (deg)	Distance (m)
10	3674.	190	2764.
20	3850.	200	2897.
30	4178.	210	3143.
40	3642.	220	3553.
50	3163.	230	4234.
60	4066.	240	5444.
70	3849.	250	7958.
80	3669.	260	9485.
90	3609.	270	9675.
100	3661.	280	9585.
110	3832.	290	9602.
120	4153.	300	7236.
130	4234.	310	5629.
140	3553.	320	4723.
150	3143.	330	4178.
160	2897.	340	3850.
170	2764.	350	3674.
180	2722.	360	3618.

Note: Distances are relative to centroid of cogeneration facility stacks locations.

Table 4-3. Maximum Impacts of HAPs and Air Toxic Pollutants for Okeelanta Power Cogeneration Facility (total 3 boilers)

Pollutant	Emission Rates		Concentrations (µg/m³)						Compound Complies With FARCs?
	Maximum (lb/hr)	Annual (TPY)	8-Hour		24-Hour		Annual		
			Impact	FARC	Impact	FARC	Impact	FARC	
acetaldehyde	1.67	4.49	0.0923	450	0.0709	107	0.0030	0.5	YES
acetone	0.82	2.19	0.0450	17800	0.0345	4238	1.5E-03	NA	YES
acetophenone	0.0079	0.021	0.0004	490	0.0003	117	1.4E-05	100	YES
acrolein	0.139	0.37	0.0077	2.3	0.0059	0.5	2.5E-04	0.02	YES
ammonia	70.6	123.3	3.8932	170	2.9908	41	0.082	100	YES
antimony	0.051	0.031	0.0028	5	0.0022	1.2	2.1E-05	0.3	YES
arsenic	0.36	0.32	0.0196	0.1	0.0151	0.02	0.00021	0.00023	YES
barium	0.11	0.09	0.0060	5	0.0046	1.2	6.0E-05	50	YES
benzene	2.79	7.48	0.1539	30	0.1182	7	0.0050	0.12	YES
benzo (a) anthracene (POM)	0.0016	0.0043	8.8E-05	NA	6.8E-05	NA	2.9E-06	0.0011	YES
benzo (a) pyrene	7.6E-05	2.0E-04	4.2E-06	NA	3.2E-06	NA	1.3E-07	0.0003	YES
beryllium	0.0087	5.2E-03	4.8E-04	0.02	3.7E-04	0.005	3.5E-06	0.00042	YES
bromine	1.16	0.91	0.0641	6.6	0.0492	1.6	6.0E-04	NA	YES
cadmium	0.0049	0.0083	2.7E-04	0.02	2.1E-04	0.005	5.5E-06	0.00056	YES
carbon disulfide	0.28	0.75	0.0154	310	0.0118	74	5.0E-04	200	YES
carbon tetrachloride	0.013	0.035	0.0007	310	0.0005	74	2.3E-05	0.067	YES
chlorine	1.97	5.29	0.1089	15	0.0836	3.6	0.0035	0.4	YES
chloroform	0.10	0.27	0.0056	490	0.0043	117	1.8E-04	0.043	YES
chromium	0.34	0.32	0.0186	5	0.0143	1.2	2.1E-04	1000	YES
chromium +6	0.067	0.064	0.0037	0.5	0.0029	0.1	4.3E-05	0.000083	YES
chrysene	0.076	0.20	0.0042	2	0.0032	0.5	1.3E-04	NA	YES
cobalt	0.330	0.37	0.0182	0.5	0.0140	0.1	2.5E-04	NA	YES
copper	0.79	1.04	0.0437	10	0.0336	2.4	6.9E-04	NA	YES
cumene	0.039	0.10	0.0021	2460	0.0016	586	6.9E-05	1	YES
dibutyl phthalate	0.124	0.33	0.0069	50	0.0053	12	2.2E-04	100	YES
ethylbenzene	0.008	0.022	0.0005	4340	0.0004	1033	1.5E-05	1000	YES
fluorine (as fluorides)	35.28	21.23	1.9466	25	1.4954	6	0.014	NA	YES
formaldehyde	2.79	7.48	0.1539	3.7	0.1182	0.9	0.0050	0.077	YES
hexane	1.18	3.16	0.0651	1760	0.0500	419	0.0021	200	YES
hydrogen chloride	116.1	113.1	6.4075	70	4.9223	17	0.0752	7	YES
indium	0.27	0.73	0.0150	1	0.0115	0.2	4.9E-04	NA	YES
iodine	0.0050	0.012	0.0003	10	0.0002	2.4	8.0E-06	NA	YES
isopropanol	19.73	52.90	1.0886	9800	0.8363	2333	3.5E-02	NA	YES
lead	0.343	0.454	0.0189	0.5	0.0145	0.1	3.0E-04	0.09	YES
manganese	0.77	1.18	0.0422	50	0.0324	12	7.8E-04	0.05	YES
mercury	0.014	0.030	0.0008	0.5	0.0006	0.1	2.0E-05	0.3	YES
methanol	3.22	8.63	0.1775	2600	0.1364	619	5.7E-03	NA	YES
methyl ethyl ketone	0.026	0.069	0.0014	5900	0.0011	1405	4.6E-05	1000	YES
methyl isobutyl ketone	1.84	4.95	0.1018	2050	0.0782	488	3.3E-03	NA	YES
methylene chloride	3.22	8.63	0.1775	1740	0.1364	414	5.7E-03	2	YES
molybdenum	0.05	0.053	0.0025	50	0.0019	12	3.5E-05	NA	YES
m&p xylene	0.017	0.045	0.0009	4340	0.0007	1033	3.0E-05	80	YES
naphthalene	1.27	3.39	0.0698	500	0.0536	119	2.3E-03	NA	YES
nickel	0.047	0.073	0.0026	10	0.0020	2.4	4.9E-05	0.0042	YES
o xylene	0.006	0.015	0.0003	4340	0.0002	1033	9.9E-06	80	YES
PAH	1.3E-06	3.4E-06	7.0E-08	2	5.4E-08	0.5	2.3E-09	NA	YES
phenols	0.088	0.24	0.0049	190	0.0037	45	1.6E-04	30	YES
phosphorus	1.26	0.77	0.0698	1	0.0536	0.2	5.1E-04	NA	YES
pom (polycyclic organic matter)	0.012	0.013	0.0007	NA	0.0005	NA	8.6E-06	NA	YES
selenium	0.079	0.10	0.0043	2	0.0033	0.5	6.6E-05	NA	YES
silver	0.0030	0.0081	1.7E-04	0.1	1.3E-04	0.02	5.4E-06	NA	YES
styrene	0.032	0.086	0.0018	2130	0.0014	507	5.7E-05	1000	YES
sulfuric acid mist	52.9	34.6	2.92	10	2.24	2.4	2.3E-02	NA	YES
tin	0.013	0.0080	7.2E-04	1	5.5E-04	0.2	5.3E-06	NA	YES
2,3,7,8 -TCDD (dioxin)	1.3E-08	3.5E-08	7.1E-10	NA	5.5E-10	NA	2.3E-11	2.2E-08	YES
toluene	0.19	0.52	0.0107	1880	0.0082	448	3.4E-04	400	YES
1, 1, 1 trichloroethane	0.36	0.98	0.0201	19000	0.015	4524	6.5E-04	NA	YES
trichloroethylene	0.016	0.044	0.0009	2690	6.9E-04	640	2.9E-05	0.77	YES
tungsten	2.8E-05	7.4E-05	1.53E-06	50	1.2E-06	12	4.9E-08	NA	YES
uranium	2.6E-05	3.0E-05	1.5E-06	0.5	1.1E-06	0.1	2.0E-08	NA	YES
vanadium	8.2E-04	0.0014	4.5E-05	0.5	3.5E-05	0.1	9.3E-07	20	YES
yttrium	1.4E-04	3.8E-04	7.8E-06	10	6.0E-06	2.4	2.5E-07	NA	YES
zinc	10.48	13.23	0.58	10	0.44	2.4	8.8E-03	NA	YES
zirconium	8.8E-04	0.0024	4.9E-05	50	3.7E-05	12	1.6E-06	NA	YES

Notes: F'ARC= Florida Ambient Reference Concentrations

Maximum concentrations determined with ISCST3 model and West Palm Beach meteorological data for 1982 to 1986.

Highest predicted concentrations (µg/m³) for a generic emission rate of 10 g/s (79.365 lb/hr) are :

8-hour= 4.379
24-hour= 3.364
Annual= 0.2311

Handwritten notes:
9.3E-05
YES
WR
OR

ATTACHMENT A

Table A-1. Maximum Fuel Usage and Heat Input Rates per Boiler, Okeelanta Power Limited Partnership

Fuel	Heat Input	Heat Transfer Efficiency (%)	Heat Output	Fuel Firing Rate
Maximum Short-Term (per boiler)				
	(MMBtu/hr)		(MMBtu/hr)	
Biomass - Bagasse	715	68	486	168,235 lb/hr ^a
- Wood Waste	715	68	486	130,000 lb/hr ^b
No. 2 Fuel Oil	490	85	417	3,551 gal/hr
Coal	490	85	417	40,833 lb/hr
Tire-Derived Fuel	340	68	231	21,935 lb/hr
Annual Average (per boiler)				
	(Btu/yr)		(Btu/yr)	
NORMAL OPERATIONS (100% BIOMASS)				
Biomass	6.263E+12	68	4.259E+12	736,871 TPY ^a
No. 2 Fuel Oil	0	85	0	0 gal/yr
Coal	0	85	0	0 TPY
Tire-Derived Fuel	0	68	0	0 TPY
TOTAL	6.263E+12		4.259E+12	
24.9% OIL FIRING				
Biomass	4.428E+12	68	3.011E+12	520,941 TPY
No. 2 Fuel Oil	1.468E+12	85	1.248E+12	10,638,685 gal/yr
Coal	0	85	0	0 TPY
Tire-Derived Fuel	0	68	0	0 TPY
TOTAL	5.896E+12		4.259E+12	
24.9% COAL FIRING				
Biomass	4.428E+12	68	3.011E+12	520,941 TPY
No. 2 Fuel Oil	0	85	0	0 gal/yr
Coal	1.468E+12	85	1.248E+12	61,172 TPY
Tire-Derived Fuel	0	68	0	0 TPY
TOTAL	5.896E+12		4.259E+12	
40.2% TIRE-DERIVED FUEL				
Biomass	3.744E+12	68	2.546E+12	340,364 TPY ^b
No. 2 Fuel Oil	0	85	0	0 gal/yr
Coal	0	85	0	0 TPY
Tire-Derived Fuel	2.519E+12	68	1.713E+12	81,246 TPY
TOTAL	6.263E+12		4.259E+12	

15.1% Coal firing?

a Based on bagasse firing.

b Based on wood waste firing.

Notes:

40 CFR 60, Subpart Da, limits fossil-fuel firing to less than 25% for each boiler (heat input basis).

40 CFR 60, Subpart Ea, limits municipal solid waste firing to 30% or less for each boiler (weight basis).

Total heat output required = 4.259E+12 Btu/yr per boiler.

Fuels may be burned in combination, not to exceed total heat outputs.

Based on fuel heating values as follows:

- Bagasse - 4,250 Btu/lb
- Wood Waste - 5,500 Btu/lb
- No. 2 Fuel Oil - 138,000 Btu/gal
- Coal - 12,000 Btu/lb
- Tire-derived fuel - 15,500 Btu/lb

Table A-2. Maximum Annual Emissions for Single Boiler at Okeelanta Power Cogeneration Facility

Regulated Pollutant	Biomass			Alternate Fuel			Total Annual Emissions (TPY)
	Emission Factor (lb/MMBtu)	Activity Factor (E12 Btu/yr)	Annual Emissions (TPY)	Emission Factor (lb/MMBtu)	Activity Factor (E12 Btu/yr)	Annual Emissions (TPY)	
<u>100% Biomass</u>							
Particulate (TSP)	0.03	6.263	93.95	--	--	--	93.95 a
Particulate (PM10)	0.03	6.263	93.95	--	--	--	93.95 a
Sulfur dioxide - Bagasse	0.02	3.758 b	37.58	--	--	--	100.21
- Wood waste	0.05	2.505 c	62.63				
Nitrogen oxides	0.15	6.263	469.73	--	--	--	469.73 a
Carbon monoxide	0.35	6.263	1,096.03	--	--	--	1,096.03 a
VOC	0.06	6.263	187.89	--	--	--	187.89 a
Lead - Bagasse	2.5E-05	3.758 b	0.047	--	--	--	0.067
- Wood Waste	1.6E-05	2.505 c	0.020				
Mercury - Bagasse	5.43E-06	3.758 b	0.0102	--	--	--	0.0152
- Wood Waste	4.00E-06	2.505 c	0.00501				
Beryllium	--	--	--	--	--	--	--
Fluorides	--	--	--	--	--	--	--
Sulfuric acid mist	0.0006	6.263	1.88	--	--	--	1.88
<u>75.1% Biomass / 24.9% Fuel Oil</u>							
Particulate (TSP)	0.03	4.428	66.42	0.03	1.468	22.02	88.44
Particulate (PM10)	0.03	4.428	66.42	0.03	1.468	22.02	88.44
Sulfur dioxide - Bagasse	0.02	2.657 b	26.57	0.05	1.468	36.70	107.55
- Wood waste	0.05	1.771 c	44.28				
Nitrogen oxides	0.15	4.428	332.10	0.15	1.468	110.10	442.20
Carbon monoxide	0.35	4.428	774.90	0.2	1.468	146.80	921.70
VOC	0.06	4.428	132.84	0.03	1.468	22.02	154.86
Lead - Bagasse	2.5E-05	2.657 b	0.033	8.9E-07	1.468	0.0007	0.048
- Wood Waste	1.6E-05	1.771 c	0.014				
Mercury - Bagasse	5.43E-06	2.657 b	0.0072	2.4E-06	1.468	0.0018	0.0125
- Wood Waste	4.00E-06	1.771 c	0.00354				
Beryllium	--	--	--	3.5E-07	1.468	0.00026	0.00026
Fluorides	--	--	--	6.27E-06	1.468	0.0046	0.0046
Sulfuric acid mist	0.0006	4.428	1.33	0.0015	1.468	1.10	2.43
<u>75.1% Biomass / 24.9% Coal</u>							
Particulate (TSP)	0.03	4.428	66.42	0.03	1.468	22.02	88.44
Particulate (PM10)	0.03	4.428	66.42	0.03	1.468	22.02	88.44
Sulfur dioxide - Bagasse	0.02	2.967 b	29.67	1.2	1.468	880.80	947.00
- Wood waste	0.05	1.461 c	36.53				
Nitrogen oxides	0.15	4.428	332.10	0.17	1.468	124.78	456.88
Carbon monoxide	0.35	4.428	774.90	0.2	1.468	146.80	921.70
VOC	0.06	4.428	132.84	0.03	1.468	22.02	154.86
Lead - Bagasse	2.5E-05	2.657 b	0.033	6.4E-05	1.468	0.0470	0.0944 a
- Wood Waste	1.6E-05	1.771 c	0.014				
Mercury - Bagasse	5.43E-06	2.657 b	0.0072	8.4E-06	1.468	0.0062	0.0169
- Wood Waste	4.00E-06	1.771 c	0.00354				
Beryllium	--	--	--	5.9E-06	1.468	0.0043	0.0043 a
Fluorides	--	--	--	0.024	1.468	17.62	17.62 a
Sulfuric acid mist	0.0006	4.428	1.33	0.036	1.468	26.42	27.75 a
<u>59.8% Biomass / 40.2% Tire-Derived Fuel</u>							
Particulate (TSP)	0.03	3.744	56.16	0.03	2.519	37.79	93.95 a
Particulate (PM10)	0.03	3.744	56.16	0.03	2.519	37.79	93.95 a
Sulfur dioxide - Bagasse	0.02	2.246 b	22.46	0.8	2.519	1,007.60	1067.50 a
- Wood waste	0.05	1.498 c	37.44				
Nitrogen oxides	0.15	3.744	280.80	0.15	2.519	188.93	469.73
Carbon monoxide	0.35	3.744	655.20	0.35	2.519	440.83	1096.03 a
VOC	0.06	3.744	112.32	0.06	2.519	75.57	187.89 a
Lead - Bagasse	2.5E-05	2.246 b	0.028	4.2E-05	2.519	0.0529	0.0930
- Wood Waste	1.6E-05	1.498 c	0.012				
Mercury - Bagasse	5.43E-06	2.246 b	0.0061	6.5E-06	2.519	0.0082	0.0173 a
- Wood Waste	4.00E-06	1.498 c	0.00300				
Beryllium	--	--	--	4.5E-07	2.519	0.00057	0.00057
Fluorides	--	--	--	6.5E-04	2.519	0.82	0.8187
Sulfuric acid mist	0.0006	3.744	1.12	0.0069	2.519	8.69	9.81

a Denotes maximum annual emissions for any fuel scenario.

b Represents 60% of total heat input.

c Represents 40% of total heat input.

Note: No emissions of total reduced sulfur, asbestos, or vinyl chloride are expected.

Fuel type percentages are based on heat input.