



AIR HYGIENE, INC.

*Testing Solutions for a Better World*

**EMISSION COMPLIANCE TEST  
FOR THE  
MITSUBISHI, MODEL 501G, UNIT 1C  
PREPARED FOR  
FLORIDA POWER AND LIGHT  
AT THE  
WEST COUNTY ENERGY CENTER  
LOXAHATCHEE, FLORIDA  
OCTOBER 5-6, 2009**



AIR HYGIENE, INC.

Corporate Headquarters  
5634 S. 122nd E. Ave. Ste. F  
Tulsa, Oklahoma 74146

Las Vegas Office  
5925 E. Lake Mead Blvd.  
Las Vegas, Nevada 89156

Philadelphia Office  
8900 State Road  
Philadelphia, Pennsylvania 19136

Houston Office  
1920 Treble Drive  
Humble, Texas 77338

(918) 307-8865 or (888) 461-8778  
[www.airhygiene.com](http://www.airhygiene.com)

RECEIVED

NOV 18 2009

BUREAU OF AIR REGULATION

EMISSION COMPLIANCE TEST  
FOR THE  
MITSUBISHI, MODEL 501G, UNIT 1C  
PREPARED FOR  
FLORIDA POWER AND LIGHT  
AT THE  
WEST COUNTY ENERGY CENTER  
LOXAHATCHEE, FLORIDA  
OCTOBER 5-6, 2009

Prepared and Reviewed by:




Thomas K. Graham, P.E., QSTI, Director of Operations



Paul Little, Director of Customer Service



Tim Page, Test Technician



Jake Fahlenkamp, QSTI, Director of Quality Assurance

## Table of Contents

<b>1.0</b>	<b>INTRODUCTION</b>	<b>1</b>
<b>1.1</b>	<b>TEST PURPOSE AND OBJECTIVES</b>	<b>1</b>
<b>1.2</b>	<b>SUMMARY OF TEST PROGRAM</b>	<b>1</b>
1.2.1	Participating Organizations	1
1.2.2	Industry	1
1.2.3	Air Permit and Federal Requirements	1
1.2.4	Plant Location	1
1.2.5	Equipment Tested	1
1.2.6	Emission Points	2
1.2.7	Pollutants Measured	2
1.2.8	Dates of Emission Test	2
<b>1.3</b>	<b>KEY PERSONNEL</b>	<b>2</b>
<b>2.0</b>	<b>SUMMARY OF TEST RESULTS</b>	<b>2</b>
<b>3.0</b>	<b>SOURCE OPERATION</b>	<b>4</b>
<b>3.1</b>	<b>PROCESS DESCRIPTION</b>	<b>4</b>
<b>3.2</b>	<b>SAMPLING LOCATION</b>	<b>4</b>
<b>4.0</b>	<b>SAMPLING AND ANALYTICAL PROCEDURES</b>	<b>5</b>
<b>4.1</b>	<b>TEST METHODS</b>	<b>5</b>
<b>4.2</b>	<b>INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS</b>	<b>5</b>

## APPENDICES

Appendix A	Test Results and Calculations
Appendix B	Emission Data Records
Appendix C	Calibration Gas Certifications
Appendix D	Quality Assurance and Quality Control Data
Appendix E	Fuel Analysis Records
Appendix F	Stratification Test Data

**Emissions Compliance Test  
Mitsubishi, Model 501G, Unit 1C  
Florida Power and Light  
West County Energy Center  
Loxahatchee, Florida  
October 5-6, 2009**

## **1.0 INTRODUCTION**

Air Hygiene International, Inc. (Air Hygiene) has completed the emissions testing study for nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), volatile organic compounds (VOC), ammonia (NH<sub>3</sub>), opacity, carbon dioxide (CO<sub>2</sub>), and oxygen (O<sub>2</sub>) from the exhaust of the Mitsubishi, Model 501G, Unit 1C for Florida Power and Light at the West County Energy Center near Loxahatchee, Florida. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on October 5-6, 2009.

## **1.1 TEST PURPOSE AND OBJECTIVES**

The purpose of the test was to conduct an initial compliance emission test to document levels of selected pollutants at two test loads (Base Load and Base Load with Duct Burners). The information will be used to confirm compliance with the operating permit issued by the Florida Department of Environmental Protection (FDEP). The specific objective was to determine the emission concentration of NO<sub>x</sub>, CO, VOC, NH<sub>3</sub>, opacity, CO<sub>2</sub>, and O<sub>2</sub> from the exhaust of Florida Power and Light's Mitsubishi, Model 501G, Unit 1C at Base Load and Base Load with Duct Burners of total capacity.

## **1.2 SUMMARY OF TEST PROGRAM**

The following list details pertinent information related to this specific project:

- 1.2.1 Participating Organizations
  - Florida Department of Environmental Protection (FDEP)
  - Florida Power and Light
  - Black and Veatch
  - Air Hygiene
- 1.2.2 Industry
  - Electric Utility / Electric Services
- 1.2.3 Air Permit and Federal Requirements
  - Permit Number: PSD-FL-354
  - Emission Unit Identification (ID): 003
- 1.2.4 Plant Location
  - West County Energy Center near Loxahatchee, Florida
- 1.2.5 Equipment Tested
  - Mitsubishi, Model 501G, Unit 1C

- 1.2.6 Emission Points
  - Exhaust from the Mitsubishi, Model 501G, Unit 1C
  - For all gases, one sample point in the exhaust duct from the Mitsubishi, Model 501G, Unit 1C, determined after conducting a stratification test (refer to Appendix F)
  - For all NH<sub>3</sub> testing, 24 sampling points in the exhaust duct from the Mitsubishi, Model 501G, Unit 1C (refer to Appendix A)
  - For opacity, one sample visual observation point from the exit of the exhaust duct to the atmosphere from the Mitsubishi, Model 501G, Unit 1C
- 1.2.7 Pollutants Measured
  - NOx
  - CO
  - VOC
  - NH<sub>3</sub>
  - Opacity
  - CO<sub>2</sub>
  - O<sub>2</sub>
- 1.2.8 Dates of Emission Test
  - October 5-6, 2009

**1.3 KEY PERSONNEL**

Florida Power and Light:	John Mirino	305-242-3895
Florida Power and Light:	David Fawcett	561-904-4907
Florida Power and Light:	Emmett Callow	561-904-4922
Black and Veatch:	Bill Stevenson	913-458-8549
FDEP:	Michael Helmke	561-837-5936
Air Hygiene:	Jake Fahlenkamp	918-307-8865
Air Hygiene:	Tim Page	918-307-8865

**2.0 SUMMARY OF TEST RESULTS**

Results from the sampling conducted on Florida Power and Light's Mitsubishi, Model 501G, Unit 1C located at the West County Energy Center on October 5-6, 2009 are summarized in the following table.

**TABLE 2.1  
SUMMARY OF MITSUBISHI, 501G, UNIT #1C RESULTS**

Parameter	Base W/O DB Load	Permit Limits	Base W/DB Load	Permit Limits
Run Duration (min / run)	60	—	60	—
Bar. Pressure (in. Hg)	29.89	—	29.84	—
Amb. Temp. (°F)	95	—	89	—
Rel. Humidity (%)	53	—	71	—
Spec. Humidity (lb water / lb air)	0.019015	—	0.020639	—
Avg. Stack Temp. (°F)	185	—	176	—
Turbine Fuel Flow (lb/min)	1,783	—	1,625	—
Duct Burner Fuel Flow (lb/min)	0	—	196	—
Total Fuel Flow (SCFH)	2,475,658	—	2,529,121	—
Stack Flow (RM19) (SCFH)	56,321,485	—	50,919,043	—
Stack Moisture (% Method 4)	10.0	—	11.3	—
Power Output (megawatts)	241.3	—	248.1	—
NOx (ppmvd)	2.42	—	2.67	—
NOx (ppm@15%O <sub>2</sub> )	1.81	2.00	1.77	2.00
NOx (ppm@15%O <sub>2</sub> &ISO)	2.07	—	2.14	—
NOx (lb/hr)	16.30	20.00	16.22	24.20
NOx (ton/year) at 8760 hr/year	71.39	—	71.03	—
NOx (lb/MMBtu)	0.007	—	0.006	—
CO (ppmvd)	0.33	—	4.11	—
CO (ppm@15%O <sub>2</sub> )	0.25	4.10	2.73	7.60
CO (ppm@15%O <sub>2</sub> &ISO)	0.28	—	3.26	—
CO (lb/hr)	1.35	23.20	15.18	52.50
CO (ton/year) at 8760 hr/year	5.92	—	66.48	—
CO (lb/MMBtu)	0.001	—	0.006	—
VOC (ppmvd)	0.60	—	1.60	—
VOC (ppm@15%O <sub>2</sub> )	0.45	1.20	1.06	1.50
VOC (ppm@15%O <sub>2</sub> &ISO)	0.51	—	1.28	—
VOC (lb/hr)	1.40	4.10	3.39	5.40
VOC (ton/year) at 8760 hr/year	6.14	—	14.83	—
VOC (lb/MMBtu)	0.001	—	0.001	—
Sulfur (gr S/100 scf)	<0.032	2.0000	<0.032	2.0000
NH <sub>3</sub> (ppmvd)	1.93	—	1.87	—
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	1.44	5.00	1.25	5.00
NH <sub>3</sub> (lb/hr)	4.80	—	4.22	—
Opacity (%)	0	10	0	10
CO <sub>2</sub> (%)	4.68	—	5.17	—
O <sub>2</sub> (%)	12.99	—	12.03	—

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol. Total hydrocarbons (THC) were report as VOC. Fuel Analysis, for C1-C6 and fuel sulfur content, was taken on October 5 and 6, 2009. The sample taken on October 6, 2009 contained insufficient sample for a fuel sulfur content analysis. The fuel sulfur content analyses for both October 5 and 6, 2009 were obtained from the October 5, 2009 sample (Appendix E).

### **3.0 SOURCE OPERATION**

#### **3.1 PROCESS DESCRIPTION**

Florida Power and Light (FPL) owns and operates the West County Energy Center (West County) located at 20505 State Road 80 in Loxahatchee, Florida. West County is a nominal 2,500 megawatt (MW) greenfield power plant and consists of two combined cycle units (Unit 1 and 2). Each combined cycle unit consists of: three nominal 250 MW Mitsubishi Model 501G combustion turbine-electrical generator (CTGs) sets with evaporative inlet cooling systems; three supplementary-fired heat recovery steam generators (HRSGs) with selective catalytic reduction (SCR) reactors; one nominal 428 million British thermal units per hour (MMBtu/hour) based on low heat value (LHV) natural gas-fired duct burner (DB) located within each of the three HRSG's; and a common nominal 500 MW steam turbine-electrical generator (STG). The total nominal generating capacity of each of the "3 on 1" combined cycle units is approximately 1,250 MW.

Each CTG has a nominal heat input rate of 2,333 MMBtu/hr when firing natural gas and 2,117 MMBtu/hr when firing distillate fuel oil (based on a compressor inlet air temperature of 59 degrees Fahrenheit (°F), the lower heating value (LHV) of each fuel, and 100 percent load), includes an automated gas turbine control system, and has dual-fuel capability of firing natural gas as the primary fuel or ultra low sulfur distillate (ULSD) fuel oil as a restricted alternate fuel. Each HRSG recovers exhaust, heat energy from each of the CTGs. Each Unit delivers steam to each STG. The efficient combustion of natural gas and restricted firing of ULSD fuel oil minimizes the emissions of carbon monoxide (CO), particulate matter (PM), sulfuric acid mist (H<sub>2</sub>SO<sub>4</sub>), sulfur dioxide (SO<sub>2</sub>) and volatile organic compounds (VOCs). Dry Low-NOx (DLN) combustors for gas firing and water injection for oil firing reduce nitrogen oxides (NOx) emissions. A selective catalyst reduction (SCR) system further reduces NOx emissions.

#### **3.2 SAMPLING LOCATION**

The 501G stack is circular and measures 21.95 feet (ft) (263.38 inches) in diameter at the test ports which are approximately 138 ft above grade level with an exit elevation of approximately 150 ft above grade level. The test ports are located approximately 44.31 ft (531.75 inches) downstream and approximately 12 ft (144 inches) upstream from the nearest disturbances. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from a single point determined after conducting a stratification test (Appendix F). During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time. For NH<sub>3</sub> testing, an initial velocity traverse was performed across the stack at base load from 24 total points. All NH<sub>3</sub> sampling occurred from the same 24 points by leaving the probe at each for an equal amount of time. All opacity observations were made by viewing the point where the exhaust system exited to the atmosphere at the top of the exhaust stack.

## 4.0 SAMPLING AND ANALYTICAL PROCEDURES

### 4.1 TEST METHODS

The emission test on the Mitsubishi, Model 501G, Unit 1C at the West County Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on October 5-6, 2009.

**TABLE 4.1  
SUMMARY OF SAMPLING METHODS**

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	Pitot
Oxygen	EPA Method 3a	Paramagnetic Cell
Carbon Dioxide	EPA Method 3a	Nondispersive Infrared Analyzer
Nitrogen Oxides	EPA Method 7e	Chemiluminescent Analyzer
Opacity	EPA Method 9	Visual Observation
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor
Total Hydrocarbons	EPA Method 25a	Flame Ionization Detector
Ammonia Slip	EPA CTM-027	Ion Chromatography M350.3
Sulfur Content Analysis	ASTM D 6667	Fuel Gas Sample and Laboratory Analysis

### 4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3a, 7e, 9, 10, 19, 25a, and Conditional Test Method (CTM)-027.

Figure 4.1 depicts the sample system used for the NO<sub>x</sub>, CO, THC, CO<sub>2</sub>, and O<sub>2</sub> tests. A stainless steel probe was inserted into the sample ports of the stack to extract gas measurements from the emission stream at a single point in the stack determined after passing an initial stratification test. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the NO<sub>x</sub>, CO, CO<sub>2</sub>, and O<sub>2</sub> analyzers through rotameters that controlled the flow rate of the sample. Exhaust samples were routed to the THC analyzer prior to gas conditioning.



Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in an air-conditioned, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NO<sub>x</sub> calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System Hyperlogger which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. Data records can be found in Appendix A and B of this report.

Figure 4.2 represents the sample system used for the wet chemistry tests (NH<sub>3</sub>). A heated stainless steel probe with an inconel liner and stainless steel nozzle was inserted into the sample ports of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter.

Three test runs of approximately 60 minutes each were conducted on the Mitsubishi, Model 501G, Unit 1C at each of the multiple test loads for NO<sub>x</sub>, CO, THC, CO<sub>2</sub>, NH<sub>3</sub>, opacity, and O<sub>2</sub>.

The stack gas analysis for O<sub>2</sub> and CO<sub>2</sub> concentrations was performed in accordance with procedures set forth in EPA Method 3a. The O<sub>2</sub> analyzer uses a paramagnetic cell detector and the CO<sub>2</sub> analyzer uses a continuous nondispersive infrared analyzer.


EPA Method 7e was used to determine concentrations of NO<sub>x</sub>. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO<sub>2</sub> in nitrogen certified gas cylinder was used to verify at least a 90 percent NO<sub>2</sub> conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

THC emission concentrations were quantified in accordance with procedures set forth in EPA Method 25a. A continuous flame ionization (FID) analyzer was used for this purpose. THC emission concentrations were reported as VOC.

**TABLE 4.2  
ANALYTICAL INSTRUMENTATION**


<b>Parameter</b>	<b>Model and Manufacturer</b>	<b>Range</b>	<b>Sensitivity</b>	<b>Detection Principle</b>
NO <sub>x</sub>	THERMO 42C	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO <sub>2</sub> to NO. Chemiluminescence of reaction of NO with O <sub>3</sub> . Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48C	User may select up to 5,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
CO <sub>2</sub>	CAI 200	0-20%	0.1%	Non-dispersive infrared.
THC	THERMO 51	User may select up to 10,000 ppm	0.1 ppm	Flame Ionization Detector.
O <sub>2</sub>	CAI 200	0-25%	0.1%	Paramagnetic cell, inherently linear.




Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.



Figure 4.1  
**EMISSIONS TESTING LAB**  
 5634 S. 122<sup>nd</sup> East Ave, Suite F  
 Tulsa, Oklahoma 74146  
 www.airhygiene.com  
 (888) 461-8778



View of Probe End (from the bottom)



Wet Chemistry Assembly (photo)





Figure 4.2  
**WET CHEMISTRY ASSEMBLY**  
 5634 S. 122<sup>nd</sup> East Ave, Suite F  
 Tulsa, Oklahoma 74146  
 www.airhygiene.com  
 (888) 461-8778

**APPENDIX A**  
**TEST RESULTS AND CALCULATIONS**

**TABLE A.1:  
EMISSIONS TESTING SCHEDULE**

<b>Unit</b>	<b>Load</b>	<b>Test Type</b>	<b>Run</b>	<b>Date</b>	<b>Start</b>	<b>Stop</b>
1C	Base Load	Stratification Test	1	10/05/09	7:20:07	8:12:07
1C	Base W/O Db	Compliance	1-1	10/05/09	10:00:15	10:59:45
1C	Base W/O Db	Compliance	1-2	10/05/09	11:55:15	12:54:45
1C	Base W/O Db	Compliance	1-3	10/05/09	13:30:15	14:29:45
1C	Base W/Db	Compliance	2-1	10/05/09	17:51:15	18:50:45
1C	Base W/Db	Compliance	2-2	10/05/09	19:05:15	20:04:45
1C	Base W/Db	Compliance	2-3	10/06/09	9:57:28	10:56:58
1C	Base W/O Db	Preliminaries	Base-V1	10/05/09	7:00:00	7:40:00
1C	Base W/O Db	Ammonia	1-1	10/05/09	10:00:00	11:34:00
1C	Base W/O Db	Ammonia	1-2	10/05/09	11:55:00	13:15:00
1C	Base W/O Db	Ammonia	1-3	10/05/09	13:30:00	14:50:00
1C	Base W/DB	Ammonia	2-1	10/05/09	15:42:00	17:25:00
1C	Base W/DB	Ammonia	2-2	10/05/09	17:51:00	19:03:00
1C	Base W/DB	Ammonia	2-3	10/06/09	19:18:00	20:30:00

TABLE A.2  
MITSUBISHI, 501G, UNIT #1C BASE W/O DB LOAD DATA SUMMARY

Parameter	Base W/O Db Load, Run - 1-1	Base W/O Db Load, Run - 1-2	Base W/O Db Load, Run - 1-3	Average
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.88	29.91	29.88	29.89
Amb. Temp. (°F)	91	97	98	95
Rel. Humidity (%)	64	52	44	53
Spec. Humidity (lb water / lb air)	0.020195	0.019710	0.017141	0.019015
Avg. Stack Temp. (°F)	183	185	186	185
Turbine Fuel Flow (lb/min)	1,799	1,779	1,771	1,783
Duct Burner Fuel Flow (lb/min)	0	0	0	0
Total Fuel Flow (SCFH)	2,497,491	2,470,180	2,459,303	2,475,658
Stack Flow (RM19) (SCFH)	56,670,297	56,255,179	56,038,978	56,321,485
Stack Moisture (% Method 4)	11.0	10.2	8.7	10.0
Power Output (megawatts)	244.1	240.8	238.9	241.3
NOx (ppmvd)	2.36	2.46	2.46	2.42
NOx (ppm@15%O <sub>2</sub> )	1.75	1.84	1.83	1.81
NOx (ppm@15%O <sub>2</sub> &ISO)	2.08	2.12	2.02	2.07
NOx (lb/hr)	15.96	16.51	16.43	16.30
NOx (ton/year) at 8760 hr/year	69.89	72.30	71.97	71.39
NOx (lb/MMBtu)	0.006	0.007	0.007	0.007
CO (ppmvd)	0.37	0.41	0.21	0.33
CO (ppm@15%O <sub>2</sub> )	0.28	0.31	0.16	0.25
CO (ppm@15%O <sub>2</sub> &ISO)	0.33	0.35	0.17	0.28
CO (lb/hr)	1.53	1.67	0.85	1.35
CO (ton/year) at 8760 hr/year	6.70	7.33	3.74	5.92
CO (lb/MMBtu)	0.001	0.001	0.000	0.001
VOC (ppmvd)	0.47	0.41	0.92	0.60
VOC (ppm@15%O <sub>2</sub> )	0.35	0.30	0.69	0.45
VOC (ppm@15%O <sub>2</sub> &ISO)	0.41	0.35	0.76	0.51
VOC (lb/hr)	1.10	0.95	2.15	1.40
VOC (ton/year) at 8760 hr/year	4.83	4.16	9.42	6.14
VOC (lb/MMBtu)	0.000	0.000	0.001	0.001
Sulfur (gr S/100 scf)	<0.032	<0.032	<0.032	<0.032
NH <sub>3</sub> (ppmvd)	1.90	1.92	1.98	1.93
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	1.41	1.43	1.48	1.44
NH <sub>3</sub> (lb/hr)	4.76	4.77	4.90	4.81
Opacity (%)	0	0	0	0
CO <sub>2</sub> (%)	4.74	4.65	4.66	4.68
O <sub>2</sub> (%)	12.97	13.00	13.01	12.99

**TABLE A.3  
MITSUBISHI, 501G, UNIT #1C BASE W/DB LOAD DATA SUMMARY**

Parameter	Base W/Db Load, Run - 2-1	Base W/Db Load, Run - 2-2	Base W/Db Load, Run - 2-3	Average
Run Duration (min / run)	60	60	60	60
Bar. Pressure (in. Hg)	29.80	29.83	29.88	29.84
Amb. Temp. (°F)	93	87	86	89
Rel. Humidity (%)	52	74	88	71
Spec. Humidity (lb water / lb air)	0.017433	0.020635	0.023849	0.020639
Avg. Stack Temp. (°F)	173	173	181	176
Turbine Fuel Flow (lb/min)	1,614	1,624	1,638	1,625
Duct Burner Fuel Flow (lb/min)	198	198	192	196
Total Fuel Flow (SCFH)	2,516,237	2,530,124	2,541,002	2,529,121
Stack Flow (RM19) (SCFH)	50,530,276	50,885,020	51,341,833	50,919,043
Stack Moisture (% Method 4)	11.6	11.3	11.0	11.3
Power Output (megawatts)	247.3	248.2	248.9	248.1
NOx (ppmvd)	2.66	2.68	2.67	2.67
NOx (ppm@15%O <sub>2</sub> )	1.76	1.78	1.78	1.77
NOx (ppm@15%O <sub>2</sub> &ISO)	1.97	2.15	2.30	2.14
NOx (lb/hr)	16.03	16.26	16.36	16.22
NOx (ton/year) at 8760 hr/year	70.23	71.21	71.65	71.03
NOx (lb/MMBtu)	0.006	0.007	0.007	0.006
CO (ppmvd)	4.65	4.52	3.15	4.11
CO (ppm@15%O <sub>2</sub> )	3.08	3.00	2.10	2.73
CO (ppm@15%O <sub>2</sub> &ISO)	3.45	3.63	2.71	3.26
CO (lb/hr)	17.07	16.73	11.74	15.18
CO (ton/year) at 8760 hr/year	74.77	73.27	51.41	66.48
CO (lb/MMBtu)	0.007	0.007	0.005	0.006
VOC (ppmvd)	1.97	1.01	1.82	1.60
VOC (ppm@15%O <sub>2</sub> )	1.31	0.67	1.22	1.06
VOC (ppm@15%O <sub>2</sub> &ISO)	1.46	0.81	1.57	1.28
VOC (lb/hr)	4.13	2.14	3.89	3.39
VOC (ton/year) at 8760 hr/year	18.10	9.35	17.03	14.83
VOC (lb/MMBtu)	0.002	0.001	0.002	0.001
Sulfur (gr S/100 scf)	<0.032	<0.032	<0.032	<0.032
NH <sub>3</sub> (ppmvd)	1.78	1.83	2.01	1.87
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	1.18	1.22	1.34	1.25
NH <sub>3</sub> (lb/hr)	3.98	4.12	4.56	4.22
Opacity (%)	0	0	0	0
CO <sub>2</sub> (%)	5.09	5.17	5.24	5.17
O <sub>2</sub> (%)	12.00	12.02	12.06	12.03



**TEST RESULTS**

**NO<sub>x</sub>, CO, VOC, CO<sub>2</sub>, and O<sub>2</sub> Emissions  
Base Load**

Florida Power and Light  
October 5, 2009  
Mitsubishi, 501G, Unit #1C  
West County Energy Center

**Fuel Data**

Fuel Fd factor	8,644	SCF edv/MMBtu
Fuel Heating Value (HV)	998	Btu/SCF fuel
Turbine Fuel Flow	1,799	lb/min
Dust Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,497.491	SCFH

**Weather Data**

Barometric Pressure	29.88	in. Hg
Relative Humidity	64	%
Ambient Temperature	91	°F
Specific Humidity	0.020185	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	244.1	megawatts
Combustor Inlet Pressure	263	psig
Meas. Stack Moisture	11.0	%
Stack Exhaust Flow (M19)	56,670,297	SCFH

Data from: NH3 Run 1

**Base W/O Db Load, Run - 1-1**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmv)	CO (ppmv)	VOC (ppmv)	CO <sub>2</sub> (%)
10/05/09 10:00:15	690	12.97	2.27	0.26	0.51	4.94
10/05/09 10:00:45	720	12.97	2.29	0.25	0.50	4.89
10/05/09 10:01:15	750	12.97	2.29	0.27	0.48	4.87
10/05/09 10:01:45	780	12.96	2.26	0.26	0.53	4.88
10/05/09 10:02:15	810	12.98	2.33	0.22	0.61	4.92
10/05/09 10:02:45	840	12.98	2.31	0.26	0.59	4.90
10/05/09 10:03:15	870	12.98	2.30	0.27	0.54	4.91
10/05/09 10:03:45	900	12.99	2.25	0.23	0.50	4.93
10/05/09 10:04:15	930	12.98	2.23	0.32	0.56	4.88
10/05/09 10:04:45	960	12.98	2.26	0.31	0.53	4.88
10/05/09 10:05:15	990	12.99	2.26	0.19	0.65	4.88
10/05/09 10:05:45	1020	12.98	2.30	0.12	0.59	4.92
10/05/09 10:06:15	1050	12.99	2.35	0.23	0.51	4.88
10/05/09 10:06:45	1080	12.99	2.35	0.21	0.56	4.86
10/05/09 10:07:15	1110	12.99	2.28	0.26	0.54	4.86
10/05/09 10:07:45	1140	12.99	2.35	0.27	0.49	4.80
10/05/09 10:08:15	1170	12.98	2.32	0.23	0.52	4.84
10/05/09 10:08:45	1200	12.99	2.37	0.17	0.57	4.87
10/05/09 10:09:15	1230	13.00	2.30	0.22	0.64	4.88
10/05/09 10:09:45	1260	13.00	2.28	0.21	0.55	4.87
10/05/09 10:10:15	1290	12.99	2.28	0.25	0.53	4.89
10/05/09 10:10:45	1320	12.99	2.33	0.26	0.54	4.84
10/05/09 10:11:15	1350	12.99	2.31	0.25	0.53	4.81
10/05/09 10:11:45	1380	12.99	2.31	0.23	0.60	4.85
10/05/09 10:12:15	1410	12.98	2.27	0.15	0.67	4.84
10/05/09 10:12:45	1440	12.97	2.27	0.23	0.62	4.84
10/05/09 10:13:15	1470	12.97	2.31	0.23	0.65	4.87
10/05/09 10:13:45	1500	12.98	2.31	0.24	0.61	4.86
10/05/09 10:14:15	1530	12.98	2.31	0.22	0.67	4.87
10/05/09 10:14:45	1560	12.97	2.31	0.24	0.67	4.90
10/05/09 10:15:15	1590	12.97	2.28	0.14	0.67	4.93
10/05/09 10:15:45	1620	12.97	2.27	0.19	0.68	4.98
10/05/09 10:16:15	1650	12.98	2.29	0.14	0.62	4.94
10/05/09 10:16:45	1680	12.98	2.32	0.14	0.61	4.98
10/05/09 10:17:15	1710	12.98	2.30	0.07	0.67	4.96
10/05/09 10:17:45	1740	12.98	2.26	0.17	0.68	4.96
10/05/09 10:18:15	1770	12.99	2.26	0.22	0.68	4.95
10/05/09 10:18:45	1800	12.99	2.26	0.18	0.64	4.93
10/05/09 10:19:15	1830	12.97	2.34	0.18	0.67	4.91
10/05/09 10:19:45	1860	12.97	2.34	0.22	0.64	4.92
10/05/09 10:20:15	1890	12.99	2.34	0.22	0.73	4.91
10/05/09 10:20:45	1920	13.00	2.29	0.24	0.71	4.90
10/05/09 10:21:15	1950	13.01	2.28	0.18	0.67	4.91
10/05/09 10:21:45	1980	12.98	2.24	0.22	0.69	4.96
10/05/09 10:22:15	2010	13.00	2.26	0.14	0.69	4.95
10/05/09 10:22:45	2040	13.01	2.25	0.26	0.72	4.95
10/05/09 10:23:15	2070	12.98	2.27	0.20	0.78	4.95
10/05/09 10:23:45	2100	12.98	2.27	0.21	0.74	4.95
10/05/09 10:24:15	2130	12.99	2.30	0.15	0.71	4.91
10/05/09 10:24:45	2160	12.99	2.33	0.20	0.76	4.89
10/05/09 10:25:15	2190	12.99	2.38	0.15	0.70	4.91
10/05/09 10:25:45	2220	12.99	2.36	0.16	0.70	4.92
10/05/09 10:26:15	2250	12.98	2.25	0.22	0.72	4.95
10/05/09 10:26:45	2280	12.98	2.27	0.14	0.73	4.92
10/05/09 10:27:15	2310	12.99	2.27	0.18	0.79	4.92
10/05/09 10:27:45	2340	12.99	2.29	0.20	0.75	4.97
10/05/09 10:28:15	2370	13.00	2.27	0.19	0.73	4.96
10/05/09 10:28:45	2400	13.00	2.27	0.12	0.75	4.95
10/05/09 10:29:15	2430	13.00	2.28	0.24	0.74	4.97
10/05/09 10:29:45	2460	12.99	2.29	0.24	0.72	4.98
10/05/09 10:30:15	2490	12.98	2.30	0.23	0.79	4.96
10/05/09 10:30:45	2520	12.98	2.30	0.22	0.76	4.96
10/05/09 10:31:15	2550	12.98	2.30	0.17	0.84	4.94
10/05/09 10:31:45	2580	12.97	2.29	0.24	0.86	4.86
10/05/09 10:32:15	2610	12.98	2.33	0.14	0.76	4.84
10/05/09 10:32:45	2640	12.98	2.27	0.17	0.73	4.92
10/05/09 10:33:15	2670	12.99	2.34	0.15	0.74	4.87
10/05/09 10:33:45	2700	13.00	2.35	0.10	0.78	4.80
10/05/09 10:34:15	2730	12.99	2.29	0.19	0.81	4.88
10/05/09 10:34:45	2760	12.99	2.21	0.16	0.77	4.90
10/05/09 10:35:15	2790	12.99	2.23	0.16	0.86	4.89
10/05/09 10:35:45	2820	12.99	2.29	0.20	0.82	4.89
10/05/09 10:36:15	2850	12.99	2.26	0.13	0.75	4.89
10/05/09 10:36:45	2880	13.00	2.25	0.21	0.87	4.89
10/05/09 10:37:15	2910	12.99	2.26	0.16	0.89	4.89
10/05/09 10:37:45	2940	12.99	2.27	0.17	0.88	4.89
10/05/09 10:38:15	2970	13.00	2.29	0.14	0.87	4.91
10/05/09 10:38:45	3000	13.00	2.29	0.13	0.89	4.94
10/05/09 10:39:15	3030	13.00	2.28	0.12	0.88	4.94
10/05/09 10:39:45	3060	13.00	2.32	0.16	0.88	5.01
10/05/09 10:40:15	3090	13.00	2.30	0.13	0.87	5.03
10/05/09 10:40:45	3120	13.00	2.30	0.21	0.87	5.01
10/05/09 10:41:15	3150	12.99	2.25	0.16	0.83	5.01
10/05/09 10:41:45	3180	12.99	2.28	0.20	0.82	5.01

Florida Power and Light  
 October 5, 2009  
 Mitsubishi, 501G, Unit #1C  
 West County Energy Center

**Fuel Data**

Fuel Fd Factor	8.644	SCF ext/MBtu
Fuel Heating Value (HRV)	996	Btu/SCF fuel
Turbine Fuel Flow	1,799	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,497.491	SCFH

**Weather Data**

Barometric Pressure	29.88	In. Hg
Relative Humidity	54	%
Ambient Temperature	91	°F
Specific Humidity	0.020195	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	244.1	megawatts
Combustor Inlet Pressure	263	psig
Meas. Stack Moisture	11.0	%
Stack Exhaust Flow (M19)	56,670.297	SCFH

Data from: NHO Run 1

**Base W/O Db Load, Run - 1-1**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
10/05/09 10:42:15	3210	13.00	2.33	0.12	0.89	5.05
10/05/09 10:42:45	3240	13.01	2.34	0.13	0.89	5.03
10/05/09 10:43:15	3270	12.99	2.33	0.12	0.87	4.96
10/05/09 10:43:45	3300	12.99	2.27	0.17	0.89	4.96
10/05/09 10:44:15	3330	13.00	2.33	0.05	0.92	5.00
10/05/09 10:44:45	3360	13.00	2.33	0.11	0.92	5.01
10/05/09 10:45:15	3390	13.00	2.33	0.14	0.88	5.01
10/05/09 10:45:45	3420	13.01	2.28	-0.05	0.89	5.00
10/05/09 10:46:15	3450	13.02	2.26	0.14	0.92	5.01
10/05/09 10:46:45	3480	13.02	2.28	0.08	0.97	5.04
10/05/09 10:47:15	3510	13.01	2.32	0.11	0.97	5.05
10/05/09 10:47:45	3540	13.01	2.28	0.14	0.90	5.04
10/05/09 10:48:15	3570	13.01	2.29	0.08	0.93	5.03
10/05/09 10:48:45	3600	13.02	2.28	0.21	0.93	4.98
10/05/09 10:49:15	3630	13.01	2.28	0.06	0.93	4.99
10/05/09 10:49:45	3660	13.01	2.32	0.10	0.94	5.06
10/05/09 10:50:15	3690	13.01	2.32	0.11	0.91	5.08
10/05/09 10:50:45	3720	13.03	2.35	0.00	0.89	5.04
10/05/09 10:51:15	3750	13.01	2.31	0.03	0.91	5.08
10/05/09 10:51:45	3780	13.00	2.31	0.19	0.98	5.03
10/05/09 10:52:15	3810	13.02	2.36	0.14	0.98	5.08
10/05/09 10:52:45	3840	13.02	2.39	0.07	0.98	5.09
10/05/09 10:53:15	3870	13.02	2.38	0.11	0.92	5.08
10/05/09 10:53:45	3900	13.01	2.32	0.16	1.02	5.04
10/05/09 10:54:15	3930	13.00	2.37	0.14	0.98	5.03
10/05/09 10:54:45	3960	13.01	2.39	0.13	1.00	4.99
10/05/09 10:55:15	3990	13.02	2.39	0.15	0.98	4.99
10/05/09 10:55:45	4020	13.02	2.34	0.14	0.95	4.96
10/05/09 10:56:15	4050	13.03	2.27	0.14	0.99	4.94
10/05/09 10:56:45	4080	13.02	2.32	0.11	0.98	4.99
10/05/09 10:57:15	4110	13.00	2.40	0.06	0.90	4.94
10/05/09 10:57:45	4140	13.00	2.43	0.17	1.00	4.92
10/05/09 10:58:15	4170	13.00	2.37	0.09	0.96	4.93
10/05/09 10:58:45	4200	13.01	2.39	0.11	1.03	4.95
10/05/09 10:59:15	4230	13.02	2.39	0.12	1.08	4.94
10/05/09 10:59:45	4260	13.02	2.28	0.12	1.08	4.99
<b>RAW AVERAGE</b>		<b>12.99</b>	<b>2.30</b>	<b>0.17</b>	<b>0.77</b>	<b>4.94</b>

	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
	(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)
Serial Number: INST-22-0001 INST-NX-0010 INST-CO-0008 INST-TH-0010 INST-22-0001					
Initial Zero	0.02	0.03	0.03	0.29	0.06
Final Zero	-0.01	-0.03	-0.44	0.50	0.41
Avg. Zero	0.01	0.00	-0.21	0.40	0.24
<b>Bias</b>					
Initial UpScale	12.01	4.92	4.91	3.26	9.19
Final UpScale	12.03	4.83	4.70	3.52	9.55
Avg. UpScale	12.02	4.88	4.81	3.39	9.37
<b>Upscale Cal Gas</b>	12.00	4.99	4.94	3.00	9.20

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm% dry basis)	12.97	2.36	0.37	0.47	4.74
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	1.75	0.28	0.35	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISO)	N/A	2.08	0.33	0.41	N/A
Emission Rate (lb/hr)	N/A	15.96	1.53	1.10	N/A
Emission Rate (tons/year) at 8760 hr/yr	N/A	69.89	6.70	4.83	N/A
Emission Rate (lb/MBtu)	N/A	0.006	0.001	0.000	N/A

Florida Power and Light  
October 5, 2009  
Mitsubishi, 601G, Unit #1C  
West County Energy Center

**Fuel Data**

Fuel Factor	8.644	SCF ex/MBtu
Fuel Heating Value (HHV)	996	Btu/SCF fuel
Turbine Fuel Flow	1,779	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,470,180	SCFH

**Weather Data**

Barometric Pressure	29.91	In. Hg
Relative Humidity	52	%
Ambient Temperature	97	°F
Specific Humidity	0.019710	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	240.8	megawatts
Combusor Inlet Pressure	280	psig
Meas. Stack Moisture	10.2	%
Stack Exhaust Flow (M19)	58,256,179	SCFH

Data from: NHG Run 2

**Base W/O Db Load, Run - 1-2**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NO <sub>x</sub> (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
10/05/09 11:45:15	6990	13.03	2.36	0.05	0.54	5.05
10/05/09 11:45:45	7020	13.04	2.40	0.01	0.56	5.09
10/05/09 11:46:15	7050	13.04	2.38	0.08	0.55	5.01
10/05/09 11:46:45	7080	13.03	2.31	0.05	0.57	5.00
10/05/09 11:47:15	7110	13.04	2.35	-0.03	0.52	4.97
10/05/09 11:47:45	7140	13.04	2.38	0.03	0.55	4.99
10/05/09 11:48:15	7170	13.03	2.42	-0.02	0.54	4.99
10/05/09 11:48:45	7200	13.03	2.45	0.00	0.57	5.02
10/05/09 11:49:15	7230	13.03	2.37	0.01	0.56	4.96
10/05/09 11:49:45	7260	13.03	2.29	0.04	0.56	5.01
10/05/09 11:50:15	7290	13.04	2.27	0.04	0.54	5.02
10/05/09 11:50:45	7320	13.04	2.29	0.00	0.53	5.03
10/05/09 11:51:15	7350	13.05	2.26	0.01	0.54	5.07
10/05/09 11:51:45	7380	13.04	2.22	-0.01	0.54	5.09
10/05/09 11:52:15	7410	13.03	2.21	0.06	0.57	5.11
10/05/09 11:52:45	7440	13.03	2.34	-0.08	0.63	5.08
10/05/09 11:53:15	7470	13.03	2.46	0.00	0.57	5.07
10/05/09 11:53:45	7500	13.05	2.41	-0.01	0.58	5.04
10/05/09 11:54:15	7530	13.04	2.30	-0.01	0.60	5.03
10/05/09 11:54:45	7560	13.04	2.33	0.04	0.54	5.05
10/05/09 11:55:15	7590	13.04	2.33	0.02	0.57	5.10
10/05/09 11:55:45	7620	13.05	2.35	0.02	0.65	5.06
10/05/09 11:56:15	7650	13.05	2.31	-0.03	0.55	5.05
10/05/09 11:56:45	7680	13.05	2.23	0.04	0.67	5.08
10/05/09 11:57:15	7710	13.02	2.31	-0.05	0.66	5.13
10/05/09 11:57:45	7740	13.02	2.37	-0.02	0.58	5.15
10/05/09 11:58:15	7770	13.02	2.41	-0.02	0.63	5.09
10/05/09 11:58:45	7800	13.03	2.39	0.00	0.59	5.10
10/05/09 11:59:15	7830	13.04	2.36	-0.15	0.59	5.12
10/05/09 11:59:45	7860	13.05	2.25	0.03	0.74	5.13
10/05/09 12:00:15	7890	13.03	2.28	0.00	0.57	5.16
10/05/09 12:00:45	7920	13.03	2.23	0.01	0.57	5.17
10/05/09 12:01:15	7950	13.03	2.24	0.07	0.64	5.21
10/05/09 12:01:45	7980	13.04	2.35	-0.03	0.64	5.19
10/05/09 12:02:15	8010	13.04	2.37	0.03	0.71	5.12
10/05/09 12:02:45	8040	13.04	2.40	-0.01	0.71	5.01
10/05/09 12:03:15	8070	13.05	2.38	0.07	0.72	4.98
10/05/09 12:03:45	8100	13.04	2.27	0.01	0.72	5.04
10/05/09 12:04:15	8130	13.04	2.33	-0.01	0.69	5.00
10/05/09 12:04:45	8160	13.04	2.30	0.00	0.70	4.94
10/05/09 12:05:15	8190	13.04	2.27	0.04	0.60	5.04
10/05/09 12:05:45	8220	13.03	2.30	0.02	0.67	5.07
10/05/09 12:06:15	8250	13.01	2.32	0.00	0.78	5.07
10/05/09 12:06:45	8280	13.02	2.35	0.01	0.64	5.04
10/05/09 12:07:15	8310	13.05	2.38	0.00	0.75	5.00
10/05/09 12:07:45	8340	13.04	2.31	0.02	0.72	5.01
10/05/09 12:08:15	8370	13.03	2.27	0.04	0.72	5.08
10/05/09 12:08:45	8400	13.03	2.30	-0.02	0.76	5.08
10/05/09 12:09:15	8430	13.04	2.40	0.00	0.81	5.11
10/05/09 12:09:45	8460	13.04	2.33	0.01	0.79	5.12
10/05/09 12:10:15	8490	13.03	2.34	-0.08	0.74	5.12
10/05/09 12:10:45	8520	13.06	2.33	-0.05	0.78	5.10
10/05/09 12:11:15	8550	13.04	2.27	0.00	0.75	5.13
10/05/09 12:11:45	8580	13.03	2.30	-0.02	0.81	5.15
10/05/09 12:12:15	8610	13.04	2.31	-0.01	0.81	5.15
10/05/09 12:12:45	8640	13.05	2.35	-0.02	0.82	5.12
10/05/09 12:13:15	8670	13.05	2.36	0.03	0.81	5.10
10/05/09 12:13:45	8700	13.04	2.39	-0.02	0.78	5.09
10/05/09 12:14:15	8730	13.03	2.35	-0.01	0.77	5.10
10/05/09 12:14:45	8760	13.03	2.45	-0.08	0.84	5.13
10/05/09 12:15:15	8790	13.03	2.35	-0.03	0.81	5.17
10/05/09 12:15:45	8820	13.06	2.40	0.00	0.81	5.13
10/05/09 12:16:15	8850	13.06	2.37	-0.13	0.89	5.07
10/05/09 12:16:45	8880	13.05	2.31	-0.03	0.84	5.09
10/05/09 12:17:15	8910	13.05	2.35	-0.02	0.86	5.12
10/05/09 12:17:45	8940	13.06	2.45	0.01	0.81	5.11
10/05/09 12:18:15	8970	13.05	2.49	0.00	0.86	5.13
10/05/09 12:18:45	9000	13.05	2.50	-0.01	0.82	5.14
10/05/09 12:19:15	9030	13.04	2.44	-0.03	0.81	5.12
10/05/09 12:19:45	9060	13.04	2.43	0.00	0.87	5.11
10/05/09 12:20:15	9090	13.04	2.40	-0.05	0.85	5.15
10/05/09 12:20:45	9120	13.04	2.27	-0.06	0.81	5.17
10/05/09 12:21:15	9150	13.02	2.23	-0.02	0.81	5.12
10/05/09 12:21:45	9180	13.02	2.27	-0.03	0.80	5.05
10/05/09 12:22:15	9210	13.03	2.32	-0.06	0.83	5.09
10/05/09 12:22:45	9240	13.05	2.36	-0.04	0.81	5.08
10/05/09 12:23:15	9270	13.07	2.29	-0.04	0.81	5.07
10/05/09 12:23:45	9300	13.07	2.27	-0.03	0.78	5.09
10/05/09 12:24:15	9330	13.07	2.24	-0.01	0.78	5.09
10/05/09 12:24:45	9360	13.05	2.22	-0.05	0.77	5.08
10/05/09 12:25:15	9390	13.04	2.36	-0.05	0.81	5.12
10/05/09 12:25:45	9420	13.05	2.45	-0.03	0.76	5.11
10/05/09 12:26:15	9450	13.05	2.41	-0.03	0.80	5.11
10/05/09 12:26:45	9480	13.05	2.42	-0.03	0.79	5.11

Florida Power and Light  
October 5, 2009  
Mitsubishi, 501G, Unit #1C  
West County Energy Center

**Fuel Data**

Fuel Fd factor	8.644	SCF oxy/MMBtu
Fuel Heating Value (HRV)	996	Btu/SCF fuel
Turbine Fuel Flow	1.779	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,470,180	SCFH

**Weather Data**

Barometric Pressure	29.91	in. Hg
Relative Humidity	52	%
Ambient Temperature	97	°F
Specific Humidity	0.019710	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	240.8	megawatts
Combustor Inlet Pressure	280	psig
Moist. Stack Molalure	10.2	%
Stack Exhaust Flow (M19)	56,255,179	SCFH

Data from: NH3 Run 2

**Base W/O Db Load, Run - 1-2**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmv d)	CO (ppmv d)	VOC (ppmv w)	CO <sub>2</sub> (%)
10/05/09 12:27:15	9510	13.06	2.33	-0.03	0.78	5.12
10/05/09 12:27:45	9540	13.06	2.32	-0.08	0.83	5.11
10/05/09 12:28:15	9570	13.05	2.29	-0.08	0.76	5.11
10/05/09 12:28:45	9600	13.03	2.33	-0.13	0.78	5.11
10/05/09 12:29:15	9630	13.04	2.37	-0.10	0.82	5.09
10/05/09 12:29:45	9660	13.06	2.50	-0.21	0.79	5.06
10/05/09 12:30:15	9690	13.07	2.53	-0.07	0.81	5.00
10/05/09 12:30:45	9720	13.06	2.42	0.00	0.80	5.06
10/05/09 12:31:15	9750	13.04	2.40	-0.04	0.77	5.06
10/05/09 12:31:45	9780	13.03	2.47	-0.03	0.75	5.06
10/05/09 12:32:15	9810	13.03	2.52	-0.07	0.88	5.02
10/05/09 12:32:45	9840	13.03	2.55	-0.05	0.80	5.01
10/05/09 12:33:15	9870	13.02	2.37	-0.09	0.80	5.01
10/05/09 12:33:45	9900	13.02	2.35	-0.02	0.78	5.03
10/05/09 12:34:15	9930	13.04	2.40	-0.03	0.81	5.06
10/05/09 12:34:45	9960	13.05	2.41	-0.01	0.77	5.08
10/05/09 12:35:15	9990	13.05	2.40	-0.02	0.73	5.10
10/05/09 12:35:45	10020	13.05	2.36	-0.05	0.77	5.07
10/05/09 12:36:15	10050	13.04	2.33	-0.02	0.71	5.09
10/05/09 12:36:45	10080	13.03	2.33	-0.07	0.76	5.10
10/05/09 12:37:15	10110	13.03	2.40	-0.05	0.74	5.08
10/05/09 12:37:45	10140	13.05	2.49	-0.05	0.76	5.07
10/05/09 12:38:15	10170	13.05	2.45	-0.07	0.77	5.06
10/05/09 12:38:45	10200	13.05	2.30	-0.05	0.80	5.09
10/05/09 12:39:15	10230	13.04	2.23	-0.03	0.78	5.10
10/05/09 12:39:45	10260	13.05	2.28	-0.03	0.75	5.12
10/05/09 12:40:15	10290	13.05	2.34	-0.07	0.84	5.06
10/05/09 12:40:45	10320	13.05	2.33	-0.08	0.90	5.06
10/05/09 12:41:15	10350	13.03	2.34	-0.08	0.82	5.09
10/05/09 12:41:45	10380	13.04	2.43	-0.08	0.93	5.10
10/05/09 12:42:15	10410	13.04	2.42	-0.09	0.97	5.10
10/05/09 12:42:45	10440	13.04	2.46	-0.06	0.84	5.10
10/05/09 12:43:15	10470	13.04	2.39	-0.14	0.83	5.10
10/05/09 12:43:45	10500	13.04	2.36	-0.07	0.84	5.15
10/05/09 12:44:15	10530	13.04	2.33	-0.08	0.81	5.14
10/05/09 12:44:45	10560	13.04	2.30	-0.10	0.84	5.13
<b>RAW AVERAGE</b>		<b>13.04</b>	<b>2.35</b>	<b>-0.03</b>	<b>0.73</b>	<b>5.08</b>

Serial Number: INST-22-0001 INST-NX-0010 INST-CO-0008 INST-TH-0010 INST-22-0001

	O <sub>2</sub> (%)	NOx (ppmv d)	CO (ppmv d)	VOC (ppmv w)	CO <sub>2</sub> (%)
Initial Zero	-0.01	-0.03	-0.44	0.50	0.41
Final Zero	-0.03	-0.02	-0.45	0.44	0.56
Avg. Zero	-0.02	-0.03	-0.45	0.47	0.49

Bias	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Initial UpScale	12.03	4.83	4.70	3.07	9.55
Final UpScale	12.04	4.78	4.55	2.95	9.61
Avg. UpScale	12.04	4.81	4.63	3.01	9.58

Upscale Cal Gas 12.00 4.99 4.94 3.00 9.20

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm% dry basis)	13.00	2.46	0.41	0.41	4.65
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	1.84	0.31	0.30	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISD)	N/A	2.12	0.35	0.35	N/A
Emission Rate (lb/hr)	N/A	16.51	1.67	0.95	N/A
Emission Rate (tons/year) at 8760 hr/yr	N/A	72.30	7.33	4.16	N/A
Emission Rate (lb/MMBtu)	N/A	0.007	0.001	0.000	N/A

Florida Power and Light  
October 5, 2009  
Mitsubishi, 501G, Unit #1C  
West County Energy Center

**Fuel Data**

Fuel Fd Factor	8.644	SCF edv/MMBtu
Fuel Heating Value (HRV)	996	Btu/SCF fuel
Turbine Fuel Flow	1.771	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,459,303	SCFH

**Weather Data**

Barometric Pressure	29.88	In. Hg
Relative Humidity	44	%
Ambient Temperature	98	°F
Specific Humidity	0.017141	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	238.9	megawatts
Combustor Inlet Pressure	259	psig
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	56,038,978	SCFH

Data from: NH3 Run 3

**Base W/O Db Load, Run - 1-3**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmv)	CO (ppmv)	VOC (ppmv)	CO <sub>2</sub> (%)
10/05/09 13:30:15	13290	13.05	2.41	-0.15	0.86	5.18
10/05/09 13:30:45	13320	13.04	2.35	-0.15	0.92	5.20
10/05/09 13:31:15	13350	13.04	2.35	-0.11	0.93	5.17
10/05/09 13:31:45	13380	13.06	2.36	-0.11	0.97	5.17
10/05/09 13:32:15	13410	13.05	2.30	-0.13	0.88	5.16
10/05/09 13:32:45	13440	13.05	2.23	-0.18	0.93	5.15
10/05/09 13:33:15	13470	13.04	2.21	-0.07	0.90	5.19
10/05/09 13:33:45	13500	13.05	2.30	-0.11	0.89	5.16
10/05/09 13:34:15	13530	13.04	2.29	-0.10	0.89	5.17
10/05/09 13:34:45	13560	13.02	2.28	-0.11	0.99	5.18
10/05/09 13:35:15	13590	13.01	2.40	-0.10	0.97	5.17
10/05/09 13:35:45	13620	13.03	2.43	-0.11	0.94	5.17
10/05/09 13:36:15	13650	13.04	2.36	-0.10	0.98	5.15
10/05/09 13:36:45	13680	13.04	2.31	-0.09	0.97	5.16
10/05/09 13:37:15	13710	13.03	2.35	-0.10	0.93	5.16
10/05/09 13:37:45	13740	13.05	2.30	-0.12	0.92	5.16
10/05/09 13:38:15	13770	13.06	2.20	-0.13	0.99	5.17
10/05/09 13:38:45	13800	13.03	2.15	-0.12	1.02	5.17
10/05/09 13:39:15	13830	13.02	2.28	-0.13	1.07	5.14
10/05/09 13:39:45	13860	13.04	2.41	-0.14	1.05	5.14
10/05/09 13:40:15	13890	13.03	2.37	-0.08	1.06	5.13
10/05/09 13:40:45	13920	13.03	2.33	-0.10	1.05	5.16
10/05/09 13:41:15	13950	13.04	2.39	-0.15	1.07	5.22
10/05/09 13:41:45	13980	13.05	2.43	-0.16	1.09	5.22
10/05/09 13:42:15	14010	13.04	2.40	-0.14	1.07	5.23
10/05/09 13:42:45	14040	13.02	2.34	-0.14	1.05	5.21
10/05/09 13:43:15	14070	13.03	2.33	-0.20	1.05	5.21
10/05/09 13:43:45	14100	13.04	2.35	-0.14	0.97	5.19
10/05/09 13:44:15	14130	13.07	2.31	-0.12	0.95	5.21
10/05/09 13:44:45	14160	13.05	2.28	-0.10	0.99	5.23
10/05/09 13:45:15	14190	13.02	2.30	-0.09	1.00	5.25
10/05/09 13:45:45	14220	13.01	2.40	-0.17	1.05	5.21
10/05/09 13:46:15	14250	13.02	2.49	-0.16	1.02	5.24
10/05/09 13:46:45	14280	13.03	2.46	-0.16	1.05	5.21
10/05/09 13:47:15	14310	13.05	2.40	-0.17	1.03	5.20
10/05/09 13:47:45	14340	13.05	2.33	-0.11	1.03	5.21
10/05/09 13:48:15	14370	13.04	2.24	-0.18	1.04	5.22
10/05/09 13:48:45	14400	13.05	2.23	-0.15	1.08	5.25
10/05/09 13:49:15	14430	13.05	2.22	-0.15	1.08	5.24
10/05/09 13:49:45	14460	13.05	2.23	-0.14	1.09	5.24
10/05/09 13:50:15	14490	13.04	2.26	-0.14	1.12	5.22
10/05/09 13:50:45	14520	13.04	2.33	-0.16	1.17	5.19
10/05/09 13:51:15	14550	13.03	2.36	-0.16	1.19	5.21
10/05/09 13:51:45	14580	13.03	2.37	-0.17	1.08	5.19
10/05/09 13:52:15	14610	13.04	2.30	-0.18	1.10	5.24
10/05/09 13:52:45	14640	13.05	2.39	-0.12	1.15	5.21
10/05/09 13:53:15	14670	13.03	2.34	-0.15	1.10	5.18
10/05/09 13:53:45	14700	13.01	2.36	-0.19	1.09	5.19
10/05/09 13:54:15	14730	13.03	2.41	-0.15	1.10	5.18
10/05/09 13:54:45	14760	13.02	2.40	-0.17	1.10	5.18
10/05/09 13:55:15	14790	13.04	2.46	-0.14	1.09	5.20
10/05/09 13:55:45	14820	13.03	2.33	-0.15	1.13	5.21
10/05/09 13:56:15	14850	13.05	2.33	-0.17	1.09	5.19
10/05/09 13:56:45	14880	13.04	2.23	-0.23	1.11	5.22
10/05/09 13:57:15	14910	13.04	2.23	-0.21	1.14	5.19
10/05/09 13:57:45	14940	13.01	2.28	-0.15	1.14	5.17
10/05/09 13:58:15	14970	13.03	2.39	-0.16	1.10	5.23
10/05/09 13:58:45	15000	13.03	2.36	-0.18	1.14	5.25
10/05/09 13:59:15	15030	13.04	2.36	-0.12	1.20	5.22
10/05/09 13:59:45	15060	13.06	2.35	-0.12	1.12	5.22
10/05/09 14:00:15	15090	13.02	2.27	-0.16	1.14	5.22
10/05/09 14:00:45	15120	13.03	2.35	-0.19	1.13	5.19
10/05/09 14:01:15	15150	13.01	2.37	-0.18	1.17	5.20
10/05/09 14:01:45	15180	13.03	2.45	-0.20	1.13	5.19
10/05/09 14:02:15	15210	13.04	2.47	-0.19	1.10	5.17
10/05/09 14:02:45	15240	13.05	2.35	-0.16	1.10	5.16
10/05/09 14:03:15	15270	13.05	2.22	-0.14	1.17	5.16
10/05/09 14:03:45	15300	13.03	2.21	-0.16	1.16	5.19
10/05/09 14:04:15	15330	13.03	2.28	-0.17	1.19	5.15
10/05/09 14:04:45	15360	13.04	2.31	-0.18	1.23	5.16
10/05/09 14:05:15	15390	13.05	2.34	-0.18	1.14	5.19
10/05/09 14:05:45	15420	13.07	2.32	-0.15	1.18	5.16
10/05/09 14:06:15	15450	13.04	2.28	-0.14	1.23	5.20
10/05/09 14:06:45	15480	13.04	2.27	-0.20	1.23	5.22
10/05/09 14:07:15	15510	13.04	2.29	-0.16	1.17	5.19
10/05/09 14:07:45	15540	13.00	2.34	-0.20	1.20	5.21
10/05/09 14:08:15	15570	13.00	2.40	-0.32	1.16	5.17
10/05/09 14:08:45	15600	13.00	2.46	-0.19	1.24	5.20
10/05/09 14:09:15	15630	13.03	2.47	-0.20	1.16	5.20
10/05/09 14:09:45	15660	13.03	2.40	-0.15	1.22	5.16
10/05/09 14:10:15	15690	13.05	2.36	-0.22	1.19	5.13
10/05/09 14:10:45	15720	13.06	2.25	-0.15	1.18	5.17
10/05/09 14:11:15	15750	13.03	2.24	-0.22	1.14	5.13
10/05/09 14:11:45	15780	13.04	2.27	-0.21	1.21	5.14

**Florida Power and Light  
October 5, 2009  
Mitsubishi, 501G, Unit #1C  
West County Energy Center**

**Fuel Data**

Fuel Fd factor	8,644	SCF adv/MMBtu
Fuel Heating Value (HHV)	996	Btu/SCF fuel
Turbine Fuel Flow	1,771	lb/min
Duct Burner Fuel Flow	0	lb/min
Total Fuel Flow	2,459,303	SCFH

**Weather Data**

Barometric Pressure	29.88	In. Hg
Relative Humidity	44	%
Ambient Temperature	98	°F
Specific Humidity	0.017141	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	238.8	megawatts
Combustor Inlet Pressure	259	psig
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	56,038,978	SCFH

Data from: NH3 Run 3

**Base W/O Db Load, Run - 1-3**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmv d)	CO (ppmv d)	VOC (ppmv w)	CO <sub>2</sub> (%)
10/05/09 14:12:15	15810	13.02	2.27	-0.23	1.26	5.07
10/05/09 14:12:45	15840	13.03	2.31	-0.20	1.29	5.03
10/05/09 14:13:15	15870	13.05	2.29	-0.22	1.28	5.04
10/05/09 14:13:45	15900	13.05	2.28	-0.26	1.18	5.11
10/05/09 14:14:15	15930	13.04	2.32	-0.28	1.20	5.15
10/05/09 14:14:45	15960	13.05	2.30	-0.14	1.22	5.18
10/05/09 14:15:15	15990	13.02	2.26	-0.21	1.27	5.19
10/05/09 14:15:45	16020	13.02	2.31	-0.14	1.23	5.20
10/05/09 14:16:15	16050	13.03	2.37	-0.16	1.28	5.16
10/05/09 14:16:45	16080	13.02	2.45	-0.27	1.22	5.14
10/05/09 14:17:15	16110	13.03	2.48	-0.18	1.13	5.14
10/05/09 14:17:45	16140	13.04	2.45	-0.16	1.19	5.14
10/05/09 14:18:15	16170	13.05	2.40	-0.18	1.13	5.08
10/05/09 14:18:45	16200	13.03	2.29	-0.20	1.26	5.12
10/05/09 14:19:15	16230	13.02	2.23	-0.13	1.15	5.20
10/05/09 14:19:45	16260	13.03	2.30	-0.17	1.21	5.21
10/05/09 14:20:15	16290	13.06	2.30	-0.18	1.13	5.17
10/05/09 14:20:45	16320	13.04	2.32	-0.17	1.22	5.17
10/05/09 14:21:15	16350	13.01	2.25	-0.14	1.22	5.22
10/05/09 14:21:45	16380	13.02	2.28	-0.22	1.14	5.24
10/05/09 14:22:15	16410	13.05	2.32	-0.19	1.22	5.20
10/05/09 14:22:45	16440	13.05	2.32	-0.25	1.28	5.23
10/05/09 14:23:15	16470	13.05	2.27	-0.13	1.20	5.27
10/05/09 14:23:45	16500	13.04	2.28	-0.17	1.11	5.27
10/05/09 14:24:15	16530	13.04	2.34	-0.25	1.14	5.22
10/05/09 14:24:45	16560	13.03	2.30	-0.19	1.19	5.21
10/05/09 14:25:15	16590	13.03	2.33	-0.18	1.24	5.19
10/05/09 14:25:45	16620	13.04	2.41	-0.21	1.29	5.12
10/05/09 14:26:15	16650	13.04	2.43	-0.22	1.22	5.13
10/05/09 14:26:45	16680	13.02	2.39	-0.25	1.26	5.15
10/05/09 14:27:15	16710	13.02	2.42	-0.33	1.25	5.16
10/05/09 14:27:45	16740	13.02	2.46	-0.28	1.24	5.18
10/05/09 14:28:15	16770	13.04	2.55	-0.28	1.28	5.19
10/05/09 14:28:45	16800	13.04	2.47	-0.23	1.26	5.24
10/05/09 14:29:15	16830	13.02	2.44	-0.19	1.23	5.25
10/05/09 14:29:45	16860	13.03	2.28	-0.25	1.24	5.27
<b>RAW AVERAGE</b>		<b>13.04</b>	<b>2.34</b>	<b>-0.17</b>	<b>1.12</b>	<b>5.19</b>

	O <sub>2</sub> (%)	NOx (ppmv d)	CO (ppmv d)	VOC (ppmv w)	CO <sub>2</sub> (%)
Serial Number: INST-22-0001	INST-AX-0010	INST-CO-0008	INST-TH-0010	INST-22-0001	
Initial Zero	-0.03	-0.02	-0.45	0.44	0.56
Final Zero	-0.04	-0.02	-0.30	0.34	0.67
Avg. Zero	-0.04	-0.02	-0.38	0.39	0.62
Initial UpScale	12.04	4.78	4.55	2.95	9.61
Final UpScale	12.01	4.76	4.40	3.26	9.67
Avg. UpScale	12.03	4.77	4.48	3.11	9.64
<b>Upscale Cal Gas</b>	<b>12.00</b>	<b>4.99</b>	<b>4.94</b>	<b>3.00</b>	<b>9.20</b>

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm% dry basis)	13.01	2.46	0.21	0.92	4.66
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	1.83	0.16	0.69	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISO)	N/A	2.02	0.17	0.76	N/A
Emission Rate (lb/hr)	N/A	16.43	0.85	2.15	N/A
Emission Rate (tons/year) at 8760 hr/yr	N/A	71.97	3.74	9.42	N/A
Emission Rate (lb/MMBtu)	N/A	0.007	0.000	0.001	N/A

**TEST RESULTS**

**NO<sub>x</sub>, CO, VOC, CO<sub>2</sub>, and O<sub>2</sub> Emissions  
Base Load with Duct Burners**



Florida Power and Light  
October 5, 2009  
Mitsubishi, 501G, Unit #1C  
West County Energy Center

**Fuel Data**

Fuel Fd factor	8.649	SCF exh/MMBtu
Fuel Heating Value (HRV)	998	Btu/SCF fuel
Turbine Fuel Flow	1,614	lb/min
Duct Burner Fuel Flow	198	lb/min
Total Fuel Flow	2,516.237	SCFH

**Weather Data**

Barometric Pressure	29.90	in. Hg
Relative Humidity	52	%
Ambient Temperature	93	°F
Specific Humidity	0.017433	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	247.3	megawatts
Combustor Inlet Pressure	264	psig
Meas. Stack Moisture	11.8	%
Stack Exhaust Flow (M19)	50,530.276	SCFH

Data from: NH3 Run 1

**Base W/Db Load, Run - 2-1**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
10/05/09 17:51:15	28950	11.99	2.51	4.24	1.64	5.02
10/05/09 17:51:45	28980	11.99	2.47	4.10	1.89	5.06
10/05/09 17:52:15	29010	11.99	2.51	4.29	1.80	5.03
10/05/09 17:52:45	29040	12.00	2.49	4.22	1.84	5.07
10/05/09 17:53:15	29070	12.01	2.51	4.27	1.93	4.99
10/05/09 17:53:45	29100	12.02	2.43	4.29	1.90	4.98
10/05/09 17:54:15	29130	11.98	2.40	4.23	2.12	5.05
10/05/09 17:54:45	29160	11.99	2.46	4.41	1.98	5.10
10/05/09 17:55:15	29190	12.01	2.48	4.25	1.66	5.14
10/05/09 17:55:45	29220	12.00	2.47	4.07	1.72	5.11
10/05/09 17:56:15	29250	12.00	2.55	4.16	1.61	5.09
10/05/09 17:56:45	29280	12.00	2.58	4.11	1.95	5.07
10/05/09 17:57:15	29310	12.00	2.53	4.26	1.72	5.05
10/05/09 17:57:45	29340	12.00	2.52	4.15	1.87	5.00
10/05/09 17:58:15	29370	12.00	2.51	4.09	1.49	4.99
10/05/09 17:58:45	29400	12.01	2.52	4.12	1.89	4.99
10/05/09 17:59:15	29430	12.00	2.51	4.16	1.39	4.98
10/05/09 17:59:45	29460	12.01	2.52	3.98	1.70	5.00
10/05/09 18:00:15	29490	11.98	2.50	4.12	1.71	4.95
10/05/09 18:00:45	29520	11.99	2.47	4.15	1.94	4.91
10/05/09 18:01:15	29550	12.00	2.49	4.23	1.94	4.77
10/05/09 18:01:45	29580	12.00	2.52	4.28	2.00	4.94
10/05/09 18:02:15	29610	12.00	2.51	4.32	1.80	4.93
10/05/09 18:02:45	29640	12.00	2.53	4.28	1.85	4.94
10/05/09 18:03:15	29670	11.99	2.48	4.29	1.87	4.96
10/05/09 18:03:45	29700	11.99	2.52	4.23	1.94	4.82
10/05/09 18:04:15	29730	11.99	2.56	4.25	1.78	4.93
10/05/09 18:04:45	29760	12.00	2.53	4.35	2.21	4.96
10/05/09 18:05:15	29790	12.00	2.50	4.41	1.67	4.88
10/05/09 18:05:45	29820	12.00	2.51	4.19	1.81	4.97
10/05/09 18:06:15	29850	12.00	2.46	4.24	1.85	5.01
10/05/09 18:06:45	29880	12.00	2.50	4.17	1.90	4.98
10/05/09 18:07:15	29910	12.00	2.52	4.17	1.70	4.96
10/05/09 18:07:45	29940	11.99	2.52	4.05	1.43	5.02
10/05/09 18:08:15	29970	11.99	2.53	3.95	1.78	5.01
10/05/09 18:08:45	30000	11.99	2.58	4.21	1.58	5.04
10/05/09 18:09:15	30030	12.01	2.60	4.10	1.70	5.05
10/05/09 18:09:45	30060	12.01	2.49	4.18	1.82	4.97
10/05/09 18:10:15	30090	12.01	2.44	4.25	1.76	4.95
10/05/09 18:10:45	30120	12.01	2.41	4.27	1.77	4.99
10/05/09 18:11:15	30150	12.00	2.46	4.16	1.42	4.98
10/05/09 18:11:45	30180	11.99	2.55	4.14	1.87	4.99
10/05/09 18:12:15	30210	11.99	2.67	4.26	1.79	4.98
10/05/09 18:12:45	30240	11.98	2.72	4.18	1.77	4.99
10/05/09 18:13:15	30270	11.99	2.76	4.15	1.59	5.00
10/05/09 18:13:45	30300	11.98	2.76	4.12	1.46	5.07
10/05/09 18:14:15	30330	11.98	2.77	4.04	1.65	5.06
10/05/09 18:14:45	30360	11.99	2.74	4.04	1.58	5.05
10/05/09 18:15:15	30390	12.00	2.64	4.04	1.54	5.01
10/05/09 18:15:45	30420	12.01	2.64	4.06	1.58	5.02
10/05/09 18:16:15	30450	11.98	2.60	4.02	1.53	4.98
10/05/09 18:16:45	30480	11.98	2.63	4.03	1.58	4.95
10/05/09 18:17:15	30510	11.97	2.67	4.12	1.83	3.69
10/05/09 18:17:45	30540	11.98	2.70	4.21	1.55	4.75
10/05/09 18:18:15	30570	12.00	2.68	4.08	1.53	5.03
10/05/09 18:18:45	30600	12.00	2.65	4.00	1.74	5.00
10/05/09 18:19:15	30630	12.00	2.59	4.01	1.55	4.94
10/05/09 18:19:45	30660	11.99	2.60	4.03	1.80	4.96
10/05/09 18:20:15	30690	11.99	2.63	4.24	1.81	4.92
10/05/09 18:20:45	30720	11.99	2.64	4.30	1.72	4.77
10/05/09 18:21:15	30750	11.99	2.66	4.28	1.73	4.92
10/05/09 18:21:45	30780	11.99	2.67	4.23	1.74	4.93
10/05/09 18:22:15	30810	11.98	2.64	4.18	1.91	4.83
10/05/09 18:22:45	30840	12.00	2.61	4.32	1.58	4.92
10/05/09 18:23:15	30870	11.99	2.58	4.15	1.74	5.04
10/05/09 18:23:45	30900	12.00	2.58	4.13	1.17	5.00
10/05/09 18:24:15	30930	12.01	2.59	3.83	1.41	5.02
10/05/09 18:24:45	30960	12.01	2.57	3.98	1.71	5.05
10/05/09 18:25:15	30990	11.99	2.52	4.14	1.75	5.00
10/05/09 18:25:45	31020	11.99	2.53	4.22	1.75	4.99
10/05/09 18:26:15	31050	12.01	2.58	4.14	2.02	5.05
10/05/09 18:26:45	31080	12.00	2.58	4.28	1.87	5.08
10/05/09 18:27:15	31110	11.98	2.61	4.24	1.80	5.04
10/05/09 18:27:45	31140	11.98	2.57	4.26	1.63	4.99
10/05/09 18:28:15	31170	11.98	2.57	4.17	1.89	5.03
10/05/09 18:28:45	31200	11.99	2.58	4.23	1.90	5.03
10/05/09 18:29:15	31230	12.00	2.62	4.22	1.53	5.06
10/05/09 18:29:45	31260	12.00	2.62	4.05	1.87	5.10
10/05/09 18:30:15	31290	12.00	2.62	4.22	1.83	5.08
10/05/09 18:30:45	31320	12.00	2.54	4.21	1.80	5.06
10/05/09 18:31:15	31350	12.01	2.58	4.16	1.69	5.00
10/05/09 18:31:45	31380	12.01	2.53	4.12	1.66	5.00
10/05/09 18:32:15	31410	12.00	2.52	4.07	1.34	4.98
10/05/09 18:32:45	31440	12.01	2.52	3.95	1.49	5.01

Florida Power and Light  
October 5, 2009  
Mitsubishi, 501G, Unit #1C  
West County Energy Center

**Fuel Data**

Fuel Fd factor	8.649	SCF edy/MMBtu
Fuel Heating Value (HHV)	988	Btu/SCF fuel
Turbine Fuel Flow	1,614	lb/min
Duct Burner Fuel Flow	198	lb/min
Total Fuel Flow	2,518,237	SCFH

**Weather Data**

Barometric Pressure	29.80	in. Hg
Relative Humidity	52	%
Ambient Temperature	93	°F
Specific Humidity	0.017433	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	247.3	megawatts
Combustor Inlet Pressure	204	psig
Meas. Stack Moisture	11.6	%
Stack Exhaust Flow (M19)	50,530,276	SCFH

Data from NH3 Run 1

**Base W/Db Load, Run - 2-1**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
10/05/09 18:33:15	31470	12.01	2.55	4.04	1.65	5.02
10/05/09 18:33:45	31500	12.00	2.54	4.02	1.12	4.74
10/05/09 18:34:15	31530	12.00	2.52	3.78	1.51	5.02
10/05/09 18:34:45	31560	11.99	2.53	3.95	1.54	5.06
10/05/09 18:35:15	31590	12.00	2.59	4.07	1.73	5.09
10/05/09 18:35:45	31620	12.00	2.50	4.12	1.62	5.02
10/05/09 18:36:15	31650	12.01	2.46	4.10	1.36	5.00
10/05/09 18:36:45	31680	12.02	2.46	4.02	1.77	4.59
10/05/09 18:37:15	31710	12.01	2.50	4.17	1.89	5.08
10/05/09 18:37:45	31740	12.00	2.54	4.32	1.79	5.07
10/05/09 18:38:15	31770	11.99	2.58	4.27	1.81	5.08
10/05/09 18:38:45	31800	12.01	2.58	4.21	1.60	5.07
10/05/09 18:39:15	31830	12.01	2.55	4.13	1.87	5.05
10/05/09 18:39:45	31860	12.01	2.49	4.28	1.95	5.02
10/05/09 18:40:15	31890	12.00	2.52	4.22	1.53	4.98
10/05/09 18:40:45	31920	12.00	2.50	4.04	1.77	5.06
10/05/09 18:41:15	31950	12.03	2.49	4.16	1.79	4.97
10/05/09 18:41:45	31980	12.01	2.50	4.25	1.75	5.13
10/05/09 18:42:15	32010	12.00	2.50	4.27	1.87	5.14
10/05/09 18:42:45	32040	12.00	2.56	4.28	1.57	5.08
10/05/09 18:43:15	32070	11.99	2.62	4.05	1.35	5.09
10/05/09 18:43:45	32100	12.00	2.64	3.98	1.73	5.13
10/05/09 18:44:15	32130	12.00	2.70	4.11	1.48	5.11
10/05/09 18:44:45	32160	12.00	2.58	4.10	1.86	5.12
10/05/09 18:45:15	32190	12.00	2.53	4.32	2.07	5.06
10/05/09 18:45:45	32220	12.00	2.56	4.45	1.76	5.10
10/05/09 18:46:15	32250	12.02	2.48	4.29	1.68	5.12
10/05/09 18:46:45	32280	12.03	2.53	4.18	1.93	5.14
10/05/09 18:47:15	32310	11.99	2.52	4.33	1.59	5.14
10/05/09 18:47:45	32340	11.99	2.57	4.14	1.42	5.06
10/05/09 18:48:15	32370	12.01	2.63	4.14	1.75	5.04
10/05/09 18:48:45	32400	12.00	2.61	4.36	2.13	5.05
10/05/09 18:49:15	32430	12.01	2.61	4.45	1.63	5.06
10/05/09 18:49:45	32460	12.01	2.54	4.24	1.67	5.04
10/05/09 18:50:15	32490	11.99	2.57	4.16	1.81	5.01
10/05/09 18:50:45	32520	12.00	2.59	4.23	1.81	5.03

**RAW AVERAGE**

O<sub>2</sub> 12.00 NOx 2.56 CO 4.17 VOC 1.72 CO<sub>2</sub> 5.00

Serial Number: INST-22-0001 INST-NX-0010 INST-CO-0008 INST-TH-0010 INST-22-0001

	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
Initial Zero	-0.05	0.00	-0.45	0.00	0.01
Final Zero	-0.03	0.01	-0.45	-0.01	0.05
Avg. Zero	-0.04	0.01	-0.45	-0.01	0.03
Initial UpScale	12.00	4.81	4.47	2.87	9.06
Final UpScale	11.99	4.79	4.45	3.07	8.96
Avg. UpScale	12.00	4.80	4.46	2.97	9.01

**Upscale Cal Gas**

O<sub>2</sub> 12.00 NOx 4.99 CO 4.94 VOC 3.00 CO<sub>2</sub> 9.20

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm% dry basis)	12.00	2.66	4.65	1.97	5.09
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	1.76	3.08	1.31	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISO)	N/A	1.97	3.45	1.46	N/A
Emission Rate (lb/hr)	N/A	16.03	17.07	4.13	N/A
Emission Rate (tons/year) at 8760 hr/yr	N/A	70.23	74.77	18.10	N/A
Emission Rate (lb/MMBtu)	N/A	0.006	0.007	0.002	N/A

Florida Power and Light  
 October 5, 2009  
 Mitsubishi, 501G, Unit #1C  
 West County Energy Center

**Fuel Data**

Fuel Fd factor	8.649	SCF exH/MBtu
Fuel Heating Value (HHV)	988	Btu/SCF fuel
Turbine Fuel Flow	1,624	B/min
Duct Burner Fuel Flow	198	B/min
Total Fuel Flow	2,530,124	SCFH

**Weather Data**

Barometric Pressure	29.83	In. Hg
Relative Humidity	74	%
Ambient Temperature	87	°F
Specific Humidity	0.020635	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	248.2	megawatts
Combustion Inlet Pressure	265	psig
Meas. Stack Moisture	11.3	%
Stack Exhaust Flow (M19)	50,885,020	SCFH

Data from: NH3 Run 2

**Base W/D6 Load, Run - 2.2**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvv)	CO <sub>2</sub> (%)
10/05/09 19:05:15	33390	11.97	2.61	4.36	2.26	5.06
10/05/09 19:05:45	33420	11.98	2.60	4.21	1.81	5.11
10/05/09 19:06:15	33450	12.01	2.60	4.07	2.06	5.13
10/05/09 19:06:45	33480	12.00	2.59	4.20	2.09	5.13
10/05/09 19:07:15	33510	12.00	2.56	4.24	1.98	5.13
10/05/09 19:07:45	33540	12.00	2.53	4.12	2.13	5.08
10/05/09 19:08:15	33570	11.99	2.54	4.18	2.35	5.11
10/05/09 19:08:45	33600	12.00	2.60	4.23	1.83	5.13
10/05/09 19:09:15	33630	12.00	2.55	4.10	2.14	5.16
10/05/09 19:09:45	33660	12.01	2.57	4.16	1.84	5.16
10/05/09 19:10:15	33690	11.99	2.50	4.04	2.29	5.16
10/05/09 19:10:45	33720	12.01	2.58	4.27	1.83	5.13
10/05/09 19:11:15	33750	11.99	2.50	4.08	2.32	5.14
10/05/09 19:11:45	33780	11.99	2.56	4.35	2.08	5.10
10/05/09 19:12:15	33810	12.00	2.52	4.34	2.47	5.12
10/05/09 19:12:45	33840	12.00	2.52	4.46	2.20	5.11
10/05/09 19:13:15	33870	12.00	2.58	4.30	2.08	5.15
10/05/09 19:13:45	33900	11.98	2.51	4.22	2.15	5.19
10/05/09 19:14:15	33930	12.00	2.56	4.34	2.24	5.20
10/05/09 19:14:45	33960	11.98	2.56	4.29	0.93	5.13
10/05/09 19:15:15	33990	12.00	2.52	4.28	0.90	5.11
10/05/09 19:15:45	34020	12.00	2.53	4.10	0.88	5.14
10/05/09 19:16:15	34050	12.07	2.56	4.21	0.97	5.10
10/05/09 19:16:45	34080	12.01	2.52	4.13	0.98	5.19
10/05/09 19:17:15	34110	11.98	2.57	4.26	1.03	5.13
10/05/09 19:17:45	34140	11.98	2.66	4.37	0.92	4.97
10/05/09 19:18:15	34170	11.97	2.61	4.28	0.77	4.99
10/05/09 19:18:45	34200	11.99	2.61	4.10	0.97	5.02
10/05/09 19:19:15	34230	11.99	2.56	4.35	0.88	5.05
10/05/09 19:19:45	34260	11.99	2.58	4.28	0.90	5.11
10/05/09 19:20:15	34290	11.99	2.59	4.18	0.84	5.10
10/05/09 19:20:45	34320	11.98	2.57	4.28	1.00	5.07
10/05/09 19:21:15	34350	11.98	2.66	4.39	0.80	5.08
10/05/09 19:21:45	34380	11.98	2.66	4.25	0.90	5.12
10/05/09 19:22:15	34410	11.98	2.68	4.25	0.86	5.20
10/05/09 19:22:45	34440	11.98	2.68	4.17	0.87	5.12
10/05/09 19:23:15	34470	11.96	2.69	4.25	1.02	5.09
10/05/09 19:23:45	34500	11.97	2.67	4.38	0.88	5.12
10/05/09 19:24:15	34530	11.99	2.62	4.24	0.77	4.98
10/05/09 19:24:45	34560	11.99	2.56	4.16	0.86	5.03
10/05/09 19:25:15	34590	11.99	2.59	4.25	0.80	5.05
10/05/09 19:25:45	34620	11.98	2.58	4.20	0.60	5.04
10/05/09 19:26:15	34650	11.98	2.59	4.15	0.90	5.06
10/05/09 19:26:45	34680	11.97	2.55	4.25	0.90	5.04
10/05/09 19:27:15	34710	12.00	2.60	4.18	0.85	5.00
10/05/09 19:27:45	34740	12.00	2.62	4.21	0.88	4.93
10/05/09 19:28:15	34770	11.99	2.63	4.29	0.67	4.85
10/05/09 19:28:45	34800	12.00	2.61	4.13	0.85	4.89
10/05/09 19:29:15	34830	12.00	2.57	4.21	0.58	4.89
10/05/09 19:29:45	34860	11.99	2.58	4.12	0.73	4.92
10/05/09 19:30:15	34890	12.00	2.57	4.12	0.59	4.77
10/05/09 19:30:45	34920	11.99	2.58	3.97	0.63	4.97
10/05/09 19:31:15	34950	12.01	2.62	4.14	0.61	5.01
10/05/09 19:31:45	34980	11.99	2.53	4.06	0.77	5.06
10/05/09 19:32:15	35010	11.99	2.48	4.19	0.60	5.04
10/05/09 19:32:45	35040	12.00	2.41	4.11	0.58	5.00
10/05/09 19:33:15	35070	12.00	2.56	4.12	0.67	4.99
10/05/09 19:33:45	35100	12.01	2.65	4.28	0.49	4.97
10/05/09 19:34:15	35130	12.00	2.59	4.08	0.75	5.00
10/05/09 19:34:45	35160	12.00	2.63	4.26	0.69	5.00
10/05/09 19:35:15	35190	11.99	2.56	4.18	0.57	5.00
10/05/09 19:35:45	35220	12.00	2.58	4.11	0.70	5.01
10/05/09 19:36:15	35250	12.01	2.55	4.12	0.58	5.01
10/05/09 19:36:45	35280	12.01	2.57	3.99	0.53	4.97
10/05/09 19:37:15	35310	12.01	2.61	3.99	0.60	4.99
10/05/09 19:37:45	35340	12.01	2.58	3.97	0.57	5.00
10/05/09 19:38:15	35370	12.00	2.64	3.96	0.54	5.03
10/05/09 19:38:45	35400	12.01	2.64	4.00	0.51	5.00
10/05/09 19:39:15	35430	12.02	2.56	3.83	0.59	5.01
10/05/09 19:39:45	35460	12.02	2.59	3.79	0.47	4.98
10/05/09 19:40:15	35490	12.01	2.55	3.77	0.65	4.97
10/05/09 19:40:45	35520	12.02	2.57	3.91	0.67	5.00
10/05/09 19:41:15	35550	12.02	2.60	3.97	0.64	5.05
10/05/09 19:41:45	35580	12.02	2.65	3.85	0.62	5.04
10/05/09 19:42:15	35610	12.01	2.64	3.92	0.46	5.02
10/05/09 19:42:45	35640	12.01	2.65	3.70	0.52	5.00
10/05/09 19:43:15	35670	12.02	2.57	3.72	0.49	5.01
10/05/09 19:43:45	35700	12.01	2.58	3.75	0.40	4.97
10/05/09 19:44:15	35730	12.02	2.60	3.81	0.62	4.92
10/05/09 19:44:45	35760	12.01	2.55	3.98	0.54	5.01
10/05/09 19:45:15	35790	12.03	2.58	3.86	0.48	5.04
10/05/09 19:45:45	35820	12.03	2.62	3.86	0.56	5.00
10/05/09 19:46:15	35850	12.02	2.63	3.86	0.50	4.96
10/05/09 19:46:45	35880	12.02	2.53	3.85	0.41	5.02

Florida Power and Light  
October 5, 2009  
Mitsubishi, 501G, Unit #1C  
West County Energy Center

**Fuel Data**

Fuel Fd factor	6.849	SCF exh/MMBtu
Fuel Heating Value (HRV)	988	Btu/SCF fuel
Turbine Fuel Flow	1.624	lb/min
Duct Burner Fuel Flow	198	lb/min
Total Fuel Flow	2,530,124	SCFH

**Weather Data**

Barometric Pressure	29.83	in. Hg
Relative Humidity	74	%
Ambient Temperature	87	°F
Specific Humidity	0.020635	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	248.2	megawatts
Combustor Inlet Pressure	265	psig
Mass Stack Molar	11.3	%
Stack Exhaust Flow (M19)	50,885,020	SCFH

Data from: NHD Run 2

**Base W/Db Load, Run - 2-2**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
10/05/09 19:47:15	35910	12.04	2.55	3.74	0.49	4.99
10/05/09 19:47:45	35940	12.04	2.54	3.75	0.53	4.99
10/05/09 19:48:15	35970	12.03	2.58	3.87	0.47	5.01
10/05/09 19:48:45	36000	12.04	2.60	3.87	0.49	4.95
10/05/09 19:49:15	36030	12.03	2.64	3.86	0.56	4.95
10/05/09 19:49:45	36060	12.02	2.59	3.91	0.44	4.96
10/05/09 19:50:15	36090	12.01	2.59	3.75	0.55	4.93
10/05/09 19:50:45	36120	12.01	2.57	3.84	0.43	4.90
10/05/09 19:51:15	36150	12.02	2.54	3.79	0.57	4.94
10/05/09 19:51:45	36180	12.02	2.57	3.90	0.43	5.01
10/05/09 19:52:15	36210	12.01	2.55	3.84	0.42	5.01
10/05/09 19:52:45	36240	12.01	2.59	3.81	0.62	4.98
10/05/09 19:53:15	36270	12.02	2.58	3.85	0.34	5.03
10/05/09 19:53:45	36300	12.03	2.66	3.59	0.56	5.03
10/05/09 19:54:15	36330	12.03	2.59	3.96	0.49	5.04
10/05/09 19:54:45	36360	12.02	2.52	3.77	0.57	5.03
10/05/09 19:55:15	36390	12.04	2.58	3.95	0.63	5.05
10/05/09 19:55:45	36420	12.03	2.57	4.08	0.39	5.02
10/05/09 19:56:15	36450	12.03	2.57	3.77	0.49	5.03
10/05/09 19:56:45	36480	12.02	2.60	3.75	0.50	5.03
10/05/09 19:57:15	36510	12.02	2.62	3.76	0.58	5.04
10/05/09 19:57:45	36540	12.02	2.62	3.92	0.64	5.00
10/05/09 19:58:15	36570	12.01	2.64	3.92	0.48	5.01
10/05/09 19:58:45	36600	12.02	2.66	3.80	0.43	5.01
10/05/09 19:59:15	36630	12.03	2.59	3.83	0.47	4.98
10/05/09 19:59:45	36660	12.02	2.53	3.83	0.54	5.00
10/05/09 20:00:15	36690	12.03	2.56	3.89	0.48	4.96
10/05/09 20:00:45	36720	12.03	2.59	3.86	0.51	4.96
10/05/09 20:01:15	36750	12.03	2.59	4.06	0.49	4.92
10/05/09 20:01:45	36780	12.03	2.57	3.86	0.52	4.90
10/05/09 20:02:15	36810	12.02	2.59	3.95	0.48	4.93
10/05/09 20:02:45	36840	12.03	2.56	4.05	0.53	4.95
10/05/09 20:03:15	36870	12.01	2.56	4.00	0.56	4.96
10/05/09 20:03:45	36900	12.01	2.66	4.02	0.58	5.00
10/05/09 20:04:15	36930	12.03	2.64	4.06	0.52	4.97
10/05/09 20:04:45	36960	12.01	2.59	4.01	0.48	5.00

**RAW AVERAGE**

	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
Serial Number:	INST-22-0001	INST-NX-0010	INST-CO-0008	INST-TH-0010	INST-22-0001
Initial Zero	-0.03	0.01	-0.45	-0.01	0.05
Final Zero	-0.06	0.06	-0.44	0.01	-0.15
Avg. Zero	-0.05	0.04	-0.45	0.00	-0.05
Initial UpScale	11.99	4.79	4.45	3.07	8.96
Final UpScale	11.99	4.79	4.48	2.78	9.00
Avg. UpScale	11.99	4.79	4.47	2.93	8.98
Upscale Cal Gas	12.00	4.99	4.94	3.00	9.20

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm% dry basis)	12.02	2.68	4.52	1.01	5.17
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	1.78	3.00	0.67	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISO)	N/A	2.15	3.63	0.81	N/A
Emission Rate (lb/hr)	N/A	16.26	16.73	2.14	N/A
Emission Rate (tons/year) at 8760 hr/yr	N/A	71.21	73.27	9.35	N/A
Emission Rate (lb/MMBtu)	N/A	0.007	0.007	0.001	N/A

Florida Power and Light  
October 6, 2009  
Mitsubishi, 501G, Unit #1C  
West County Energy Center

**Fuel Data**

Fuel Fd factor	8.649	SCF cub/MMBtu
Fuel Heating Value (HHV)	993	Btu/SCF fuel
Turbine Fuel Flow	1,638	lb/min
Duct Burner Fuel Flow	192	lb/min
Total Fuel Flow	2,341,002	SCFH

**Weather Data**

Barometric Pressure	29.88	In. Hg
Relative Humidity	88	%
Ambient Temperature	88	°F
Specific Humidity	0.023849	lb H <sub>2</sub> O / lb air

**Unit Data**

Unit Load	248.9	megawatts
Combustor Inlet Pressure	266	psig
Meas. Stack Moisture	11.0	%
Stack Exhaust Flow (M19)	51,341,833	SCFH

Data from NH3 Run 3

**Base W/Db Load, Run - 2-3**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmv)	CO (ppmv)	VOC (ppmv)	CO <sub>2</sub> (%)
10/06/09 09:57:28	9000	12.07	2.64	2.90	1.67	5.45
10/06/09 09:57:58	9030	12.07	2.62	2.93	1.85	5.46
10/06/09 09:58:28	9060	12.06	2.59	3.06	1.65	5.45
10/06/09 09:58:58	9090	12.06	2.66	2.88	1.64	5.45
10/06/09 09:59:28	9120	12.06	2.64	2.93	1.66	5.39
10/06/09 09:59:58	9150	12.06	2.66	2.95	1.61	5.52
10/06/09 10:00:28	9180	12.08	2.63	2.93	1.54	5.45
10/06/09 10:00:58	9210	12.08	2.60	2.76	1.72	5.36
10/06/09 10:01:28	9240	12.08	2.58	3.00	1.79	5.29
10/06/09 10:01:58	9270	12.06	2.63	3.01	1.74	5.40
10/06/09 10:02:28	9300	12.06	2.66	2.96	1.58	5.36
10/06/09 10:02:58	9330	12.07	2.69	2.87	1.75	5.45
10/06/09 10:03:28	9360	12.05	2.69	2.97	1.69	5.45
10/06/09 10:03:58	9390	12.05	2.71	2.87	1.63	5.46
10/06/09 10:04:28	9420	12.06	2.68	2.82	1.65	5.46
10/06/09 10:04:58	9450	12.05	2.62	2.76	1.71	5.51
10/06/09 10:05:28	9480	12.06	2.62	2.95	1.84	5.52
10/06/09 10:05:58	9510	12.08	2.60	2.96	1.56	5.48
10/06/09 10:06:28	9540	12.06	2.59	2.75	1.55	5.44
10/06/09 10:06:58	9570	12.07	2.66	2.83	1.59	5.47
10/06/09 10:07:28	9600	12.08	2.71	2.75	1.57	5.52
10/06/09 10:07:58	9630	12.08	2.64	2.76	1.68	5.52
10/06/09 10:08:28	9660	12.07	2.62	2.81	1.69	5.55
10/06/09 10:08:58	9690	12.06	2.64	2.96	2.00	5.52
10/06/09 10:09:28	9720	12.06	2.64	3.20	1.75	5.52
10/06/09 10:09:58	9750	12.07	2.67	2.87	1.58	5.58
10/06/09 10:10:28	9780	12.07	2.61	2.74	1.79	5.39
10/06/09 10:10:58	9810	12.07	2.58	2.87	1.76	5.48
10/06/09 10:11:28	9840	12.06	2.63	2.88	1.78	5.47
10/06/09 10:11:58	9870	12.07	2.65	2.98	1.83	5.48
10/06/09 10:12:28	9900	12.07	2.65	2.93	1.75	5.48
10/06/09 10:12:58	9930	12.06	2.62	2.90	1.82	5.46
10/06/09 10:13:28	9960	12.07	2.56	2.89	1.81	5.37
10/06/09 10:13:58	9990	12.06	2.57	2.86	1.91	5.48
10/06/09 10:14:28	10020	12.06	2.58	2.87	1.77	5.53
10/06/09 10:14:58	10050	12.06	2.58	2.83	1.85	5.53
10/06/09 10:15:28	10080	12.08	2.73	2.85	1.86	5.50
10/06/09 10:15:58	10110	12.08	2.70	2.86	1.80	5.52
10/06/09 10:16:28	10140	12.08	2.64	2.79	1.83	5.48
10/06/09 10:16:58	10170	12.07	2.62	2.82	1.89	5.57
10/06/09 10:17:28	10200	12.07	2.60	2.89	1.82	5.50
10/06/09 10:17:58	10230	12.05	2.64	2.81	1.91	5.54
10/06/09 10:18:28	10260	12.04	2.65	2.86	1.98	5.59
10/06/09 10:18:58	10290	12.08	2.66	3.05	1.94	5.51
10/06/09 10:19:28	10320	12.08	2.64	2.99	1.94	5.37
10/06/09 10:19:58	10350	12.08	2.59	2.86	1.91	5.51
10/06/09 10:20:28	10380	12.09	2.61	2.93	1.98	5.48
10/06/09 10:20:58	10410	12.07	2.62	2.93	1.91	5.43
10/06/09 10:21:28	10440	12.07	2.57	2.77	2.01	5.37
10/06/09 10:21:58	10470	12.07	2.62	2.81	2.04	5.39
10/06/09 10:22:28	10500	12.07	2.66	2.84	2.07	5.42
10/06/09 10:22:58	10530	12.08	2.65	2.90	2.05	5.51
10/06/09 10:23:28	10560	12.09	2.69	2.87	1.90	5.55
10/06/09 10:23:58	10590	12.08	2.63	2.82	2.14	5.37
10/06/09 10:24:28	10620	12.08	2.63	3.01	2.00	5.50
10/06/09 10:24:58	10650	12.08	2.61	2.94	2.09	5.59
10/06/09 10:25:28	10680	12.07	2.56	2.94	1.82	5.53
10/06/09 10:25:58	10710	12.07	2.56	2.96	1.66	5.41
10/06/09 10:26:28	10740	12.07	2.62	2.86	1.80	5.56
10/06/09 10:26:58	10770	12.07	2.63	3.05	1.89	5.58
10/06/09 10:27:28	10800	12.06	2.65	3.10	1.82	5.52
10/06/09 10:27:58	10830	12.06	2.66	3.09	1.85	5.48
10/06/09 10:28:28	10860	12.05	2.64	3.11	1.91	5.60
10/06/09 10:28:58	10890	12.07	2.58	3.29	1.98	5.59
10/06/09 10:29:28	10920	12.06	2.61	3.39	1.87	5.65
10/06/09 10:29:58	10950	12.06	2.63	3.22	1.85	5.59
10/06/09 10:30:28	10980	12.07	2.66	3.10	1.86	5.64
10/06/09 10:30:58	11010	12.06	2.58	3.08	1.85	5.69
10/06/09 10:31:28	11040	12.07	2.55	3.19	1.89	5.65
10/06/09 10:31:58	11070	12.06	2.56	3.28	1.88	5.64
10/06/09 10:32:28	11100	12.05	2.58	3.22	1.88	5.63
10/06/09 10:32:58	11130	12.06	2.57	3.36	1.89	5.65
10/06/09 10:33:28	11160	12.05	2.64	3.32	1.98	5.67
10/06/09 10:33:58	11190	12.04	2.67	3.43	2.01	5.64
10/06/09 10:34:28	11220	12.04	2.66	3.46	2.03	5.65
10/06/09 10:34:58	11250	12.04	2.67	3.59	1.91	5.64
10/06/09 10:35:28	11280	12.03	2.64	3.45	1.97	5.64
10/06/09 10:35:58	11310	12.04	2.62	3.47	1.98	5.59
10/06/09 10:36:28	11340	12.03	2.63	3.51	2.09	5.62
10/06/09 10:36:58	11370	12.02	2.57	3.49	2.01	5.63
10/06/09 10:37:28	11400	12.02	2.66	3.46	2.08	5.50
10/06/09 10:37:58	11430	12.05	2.70	3.63	1.98	5.64
10/06/09 10:38:28	11460	12.04	2.68	3.60	2.05	5.63
10/06/09 10:38:58	11490	12.03	2.76	3.61	2.06	5.62

Florida Power and Light  
 October 6, 2009  
 Mitsubishi, 501G, Unit #1C  
 West County Energy Center

Fuel Data

Fuel Fd factor	9.649	SCF est/MMBtu
Fuel Heating Value (HHV)	988	Btu/SCF fuel
Turbine Fuel Flow	1,638	lb/min
Duct Burner Fuel Flow	192	lb/min
Total Fuel Flow	2,541,002	SCFH

Weather Data

Barometric Pressure	29.88	In. Hg
Relative Humidity	88	%
Ambient Temperature	86	F
Specific Humidity	0.023849	lb H <sub>2</sub> O / lb air

Unit Data

Unit Load	248.9	megawatts
Combustor Inlet Pressure	266	psig
Meas. Stack Moisture	11.0	%
Stack Exhaust Flow (M19)	51,341,833	SCFH

Data from: NHD Run 3

Base W/Db Load, Run - 2-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
10/06/09 10:39:28	11520	12.04	2.76	3.52	2.03	5.55
10/06/09 10:39:58	11550	12.03	2.74	3.56	2.13	5.55
10/06/09 10:40:28	11580	12.03	2.76	3.64	2.16	5.54
10/06/09 10:40:58	11610	12.03	2.81	3.65	2.09	5.56
10/06/09 10:41:28	11640	12.03	2.75	3.62	1.93	5.51
10/06/09 10:41:58	11670	12.04	2.74	3.45	2.05	5.57
10/06/09 10:42:28	11700	12.04	2.68	3.54	2.07	5.63
10/06/09 10:42:58	11730	12.03	2.76	3.62	2.12	5.44
10/06/09 10:43:28	11760	12.03	2.77	3.58	2.06	5.64
10/06/09 10:43:58	11790	12.02	2.75	3.53	2.13	5.61
10/06/09 10:44:28	11820	12.01	2.73	3.53	2.23	5.58
10/06/09 10:44:58	11850	12.02	2.69	3.64	1.78	5.60
10/06/09 10:45:28	11880	12.01	2.69	3.59	1.64	5.59
10/06/09 10:45:58	11910	12.01	2.68	3.66	1.64	5.58
10/06/09 10:46:28	11940	12.03	2.68	3.48	1.75	5.59
10/06/09 10:46:58	11970	12.01	2.71	3.64	1.71	5.61
10/06/09 10:47:28	12000	12.01	2.67	3.61	1.69	5.63
10/06/09 10:47:58	12030	12.02	2.69	3.40	1.67	5.56
10/06/09 10:48:28	12060	12.03	2.72	3.64	1.70	5.56
10/06/09 10:48:58	12090	12.04	2.75	3.56	1.61	5.58
10/06/09 10:49:28	12120	12.04	2.79	3.54	1.74	5.61
10/06/09 10:49:58	12150	12.03	2.73	3.64	1.69	5.60
10/06/09 10:50:28	12180	12.02	2.71	3.61	1.77	5.58
10/06/09 10:50:58	12210	12.02	2.75	3.60	1.69	5.60
10/06/09 10:51:28	12240	12.02	2.82	3.54	1.77	5.60
10/06/09 10:51:58	12270	12.03	2.80	3.62	1.68	5.61
10/06/09 10:52:28	12300	12.04	2.74	3.50	1.73	5.61
10/06/09 10:52:58	12330	12.03	2.77	3.48	1.70	5.59
10/06/09 10:53:28	12360	12.02	2.76	3.50	1.74	5.59
10/06/09 10:53:58	12390	12.01	2.75	3.61	1.84	5.64
10/06/09 10:54:28	12420	12.04	2.76	3.74	1.88	5.61
10/06/09 10:54:58	12450	12.06	2.81	3.62	1.84	5.57
10/06/09 10:55:28	12480	12.06	2.77	3.31	1.82	5.59
10/06/09 10:55:58	12510	12.03	2.75	3.47	1.87	5.41
10/06/09 10:56:28	12540	12.03	2.80	3.51	1.78	5.59
10/06/09 10:56:58	12570	12.05	2.77	3.43	1.88	5.59

RAW AVERAGE

O <sub>2</sub>	12.05	NOx	2.67	CO	3.19	VOC	1.84	CO <sub>2</sub>	5.53
----------------	-------	-----	------	----	------	-----	------	-----------------	------

Serial Number: INST-22-0001 INST-NX-0010 INST-CO-0008 INST-TI-0010 INST-22-0001

	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
Initial Zero	0.04	0.06	0.28	0.25	0.26
Final Zero	0.01	0.06	-0.22	0.49	0.43
Avg. Zero	0.03	0.06	0.03	0.37	0.35
Initial UpScale	12.01	4.97	5.13	3.19	9.42
Final UpScale	11.98	4.90	4.84	3.15	9.48
Avg. UpScale	12.00	4.94	4.99	3.17	9.45

Upscale Cal Gas

O <sub>2</sub>	12.00	NOx	4.99	CO	4.94	VOC	3.00	CO <sub>2</sub>	9.20
----------------	-------	-----	------	----	------	-----	------	-----------------	------

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm% dry basis)	12.06	2.67	3.15	1.82	5.24
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	1.78	2.10	1.22	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISO)	N/A	2.30	2.71	1.57	N/A
Emission Rate (lb/hr)	N/A	16.36	11.74	3.89	N/A
Emission Rate (tons/year) at 8760 hr/yr	N/A	71.65	51.41	17.03	N/A
Emission Rate (lb/MMBtu)	N/A	0.007	0.005	0.002	N/A

**TEST RESULTS**

**NH<sub>3</sub> Emissions  
Base Load**



Air Hygiene International, Inc.  
 5634 S. 122nd East Ave, Suite F  
 Tulsa, Oklahoma 74146  
 (888) 461-8778  
 www.airhygiene.com

## AMMONIA ANALYSIS

PARAMETER	UNITS	RUN						BLANK
		1		2		3		
		Front (f)	Back (b)	Front (f)	Back (b)	Front (f)	Back (b)	
Sample Number		02	03	04	05	06	07	01
Lab Log Number		U1C-R1-FH	U1C-R1-BH	U1C-R2-FH	U1C-R2-BH	U1C-R3-FH	U1C-R3-BH	BLANK
Results (C <sub>f</sub> or C <sub>b</sub> )	(mg/L)	8.2500	0.1400	11.1000	0.1000	11.0000	0.1900	0.1000
Practical Quantitation Limit (PQL)	(mg/L)	0.100	0.100	0.100	0.100	0.100	0.100	0.100
Sample Volume (V <sub>NH3</sub> )	(ml)	270	150	200	190	210	200	80
DGM Volume (V <sub>m</sub> ) <sub>dscf</sub>	(dscf)	54.99		54.24		55.20		55.20
DGM Volume (V <sub>m</sub> ) <sub>dstdL</sub>	(L <sub>dstd</sub> )	1557.27		1535.86		1563.01		1563.01
Sum of NH <sub>3</sub> Ion (N)	(mg/L)	8.2500	0.1400	11.1000	0.1000	11.0000	0.1900	0.1000
Total Sample Volume (S)	(ml)	270	150	200	190	210	200	80
Volume of NH <sub>3</sub> (V <sub>a</sub> )	(L)	0.00293	0.00003	0.00292	0.00002	0.00304	0.00005	0.00001
O <sub>2</sub> Concentration	(%)	12.97		13.00		13.01		N/A
NH <sub>3</sub> Concentration (C <sub>NH3</sub> )	(ppmvd)	1.90		1.92		1.98		0.007
C <sub>NH3</sub> @ 15% O <sub>2</sub>	(ppmvd)	1.41		1.43		1.48		N/A

### Equations & Constants:

Example Using Data from the 1st run

#### DGM Volume (L<sub>dstd</sub>)

$$(V_m)_{dstdL} (L_{dstd}) = (V_m)_{dscf} \times 28.31685$$

$$(V_m)_{dstdL} (L_{dstd}) = 54.99 \text{ dscf} \times 28.31685 \text{ L/ft}^3 = 1557.27 \text{ L}_{dstd}$$

(V<sub>m</sub>)<sub>dscf</sub> = Volume of gas sample measured by the DGM, corrected to standard conditions.

C<sub>f</sub> = Concentration of NH<sub>3</sub> ion in the front half of train (main catch)

C<sub>b</sub> = Concentration of NH<sub>3</sub> ion in the back half of train (breakthrough)

MW = molecular weight (ref. ASTM D 3588)

#### Volume of NH<sub>3</sub> (L)

$$V_a (L) = \frac{N \times S}{MW \times 1000} \times 22.4$$

$$V_a (L) = \frac{1000}{MW \times 1000}$$

$$V_a (L) = \frac{8.25 \text{ mg}}{\text{L}} \times \frac{270 \text{ ml}}{\text{L}} \times \frac{\text{L}}{1000 \text{ ml}} \times \frac{22.4 \text{ L ideal gas}}{\text{g-mol substance}} \times \frac{\text{g-mol NH}_3}{17.03 \text{ g}} \times \frac{\text{g}}{1000 \text{ mg}} = 0.00293 \text{ L}$$

#### NH<sub>3</sub> Concentration (ppmvd)

$$C_{NH3} (\text{ppmvd}) = \frac{V_{a(\text{front})} + V_{a(\text{back})}}{(V_m)_{dstdL}} \times 10^6$$

$$C_{NH3} (\text{ppmvd}) = \frac{0.00293 \text{ L} + 0.00003 \text{ L}}{1557.27 \text{ L}_{dstd}} \times \frac{10^6 \text{ parts}}{1 \text{ part}} = 1.899 \text{ ppmvd}$$

22.4 = liters of ideal gas per mol of substance at 0°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)



**CTM 027 (AMMONIA) - RESULTS**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/05/09
<b>Sampling Location</b>	Unit 1	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b>Stack Type</b>	Circular

Historical Data						
Run Number		Base W/O DB-1	Base W/O DB-2	Base W/O DB-3	Average	
Run Start Time		10:00	11:55	13:30		hh:mm
Run Stop Time		11:34	13:15	14:50		hh:mm
Meter Calibration Factor	(Y)	1.054	1.054	1.054		
Pitot Tube Coefficient	(C <sub>p</sub> )	0.840	0.840	0.840		
Average Nozzle Diameter	(D <sub>na</sub> )	0.248	0.248	0.248		in
Stack Test Data						
Initial Meter Volume	(V <sub>m</sub> ) <sub>i</sub>	267.800	320.278	372.628		ft3
Final Meter Volume	(V <sub>m</sub> ) <sub>f</sub>	319.900	372.199	425.770		ft3
Total Meter Volume	(V <sub>m</sub> )	52.100	51.921	53.142	52.388	ft3
Total Sampling Time	(Θ)	60.0	60.0	60.0	60.0	min
Average Meter Temperature	(t <sub>m</sub> ) <sub>avg</sub>	69.7	75.8	78.9	74.8	oF
Average Stack Temperature	(t <sub>s</sub> ) <sub>avg</sub>	182.5	184.8	186.3	184.5	oF
Barometric Pressure	(P <sub>b</sub> )	29.88	29.90	29.90	29.89	in Hg
Stack Static Pressure	(P <sub>static</sub> )	-0.70	-0.70	-0.70	-0.70	in H2O
Absolute Stack Pressure	(P <sub>s</sub> )	29.83	29.85	29.85	29.84	in Hg
Average Orifice Pressure Drop	(ΔH) <sub>avg</sub>	2.59	2.54	2.65	2.59	in H2O
Absolute Meter Pressure	(P <sub>m</sub> )	30.00	30.02	30.02	30.02	in Hg
Avg Square Root Pitot Pressure	(ΔP <sup>1/2</sup> ) <sub>avn</sub>	0.97	0.96	0.98	0.97	(in H2O) <sup>1/2</sup>
Moisture Content Data						
Impingers 1-3 Water Volume Gain	(V <sub>n</sub> )	131.7	111.9	104.1	115.9	ml
Impinger 4 Silica Gel Weight Gain	(W <sub>n</sub> )	13.4	19.5	7.9	13.6	g
Total Water Volume Collected	(V <sub>lc</sub> )	145.2	131.4	112.0	129.5	ml
Standard Water Vapor Volume	(V <sub>w</sub> ) <sub>std</sub>	6.833	6.187	5.272	6.097	scf
Standard Meter Volume	(V <sub>m</sub> ) <sub>std</sub>	54.994	54.238	55.197	54.810	dscf
Calculated Stack Moisture	(B <sub>ws(calc)</sub> )	11.05	10.24	8.72	10.00	%
Saturated Stack Moisture	(B <sub>ws(svp)</sub> )	54.1	56.8	58.6	56.5	%
Reported Stack Moisture Content	(B <sub>ws</sub> )	11.05	10.24	8.72	10.00	%
Gas Analysis Data						
Carbon Dioxide Percentage	(%CO <sub>2</sub> )	4.7	4.7	4.7	4.7	%
Oxygen Percentage	(%O <sub>2</sub> )	13.0	13.0	13.0	13.0	%
Carbon Monoxide Percentage	(%CO)	0.0	0.0	0.0	0.0	%
Nitrogen Percentage	(%N <sub>2</sub> )	82.3	82.3	82.3	82.3	%
Dry Gas Molecular Weight	(M <sub>d</sub> )	29.28	29.26	29.27	29.27	lb/lb-mole
Wet Stack Gas Molecular Weight	(M <sub>s</sub> )	28.03	28.11	28.28	28.14	lb/lb-mole
Calculated Fuel Factor	(F <sub>d</sub> )	1.673	1.699	1.693	1.688	
Fuel F-Factor	(F <sub>d</sub> )	8644	8644	8644	8644	dscf/MMBtu
Percent Excess Air	(%EA)	148.2	148.7	149.1	148.7	%
Volumetric Flow Rate Data						
Average Stack Gas Velocity	(V <sub>s</sub> )	61.21	60.44	61.74	61.13	ft/sec
Stack Cross-Sectional Area	(A <sub>s</sub> )	378.35	378.35	378.35	378.35	ft2
Actual Stack Flow Rate	(Q <sub>aw</sub> )	1,389,526	1,372,077	1,401,471	1,387,692	acfm
Wet Standard Stack Flow Rate	(Q <sub>sw</sub> )	68,304	67,252	68,538	68,031	wkscfh
Dry Standard Stack Flow Rate	(Q <sub>sd</sub> )	1,012,641	1,006,095	1,042,717	1,020,484	dscfm
Percent of Isokinetic Rate	(I)	104.3	103.6	103.5	103.8	%
Ammonia Rate Data						
Stack Ammonia Concentration	(C <sub>NH3</sub> )	1.90	1.92	1.98	1.93	ppm
	(C <sub>NH3</sub> )	1.41	1.43	1.48	1.44	ppm@15%O <sub>2</sub>

**CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE**

**ALARMS exist and have been acknowledged.**

Source Information				
Plant Name	West County Energy Center			
Sampling Location	Unit 1			
Fuel or Source Type	Gas, Natural			
Fuel F-Factor	8644	8644	8644	

Test Information				
Starting Test Date		10/05/09		
Project #		bv-09-westcounty.fl-comp#1		
Operator		TP		
Standard Temperature		68	oF	
Standard Pressure		29.92	in Hg	
Minimum Required Sample Vol.	indust. spec.	35	scf	
Run Duration	chk Subpart	60	minutes	
Unit Number		1C		
Load	% or w/DB	Base W/O DB		
Base Run Number		Base W/O DB		
Number of Ports Available		4		
Number of Ports Used		4		
Port Inside Diameter		6.00	in	
Circular Stack				

Test Equipment Information					
Run		1	2	3	
Meter Box Number	from ACS	samp-cp-0005	samp-cp-0005	samp-cp-0005	
Meter Calibration Factor	(Y)	1.054	1.054	1.054	
Orifice Meter Coefficient	( $\Delta H @$ )	1.694	1.694	1.694	in H <sub>2</sub> O
Pitot Identification	from ACS	samp-up-0002	samp-up-0002	samp-up-0002	
Pitot Tube Coefficient	(C <sub>p</sub> )	0.840	0.840	0.840	
Nozzle Diameter	(D <sub>n</sub> )	0.248	0.248	0.248	in
Probe Number	from ACS	samp-up-0002	samp-up-0002	samp-up-0002	
Probe Length		120.00	120.00	120.00	in
(SS, Glass ....) Liner Material	from list	inconel	inconel	inconel	
Sample Case / Oven Number	from ACS	samp-bh-0006	samp-bh-0006	samp-bc-0006	
Impinger Case Number	from ACS	samp-bc-0006	samp-bc-0002	samp-bc-0006	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	5634 S. 122nd East Ave., Suite F
City, State Country Zip	Tulsa, Oklahoma 74146
Project Manager	Jake Fahlenkamp
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	West County Energy Center			Date	10/05/09
Sampling Location	Unit 1			Project #	bv-09-westcounty.fl-comp#1
Operator	TP			# of Ports Used	4
Stack Type	Circular			Pitot Identification	samp-up-0002
Pitot Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Pitot Coefficient (C <sub>p</sub> ) 0.84

Stack Dimensions			
Diameter or Length of Stack	(D)	263.38	in
Width of Stack	(W)		in
Area of Stack	(A <sub>s</sub> )	378.35	ft <sup>2</sup>

Pressures			
Barometric Pressure	(P <sub>b</sub> )	29.80	in Hg
Static Pressure	(P <sub>static</sub> )	-0.70	in H <sub>2</sub> O
Absolute Stack Pressure	(P <sub>s</sub> )	29.75	in Hg

Stack Gas Composition			
Composition Data:		Estimated Composition	
Carbon Dioxide Concentration	(%CO <sub>2</sub> )	4.7	%
Oxygen Concentration	(%O <sub>2</sub> )	13.0	%
Carbon Monoxide Concentration	(%CO)	0.0	%
Nitrogen Concentration	(%N <sub>2</sub> )	82.3	%
Stack Moisture Content	(B <sub>ws</sub> )	10.000	%
Stack Dry Molecular Weight	(M <sub>d</sub> )	29.27	lb/lb-mole
Stack Wet Molecular Weight	(M <sub>s</sub> )	28.14	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v <sub>s</sub> )	60.5	ft/sec
Avg Stack Dry Std Flow Rate	(Q <sub>sd</sub> )	60,257,560	dscf/hr
Avg Stack Dry Std Flow Rate	(Q <sub>sd</sub> )	1,004,293	dscf/min
Avg Stack Wet Flow Rate	(Q <sub>sw</sub> )	1,373,044	acf/min
Avg Stack Wet Std Flow Rate	(Q <sub>sw</sub> )	66,952,844	ascf/hr

Stack Cross Section Schematic			


Velocity Traverse Data				
Run Number		Base W/O DB-V1		
Run Time	7:00	Start	7:40	End
Traverse Point	Velocity Head (Δp)	Null Angle (N <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Local Velocity (v <sub>s(θ)</sub> )
	in H <sub>2</sub> O	deg	oF	ft/sec
A-1	0.65	0	180	50.6
A-2	0.73	-5	182	53.7
A-3	0.80	5	184	56.3
A-4	0.87	10	183	58.7
A-5	0.89	5	186	59.5
A-6	0.81	0	187	56.8
B-1	0.54	0	184	46.3
B-2	0.64	0	191	50.7
B-3	0.70	5	192	53.0
B-4	0.74	0	190	54.4
B-5	0.77	5	191	55.6
B-6	0.75	0	192	54.9
C-1	1.00	-5	177	62.6
C-2	1.10	-5	183	66.0
C-3	1.20	5	184	69.0
C-4	1.20	5	185	69.0
C-5	1.10	5	186	66.2
C-6	0.90	5	187	59.9
D-1	0.90	0	181	59.6
D-2	1.10	-5	183	66.0
D-3	1.30	10	187	72.0
D-4	1.30	5	188	72.0
D-5	1.20	5	189	69.3
D-6	1.20	0	191	69.4
Average	0.93	4	186	
	0.96	= Square roots of Δp		

**METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES**

Plant Name	West County Energy Center	Date	10/05/09
Sampling Location	Unit 1	Project #	bv-09-westcounty.fl-comp#1
Operator	TP	# of Ports Available	4
Stack Type	Circular	# of Ports Used	4
Stack Size	Large	Port Inside Diameter	6.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L <sub>fw</sub> )	282.38	in
Distance to Near Wall of Stack	(L <sub>nw</sub> )	19.00	in
Diameter of Stack	(D)	263.38	in
Area of Stack	(A <sub>s</sub> )	378.35	ft <sup>2</sup>

Distance from Port to Disturbances			
Distance Upstream	(A)	144.00	in
Diameters Upstream	(A <sub>D</sub> )	0.55	diameters
Distance Downstream	(B)	531.75	in
Diameters Downstream	(B <sub>D</sub> )	2.02	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of <sup>1</sup> Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 <sup>2</sup>	8 or 12 <sup>2</sup>
Upstream Spec		24	16
Downstream Spec		24	16
Traverse Pts Required		24	16

<sup>1</sup> Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

<sup>2</sup> 8 for Circular Stacks 12 to 24 inches  
12 for Circular Stacks over 24 inches

Number of Traverse Points Used			
4	Ports by	6	Across
24	Pts Used	24	Required
		Particulate Traverse	

Location of Traverse Points in Circular Stacks									
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
	Number of Traverse Points Across the Stack								
Number	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.02	5 4/8	24 4/8
2	0.07	17 5/8	36 5/8
3	0.12	31 1/8	50 1/8
4	0.18	46 5/8	65 5/8
5	0.25	65 7/8	84 7/8
6	0.36	93 6/8	112 6/8
7			
8			
9			
10			
11			
12			

**METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER**

<b>Plant Name</b>	West County Energy Center			<b>Date</b>	10/05/09		
<b>Sampling Location</b>	Unit 1			<b>Project #</b>	bv-09-westcounty.fl-comp#1		
<b>Operator</b>	TP			<b># of Ports Used</b>	4		
<b>Fuel Type</b>	Gas, Natural	<b>Minimum Fuel Factor</b>	1.600	<b>Maximum Fuel Factor</b>	1.836		
<b>Orsat Leak Check</b>	<input checked="" type="checkbox"/>	<b>PreTest</b>	<input checked="" type="checkbox"/>	<b>PostTest</b>	<b>Orsat Identification</b> N/A		

Gas Analysis Data										
Run Number		Base W/O DB-1		Run Start Time		10:00	Run Stop Time		11:34	
Sample Analysis Time	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N <sub>2</sub> )	Dry Molecular Weight (M <sub>d</sub> )	Molecular Weight Deviation (ΔM <sub>d</sub> )	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:34	4.7	13.0	0.4	4.7	13.0	0.0	82.3	29.28	0.00	
<b>Results</b>			<b>Averages</b>	4.7	13.0	0.0	82.3	29.28		
<b>Average Calculated Fuel Factor</b>				(F <sub>o</sub> ) <sub>avg</sub>	1.673	<b>Molecular Wt Deviation &lt; 0.3?</b>			<input checked="" type="checkbox"/>	
<b>Average Excess Air</b>				(%EA) <sub>avg</sub>	148.2	percent	<b>Fuel Factor in Handbook Range?</b>			<input checked="" type="checkbox"/>

Gas Analysis Data										
Run Number		Base W/O DB-2		Run Start Time		11:55	Run Stop Time		13:15	
Sample Analysis Time	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N <sub>2</sub> )	Dry Molecular Weight (M <sub>d</sub> )	Molecular Weight Deviation (ΔM <sub>d</sub> )	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:20	4.7	13.0	0.4	4.7	13.0	0.0	82.3	29.26	0.00	
<b>Results</b>			<b>Averages</b>	4.7	13.0	0.0	82.3	29.26		
<b>Average Calculated Fuel Factor</b>				(F <sub>o</sub> ) <sub>avg</sub>	1.699	<b>Molecular Wt Deviation &lt; 0.3?</b>			<input checked="" type="checkbox"/>	
<b>Average Excess Air</b>				(%EA) <sub>avg</sub>	148.7	percent	<b>Fuel Factor in Handbook Range?</b>			<input checked="" type="checkbox"/>

Gas Analysis Data										
Run Number		Base W/O DB-3		Run Start Time		13:30	Run Stop Time		14:50	
Sample Analysis Time	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N <sub>2</sub> )	Dry Molecular Weight (M <sub>d</sub> )	Molecular Weight Deviation (ΔM <sub>d</sub> )	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:20	4.7	13.0	0.2	4.7	13.0	0.0	82.3	29.27	0.00	
<b>Results</b>			<b>Averages</b>	4.7	13.0	0.0	82.3	29.27		
<b>Average Calculated Fuel Factor</b>				(F <sub>o</sub> ) <sub>avg</sub>	1.693	<b>Molecular Wt Deviation &lt; 0.3?</b>			<input checked="" type="checkbox"/>	
<b>Average Excess Air</b>				(%EA) <sub>avg</sub>	149.1	percent	<b>Fuel Factor in Handbook Range?</b>			<input checked="" type="checkbox"/>

Fuel Factor F <sub>o</sub>		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Wood	1.000	1.120
Wood Bark	1.003	1.130

**METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES**

Plant Name	West County Energy Center				Date	10/05/09		
Sampling Location	Unit 1				Project #	bv-09-westcounty.fl-comp#1		
Operator	TP				# of Ports Used	4		
Stack Type	Circular				Meter Box Number	samp-cp-0005		
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Meter Cal Factor (Y)	1.054		

Moisture Content Data								
Run Number	Base W/O DB-1		Run Start Time		10:00	Run Stop Time		11:34
Total Meter Volume	(V <sub>m</sub> )	52.100	dcf	Barometric Press.		(P <sub>b</sub> )	29.88	in Hg
Avg Stack Temp	(t <sub>s</sub> ) <sub>avg</sub>	183	oF	Stack Static Press.		(P <sub>static</sub> )	-0.70	in H2O
Avg Meter Temp	(t <sub>m</sub> ) <sub>avg</sub>	70	oF	Avg Orifice Press.		(ΔH) <sub>avg</sub>	2.59	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	H2SO4	H2SO4		Sil Gel				
Final Value	(V <sub>f</sub> ),(W <sub>f</sub> )	818.20	734.00	645.00	931.80			
Initial Value	(V <sub>i</sub> ),(W <sub>i</sub> )	708.50	715.80	641.40	918.40			
Net Value	(V <sub>n</sub> ),(W <sub>n</sub> )	109.7	18.2	3.6	13.4			
Results								
Total Weight	(W <sub>i</sub> )	144.90	g	Water Vol Weighed		(V <sub>wsq(std)</sub> )	6.832	scf
Std Meter Volume	(V <sub>m(std)</sub> )	55.010	dscf	Sat. Moisture Content		(B <sub>ws(svp)</sub> )	54.1	%
Calc Moisture Content	(B <sub>ws(calc)</sub> )	11.0	%	Final Moisture Content		(B <sub>ws</sub> )	11.0	%

Moisture Content Data								
Run Number	Base W/O DB-2		Run Start Time		11:55	Run Stop Time		13:15
Total Meter Volume	(V <sub>m</sub> )	51.921	dcf	Barometric Press.		(P <sub>b</sub> )	29.90	in Hg
Avg Stack Temp	(t <sub>s</sub> ) <sub>avg</sub>	185	oF	Stack Static Press.		(P <sub>static</sub> )	-0.70	in H2O
Avg Meter Temp	(t <sub>m</sub> ) <sub>avg</sub>	76	oF	Avg Orifice Press.		(ΔH) <sub>avg</sub>	2.54	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	H2SO4	H2SO4		Sil Gel				
Final Value	(V <sub>f</sub> ),(W <sub>f</sub> )	824.80	721.60	613.10	923.40			
Initial Value	(V <sub>i</sub> ),(W <sub>i</sub> )	769.80	678.00	600.00	903.90			
Net Value	(V <sub>n</sub> ),(W <sub>n</sub> )	55.0	43.6	13.1	19.5			
Results								
Total Weight	(W <sub>i</sub> )	131.20	g	Water Vol Weighed		(V <sub>wsq(std)</sub> )	6.186	scf
Std Meter Volume	(V <sub>m(std)</sub> )	54.227	dscf	Sat. Moisture Content		(B <sub>ws(svp)</sub> )	56.8	%
Calc Moisture Content	(B <sub>ws</sub> )	10.2	%	Final Moisture Content		(B <sub>ws</sub> )	10.2	%

Moisture Content Data								
Run Number	Base W/O DB-3		Run Start Time		13:30	Run Stop Time		14:50
Total Meter Volume	(V <sub>m</sub> )	53.142	dcf	Barometric Press.		(P <sub>b</sub> )	29.90	in Hg
Avg Stack Temp	(t <sub>s</sub> ) <sub>avg</sub>	186	oF	Stack Static Press.		(P <sub>static</sub> )	-0.70	in H2O
Avg Meter Temp	(t <sub>m</sub> ) <sub>avg</sub>	79	oF	Avg Orifice Press.		(ΔH) <sub>avg</sub>	2.65	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	H2SO4	H2SO4		Sil Gel				
Final Value	(V <sub>f</sub> ),(W <sub>f</sub> )	787.60	720.60	650.10	939.70			
Initial Value	(V <sub>i</sub> ),(W <sub>i</sub> )	708.90	700.50	645.00	931.80			
Net Value	(V <sub>n</sub> ),(W <sub>n</sub> )	78.7	20.1	5.1	7.9			
Results								
Total Weight	(W <sub>i</sub> )	111.80	g	Water Vol Weighed		(V <sub>wsq(std)</sub> )	5.271	scf
Std Meter Volume	(V <sub>m(std)</sub> )	55.198	dscf	Sat. Moisture Content		(B <sub>ws(svp)</sub> )	58.6	%
Calc Moisture Content	(B <sub>ws</sub> )	8.7	%	Final Moisture Content		(B <sub>ws</sub> )	8.7	%

**CTM 027 (AMMONIA) ISOKINETIC SAMPLING DATA**

Plant Name	West County Energy Center			Date	10/5/2009		
Sampling Location	Unit 1			Project #	bv-09-westcounty.fl-comp#1		
Operator	TP			Run #	Base W/O DB-1		
# of Points Across	6			# of Ports Used	4		

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C <sub>p</sub> )	0.84	
Avg Stack Temp	(t <sub>s</sub> )	186	oF
Avg Gas Meter Temp	(t <sub>m</sub> )	68	
DH @ 0.75 SCFM	(ΔH@)	1.69	in H2O
Avg Pitot Tube Diff. Pressure	(ΔP <sub>pit</sub> )	0.93	in H2O
Stack Moisture Content	(B <sub>vs</sub> )	11.60	%
Stack Dry Molecular Weight	(M <sub>d</sub> )	29.28	lb/lb-mole
Estimated Orifice Flow Rate	(Q <sub>m</sub> )	0.750	acfm
DP to DH Isokinetic Factor	(K)	2.55	

Leak Checks							
Train	Pre	0.005	ft3/min @	15	in	Hg	
OK?	Post	0	ft3/min @	15	in	Hg	
Pitot	Pre	7.1/6.3	in. H <sub>2</sub> O for	15	sec		
OK?	Post	6.6/5.8	in. H <sub>2</sub> O for	15	sec		
Orsat	OK?						

Sampling Equipment			
Meter #	samp-cp-0005		
Meterbox Cal. Factor	(Y)	1.054	
Nozzle #	N/A		
Average Nozzle Diameter	(D <sub>na</sub> )	0.2480	in
Rec. Nozzle Diameter	(D <sub>n</sub> )	0.2288	in
Probe # / Length	samp-up-0002	/ 120	
Liner Material	inconel		
Sample Case / Oven #	samp-bh-0006		
Impinger Case #	samp-bc-0006		

Nozzle Measurements				
Pre	0.248	0.248	0.248	PASS
Post	0.248	0.248	0.248	PASS

Pressures			
Barometric Pressure	(P <sub>b</sub> )	29.88	in Hg
Stack Static Pressure	(P <sub>static</sub> )	-0.70	in H2O
Absolute Stack Pressure	(P <sub>s</sub> )	29.83	in Hg
Absolute Meter Pressure	(P <sub>m</sub> )	30.00	in Hg

Run Time			
Start	10:00	End	11:34

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	708.50	715.80	641.40	918.40				
Post	818.20	734.00	645.00	931.80				

Wash Volume	H <sub>2</sub> O	50.0	ml	Filter #
	MeCl		ml	

Traverse Point #	Sampling Time (ϕ)	Timer Time	Dry Gas Meter Reading (V <sub>m</sub> )	Velocity Head (Δp)	Desired Orifice ΔH (ΔH <sub>d</sub> )	Actual Orifice ΔH (ΔH <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Probe Temp (t <sub>p</sub> )	Filter Temp (t <sub>f</sub> )	Impinger Exit Temp (t <sub>i</sub> )	Aux Temp (t <sub>a</sub> )	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>mo</sub> )	Pump Vacuum (in Hg)	Square Root ΔP (ΔP <sup>1/2</sup> )	Local Stack Velocity (v <sub>s</sub> ) <sub>i</sub>	Cumulative Meter Volume (V <sub>m,stk</sub> )	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m,stk</sub> )
A-1	0.0	0:00:00	267.800	0.850	2.171	2.300	185	250	263	57		65	64	2.5	0.92	58.21	2.094	99.1	50.254
A-2	2.5	0:02:30	269.765	0.870	2.222	2.300	193	249	269	52		67	64	2.5	0.93	59.26	4.106	97.0	49.275
A-3	5.0	0:05:00	271.657	0.820	2.094	2.200	184	248	268	55		66	64	2.0	0.91	57.13	6.227	98.8	49.820
A-4	7.5	0:07:30	273.650	0.720	1.839	1.900	198	247	258	53		68	64	1.5	0.85	54.12	8.351	101.7	50.103
A-5	10.0	0:10:00	275.650	0.580	1.481	1.600	185	246	257	54		68	65	1.0	0.76	48.09	10.258	103.1	49.239
A-6	12.5	0:12:30	277.450	0.550	1.405	1.500	184	245	255	55		69	65	1.0	0.74	46.79	12.333	106.3	49.331
B-1	15.0	0:15:00	279.410	0.770	1.966	2.100	179	251	254	60		70	66	2.0	0.88	55.15	14.385	105.6	49.321
B-2	17.5	0:17:30	281.350	0.750	1.915	2.000	180	248	257	56		70	67	2.0	0.87	54.47	16.002	103.2	48.006
B-3	20.0	0:20:00	282.880	0.740	1.890	2.000	178	247	257	56		71	67	2.0	0.86	54.02	17.987	102.8	47.965
B-4	22.5	0:22:30	284.760	0.730	1.864	2.000	179	247	257	58		71	67	2.0	0.85	53.70	20.035	103.0	48.084
B-5	25.0	0:25:00	286.700	0.700	1.788	1.900	178	250	258	58		72	68	2.0	0.84	52.54	22.458	105.4	49.000
B-6	27.5	0:27:30	289.000	0.520	1.328	1.400	177	249	258	58		72	68	2.0	0.72	45.25	24.183	105.3	48.366
C-1	30.0	0:30:00	290.639	1.300	3.320	3.500	177	255	257	60		71	68	5.5	1.14	71.55	26.936	105.3	49.729
C-2	32.5	0:32:30	293.240	1.300	3.320	3.500	181	256	260	55		73	69	5.5	1.14	71.77	30.109	106.9	51.615
C-3	35.0	0:35:00	296.245	1.300	3.320	3.500	179	255	261	57		73	69	5.5	1.14	71.66	31.845	104.7	50.952
C-4	37.5	0:37:30	297.890	1.300	3.320	3.500	186	253	259	59		74	69	5.5	1.14	72.05	34.492	104.4	51.739
C-5	40.0	0:40:00	300.400	1.200	3.065	3.200	179	253	263	63		74	70	5.5	1.10	68.85	37.098	104.4	52.374
C-6	42.5	0:42:30	302.875	1.100	2.809	3.000	182	254	258	65		74	70	5.0	1.05	66.07	39.582	104.3	52.776
D-1	45.0	0:45:00	305.235	1.200	3.065	3.200	180	251	260	63		73	71	5.5	1.10	68.90	42.167	104.2	53.263
D-2	47.5	0:47:30	307.690	1.200	3.065	3.200	181	249	258	58		74	70	5.5	1.10	68.95	45.073	104.9	54.087
D-3	50.0	0:50:00	310.450	1.200	3.065	3.200	183	253	260	61		75	71	5.5	1.10	69.06	47.280	104.1	54.034
D-4	52.5	0:52:30	312.550	1.200	3.065	3.200	183	249	260	63		76	71	5.5	1.10	69.06	49.852	104.0	54.384
D-5	55.0	0:55:00	315.000	1.100	2.809	3.000	185	249	259	67		76	71	5.5	1.05	66.22	52.565	104.5	54.850
D-6	57.5	0:57:30	317.585	1.100	2.809	3.000	184	249	261	68		76	71	5.5	1.05	66.17	54.994	104.3	54.994
Last Pt	60.0	1:00:00	319.900																
Final Val	60.0	1:00:00	319.900											Max Vac	5.5	Final Values	54.994	104.3	
Average Values				0.96		2.59	183	250	259	59		72	68		0.97	61.21			

**CTM 027 (AMMONIA) ISOKINETIC SAMPLING DATA**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/5/2009
<b>Sampling Location</b>	Unit 1	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b>Run #</b>	Base W/O DB-2
<b># of Points Across</b>	6	<b># of Ports Used</b>	4

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
<b>Pitot Tube Coefficient</b>	(C <sub>p</sub> )	0.84	
<b>Avg Stack Temp</b>	(t <sub>s</sub> )	183	oF
<b>Avg Gas Meter Temp</b>	(t <sub>m</sub> )	70	
<b>DH @ 0.75 SCFM</b>	(ΔH@)	1.69	in H2O
<b>Avg Pitot Tube Diff. Pressure</b>	(ΔP <sub>pit</sub> )	0.97	in H2O
<b>Stack Moisture Content</b>	(B <sub>ws</sub> )	11.60	%
<b>Stack Dry Molecular Weight</b>	(M <sub>d</sub> )	29.28	lb/lb-mole
<b>Estimated Orifice Flow Rate</b>	(Q <sub>m</sub> )	0.868	acfm
<b>DP to DH Isokinetic Factor</b>	(K)	2.58	

Leak Checks					
<b>Train</b>	<b>Pre</b>	0.0075	ft3/min @	15	in Hg
<b>OK? <input checked="" type="checkbox"/></b>	<b>Post</b>	0	ft3/min @	15	in Hg
<b>Pitot</b>	<b>Pre</b>	6.5/7.2	in. H <sub>2</sub> O for	15	sec
<b>OK? <input checked="" type="checkbox"/></b>	<b>Post</b>	6.0/6.4	in. H <sub>2</sub> O for	15	sec
<b>Orsat</b>	<b>OK? <input type="checkbox"/></b>				

Sampling Equipment			
<b>Meter #</b>	samp-cp-0005		
<b>Meterbox Cal. Factor</b>	(Y)	1.054	
<b>Nozzle #</b>	N/A		
<b>Average Nozzle Diameter</b>	(D <sub>na</sub> )	0.2480	in
<b>Rec. Nozzle Diameter</b>	(D <sub>n</sub> )	0.2429	in
<b>Probe # / Length</b>	samp-up-0002 / 120 in		
<b>Liner Material</b>	inconel		
<b>Sample Case / Oven #</b>	samp-bh-0006		
<b>Impinger Case #</b>	samp-bc-0002		

Nozzle Measurements				
<b>Pre</b>	0.248	0.248	0.248	PASS
<b>Post</b>	0.248	0.248	0.248	PASS

Pressures			
<b>Barometric Pressure</b>	(P <sub>b</sub> )	29.90	in Hg
<b>Stack Static Pressure</b>	(P <sub>static</sub> )	-0.70	in H2O
<b>Absolute Stack Pressure</b>	(P <sub>s</sub> )	29.85	in Hg
<b>Absolute Meter Pressure</b>	(P <sub>m</sub> )	30.02	in Hg

Run Time		
<b>Start</b>	11:55	<b>End</b> 13:15

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
<b>Pre</b>	769.80	678.00	600.00	903.90				
<b>Post</b>	824.80	721.60	613.10	923.40				

<b>Wash Volume</b>	<b>H<sub>2</sub>O</b>	50.0	ml	<b>Filter #</b>	
	<b>MeCl</b>		ml		

Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V <sub>m</sub> )	Velocity Head (Δp)	Desired Orifice ΔH (ΔH <sub>d</sub> )	Actual Orifice ΔH (ΔH <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>mo</sub> )	Pump Vacuum	Square Root ΔP (ΔP <sup>1/2</sup> )	Local Stack Velocity (v <sub>s</sub> )	Cumulative Meter Volume (V <sub>m,stk</sub> )	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m,stk</sub> )
A-1	0.0	0:00:00	320.278	1.200	3.091	3.300	179	252	241	64		76	73	5.5	1.10	68.82	2.577	102.2	61.853
A-2	2.5	0:02:30	322.735	1.300	3.349	3.500	183	252	248	64		77	73	6.0	1.14	71.86	4.994	97.4	59.927
A-3	5.0	0:05:00	325.040	1.300	3.349	3.500	189	254	251	64		77	72	6.0	1.14	72.19	7.612	98.5	60.898
A-4	7.5	0:07:30	327.535	1.300	3.349	3.500	182	251	255	66		77	72	6.0	1.14	71.80	10.225	98.8	61.352
A-5	10.0	0:10:00	330.025	1.200	3.091	3.300	183	249	256	65		78	73	1.2	1.10	69.04	12.817	99.7	61.520
A-6	12.5	0:12:30	332.500	0.980	2.525	2.700	186	235	256	65		79	73	5.0	0.99	62.54	15.579	103.6	62.317
B-1	15.0	0:15:00	335.145	0.880	2.267	2.400	180	246	235	58		76	74	3.5	0.94	58.98	17.775	103.4	60.943
B-2	17.5	0:17:30	337.245	0.900	2.319	2.400	182	247	245	55		77	74	3.5	0.95	59.74	20.408	105.6	61.223
B-3	20.0	0:20:00	339.765	1.300	3.349	3.500	180	248	246	54		82	74	6.5	1.14	71.69	22.894	104.5	61.052
B-4	22.5	0:22:30	342.150	1.300	3.349	3.500	185	248	248	54		79	74	6.5	1.14	71.97	25.210	103.0	60.504
B-5	25.0	0:25:00	344.365	1.100	2.834	3.000	183	249	243	54		79	74	6.5	1.05	66.10	27.737	103.2	60.518
B-6	27.5	0:27:30	346.785	1.100	2.834	3.000	184	245	239	57		79	74	5.5	1.05	66.15	30.320	103.5	60.639
C-1	30.0	0:30:00	349.258	0.560	1.443	1.500	181	259	268	62		76	74	2.0	0.75	47.09	32.346	104.4	59.716
C-2	32.5	0:32:30	351.200	0.580	1.494	1.600	181	256	260	56		78	74	2.0	0.76	47.92	34.143	104.3	58.530
C-3	35.0	0:35:00	352.925	0.670	1.726	1.800	182	256	263	55		77	74	2.0	0.82	51.55	36.026	104.1	57.641
C-4	37.5	0:37:30	354.730	0.700	1.803	1.900	182	256	263	57		78	74	2.5	0.84	52.69	37.975	104.0	56.962
C-5	40.0	0:40:00	356.600	0.750	1.932	2.000	183	258	255	58		79	74	3.0	0.87	54.58	39.965	103.8	56.421
C-6	42.5	0:42:30	358.510	0.760	1.958	2.100	188	254	254	60		79	74	3.5	0.87	55.16	42.054	103.8	56.072
D-1	45.0	0:45:00	360.515	0.630	1.623	1.700	186	256	259	61		77	74	2.5	0.79	50.14	44.087	104.2	55.689
D-2	47.5	0:47:30	362.465	0.680	1.752	1.800	189	252	254	58		77	74	2.5	0.82	52.21	46.106	104.3	55.327
D-3	50.0	0:50:00	364.400	0.760	1.958	2.100	189	254	256	61		79	74	2.5	0.87	55.20	48.033	104.0	54.895
D-4	52.5	0:52:30	366.250	0.800	2.061	2.200	191	252	255	60		78	74	3.0	0.89	56.72	50.042	103.8	54.591
D-5	55.0	0:55:00	368.175	0.830	2.138	2.300	190	253	257	63		78	74	3.5	0.91	57.73	52.102	103.6	54.368
D-6	57.5	0:57:30	370.150	0.850	2.190	2.300	197	251	255	64		79	74	4.0	0.92	58.73	54.238	103.6	54.238
Last Pt	60.0	1:00:00	372.199																
Final Val	60.0	1:00:00	372.199											Max Vac	6.5	Final Values	54.238	103.6	
Average Values				0.93		2.54	185	251	253	60		78	74		0.96	60.44			



**CTM 027 (AMMONIA) ISOKINETIC SAMPLING DATA**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/5/2009
<b>Sampling Location</b>	Unit 1	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b>Run #</b>	Base W/O DB-3
<b># of Points Across</b>	6	<b># of Ports Used</b>	4

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
<b>Pitot Tube Coefficient</b>	(C <sub>p</sub> )	0.84	
<b>Avg Stack Temp</b>	(t <sub>s</sub> )	185	oF
<b>Avg Gas Meter Temp</b>	(t <sub>m</sub> )	76	
<b>DH @ 0.75 SCFM</b>	(ΔH@)	1.69	in H2O
<b>Avg Pitot Tube Diff. Pressure</b>	(ΔP <sub>avg</sub> )	0.96	in H2O
<b>Stack Moisture Content</b>	(B <sub>wt</sub> )	11.60	%
<b>Stack Dry Molecular Weight</b>	(M <sub>d</sub> )	29.26	lb/lb-mole
<b>Estimated Orifice Flow Rate</b>	(Q <sub>m</sub> )	0.865	acfm
<b>DP to DH Isokinetic Factor</b>	(K)	2.60	

Leak Checks					
<b>Train</b>	<b>Pre</b>	0	ft3/min @	15	in Hg
<b>OK?</b>	<input checked="" type="checkbox"/>				
	<b>Post</b>	0	ft3/min @	15	in Hg
<b>Pitot</b>	<b>Pre</b>	6.4/5.9	in. H <sub>2</sub> O for	15	sec
<b>OK?</b>	<input checked="" type="checkbox"/>				
	<b>Post</b>	6.3/7.2	in. H <sub>2</sub> O for	15	sec
<b>Orsat</b>	<b>OK?</b>	<input type="checkbox"/>			

Sampling Equipment			
<b>Meter #</b>	samp-cp-0005		
<b>Meterbox Cal. Factor</b>	(Y)	1.054	
<b>Nozzle #</b>	N/A		
<b>Average Nozzle Diameter</b>	(D <sub>na</sub> )	0.2480	in
<b>Rec. Nozzle Diameter</b>	(D <sub>n</sub> )	0.2421	in
<b>Probe # / Length</b>	samp-up-0002 / 120		in
<b>Liner Material</b>	inconel		
<b>Sample Case / Oven #</b>	samp-bc-0006		
<b>Impinger Case #</b>	samp-bc-0006		

Nozzle Measurements				
<b>Pre</b>	0.248	0.248	0.248	PASS
<b>Post</b>	0.248	0.248	0.248	PASS

Pressures			
<b>Barometric Pressure</b>	(P <sub>b</sub> )	29.90	in Hg
<b>Stack Static Pressure</b>	(P <sub>static</sub> )	-0.70	in H2O
<b>Absolute Stack Pressure</b>	(P <sub>a</sub> )	29.85	in Hg
<b>Absolute Meter Pressure</b>	(P <sub>m</sub> )	30.02	in Hg

Run Time		
<b>Start</b>	13:30	<b>End</b> 14:50

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
<b>Pre</b>	708.90	700.50	645.00	931.80				
<b>Post</b>	787.60	720.60	650.10	939.70				

<b>Wash Volume</b>	<b>H<sub>2</sub>O</b>	50.0	ml	<b>Filter #</b>	
	<b>MeCl</b>		ml		

Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V <sub>m</sub> )	Velocity Head (Δp)	Desired Orifice ΔH (ΔH <sub>d</sub> )		Stack Temp (t <sub>s</sub> )	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>mo</sub> )	Pump Vacuum	Square Root ΔP (Δp <sup>1/2</sup> )	Local Stack Velocity (v <sub>s</sub> )	Cumulative Meter Volume (V <sub>m</sub> ) <sub>std</sub>	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m</sub> ) <sub>std</sub>
					in H2O	in H2O													
	min	hh:mm:ss	ft3	in H2O	in H2O	in H2O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H2O) <sup>1/2</sup>	ft/sec	scf	%	scf
A-1	0.0	0:00:00	372.628	0.780	2.025	2.100	188	251	235	67		77	75	2.0	0.88	55.89	2.020	100.0	48.484
A-2	2.5	0:02:30	374.565	0.860	2.233	2.400	191	252	246	65		87	75	3.0	0.93	58.82	4.383	106.3	52.596
A-3	5.0	0:05:00	376.850	0.820	2.129	2.200	190	249	266	64		80	75	3.0	0.91	57.39	6.193	100.8	49.544
A-4	7.5	0:07:30	378.590	0.850	2.207	2.300	190	251	249	66		80	75	3.0	0.92	58.43	8.337	101.1	50.019
A-5	10.0	0:10:00	380.650	0.900	2.337	2.400	190	252	245	63		80	77	3.0	0.95	60.13	10.487	100.7	50.337
A-6	12.5	0:12:30	382.720	0.880	2.285	2.400	194	248	241	61		82	76	3.5	0.94	59.64	12.705	101.3	50.820
B-1	15.0	0:15:00	384.857	0.540	1.402	1.500	180	246	254	61		79	76	3.5	0.73	46.21	14.930	105.8	51.190
B-2	17.5	0:17:30	387.000	0.640	1.662	1.800	183	250	260	59		79	76	2.5	0.80	50.43	16.947	106.3	50.840
B-3	20.0	0:20:00	388.940	0.690	1.792	1.900	183	253	258	59		80	76	2.5	0.83	52.36	18.967	106.2	50.578
B-4	22.5	0:22:30	390.885	0.710	1.843	1.900	185	254	258	61		81	77	2.5	0.84	53.20	20.988	106.1	50.371
B-5	25.0	0:25:00	392.835	0.720	1.869	2.000	184	254	252	63		81	77	2.5	0.85	53.53	22.994	105.8	50.169
B-6	27.5	0:27:30	394.770	0.740	1.921	2.000	184	255	253	66		81	77	3.0	0.86	54.27	25.053	105.7	50.105
C-1	30.0	0:30:00	396.755	1.200	3.116	3.300	180	253	256	68		79	77	6.0	1.10	68.89	27.595	105.3	50.945
C-2	32.5	0:32:30	399.195	1.200	3.116	3.300	182	249	257	68		81	77	6.0	1.10	69.00	30.191	105.1	51.755
C-3	35.0	0:35:00	401.690	1.200	3.116	3.300	184	249	252	66		81	81	6.0	1.10	69.11	32.724	104.7	52.359
C-4	37.5	0:37:30	404.135	1.200	3.116	3.300	183	250	251	66		82	78	6.0	1.10	69.05	35.221	104.4	52.832
C-5	40.0	0:40:00	406.540	1.200	3.116	3.300	183	251	251	68		82	77	6.0	1.10	69.05	37.908	104.5	53.517
C-6	42.5	0:42:30	409.125	1.000	2.596	2.700	186	249	251	67		82	77	5.0	1.00	63.18	40.403	104.8	53.871
D-1	45.0	0:45:00	411.530	1.100	2.856	3.000	184	248	259	67		81	77	5.0	1.05	66.16	42.659	104.2	53.885
D-2	47.5	0:47:30	413.700	1.200	3.116	3.300	188	248	260	68		81	77	6.0	1.10	69.32	44.843	103.4	53.812
D-3	50.0	0:50:00	415.800	1.200	3.116	3.300	188	250	260	66		81	77	6.0	1.10	69.32	47.412	103.3	54.186
D-4	52.5	0:52:30	418.270	1.200	3.116	3.300	190	247	260	67		82	77	6.0	1.10	69.43	50.005	103.4	54.551
D-5	55.0	0:55:00	420.765	1.200	3.116	3.300	189	248	265	68		82	78	6.0	1.10	69.37	52.793	103.8	55.088
D-6	57.5	0:57:30	423.450	1.200	3.116	3.300	191	249	250	68		82	80	6.0	1.10	69.48	55.197	103.5	55.197
Last Pt	60.0	1:00:00	425.770																
Final Val	60.0	1:00:00	425.770											Max Vac	6.0	Final Values	55.197	103.5	
Average Values				0.968		2.650	186	250	254	65		81	77		0.98	61.74			

**CTM 027 (AMMONIA) - SAMPLE RECOVERY AND INTEGRITY DATA SHEET**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/05/09
<b>Sampling Location</b>	Unit 1	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b>Acetone Lot Number</b>	N/A

Run History Data				
Run Number	Base W/O DB-1	Base W/O DB-2	Base W/O DB-3	
<b>Run Start Time</b>	10:00	11:55	13:30	(hh:mm)
<b>Run Stop Time</b>	11:34	13:15	14:50	(hh:mm)
<b>Train Prepared By</b>	AS	AS	AS	
<b>Train Recovered By</b>	AS	AS	AS	
<b>Recovery Date</b>	10/5/2009	10/5/2009	10/5/2009	(mm/dd/yy)

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Volume					
<b>Final Volume</b>	(V <sub>f</sub> )	2201.2	2163.4	2162.2	ml
<b>Initial Volume</b>	(V <sub>i</sub> )	2069.4	2051.5	2058.1	ml
<b>Net Volume</b>	(V <sub>n</sub> )	131.7	111.9	104.1	ml
<b>Comments</b>					
Impinger 4 - Silica Gel Weight					
<b>Final Weight</b>	(W <sub>f</sub> )	931.8	923.4	939.7	g
<b>Initial Weight</b>	(W <sub>i</sub> )	918.4	903.9	931.8	g
<b>Net Weight</b>	(W <sub>n</sub> )	13.4	19.5	7.9	g
<b>Comments</b>					
Total Water Collected					
<b>Total Volume</b>	(V <sub>c</sub> )	145.2	131.4	112.0	ml



**TEST RESULTS**

**NH<sub>3</sub> Emissions  
Base Load with Duct Burners**



Air Hygiene International, Inc.  
 5634 S. 122nd East Ave, Suite F  
 Tulsa, Oklahoma 74146  
 (888) 461-8778  
 www.airhygiene.com

## AMMONIA ANALYSIS

PARAMETER	UNITS	RUN						BLANK
		1		2		3		
		Front (f)	Back (b)	Front (f)	Back (b)	Front (f)	Back (b)	
Sample Number		10	11	12	13	14	15	01
Lab Log Number		U1C-FH-R1	U1C-BH-R1	U1C-FH-R2	U1C-BH-R2	U1C-FH-R3	U1C-BH-R3	BLANK
Results ( $C_f$ or $C_b$ )	(mg/L)	8.8800	0.1100	10.6000	0.1200	11.8000	0.1600	0.1000
Practical Quantitation Limit (PQL)	(mg/L)	0.100	0.100	0.100	0.100	0.100	0.100	0.100
Sample Volume ( $V_{NH_3}$ )	(ml)	240	200	200	220	200	250	80
DGM Volume ( $V_m$ ) <sub>dscf</sub>	(dscf)	56.17		54.39		55.45		56.17
DGM Volume ( $V_m$ ) <sub>dstdL</sub>	(L <sub>dstd</sub> )	1590.62		1540.29		1570.30		1590.62
Sum of $NH_3$ Ion (N)	(mg/L)	8.8800	0.1100	10.6000	0.1200	11.8000	0.1600	0.1000
Total Sample Volume (S)	(ml)	240	200	200	220	200	250	80
Volume of $NH_3$ ( $V_a$ )	(L)	0.00280	0.00003	0.00279	0.00003	0.00310	0.00005	0.00001
O <sub>2</sub> Concentration	(%)	12.00		12.02		12.06		N/A
$NH_3$ Concentration ( $C_{NH_3}$ )	(ppmvd)	1.78		1.83		2.01		0.007
$C_{NH_3}$ @ 15% O <sub>2</sub>	(ppmvd)	1.18		1.22		1.34		N/A

### Equations & Constants:

Example Using Data from the 1st run

#### DGM Volume ( $L_{dstd}$ )

$$(V_m)_{dstdL} (L_{dstd}) = (V_m)_{dscf} \times 28.31685$$

$$(V_m)_{dstdL} (L_{dstd}) = 56.17 \text{ dscf} \times 28.31685 \text{ L/ft}^3 = 1590.62 \text{ L}_{dstd}$$

$(V_m)_{dscf}$  = Volume of gas sample measured by the DGM, corrected to standard conditions.

$C_f$  = Concentration of  $NH_3$  ion in the front half of train (main catch)

MW = molecular weight (ref. ASTM D 3588)

$C_b$  = Concentration of  $NH_3$  ion in the back half of train (breakthrough)

#### Volume of $NH_3$ (L)

$$V_a (L) = \frac{N \times S}{MW \times 1000} \times 22.4$$

$$V_a (L) = \frac{8.88 \text{ mg}}{L} \times 240 \text{ ml} \times \frac{L}{1000 \text{ ml}} \times \frac{22.4 \text{ L ideal gas}}{\text{g-mol substance}} \times \frac{\text{g-mol } NH_3}{17.03 \text{ g}} \times \frac{g}{1000 \text{ mg}} = 0.00280 \text{ L}$$

#### $NH_3$ Concentration (ppmvd)

$$C_{NH_3} (\text{ppmvd}) = \frac{V_{a(\text{front})} + V_{a(\text{back})}}{(V_m)_{dstdL}} \times 10^6$$

$$C_{NH_3} (\text{ppmvd}) = \frac{0.0028 \text{ L} + 0.00003 \text{ L}}{1590.62 \text{ L}_{dstd}} \times \frac{10^6 \text{ parts}}{1 \text{ part}} = 1.781 \text{ ppmvd}$$

22.4 = liters of ideal gas per mol of substance at 0°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)

**CTM 027 (AMMONIA) - RESULTS**

Plant Name	West County Energy Center	Date	10/5/2009 - 10/6/2009
Sampling Location	Unit 1C	Project #	bv-09-westcounty.fl-comp#1
Operator	TP	Stack Type	Circular

Historical Data						
Run Number		Base W/DB-1	Base W/DB-2	Base W/DB-3	Average	
Run Start Time		17:51	19:18	9:57		hh:mm
Run Stop Time		19:03	20:30	11:10		hh:mm
Meter Calibration Factor	(Y)	1.054	1.054	1.054		
Pitot Tube Coefficient	(C <sub>p</sub> )	0.840	0.840	0.840		
Average Nozzle Diameter	(D <sub>na</sub> )	0.248	0.248	0.248		in
Stack Test Data						
Initial Meter Volume	(V <sub>m</sub> ) <sub>i</sub>	479.088	533.303	586.721		ft3
Final Meter Volume	(V <sub>m</sub> ) <sub>f</sub>	532.798	585.280	639.468		ft3
Total Meter Volume	(V <sub>m</sub> )	53.710	51.977	52.747	52.811	ft3
Total Sampling Time	( $\Theta$ )	60.0	60.0	60.0	60.0	min
Average Meter Temperature	(t <sub>m</sub> ) <sub>avg</sub>	73.8	73.1	70.8	72.5	oF
Average Stack Temperature	(t <sub>s</sub> ) <sub>avg</sub>	172.8	172.9	180.9	175.5	oF
Barometric Pressure	(P <sub>b</sub> )	29.80	29.80	29.80	29.80	in Hg
Stack Static Pressure	(P <sub>static</sub> )	-0.70	-0.70	-0.70	-0.70	in H2O
Absolute Stack Pressure	(P <sub>s</sub> )	29.75	29.75	29.75	29.75	in Hg
Average Orifice Pressure Drop	( $\Delta H$ ) <sub>avg</sub>	2.79	2.59	2.70	2.69	in H2O
Absolute Meter Pressure	(P <sub>m</sub> )	29.92	29.92	29.92	29.92	in Hg
Avg Square Root Pitot Pressure	( $\Delta P^{1/2}$ ) <sub>avg</sub>	1.00	0.97	1.00	0.99	(in H2O) <sup>1/2</sup>
Moisture Content Data						
Impingers 1-3 Water Volume Gain	(V <sub>w</sub> )	142.6	128.5	126.1	132.4	ml
Impinger 4 Silica Gel Weight Gain	(W <sub>n</sub> )	13.4	18.1	19.3	16.9	g
Total Water Volume Collected	(V <sub>c</sub> )	156.0	146.7	145.5	149.4	ml
Standard Water Vapor Volume	(V <sub>w</sub> ) <sub>std</sub>	7.342	6.903	6.847	7.031	scf
Standard Meter Volume	(V <sub>m</sub> ) <sub>std</sub>	56.172	54.395	55.455	55.341	dscf
Calculated Stack Moisture	(B <sub>ws(calc)</sub> )	11.56	11.26	10.99	11.27	%
Saturated Stack Moisture	(B <sub>ws(svp)</sub> )	43.7	43.7	52.3	46.6	%
Reported Stack Moisture Content	(B <sub>ws</sub> )	11.56	11.26	10.99	11.27	%
Gas Analysis Data						
Carbon Dioxide Percentage	(%CO <sub>2</sub> )	5.1	5.2	5.2	5.2	%
Oxygen Percentage	(%O <sub>2</sub> )	12.0	12.0	12.1	12.0	%
Carbon Monoxide Percentage	(%CO)	0.0	0.0	0.0	0.0	%
Nitrogen Percentage	(%N <sub>2</sub> )	82.9	82.8	82.7	82.8	%
Dry Gas Molecular Weight	(M <sub>d</sub> )	29.29	29.31	29.32	29.31	lb/lb-mole
Wet Stack Gas Molecular Weight	(M <sub>w</sub> )	27.99	28.03	28.08	28.03	lb/lb-mole
Calculated Fuel Factor	(F <sub>c</sub> )	1.748	1.717	1.687	1.718	
Fuel F-Factor	(F <sub>d</sub> )	8644	8644	8644	8644	dscf/MMBtu
Percent Excess Air	(%EA)	121.4	122.1	123.4	122.3	%
Volumetric Flow Rate Data						
Average Stack Gas Velocity	(v <sub>s</sub> )	62.62	60.33	62.64	61.86	ft/sec
Stack Cross-Sectional Area	(A <sub>c</sub> )	378.35	378.35	378.35	378.35	ft <sup>2</sup>
Actual Stack Flow Rate	(Q <sub>aw</sub> )	1,421,507	1,369,592	1,421,878	1,404,326	acfm
Wet Standard Stack Flow Rate	(Q <sub>sw</sub> )	70,754	68,165	69,880	69,599	wkscfh
Dry Standard Stack Flow Rate	(Q <sub>sd</sub> )	1,042,898	1,008,144	1,036,672	1,029,238	dscfm
Percent of Isokinetic Rate	(I)	100.0	100.6	99.7	100.1	%
Ammonia Rate Data						
Stack Ammonia Concentration	(C <sub>NH3</sub> )	1.78	1.83	2.01	1.87	ppm
	(C <sub>NH3</sub> )	1.18	1.22	1.34	1.25	ppm@15%O <sub>2</sub>
Ammonia Emission Rate	(E <sub>NH3</sub> )	4.93	4.90	5.53	5.12	lbs/hr

**CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE**

**ALARMS exist and have been acknowledged.**

Source Information				
Plant Name	West County Energy Center			
Sampling Location	Unit 1C			
Fuel or Source Type	Gas, Natural			
Fuel F-Factor	8644	8644	8644	

Test Information			
Starting Test Date		10/5/2009 - 10/6/2009	
Project #		bv-09-westcounty.fl-comp#1	
Operator		TP	
Standard Temperature		68	oF
Standard Pressure		29.92	in Hg
Minimum Required Sample Vol.	indust. spec.	35	scf
Run Duration	chk Subpart	60	minutes
Unit Number		1C	
Load	% or w/DB	Base W/DB	
Base Run Number		Base W/DB	
Number of Ports Available		4	
Number of Ports Used		4	
Port Inside Diameter		6.00	in
Circular Stack			

Test Equipment Information					
Run		1	2	3	
Meter Box Number	from ACS	samp-cp-0005	samp-cp-0005	samp-cp-0005	
Meter Calibration Factor	(Y)	1.054	1.054	1.054	
Orifice Meter Coefficient	( $\Delta H @$ )	1.694	1.694	1.694	in H <sub>2</sub> O
Pitot Identification	from ACS	samp-up-0002	samp-up-0002	samp-up-0002	
Pitot Tube Coefficient	(C <sub>p</sub> )	0.840	0.840	0.840	
Nozzle Diameter	(D <sub>n</sub> )	0.248	0.248	0.248	in
Probe Number	from ACS	samp-up-0002	samp-up-0002	samp-up-0002	
Probe Length		120.00	120.00	120.00	in
(SS, Glass ....) Liner Material	from list	inconel	inconel	inconel	
Sample Case / Oven Number	from ACS	samp-bh-0006	samp-bh-0006	samp-bh-0006	
Impinger Case Number	from ACS	samp-bc-0002	samp-bc-0006	samp-bc-0002	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	5634 S. 122nd East Ave., Suite F
City, State Country Zip	Tulsa, Oklahoma 74146
Project Manager	Jake Fahlenkamp
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

**METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE**

<b>Plant Name</b>	West County Energy Center			<b>Date</b>	10/5/2009 - 10/6/2009	
<b>Sampling Location</b>	Unit 1C			<b>Project #</b>	bv-09-westcounty.fl-comp#1	
<b>Operator</b>	TP			<b># of Ports Used</b>	4	
<b>Stack Type</b>	Circular			<b>Pitot Identification</b>	samp-up-0002	
<b>Pitot Leak Check</b>	<input checked="" type="checkbox"/>	<b>PreTest</b>	<input checked="" type="checkbox"/>	<b>PostTest</b>	<b>Pitot Coefficient (C<sub>p</sub>)</b> 0.84	

Stack Dimensions			
<b>Diameter or Length of Stack</b>	(D)	263.38	in
<b>Width of Stack</b>	(W)		in
<b>Area of Stack</b>	(A <sub>s</sub> )	378.35	ft <sup>2</sup>

Pressures			
<b>Barometric Pressure</b>	(P <sub>b</sub> )	29.80	in Hg
<b>Static Pressure</b>	(P <sub>static</sub> )	-0.70	in H <sub>2</sub> O
<b>Absolute Stack Pressure</b>	(P <sub>s</sub> )	29.75	in Hg

Stack Gas Composition			
<b>Composition Data:</b>		<b>Estimated Composition</b>	
<b>Carbon Dioxide Concentration</b>	(%CO <sub>2</sub> )	5.0	%
<b>Oxygen Concentration</b>	(%O <sub>2</sub> )	12.0	%
<b>Carbon Monoxide Concentration</b>	(%CO)	0.0	%
<b>Nitrogen Concentration</b>	(%N <sub>2</sub> )	83.0	%
<b>Stack Moisture Content</b>	(B <sub>ws</sub> )	10.000	%
<b>Stack Dry Molecular Weight</b>	(M <sub>d</sub> )	29.28	lb/lb-mole
<b>Stack Wet Molecular Weight</b>	(M <sub>s</sub> )	28.15	lb/lb-mole

Results			
<b>Avg Stack Gas Velocity</b>	(V <sub>s</sub> )	60.5	ft/sec
<b>Avg Stack Dry Std Flow Rate</b>	(Q <sub>sd</sub> )	60,246,386	dscf/hr
<b>Avg Stack Dry Std Flow Rate</b>	(Q <sub>sd</sub> )	1,004,106	dscf/min
<b>Avg Stack Wet Flow Rate</b>	(Q <sub>sw</sub> )	1,372,789	acf/min
<b>Avg Stack Wet Std Flow Rate</b>	(Q <sub>sw</sub> )	66,940,428	ascf/hr

Stack Cross Section Schematic			


Velocity Traverse Data				
Run Number		Base W/DB-V1		
Run Time	7:00	Start	7:40	End
Traverse Point	Velocity Head (Δp)	Null Angle (N <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Local Velocity (V <sub>s0</sub> )
	in H <sub>2</sub> O	deg	oF	ft/sec
A-1	0.65	0	180	50.6
A-2	0.73	-5	182	53.7
A-3	0.80	5	184	56.3
A-4	0.87	10	183	58.7
A-5	0.89	5	186	59.5
A-6	0.81	0	187	56.8
B-1	0.54	0	184	46.3
B-2	0.64	0	191	50.7
B-3	0.70	5	192	53.0
B-4	0.74	0	190	54.4
B-5	0.77	5	191	55.6
B-6	0.75	0	192	54.9
C-1	1.00	-5	177	62.6
C-2	1.10	-5	183	66.0
C-3	1.20	5	184	69.0
C-4	1.20	5	185	69.0
C-5	1.10	5	186	66.1
C-6	0.90	5	187	59.9
D-1	0.90	0	181	59.6
D-2	1.10	-5	183	66.0
D-3	1.30	10	187	72.0
D-4	1.30	5	188	72.0
D-5	1.20	5	189	69.3
D-6	1.20	0	191	69.4
<b>Average</b>	0.93	4	186	
	0.96	= Square roots of Δp		

**METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/5/2009 - 10/6/2009
<b>Sampling Location</b>	Unit 1C	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b># of Ports Available</b>	4
<b>Stack Type</b>	Circular	<b># of Ports Used</b>	4
<b>Stack Size</b>	Large	<b>Port Inside Diameter</b>	6.00

Circular Stack or Duct Diameter			
<b>Distance to Far Wall of Stack</b>	(L <sub>fw</sub> )	282.38	in
<b>Distance to Near Wall of Stack</b>	(L <sub>nw</sub> )	19.00	in
<b>Diameter of Stack</b>	(D)	263.38	in
<b>Area of Stack</b>	(A <sub>s</sub> )	378.35	ft <sup>2</sup>

Distance from Port to Disturbances			
<b>Distance Upstream</b>	(A)	144.00	in
<b>Diameters Upstream</b>	(A <sub>D</sub> )	0.55	diameters
<b>Distance Downstream</b>	(B)	531.75	in
<b>Diameters Downstream</b>	(B <sub>D</sub> )	2.02	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of <sup>1</sup> Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 <sup>2</sup>	8 or 12 <sup>2</sup>
<b>Upstream Spec</b>		24	16
<b>Downstream Spec</b>		24	16
<b>Traverse Pts Required</b>		24	16

<sup>1</sup> Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.  
<sup>2</sup> 8 for Circular Stacks 12 to 24 inches  
 12 for Circular Stacks over 24 inches

Number of Traverse Points Used			
4	Ports by	6	Across
24	Pts Used	24	Required
		Particulate Traverse	

Location of Traverse Points in Circular Stacks										
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point)									
Number	Number of Traverse Points Across the Stack									
1	.146	.067	.044	.032	.026	.021	.018	.016	.014	
2	.854	.250	.146	.105	.082	.067	.057	.049	.044	
3		.750	.296	.194	.146	.118	.099	.085	.075	
4		.933	.704	.323	.226	.177	.146	.125	.109	
5			.854	.677	.342	.250	.201	.169	.146	
6			.956	.806	.658	.356	.269	.220	.188	
7				.895	.774	.644	.366	.283	.236	
8				.968	.854	.750	.634	.375	.296	
9					.918	.823	.731	.625	.382	
10					.974	.882	.799	.717	.618	
11						.933	.854	.780	.704	
12						.979	.901	.831	.764	

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.02	5 4/8	24 4/8
2	0.07	17 5/8	36 5/8
3	0.12	31 1/8	50 1/8
4	0.18	46 5/8	65 5/8
5	0.25	65 7/8	84 7/8
6	0.36	93 6/8	112 6/8
7			
8			
9			
10			
11			
12			



**METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER**

<b>Plant Name</b>	West County Energy Center			<b>Date</b>	10/5/2009 - 10/6/2009		
<b>Sampling Location</b>	Unit 1C			<b>Project #</b>	bv-09-westcounty.fl-comp#1		
<b>Operator</b>	TP			<b># of Ports Used</b>	4		
<b>Fuel Type</b>	Gas, Natural	<b>Minimum Fuel Factor</b>	1.600	<b>Maximum Fuel Factor</b>	1.836		
<b>Orsat Leak Check</b>	<input checked="" type="checkbox"/>	<b>PreTest</b>	<input checked="" type="checkbox"/>	<b>PostTest</b>	<b>Orsat Identification</b> N/A		

Gas Analysis Data										
Run Number		Base W/DB-1			Run Start Time		17:51	Run Stop Time		19:03
Sample Analysis Time	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N <sub>2</sub> )	Dry Molecular Weight (M <sub>d</sub> )	Molecular Weight Deviation (ΔM <sub>d</sub> )	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:12	5.1	12.0	4.7	5.1	12.0	0.0	82.9	29.29	0.00	
<b>Results</b>			<b>Averages</b>			5.1	12.0	0.0	82.9	29.29
<b>Average Calculated Fuel Factor</b>			(F <sub>o</sub> ) <sub>avg</sub>			1.748	<b>Molecular Wt Deviation &lt; 0.3?</b>		<input checked="" type="checkbox"/>	
<b>Average Excess Air</b>			(%EA) <sub>avg</sub>			121.4	<b>Fuel Factor in Handbook Range?</b>		<input checked="" type="checkbox"/>	

Gas Analysis Data										
Run Number		Base W/DB-2			Run Start Time		19:18	Run Stop Time		20:30
Sample Analysis Time	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N <sub>2</sub> )	Dry Molecular Weight (M <sub>d</sub> )	Molecular Weight Deviation (ΔM <sub>d</sub> )	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:12	5.2	12.0	4.5	5.2	12.0	0.0	82.8	29.31	0.00	
<b>Results</b>			<b>Averages</b>			5.2	12.0	0.0	82.8	29.31
<b>Average Calculated Fuel Factor</b>			(F <sub>o</sub> ) <sub>avg</sub>			1.717	<b>Molecular Wt Deviation &lt; 0.3?</b>		<input checked="" type="checkbox"/>	
<b>Average Excess Air</b>			(%EA) <sub>avg</sub>			122.1	<b>Fuel Factor in Handbook Range?</b>		<input checked="" type="checkbox"/>	

Gas Analysis Data										
Run Number		Base W/DB-3			Run Start Time		9:57	Run Stop Time		11:10
Sample Analysis Time	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO <sub>2</sub> )	Oxygen Conc. (%O <sub>2</sub> )	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N <sub>2</sub> )	Dry Molecular Weight (M <sub>d</sub> )	Molecular Weight Deviation (ΔM <sub>d</sub> )	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:13	5.2	12.1	2.1	5.2	12.1	0.0	82.7	29.32	0.00	
<b>Results</b>			<b>Averages</b>			5.2	12.1	0.0	82.7	29.32
<b>Average Calculated Fuel Factor</b>			(F <sub>o</sub> ) <sub>avg</sub>			1.687	<b>Molecular Wt Deviation &lt; 0.3?</b>		<input checked="" type="checkbox"/>	
<b>Average Excess Air</b>			(%EA) <sub>avg</sub>			123.4	<b>Fuel Factor in Handbook Range?</b>		<input checked="" type="checkbox"/>	

Fuel Factor F <sub>o</sub>		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Wood	1.000	1.120
Wood Bark	1.003	1.130

**METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES**

Plant Name	West County Energy Center			Date	10/5/2009 - 10/6/2009		
Sampling Location	Unit 1C			Project #	bv-09-westcounty.fl-comp#1		
Operator	TP			# of Ports Used	4		
Stack Type	Circular			Meter Box Number	samp-cp-0005		
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Meter Cal Factor (Y)	1.054	

Moisture Content Data							
Run Number	Base W/DB-1		Run Start Time		Run Stop Time		
Total Meter Volume	(V <sub>m</sub> )	53.710	dcf	Barometric Press.	(P <sub>b</sub> )	29.80	in Hg
Avg Stack Temp	(t <sub>s</sub> ) <sub>avg</sub>	173	oF	Stack Static Press.	(P <sub>static</sub> )	-0.70	in H2O
Avg Meter Temp	(t <sub>m</sub> ) <sub>avg</sub>	74	oF	Avg Orifice Press.	(ΔH) <sub>avg</sub>	2.79	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	H2SO4		H2SO4		Sil Gel		
Final Value	(V <sub>f</sub> ),(W <sub>f</sub> )	834.00	743.50	650.20	978.50		
Initial Value	(V <sub>i</sub> ),(W <sub>i</sub> )	722.70	717.40	645.30	965.10		
Net Value	(V <sub>n</sub> ),(W <sub>n</sub> )	111.3	26.1	4.9	13.4		
Results							
Total Weight	(W <sub>f</sub> )	155.70	g	Water Vol Weighed	(V <sub>wsg(std)</sub> )	7.341	scf
Std Meter Volume	(V <sub>m(std)</sub> )	56.160	dscf	Sat. Moisture Content	(B <sub>ws(svp)</sub> )	43.7	%
Calc Moisture Content	(B <sub>ws(calc)</sub> )	11.6	%	Final Moisture Content	(B <sub>ws</sub> )	11.6	%

Moisture Content Data							
Run Number	Base W/DB-2		Run Start Time		Run Stop Time		
Total Meter Volume	(V <sub>m</sub> )	51.977	dcf	Barometric Press.	(P <sub>b</sub> )	29.80	in Hg
Avg Stack Temp	(t <sub>s</sub> ) <sub>avg</sub>	173	oF	Stack Static Press.	(P <sub>static</sub> )	-0.70	in H2O
Avg Meter Temp	(t <sub>m</sub> ) <sub>avg</sub>	73	oF	Avg Orifice Press.	(ΔH) <sub>avg</sub>	2.59	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	H2SO4		H2SO4		Sil Gel		
Final Value	(V <sub>f</sub> ),(W <sub>f</sub> )	790.50	764.00	616.70	944.20		
Initial Value	(V <sub>i</sub> ),(W <sub>i</sub> )	723.50	715.60	603.80	926.10		
Net Value	(V <sub>n</sub> ),(W <sub>n</sub> )	67.0	48.4	12.9	18.1		
Results							
Total Weight	(W <sub>f</sub> )	146.40	g	Water Vol Weighed	(V <sub>wsg(std)</sub> )	6.903	scf
Std Meter Volume	(V <sub>m(std)</sub> )	54.391	dscf	Sat. Moisture Content	(B <sub>ws(svp)</sub> )	43.7	%
Calc Moisture Content	(B <sub>ws</sub> )	11.3	%	Final Moisture Content	(B <sub>ws</sub> )	11.3	%

Moisture Content Data							
Run Number	Base W/DB-3		Run Start Time		Run Stop Time		
Total Meter Volume	(V <sub>m</sub> )	52.747	dcf	Barometric Press.	(P <sub>b</sub> )	29.80	in Hg
Avg Stack Temp	(t <sub>s</sub> ) <sub>avg</sub>	181	oF	Stack Static Press.	(P <sub>static</sub> )	-0.70	in H2O
Avg Meter Temp	(t <sub>m</sub> ) <sub>avg</sub>	71	oF	Avg Orifice Press.	(ΔH) <sub>avg</sub>	2.70	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	H2SO4		H2SO4		Sil Gel		
Final Value	(V <sub>f</sub> ),(W <sub>f</sub> )	755.60	747.50	664.10	982.70		
Initial Value	(V <sub>i</sub> ),(W <sub>i</sub> )	691.80	702.00	647.50	963.40		
Net Value	(V <sub>n</sub> ),(W <sub>n</sub> )	63.8	45.5	16.6	19.3		
Results							
Total Weight	(W <sub>f</sub> )	145.20	g	Water Vol Weighed	(V <sub>wsg(std)</sub> )	6.846	scf
Std Meter Volume	(V <sub>m(std)</sub> )	55.453	dscf	Sat. Moisture Content	(B <sub>ws(svp)</sub> )	52.3	%
Calc Moisture Content	(B <sub>ws</sub> )	11.0	%	Final Moisture Content	(B <sub>ws</sub> )	11.0	%

**CTM 027 (AMMONIA) ISOKINETIC SAMPLING DATA**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/5/2009 - 10/6/2009
<b>Sampling Location</b>	Unit 1C	<b>Project #</b>	bw-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b>Run #</b>	Base W/DB-1
<b># of Points Across</b>	6	<b># of Ports Used</b>	4

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
<b>Pitot Tube Coefficient</b>	(C <sub>p</sub> )	0.84	
<b>Avg Stack Temp</b>	(t <sub>s</sub> )	173	oF
<b>Avg Gas Meter Temp</b>	(t <sub>m</sub> )	74	
<b>DH @ 0.75 SCFM</b>	(ΔH@)	1.69	in H2O
<b>Avg Pitot Tube Diff. Pressure</b>	(ΔP <sub>pt</sub> )	1.00	in H2O
<b>Stack Moisture Content</b>	(B <sub>wsp</sub> )	10.00	%
<b>Stack Dry Molecular Weight</b>	(M <sub>d</sub> )	29.29	lb/lb-mole
<b>Estimated Orifice Flow Rate</b>	(Q <sub>m</sub> )	0.750	acfm
<b>DP to DH Isokinetic Factor</b>	(K)	2.71	

Leak Checks					
<b>Train</b>	<b>Pre</b>	0.005	ft3/min @	15	in Hg
<b>OK?</b>	<input checked="" type="checkbox"/>	<b>Post</b>	0	ft3/min @	15
<b>Pitot</b>	<b>Pre</b>	6.6/5.7	in. H <sub>2</sub> O for	15	sec
<b>OK?</b>	<input checked="" type="checkbox"/>	<b>Post</b>	5.9/6.0	in. H <sub>2</sub> O for	15
<b>Orsat</b>	<b>OK?</b>	<input type="checkbox"/>			

Sampling Equipment			
<b>Meter #</b>	samp-cp-0005		
<b>Meterbox Cal. Factor</b>	(Y)	1.054	
<b>Nozzle #</b>	N/A		
<b>Average Nozzle Diameter</b>	(D <sub>na</sub> )	0.2480	in
<b>Rec. Nozzle Diameter</b>	(D <sub>n</sub> )	0.2206	in
<b>Probe # / Length</b>	samp-up-0002	/ 120	in
<b>Liner Material</b>	inconel		
<b>Sample Case / Oven #</b>	samp-bh-0006		
<b>Impinger Case #</b>	samp-bc-0002		

Nozzle Measurements				
<b>Pre</b>	0.248	0.248	0.248	PASS
<b>Post</b>	0.248	0.248	0.248	PASS

Run Time		
<b>Start</b>	17:51	<b>End</b> 19:03

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
<b>Pre</b>	722.70	717.40	645.30	965.10				
<b>Post</b>	834.00	743.50	650.20	978.50				

Pressures			
<b>Barometric Pressure</b>	(P <sub>b</sub> )	29.80	in Hg
<b>Stack Static Pressure</b>	(P <sub>static</sub> )	-0.70	in H2O
<b>Absolute Stack Pressure</b>	(P <sub>a</sub> )	29.75	in Hg
<b>Absolute Meter Pressure</b>	(P <sub>m</sub> )	29.92	in Hg

<b>Wash Volume</b>	<b>H<sub>2</sub>O</b>	50.0	ml	<b>Filter #</b>	
	<b>MeCl</b>		ml		

Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V <sub>m</sub> )	Velocity Head (Δp)	Desired Orifice ΔH (ΔH <sub>d</sub> )		Actual Orifice ΔH (ΔH <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>mo</sub> )	Pump Vacuum	Square Root ΔP (ΔP <sup>1/2</sup> )	Local Stack Velocity (v <sub>s</sub> )	Cumulative Meter Volume (V <sub>m</sub> ) <sub>Σ</sub>	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m</sub> ) <sub>Σ</sub>
					in H2O	in H2O														
	min	hh:mm:ss	ft3	in H2O	in H2O	in H2O	oF	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H2O) <sup>1/2</sup>	ft/sec	scf	%	scf
A-1	0.0	0:00:00	479.088	0.600	1.629	1.600	170	247	257	68			74	72	1.5	0.77	48.23	1.960	107.7	47.031
A-2	2.5	0:02:30	480.965	0.610	1.656	1.700	174	247	258	64			74	72	1.5	0.78	48.79	3.944	108.1	47.325
A-3	5.0	0:05:00	482.865	0.730	1.981	2.000	174	247	260	59			75	72	2.0	0.85	53.37	5.494	99.5	43.954
A-4	7.5	0:07:30	484.350	0.800	2.171	2.200	176	249	259	57			75	73	2.5	0.89	55.96	7.618	100.1	45.708
A-5	10.0	0:10:00	486.385	0.850	2.307	2.300	175	246	257	56			76	72	3.0	0.92	57.64	9.753	99.8	46.813
A-6	12.5	0:12:30	488.430	0.880	2.388	2.400	175	249	260	56			76	72	3.0	0.94	58.65	11.909	99.5	47.635
B-1	15.0	0:15:00	490.495	0.620	1.683	1.700	170	249	259	68			75	72	1.5	0.79	49.03	13.881	100.6	47.591
B-2	17.5	0:17:30	492.385	0.740	2.009	2.000	171	246	256	64			75	72	2.5	0.86	53.61	15.864	100.3	47.593
B-3	20.0	0:20:00	494.285	0.810	2.199	2.200	171	243	249	64			75	72	2.5	0.90	56.09	17.969	100.2	47.918
B-4	22.5	0:22:30	496.300	0.810	2.199	2.200	171	241	253	64			75	72	2.5	0.90	56.09	20.048	100.0	48.115
B-5	25.0	0:25:00	498.290	0.800	2.171	2.200	172	244	258	65			76	73	2.5	0.89	55.78	22.144	100.0	48.314
B-6	27.5	0:27:30	500.300	0.800	2.171	2.200	172	243	251	66			76	72	2.5	0.89	55.78	24.266	100.1	48.533
C-1	30.0	0:30:00	502.334	1.300	3.528	3.500	169	254	263	64			79	72	5.5	1.14	70.94	26.841	99.7	49.552
C-2	32.5	0:32:30	504.800	1.300	3.528	3.500	171	252	263	56			75	72	5.5	1.14	71.05	29.545	99.8	50.648
C-3	35.0	0:35:00	507.380	1.300	3.528	3.500	173	254	259	53			75	73	5.5	1.14	71.17	32.460	100.7	51.936
C-4	37.5	0:37:30	510.165	1.300	3.528	3.500	173	253	260	56			75	72	5.5	1.14	71.17	34.698	99.6	52.046
C-5	40.0	0:40:00	512.300	1.300	3.528	3.500	172	254	260	55			75	73	5.5	1.14	71.11	37.393	99.7	52.791
C-6	42.5	0:42:30	514.875	1.300	3.528	3.500	173	254	268	55			75	72	5.5	1.14	71.17	40.031	99.6	53.375
D-1	45.0	0:45:00	517.392	1.400	3.800	3.800	171	238	254	56			74	72	6.0	1.18	73.74	42.769	99.6	54.024
D-2	47.5	0:47:30	520.000	1.400	3.800	3.800	172	240	255	55			74	72	6.0	1.18	73.80	45.529	99.6	54.635
D-3	50.0	0:50:00	522.630	1.300	3.528	3.500	175	239	256	57			75	73	6.0	1.14	71.28	48.377	100.0	55.288
D-4	52.5	0:52:30	525.350	1.300	3.528	3.500	175	242	253	58			75	73	5.5	1.14	71.28	50.942	99.8	55.573
D-5	55.0	0:55:00	527.800	1.200	3.257	3.300	177	240	253	59			76	73	5.5	1.10	68.59	53.556	99.9	55.884
D-6	57.5	0:57:30	530.300	1.200	3.257	3.300	176	239	257	60			75	72	5.5	1.10	68.54	56.172	100.0	56.172
Last Pt	60.0	1:00:00	532.798																	
Final Val	60.0	1:00:00	532.798										Max Vac	6.0		Final Values	56.172	100.0		
Average Values				1.03		2.79	173	246	257	60			75	72		1.00	62.62			

**CTM 027 (AMMONIA) ISOKINETIC SAMPLING DATA**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/5/2009 - 10/6/2009
<b>Sampling Location</b>	Unit 1C	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b>Run #</b>	Base W/DB-2
<b># of Points Across</b>	6	<b># of Ports Used</b>	4

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
<b>Pitot Tube Coefficient</b>	(C <sub>p</sub> )	0.84	
<b>Avg Stack Temp</b>	(t <sub>s</sub> )	173	oF
<b>Avg Gas Meter Temp</b>	(t <sub>m</sub> )	74	
<b>DH @ 0.75 SCFM</b>	(ΔH@)	1.69	in H2O
<b>Avg Pitot Tube Diff. Pressure</b>	(ΔP <sub>avg</sub> )	1.00	in H2O
<b>Stack Moisture Content</b>	(B <sub>wa</sub> )	10.00	%
<b>Stack Dry Molecular Weight</b>	(M <sub>d</sub> )	29.29	lb/lb-mole
<b>Estimated Orifice Flow Rate</b>	(Q <sub>m</sub> )	0.895	acfm
<b>DP to DH Isokinetic Factor</b>	(K)	2.71	

Leak Checks					
<b>Train</b>	<b>Pre</b>	0.0075	ft3/min @	15	in Hg
<b>OK?</b>	<input checked="" type="checkbox"/>	<b>Post</b>	0.015	ft3/min @	15
<b>Pitot</b>	<b>Pre</b>	6.2/5.8	in. H <sub>2</sub> O for	15	sec
<b>OK?</b>	<input checked="" type="checkbox"/>	<b>Post</b>	6.7/5.6	in. H <sub>2</sub> O for	15
<b>Orsat</b>	<b>OK?</b>	<input type="checkbox"/>			

Sampling Equipment		
<b>Meter #</b>	samp-cp-0005	
<b>Meterbox Cal. Factor</b>	(Y)	1.054
<b>Nozzle #</b>	N/A	
<b>Average Nozzle Diameter</b>	(D <sub>na</sub> )	0.2480 in
<b>Rec. Nozzle Diameter</b>	(D <sub>ra</sub> )	0.2408 in
<b>Probe # / Length</b>	samp-pp-0002 / 120 in	
<b>Liner Material</b>	inconel	
<b>Sample Case / Oven #</b>	samp-bh-0006	
<b>Impinger Case #</b>	samp-bc-0006	

Nozzle Measurements				
<b>Pre</b>	0.248	0.248	0.248	PASS
<b>Post</b>	0.248	0.248	0.248	PASS

Pressures			
<b>Barometric Pressure</b>	(P <sub>b</sub> )	29.80	in Hg
<b>Stack Static Pressure</b>	(P <sub>static</sub> )	-0.70	in H2O
<b>Absolute Stack Pressure</b>	(P <sub>a</sub> )	29.75	in Hg
<b>Absolute Meter Pressure</b>	(P <sub>m</sub> )	29.92	in Hg

Run Time		
<b>Start</b>	19:18	<b>End</b> 20:30

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
<b>Pre</b>	723.50	715.60	603.80	926.10				
<b>Post</b>	790.50	764.00	616.70	944.20				

<b>Wash</b>	<b>H<sub>2</sub>O</b>	50.0	ml	<b>Filter #</b>	
<b>Volume</b>	<b>MeCl</b>		ml		

Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V <sub>m</sub> )	Velocity Head (Δp)	Desired Orifice ΔH (ΔH <sub>d</sub> )	Actual Orifice ΔH (ΔH <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>mo</sub> )	Pump Vacuum	Square Root ΔP (ΔP <sup>1/2</sup> )	Local Stack Velocity (V <sub>s</sub> )	Cumulative Meter Volume (V <sub>m,stat</sub> )	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m,stat</sub> )
	min	hh:mm:ss	ft3	in H2O	in H2O	in H2O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H2O) <sup>1/2</sup>	ft/sec	scf	%	scf
A-1	0.0	0:00:00	533.303	1.200	3.253	3.300	171	223	225	58		74	72	4.5	1.10	68.27	2.539	98.8	60.941
A-2	2.5	0:02:30	535.725	1.300	3.524	3.500	173	234	223	53		75	73	5.0	1.14	71.17	5.235	99.9	62.821
A-3	5.0	0:05:00	538.300	1.300	3.524	3.500	173	234	226	54		75	72	5.0	1.14	71.17	7.792	98.5	62.336
A-4	7.5	0:07:30	540.740	1.200	3.253	3.300	176	238	228	56		75	72	5.0	1.10	68.54	10.411	99.5	62.463
A-5	10.0	0:10:00	543.240	1.200	3.253	3.300	176	243	227	59		76	72	5.0	1.10	68.54	13.048	100.2	62.628
A-6	12.5	0:12:30	545.760	1.100	2.982	3.000	177	239	227	63		76	72	5.0	1.05	65.67	15.599	100.8	62.396
B-1	15.0	0:15:00	548.200	1.100	2.982	3.000	170	249	231	63		79	72	5.0	1.05	65.31	18.247	101.8	62.563
B-2	17.5	0:17:30	550.740	1.200	3.253	3.300	171	251	237	62		75	72	5.0	1.10	68.27	20.840	101.7	62.519
B-3	20.0	0:20:00	553.215	1.300	3.524	3.500	171	253	246	63		75	72	5.0	1.14	71.05	23.475	101.3	62.601
B-4	22.5	0:22:30	555.730	1.300	3.524	3.500	173	254	249	66		75	72	5.0	1.14	71.17	26.116	101.1	62.679
B-5	25.0	0:25:00	558.250	1.200	3.253	3.300	173	256	252	67		75	72	5.0	1.10	68.38	28.708	101.1	62.637
B-6	27.5	0:27:30	560.725	1.000	2.711	2.700	174	253	244	68		75	72	3.5	1.00	62.47	31.062	101.0	62.123
C-1	30.0	0:30:00	562.975	0.550	1.491	1.500	169	247	243	68		73	72	1.0	0.74	46.14	33.125	102.1	61.154
C-2	32.5	0:32:30	564.950	0.550	1.491	1.500	170	251	248	67		74	73	1.0	0.74	46.18	34.872	102.0	59.780
C-3	35.0	0:35:00	566.625	0.710	1.925	1.900	171	252	247	67		73	71	1.0	0.84	52.51	36.625	101.4	58.600
C-4	37.5	0:37:30	568.300	0.700	1.897	1.900	172	249	244	67		73	71	1.0	0.84	52.18	38.405	100.9	57.607
C-5	40.0	0:40:00	570.000	0.750	2.033	2.000	172	252	245	67		75	72	1.0	0.87	54.01	40.226	100.4	56.790
C-6	42.5	0:42:30	571.745	0.800	2.168	2.200	172	249	241	67		73	71	1.0	0.89	55.78	42.047	99.8	56.063
D-1	45.0	0:45:00	573.483	0.530	1.437	1.400	171	242	242	59		73	71	2.0	0.73	45.37	44.130	100.8	55.743
D-2	47.5	0:47:30	575.475	0.680	1.843	1.800	173	241	240	55		73	70	1.0	0.82	51.47	46.068	100.8	55.281
D-3	50.0	0:50:00	577.325	0.760	2.060	2.100	174	245	238	54		73	72	2.0	0.87	54.46	48.082	100.7	54.950
D-4	52.5	0:52:30	579.250	0.760	2.060	2.100	175	242	233	54		73	72	2.0	0.87	54.50	50.122	100.7	54.678
D-5	55.0	0:55:00	581.200	0.850	2.304	2.300	177	242	233	57		73	72	2.5	0.92	57.73	52.320	100.8	54.595
D-6	57.5	0:57:30	583.300	0.850	2.304	2.300	175	245	230	57		74	70	2.5	0.92	57.64	54.395	100.6	54.395
Last Pt	60.0	1:00:00	585.280																
Final Val	60.0	1:00:00	585.280										Max Vac	5.0	Final Values		54.395	100.6	
Average Values				0.95		2.59	173	245	237	61		74	72		0.97	60.33			

**CTM 027 (AMMONIA) ISOKINETIC SAMPLING DATA**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/6/2009
<b>Sampling Location</b>	Unit 1C	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b>Run #</b>	Base W/DB-3
<b># of Points Across</b>	6	<b># of Ports Used</b>	4

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
<b>Pitot Tube Coefficient</b>	(C <sub>p</sub> )	0.84	
<b>Avg Stack Temp</b>	(t <sub>s</sub> )	173	oF
<b>Avg Gas Meter Temp</b>	(t <sub>m</sub> )	73	
<b>DH @ 0.75 SCFM</b>	(ΔH@)	1.69	in H2O
<b>Avg Pitot Tube Diff. Pressure</b>	(ΔP <sub>pit</sub> )	0.97	in H2O
<b>Stack Moisture Content</b>	(B <sub>ws</sub> )	10.00	%
<b>Stack Dry Molecular Weight</b>	(M <sub>d</sub> )	29.31	lb/lb-mole
<b>Estimated Orifice Flow Rate</b>	(Q <sub>m</sub> )	0.866	acfm
<b>DP to DH Isokinetic Factor</b>	(K)	2.71	

Leak Checks					
Train OK? <input checked="" type="checkbox"/>	Pre	0.015	ft3/min @	15	in Hg
	Post	0	ft3/min @	15	in Hg
Pitot OK? <input checked="" type="checkbox"/>	Pre	5.4/7.0	in. H2O for	15	sec
	Post	6.3/6.5	in. H2O for	15	sec
Orsat OK? <input type="checkbox"/>					

Sampling Equipment			
<b>Meter #</b>	samp-cp-0005		
<b>Meterbox Cal. Factor</b>	(Y)	1.054	
<b>Nozzle #</b>	N/A		
<b>Average Nozzle Diameter</b>	(D <sub>na</sub> )	0.2480	in
<b>Rec. Nozzle Diameter</b>	(D <sub>n</sub> )	0.2393	in
<b>Probe # / Length</b>	samp-up-0002 / 120		
<b>Liner Material</b>	inconel		
<b>Sample Case / Oven #</b>	samp-bh-0006		
<b>Impinger Case #</b>	samp-bc-0002		

Pressures			
<b>Barometric Pressure</b>	(P <sub>b</sub> )	29.80	in Hg
<b>Stack Static Pressure</b>	(P <sub>static</sub> )	-0.70	in H2O
<b>Absolute Stack Pressure</b>	(P <sub>s</sub> )	29.75	in Hg
<b>Absolute Meter Pressure</b>	(P <sub>m</sub> )	29.92	in Hg

Nozzle Measurements				
Pre	0.248	0.248	0.248	PASS
Post	0.248	0.248	0.248	PASS

Run Time		
Start	9:57	End 11:10

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8	Wash Volume	H <sub>2</sub> O MeCl	50.0 ml	Filter #
Pre	691.80	702.00	647.50	963.40								
Post	755.60	747.50	664.10	982.70								

Traverse Point #	Sampling Time (Θ)	Timer Time	Dry Gas Meter Reading (V <sub>m</sub> )	Velocity Head (Δp)	Desired Orifice ΔH (ΔH <sub>d</sub> )	Actual Orifice ΔH (ΔH <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>mo</sub> )	Pump Vacuum	Square Root ΔP (ΔP <sup>1/2</sup> )	Local Stack Velocity (v <sub>s</sub> )	Cumulative Meter Volume (V <sub>m</sub> ) <sub>STW</sub>	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m</sub> ) <sub>STW</sub>
A-1	0.0	0:00:00	586.721	1.100	2.954	3.000	183	252	260	60		68	67	4.0	1.05	65.97	2.412	99.0	57.898
A-2	2.5	0:02:30	589.000	1.000	2.685	2.700	184	253	258	54		70	67	3.5	1.00	62.94	4.788	100.6	57.455
A-3	5.0	0:05:00	591.250	0.940	2.524	2.500	184	250	259	54		71	68	3.5	0.97	61.03	7.105	101.4	56.841
A-4	7.5	0:07:30	593.450	0.850	2.282	2.300	184	249	254	57		72	67	2.5	0.92	58.03	9.263	101.2	55.579
A-5	10.0	0:10:00	595.500	0.800	2.148	2.100	186	244	239	66		72	69	2.0	0.89	56.39	11.322	100.9	54.344
A-6	12.5	0:12:30	597.460	0.760	2.041	2.100	186	244	253	66		73	68	2.0	0.87	54.96	13.355	100.8	53.420
B-1	15.0	0:15:00	599.396	0.750	2.014	2.000	180	251	240	68		70	67	1.5	0.87	54.34	15.499	101.6	53.138
B-2	17.5	0:17:30	601.430	0.750	2.014	2.000	182	250	244	59		71	67	1.5	0.87	54.43	17.468	101.1	52.403
B-3	20.0	0:20:00	603.300	0.740	1.987	2.000	179	250	247	55		72	68	2.5	0.86	53.94	19.517	101.3	52.046
B-4	22.5	0:22:30	605.250	0.730	1.960	1.900	182	253	255	55		72	68	1.5	0.85	53.70	21.513	101.2	51.632
B-5	25.0	0:25:00	607.150	0.600	1.611	1.600	178	253	251	56		74	68	1.0	0.77	48.53	23.347	101.2	50.940
B-6	27.5	0:27:30	608.900	0.550	1.477	1.500	178	253	252	55		73	68	1.0	0.74	46.46	25.151	101.4	50.302
C-1	30.0	0:30:00	610.620	1.100	2.954	2.700	180	257	258	56		72	70	3.0	1.05	65.81	27.389	100.6	50.565
C-2	32.5	0:32:30	612.750	1.200	3.222	3.200	179	254	259	55		75	69	4.0	1.10	68.68	29.647	99.7	50.824
C-3	35.0	0:35:00	614.900	1.300	3.491	3.500	179	255	256	55		74	69	5.5	1.14	71.49	32.408	100.0	51.853
C-4	37.5	0:37:30	617.525	1.300	3.491	3.500	179	254	255	57		74	72	5.5	1.14	71.49	34.847	99.5	52.270
C-5	40.0	0:40:00	619.850	1.300	3.491	3.500	178	255	255	59		74	69	5.5	1.14	71.43	37.487	99.5	52.923
C-6	42.5	0:42:30	622.360	1.300	3.491	3.500	177	255	254	65		74	70	5.5	1.14	71.38	40.130	99.4	53.507
D-1	45.0	0:45:00	624.875	1.000	2.685	2.700	182	257	250	68		73	69	3.5	1.00	62.85	42.468	99.5	53.644
D-2	47.5	0:47:30	627.100	1.200	3.222	3.200	183	258	255	68		73	70	4.5	1.10	68.90	44.954	99.4	53.945
D-3	50.0	0:50:00	629.465	1.300	3.491	3.500	182	258	251	67		75	71	5.5	1.14	71.66	47.560	99.3	54.355
D-4	52.5	0:52:30	631.950	1.300	3.491	3.500	180	256	256	66		74	70	5.5	1.14	71.54	50.188	99.3	54.750
D-5	55.0	0:55:00	634.450	1.200	3.222	3.200	179	257	256	67		74	70	5.5	1.10	68.68	52.813	99.5	55.109
D-6	57.5	0:57:30	636.950	1.200	3.222	3.200	178	257	254	67		74	71	5.5	1.10	68.63	55.455	99.7	55.455
Last Pt	60.0	1:00:00	639.468																
Final Val	60.0	1:00:00	639.468											Max Vac	5.5	Final Values	55.455	99.7	
Average Values				1.011		2.704	181	253	253	61		73	69		1.00	62.64			

**CTM 027 (AMMONIA) - SAMPLE RECOVERY AND INTEGRITY DATA SHEET**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	10/5/2009 - 10/6/2009
<b>Sampling Location</b>	Unit 1C	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Operator</b>	TP	<b>Acetone Lot Number</b>	N/A

Run History Data				
Run Number	Base W/DB-1	Base W/DB-2	Base W/DB-3	
<b>Run Start Time</b>	17:51	19:18	9:57	(hh:mm)
<b>Run Stop Time</b>	19:03	20:30	11:10	(hh:mm)
<b>Train Prepared By</b>	AS	AS	AS	
<b>Train Recovered By</b>	AS	AS	AS	
<b>Recovery Date</b>	10/5/2009	10/5/2009	10/5/2009	(mm/dd/yy)



Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Volume					
<b>Final Volume</b>	(V <sub>f</sub> )	2231.7	2175.1	2171.1	ml
<b>Initial Volume</b>	(V <sub>i</sub> )	2089.2	2046.6	2045.0	ml
<b>Net Volume</b>	(V <sub>n</sub> )	142.6	128.5	126.1	ml
<b>Comments</b>					
Impinger 4 - Silica Gel Weight					
<b>Final Weight</b>	(W <sub>f</sub> )	978.5	944.2	982.7	g
<b>Initial Weight</b>	(W <sub>i</sub> )	965.1	926.1	963.4	g
<b>Net Weight</b>	(W <sub>n</sub> )	13.4	18.1	19.3	g
<b>Comments</b>					
Total Water Collected					
<b>Total Volume</b>	(V <sub>tc</sub> )	156.0	146.7	145.5	ml

# Ammonia Sample Log-In Sheet

Lab Tech: Albert Septiano  
Project: bv-09-westcounty.fl-comp#1  
Collected by: Albert Septiano  
Date Received: 10/5/2009 and 10/6/2009



## BLANKS

Filter

AHI Lab #	Sample ID	Sample Source Description	Run #	Contents	Sample Date	Comments	Volume (ml)
BLANK	01	Unit 1C w/o DB		H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	80

## SAMPLES

AHI Lab #	Sample ID	Sample Source Description	Run #	Contents	Sample Date	Comments	Volume (ml)
U1C-R1-FH	02	Unit 1C Run 1 w/o DB Front Half	1	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	270
U1C-R1-BH	03	Unit 1C Run 1 w/o DB Back Half	1	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	150
U1C-R2-FH	04	Unit 1C Run 2 w/o DB Front Half	2	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	200
U1C-R2-BH	05	Unit 1C Run 2 w/o DB Back Half	2	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	190
U1C-R3-FH	06	Unit 1C Run 3 w/o DB Front Half	3	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	210
U1C-R3-BH	07	Unit 1C Run 3 w/o DB Back Half	3	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	200
U1C-FH-R1	10	Unit 1C Run 1 w/DB Front Half	1	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	240
U1C-BH-R1	11	Unit 1C Run 1 w/DB Back Half	1	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	200
U1C-FH-R2	12	Unit 1C Run 2 w/DB Front Half	2	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	200
U1C-BH-R2	13	Unit 1C Run 2 w/DB Back Half	2	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/5/2009	Normal	220
U1C-FH-R3	14	Unit 1C Run 3 w/DB Front Half	3	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/6/2009	Normal	200
U1C-BH-R3	15	Unit 1C Run 3 w/DB Back Half	3	H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> O	10/6/2009	Normal	250

# Ammonia Sample Measurement

Lab Tech:	Albert Septiano
Project:	bv-09-westcounty.fl-comp#1
Date Analyzed:	10/5/2009
Time Analyzed:	2:30 PM
Temp (°F)	74.0
Humidity	45%
BP (In HG)	29.80
Analysis Method	350.3



Calibration Data		
Concentration (ppm)	Pre-Cal (ppm)	Pre-Cal (mV)
0.0	0.0	145.8
1.0	1.0	9.3
5.0	5.0	-30.0
10.0	10.0	-49.3
20.0	20.0	-69.1
Slope		
Linearity	1.0000	N/A

Sample ID	Sample Amt Used (ml)	ISA/pH Volume (ml)	Meter Reading (mg/L)	Time Analyzed (hh:mm:ss)	Dilution Factor	Sample Volume	MQL (mg/L)	PQL (mg/L)	Final Conc. (mg/L)
BLANK	80.0	2.0	0.0	15:00:00	1.0	80.0	0.10	0.1	BPQL
U1C-R1-FH	90.0	2.0	8.3	15:10:00	1.0	270.0	0.10	0.1	8.3
U1C-R1-BH	80.0	2.0	0.1	15:21:00	1.0	150.0	0.10	0.1	0.1
U1C-R2-FH	80.0	2.0	11.1	15:42:00	1.0	200.0	0.10	0.1	11.1
U1C-R2-BH	80.0	2.0	0.1	15:59:00	1.0	190.0	0.10	0.1	BPQL
U1C-R3-FH	85.0	2.0	11.0	16:15:00	1.0	210.0	0.10	0.1	11.0
U1C-R3-BH	90.0	2.0	0.2	16:30:00	1.0	200.0	0.10	0.1	0.2
U1C-FH-R1	90.0	2.0	8.9	9:12:00	1.0	240.0	0.10	0.1	8.9
U1C-BH-R1	90.0	2.0	0.1	9:17:00	1.0	200.0	0.10	0.1	0.1
U1C-FH-R2	90.0	2.0	10.6	9:25:00	1.0	200.0	0.10	0.1	10.6
U1C-BH-R2	90.0	2.0	0.1	9:30:00	1.0	220.0	0.10	0.1	0.1
U1C-FH-R3	90.0	2.0	11.8	14:20:00	1.0	200.0	0.10	0.1	11.8
U1C-BH-R3	90.0	2.0	0.2	14:28:00	1.0	250.0	0.10	0.1	0.2





## Ammonia Analysis

**Project Name:** bv-09-westcounty.fl-comp#1  
**Date Received:** 10/5/2009 and 10/6/2009

**AHI Lab No.:** BLANK  
**Sample ID:** 01  
**Sampling Date:** 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	BPQL	0.10	10/5/09 15:00
Volume	Volume in ml	N/A	80	N/A	10/5/09 14:30

**AHI Lab No.:** U1C-R1-FH  
**Sample ID:** 02  
**Sampling Date:** 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	8.25	0.10	10/5/09 15:10
Volume	Volume in ml	N/A	270	N/A	10/5/09 14:30

**AHI Lab No.:** U1C-R1-BH  
**Sample ID:** 03  
**Sampling Date:** 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	0.14	0.10	10/5/09 15:21
Volume	Volume in ml	N/A	150	N/A	10/5/09 14:30

**AHI Lab No.:** U1C-R2-FH  
**Sample ID:** 04  
**Sampling Date:** 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	11.1	0.10	10/5/09 15:42
Volume	Volume in ml	N/A	200	N/A	10/5/09 14:30

**AHI Lab No.:** U1C-R2-BH  
**Sample ID:** 05  
**Sampling Date:** 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	BPQL	0.10	10/5/09 15:59
Volume	Volume in ml	N/A	190	N/A	10/5/09 14:30

**AHI Lab No.:** U1C-R3-FH  
**Sample ID:** 06  
**Sampling Date:** 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	11	0.10	10/5/09 16:15
Volume	Volume in ml	N/A	210	N/A	10/5/09 14:30

**AHI Lab No.:** U1C-R3-BH  
**Sample ID:** 07  
**Sampling Date:** 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	0.19	0.10	10/5/09 16:30
Volume	Volume in ml	N/A	200	N/A	10/5/09 14:30



## Ammonia Analysis

AHI Lab No.: U1C-FH-R1  
 Sample ID: 10  
 Sampling Date: 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	8.88	0.10	10/5/09 9:12
Volume	Volume in ml	N/A	240	N/A	10/5/09 14:30

AHI Lab No.: U1C-BH-R1  
 Sample ID: 11  
 Sampling Date: 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	0.11	0.10	10/5/09 9:17
Volume	Volume in ml	N/A	200	N/A	10/5/09 14:30

AHI Lab No.: U1C-FH-R2  
 Sample ID: 12  
 Sampling Date: 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	10.6	0.10	10/5/09 9:25
Volume	Volume in ml	N/A	200	N/A	10/5/09 14:30

AHI Lab No.: U1C-BH-R2  
 Sample ID: 13  
 Sampling Date: 10/5/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	0.12	0.10	10/5/09 9:30
Volume	Volume in ml	N/A	220	N/A	10/5/09 14:30

AHI Lab No.: U1C-FH-R3  
 Sample ID: 14  
 Sampling Date: 10/6/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	11.8	0.10	10/5/09 14:20
Volume	Volume in ml	N/A	200	N/A	10/5/09 14:30

AHI Lab No.: U1C-BH-R3  
 Sample ID: 15  
 Sampling Date: 10/6/2009

Test Requested	Method Parameter	Prep Info	Result	PQL*	Analysis Date
Ammonia Nitrogen	EPA 350.3 Ammonia	N/A	0.16	0.10	10/5/09 14:28
Volume	Volume in ml	N/A	250	N/A	10/5/09 14:30

**TEST RESULTS**

**Opacity**  
**Base Load**

<b>Company:</b> Florida Power and Light <b>Equipment:</b> Mitsubishi 501G, Unit 1C base load w/o DB <b>Location:</b> West County Energy Center <b>Date:</b> October 8, 2009 <b>Project #:</b> bv-09-westcounty.fl-comp#1						Run 1	<b>Average Opacity:</b> 0.00 % <b>Maximum Opacity:</b> 0 % <b>6 Minute Average:</b> 0.00 % <b>6 Minute Maximum:</b> 0.00 % <b>Max Time w/ Opacity:</b> 0.00 minutes				
TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

**Company:** Florida Power and Light  
**Equipment:** Mitsubishi 501G, Unit 1C base load w/o DB  
**Location:** West County Energy Center  
**Date:** October 8, 2009  
**Project #:** bv-09-westcounty.fl-comp#1

Run 2

**Average Opacity:** 0.00 %  
**Maximum Opacity:** 0 %  
**6 Minute Average:** 0.00 %  
**6 Minute Maximum:** 0.00 %  
**Max Time w/ Opacity:** 0.00 minutes

TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

Company: Florida Power and Light  
 Equipment: Mitsubishi 501G, Unit 1C base load w/o DB  
 Location: West County Energy Center  
 Date: October 8, 2009  
 Project #: bv-09-westcounty.fl-comp#1

Run 3

Average Opacity: 0.00 %  
 Maximum Opacity: 0 %  
 6 Minute Average: 0.00 %  
 6 Minute Maximum: 0.00 %  
 Max Time w/ Opacity: 0.00 minutes


TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

Company: Florida Power and Light  
Equipment: Mitsubishi 501G, Unit 1C base load w/o DB  
Location: West County Energy Center  
Date: October 8, 2009  
Project #: bv-09-westcounty.fl-comp#1


Run 1

Average Opacity: 0.00 %  
Maximum Opacity: 0 %  
6 Minute Average: 0.00 %  
6 Minute Maximum: 0.00 %  
Max Time w/ Opacity: 0.00 minutes

### OPACITY READINGS (15 second intervals)



### OPACITY RESULTS (6 minute averages)




Company: Florida Power and Light  
Equipment: Mitsubishi 501G, Unit 1C base load w/o DB  
Location: West County Energy Center  
Date: October 8, 2009  
Project #: bv-09-westcounty.fl-comp#1


Run 2

Average Opacity: 0.00 %  
Maximum Opacity: 0 %  
6 Minute Average: 0.00 %  
6 Minute Maximum: 0.00 %  
Max Time w/ Opacity: 0.00 minutes

**OPACITY READINGS  
(15 second intervals)**



**OPACITY RESULTS  
(6 minute averages)**






**Company:** Florida Power and Light  
**Equipment:** Mitsubishi 501G, Unit 1C base load w/o DB  
**Location:** West County Energy Center  
**Date:** October 8, 2009  
**Project #:** bv-09-westcounty.fl-comp#1


Run 3

**Average Opacity:** 0.00 %  
**Maximum Opacity:** 0 %  
**6 Minute Average:** 0.00 %  
**6 Minute Maximum:** 0.00 %  
**Max Time w/ Opacity:** 0.00 minutes

**OPACITY READINGS  
(15 second intervals)**



**OPACITY RESULTS  
(6 minute averages)**



Method Used (Circle One)  
 Method B  203A  203B  Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20505 State Road 80  
 City: Loxatchee, Florida State: FL Zip: 33470

Form Number \_\_\_\_\_ Page 1 of 6  
 Continued on Form Number \_\_\_\_\_

Process: Electricity Production Unit: C Operating Mode: BASE WOODCH  
 Control Equipment: AMMONIA INJECTION Operating Mode: Normal

Observation Date	Time Zone				Start Time	End Time	Comments
	min.	sec.	0	15			
<u>10/5/09</u>			<u>EST</u>		<u>10:00</u>	<u>10:30</u>	

Describe Emissions Point: most southern stack of three


Height of Emiss. Pt. Start: 150 End: 150 Height of Emiss. Pt. Rel. to Observer Start: 130 End: 150  
 Distance to Emiss. Pt. Start: 350 End: 450 Direction to Emiss. Pt. (Degrees) Start: 31 End: 31

1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Vertical Angle to Obs. Pt. Start: 16 End: 16 Direction to Obs. Pt. (Degrees) Start: 34 End: 34  
 Distance and Direction to Observation Point from Emission Point Start: 450 SW End: 450 SW

Describe Emissions: Start: N/V End: N/V Water Droplet Plume: Start: None End: None  
 Emission Color: Start: N/V End: N/V Start: None End: None  
N/V - NON VISIBLE

Describe Plume Background: Start: Blue Sky End: Blue Sky  
 Background Color: Start: Blue End: Blue Sky Conditions: Start: Scattered End: Same  
 Wind Speed: Start: 10-15 End: 10-15 Wind Direction: Start: NE End: NE  
 Ambient Temp. Start: 91 End: 91 Wet Bulb Temp. RH Percent: 69



Observer's Name (Print): Daniel Corines  
 Observer's Signature: [Signature] Date: 10/5/09  
 Organization: Air Axiom Inc.  
 Certified By: Eastern Technical Associates Date: 4/22/09

Additional Information

Method Used (Circle One)  
 Method 9    203A    203B    Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Form Number \_\_\_\_\_ Page 2 of 6

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20505 State Road 80  
 City: Loxatchee, Florida State: FL Zip: 32470

Continued on Form Number \_\_\_\_\_

Process: Electricity Production Unit #: \_\_\_\_\_ Operating Mode: Base Load  
 Control Equipment: Amine Injection Operating Mode: Normal

Observation Date: 10/5/09 Time Zone: EST Start Time: 10:31 End Time: 11:01

Describe Emissions Point: most southern stack of three  
 Height of Emiss. Pt. Start: 150 End: 150 Height of Emiss. Pt. Rel. to Observer Start: 150 End: 150  
 Distance to Emiss. Pt. Start: 350 End: 350 Direction to Emiss. Pt. (Degrees) Start: 31 End: 31


Min	Sec	Time Zone				Comments
		0	15	30	45	

Vertical Angle to Obs. Pt. Start: 16 End: 16 Direction to Obs. Pt. (Degrees) Start: 29 End: 29  
 Distance and Direction to Observation Point from Emission Point Start: 350 SW End: 350 SW

1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Start: N/V End: N/V Emission Color Start: N/V End: N/V Water Droplet Plume Start: None End: None

Describe Plume Background Start: Blue Sky End: Blue Sky Background Color Start: Blue End: Blue Sky Condition Start: Scattered End: Same  
 Wind Speed Start: 10-15 End: 10-15 Wind Direction Start: NE End: NE  
 Ambient Temp. Start: 91 End: 91 Wet Bulb Temp. \_\_\_\_\_ RH Percent \_\_\_\_\_



Observer's Name (Print): Darin Holmes Date: 10/5/09  
 Observer's Signature: \_\_\_\_\_  
 Organization: Air Systems Inc. Certified By: Eastern Technical Associates Date: 4/22/09

Additional Information

Method Used (Circle One)  
 Method B    203A    203B    Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Form Number \_\_\_\_\_ Page 3 of 6

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20505 State Road 80  
 City: Loxatchee, Florida State: \_\_\_\_\_ Zip: 33470

Continued on Form Number \_\_\_\_\_

Process: Electricity Production Unit #: \_\_\_\_\_ Operating Mode: Base Load  
 Control Equipment: Ammonia Injection Operating Mode: Normal

Observation Date: 10/5/09 Time Zone: EST Start Time: 11:05 End Time: 11:35

Describe Emissions Port: Most South-most stack of three  
 Height of Emiss. Pt. Start: 138 End: 138 Height of Emiss. Pt. Rel. to Observer Start: 130 End: 130  
 Distance to Emiss. Pt. Start: 450 End: 450 Direction to Emiss. Pt. (Degrees) Start: 31 End: 31


Min	Sec	Time Zone				Comments
		0	15	30	45	

Vertical Angle to Obs. Pt. Start: 16 End: 16 Direction to Obs. Pt. (Degrees) Start: 29 End: 29  
 Distance and Direction to Observation Point from Emission Point Start: 450 SW End: 450 SW

1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Start: N/V End: N/V Water Droplet Plume Start: None End: None  
 Emission Color Start: N/V End: N/V

Describe Plume Background Start: Blue Sky End: Blue Sky Sky Conditions Start: Scattered End: Same  
 Background Color Start: Blue End: Blue Wind Speed Start: 10-15 End: 10-15 Wind Direction Start: NE End: NE  
 Ambient Temp. Start: 93 End: 93 Wet Bulb Temp. Start: \_\_\_\_\_ End: 52



Additional Information

Observer's Name (Print): Darin Holmes  
 Observer's Signature: \_\_\_\_\_ Date: 10/5/09  
 Organization: Air Hygiene Inc.  
 Certified By: Eastern Technical Associates Date: 10/22/09

Method Used (Circle One)  
 Method 9 203A 203B Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Form Number \_\_\_\_\_ Page 4 of 6

Company Name Florida Power & Light  
 Facility Name West County Energy Center  
 Street Address 20505 State Road 80  
 City Loxatchee, Florida State FL Zip 33470

Continued on Form Number \_\_\_\_\_

Process Electricity Production Unit # C Operating Mode Base Load  
 Control Equipment Ammonia Injection Operating Mode Normal

Observation Date 10/5/09 Time Zone EST Start Time 11:36 End Time 12:04

Describe Emissions Point  
most southern stack of three

Height of Emiss. Pt. Start 138 End 138 Height of Emiss. Pt. Rel. to Observer Start 130 End 130  
 Distance to Emiss. Pt. Start 450 End 450 Direction to Emiss. Pt. (Degrees) Start 31 End 31


Min. Sec. 0 15 30 45 Comments

Direction to Obs. Pt. (Degrees) Start 16 End 16 Start 24 End 24  
 Distance and Direction to Observation Point from Emission Point Start 420S W End 450S W

1	0	15	30	45	Comments
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions  
 Start N/V End N/V Water Droplet Plume  
 Emission Color Start N/V End N/V Start None End None

Describe Plume Background  
 Start Blue Sky End Blue Sky Sky Condition  
 Background Color Start Blue End Blue Start Scattered End Same  
 Wind Speed Start 10-15 End 10-15 Wind Direction Start NE End NE  
 Ambient Temp. Start 75 End 72 Wet Bulb Temp. RH Percent Start 52



Observer's Name (Print) Darin Grimes  
 Observer's Signature [Signature] Date 10/5/09  
 Organization Air Hygiene Inc.  
 Certified By Eastern Technical Associates Date 4/22/09

Additional Information

Method Used (Circle One)  
 Method 9    203A    203B    Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20505 State Road 80  
 City: Loxatchee, Florida State: FL Zip: 33470


Process: Electricity Production Unit #: \_\_\_\_\_ Operating Mode: Base Load  
 Control Equipment: Aminonia Injection Operating Mode: Normal

Describe Emissions Point: Southern of three stacks  
 Height of Emiss. Pt. Start: 138 End: 138 Height of Emiss. Pt. Rel. to Observer Start: 30 End: 130  
 Distance to Emiss. Pt. Start: 450 End: 450 Direction to Emiss. Pt. (Degrees) Start: 31 End: 31

Vertical Angle to Obs. Pt. Start: 16 End: 16 Direction to Obs. Pt. (Degrees) Start: 34 End: 34  
 Distance and Direction to Observation Point from Emission Point Start: 450 SW End: 450 SW

Describe Emissions  
 Start: N/V End: N/V Water Droplet Plume: \_\_\_\_\_  
 Emission Color: \_\_\_\_\_  
 Start: N/V End: N/V Start: None End: None

Describe Plume Background  
 Start: Blue End: Blue Sky Sky Condition: \_\_\_\_\_  
 Background Color: Blue Start: Blue End: Scattered Same: \_\_\_\_\_  
 Wind Speed: 10-15 End: 10-15 Wind Direction: NE End: NE  
 Ambient Temp: 80 End: 80 Wet Bulb Temp: \_\_\_\_\_ RH Percent: 47



Form Number \_\_\_\_\_ Page 5 of 6

Continued on Form Number \_\_\_\_\_

Obs. No.	Observation Date		Time Zone				Start Time	End Time	Comments
	Mo.	Dec.	0	15	30	45			
1	10	5	01	ES			12:08	13:08	
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									

Observer's Name (Print): Darin Grimes  
 Observer's Signature: \_\_\_\_\_ Date: 12/5/09  
 Organization: Big Aysienic Inc.  
 Certified By: Eastern Technical Associates Date: 11/22/09

Additional Information

Method Used (Circle One)  
 Method 9 203A 203B Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Form Number \_\_\_\_\_ Page 6 of 6

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20505 State Road 80  
 City: Loachsee, Florida 33470

Continued on Form Number \_\_\_\_\_

Process: Electricity Production Unit # \_\_\_\_\_ Operating Mode: Base Load  
 Control Equipment: Ammonia Injection Operating Mode: Normal

Observation Date: 10/5/09 Time Zone: EST Start Time: 18:09 End Time: 18:39


Describe Emissions Point: most southern stack of three  
 Height of Emiss. Pt. Start: 158 End: 158 Height of Emiss. Pt. Rel. to Observer Start: 150 End: 152  
 Distance to Emiss. Pt. Start: 450 End: 450 Direction to Emiss. Pt. (Degrees) Start: 31 End: 31

Min	Sec	Time Zone				Comments
		0	15	30	45	
1	0	0	0	0	0	
2	0	0	0	0	0	
3	0	0	0	0	0	
4	0	0	0	0	0	
5	0	0	0	0	0	
6	0	0	0	0	0	
7	0	0	0	0	0	
8	0	0	0	0	0	
9	0	0	0	0	0	
10	0	0	0	0	0	
11	0	0	0	0	0	
12	0	0	0	0	0	
13	0	0	0	0	0	
14	0	0	0	0	0	
15	0	0	0	0	0	
16	0	0	0	0	0	
17	0	0	0	0	0	
18	0	0	0	0	0	
19	0	0	0	0	0	
20	0	0	0	0	0	
21	0	0	0	0	0	
22	0	0	0	0	0	
23	0	0	0	0	0	
24	0	0	0	0	0	
25	0	0	0	0	0	
26	0	0	0	0	0	
27	0	0	0	0	0	
28	0	0	0	0	0	
29	0	0	0	0	0	
30	0	0	0	0	0	

Vertical Angle to Obs. Pt. Start: 16 End: 16 Direction to Obs. Pt. (Degrees) Start: 29 End: 34  
 Distance and Direction to Observation Point from Emission Point Start: 450 SW End: 450 SW

Describe Emissions: Start: N/V End: N/V Water Droplet Plume Start: None End: None  
 Emission Color: Start: N/V End: N/V

Describe Plume Background: Start: Blue Sky End: Blue Sky Sky Conditions Start: Clear End: Same  
 Background Color: Start: Blue End: Blue Wind Speed Start: 10-15 End: 10-15 Wind Direction Start: NE End: NE  
 Ambient Temp. Start: 100 End: 100 Wet Bulb Temp. RH Percent Start: 41



Latitude \_\_\_\_\_ Longitude \_\_\_\_\_ Densitation \_\_\_\_\_  
 Additional Information \_\_\_\_\_

Observer's Name (Print): DANN GRIMES  
 Observer's Signature: [Signature] Date: 10/5/09  
 Organization: Air Systems Inc.  
 Certified By: Eastern Technical Associates Date: 10/22/09

**TEST RESULTS**

**Opacity  
Base Load with Duct Burners**



Company: Florida Power and Light  
 Equipment: Mitsubishi 501G, Unit 1C base load w/DB  
 Location: West County Energy Center  
 Date: October 7, 2009  
 Project #: bv-09-westcounty.fl-comp#1

Run 1

Average Opacity: 0.00 %  
 Maximum Opacity: 0 %  
 6 Minute Average: 0.00 %  
 6 Minute Maximum: 0.00 %  
 Max Time w/ Opacity: 0.00 minutes

TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

<b>Company:</b> Florida Power and Light <b>Equipment:</b> Mitsubishi 501G, Unit 1C base load w/DB <b>Location:</b> West County Energy Center <b>Date:</b> October 7, 2009 <b>Project #:</b> bv-09-westcounty.fl-comp#1						Run 2	<b>Average Opacity:</b> 0.00 % <b>Maximum Opacity:</b> 0 % <b>6 Minute Average:</b> 0.00 % <b>6 Minute Maximum:</b> 0.00 % <b>Max Time w/ Opacity:</b> 0.00 minutes				
TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

**Company:** Florida Power and Light  
**Equipment:** Mitsubishi 501G, Unit 1C base load w/DB  
**Location:** West County Energy Center  
**Date:** October 7, 2009  
**Project #:** bv-09-westcounty.fl-comp#1

Run 3

**Average Opacity:** 0.00 %  
**Maximum Opacity:** 0 %  
**6 Minute Average:** 0.00 %  
**6 Minute Maximum:** 0.00 %  
**Max Time w/ Opacity:** 0.00 minutes


TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

Company: Florida Power and Light  
Equipment: Mitsubishi 501G, Unit 1C base load w/DB  
Location: West County Energy Center  
Date: October 7, 2009  
Project #: bv-09-westcounty.fl-comp#1


Run 1

Average Opacity: 0.00 %  
Maximum Opacity: 0 %  
6 Minute Average: 0.00 %  
6 Minute Maximum: 0.00 %  
Max Time w/ Opacity: 0.00 minutes

**OPACITY READINGS  
(15 second intervals)**



**OPACITY RESULTS  
(6 minute averages)**




Company: Florida Power and Light  
Equipment: Mitsubishi 501G, Unit 1C base load w/DB  
Location: West County Energy Center  
Date: October 7, 2009  
Project #: bv-09-westcounty.fl-comp#1


Run 2

Average Opacity: 0.00 %  
Maximum Opacity: 0 %  
6 Minute Average: 0.00 %  
6 Minute Maximum: 0.00 %  
Max Time w/ Opacity: 0.00 minutes

### OPACITY READINGS (15 second intervals)



### OPACITY RESULTS (6 minute averages)




Company: Florida Power and Light  
Equipment: Mitsubishi 501G, Unit 1C base load w/DB  
Location: West County Energy Center  
Date: October 7, 2009  
Project #: bv-09-westcounty.fl-comp#1


Run 3

Average Opacity: 0.00 %  
Maximum Opacity: 0 %  
6 Minute Average: 0.00 %  
6 Minute Maximum: 0.00 %  
Max Time w/ Opacity: 0.00 minutes

### OPACITY READINGS (15 second intervals)



### OPACITY RESULTS (6 minute averages)



Method Used (Circle One)  
 Method 9    203A    203B    Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Form Number \_\_\_\_\_ Page 3 of 6  
 Continued on Form Number \_\_\_\_\_

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20505 State Road 80  
 City: Loxley, Florida State: FL Zip: 32470

Observation Date: 10/5/09 Time Zone: EST Start Time: 16:40 End Time: 17:10

Process: Electricity Production Unit #: \_\_\_\_\_ Operating Mode: With Base Loads  
 Control Equipment: Air Pollution Injection Operating Mode: Normal

Min	Sec	Time Zone				Comments
		0	15	30	45	
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11		0	0	0	0	
12		0	0	0	0	
13		0	0	0	0	
14		0	0	0	0	
15		0	0	0	0	
16		0	0	0	0	
17		0	0	0	0	
18		0	0	0	0	
19		0	0	0	0	
20		0	0	0	0	
21		0	0	0	0	
22		0	0	0	0	
23		0	0	0	0	
24		0	0	0	0	
25		0	0	0	0	
26		0	0	0	0	
27		0	0	0	0	
28		0	0	0	0	
29		0	0	0	0	
30		0	0	0	0	


Describe Emissions Point: Southern stack of three

Height of Emiss. Pt. Start: 138 End: 138 Height of Emiss. Pt. Rel. to Obs. Pt. Start: 132 End: 132  
 Distance to Emiss. Pt. Start: 450 End: 450 Direction to Emiss. Pt. (Degrees) Start: 28 End: 28

Vertical Angle to Obs. Pt. Start: 16 End: 16 Direction to Obs. Pt. (Degrees) Start: 20 End: 20  
 Distance and Direction to Observation Point from Emission Point Start: 450 SE End: 450 SE

Describe Emissions  
 Start: N/V End: N/V Water Droplet Plume  
 Emission Color: N/V Start: None End: None

Describe Plume Background  
 Start: Blue Sky End: Blue Sky Sky Conditions: Scattered End: Same  
 Background Color: Blue Wind Speed: 10-15 End: 10-15 Wind Direction: NE End: NE  
 Ambient Temp: 97 End: 97 Wet Bulb Temp: \_\_\_\_\_ RH Percent: 52



Additional Information

Observer's Name (Print): Daniel Grooms  
 Observer's Signature: \_\_\_\_\_ Date: 10/5/09  
 Organization: Air Assessment Inc.  
 Certified By: Eastern Technical Associates Date: 9/20/09

Method Used (Circle One)  
 Method 9      203A      203B      Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20505 State Road 80  
 City: Leesville, Florida 32470

Form Number \_\_\_\_\_ Page 4 of 6  
 Continued on Form Number \_\_\_\_\_

Process: Electricity Production      Unit # \_\_\_\_\_      Operating Mode: With Bypass  
 Control Equipment: Ammonia Injection      Operating Mode: Normal

Observation Date: 10/5/09      Time Zone: EST      Start Time: 17:11      End Time: 17:31

Describe Emissions Point: Southern stack of three  
 Height of Emiss. Pt. Start: 138      End: 138      Height of Emiss. Pt. Rel. to Observer Start: 132      End: 132  
 Distance to Emiss. Pt. Start: 450      End: 450      Direction to Emiss. Pt. (Degrees) Start: 28      End: 28


Min	Sec	Time Zone				Comments
		0	15	30	45	

Vertical Ang. to Obs. Pt. Start: 16      End: 16      Direction to Obs. Pt. (Degrees) Start: 20      End: 20  
 Distance and Direction to Observation Point from Emission Point Start: 450 SE      End: 450 SE

1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions: Start: N/V      End: N/V      Water Droplet Plume: Start: None      End: None

Describe Plume Background: Start: Blue Sky      End: Blue Sky  
 Background Color: Start: Blue      End: Blue      Sky Conditions: Start: Scattered      End: Same  
 Wind Speed: Start: 10-15      End: 10-15      Wind Direction: Start: NE      End: NE  
 Ambient Temp: Start: 97      End: 97      Wet Bulb Temp: RH Percent: 52



Latitude \_\_\_\_\_ Longitude \_\_\_\_\_ Declination \_\_\_\_\_  
 Additional Information \_\_\_\_\_

Observer's Name (Print): Darryl Williams  
 Observer's Signature: [Signature]      Date: 10/5/09  
 Organization: Air Systems Inc.  
 Certified By: Eastern Technical Associates      Date: 9/22/09



Method Used (Circle One)  
 Method 9    203A    203B    Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20505 State Road 80  
 City: Loxatchee, Florida    State: FL    Zip: 32470

Form Number \_\_\_\_\_ Page 5 of 6  
 Continued on Form Number \_\_\_\_\_

Process: Electricity Production    Unit #: \_\_\_\_\_    Operating Mode: With BOSCHICKS  
 Control Equipment: AMMONIA INJECTION    Operating Mode: Normal

Observation Date: 10/5/07    Time Zone: EST    Start Time: 17:32    End Time: 18:02


Describe Emissions Point: Southern stack of three  
 Height of Emiss. Pt. Start: 138    End: 138    Height of Emiss. Pt. Rel. to Observer Start: 132    End: 132  
 Distance to Emiss. Pt. Start: 450    End: 450    Direction to Emiss. Pt. (Degrees) Start: 28    End: 28

No.	Time				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Vertical Angle to Obs. Pt. Start: 16    End: 16    Direction to Obs. Pt. (Degrees) Start: 20    End: 20  
 Distance and Direction to Obs. Pt. from Emission Point Start: 450 SE    End: 450 SE

Describe Emissions: Start: N/V    End: N/V    Water Droplet Plume: Start: Noise    End: None

Describe Plume Background: Start: Blue Sky    End: Blue Sky  
 Background Color: Start: Blue    End: Blue    Sky Conditions: Start: Scattered    End: Same  
 Wind Speed: Start: 10-15    End: 10-15    Wind Direction: Start: NE    End: NE  
 Ambient Temp: Start: 98    End: 98    Wet Bulb Temp: 44



Observer's Name (Print): Darin Corines  
 Observer's Signature: \_\_\_\_\_ Date: 10/5/07  
 Organization: Air Hygiene Inc.  
 Certified By: Lauren Technical Associates Date: 4/22/07

Additional Information

Method Used (Circle One)  
 Method 9 203A 203B Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Company Name: Florida Power & Light  
 Facility Name: West County Energy Center  
 Street Address: 20525 State Road 80  
 City: Loxley, Florida 32470

Form Number \_\_\_\_\_ Page 6 of 6  
 Continued on Form Number \_\_\_\_\_

Process: Electricity Production Unit #: \_\_\_\_\_ Operating Mode: With Base Loads  
 Control Equipment: AMMONIA Injection Operating Mode: Normal

Observation Date: 10/5/09 Time Zone: EST Start Time: 18:03 End Time: 18:33

Describe Emissions Point  
Southern stack of three

Min	Time				Comments
	0	15	30	45	


Height of Emiss. Pt. Start: 138 End: 138 Height of Emiss. Pt. Rel. to Observer Start: 132 End: 132  
 Distance to Emiss. Pt. Start: 450 End: 450 Direction to Emiss. Pt. (Degrees) Start: 20 End: 20

1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Vertical Angle to Obs. Pt. Start: 16 End: 16 Direction to Obs. Pt. (Degrees) Start: 20 End: 20  
 Distance and Dir. to Observation Point from Emission Point Start: 450 SE End: 450 SE

Describe Emissions  
 Start: N/V End: N/V Emission Color: \_\_\_\_\_ Water Droplet Plume: \_\_\_\_\_  
 Start: N/V End: N/V Start: None End: None

Describe Plume Background  
 Start: Blue Sky End: Blue Sky Background Color: \_\_\_\_\_ Sky Conditions: \_\_\_\_\_  
 Start: Blue End: Blue Start: Scattered End: Same  
 Wind Speed: \_\_\_\_\_ Wind Direction: \_\_\_\_\_ Start: 10-15 End: 10-15 Start: NE End: NE  
 Ambient Temp: \_\_\_\_\_ Wet Bulb Temp: \_\_\_\_\_ RH Percent: \_\_\_\_\_  
 Start: 98 End: 98 Start: \_\_\_\_\_ End: 44



Latitude \_\_\_\_\_ Longitude \_\_\_\_\_ Declination \_\_\_\_\_  
 Additional Information \_\_\_\_\_

Observer's Name (Print): Doreen Coimes  
 Observer's Signature: \_\_\_\_\_ Date: 10/5/09  
 Organization: Env. Scientific Inc.  
 Certified By: Eastern Technical Associates Date: 10/22/09

Method Used (Circle One)  
 Method 9 203A 203B Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Company Name: Florida Power & Light  
 Facility Name: Energy Center  
 Street Address: State Road 80  
 City: Lawteehoe State: Florida Zip: 32470

Form Number \_\_\_\_\_ Page 1 of 2  
 Continued on Form Number \_\_\_\_\_

Process: Electricity Production Unit #: 1B Operating Mode: With  
 Control Equipment: NOx SCR Injection Operating Mode: Normal

Observation Date: 10/6/09 Time Zone: EST Start Time: 10:00 End Time: 10:30

Describe Emissions Point: southern stack of three  
 Height of Emiss. Pt. Start: 138 End: 138 Height of Emiss. Pt. Rel. to Observer Start: 132 End: 132  
 Distance to Emiss. Pt. Start: 450 End: 450 Direction to Emiss. Pt. (Degrees) Start: 30 End: 30


min sec 0 15 30 45 Comments

Vertical Angle to Obs. Pt. Start: 16 End: 16 Direction to Obs. Pt. (Degrees) Start: 21 End: 21  
 Distance and Direction to Observation Point from Emission Point: Start: 450 SE End: 450 SE

1	0	15	30	45	
2	0	15	30	45	
3	0	15	30	45	
4	0	15	30	45	
5	0	15	30	45	
6	0	15	30	45	
7	0	15	30	45	
8	0	15	30	45	
9	0	15	30	45	
10	0	15	30	45	
11	0	15	30	45	
12	0	15	30	45	
13	0	15	30	45	
14	0	15	30	45	
15	0	15	30	45	
16	0	15	30	45	
17	0	15	30	45	
18	0	15	30	45	
19	0	15	30	45	
20	0	15	30	45	
21	0	15	30	45	
22	0	15	30	45	
23	0	15	30	45	
24	0	15	30	45	
25	0	15	30	45	
26	0	15	30	45	
27	0	15	30	45	
28	0	15	30	45	
29	0	15	30	45	
30	0	15	30	45	

Describe Emissions: Start: N/V End: N/V Emission Color: N/V Water Droplet Plume: Start: N/A End: N/A

Describe Plume Background: Start: Blue Sky End: Blue Sky Background Color: Blue Sky Conditions: Scattered S.C.M.P.  
 Wind Speed: Start: 10-15 End: 10-15 Wind Direction: Start: NE End: NE  
 Ambient Temp.: Start: 80 End: 80 Wet Bulb Temp.: 88 RH Percent: \_\_\_\_\_



Observer's Name (Print): Dustin G. Jones  
 Observer's Signature: \_\_\_\_\_ Date: 10/6/09  
 Organization: West Virginia Tech. Assoc.  
 Certified By: Jason Technical Associates Date: 7/22/09

Additional Information: \_\_\_\_\_

Method Used (Circle One)  
 Method 9 203A 203B Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Company Name: Florida Power & Light  
 Facility Name: 10700 Energy Center  
 Street Address: 25 State Road 80  
 City: Orlando, Florida State: FL Zip: 32817

Form Number \_\_\_\_\_ Page 2 of 2  
 Continued on Form Number \_\_\_\_\_

Process: Electric Production Unit #: 1E Operating Mode: With  
 Control Equipment: AMISS with Injection Operating Mode: Normal

Observation Date: 10/6/09 Time Zone: EST Start Time: 10:31 End Time: 11:01

Describe Emissions Point: Smaller stack of three  
 Height of Emiss. Pt. Start: 138 End: 138 Height of Emiss. Pt. Ref. to Observer Start: 132 End: 132  
 Distance to Emiss. Pt. Start: 450 End: 450 Direction to Emiss. Pt. (Degrees) Start: 30 End: 30


Observation No.	Time Zone				Comments
	0	15	30	45	

Vertical Angle to Obs. Pt. Start: 18 End: 16 Direction to Obs. Pt. (Degrees) Start: 21 End: 21  
 Distance and Direction to Observation Point from Emission Point Start: 450 SE End: 450 SE

Observation No.	Time Zone				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Start: N/V End: N/V Emission Color: N/V Water Droplet Plume Start: N/V End: N/V Start: Noise End: Noise

Describe Plume Background Start: Blue Sky End: Blue Sky Background Color: Blue Sky Conditions: Sc. Hair End: Same  
 Wind Speed Start: 10-15 End: 10-15 Wind Direction Start: NE End: NE  
 Ambient Temp. Start: 86 End: 86 Wet Bulb Temp. 88 RH Percent



Latitude \_\_\_\_\_ Longitude \_\_\_\_\_ Declination \_\_\_\_\_  
 Additional Information \_\_\_\_\_

Observer's Name (Print): Dennis Gump  
 Observer's Signature: \_\_\_\_\_ Date: 10/6/09  
 Organization: Ray Avicchi LLC  
 Certified By: Clayton Technical Associates Date: 9/22/09

**CALCULATIONS**

**EXAMPLE CALCULATIONS (FFACTOR)**

RM 19, (07-19-06),  
2.0 Summary of Method,  
2.1 Emission Rates. Oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) concentrations and appropriate F factors (ratios of combustion gas volumes to heat inputs) are used to calculate pollutant emission rates from pollutant concentrations.

RM 19, (07-19-06),  
12.2 Emission Rates of PM, SO<sub>2</sub>, and NO<sub>x</sub>. Select from the following sections the applicable procedure to compute the PM, SO<sub>2</sub>, or NO<sub>x</sub> emission rate (E) in lb/MMBtu. The pollutant concentration must be in lb/scf and the F factor must be in scf/MMBtu. If the pollutant concentration (C) is not in the appropriate units, use Table 19-1 in Section 17.0 to make the proper conversion. An F factor is the ratio of the gas volume of the products of combustion to the heat content of the fuel. The dry F factor (F<sub>d</sub>) includes all components of combustion less water, the wet F factor (F<sub>w</sub>) includes all components of combustion, and the carbon F factor (F<sub>c</sub>) includes only carbon dioxide.

Mark's Std Hdbk, 10th ed., pg 4-26  
**High Heat Value Dry (HHV<sub>dry</sub>)**, calc for Methane (single component for the fuel gas)

$$HHV_{dry} (Btu / SCF) = \left[ \left( \frac{M_{\%}}{100} \right) \times GCM \right] \quad HHV_{dry} = \frac{96.84 \%}{100.00} \times \frac{994.85 \text{ Btu}}{SCF} = \frac{963.40 \text{ Btu}}{SCF}$$

Mark's Std Hdbk, 10th ed., pg 4-26  
**Low Heat Value Dry (LHV<sub>dry</sub>)**, calc for Methane (single component for the fuel gas)

$$LHV_{dry} (Btu / SCF) = \left[ \left( \frac{M_{\%}}{100} \right) \times NCM \right] \quad LHV_{dry} = \frac{96.84 \%}{100.00} \times \frac{895.75 \text{ Btu}}{SCF} = \frac{867.44 \text{ Btu}}{SCF}$$

Civil Eng. Ref. Man., 7th Ed., pg 14-9/GPA Ref. Bulletin 181-86, App. C  
**High Heat Value Wet (HHV<sub>wet</sub>)**, calc for entire sample (all components of the fuel gas)

$$HHV_{wet} (Btu / SCF) = \frac{HHV_{dry}}{W / D. \text{ factor}} \quad HHV_{wet} = \frac{995.66 \text{ Btu/SCF}}{1.0236} = 972.70 \text{ Btu/SCF}$$

Civil Eng. Ref. Man., 7th Ed., pg 14-9/GPA Ref. Bulletin 181-86, App. C  
**Low Heat Value Wet (LHV<sub>wet</sub>)**, calc for entire sample (all components of the fuel gas)

$$LHV_{wet} (Btu / SCF) = \frac{LHV_{dry}}{W / D. \text{ factor}} \quad LHV_{wet} = \frac{897.00 \text{ Btu/SCF}}{1.0236} = 876.32 \text{ Btu/SCF}$$

**Lbs Component per Lb-Mol of Gas (CM)**, calc for Methane (single component for the fuel gas)

$$CM (lb / lb - mol) = \left[ \left( \frac{M_{\%}}{100} \right) \times MW \right] \quad CM = \frac{96.84 \%}{100.00} \times \frac{16.04 \text{ lb}}{\text{lb-mol}} = 15.54 \text{ lb/lb-mol}$$

ASTM D 3588

**Fuel Molecular Weight (MW<sub>Fuel</sub>)**

$$MW_{Fuel} (lb / lb - mol) = \left[ \sum (CM) \right] \quad MW_{Fuel} = 15.54 \text{ lb/lb-mol} + 0.42 \text{ lb/lb-mol} + \text{etc.} = 16.645 \text{ lb/lb-mol}$$

**Btu per Lb of Gas Gross (GCV)**

$$GCV (Btu / lb) = \left[ \frac{HHV_{dry} \times G}{MW_{Fuel}} \right] \quad GCV = \frac{995.66 \text{ Btu/SCF} \times 385.23 \text{ ft}^3/\text{lbmol}}{16.645 \text{ lb/lb-mol}} = 23,043.75 \text{ Btu/lb}$$

ASTM D 3588 (SG)

**Specific Gravity**

$$SG = \left[ \frac{MW_{Fuel}}{MW_{AIR}} \right] \quad SG = \frac{16.64 \text{ lb/lb-mol}}{28.96 \text{ lb/lb-mol}} = 0.5747$$

**Btu per Lb of Gas Net (NCV)**

$$NCV (Btu / lb) = \left[ \frac{LHV_{dry} \times G}{MW_{Fuel}} \right] \quad NCV = \frac{897.00 \text{ Btu/SCF} \times 385.23 \text{ ft}^3/\text{lbmol}}{16.645 \text{ lb/lb-mol}} = 20,760.39 \text{ Btu/lb}$$

**Weight Percent of Component (C<sub>%</sub>), methane**

$$C_{\%} (\%) = \left[ \left( \frac{CM}{MW_{Fuel}} \right) \times 100 \right] \quad C_{\%} = \frac{15.54 \text{ lb/lb-mol}}{16.64 \text{ lb/lb-mol}} \times 100 = 93.34 \%$$

RM 19, (07-19-06), **Weight Percent of Volatile Organic Compounds (VOC<sub>%</sub>)**

$$VOC_{\%} (\%) = \left[ \sum_{C_2H_6}^{C_4H_{10}} M_{\%} \right] \quad VOC_{\%} = 0.50 \% + 0.10 \% + 0.10 \% + \text{etc.} = 0.83 \%$$

RM 19, (07-19-06), 12.3.2 **Determined F Factors**. If the fuel burned is not listed in Table 19-2 or if the owner or operator chooses to determine an F factor rather than use the values in Table 19-2, use the procedure below: 12.3.2.1 Equations. Use the eq

RM 19, (07-19-06),

12.1 Nomenclature

**K (scf/lb)%**

H	3.64
C	1.53
S	0.57
N <sub>2</sub>	0.14
O <sub>2</sub>	0.46

$$F_d = \frac{K(K_{hd} \%H + K_c \%C + K_s \%S + K_n \%N - K_o \%O)}{GCV} \quad \text{Eq. 19-13}$$

$$F_d = \frac{10^6 \text{ Btu}}{\text{MMBtu}} \times \left[ \frac{3.64 \text{ SCF}}{\text{lb} \cdot \%} \times 24.12 \% + \frac{1.53 \text{ SCF}}{\text{lb} \cdot \%} \times 73.19 \% + \frac{0.57 \text{ SCF}}{\text{lb} \cdot \%} \times 0.00 \% + \frac{0.14 \text{ SCF}}{\text{lb} \cdot \%} \times 1.10 \% - \frac{0.46 \text{ SCF}}{\text{lb} \cdot \%} \times 1.59 \% \right] \times \frac{\text{lb}}{23,043.75 \text{ Btu}} = \frac{8,644.29 \text{ SCF}}{\text{MMBtu}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (INFORMATION)**

**Specific Humidity (RH<sub>sp</sub>)**

Note: RH<sub>sp</sub> (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} \text{ (lb / lb)} = \left[ \left( \frac{gr}{lb} \right) \times \frac{lb}{7000gr} \right] \quad RH_{sp} = \frac{141.36 \text{ gr}}{lb} \times \frac{1 \text{ lb}}{7000 \text{ gr}} = 0.020195 \frac{\text{lb H}_2\text{O}}{\text{lb Air}}$$

**Fuel Flow Conversion (Q<sub>f</sub>)**

Note: Q<sub>f</sub>(lb/min) is a value updated from the source operator.

$$Q_f = \left[ Q_f \times G \times \left( \frac{1}{MW_{fuel}} \right) \right] \quad Q_f = \frac{1,798.50 \text{ lb}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{385.23 \text{ ft}^3}{\text{lb-mol}} \times \frac{\text{lb-mol}}{16.64 \text{ lb}} = 2,497,491 \text{ SCFH}$$

**Combustor Inlet Pressure / Compressor Discharge Pressure (CIP / CDP)**  
(corrected from gauge to atmospheric pres. and conv. to mm Hg.)

Note: CIP / CDP (psig) is a value obtained from the source operator.

$$CIP / CDP = \left[ (\text{psig} + P) \times \frac{51.71493 \text{ mmHg}}{1 \text{ psi}} \right] \quad CIP / CDP = (262.6 \text{ psig} + 14.6757) \times \frac{51.71493 \text{ mmHg}}{1 \text{ psia}} = 14,340 \text{ mmHg (abs)}$$

**EXAMPLE CALCULATIONS (CALIBRATION)**

**Analyzer Calibration Error**

RM 7E, (08-15-06), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left( \frac{C_{Dir} - C_r}{CS} \right) \times 100 \quad \text{Eq. 7E-1} \quad ACE = \frac{5.11 \text{ ppm} - 4.99 \text{ ppm}}{12.10 \text{ ppm}} \times 100 = 0.99 \%$$

**Calibration Error and Estimated Point, RM 25A, THC Analyzer**

RM 25A, (07-19-06), 8.4 Calibration Error Test. Immediately prior to the test series (within 2 hours of the start of the test), introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response. Then introduce low-level and mid-level calibration gases successively to the measurement system. ... These differences must be less than 5 percent of the respective calibration gas value. (calc for THC analyzer mid gas, if applicable)

$$E_p = \frac{C_{Dir(H)} - C_{Dir(Z)}}{C_{V(H)} - C_{V(Z)}} \times C_{Dir(M)} + C_{Dir(Z)} \quad \text{Eq. of a line } y=mx+b \quad E_p = \frac{8.40 \text{ ppm} - 0.09 \text{ ppm}}{8.40 \text{ ppm} - 0.00 \text{ ppm}} \times 4.94 \text{ ppm} + 0.09 = 4.98 \text{ ppm}$$

$$ACE = \left( \frac{C_{Dir} - C_r}{CS} \right) \times 100 \quad \text{Eq. 7E-1} \quad ACE_{THC} = \frac{4.88 \text{ ppm} - 4.98 \text{ ppm}}{4.94 \text{ ppm}} \times 100 = -1.97 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)**

**System Bias**

RM 7E, (08-15-06), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left( \frac{C_S - C_{Dir}}{C_S} \right) \times 100 \quad \text{Eq. 7E-2} \quad SB = \frac{4.92 \text{ ppm} - 5.11 \text{ ppm}}{12.10 \text{ ppm}} \times 100 = -1.57 \%$$

**Alternative Drift and Bias**

RM 7E, (08-15-06), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs - Cdir| is ≤ 0.5 ppmv or if |Cs - Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Air} = |C_S - C_{Dir}| \quad \text{Eq. Section 13.2 and 13.3} \quad SB / D_{Air} = |4.92 \text{ ppm} - 5.11 \text{ ppm}| = 0.19 \text{ ppm}$$

**Bias Adjusted Average**

RM 7E, (08-15-06), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{Avg} - C_O) \times \left( \frac{C_{M1}}{C_M - C_O} \right) \quad \text{Eq. 7E-5} \quad C_{Gas} = \left( 2.30 \text{ ppm} - 0.00 \text{ ppm} \right) \times \left( \frac{4.99 \text{ ppm}}{4.88 \text{ ppm} - 0.00 \text{ ppm}} \right) = 2.36 \text{ ppm}$$

**EXAMPLE CALCULATIONS (RUNS)**

**Stack Exhaust Flow (Qs) - RM19**

$$Q_s = \left( \frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left( \frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right) \quad Q_s = \frac{8,644.29 \text{ SCF}}{\text{MMBtu}} \times \frac{2,497,490.52 \text{ SCF}}{\text{hr}} \times \frac{995.66 \text{ Btu}}{\text{SCF}} \times \frac{\text{MMBtu}}{10^6 \text{ Btu}} \times \left( \frac{20.90\%}{20.9\% - 13.0\%} \right) = 56,670,296.55 \text{ SCFH}$$

**Diluent-Corrected Pollutant Concentration, O<sub>2</sub> Based**

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O<sub>2</sub> Concentration. Calculate the O<sub>2</sub> corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable)

$$C_{adj} = C_{Gas(Targ)} \times \left( \frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right) \quad \text{Eq. 20-4} \quad C_{adj} = 2.36 \text{ ppm} \times \left( \frac{20.9\% - 15.00\%}{20.9\% - 12.97\%} \right) = 1.75 \text{ ppm@15\%O}_2$$

**Diluent-Corrected Polutant Concentration Corrected to ISO Conditions**

40CFR60.335(b)(1), Conversion for conc. at ISO Conditions (68°F, 1 atm). Calculate, as follows: (calc for NOx@15% with Run 1 data, if applicable)

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (11_o - 0.00633))} \times \left( \frac{288}{T_o} \right)^{1.53} \quad C_{ISO} = 1.75 \text{ ppm@15\%O}_2 \times \sqrt{\frac{262.6 \text{ psig} + 14.69232 \text{ psi}}{262.6 \text{ psig} + 14.6757 \text{ psi}}} \times e^{(19 \times (0.020195 \text{ lb/lb} - 0.00633))} \times \left( \frac{288 \text{ K}}{306 \text{ K}} \right)^{1.53} = 2.08 \text{ ppm@15\% and ISO}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.



**EXAMPLE CALCULATIONS (RUNS)**

**Emissions Rate (lb/hr)**

Calculation for pound per hour emission rate. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G} \qquad E_{lb/hr} = \frac{2.36 \text{ ppm}}{10^6 \text{ ppm/part}} \times \frac{56,670,297 \text{ SCFH} \times 46.01 \text{ lb/lb-mol}}{385.23 \text{ SCF/lb-mol}} = \frac{15.96 \text{ lb}}{\text{hr}}$$

**Emissions Rate (ton/year)**

Calculation for tons per year emission rate based on 8760 hours per year. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{ton/yr} = \frac{E_{lb/hr} \times \text{hr}_{year}}{2000} \qquad E_{ton/yr} = \frac{15.96 \text{ lb}}{\text{hr}} \times \frac{8,760 \text{ hr}}{\text{year}} \times \frac{\text{ton}}{2000 \text{ lb}} = \frac{69.89 \text{ ton}}{\text{year}}$$

**Emissions Rate (lb/MMBtu)**

RM 19, (07-19-06), 12.2 Emission Rates of PM, SO<sub>2</sub>, and NOx. Select from the following sections the applicable procedure to compute the PM, SO<sub>2</sub>, or NOx emission rate (E) in ng/J (lb/million Btu). (calc for NOx gas Run 1, if applicable)

**Oxygen Based**

12.2.1 Oxygen-Based F Factor, Dry Basis. When measurements are on a dry basis for both O<sub>2</sub> (%O<sub>2</sub>d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d \text{ Factor} \times \text{Conv}_c \times 20.9\%}{20.9\% - C_{Gas(O_2)}} \qquad \text{Eq. 19-1}$$

$$E_{lb/MMBtu} = \frac{2.36 \text{ ppm} \times 8,644.29 \text{ SCF/MMBtu} \times 0.0000001194 \text{ lb/ppm} \cdot \text{ft}^3 \times 20.9\%}{20.9\% - 12.97\%} = \frac{0.006 \text{ lb}}{\text{MMBtu}}$$

**Conversion Constant**

Conv<sub>c</sub> for NOx

$$\text{Conv}_c (\text{lb} / \text{ppm} \cdot \text{ft}^3) = \frac{MW}{10^6} \qquad \text{Conv}_c = \frac{46.01 \text{ lb}}{\text{lb} \cdot \text{mole}} \times \frac{\text{lb} \cdot \text{mole}}{385.23 \text{ SCF}} = \frac{0.0000001194 \text{ lb}}{\text{ppm} \cdot \text{ft}^3}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:**

ACE = Analyzer calibration error, percent of calibration span.  
B<sub>WS</sub> = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.  
C<sub>avg</sub> = Average unadjusted gas concentration indicated by data recorder for the test run.  
C<sub>D</sub> = Pollutant concentration adjusted to dry conditions.  
C<sub>dir</sub> = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.  
C<sub>gas</sub> = Average effluent gas concentration adjusted for bias.  
C<sub>M</sub> = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.  
C<sub>MA</sub> = Actual concentration of the upscale calibration gas, ppmv.  
C<sub>O</sub> = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.  
C<sub>S</sub> = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.  
C<sub>SS</sub> = Concentration of NOx measured in the spiked sample.  
C<sub>spike</sub> = Concentration of NOx in the undiluted spike gas.  
C<sub>calc</sub> = Calculated concentration of NOx in the spike gas diluted in the sample.  
C<sub>y</sub> = Manufacturer certified concentration of a calibration gas (low, mid, or high).  
C<sub>w</sub> = Pollutant concentration measured under moist sample conditions, wet basis.  
CS = Calibration span.  
D = Drift assessment, percent of calibration span.  
E<sub>p</sub> = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.  
Eff<sub>NO2</sub> = NO<sub>2</sub> to NO converter efficiency, percent.  
H = High calibration gas, designator.  
L = Low calibration gas, designator.  
M = Mid calibration gas, designator.  
NO<sub>Final</sub> = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.  
NO<sub>xCorr</sub> = The NO<sub>x</sub> concentration corrected for the converter efficiency.  
NO<sub>xFinal</sub> = The final NO<sub>x</sub> concentration observed during the converter efficiency test in Section 16.2.2.  
NO<sub>xPeak</sub> = The highest NO<sub>x</sub> concentration observed during the converter efficiency test in Section 16.2.2.  
Q<sub>spike</sub> = Flow rate of spike gas introduced in system calibration mode, L/min.  
Q<sub>total</sub> = Total sample flow rate during the spike test, L/min.  
R = Spike recovery, percent.  
SB = System bias, percent of calibration span.  
SB<sub>i</sub> = Pre-run system bias, percent of calibration span.  
SB<sub>f</sub> = Post-run system bias, percent of calibration span.  
SB / D<sub>alt</sub> = Alternative absolute difference criteria to pass bias and/or drift checks.  
SCE = System calibration error, percent of calibration span.  
SCE<sub>i</sub> = Pre-run system calibration error, percent of calibration span.  
SCE<sub>f</sub> = Post-run system calibration error, percent of calibration span.  
Z = Zero calibration gas, designator.

**40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:**

P<sub>r</sub> = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg  
P<sub>o</sub> = observed combustor inlet absolute pressure at test, mm Hg  
H<sub>o</sub> = observed humidity of ambient air, g H<sub>2</sub>O/g air  
e = transcendental constant, 2.718  
T<sub>a</sub> = ambient temperature, K

**RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:**

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant  
 $B_{wa}$  = Moisture fraction of ambient air, percent.  
 Btu = British thermal unit  
 $\%_C$  = Concentration of carbon from an ultimate analysis of fuel, weight percent.  
 $\%_{CO2d}, \%_{CO2w}$  = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.  
 CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.  
 $E$  = Pollutant emission rate, ng/J (lb/million Btu).  
 $E_a$  = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).  
 $E_{in}, E_{out}$  = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).  
 $E_w$  = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).  
 $E_{wo}$  = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).  
 $E_{ci}$  = Pollutant rate in combined effluent, ng/J (lb/million Btu).  
 $E_{co}$  = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).  
 $E_s$  = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).  
 $E_{di}$  = Average inlet SO<sub>2</sub> rate for each sampling period d, ng/J (lb/million Btu).  
 $E_g$  = Pollutant rate from gas turbine, ng/J (lb/million Btu).  
 $E_{ga}$  = Daily geometric average pollutant rate, ng/J (lb/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 $E_{g,i}, E_{g,o}$  = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 $E_h$  = Hourly average pollutant, ng/J (lb/million Btu).  
 $E_{hj}$  = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.  
 $F_c$  = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19  
 $F_d, F_w, F_c$  = Volumes of combustion components per unit of heat content, scm<sup>3</sup>/J (scf/million Btu).  
 ft<sup>3</sup> = cubic feet  
 $G$  = ideal gas conversion factor  
 (385.23 SCF/lb-mol at 68 deg F & 14.696 psia)  
 $GCM$  = gross Btu per SCF (constant, compound based)  
 $GCV$  = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).  
 $GCV_p, GCV_r$  = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).  
 $\%_H$  = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.  
 $H_s$  = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).  
 $H_g$  = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).  
 $\%_{H2O}$  = Concentration of water from an ultimate analysis of fuel, weight percent.  
 $H$  = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).  
 $K$  = volume of combustion component per pound of component (constant)  
 $K$  = Conversion factor, 10<sup>-5</sup> (kJ/J)/(%) [10<sup>6</sup> Btu/million Btu].  
 $K_c$  = (9.57 scm<sup>3</sup>/kg)/% [(1.53 scf/lb)/%].  
 $K_{cc}$  = (2.0 scm<sup>3</sup>/kg)/% [(0.321 scf/lb)/%].  
 $K_{cd}$  = (22.7 scm<sup>3</sup>/kg)/% [(3.64 scf/lb)/%].  
 $K_{cw}$  = (34.74 scm<sup>3</sup>/kg)/% [(5.57 scf/lb)/%].  
 $K_n$  = (0.86 scm<sup>3</sup>/kg)/% [(0.14 scf/lb)/%].  
 $K_o$  = (2.85 scm<sup>3</sup>/kg)/% [(0.46 scf/lb)/%].  
 $K_s$  = (3.54 scm<sup>3</sup>/kg)/% [(0.57 scf/lb)/%].  
 $K_{sulfur}$  = 2x10<sup>4</sup> Btu/Mt%-MMBtu  
 $K_w$  = (1.30 scm<sup>3</sup>/kg)/% [(0.21 scf/lb)/%].  
 lb = pound  
 ln = Natural log of indicated value.  
 $L_p, L_r$  = Weight of the product and raw fuel lots, respectively, metric ton (ton).  
 $\%_N$  = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.  
 $M\%$  = mole percent  
 mol = mole  
 $MW$  = molecular weight (lb/lb-mol)  
 $MW_{AIR}$  = molecular weight of air ( 28.9625 lb/lb-mole)<sup>1</sup>  
 $NCM$  = net Btu per SCF (constant based on compound)  
 $\%_O$  = Concentration of oxygen from an ultimate analysis of fuel, weight percent.  
 $\%_{O2d}, \%_{O2w}$  = Concentration of oxygen on a dry and wet basis, respectively, percent.  
 $P_B$  = barometric pressure, in Hg  
 $P_s$  = Potential SO<sub>2</sub> emissions, percent.  
 $\%_S$  = Sulfur content of as-fired fuel lot, dry basis, weight percent.  
 $S_d$  = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).  
 $\%_{S1}$  = Concentration of sulfur from an ultimate analysis of fuel, weight percent.  
 $S(wt\%)$  = weight percent of sulfur, per lab analysis by appropriate ASTM standard  
 $S_1$  = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).  
 $S_d$  = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).  
 $\%S_p, \%S_r$  = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.  
 SCF = standard cubic feet  
 SH = specific humidity, pounds of water per pound of air  
 $t_{0.95}$  = Values shown in Table 19-3 for the indicated number of data points n.  
 $T_{amb}$  = ambient temperature, °F  
 $W/D$  Factor = 1.0236 = conv. at 14.696 psia and  
 68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)  
 $X_{CO2}$  = CO<sub>2</sub> Correction factor, percent.  
 $X_k$  = Fraction of total heat input from each type of fuel k.

# Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

## Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

### ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO <sub>2</sub> (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH <sub>3</sub> (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03

### 40CFR60, App. A, RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO <sub>2</sub> =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH <sub>3</sub> =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534

NOTE: units are lb/ppm\*ft<sup>3</sup>

## Formulas:

1. Corrected Raw Average (C<sub>Gas</sub>), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_O) \times \left( \frac{C_{MA}}{C_M - C_O} \right)$$

2. Correction to % O<sub>2</sub>, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left( \frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right)$$

3. Correction to % O<sub>2</sub> and ISO Conditions

$$C_{ISO} = C_{adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_o - 0.00633))} \times \left( \frac{288}{T_a} \right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh)

$$Q_s = \left( \frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left( \frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_s \times MW}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O<sub>2</sub> based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O_2)}}$$

8. Emission Concentration in g/hp\*hr

$$E_{g/hp-hr} = \frac{E_{lb/hr} \times 453.6}{mw \times 1314.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp}$$

**APPENDIX B**  
**UNIT OPERATION PARAMETERS**

## Florida Power and Light

<b>Air Permit # :</b>	PSD-FL-354
<b>Plant Name or Location:</b>	West County Energy Center
<b>Date:</b>	October 5-6, 2009
<b>Project Number:</b>	bv-09-westcounty.fl-comp#1
<b>Manufacturer &amp; Equipment:</b>	Mitsubishi
<b>Model:</b>	501G
<b>Unit Number:</b>	1C
<b>Test Load:</b>	Base with and without Duct Burners
<b>Tester(s) / Test Unit(s):</b>	JRF/TP 210

	UNITS	RUN					
		1-1	1-2	1-3	2-1	2-2	2-3
<b>Start Time</b>	hh:mm:ss	10:00:15	11:55:15	13:30:15	17:51:15	19:05:15	09:57:28
<b>End Time</b>	hh:mm:ss	10:59:45	12:54:45	14:29:45	18:50:45	20:04:45	10:56:58
<b>Bar. Pressure</b>	in. Hg	29.88	29.91	29.88	29.80	29.83	29.88
<b>Amb. Temp.</b>	°F	91	97	98	93	87	86
<b>Rel. Humidity</b>	%	64	52	44	52	74	88
<b>Spec. Humidity</b>	lb water / lb air	0.020195	0.019710	0.017141	0.017433	0.020635	0.023849
<b>Date</b>	mm/dd/yy	10/05/09	10/05/09	10/05/09	10/05/09	10/05/09	10/06/09
<b>Load Designator</b>		Base w/o DB	Base w/o DB	Base w/o DB	Base w/DB	Base w/DB	Base w/DB
<b>Comb. Inlet Pres.</b>	psig	262.6	260.4	259.0	264.4	265.2	266.0
<b>Turbine Fuel Flow</b>	lb/min	1,799	1,779	1,771	1,614	1,624	1,638
<b>Duct Burner Fuel Flow</b>	lb/min	0	0	0	198	198	192
<b>Total Fuel Flow</b>	SCFH	2,497,491	2,470,180	2,459,303	2,516,237	2,530,124	2,541,002
<b>Stack Moisture</b>	% Method 4	11.0	10.2	8.7	11.6	11.3	11.0
<b>Power Output</b>	megawatts	244.1	240.8	238.9	247.3	248.2	248.9

**UNIT OPERATION PARAMETERS**

**Base Load**

Combustor Inlet Pressure C	CT C Gas Flow	DB C Gas Flow	CT C Load
psig	KPPH	KPPH	MW

05-Oct-09 10:00:15	263.24	108.21	0.00	244.90
05-Oct-09 10:01:15	263.09	108.21	0.00	244.67
05-Oct-09 10:02:15	263.18	109.87	0.00	245.48
05-Oct-09 10:03:15	263.10	108.24	0.00	245.29
05-Oct-09 10:04:15	262.85	108.09	0.00	244.30
05-Oct-09 10:05:15	262.94	107.54	0.00	243.91
05-Oct-09 10:06:15	263.07	108.04	0.00	244.71
05-Oct-09 10:07:15	262.94	107.96	0.00	244.54
05-Oct-09 10:08:15	262.89	111.49	0.00	244.73
05-Oct-09 10:09:15	262.98	109.49	0.00	245.05
05-Oct-09 10:10:15	263.04	106.44	0.00	244.61
05-Oct-09 10:11:15	262.86	108.37	0.00	244.54
05-Oct-09 10:12:15	262.95	107.27	0.00	244.62
05-Oct-09 10:13:15	263.03	108.56	0.00	244.85
05-Oct-09 10:14:15	262.92	107.92	0.00	244.43
05-Oct-09 10:15:15	263.03	105.37	0.00	244.35
05-Oct-09 10:16:15	263.11	104.45	0.00	244.22
05-Oct-09 10:17:15	263.14	108.74	0.00	245.01
05-Oct-09 10:18:15	263.24	108.97	0.00	244.98
05-Oct-09 10:19:15	263.06	108.10	0.00	244.72
05-Oct-09 10:20:15	263.04	108.47	0.00	244.90
05-Oct-09 10:21:15	263.00	110.30	0.00	245.16
05-Oct-09 10:22:15	262.86	109.53	0.00	244.22
05-Oct-09 10:23:15	262.94	108.02	0.00	244.59
05-Oct-09 10:24:15	263.07	108.07	0.00	244.50
05-Oct-09 10:25:15	262.88	107.89	0.00	244.87
05-Oct-09 10:26:15	262.87	108.17	0.00	244.72
05-Oct-09 10:27:15	262.73	109.49	0.00	244.49
05-Oct-09 10:28:15	262.61	108.48	0.00	244.47
05-Oct-09 10:29:15	262.66	107.72	0.00	244.32
05-Oct-09 10:30:15	262.75	106.75	0.00	244.01
05-Oct-09 10:31:15	262.74	107.66	0.00	243.98
05-Oct-09 10:32:15	262.78	103.56	0.00	244.36
05-Oct-09 10:33:15	262.74	107.62	0.00	244.40
05-Oct-09 10:34:15	262.46	106.84	0.00	244.06
05-Oct-09 10:35:15	262.25	107.78	0.00	243.78
05-Oct-09 10:36:15	262.32	106.46	0.00	243.77
05-Oct-09 10:37:15	262.28	108.49	0.00	243.64
05-Oct-09 10:38:15	262.42	108.23	0.00	243.63
05-Oct-09 10:39:15	262.31	107.84	0.00	243.86
05-Oct-09 10:40:15	262.33	107.78	0.00	243.65
05-Oct-09 10:41:15	262.34	107.37	0.00	243.56
05-Oct-09 10:42:15	262.17	108.38	0.00	243.82
05-Oct-09 10:43:15	262.24	106.44	0.00	243.88
05-Oct-09 10:44:15	262.09	107.97	0.00	243.31
05-Oct-09 10:45:15	262.18	107.89	0.00	243.63
05-Oct-09 10:46:15	261.94	108.43	0.00	243.57
05-Oct-09 10:47:15	262.07	107.44	0.00	243.20
05-Oct-09 10:48:15	262.18	108.92	0.00	243.44
05-Oct-09 10:49:15	262.24	107.44	0.00	243.58
05-Oct-09 10:50:15	262.32	107.66	0.00	243.36
05-Oct-09 10:51:15	262.22	107.85	0.00	243.26
05-Oct-09 10:52:15	262.16	107.02	0.00	243.61
05-Oct-09 10:53:15	262.13	108.36	0.00	243.69
05-Oct-09 10:54:15	262.03	107.98	0.00	243.25
05-Oct-09 10:55:15	261.87	108.05	0.00	243.08
05-Oct-09 10:56:15	261.85	107.76	0.00	242.82
05-Oct-09 10:57:15	261.99	107.71	0.00	243.06
05-Oct-09 10:58:15	261.93	107.91	0.00	243.18
05-Oct-09 10:59:15	261.66	107.82	0.00	242.82
Average	262.61	107.91	0.00	244.12



Combustor Inlet Pressure C	CT C Gas Flow	DB C Gas Flow	CT C Load
psig	KPPH	KPPH	MW

05-Oct-09 11:55:15	260.68	106.62	0.00	241.06
05-Oct-09 11:56:15	260.70	106.80	0.00	241.34
05-Oct-09 11:57:15	260.91	107.51	0.00	241.37
05-Oct-09 11:58:15	260.90	106.87	0.00	241.85
05-Oct-09 11:59:15	260.64	106.50	0.00	241.27
05-Oct-09 12:00:15	260.33	106.73	0.00	240.79
05-Oct-09 12:01:15	260.35	106.30	0.00	240.63
05-Oct-09 12:02:15	260.58	106.67	0.00	241.25
05-Oct-09 12:03:15	260.48	106.68	0.00	240.97
05-Oct-09 12:04:15	260.57	106.14	0.00	240.97
05-Oct-09 12:05:15	260.65	106.04	0.00	241.31
05-Oct-09 12:06:15	260.83	106.89	0.00	241.55
05-Oct-09 12:07:15	260.82	106.84	0.00	241.85
05-Oct-09 12:08:15	260.66	106.84	0.00	241.52
05-Oct-09 12:09:15	260.66	106.66	0.00	241.35
05-Oct-09 12:10:15	260.60	106.88	0.00	241.37
05-Oct-09 12:11:15	260.57	106.87	0.00	241.26
05-Oct-09 12:12:15	260.67	106.95	0.00	240.95
05-Oct-09 12:13:15	260.70	107.19	0.00	241.47
05-Oct-09 12:14:15	260.74	107.22	0.00	240.98
05-Oct-09 12:15:15	260.56	107.22	0.00	241.40
05-Oct-09 12:16:15	260.32	106.95	0.00	240.96
05-Oct-09 12:17:15	260.50	106.81	0.00	240.47
05-Oct-09 12:18:15	260.65	106.58	0.00	241.09
05-Oct-09 12:19:15	260.79	106.73	0.00	241.05
05-Oct-09 12:20:15	260.56	106.20	0.00	240.94
05-Oct-09 12:21:15	260.38	106.74	0.00	240.82
05-Oct-09 12:22:15	260.34	107.15	0.00	240.71
05-Oct-09 12:23:15	260.30	107.28	0.00	240.83
05-Oct-09 12:24:15	260.42	106.86	0.00	240.60
05-Oct-09 12:25:15	260.58	106.52	0.00	240.60
05-Oct-09 12:26:15	260.74	107.10	0.00	241.43
05-Oct-09 12:27:15	260.47	107.01	0.00	240.94
05-Oct-09 12:28:15	260.47	106.60	0.00	240.69
05-Oct-09 12:29:15	260.58	106.71	0.00	240.87
05-Oct-09 12:30:15	260.33	106.53	0.00	241.25
05-Oct-09 12:31:15	260.47	106.34	0.00	240.70
05-Oct-09 12:32:15	260.47	106.76	0.00	240.88
05-Oct-09 12:33:15	260.46	107.16	0.00	241.28
05-Oct-09 12:34:15	260.20	106.99	0.00	240.58
05-Oct-09 12:35:15	259.99	107.23	0.00	240.36
05-Oct-09 12:36:15	260.08	106.64	0.00	240.45
05-Oct-09 12:37:15	260.20	106.65	0.00	240.29
05-Oct-09 12:38:15	260.12	107.20	0.00	240.98
05-Oct-09 12:39:15	259.94	106.26	0.00	240.19
05-Oct-09 12:40:15	260.24	106.40	0.00	240.48
05-Oct-09 12:41:15	260.28	106.71	0.00	240.64
05-Oct-09 12:42:15	260.18	106.64	0.00	240.70
05-Oct-09 12:43:15	259.96	106.65	0.00	240.70
05-Oct-09 12:44:15	259.67	106.55	0.00	239.97
05-Oct-09 12:45:15	259.61	106.36	0.00	239.84
05-Oct-09 12:46:15	259.49	106.25	0.00	240.17
05-Oct-09 12:47:15	259.54	106.12	0.00	239.59
05-Oct-09 12:48:15	259.86	106.72	0.00	240.11
05-Oct-09 12:49:15	260.11	106.71	0.00	240.12
05-Oct-09 12:50:15	260.27	106.85	0.00	240.46
05-Oct-09 12:51:15	260.26	107.14	0.00	241.14
05-Oct-09 12:52:15	260.01	106.81	0.00	240.63
05-Oct-09 12:53:15	259.92	106.36	0.00	240.12
05-Oct-09 12:54:15	259.94	106.12	0.00	239.96
Average	260.37	106.73	0.00	240.84

Combustor Inlet Pressure C	CT C Gas Flow	DB C Gas Flow	CT C Load
psig	KPPH	KPPH	MW

05-Oct-09 13:30:15	259.50	106.57	0.00	240.08
05-Oct-09 13:31:15	259.39	106.00	0.00	239.26
05-Oct-09 13:32:15	259.12	106.41	0.00	239.48
05-Oct-09 13:33:15	259.21	105.90	0.00	238.87
05-Oct-09 13:34:15	259.42	106.32	0.00	239.46
05-Oct-09 13:35:15	259.52	106.05	0.00	239.51
05-Oct-09 13:36:15	259.35	106.44	0.00	240.07
05-Oct-09 13:37:15	259.14	106.30	0.00	239.11
05-Oct-09 13:38:15	258.98	106.20	0.00	239.14
05-Oct-09 13:39:15	259.27	106.25	0.00	238.91
05-Oct-09 13:40:15	259.33	106.54	0.00	239.75
05-Oct-09 13:41:15	259.25	106.40	0.00	238.93
05-Oct-09 13:42:15	259.15	106.05	0.00	239.31
05-Oct-09 13:43:15	259.15	106.39	0.00	239.00
05-Oct-09 13:44:15	258.87	106.34	0.00	239.26
05-Oct-09 13:45:15	259.18	106.11	0.00	238.96
05-Oct-09 13:46:15	259.42	106.45	0.00	239.51
05-Oct-09 13:47:15	259.05	106.37	0.00	239.76
05-Oct-09 13:48:15	258.84	106.35	0.00	238.74
05-Oct-09 13:49:15	258.83	105.95	0.00	238.68
05-Oct-09 13:50:15	259.31	106.12	0.00	239.11
05-Oct-09 13:51:15	259.52	105.50	0.00	239.39
05-Oct-09 13:52:15	259.52	109.17	0.00	240.00
05-Oct-09 13:53:15	259.43	106.98	0.00	239.38
05-Oct-09 13:54:15	259.31	105.77	0.00	238.99
05-Oct-09 13:55:15	259.06	105.92	0.00	239.33
05-Oct-09 13:56:15	258.83	106.18	0.00	239.09
05-Oct-09 13:57:15	258.88	106.45	0.00	238.93
05-Oct-09 13:58:15	258.95	106.23	0.00	238.98
05-Oct-09 13:59:15	258.82	106.36	0.00	239.08
05-Oct-09 14:00:15	258.81	106.60	0.00	238.75
05-Oct-09 14:01:15	258.91	105.91	0.00	238.71
05-Oct-09 14:02:15	258.66	105.26	0.00	238.43
05-Oct-09 14:03:15	258.44	105.49	0.00	238.50
05-Oct-09 14:04:15	258.48	105.23	0.00	237.94
05-Oct-09 14:05:15	258.33	105.66	0.00	238.23
05-Oct-09 14:06:15	258.57	105.68	0.00	238.17
05-Oct-09 14:07:15	258.91	105.93	0.00	238.50
05-Oct-09 14:08:15	259.27	105.69	0.00	239.36
05-Oct-09 14:09:15	258.95	106.43	0.00	239.75
05-Oct-09 14:10:15	258.53	105.89	0.00	238.68
05-Oct-09 14:11:15	258.35	107.62	0.00	238.42
05-Oct-09 14:12:15	258.35	105.50	0.00	237.80
05-Oct-09 14:13:15	258.51	106.75	0.00	238.50
05-Oct-09 14:14:15	258.71	107.24	0.00	238.50
05-Oct-09 14:15:15	258.86	106.28	0.00	238.73
05-Oct-09 14:16:15	259.07	106.86	0.00	238.71
05-Oct-09 14:17:15	259.00	106.04	0.00	239.08
05-Oct-09 14:18:15	258.46	106.92	0.00	238.86
05-Oct-09 14:19:15	258.37	105.38	0.00	237.89
05-Oct-09 14:20:15	258.38	105.67	0.00	238.34
05-Oct-09 14:21:15	258.48	106.10	0.00	238.18
05-Oct-09 14:22:15	258.63	106.30	0.00	238.77
05-Oct-09 14:23:15	258.59	106.49	0.00	238.53
05-Oct-09 14:24:15	258.79	106.43	0.00	238.30
05-Oct-09 14:25:15	258.96	106.36	0.00	238.55
05-Oct-09 14:26:15	259.03	106.46	0.00	238.92
05-Oct-09 14:27:15	259.08	106.58	0.00	238.81
05-Oct-09 14:28:15	259.01	106.49	0.00	239.26
05-Oct-09 14:29:15	258.64	106.50	0.00	238.73
Average	258.95	106.26	0.00	238.93

**UNIT OPERATION PARAMETERS**

**Base Load with Duct Burners**

Combustor Inlet Pressure C	CT C Gas Flow	DB C Gas Flow	CT C Load
psig	KPPH	KPPH	MW

05-Oct-09 17:51:15	264.85	96.95	11.89	247.81
05-Oct-09 17:52:15	264.64	97.03	11.88	247.53
05-Oct-09 17:53:15	264.52	96.71	11.88	247.57
05-Oct-09 17:54:15	264.49	96.66	11.86	247.32
05-Oct-09 17:55:15	264.35	96.65	11.86	247.08
05-Oct-09 17:56:15	264.37	96.65	11.86	246.94
05-Oct-09 17:57:15	264.39	96.81	11.86	247.30
05-Oct-09 17:58:15	264.43	96.73	11.87	247.10
05-Oct-09 17:59:15	264.32	96.82	11.88	247.38
05-Oct-09 18:00:15	264.35	97.06	11.88	247.45
05-Oct-09 18:01:15	264.35	96.72	11.89	247.26
05-Oct-09 18:02:15	264.25	96.95	11.89	247.26
05-Oct-09 18:03:15	264.32	96.91	11.91	247.27
05-Oct-09 18:04:15	264.32	96.55	11.92	246.89
05-Oct-09 18:05:15	264.18	96.32	11.92	246.87
05-Oct-09 18:06:15	264.10	96.52	11.91	247.02
05-Oct-09 18:07:15	264.13	96.52	11.90	247.05
05-Oct-09 18:08:15	264.17	96.66	11.90	247.20
05-Oct-09 18:09:15	264.07	96.76	11.90	247.02
05-Oct-09 18:10:15	264.21	96.53	11.90	247.18
05-Oct-09 18:11:15	264.17	96.57	11.89	246.84
05-Oct-09 18:12:15	264.40	96.67	11.86	247.12
05-Oct-09 18:13:15	264.41	96.70	11.86	247.08
05-Oct-09 18:14:15	264.25	96.95	11.85	247.40
05-Oct-09 18:15:15	264.15	96.61	11.86	247.29
05-Oct-09 18:16:15	264.25	96.63	11.85	246.68
05-Oct-09 18:17:15	264.25	96.63	11.86	247.23
05-Oct-09 18:18:15	264.15	96.83	11.86	247.25
05-Oct-09 18:19:15	264.29	96.79	11.86	247.02
05-Oct-09 18:20:15	264.40	96.80	11.86	247.03
05-Oct-09 18:21:15	264.58	96.74	11.89	247.50
05-Oct-09 18:22:15	264.44	96.76	11.89	247.17
05-Oct-09 18:23:15	264.42	97.15	11.88	247.57
05-Oct-09 18:24:15	264.29	96.68	11.88	247.41
05-Oct-09 18:25:15	264.31	96.70	11.88	246.96
05-Oct-09 18:26:15	264.48	96.70	11.88	247.06
05-Oct-09 18:27:15	264.48	96.98	11.85	247.41
05-Oct-09 18:28:15	264.43	96.93	11.86	247.39
05-Oct-09 18:29:15	264.43	96.99	11.85	247.21
05-Oct-09 18:30:15	264.25	96.74	11.86	247.44
05-Oct-09 18:31:15	264.35	96.76	11.85	247.15
05-Oct-09 18:32:15	264.31	96.80	11.85	247.28
05-Oct-09 18:33:15	264.35	96.75	11.85	247.18
05-Oct-09 18:34:15	264.50	97.10	11.85	247.16
05-Oct-09 18:35:15	264.48	96.71	11.86	247.34
05-Oct-09 18:36:15	264.48	97.00	11.85	247.60
05-Oct-09 18:37:15	264.45	97.46	11.85	247.45
05-Oct-09 18:38:15	264.49	96.71	11.86	246.98
05-Oct-09 18:39:15	264.29	96.86	11.86	247.58
05-Oct-09 18:40:15	264.32	96.52	11.85	247.02
05-Oct-09 18:41:15	264.29	96.95	11.86	247.32
05-Oct-09 18:42:15	264.46	96.79	11.86	246.98
05-Oct-09 18:43:15	264.46	96.66	11.87	247.43
05-Oct-09 18:44:15	264.51	97.04	11.85	247.60
05-Oct-09 18:45:15	264.40	97.35	11.85	247.40
05-Oct-09 18:46:15	264.33	97.37	11.86	247.22
05-Oct-09 18:47:15	264.45	98.41	11.85	247.73
05-Oct-09 18:48:15	264.38	97.42	11.85	247.18
05-Oct-09 18:49:15	264.54	96.85	11.85	247.40
05-Oct-09 18:50:15	264.47	97.40	11.86	247.70
Average	264.37	96.85	11.87	247.25

Combustor Inlet Pressure C	CT C Gas Flow	DB C Gas Flow	CT C Load
psig	KPPH	KPPH	MW

05-Oct-09 19:05:15	264.35	97.22	11.85	247.87
05-Oct-09 19:06:15	264.33	96.92	11.85	247.07
05-Oct-09 19:07:15	264.26	97.32	11.85	247.35
05-Oct-09 19:08:15	264.38	96.79	11.85	246.99
05-Oct-09 19:09:15	264.43	97.18	11.86	247.56
05-Oct-09 19:10:15	264.59	98.09	11.86	247.53
05-Oct-09 19:11:15	264.51	97.53	11.86	247.33
05-Oct-09 19:12:15	264.45	97.13	11.85	247.43
05-Oct-09 19:13:15	264.43	96.74	11.86	247.50
05-Oct-09 19:14:15	264.42	97.05	11.86	247.40
05-Oct-09 19:15:15	264.43	97.29	11.86	247.59
05-Oct-09 19:16:15	264.37	97.45	11.88	247.38
05-Oct-09 19:17:15	264.42	97.51	11.88	247.18
05-Oct-09 19:18:15	264.36	97.85	11.88	247.42
05-Oct-09 19:19:15	264.36	97.66	11.88	247.09
05-Oct-09 19:20:15	264.31	97.21	11.88	246.97
05-Oct-09 19:21:15	264.46	96.22	11.87	246.90
05-Oct-09 19:22:15	264.49	96.42	11.87	247.40
05-Oct-09 19:23:15	264.50	95.92	11.85	247.41
05-Oct-09 19:24:15	264.31	97.98	11.85	247.65
05-Oct-09 19:25:15	264.37	97.23	11.84	247.24
05-Oct-09 19:26:15	264.31	97.21	11.85	247.25
05-Oct-09 19:27:15	264.41	96.98	11.85	247.13
05-Oct-09 19:28:15	264.55	97.56	11.85	247.77
05-Oct-09 19:29:15	264.36	96.88	11.85	247.26
05-Oct-09 19:30:15	264.58	98.10	11.86	247.74
05-Oct-09 19:31:15	264.70	97.30	11.85	247.58
05-Oct-09 19:32:15	264.74	97.40	11.85	247.43
05-Oct-09 19:33:15	264.93	97.57	11.85	247.77
05-Oct-09 19:34:15	264.85	97.94	11.85	248.09
05-Oct-09 19:35:15	264.78	96.78	11.85	247.65
05-Oct-09 19:36:15	264.78	98.46	11.85	247.64
05-Oct-09 19:37:15	264.93	97.15	11.85	247.73
05-Oct-09 19:38:15	265.17	95.58	11.85	247.88
05-Oct-09 19:39:15	265.18	97.16	11.85	248.04
05-Oct-09 19:40:15	265.45	98.61	11.86	248.77
05-Oct-09 19:41:15	265.62	97.37	11.86	248.24
05-Oct-09 19:42:15	265.79	98.21	11.88	249.32
05-Oct-09 19:43:15	265.86	98.04	11.89	249.07
05-Oct-09 19:44:15	265.93	97.29	11.90	249.11
05-Oct-09 19:45:15	265.98	98.25	11.90	248.98
05-Oct-09 19:46:15	266.12	98.00	11.90	249.14
05-Oct-09 19:47:15	266.13	97.25	11.91	249.61
05-Oct-09 19:48:15	265.98	96.87	11.91	249.21
05-Oct-09 19:49:15	266.01	97.43	11.91	249.45
05-Oct-09 19:50:15	266.19	97.12	11.91	249.43
05-Oct-09 19:51:15	266.18	97.25	11.91	249.52
05-Oct-09 19:52:15	266.18	97.82	11.91	249.54
05-Oct-09 19:53:15	266.09	97.64	11.91	249.30
05-Oct-09 19:54:15	266.03	98.22	11.91	249.51
05-Oct-09 19:55:15	266.25	98.16	11.92	249.50
05-Oct-09 19:56:15	266.32	98.21	11.91	249.82
05-Oct-09 19:57:15	266.35	98.42	11.92	249.56
05-Oct-09 19:58:15	266.36	97.52	11.92	249.68
05-Oct-09 19:59:15	266.09	98.09	11.92	249.84
05-Oct-09 20:00:15	266.03	98.37	11.90	249.50
05-Oct-09 20:01:15	266.08	98.28	11.90	249.43
05-Oct-09 20:02:15	265.90	97.28	11.91	248.79
05-Oct-09 20:03:15	265.96	96.22	11.90	248.79
05-Oct-09 20:04:15	265.86	97.49	11.91	249.07
Average	265.16	97.44	11.88	248.22

	Combustor Inlet Pressure C	CT C Gas Flow	DB C Gas Flow	CT C Load
	psig	KPPH	KPPH	MW
06-Oct-09 09:57:28	265.90	98.75	11.30	248.93
06-Oct-09 09:58:28	265.83	98.30	11.30	249.07
06-Oct-09 09:59:28	265.90	98.34	11.30	248.36
06-Oct-09 10:00:28	265.80	98.41	11.30	248.75
06-Oct-09 10:01:28	265.79	98.33	11.30	248.28
06-Oct-09 10:02:28	265.97	98.38	11.31	248.63
06-Oct-09 10:03:28	266.05	98.35	11.31	248.75
06-Oct-09 10:04:28	265.86	98.48	11.32	248.89
06-Oct-09 10:05:28	265.74	98.50	11.31	248.47
06-Oct-09 10:06:28	265.74	98.37	11.31	248.50
06-Oct-09 10:07:28	265.86	98.27	11.32	248.59
06-Oct-09 10:08:28	265.84	98.38	11.32	248.79
06-Oct-09 10:09:28	265.81	98.11	11.31	248.48
06-Oct-09 10:10:28	265.84	98.52	11.32	249.07
06-Oct-09 10:11:28	265.76	98.46	11.32	248.79
06-Oct-09 10:12:28	265.59	98.54	11.32	248.70
06-Oct-09 10:13:28	265.66	98.24	11.32	248.48
06-Oct-09 10:14:28	265.76	98.54	11.31	248.51
06-Oct-09 10:15:28	265.85	98.77	11.31	248.73
06-Oct-09 10:16:28	265.78	98.55	11.31	248.69
06-Oct-09 10:17:28	265.77	98.69	11.31	248.70
06-Oct-09 10:18:28	265.74	98.42	11.31	248.67
06-Oct-09 10:19:28	265.76	98.43	11.31	248.68
06-Oct-09 10:20:28	265.76	98.35	11.30	248.75
06-Oct-09 10:21:28	265.95	98.37	11.31	248.59
06-Oct-09 10:22:28	265.94	98.40	11.31	248.80
06-Oct-09 10:23:28	265.98	98.14	11.30	248.69
06-Oct-09 10:24:28	265.88	97.99	11.31	248.68
06-Oct-09 10:25:28	265.96	98.15	11.39	248.88
06-Oct-09 10:26:28	266.09	98.53	11.43	248.98
06-Oct-09 10:27:28	266.14	98.21	11.47	248.80
06-Oct-09 10:28:28	266.16	98.50	11.50	249.52
06-Oct-09 10:29:28	266.02	98.20	11.51	248.87
06-Oct-09 10:30:28	265.99	98.11	11.52	248.88
06-Oct-09 10:31:28	265.92	97.92	11.55	249.02
06-Oct-09 10:32:28	265.86	98.24	11.57	248.49
06-Oct-09 10:33:28	266.04	98.39	11.62	248.89
06-Oct-09 10:34:28	266.08	98.42	11.68	248.87
06-Oct-09 10:35:28	266.06	97.88	11.73	249.16
06-Oct-09 10:36:28	266.04	98.02	11.77	248.91
06-Oct-09 10:37:28	266.11	97.56	11.80	248.72
06-Oct-09 10:38:28	266.07	97.87	11.83	248.98
06-Oct-09 10:39:28	266.16	97.92	11.83	248.73
06-Oct-09 10:40:28	266.11	98.07	11.84	248.97
06-Oct-09 10:41:28	266.16	97.71	11.84	248.96
06-Oct-09 10:42:28	266.20	98.03	11.84	249.16
06-Oct-09 10:43:28	266.28	98.08	11.85	249.37
06-Oct-09 10:44:28	266.24	98.09	11.87	249.21
06-Oct-09 10:45:28	266.24	97.61	11.87	249.25
06-Oct-09 10:46:28	266.18	97.76	11.87	249.24
06-Oct-09 10:47:28	266.31	98.30	11.86	249.31
06-Oct-09 10:48:28	266.27	98.02	11.87	249.27
06-Oct-09 10:49:28	266.33	98.18	11.86	249.30
06-Oct-09 10:50:28	266.36	98.19	11.87	249.22
06-Oct-09 10:51:28	266.43	98.38	11.87	249.51
06-Oct-09 10:52:28	266.54	98.28	11.86	249.31
06-Oct-09 10:53:28	266.51	98.27	11.85	249.81
06-Oct-09 10:54:28	266.61	98.18	11.86	249.68
06-Oct-09 10:55:28	266.52	98.80	11.85	249.51
06-Oct-09 10:56:28	266.57	97.70	11.85	249.32
Average	266.03	98.25	11.54	248.92

**APPENDIX C**

**CALIBRATION GAS CERTIFICATIONS**



# CERTIFICATE of ANALYSIS

## Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121  
Section 2.2 Procedure: G-1

Cylinder Number: CC54452

Customer: AIR HYGIENE  
P.O. Number: 9021401  
Item Number: SGZCAH094  
Notes:  
File Name: 326407864E  
Assay Date: 17-Mar-09

Shipping Order #: 32650786  
Transfer #: 32640786  
LOT #: LPX249096  
Valve: CGA590  
Cyl. Pressure:\* 1900psig

\*Cylinder should not be used when gas pressure is below 150 psig

Expiration Date: 16-Mar-12

Component	Requested Concentration	Assay Concentration
Carbon Dioxide	9 %	9.20 ±0.17 %
Oxygen	12 %	12.0 ±0.1 %
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS105	GMIS105	8.02	%	0.05	CO2	N2	AL-0105	10/27/2010	N.A.
SRM128	2658a	9.397	%	0.049	O2	N2	CAL014583	7/1/2011	72-C-45

Analysis Information:

Component 1: Carbon Dioxide		First Triad Analysis On: 3/16/2009				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect								
Model Number:	EN3024	Zero	0.18	0.28	0.20	Zero			
Serial Number:	3024	Reference	7.62	7.58	7.66	Reference			
Analytical Principle:	FTIR	Candidate	8.75	8.60	8.78	Candidate			
MPC Calibrated:	02/18/09	Result	9.25	9.09	9.28	Result			
		Mean Result: 9.20 %				Mean Result:			

Component 2: Oxygen		First Triad Analysis On: 3/17/2009				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	Servomex								
Model Number:	4605C	Zero	0.02	0.01	0.02	Zero			
Serial Number:	1101	Reference	9.30	9.31	9.31	Reference			
Analytical Principle:	Paramag.	Candidate	11.84	11.84	11.85	Candidate			
MPC Calibrated:	02/24/09	Result	11.86	11.96	11.97	Result			
		Mean Result: 11.96 %				Mean Result:			

Analyst Signature: M. Adnane

Calculated by: M. Adnane





# CERTIFICATE of ANALYSIS

## Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121  
Section 2.2 Procedure: G-1

Cylinder Number: AL-2533

Customer: AIR HYGIENE  
P.O. Number: 110207  
Item Number: SGZCAH095  
Notes:

Shipping Order #: 27432766  
Transfer #: 27432766  
LOT #: LPX229603  
Valve: CGA590  
Cyl. Pressure\*: 1900psig

\*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 16-Nov-07

Expiration Date: 15-Nov-10

Component	Requested Concentration	Assay Concentration
Carbon Dioxide	19 %	19.3 ±0.1 %
Oxygen	21 %	20.9 ±0.2 %
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS327	GMIS327	14.05	%	0.06	CO2	N2	CC180047	7/24/2008	N.A.
GMIS355	GMIS355	10.0	%	0.1	O2	N2	CC180358	4/14/2009	N.A.

Analysis Information:

Component 1: Carbon Dioxide		First Triad Analysis On: 11/9/2007				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	0.29	0.30	0.31					
Model Number:	EN3024	16.07	16.08	16.17					
Serial Number:	3024	21.83	22.11	21.98					
Analytical Principle:	FTIR	19.22	19.38	19.27	%				
MPC Calibrated:	10/11/07	Mean Result: 19.29			%	Mean Result:			
		Zero				Zero			
		Reference				Reference			
		Candidate				Candidate			
		Result				Result			

Component 2: Oxygen		First Triad Analysis On: 11/16/2007				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	Servomex	0.05	0.05	0.05					
Model Number:	4605C	9.92	9.92	9.91					
Serial Number:	1101	20.68	20.70	20.68					
Analytical Principle:	Paramag.	20.91	20.93	20.91	%				
MPC Calibrated:	11/06/07	Mean Result: 20.92			%	Mean Result:			
		Zero				Zero			
		Reference				Reference			
		Candidate				Candidate			
		Result				Result			

Analyst Signature: M. Adnane

Calculated by: M. Adnane



**AIR LIQUIDE**

Air Liquide America  
Specialty Gases LLC



**Scott**

**RATA CLASS**

*Dual-Analyzed Calibration Standard*

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: ALAS-47882

Project No.: 05-76528-008

Customer

AIR LIQUIDE AMERICA L.P.

ATTN: STEPHANIE PADGETT  
801 W NORTH CARRIER PKWY  
GRAND PRAIRIE TX 75050-1003

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: **AAL069415** Certification Date: **01Jun2009** Exp. Date: **30Nov2009**  
Cylinder Pressure\*\*\*: **2000 PSIG**

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
CARBON MONOXIDE	4.94 PPM	+/- 1%	Direct NIST and NMI
NITRIC OXIDE	4.96 PPM	+/- 1%	Direct NIST and NMI
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	4.99 PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2635	02Oct2010	KAL003090	25.21 PPM	CARBON MONOXIDE
NTRM 2629	15Aug2013	KAL003016	19.83 PPM	NITRIC OXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
HORIBA/APMA-360/42244670011	08May2009	NDIR
ECO PHYSICS/CLD 84M/84M0359	19May2009	CHEMI

**ANALYZER READINGS**

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis	Second Triad Analysis	Calibration Curve
<b>CARBON MONOXIDE</b> Date: 27May2009 Response Unit: MV Z1=0.00000 R1=25.22000 T1=5.01200 R2=25.21000 Z2=0.00000 T2=5.01300 Z3=0.00000 T3=5.01500 R3=25.21000 Avg. Concentration: 4.963 PPM	Date: 03Jun2009 Response Unit: MV Z1=0.00000 R1=10.02000 T1=4.93600 R2=10.00000 Z2=0.00000 T2=4.94200 Z3=0.00000 T3=4.94000 R3=10.00000 Avg. Concentration: 4.916 PPM	Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup> r = 0.999978 Constants: A = -0.01235827 B = 0.985727112 C = 0.0015772 D = 0 E = 0
<b>NITRIC OXIDE</b> Date: 27May2009 Response Unit: MV Z1=0.00000 R1=19.83000 T1=4.94500 R2=19.86000 Z2=0.00000 T2=4.93500 Z3=0.00000 T3=4.95100 R3=19.78000 Avg. Concentration: 4.966 PPM	Date: 03Jun2009 Response Unit: MV Z1=0.00000 R1=19.83000 T1=4.94800 R2=19.84000 Z2=0.00000 T2=4.94500 Z3=0.00000 T3=4.94300 R3=19.87000 Avg. Concentration: 4.962 PPM	Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup> r = 0.999996 Constants: A = 0.021602025 B = 1.002315407 C = 0 D = 0 E = 0

Special Notes: AIR HYGIENE PART #SG2CAH070

APPROVED BY:

JEFF CROTEAU



# CERTIFICATION OF ANALYSIS

## Interference Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121  
Section 2.2, Procedure G-1

Cylinder S/N: CC60943

Customer: AIR HYGIENE  
Location: TULSA, OK

Shipping Order Number: 32650834  
Transfer Number: 32650934  
Lot Number: SFS130142  
Valve: CGA 660  
Cylinder Pressure\*: 2000 PSIG  
\*Cylinder should not be used when  
gas pressure is below 150 psig

P.O. Number: 9021401  
Item Number: SGZCAH072

Assay Date: 26-Mar-2009

Expiration Date: 26-Mar-2011

Components	Requested Concentration	Assay Concentration
Nitrogen	Balance	Balance
Carbon Monoxide	12 ppm	12.1 ± 0.1 ppm
Nitric Oxide	12 ppm	12.1 ± 0.2 ppm
NOx		12.1 ppm

### Reference Standard(s) Employed For Analysis

Certified Concentration and Uncertainty	Component	Balance	Cyl. No.	SRM/PRM/Mix No.	Exp. Date	Sample No.	Type
10.03 ± 0.06 ppm	Carbon Monoxide	Nitrogen	CC99308	SFS114251	5-Aug-2010	DT	GMIS
7.61 ± 0.07 ppm	Nitric Oxide	Nitrogen	EB0010197	SFS119011	3-Oct-2010	CJ	GMIS

### Analytical Data

Component:		FIRST TRIAD ANALYSIS 17-Mar-2009			SECOND TRIAD ANALYSIS 26-Mar-2009						
Carbon Monoxide		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units		
Analyzer Information	Fourier Transform IR	Zero	-0.0011	0.0147	0.0138	ppm	Zero	0.0031	-0.0024	-0.0048	ppm
Manufacturer:	MKS Instruments	Reference	9.8709	9.8655	9.8760	ppm	Reference	9.8678	9.8818	9.8751	ppm
Model Number:	2031	Candidate	11.888	11.860	11.871	ppm	Candidate	11.889	11.878	11.882	ppm
Serial Number:	10387278	Result	12.08	12.08	12.06	ppm	Result	12.09	12.06	12.07	ppm
MPR Last Calibrated:	12-Mar-2009	Evaluation	Valid	Valid	Valid		Evaluation	Valid	Valid	Valid	
Analytical Principle:	FTIR	Mean Analytical Result:			12.07	ppm	Mean Analytical Result:			12.07	ppm
Component:		FIRST TRIAD ANALYSIS 17-Mar-2009			SECOND TRIAD ANALYSIS 26-Mar-2009						
Nitric Oxide		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units		
Analyzer Information	Fourier Transform IR	Zero	-0.0100	-0.0102	-0.0512	ppm	Zero	0.0094	-0.0040	-0.0134	ppm
Manufacturer:	MKS Instruments	Reference	7.6970	7.7482	7.7055	ppm	Reference	7.7043	7.7086	7.7108	ppm
Model Number:	2031	Candidate	12.292	12.294	12.290	ppm	Candidate	12.181	12.136	12.171	ppm
Serial Number:	10387278	Result	12.15	12.07	12.11	ppm	Result	12.04	11.98	12.00	ppm
MPR Last Calibrated:	22-Mar-2009	Evaluation	Valid	Valid	Valid		Evaluation	Valid	Valid	Valid	
Analytical Principle:	FTIR	Mean Analytical Result:			12.11	ppm	Mean Analytical Result:			12.01	ppm

Analyst: 

Tan Ngo

Approved by: 

Thuan Tran



AIR LIQUIDE

CERTIFICATION OF ANALYSIS

Interference Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121 Section 2.2, Procedure G-1

Cylinder S/N: CC150921

Customer: AIR HYGIENE
Location: TULSA, OK

P.O. Number: 8080801
Item Number: SGZCAH001

Shipping Order Number: 30555150
Transfer Number: 30555150
Lot Number: SFS124130
Valve: CGA 350
Cylinder Pressure\*: 2000 PSIG
\*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 25-Aug-2008

Expiration Date: 25-Aug-2011

Table with 3 columns: Components, Requested Concentration, Assay Concentration. Rows for Nitrogen and Methane.

Reference Standard(s) Employed For Analysis

Table with 8 columns: Certified Concentration and Uncertainty, Component, Balance, Cyl. No., SRM/PRM/Mix No., Exp. Date, Sample No., Type. Row for Methane.

Analytical Data

Table with columns: Component, Analyzer Information, Zero, Reference, Candidate, Result, Evaluation, Units. Includes 'FIRST TRIAD ANALYSIS' data.

Analyst: [Signature] Tan Ngo

Approved by: [Signature] Thuan Tran



AIR LIQUIDE

CERTIFICATION OF ANALYSIS

Interference Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121 Section 2.2, Procedure G-1

Cylinder S/N: CC150841

Customer: AIR HYGIENE
Location: TULSA, OK

Shipping Order Number: 30336104
Transfer Number: 30336104
Lot Number: SFS123631
Valve: CGA 350
Cylinder Pressure: 2000 PSIG
Cylinder should not be used when gas pressure is below 150 psig

P.O. Number: 807.1801
Item Number: SGZCAH0021

Assay Date: 4-Aug-2008

Expiration Date: 4-Aug-2011

Table with 3 columns: Components, Requested Concentration, Assay Concentration. Rows for Nitrogen and Methane.

Reference Standard(s) Employed For Analysis


Table with 8 columns: Certified Concentration and Uncertainty, Component, Balance, Cyl. No., SRM/PRM/Mix No., Exp. Date, Sample No., Type. Row for Methane.

Analytical Data

Table with columns: Component, Analyzer Information, FIRST TRIAD ANALYSIS (Trial 1, 2, 3), Units. Row for Methane.

Analyst: [Signature] Gary Williams

Approved by: [Signature] Thuan Tran



## CERTIFICATION OF ANALYSIS

### Interference Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121  
Section 2.2, Procedure G-1

Customer: AIR HYGIENE  
Location: TULSA, OK

Cylinder S/N: CC53032

Shipping Order Number: 30736937  
Transfer Number: 30736937  
Lot Number: SFS125022  
Valve: CGA 350

P.O. Number: 8082701  
Item Number: SGZCAH006

Cylinder Pressure\*: 2000 PSIG  
\*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 25-Sep-2008

Expiration Date: 25-Sep-2011

Components	Requested Concentration	Assay Concentration
Nitrogen	Balance	Balance
Methane	8.5 ppm	8.40 ± 0.10 ppm

Reference Standard(s) Employed For Analysis


Certified Concentration and Uncertainty	Component	Balance	Cyl. No.	SRM/PRM/Mix No.	Exp. Date	Sample No.	Type
10.06 ± 0.04 ppm	Methane	Air	CC52347	SFS103877	18-Mar-2010	NK	GMIS

Analytical Data

Component:	Methane	FIRST TRIAD ANALYSIS 25-Sep-2008			Units	
		Zero	Trial 1	Trial 2		Trial 3
Analyzer Information	Gas Chromatograph				Area	
Manufacturer:	Hewlett Packard	Reference	95.357	95.042	95.188	Area
Model Number:	G1540A	Candidate	79.484	79.558	79.410	Area
Serial Number:	US00003390/Meth	Result	8.385	8.421	8.392	ppm
MPR Last Calibrated:	24-Sep-2008	Evaluation	Valid	Valid	Valid	
Analytical Principle:	FID & TCD	Mean Analytical Result:			8.399	ppm

Analyst: Tan Ngo

Approved by: Thuan Tran



# CERTIFICATION OF ANALYSIS

## Interference Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121  
Section 2.2, Procedure G-1

Cylinder S/N: EB0011231

Customer: AIR HYGIENE  
Location: TULSA, OK

Shipping Order Number: 33431111  
Transfer Number: 33431111  
Lot Number: SFS131864  
Valve: CGA 660  
Cylinder Pressure\*: 2000 PSIG  
\*Cylinder should not be used when  
gas pressure is below 150 psig

P.O. Number: 9042601  
Item Number: SGZCAH032

Assay Date: 21-May-2009

Expiration Date: 21-Nov-2009

Components	Requested Concentration	Assay Concentration
Nitrogen	Balance	Balance
Nitrogen Dioxide	45-50 ppm	48.0 ± 1.2 ppm

Reference Standard(s) Employed For Analysis

Certified Concentration and Uncertainty	Component	Balance	Cyl. No.	SRM/PRM/Mix No.	Exp. Date	Sample No.	Type
51.4 ± 1.2 ppm	Nitrogen Dioxide	Nitrogen	EB0009973	SFS119543	12-Jul-2010	BI	GMIS

Analytical Data

Component:	Nitrogen Dioxide	FIRST TRIAD ANALYSIS 13-May-2009				SECOND TRIAD ANALYSIS 21-May-2009				
		Zero	Trial 1	Trial 2	Trial 3	Zero	Trial 1	Trial 2	Trial 3	
Analyzer Information	Found: Transmittance IR									Units
Manufacturer:	MKS Instruments	Reference	50.127	50.162	50.262	Reference	50.071	50.164	50.252	ppm
Model Number:	2031	Candidate	46.799	46.807	46.814	Candidate	46.904	46.907	46.886	ppm
Serial Number:	10387278	Result	47.99	47.96	47.87	Result	48.15	48.06	47.95	ppm
MPR Last Calibrated:	29-Apr-2009	Evaluation	Valid	Valid	Valid	Evaluation	Valid	Valid	Valid	ppm
Analytical Principle:	FTIR	Mean Analytical Result: 47.94 ppm				Mean Analytical Result: 48.06 ppm				

Analyst:  Tan Ngo

Approved by:  Thuan Tran

**APPENDIX D**  
**QUALITY ASSURANCE AND QUALITY CONTROL DATA**



## QA/QC PROGRAM

Air Hygiene ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses five major areas:

1. QA reviews of reports, laboratory work, and field testing
2. Equipment calibration and maintenance
3. Chain-of-custody
4. Training
5. Knowledge of current test methods

Each of these areas is discussed individually below.

### QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

### Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program.

### Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

### Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3. A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

### Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

## COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO<sub>2</sub> to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO<sub>2</sub> in a balance of nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

### INSTRUMENTAL ANALYSIS QUALITY ASSURANCE DATA

Date: October 5-6, 2009  
Company: Florida Power and Light  
Location: Loxahatchee, Florida  
Techs: JRF/TP


#### Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
October 5-6, 2009	1	0

Calibration Date: October 5, 2009  
 Client: Florida Power and Light


NOx Span (ppm) = 12.10

THERMO 42C (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2% ≤0.5ppm)
0.00	0.00	0.00	0.00	YES (%)
4.99	5.11	0.99	0.12	YES (%)
12.10	12.11	0.08	0.01	YES (%)
Linearity = 1.000				




CO Span (ppm) = 12.10

THERMO 48C (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2% ≤0.5ppm)
0.00	-0.03	-0.25	0.03	YES (%)
4.94	4.95	0.08	0.01	YES (%)
12.10	12.08	-0.17	0.02	YES (%)
Linearity = 1.000				




O<sub>2</sub> Span (%) = 20.90

CAI 200 (O <sub>2</sub> Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2% ≤0.5%)
0.00	0.04	0.19	0.04	YES (%)
12.00	11.96	-0.19	0.04	YES (%)
20.90	20.91	0.05	0.01	YES (%)
Linearity = 1.002				



THC Range (ppm) = 10.5


THERMO 51 (THC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail (±2.5%) <sup>1</sup>
0.00	0.09	0.86	N/A	YES
3.00	3.15	3.07	3.06	YES
4.94	4.88	-1.97	4.98	YES
8.40	8.40	0.00	N/A	YES
Linearity = 1.022				



<sup>1</sup>zero/high based on 2% of span/low/mid based on 5% of concentration

CO<sub>2</sub> Span (%) = 19.30


CAI 200 (CO <sub>2</sub> Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2% ≤0.5%)
0.00	-0.01	-0.05	0.01	YES (%)
9.20	9.22	0.10	0.02	YES (%)
19.30	19.26	-0.21	0.04	YES (%)
Linearity = 1.002				



Calibration Date: October 6, 2009  
 Client: Florida Power and Light


NOx Span (ppm) = 12.10

THERMO 42C (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2% ≤0.5ppm)
0.00	0.02	0.17	0.02	YES (%)
4.99	5.08	0.74	0.09	YES (%)
12.10	12.17	0.58	0.07	YES (%)
Linearity = 0.996				




CO Span (ppm) = 12.10

THERMO 48C (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2% ≤0.5ppm)
0.00	0.03	0.25	0.03	YES (%)
4.94	5.00	0.50	0.06	YES (%)
12.10	12.18	0.66	0.08	YES (%)
Linearity = 0.996				




O2 Span (%) = 20.90

CAI 200 (O <sub>2</sub> Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2% ≤0.5%)
0.00	0.04	0.19	0.04	YES (%)
12.00	11.97	-0.14	0.03	YES (%)
20.90	20.91	0.05	0.01	YES (%)
Linearity = 1.002				



THC Range (ppm) = 10.5


THERMO 51 (THC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail (±2.5% <sup>1</sup> )
0.00	0.00	0.00	N/A	YES
3.00	3.19	3.95	3.07	YES
4.94	5.29	4.70	5.06	YES
8.40	8.60	1.90	N/A	YES
Linearity = 1.002				



<sup>1</sup>zero/high based on 2% of span/low/mid based on 5% of concentration

CO2 Span (%) = 19.30

CAI 200 (CO <sub>2</sub> Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2% ≤0.5%)
0.00	0.05	0.26	0.05	YES (%)
9.20	9.42	1.14	0.22	YES (%)
19.30	19.39	0.47	0.09	YES (%)
Linearity = 0.998				



**NOx Converter Efficiency**

**Date:** October 5, 2009

**Analyzer:** INST-NX-0010

RM 7E, (08-15-06), 8.2.4.1 Introduce a concentration of 40 to 60 ppmv NO<sub>2</sub> to the analyzer in direct calibration mode and record the NOx concentration displayed by the analyzer. ... Calculate the converter efficiency using Equation 7E-7 in Section 12.7. The specification for converter efficiency in Section 13.5 must be met. ... The NO<sub>2</sub> must be prepared according to the EPA Traceability Protocol and have an accuracy within 2.0 percent.

<b>Audit Gas:</b>	NO <sub>2</sub> Concentration (C <sub>v</sub> ), ppmvd	<b>48.00</b>
<b>Converter Efficiency Calculations:</b>		
	Analyzer Reading, NO Channel, ppmvd	<b>2.17</b>
	Analyzer Reading, NOx Channel, ppmvd	<b>48.96</b>
	Analyzer Reading, NO <sub>2</sub> Channel (C <sub>Dir(NO2)</sub> ), ppmvd	<b>46.79</b>
	Converter Efficiency, %	<b>97.48</b>

RM 7E, (08-15-06), 13.5 NO<sub>2</sub> to NO Conversion Efficiency Test (as applicable). The NO<sub>2</sub> to NO conversion efficiency, calculated according to Equation 7E-7 or Equation 7E-9, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left( \frac{C_{Dir}}{C_V} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{46.79 \text{ ppmvd}}{48.00 \text{ ppmvd}} \times 100 = 97.48\%$$

Date/Time mm/dd/yy hh:mm:ss	Elapsed Time Seconds	NOx ppmvd	NO ppmvd
10/05/09 6:30:45	1528	30.96	3.33
10/05/09 6:31:15	1558	42.61	3.28
10/05/09 6:31:45	1588	45.32	2.90
10/05/09 6:32:15	1618	46.82	2.63
10/05/09 6:32:45	1648	47.72	2.45
10/05/09 6:33:15	1678	48.42	2.32
10/05/09 6:33:45	1708	48.96	2.17

**NOx Converter Efficiency**

**Date:** October 6, 2009

**Analyzer:** INST-NX-0010

RM 7E, (08-15-06), 8.2.4.1 Introduce a concentration of 40 to 60 ppmv NO<sub>2</sub> to the analyzer in direct calibration mode and record the NOx concentration displayed by the analyzer. ... Calculate the converter efficiency using Equation 7E-7 in Section 12.7. The specification for converter efficiency in Section 13.5 must be met. ... The NO<sub>2</sub> must be prepared according to the EPA Traceability Protocol and have an accuracy within 2.0 percent.

<b>Audit Gas:</b>	NO <sub>2</sub> Concentration (C <sub>v</sub> ), ppmvd	<b>48.00</b>
<b>Converter Efficiency Calculations:</b>		
	Analyzer Reading, NO Channel, ppmvd	<b>2.32</b>
	Analyzer Reading, NOx Channel, ppmvd	<b>49.74</b>
	Analyzer Reading, NO <sub>2</sub> Channel (C <sub>Dir(NO2)</sub> ), ppmvd	<b>47.42</b>
	Converter Efficiency, %	<b>98.79</b>

RM 7E, (08-15-06), 13.5 NO<sub>2</sub> to NO Conversion Efficiency Test (as applicable). The NO<sub>2</sub> to NO conversion efficiency, calculated according to Equation 7E-7 or Equation 7E-9, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left( \frac{C_{Dir}}{C_V} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{47.42 \text{ ppmvd}}{48.00 \text{ ppmvd}} \times 100 = 98.79\%$$

Date/Time mm/dd/yy hh:mm:ss	Elapsed Time Seconds	NOx ppmvd	NO ppmvd
10/06/09 07:48:58	1290	5.10	4.98
10/06/09 07:49:28	1320	23.89	3.81
10/06/09 07:49:58	1350	45.70	2.27
10/06/09 07:50:28	1380	48.48	2.17
10/06/09 07:50:58	1410	49.65	2.03
10/06/09 07:51:28	1440	49.33	1.93
10/06/09 07:51:58	1470	49.73	1.87
10/06/09 07:52:28	1500	49.74	2.32

DRIFT AND BIAS CHECK		
Strat Test Pre and Post QA/QC Check	O2	NOx
Initial Zero	0.02	0.03
Final Zero	-0.01	-0.03
Avg. Zero	0.01	0.00
Initial UpScale	12.01	11.80
Final UpScale	12.03	11.76
Avg. UpScale	12.02	11.78
Sys Resp (Zero)	0.04	0.00
Sys Resp (Upscale)	11.96	12.11
Upscale Cal Gas	12.00	12.10
Initial Zero Bias	-0.10%	0.25%
Final Zero Bias	-0.24%	-0.25%
Zero Drift	0.14%	0.50%
Initial Upscale Bias	0.24%	-2.56%
Final Upscale Bias	0.33%	-2.89%
Upscale Drift	0.10%	0.33%
Alternative Specification Abs Difr	Initial Zero	0.02
	Final Zero	0.05
	Initial Upscale	0.05
	Final Upscale	0.07
Calibration Span	20.90	12.10
3% of Range (drift)	0.63	0.36
5% of Range (bias)	1.05	0.61

Response Time (min)	0.5	1.2
Sys. Response (min)	1.2	

INJECTIONS

Date/Time	O2 %	NOx PPM
10/05/09 07:07:37	21.04	0.04
10/05/09 07:07:47	17.24	0.04
10/05/09 07:07:57	0.94	0.08
10/05/09 07:08:07	0.11	-0.14
10/05/09 07:08:17	0.07	1.53
10/05/09 07:08:27	0.05	6.96
10/05/09 07:08:37	0.05	10.68
10/05/09 07:08:47	0.04	11.30
10/05/09 07:08:57	0.02	11.73
10/05/09 07:09:07	0.02	11.77
10/05/09 07:09:17	0.01	11.82
10/05/09 07:09:27	0.01	11.87
10/05/09 07:09:37	0.01	11.85
10/05/09 07:09:47	0.01	11.83
10/05/09 07:09:57	0.01	11.83
10/05/09 07:10:07	0.00	11.86
10/05/09 07:10:17	0.26	11.86
10/05/09 07:10:27	9.97	11.83
10/05/09 07:10:37	11.95	9.71
10/05/09 07:10:47	11.99	5.91
10/05/09 07:10:57	12.00	3.41
10/05/09 07:11:07	12.00	1.42
10/05/09 07:11:17	12.02	0.19

DRIFT AND BIAS CHECK						
Base W/O Db Load, Run - 1-1	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	12.99	2.30	0.17	0.77	4.94	
Corrected Average	12.97	2.36	0.37	0.47	4.74	
Initial Zero	0.02	0.03	0.03	0.29	0.06	
Final Zero	-0.01	-0.03	-0.44	0.50	0.41	
Avg. Zero	0.01	0.00	-0.21	0.40	0.24	
Initial UpScale	12.01	4.92	4.91	3.26	9.19	
Final UpScale	12.03	4.83	4.70	3.52	9.55	
Avg. UpScale	12.02	4.88	4.81	3.39	9.37	
Sys Resp (Zero)	0.04	0.00	-0.03	0.09	-0.01	
Sys Resp (Upscale)	11.96	5.11	4.95	3.15	9.22	
Upscale Cal Gas	12.00	4.99	4.94	3.00	9.20	
Initial Zero Bias	-0.10%	0.25%	0.50%	1.90%	0.36%	
Final Zero Bias	-0.24%	-0.25%	-3.39%	3.90%	2.18%	
Zero Drift	0.14%	0.50%	3.88%	2.00%	1.81%	
Initial Upscale Bias	0.24%	-1.57%	-0.33%	1.05%	-0.16%	
Final Upscale Bias	0.33%	-2.31%	-2.07%	3.52%	1.71%	
Upscale Drift	0.10%	0.74%	1.74%	2.48%	1.87%	
Alternative Specification Abs Diff	Initial Zero	0.02	0.03	0.06	--	0.07
	Final Zero	0.05	0.03	0.41	--	0.42
	Initial Upscale	0.05	0.19	0.04	--	0.03
	Final Upscale	0.07	0.28	0.25	--	0.33
Calibration Span	20.90	12.10	12.10	10.50	19.30	
3% of Cal. Span (drift)	0.63	0.36	0.36	0.32	0.58	
5% of Cal. Span (bias)	1.05	0.61	0.61	0.53	0.97	

DRIFT AND BIAS CHECK						
Base W/O Db Load, Run - 1-2	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	13.04	2.35	-0.03	0.73	5.08	
Corrected Average	13.00	2.46	0.41	0.41	4.65	
Initial Zero	-0.01	-0.03	-0.44	0.50	0.41	
Final Zero	-0.03	-0.02	-0.45	0.44	0.56	
Avg. Zero	-0.02	-0.03	-0.45	0.47	0.49	
Initial UpScale	12.03	4.83	4.70	3.07	9.55	
Final UpScale	12.04	4.78	4.55	2.95	9.61	
Avg. UpScale	12.04	4.81	4.63	3.01	9.58	
Sys Resp (Zero)	0.04	0.00	-0.03	0.09	-0.01	
Sys Resp (Upscale)	11.96	5.11	4.95	3.15	9.22	
Upscale Cal Gas	12.00	4.99	4.94	3.00	9.20	
Initial Zero Bias	-0.24%	-0.25%	-3.39%	3.90%	2.18%	
Final Zero Bias	-0.33%	-0.17%	-3.47%	3.33%	2.95%	
Zero Drift	0.10%	0.08%	0.08%	0.57%	0.78%	
Initial Upscale Bias	0.33%	-2.31%	-2.07%	-0.76%	1.71%	
Final Upscale Bias	0.38%	-2.73%	-3.31%	-1.90%	2.02%	
Upscale Drift	0.05%	0.41%	1.24%	1.14%	0.31%	
Alternative Specification Abs Diff	Initial Zero	0.05	0.03	0.41	--	0.42
	Final Zero	0.07	0.02	0.42	--	0.57
	Initial Upscale	0.07	0.28	0.25	--	0.33
	Final Upscale	0.08	0.33	0.40	--	0.39
Calibration Span	20.90	12.10	12.10	10.50	19.30	
3% of Cal. Span (drift)	0.63	0.36	0.36	0.32	0.58	
5% of Cal. Span (bias)	1.05	0.61	0.61	0.53	0.97	



DRIFT AND BIAS CHECK						
Base W/O Db Load, Run - 1-3	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	13.04	2.34	-0.17	1.12	5.19	
Corrected Average	13.01	2.46	0.21	0.92	4.66	
Initial Zero	-0.03	-0.02	-0.45	0.44	0.56	
Final Zero	-0.04	-0.02	-0.30	0.34	0.67	
Avg. Zero	-0.04	-0.02	-0.38	0.39	0.62	
Initial UpScale	12.04	4.78	4.55	2.95	9.61	
Final UpScale	12.01	4.76	4.40	3.26	9.67	
Avg. UpScale	12.03	4.77	4.48	3.11	9.64	
Sys Resp (Zero)	0.04	0.00	-0.03	0.09	-0.01	
Sys Resp (Upscale)	11.96	5.11	4.95	3.15	9.22	
Upscale Cal Gas	12.00	4.99	4.94	3.00	9.20	
Initial Zero Bias	-0.33%	-0.17%	-3.47%	3.33%	2.95%	
Final Zero Bias	-0.38%	-0.17%	-2.23%	2.38%	3.52%	
Zero Drift	0.05%	0.00%	1.24%	0.95%	0.57%	
Initial Upscale Bias	0.38%	-2.73%	-3.31%	-1.90%	2.02%	
Final Upscale Bias	0.24%	-2.89%	-4.55%	1.05%	2.33%	
Upscale Drift	0.14%	0.17%	1.24%	2.95%	0.31%	
Alternative Specification Abs Diff	Initial Zero	0.07	0.02	0.42	--	0.57
	Final Zero	0.08	0.02	0.27	--	0.68
	Initial Upscale	0.08	0.33	0.40	--	0.39
	Final Upscale	0.05	0.35	0.55	--	0.45
Calibration Span	20.90	12.10	12.10	10.50	19.30	
3% of Cal. Span (drift)	0.63	0.36	0.36	0.32	0.58	
5% of Cal. Span (bias)	1.05	0.61	0.61	0.53	0.97	

DRIFT AND BIAS CHECK						
Base W/Db Load, Run - 2-1	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	12.00	2.56	4.17	1.72	5.00	
Corrected Average	12.00	2.66	4.65	1.97	5.09	
Initial Zero	-0.05	0.00	-0.45	0.00	0.01	
Final Zero	-0.03	0.01	-0.45	-0.01	0.05	
Avg. Zero	-0.04	0.01	-0.45	-0.01	0.03	
Initial UpScale	12.00	4.81	4.47	2.87	9.06	
Final UpScale	11.99	4.79	4.45	3.07	8.96	
Avg. UpScale	12.00	4.80	4.46	2.97	9.01	
Sys Resp (Zero)	0.04	0.00	-0.03	0.09	-0.01	
Sys Resp (Upscale)	11.96	5.11	4.95	3.15	9.22	
Upscale Cal Gas	12.00	4.99	4.94	3.00	9.20	
Initial Zero Bias	-0.43%	0.00%	-3.47%	-0.86%	0.10%	
Final Zero Bias	-0.33%	0.08%	-3.47%	-0.95%	0.31%	
Zero Drift	0.10%	0.08%	0.00%	0.10%	0.21%	
Initial Upscale Bias	0.19%	-2.48%	-3.97%	-2.67%	-0.83%	
Final Upscale Bias	0.14%	-2.64%	-4.13%	-0.76%	-1.35%	
Upscale Drift	0.05%	0.17%	0.17%	1.90%	0.52%	
Alternative Specification Abs Diff	Initial Zero	0.09	0.00	0.42	--	0.02
	Final Zero	0.07	0.01	0.42	--	0.06
	Initial Upscale	0.04	0.30	0.48	--	0.16
	Final Upscale	0.03	0.32	0.50	--	0.26
Calibration Span	20.90	12.10	12.10	10.50	19.30	
3% of Cal. Span (drift)	0.63	0.36	0.36	0.32	0.58	
5% of Cal. Span (bias)	1.05	0.61	0.61	0.53	0.97	

DRIFT AND BIAS CHECK						
Base W/Db Load, Run - 2-2	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	12.01	2.58	4.05	0.87	5.03	
Corrected Average	12.02	2.68	4.52	1.01	5.17	
Initial Zero	-0.03	0.01	-0.45	-0.01	0.05	
Final Zero	-0.06	0.06	-0.44	0.01	-0.15	
Avg. Zero	-0.05	0.04	-0.45	0.00	-0.05	
Initial UpScale	11.99	4.79	4.45	3.07	8.96	
Final UpScale	11.99	4.79	4.48	2.78	9.00	
Avg. UpScale	11.99	4.79	4.47	2.93	8.98	
Sys Resp (Zero)	0.04	0.00	-0.03	0.09	-0.01	
Sys Resp (Upscale)	11.96	5.11	4.95	3.15	9.22	
Upscale Cal Gas	12.00	4.99	4.94	3.00	9.20	
Initial Zero Bias	-0.33%	0.08%	-3.47%	-0.95%	0.31%	
Final Zero Bias	-0.48%	0.50%	-3.39%	-0.76%	-0.73%	
Zero Drift	0.14%	0.41%	0.08%	0.19%	1.04%	
Initial Upscale Bias	0.14%	-2.64%	-4.13%	-0.76%	-1.35%	
Final Upscale Bias	0.14%	-2.64%	-3.88%	-3.52%	-1.14%	
Upscale Drift	0.00%	0.00%	0.25%	2.76%	0.21%	
Alternative Specification Abs Diff	Initial Zero	0.07	0.01	0.42	--	0.06
	Final Zero	0.10	0.06	0.41	--	0.14
	Initial Upscale	0.03	0.32	0.50	--	0.26
	Final Upscale	0.03	0.32	0.47	--	0.22
Calibration Span	20.90	12.10	12.10	10.50	19.30	
3% of Cal. Span (drift)	0.63	0.36	0.36	0.32	0.58	
5% of Cal. Span (bias)	1.05	0.61	0.61	0.53	0.97	

DRIFT AND BIAS CHECK						
Base W/Db Load, Run - 2-3	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	12.05	2.67	3.19	1.84	5.53	
Corrected Average	12.06	2.67	3.15	1.82	5.24	
Initial Zero	0.04	0.06	0.28	0.25	0.26	
Final Zero	0.01	0.06	-0.22	0.49	0.43	
Avg. Zero	0.03	0.06	0.03	0.37	0.35	
Initial UpScale	12.01	4.97	5.13	3.19	9.42	
Final UpScale	11.98	4.90	4.84	3.15	9.48	
Avg. UpScale	12.00	4.94	4.99	3.17	9.45	
Sys Resp (Zero)	0.04	0.02	0.03	0.00	0.05	
Sys Resp (Upscale)	11.97	5.08	5.00	3.19	9.42	
Upscale Cal Gas	12.00	4.99	4.94	3.00	9.20	
Initial Zero Bias	0.00%	0.33%	2.07%	2.38%	1.09%	
Final Zero Bias	-0.14%	0.33%	-2.07%	4.67%	1.97%	
Zero Drift	0.14%	0.00%	4.13%	2.29%	0.88%	
Initial Upscale Bias	0.19%	-0.91%	1.07%	0.00%	0.00%	
Final Upscale Bias	0.05%	-1.49%	-1.32%	-0.38%	0.31%	
Upscale Drift	0.14%	0.58%	2.40%	0.38%	0.31%	
Alternative Specification Abs Diff	Initial Zero	0.00	0.04	0.25	--	0.21
	Final Zero	0.03	0.04	0.25	--	0.38
	Initial Upscale	0.04	0.11	0.13	--	0.00
	Final Upscale	0.01	0.18	0.16	--	0.06
Calibration Span	20.90	12.10	12.10	10.50	19.30	
3% of Cal. Span (drift)	0.63	0.36	0.36	0.32	0.58	
5% of Cal. Span (bias)	1.05	0.61	0.61	0.53	0.97	

**METERING SYSTEM CALIBRATION SHEET**

**EPA Reference Method 5**

**Metering System Pre-Test Calibration**

**Air Hygiene Asset ID: samp-cp-0005**

Filename: \\SERVER2\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.D\Current\SAMP-CP-0005 Calibration 7-16-09.xls\Original (5 point)

Make: ES

Date: 07/16/09

Model #: C-5000-XS

Barometric Pressure: 29.12 (in. Hg)

Serial #: 1418

Theoretical Critical Vacuum: 13.74 (in. Hg)

**DRY GAS METER READINGS**

ΔH (in H <sub>2</sub> O)	Time (min)	Volume			Initial Temps.	
		Initial (cu ft)	Final (cu ft)	Total (cu ft)	Inlet (deg F)	Outlet (deg F)
0.26	17.00	234.230	239.240	5.010	85.0	83.0
0.57	12.00	239.240	244.490	5.250	85.0	84.0
1.00	10.00	244.490	250.160	5.670	85.0	84.0
1.80	10.00	250.160	257.480	7.320	87.0	85.0
3.30	10.00	257.480	267.360	9.880	88.0	86.0

Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Ambient Temperature		
Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
85.0	83.0	40	0.2354	16.0	85.6	86.2	85.9
86.0	85.0	48	0.3491	16.0	86.4	86.5	86.5
87.0	85.0	55	0.4530	16.0	86.9	87.3	87.1
88.0	86.0	63	0.5840	16.0	87.3	87.8	87.6
89.0	86.0	73	0.7945	16.0	87.8	88.3	88.1

**RESULTS**

DRY GAS METER		ORIFICE		
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)
4.734	134.06	4.988	141.2	5.300
4.955	140.34	5.219	147.8	5.551
5.355	151.66	5.640	159.7	6.007
6.912	195.74	7.268	205.8	7.747
9.351	264.82	9.883	279.9	10.544

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in H <sub>2</sub> O)	Value (mm H <sub>2</sub> O)	Variation (in H <sub>2</sub> O)
0.000	1.054	1.608	40.84	-0.086
-0.001	1.053	1.600	40.64	-0.094
-0.001	1.053	1.669	42.39	-0.025
-0.002	1.052	1.806	45.87	0.111
0.003	1.057	1.789	45.43	0.094
<b>AVERAGE:</b>	<b>1.054</b>	<b>1.694</b>	<b>43.04</b>	<b>PASSED</b>

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H<sub>2</sub>O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>/(in.Hg)\*(min)).

SIGNATURE: \_\_\_\_\_

*Craig McCarty*

DATE: 07/16/09

**METERING SYSTEM CALIBRATION SHEET**  
**EPA Reference Method 5**  
**Metering System Post-Test Calibration**  
**Air Hygiene Assett ID: samp-cp-0005**

Filename: \\SERVER2\public\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.0\Current\{SAMP-CP-0005 Calibration 7-16-09.xls}10-16-09 (3 point)

Make: ES  
 Model #: C-5000-XS  
 Serial #: 1418

Date: 10/16/09  
 Barometric Pressure: 29.15 (in. Hg)  
 Theoretical Critical Vacuum: 13.75 (in. Hg)

DRY GAS METER READINGS						
-H (in H <sub>2</sub> O)	Time (min)	Volume			Initial Temps.	
		Initial (cu ft)	Final (cu ft)	Total (cu ft)	Inlet (deg F)	Outlet (deg F)
3.20	10.00	477.110	487.020	9.910	65.0	60.0
3.20	10.00	487.020	496.930	9.910	63.0	60.0
3.20	10.00	496.930	506.860	9.930	64.0	61.0

Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Ambient Temperature		
Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
63.0	60.0	73	0.7945	16.0	63.0	63.0	63.0
65.0	62.0	73	0.7945	16.0	63.0	63.0	63.0
65.0	61.0	73	0.7945	16.0	63.0	63.0	63.0

RESULTS				
DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)
9.841	278.69	10.127	286.8	10.300
9.831	278.43	10.127	286.8	10.300
9.847	278.85	10.127	286.8	10.300

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR -H@		
Variation (number)	Value (number)	Value (in H <sub>2</sub> O)	Value (mm H <sub>2</sub> O)	Variation (in H <sub>2</sub> O)
0.000	1.029	1.736	44.10	0.002
0.001	1.030	1.733	44.02	-0.001
-0.001	1.028	1.733	44.02	-0.001
<b>AVERAGE:</b>	<b>1.029</b>	<b>1.734</b>	<b>44.04</b>	<b>PASSED</b>

<b>LAST 5-PT:</b>	<b>1.054</b>	<b>1.694</b>	<b>PASSED</b>	<b>5-PT Date:</b>
<b>% DIFF:</b>	<b>2.4%</b>	<b>2.3%</b>		<b>07/16/09</b>

40 CFR - CHAPTER I - PART 60  
 Appendix A, Method 5  
 10.3.2 Calibration After Use  
 After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single, intermediate orifice setting (based on the previous field test)...Calculate the average value of the DGM calibration factor. If the value has changed by more than 5 percent, recalibrate the meter over the full range of orifice settings, as detailed in Section 10.3.1.

10.3.3 Acceptable Variation in Calibration  
 If the DGM coefficient values obtained before and after a test series differ by more than 5 percent, the test series shall either be voided, or calculations for the test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H<sub>2</sub>O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).

SIGNATURE: Craig McCarty

DATE: 10/16/09

# VISIBLE EMISSIONS EVALUATOR

This is to certify that

**DARIN GRIMES**

met the specifications of Federal Reference Method 9 and qualifies as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, NC. This certificate is valid for six months from date of issue.

**374248**

GERT NUMBER

**4/22/2009**

DATE OF SCHOOL

**TULSA, OK**

SCHOOL LOCATION

**10/22/2009**

CERTIFICATION EXP. DATE

**GRI748589**

STUDENT ID NUMBER

*Michael W. Sanford*

MANAGER OF TRAINING SERVICES

**APPENDIX E**  
**FUEL ANALYSIS RECORDS**

Client: Florida Power and Light  
 Location: West County Energy Center  
 Date: October 5, 2009  
 Project #: bv-09-westcounty.fl-comp#1

Natural Gas - Fuel Analysis

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component	Mole (%)	Molecular <sup>1</sup> Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross <sup>1,3</sup> Heating Value (Btu/ft <sup>3</sup> )	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net <sup>1,3</sup> Heating Value (Btu/ft <sup>3</sup> )	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH <sub>4</sub>	96.839	16.0430	15.54	93.34	994.85	963.40	867.44
Ethane	C <sub>2</sub> H <sub>6</sub>	1.410	30.0700	0.42	2.55	1,743.15	24.58	22.48
Propane	C <sub>3</sub> H <sub>8</sub>	0.187	44.0970	0.08	0.50	2,478.35	4.63	4.26
iso-Butane	iC <sub>4</sub> H <sub>10</sub>	0.029	58.1230	0.02	0.10	3,203.11	0.93	0.86
n-Butane	nC <sub>4</sub> H <sub>10</sub>	0.029	58.1230	0.02	0.10	3,213.35	0.93	0.86
Iso-Pentane	iC <sub>5</sub> H <sub>12</sub>	0.004	72.1500	0.00	0.02	3,940.87	0.16	0.15
n-Pentane	nC <sub>5</sub> H <sub>12</sub>	0.000	72.1500	0.00	0.00	3,948.75	0.00	0.00
Hexanes	C <sub>6</sub> H <sub>14</sub>	0.022	86.1770	0.02	0.11	4,684.54	1.03	0.95
Heptanes	C <sub>7</sub> H <sub>16</sub>	0.000	100.2040	0.00	0.00	5,419.94	0.00	0.00
Octanes	C <sub>8</sub> H <sub>18</sub>	0.000	114.2310	0.00	0.00	6,155.14	0.00	0.00
Carbon Dioxide	CO <sub>2</sub>	0.827	44.0100	0.36	2.19	0.00	0.00	0.00
Nitrogen	N <sub>2</sub>	0.653	28.0134	0.18	1.10	0.00	0.00	0.00
Hydrogen Sulfide	H <sub>2</sub> S	0.000	34.0800	0.00	0.00	627.54	0.00	0.00
Oxygen	O <sub>2</sub>	0.000	31.9988	0.00	0.00	0.00	0.00	0.00
Helium	He	0.000	4.0026	0.00	0.00	0.00	0.00	0.00
Hydrogen	H <sub>2</sub>	0.000	2.0159	0.00	0.00	319.34	0.00	0.00
Totals	100.000		16.64	100.00	dry	995.66	dry	897.00
					wet <sup>2,5</sup>	972.70	wet <sup>2,5</sup>	876.32

Characteristics of Fuel Gas	
Molecular Weight of gas =	16.645 lb/lb-mole
Btu per lb. of gas <sup>4</sup> =	23,043.749 gross (HHV)
Btu per lb. of gas <sup>4</sup> =	20,760.392 net (LHV)
Density of fuel gas <sup>2</sup> =	0.0432 lb/cu. ft
Wt % VOC in fuel gas =	0.83 %
Specific Gravity <sup>1</sup> =	0.5747

Component	Wt%
carbon	73.19
oxygen	1.59
hydrogen	24.12
nitrogen	1.10
helium	0.00
sulfur	0.00
Total	100.00

**F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,644.29**  
 (Based on EPA RM-19) at 68 deg F and 14.696 psia

**F-Factor Calculation:**

$$F\text{-Factor} = 1,000,000 * ((3.84 * \%H) + (1.53 * \%C) + (0.57 * \%S) + (0.14 * \%N) - (0.46 * \%O)) / GCV$$

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

**References:**

- ASTM D 3588
- Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg
- Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III
- Introduction to Fluid Mechanics, 3rd ed. - William S. Janna
- GPA Reference Bulletin 181-86, revised 1986, reprinted 1995



HOUSTON LABORATORIES  
 8820 INTERCHANGE DRIVE  
 HOUSTON, TEXAS 77054  
 PHONE (713) 660-0901

## Certificate of Analysis

Number: 1030-2009100200-001A

Mars Sharief  
 Air Hygiene  
 5634 S. 122nd East Ave.  
 Suite F  
 Tulsa OK 74146

October 14, 2009

Sample ID:		Sampled By:	
Station Name :	Unit 1 C and w/o DB	Sample Of:	Gas Spot
Station Number :		Sample Date:	10/05/2009
Station Location :	Tulsa, Oklahoma	Sample Conditions:	N.G. Pres. , N.G. Temp.
Sample Point:		PO / Ref. No:	
		COC. No:	

### ANALYTICAL DATA

Components	Mol %	Wt %	GPM at 14.696 psia	Method	Lab Tech.	Date Analyzed
				GPA-2261 M	PW	10/13/2009 2:14:17
Nitrogen	0.653	1.099				
Carbon Dioxide	0.827	2.187				
Methane	96.839	93.330				
Ethane	1.410	2.547	0.376			
Propane	0.187	0.495	0.051			
Iso Butane	0.029	0.101	0.009			
n-Butane	0.029	0.101	0.009			
Iso Pentane	0.004	0.017	0.001			
Hexanes Plus	0.022	0.123	0.010			
	100.000	100.000	0.456			
	<b>C2 +</b>	<b>C3 +</b>	<b>iC5 +</b>			
GPM TOTAL :	0.456	0.080	0.011			
Relative Density	Real Gas			0.5757		
Calculated Molecular Weight				16.65		
Compressibility Factor				0.9979		
Calculated Gross BTU per ft <sup>3</sup> @14.696 psia & 60°F						
Real Gas	Dry Basis	1013				
	Saturated Basis	995				

**Comments :**

Cylinder Number 1175

Hydrocarbon Laboratory Manager

**Quality Assurance:**

The above analyses are performed in accordance with ASTM, UOP or GPA guidelines for quality assurance, unless otherwise stated





HOUSTON LABORATORIES  
 8820 INTERCHANGE DRIVE  
 HOUSTON, TEXAS 77054  
 PHONE (713) 660-0901

## Certificate of Analysis

Number: 1030-2009100200-001A

Mars Sharief  
 Air Hygiene  
 5634 S. 122nd East Ave.  
 Suite F  
 Tulsa OK 74146

October 14, 2009

Sample ID:		Sampled By:	
Station Name:	Unit 1 C and w/o DB	Sample Of:	Gas
Station Number :		Sample Date:	10/05/2009
Location:	Tulsa, Oklahoma	Sample Condition:	
Sample Point:		PO / Ref. No:	

### ANALYTICAL DATA

Test	Method	Result	Unit	Detection Limit	Lab Tech.	Date Analyzed
Total Sulfur By UV	ASTM-D-6667	<1.0	PPMW	1.0	EM	10/14/09
Total Sulfur By UV	ASTM-D-6667	<0.0001	Wt%.		EM	10/14/09
Total Sulfur By UV	ASTM-D-6667	<0.032	gr/100 cu.ft.		EM	10/14/09

Comments: Cylinder Number: 1175  
 Sample On: 10/05/2009

Hydrocarbon Laboratory Manager

Quality Assurance: The above analyses are performed in accordance with ASTM, UOP or GPA guidelines for quality assurance, unless otherwise stated.

Client: Florida Power and Light  
 Location: West County Energy Center  
 Date: October 6, 2009  
 Project #: bv-09-westcounty.fl-comp#1

**Natural Gas - Fuel Analysis**

Standardized to 68 deg F and 14.696 psia - EPA Standards

Gas Component		Mole (%)	Molecular <sup>1</sup> Weight (lb/lb-mole)	Lbs Component per Lb-Mole of Gas	Wt. % of Component	Ideal Gross <sup>1,3</sup> Heating Value (Btu/ft <sup>3</sup> )	Fuel Heat Value [HHV] (Btu/SCF)	Ideal Net <sup>1,3</sup> Heating Value (Btu/ft <sup>3</sup> )	Fuel Heat Value [LHV] (Btu/SCF)
Methane	CH <sub>4</sub>	96.570	16.0430	15.49	93.04	994.85	960.72	895.75	865.03
Ethane	C <sub>2</sub> H <sub>6</sub>	1.280	30.0700	0.38	2.31	1,743.15	22.31	1,594.41	20.41
Propane	C <sub>3</sub> H <sub>8</sub>	0.121	44.0970	0.05	0.32	2,478.35	3.00	2,280.17	2.76
iso-Butane	iC <sub>4</sub> H <sub>10</sub>	0.020	58.1230	0.01	0.07	3,203.11	0.64	2,955.38	0.59
n-Butane	nC <sub>4</sub> H <sub>10</sub>	0.019	58.1230	0.01	0.07	3,213.35	0.61	2,965.62	0.56
Iso-Pentane	iC <sub>5</sub> H <sub>12</sub>	0.007	72.1500	0.01	0.03	3,940.87	0.28	3,643.50	0.26
n-Pentane	nC <sub>5</sub> H <sub>12</sub>	0.000	72.1500	0.00	0.00	3,948.75	0.00	3,648.32	0.00
Hexanes	C <sub>6</sub> H <sub>14</sub>	0.018	86.1770	0.02	0.09	4,684.54	0.84	4,337.82	0.78
Heptanes	C <sub>7</sub> H <sub>16</sub>	0.000	100.2040	0.00	0.00	5,419.94	0.00	5,023.77	0.00
Octanes	C <sub>8</sub> H <sub>18</sub>	0.000	114.2310	0.00	0.00	6,155.14	0.00	5,709.23	0.00
Carbon Dioxide	CO <sub>2</sub>	0.799	44.0100	0.35	2.11	0.00	0.00	0.00	0.00
Nitrogen	N <sub>2</sub>	1.166	28.0134	0.33	1.96	0.00	0.00	0.00	0.00
Hydrogen Sulfide	H <sub>2</sub> S	0.000	34.0800	0.00	0.00	627.54	0.00	578.00	0.00
Oxygen	O <sub>2</sub>	0.000	31.9988	0.00	0.00	0.00	0.00	0.00	0.00
Helium	He	0.000	4.0026	0.00	0.00	0.00	0.00	0.00	0.00
Hydrogen	H <sub>2</sub>	0.000	2.0159	0.00	0.00	319.34	0.00	269.82	0.00
<b>Totals</b>		<b>100.000</b>		<b>16.65</b>	<b>100.00</b>	<b>dry</b>	<b>988.40</b>	<b>dry</b>	<b>890.39</b>
						<b>wet<sup>2,5</sup></b>	<b>965.61</b>	<b>wet<sup>2,5</sup></b>	<b>869.86</b>

Characteristics of Fuel Gas	
Molecular Weight of gas =	16.652 lb/lb-mole
Btu per lb. of gas <sup>4</sup> =	22,865.208 gross (HHV)
Btu per lb. of gas <sup>4</sup> =	20,597.777 net (LHV)
Density of fuel gas <sup>2</sup> =	0.0432 lb/cu. ft
Wt % VOC in fuel gas =	0.58 %
Specific Gravity <sup>1</sup> =	0.5750

Component	Wt%
carbon	72.55
oxygen	1.54
hydrogen	23.95
nitrogen	1.96
helium	0.00
sulfur	0.00
<b>Total</b>	<b>100.00</b>

**F-Factor (SCF dry exhaust per MMBtu [HHV]) = 8,648.59**  
 (Based on EPA RM-19) at 68 deg F and 14.696 psia

**F-Factor Calculation:**

$$F\text{-Factor} = 1,000,000 * ((3.64\%H) + (1.53\%C) + (0.57\%S) + (0.14\%N) - (0.46\%O)) / GCV$$

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of natural gas based on specific gravity multiplied by density of air at 68 deg F and 14.696 psia.

**References:**

- <sup>1</sup> ASTM D 3588
- <sup>2</sup> Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg
- <sup>3</sup> Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III
- <sup>4</sup> Introduction to Fluid Mechanics, 3rd ed. - William S. Janna
- <sup>5</sup> GPA Reference Bulletin 181-86, revised 1986, reprinted 1995



**HOUSTON LABORATORIES**  
 8820 INTERCHANGE DRIVE  
 HOUSTON, TEXAS 77054  
 PHONE (713) 660-0901

## Certificate of Analysis

Number: 1030-2009100200-002A

Mars Sharief  
 Air Hygiene  
 5634 S. 122nd East Ave.  
 Suite F  
 Tulsa OK 74146

October 14, 2009

Sample ID:		Sampled By:	
Station Name :	Unit 1 C w/DB and Unit 1B w/DB	Sample Of:	Gas Spot
Station Number :		Sample Date:	10/06/2009
Station Location :	Tulsa, Oklahoma	Sample Conditions:	N.G. Pres. , N.G. Temp.
Sample Point:		PO / Ref. No:	
		COC. No:	

### ANALYTICAL DATA

Components	Mol %	Wt %	GPM at 14.696 psia	Method	Lab Tech.	Date Analyzed
				GPA-2261 M	PW	10/13/2009 2:14:17
Nitrogen	1.166	1.961				
Carbon Dioxide	0.799	2.112				
Methane	96.570	93.029				
Ethane	1.280	2.311	0.341			
Propane	0.121	0.320	0.033			
Iso Butane	0.020	0.070	0.007			
n-Butane	0.019	0.066	0.006			
Iso Pentane	0.007	0.030	0.003			
Hexanes Plus	0.018	0.101	0.008			
	<u>100.000</u>	<u>100.000</u>	<u>0.398</u>			
	<b>C2 +</b>	<b>C3 +</b>	<b>IC5 +</b>			
GPM TOTAL :	0.398	0.057	0.011			
Relative Density	Real Gas			0.5759		
Calculated Molecular Weight				16.65		
Compressibility Factor				0.9980		
Calculated Gross BTU per ft <sup>3</sup> @14.696 psia & 60°F						
Real Gas	Dry Basis	1006				
	Saturated Basis	988				
<b>Comments :</b>	valves ok ; Note Nitrogen. ; Insufficient Sample For Rerun.					
	Cylinder Number 767					

*Mars Sharief*

Hydrocarbon Laboratory Manager

**Quality Assurance:** The above analyses are performed in accordance with ASTM, UOP or GPA guidelines for quality assurance, unless otherwise stated



HOUSTON LABORATORIES  
 8820 INTERCHANGE DRIVE  
 HOUSTON, TEXAS 77054  
 PHONE (713) 660-0901

## Certificate of Analysis

Number: 1030-2009100200-002A

Mars Sharief  
 Air Hygiene  
 5634 S. 122nd East Ave.  
 Suite F  
 Tulsa OK 74146

October 14, 2009

Sample ID:		Sampled By:	
Station Name:	Unit 1 C w/DB and Unit 1B w/DB	Sample Of:	Gas
Station Number:		Sample Date:	10/06/2009
Location:	Tulsa, Oklahoma	Sample Condition:	
Sample Point:		PO / Ref. No:	

### ANALYTICAL DATA

Test	Method	Result	Unit	Detection Limit	Lab Tech.	Date Analyzed
Total Sulfur By UV	ASTM-D-6667	NR	PPMW	1.0	EM	10/14/09
Total Sulfur By UV	ASTM-D-6667	NR	Wt%.		EM	10/14/09
Total Sulfur By UV	ASTM-D-6667	NR	gr/100 cu.ft.		EM	10/14/09

**Comments:** Cylinder Number: 767  
 NR= No result ( Insufficient sample )  
 Sample On: 10/06/2009

Hydrocarbon Laboratory Manager

Quality Assurance: The above analyses are performed in accordance with ASTM, UOP or GPA guidelines for quality assurance, unless otherwise stated.

# SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD



Air Hygiene International, Inc.  
5634 S. 122nd East Ave, Suite F  
Tulsa, Oklahoma 74146  
(888) 461-8778  
www.airhygiene.com

Project Number:		bv-09-westcounty.fl-comp#1		Laboratory Analysis Requested:			
Person Taking Samples:		JRF		ASTM 6667 and GPA-2261 M			
Sample Number	Location	Date	Volume	Analysis Method			
				ASTM 6667	GPA 2261 M		
001175	Unit 1C w and w/o DB	10/5/2009		x	x		
000767	Unit 1C w/DB and Unit 1B w/DB	10/6/2009		x	x		
003764	Unit 1B w/oDB and Unit 1A w/DB	10/7/2009		x	x		
000152	Unit 1A w/o DB	10/8/2009		x	x		
Relinquished by: (Signature) <u>[Signature]</u>		Date: <u>10/12/09</u>	Time: <u>12:30</u>	Received by: (Signature) <u>Martin Cisneros</u>		Date: <u>10/13/09</u>	Time: <u>12:00</u>
Relinquished by: (Signature) _____		Date: _____	Time: _____	Received by: (Signature) _____		Date: _____	Time: _____

**APPENDIX F**  
**STRATIFICATION TEST DATA**

Source Information	
<b>Company</b>	Florida Power and Light
<b>Plant Name</b>	West County Energy Center
<b>Equipment</b>	Mistubishi 501G
<b>Location</b>	Loxahatchee, Florida

Test Information	
<b>Date</b>	10/05/09
<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Unit Number</b>	1C
<b>Load</b>	Base Load
<b>Number of Ports Available</b>	4
<b>Number of Ports Used</b>	4

Stack and Test Type	
<input type="radio"/> Isokinetic Traverse (Wet Chemistry Testing) <input type="radio"/> Velocity Traverse (Flow and Flow RATA Test) <input checked="" type="radio"/> <b>Stratification Traverse (Compliance Test)</b> <input checked="" type="checkbox"/> RM 20 <input type="radio"/> Stratification Traverse (RATA) <input type="checkbox"/> Part 60 <input type="checkbox"/> Part 75	<b>Circular Stack</b>

bv-09-westcounty.fl-comp#1-U1C-strat

**METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE**

Company	Florida Power and Light	Date	10/05/09
Plant Name	West County Energy Center	Project #	bv-09-westcounty.fl-comp#1
Equipment	Mitsubishi 501G	# of Ports Available	4
Location	Loxahatchee, Florida	# of Ports Used	4



Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L <sub>fw</sub> )	282.38	in.
Distance to Near Wall of Stack	(L <sub>nw</sub> )	19.00	in.
Diameter of Stack	(D)	263.38	in.
Area of Stack	(A <sub>s</sub> )	378.35	ft <sup>2</sup>

Distance from Disturbances to Port			
Distance Upstream	(A)	144.00	in.
Diameters Upstream	(A <sub>D</sub> )	0.55	diameters
Distance Downstream	(B)	531.75	in.
Diameters Downstream	(B <sub>D</sub> )	2.02	diameters

Number of Traverse Points Required					
Diameters to		Minimum Number of <sup>1</sup>		Minimum Number of	
Flow Disturbance		Traverse Points		Traverse Points	
Down (B <sub>D</sub> )	Up (A <sub>D</sub> )	Particulate	Velocity	Comp Stratification	
Stream	Stream	Points	Points	Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	AN 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12	12 points	
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>= 2.00	8 or 12 <sup>2</sup>	8 or 12 <sup>2</sup>	Minimum Number of	
Upstream Spec		24	16	Traverse Points	
Downstream Spec		24	16	RATA Stratification	
Traverse Pts Required		24	16	Criteria	Points
<sup>1</sup> Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.					
<sup>2</sup> 8 for Circular Stacks 12 to 24 inches					
12 for Circular Stacks over 24 inches					
		Part75/60		12 RM1 pts	
		75 abrv (a)		3 points	
		75 abrv (b)		6 points	

Number of Traverse Points Used				
4	Ports by	3	Pts / port	Stratification Traverse
12	Pts Used	12	Required	(Compliance Test)

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	11 5/8	30 5/8
2	14.6%	38 4/8	57 4/8
3	29.6%	78	97
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			





**STRATIFICATION TRAVERSE (COMPLIANCE TEST) RESULTS**

<b>Company</b>	Florida Power and Light	<b>Date</b>	10/05/09
<b>Plant Name</b>	West County Energy Center	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Equipment</b>	Mistubishi 501G	<b># of Ports Available</b>	4
<b>Location</b>	Loxahatchee, Florida	<b># of Ports Used</b>	4

Stack Dimensions				Traverse Data			
<b>Diameter or Length of Stack</b>	(D)	263.38	in.	4	<b>Ports by</b>	3	<b>Pts / port</b>
<b>Width of Stack</b>	(W)		in.	12	<b>Pts Used</b>	12	<b>Required</b>
<b>Area of Stack</b>	(A <sub>s</sub> )	378.35	ft <sup>2</sup>	<b>Run Start</b>	7:20:07	<b>Run End</b>	8:12:07

Traverse Point	Time Per Point	Point Start Time	Point Stop Time (Reading)	O2	Percent Difference	NOx	Percent Difference
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%
D-3	3.00	7:20:07	7:23:07	12.94	0.12%	2.84	16.31%
D-2	3.00	7:23:07	7:26:07	12.95	0.05%	2.62	7.30%
D-1	3.00	7:26:07	7:29:07	12.97	0.11%	2.33	4.57%
C-3	9.00	7:29:07	7:38:07	12.98	<b>0.19%</b>	2.29	6.21%
C-2	3.00	7:38:07	7:41:07	12.95	0.05%	2.15	11.95%
C-1	3.00	7:41:07	7:44:07	12.95	0.05%	2.21	9.49%
B-3	7.00	7:44:07	7:51:07	12.95	0.05%	2.79	14.27%
B-2	3.00	7:51:07	7:54:07	12.97	0.11%	2.74	12.22%
B-1	3.00	7:54:07	7:57:07	12.94	0.12%	2.82	15.49%
A-3	9.00	7:57:07	8:06:07	12.95	0.05%	2.51	2.80%
A-2	3.00	8:06:07	8:09:07	12.96	0.03%	2.11	13.58%
A-1	3.00	8:09:07	8:12:07	12.96	0.03%	1.89	<b>22.59%</b>
<b>Correct to</b>	<b>15</b>	<b>% O2</b>	<b>Average</b>	12.96		2.44	

**STRATIFICATION TRAVERSE (COMPLIANCE TEST) RESULTS**

<b>Company</b>	Florida Power and Light	<b>Date</b>	10/05/09
<b>Plant Name</b>	West County Energy Center	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Equipment</b>	Mistubishi 501G	<b># of Ports Available</b>	4
<b>Location</b>	Loxahatchee, Florida	<b># of Ports Used</b>	4

Stack Dimensions				Traverse Data			
<b>Diameter or Length of Stack</b>	(D)	263.38	in.	4	<b>Ports by</b>	3	<b>Pts / port</b>
<b>Width of Stack</b>	(W)		in.	12	<b>Pts Used</b>	12	<b>Required</b>
<b>Area of Stack</b>	(A <sub>s</sub> )	378.35	ft <sup>2</sup>	<b>Run Start</b>	7:20:07	<b>Run End</b>	8:12:07

Traverse Point	Time Per Point	Point Start Time	Point Stop Time (Reading)	O2	Percent Difference	NOx	Percent Difference
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm@15%O2	%
D-3	3.00	7:20:07	7:23:07	12.94	0.12%	2.11	16.09%
D-2	3.00	7:23:07	7:26:07	12.95	0.05%	1.94	7.23%
D-1	3.00	7:26:07	7:29:07	12.97	0.11%	1.73	4.40%
C-3	6.00	7:29:07	7:38:07	12.98	<b>0.19%</b>	1.71	5.92%
C-2	3.00	7:38:07	7:41:07	12.95	0.05%	1.60	12.00%
C-1	3.00	7:41:07	7:44:07	12.95	0.05%	1.64	9.55%
B-3	7.00	7:44:07	7:51:07	12.95	0.05%	2.07	14.19%
B-2	3.00	7:51:07	7:54:07	12.97	0.11%	2.04	12.43%
B-1	3.00	7:54:07	7:57:07	12.94	0.12%	2.09	15.27%
A-3	9.00	7:57:07	8:06:07	12.95	0.05%	1.86	2.73%
A-2	3.00	8:06:07	8:09:07	12.96	0.03%	1.57	13.53%
A-1	3.00	8:09:07	8:12:07	12.96	0.03%	1.40	<b>22.55%</b>
<b>Average</b>				12.96		1.81	

**STRAT TEST DETERMINED SAMPLE POINTS FOR CIRCULAR STACK**

<b>Company</b>	Florida Power and Light	<b>Date</b>	10/05/09
<b>Plant Name</b>	West County Energy Center	<b>Project #</b>	bv-09-westcounty.fl-comp#1
<b>Equipment</b>	Mitsubishi 501G	<b># of Ports Available</b>	4
<b>Location</b>	Loxahatchee, Florida	<b># of Ports Used</b>	4

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	263.38	in.	4	Ports by	3	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A <sub>s</sub> )	378.35	ft <sup>2</sup>	Run Start	7:20:07	Run End	8:12:07

40 CFR 60, Appendix A, Method 7E Criteria					
Stratification Results		Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
Maximum Percent Difference	22.55 % for NOx				
Maximum Pollutant Conc. Diff.	0.41 ppm@15%O2 for NOx				
Maximum Diluent Conc. Diff.	0.02 % for O2				
Stack Diameter	263.38 in.		%	in.	in.
Stratification Conclusions		1			
Maximum % Diff.	Percent Diff. >10% Failed Stratification Test	2			
Maximum Conc. Diff.	Conc. Diff. ≤ 0.5ppm Passed 8.1.2 Single Pt. Criteria	3			
Stack Diameter	D > 93.6 in.				
Passed Strat. Test Under RM 7E 8.1.2 Single Pt. Criteria Sample from the point that most closely matches the average		Test Type	Use 6.5.6.3(a) points? 6.5.6(b)(2) alt. points could apply		

