



AIR HYGIENE, INC.

*Testing Solutions for a Better World*

RECEIVED

MAY 20 2011

BUREAU OF  
AIR REGULATION

**EMISSION COMPLIANCE TEST  
FOR THE  
MITSUBISHI, MODEL 501G, UNIT 3B  
PREPARED FOR  
FLORIDA POWER AND LIGHT  
AT THE  
WEST COUNTY ENERGY CENTER  
LOXAHATCHEE, FLORIDA  
APRIL 9, 2011**



**Corporate Headquarters**

5634 S. 122<sup>nd</sup> E. Ave. Suite F  
Tulsa, OK 74146



AIR HYGIENE, INC.

(918) 307-8865 or (888) 461-8778  
[www.airhygiene.com](http://www.airhygiene.com)

**Remote Testing Offices**

Las Vegas, NV 89156

Ft. Worth, TX 76028

Humble, TX 77338

Shreveport, LA 71115

Miami, FL 33101

Philadelphia, PA 19136

**EMISSION COMPLIANCE TEST  
FOR THE  
MITSUBISHI, MODEL 501G, UNIT 3B  
PREPARED FOR  
FLORIDA POWER AND LIGHT  
AT THE  
WEST COUNTY ENERGY CENTER  
LOXAHATCHEE, FLORIDA  
APRIL 9, 2011**

Prepared and Reviewed by:



Mars Sharief, QSTI, Director of Specialty Testing



Paul Little, QSTI, Director of Customer Service



Jake Fahlenkamp, QSTI, Director of Quality Assurance

## Table of Contents

<b>1.0</b>	<b>INTRODUCTION</b>	<b>1</b>
1.1	TEST PURPOSE AND OBJECTIVES	1
1.2	SUMMARY OF TEST PROGRAM	1
1.2.1	Participating Organizations	1
1.2.2	Industry	1
1.2.3	Air Permit and Federal Requirements	1
1.2.4	Plant Location	1
1.2.5	Equipment Tested	1
1.2.6	Emission Points	2
1.2.7	Pollutants Measured	2
1.2.8	Date of Emission Test	2
1.3	KEY PERSONNEL	2
<b>2.0</b>	<b>SUMMARY OF TEST RESULTS</b>	<b>2</b>
<b>3.0</b>	<b>SOURCE OPERATION</b>	<b>4</b>
3.1	PROCESS DESCRIPTION	4
3.2	SAMPLING LOCATION	4
<b>4.0</b>	<b>SAMPLING AND ANALYTICAL PROCEDURES</b>	<b>5</b>
4.1	TEST METHODS	5
4.2	INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS	5

## APPENDICES

Appendix A	Test Results and Calculations
Appendix B	Emission Data Records
Appendix C	Calibration Gas Certifications
Appendix D	Quality Assurance and Quality Control Data
Appendix E	Fuel Analysis Records
Appendix F	Stratification Test Data

**Emissions Compliance Test  
Mitsubishi, Model 501G, Unit 3B  
Florida Power and Light  
West County Energy Center  
Loxahatchee, Florida  
April 9, 2011**

**1.0 INTRODUCTION**

Air Hygiene International, Inc. (Air Hygiene) has completed the emissions testing study for nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), volatile organic compounds (VOC), ammonia (NH<sub>3</sub>), opacity, carbon dioxide (CO<sub>2</sub>), and oxygen (O<sub>2</sub>) from the exhaust of the Mitsubishi, Model 501G, Unit 3B for Florida Power and Light at the West County Energy Center near Loxahatchee, Florida. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on April 9, 2011.

**1.1 TEST PURPOSE AND OBJECTIVES**

The purpose of the test was to conduct an initial compliance emission test to document levels of selected pollutants at one test load (Fuel Oil). The information will be used to confirm compliance with the operating permit issued by the Florida Department of Environmental Protection (FDEP). The specific objective was to determine the emission concentration of NO<sub>x</sub>, CO, VOC, NH<sub>3</sub>, opacity, CO<sub>2</sub>, and O<sub>2</sub> from the exhaust of Florida Power and Light's Mitsubishi, Model 501G, Unit 3B firing Fuel Oil of total capacity.

**1.2 SUMMARY OF TEST PROGRAM**

The following list details pertinent information related to this specific project:

- 1.2.1 Participating Organizations
  - Florida Department of Environmental Protection (FDEP)
  - Florida Power and Light
  - Black and Veatch
  - Air Hygiene
- 1.2.2 Industry
  - Electric Utility / Electric Services
- 1.2.3 Air Permit and Federal Requirements
  - Permit Number: PSD-FL-396
  - Emission Unit Identification (ID): 014
- 1.2.4 Plant Location
  - West County Energy Center near Loxahatchee, Florida
- 1.2.5 Equipment Tested
  - Mitsubishi, Model 501G, Unit 3B

- 1.2.6 Emission Points
  - Exhaust from the Mitsubishi, Model 501G, Unit 3B
  - For all gases, 12 sample points in the exhaust duct from the Mitsubishi, Model 501G, Unit 3B, determined after conducting a stratification test (refer to Appendix F)
  - For all NH<sub>3</sub> testing, 24 sampling points in the exhaust duct from the Mitsubishi, Model 501G, Unit 3B (refer to Appendix A)
  - For opacity, one sample visual observation point from the exit of the exhaust duct to the atmosphere from the Mitsubishi, Model 501G, Unit 3B
- 1.2.7 Pollutants Measured
  - NO<sub>x</sub>
  - CO
  - VOC
  - NH<sub>3</sub>
  - Opacity
  - CO<sub>2</sub>
  - O<sub>2</sub>
- 1.2.8 Date of Emission Test
  - April 9, 2011

**1.3 KEY PERSONNEL**

Florida Power and Light:	John Mirino	305-242-3895
Florida Power and Light:	David Fawcett	561-904-4907
Black and Veatch:	Bill Stevenson	913-458-8549
Air Hygiene:	Jake Fahlenkamp	918-307-8865
Air Hygiene:	Mukund Venkitachalam	918-307-8865

**2.0 SUMMARY OF TEST RESULTS**

Results from the sampling conducted on Florida Power and Light's Mitsubishi, Model 501G, Unit 3B located at the West County Energy Center on April 9, 2011 are summarized in the following table.

**TABLE 2.1**  
**SUMMARY OF MITSUBISHI, 501G, UNIT 3B RESULTS**

Parameter	Fuel Oil Load	Permit Limits
Date (mm/dd/yy)	04/09/11	—
Start Time (hh:mm:ss)	11:00:29	—
End Time (hh:mm:ss)	15:44:59	—
Run Duration (min / run)	82	—
Bar. Pressure (in. Hg)	30.13	—
Amb. Temp. (°F)	89	—
Rel. Humidity (%)	41	—
Spec. Humidity (lb water / lb air)	0.011862	—
Ammonia Injection Rate (lb/hr)	439.8	—
Turbine Fuel Flow (gal/hr)	15,532	—
Total Fuel Flow (SCFH)	2,076	2,117
Stack Flow (RM19) (SCFH)	54,610,928	—
Stack Moisture (% Method 4)	8.6	—
Heat Input (MMBtu/hr)	2,042.4	—
Power Output (megawatts)	208.7	—
NOx (ppmvd)	8.67	—
NOx (ppm@15%O <sub>2</sub> )	7.03	8.0
NOx (ppm@15%O <sub>2</sub> &ISO)	7.17	—
NOx (lb/hr)	56.58	82.4
NOx (ton/year) at 500 hr/year	14.15	—
NOx (lb/MMBtu)	0.027	—
CO (ppmvd)	5.91	—
CO (ppm@15%O <sub>2</sub> )	4.79	8
CO (ppm@15%O <sub>2</sub> &ISO)	4.89	—
CO (lb/hr)	23.46	42.0
CO (ton/year) at 500 hr/year	5.86	—
CO (lb/MMBtu)	0.011	—
VOC (ppmvd)	0.48	—
VOC (ppm@15%O <sub>2</sub> )	0.39	6
VOC (ppm@15%O <sub>2</sub> &ISO)	0.39	—
VOC (lb/hr)	1.09	19.6
VOC (ton/year) at 500 hr/year	0.27	—
VOC (lb/MMBtu)	0.000	—
Sulfur (wt%)	0.0007	0.0015
NH <sub>3</sub> (ppmvd)	0.92	—
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	0.74	5
Opacity (%)	0	10
CO <sub>2</sub> (%)	5.36	—
O <sub>2</sub> (%)	13.62	—

The results of all measured pollutant emissions were below the required limits. All testing was performed without any real or apparent errors. All testing was conducted according to the approved testing protocol. Total hydrocarbons (THC) were report as VOC.

### **3.0 SOURCE OPERATION**

#### **3.1 PROCESS DESCRIPTION**

Florida Power and Light (FPL) owns and operates the West County Energy Center (West County) located at 20505 State Road 80 in Loxahatchee, Florida. West County is a nominal 3,750 megawatt (MW) greenfield power plant and consists of three combined cycle units (Unit 1, 2 and 3). Each combined cycle unit consists of: three nominal 250 MW Mitsubishi Model 501G combustion turbine-electrical generator (CTGs) sets with evaporative inlet cooling systems; three supplementary-fired heat recovery steam generators (HRSGs) with selective catalytic reduction (SCR) reactors; one nominal 428 million British thermal units per hour (MMBtu/hour) based on low heat value (LHV) natural gas-fired duct burner (DB) located within each of the three HRSG's; and a common nominal 500 MW steam turbine-electrical generator (STG). The total nominal generating capacity of each of the "3 on 1" combined cycle unit is approximately 1,250 MW.

Each CTG has a nominal heat input rate of 2,333 MMBtu/hr when firing natural gas and 2,117 MMBtu/hr when firing distillate fuel oil (based on a compressor inlet air temperature of 59 degrees Fahrenheit (°F), the lower heating value (LHV) of each fuel, and 100 percent load), includes an automated gas turbine control system, and has dual-fuel capability of firing natural gas as the primary fuel or ultra-low sulfur distillate (ULSD) fuel oil as a restricted alternate fuel. Each HRSG recovers exhaust, heat energy from each of the CTGs. Each Unit delivers steam to each STG. The efficient combustion of natural gas and restricted firing of ULSD fuel oil minimizes the emissions of carbon monoxide (CO), particulate matter (PM), sulfuric acid mist (H<sub>2</sub>SO<sub>4</sub>), sulfur dioxide (SO<sub>2</sub>) and volatile organic compounds (VOCs). Dry Low-NOx (DLN) combustors for gas firing and water injection for oil firing reduce nitrogen oxides (NOx) emissions. A selective catalyst reduction (SCR) system further reduces NOx emissions.

#### **3.2 SAMPLING LOCATION**

The 501G stack is circular and measures 21.9 feet (ft) (263 inches) in diameter at the test ports which are approximately 138 ft above grade level with an exit elevation of approximately 150 ft above grade level. The test ports are located approximately 44.3 ft (531 inches) downstream and approximately 12 ft (144 inches) upstream from the nearest disturbances. All exhaust samples for gaseous emissions were continuously drawn from the exhaust system at the sample ports from 12 points (three points per port) determined after conducting a stratification test (Appendix F). During the stratification test three points were traversed from each of the four ports. The probe was allowed to remain at a point for two times the system response time. For NH<sub>3</sub> testing, an initial velocity traverse was performed across the stack at base load from 24 total points. All NH<sub>3</sub> sampling occurred from the same 24 points by leaving the probe at each for an equal amount of time. All opacity observations were made by viewing the point where the exhaust system exited to the atmosphere at the top of the exhaust stack.

## 4.0 SAMPLING AND ANALYTICAL PROCEDURES

### 4.1 TEST METHODS

The emission test on the Mitsubishi, Model 501G, Unit 3B at the West County Energy Center was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on April 9, 2011.

**TABLE 4.1  
SUMMARY OF SAMPLING METHODS**

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	Pitot
Oxygen	EPA Method 3a	Paramagnetic Cell
Carbon Dioxide	EPA Method 3a	Nondispersive Infrared Analyzer
Nitrogen Oxides	EPA Method 7e	Chemiluminescent Analyzer
Opacity	EPA Method 9	Visual Observation
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Stack Flow Rate	EPA Method 19	Dry Oxygen F Factor
Total Hydrocarbons	EPA Method 25a	Flame Ionization Detector
Ammonia Slip	EPA CTM-027	Ion Chromatography M350.3
Sulfur Content Analysis	ASTM D 5453	Fuel Gas Sample and Laboratory Analysis

### 4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3a, 7e, 9, 10, 19, 25a, and Conditional Test Method (CTM)-027.

Figure 4.1 depicts the sample system used for the NO<sub>x</sub>, CO, THC, CO<sub>2</sub>, and O<sub>2</sub> tests. A stainless steel probe was inserted into the sample ports of the stack to extract gas measurements from the emission stream at twelve points in the stack. The gas sample was continuously pulled through the probe and transported, via heat-traced Teflon® tubing, to a stainless steel minimum-contact condenser designed to dry the sample. Transportation of the sample, through Teflon® tubing, continued into the sample manifold within the mobile laboratory via a stainless steel/Teflon® diaphragm pump. From the manifold, the sample was partitioned to the NO<sub>x</sub>, CO, CO<sub>2</sub>, and O<sub>2</sub> analyzers through rotameters that controlled the flow rate of the sample. Exhaust samples were routed to the THC analyzer prior to gas conditioning.



Figure 4.1 shows that the sample system was also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in an air-conditioned, trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NO<sub>x</sub> calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System Hyperlogger which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. Data records can be found in Appendix A and B of this report.

Figure 4.2 represents the sample system used for the wet chemistry tests (NH<sub>3</sub>). A heated stainless steel probe with an inconel liner and stainless steel nozzle was inserted into the sample ports of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter.

Three test runs of approximately 75 minutes each were conducted on the Mitsubishi, Model 501G, Unit 3B at the maximum test load for NO<sub>x</sub>, CO, THC, CO<sub>2</sub>, NH<sub>3</sub>, opacity, and O<sub>2</sub>.

The stack gas analysis for O<sub>2</sub> and CO<sub>2</sub> concentrations was performed in accordance with procedures set forth in EPA Method 3a. The O<sub>2</sub> analyzer uses a paramagnetic cell detector and the CO<sub>2</sub> analyzer uses a continuous nondispersive infrared analyzer.


EPA Method 7e was used to determine concentrations of NO<sub>x</sub>. A chemiluminescent analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO<sub>2</sub> in nitrogen certified gas cylinder was used to verify at least a 90 percent NO<sub>2</sub> conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

THC emission concentrations were quantified in accordance with procedures set forth in EPA Method 25a. A continuous flame ionization (FID) analyzer was used for this purpose. THC emission concentrations were reported as VOC.

**TABLE 4.2  
ANALYTICAL INSTRUMENTATION**

<b>Parameter</b>	<b>Model and Manufacturer</b>	<b>Range</b>	<b>Sensitivity</b>	<b>Detection Principle</b>
NO <sub>x</sub>	THERMO 42i-HL	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO <sub>2</sub> to NO. Chemiluminescence of reaction of NO with O <sub>3</sub> . Detection by PMT. Inherently linear for listed ranges.
CO	THERMO 48i	User may select up to 5,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
CO <sub>2</sub>	THERMO 410i	0-20%	0.1%	Non-dispersive infrared.
THC	THERMO 51C	User may select up to 10,000 ppm	0.1 ppm	Flame Ionization Detector.
O <sub>2</sub>	THERMO 42i-HL	0-25%	0.1%	Paramagnetic cell, inherently linear.



Shown fully equipped. Some labs may not contain these features and others may contain additional features specific to certain scopes.



Figure 4.1  
 EMISSIONS TESTING LAB  
 5634 S. 122<sup>nd</sup> East Ave, Suite F  
 Tulsa, Oklahoma 74146  
 www.airhygiene.com  
 (888) 461-8778







Figure 4.2  
WET CHEMISTRY ASSEMBLY  
5634 S. 122<sup>nd</sup> East Ave, Suite F  
Tulsa, Oklahoma 74146  
www.airhygiene.com  
(888) 461-8778

**APPENDIX A**  
**TEST RESULTS AND CALCULATIONS**

**TABLE A.1:  
EMISSIONS TESTING SCHEDULE**

<b>Unit</b>	<b>Load</b>	<b>Test Type</b>	<b>Run</b>	<b>Date</b>	<b>Start</b>	<b>Stop</b>	<b>Time Sync</b>
3B	Fuel Oil	Stratification Test	1	04/09/11	9:40:29	10:35:59	DAHS
3B	Fuel Oil	Compliance	1	04/09/11	11:00:29	12:12:29	DAHS
3B	Fuel Oil	Compliance	2	04/09/11	12:37:29	14:13:59	DAHS
3B	Fuel Oil	Compliance	3	04/09/11	14:30:29	15:44:59	DAHS
3B	Fuel Oil	Preliminaries	Fuel Oil-V1	04/09/11	9:05:00	9:25:00	DAHS
3B	Fuel Oil	Ammonia	Fuel Oil-1	04/09/11	11:00:00	12:13:00	DAHS
3B	Fuel Oil	Ammonia	Fuel Oil-2	04/09/11	12:37:00	14:15:00	DAHS
3B	Fuel Oil	Ammonia	Fuel Oil-3	04/09/11	14:30:00	15:47:00	DAHS
3B	Fuel Oil	Opacity	1	04/09/11	12:00:00	13:00:00	EST
3B	Fuel Oil	Opacity	2	04/09/11	13:00:00	14:00:00	EST
3B	Fuel Oil	Opacity	3	04/09/11	14:00:00	15:00:00	EST

Note: DAHS Time (EST minus 1hr)

**TABLE A.2**  
**MITSUBISHI, 501G, UNIT 3B FUEL OIL LOAD DATA SUMMARY**

Parameter	Fuel Oil Load, Run - 1	Fuel Oil Load, Run - 2	Fuel Oil Load, Run - 3	Average
Date (mm/dd/yy)	04/09/11	04/09/11	04/09/11	04/09/11
Start Time (hh:mm:ss)	11:00:29	12:37:29	14:30:29	11:00:29
End Time (hh:mm:ss)	12:12:29	14:13:59	15:44:59	15:44:59
Run Duration (min / run)	72	97	75	82
Bar. Pressure (in. Hg)	30.15	30.14	30.11	30.13
Amb. Temp. (°F)	86	90	90	89
Rel. Humidity (%)	43	39	42	41
Spec. Humidity (lb water / lb air)	0.011325	0.011667	0.012595	0.011862
Ammonia Injection Rate (lb/hr)	444.2	438.2	437.0	439.8
Turbine Fuel Flow (gal/hr)	15,691	15,509	15,395	15,532
Total Fuel Flow (SCFH)	2,098	2,073	2,058	2,076
Stack Flow (RM19) (SCFH)	55,245,283	54,658,489	53,929,012	54,610,928
Stack Moisture (% Method 4)	8.4	8.7	8.7	8.6
Heat Input (MMBtu/hr)	2,063.3	2,039.4	2,024.4	2,042.4
Power Output (megawatts)	211.5	208.3	206.3	208.7
NOx (ppmvd)	8.58	9.20	8.24	8.67
NOx (ppm@15%O <sub>2</sub> )	6.97	7.48	6.66	7.03
NOx (ppm@15%O <sub>2</sub> &ISO)	7.08	7.56	6.85	7.17
NOx (lb/hr)	56.62	60.05	53.07	56.58
NOx (ton/year) at 500 hr/year	14.16	15.01	13.27	14.15
NOx (lb/MMBtu)	0.027	0.029	0.026	0.027
CO (ppmvd)	5.79	5.81	6.14	5.91
CO (ppm@15%O <sub>2</sub> )	4.70	4.72	4.96	4.79
CO (ppm@15%O <sub>2</sub> &ISO)	4.78	4.77	5.11	4.89
CO (lb/hr)	23.25	23.06	24.05	23.46
CO (ton/year) at 500 hr/year	5.81	5.77	6.01	5.86
CO (lb/MMBtu)	0.011	0.011	0.012	0.011
VOC (ppmvd)	0.40	0.70	0.33	0.48
VOC (ppm@15%O <sub>2</sub> )	0.32	0.57	0.27	0.39
VOC (ppm@15%O <sub>2</sub> &ISO)	0.33	0.58	0.28	0.39
VOC (lb/hr)	0.92	1.59	0.75	1.09
VOC (ton/year) at 500 hr/year	0.23	0.40	0.19	0.27
VOC (lb/MMBtu)	0.000	0.001	0.000	0.00
Sulfur (wt%)	0.0007	0.0007	0.0007	0.0007
NH <sub>3</sub> (ppmvd)	1.28	0.72	0.75	0.92
NH <sub>3</sub> (ppm@15%O <sub>2</sub> )	1.04	0.59	0.61	0.74
Opacity (%)	0	0	0	0
CO <sub>2</sub> (%)	5.37	5.37	5.36	5.36
O <sub>2</sub> (%)	13.63	13.64	13.60	13.62

**TEST RESULTS**

**NO<sub>x</sub>, CO, VOC, CO<sub>2</sub>, and O<sub>2</sub> Emissions  
Fuel Oil Load**



Florida Power and Light  
 April 9, 2011  
 Mitsubishi, 501G, Unit 3B  
 West County Energy Center

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,691	gal/hr

**Weather Data**

Barometric Pressure	30.15
Relative Humidity	43
Ambient Temperature	86
Specific Humidity	0.011325

**Unit Data**

Unit Load	211.5	megawatts
Heat Input	2,063	MMBtu/hr
Combustor Inlet Pressure	260	psig
Ammonia Injection Rate	444	lb/hr
Meas. Stack Moisture	8.4	%
Stack Exhaust Flow (M19)	55,245,283	SCFH

Data from: Run 1 NH3

Fuel Oil Load, Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmwv)	CO <sub>2</sub> (%)
04/09/11 11:00:29	13650	13.63	9.38	5.81	0.24	5.40
04/09/11 11:00:59	13680	13.63	9.02	6.09	0.21	5.41
04/09/11 11:01:29	13710	13.61	8.76	6.12	0.20	5.41
04/09/11 11:01:59	13740	13.61	8.72	5.89	0.26	5.40
04/09/11 11:02:29	13770	13.61	8.79	5.74	0.20	5.42
04/09/11 11:02:59	13800	13.61	8.90	5.69	0.14	5.43
04/09/11 11:03:29	13830	13.62	8.84	5.62	0.19	5.42
04/09/11 11:03:59	13860	13.62	8.83	5.55	0.17	5.43
04/09/11 11:04:29	13890	13.64	8.80	5.80	0.18	5.43
04/09/11 11:04:59	13920	13.63	8.67	6.28	0.18	5.41
04/09/11 11:05:29	13950	13.64	8.40	6.60	0.23	5.43
04/09/11 11:05:59	13980	13.64	8.45	6.19	0.19	5.45
04/09/11 11:06:29	14010	13.62	7.88	5.48	0.15	5.44
04/09/11 11:06:59	14040	13.62	7.35	5.19	0.09	5.45
04/09/11 11:07:29	14070	13.63	7.27	5.37	0.12	5.45
04/09/11 11:07:59	14100	13.65	7.09	5.83	0.18	5.43
04/09/11 11:08:29	14130	13.64	6.81	6.36	0.15	5.44
04/09/11 11:08:59	14160	13.62	6.65	6.18	0.10	5.46
04/09/11 11:09:29	14190	13.63	6.77	5.57	0.10	5.47
04/09/11 11:09:59	14220	13.63	7.12	5.14	0.06	5.47
04/09/11 11:10:29	14250	13.65	7.23	5.65	0.03	5.47
04/09/11 11:10:59	14280	13.66	6.87	6.40	0.07	5.45
04/09/11 11:11:29	14310	13.65	6.44	6.41	0.07	5.47
04/09/11 11:11:59	14340	13.64	6.35	5.62	0.06	5.49
04/09/11 11:12:29	14370	13.64	6.63	5.16	0.10	5.47
04/09/11 11:12:59	14400	13.66	6.69	5.63	0.10	5.46
04/09/11 11:13:29	14430	13.68	6.42	6.40	0.05	5.46
04/09/11 11:13:59	14460	13.67	6.18	6.41	0.04	5.46
04/09/11 11:14:29	14490	13.67	6.26	6.11	0.04	5.47
04/09/11 11:14:59	14520	13.65	6.24	6.10	0.04	5.50
04/09/11 11:20:59	14880	13.65	7.59	5.14	0.03	5.51
04/09/11 11:21:29	14910	13.67	7.69	5.44	0.04	5.49
04/09/11 11:21:59	14940	13.68	7.61	6.07	0.05	5.48
04/09/11 11:22:29	14970	13.70	7.22	6.67	0.01	5.48
04/09/11 11:22:59	15000	13.68	6.98	6.87	0.03	5.49
04/09/11 11:23:29	15030	13.64	7.15	6.16	0.03	5.50
04/09/11 11:23:59	15060	13.63	7.59	5.12	0.00	5.54
04/09/11 11:24:29	15090	13.63	7.84	4.72	0.01	5.55
04/09/11 11:24:59	15120	13.66	7.85	5.12	0.02	5.51
04/09/11 11:25:29	15150	13.69	7.57	5.99	-0.01	5.50
04/09/11 11:25:59	15180	13.69	7.13	6.98	0.01	5.50
04/09/11 11:26:29	15210	13.67	6.93	6.95	-0.03	5.50
04/09/11 11:26:59	15240	13.66	7.17	6.27	-0.04	5.53
04/09/11 11:27:29	15270	13.65	7.26	5.56	-0.01	5.54
04/09/11 11:27:59	15300	13.65	7.02	5.24	-0.01	5.52
04/09/11 11:28:29	15330	13.67	7.04	5.57	0.00	5.52
04/09/11 11:28:59	15360	13.67	7.38	5.88	0.03	5.53
04/09/11 11:29:29	15390	13.66	7.68	5.87	0.03	5.52
04/09/11 11:29:59	15420	13.66	7.78	5.95	0.03	5.53
04/09/11 11:30:29	15450	13.65	8.09	5.82	0.01	5.55
04/09/11 11:30:59	15480	13.66	8.43	5.34	-0.01	5.54
04/09/11 11:31:29	15510	13.66	8.43	5.51	0.00	5.53
04/09/11 11:31:59	15540	13.68	8.35	5.84	0.02	5.53
04/09/11 11:32:29	15570	13.70	7.85	6.25	0.02	5.51
04/09/11 11:32:59	15600	13.68	7.22	6.19	0.03	5.53
04/09/11 11:33:29	15630	13.66	7.06	5.68	0.06	5.54

**Florida Power and Light  
April 9, 2011  
Mitsubishi, 501G, Unit 3B  
West County Energy Center**

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,691	gal/hr

**Weather Data**

Barometric Pressure	30.15
Relative Humidity	43
Ambient Temperature	86
Specific Humidity	0.011325

**Unit Data**

Unit Load	211.5	megawatts
Heat Input	2,063	MMBtu/hr
Combustor Inlet Pressure	260	psig
Ammonia Injection Rate	444	lb/hr
Meas. Stack Moisture	8.4	%
Stack Exhaust Flow (M19)	55,245,283	SCFH

Data from: Run 1 NH3

**Fuel Oil Load, Run - 1**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NO <sub>x</sub> (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
04/09/11 11:33:59	15660	13.67	7.34	5.24	0.07	5.53
04/09/11 11:34:29	15690	13.69	7.63	5.51	0.05	5.52
04/09/11 11:34:59	15720	13.70	7.52	6.13	0.06	5.52
04/09/11 11:35:29	15750	13.70	7.39	6.32	0.05	5.50
04/09/11 11:38:59	15960	13.71	9.03	5.20	0.08	5.50
04/09/11 11:39:29	15990	13.70	8.80	5.37	0.07	5.51
04/09/11 11:39:59	16020	13.70	8.94	5.69	0.05	5.52
04/09/11 11:40:29	16050	13.70	9.12	5.48	0.05	5.51
04/09/11 11:40:59	16080	13.70	8.22	5.28	0.05	5.54
04/09/11 11:41:29	16110	13.70	7.69	5.21	0.04	5.53
04/09/11 11:41:59	16140	13.72	8.23	5.64	0.10	5.50
04/09/11 11:42:29	16170	13.73	9.02	6.09	0.09	5.51
04/09/11 11:42:59	16200	13.71	9.75	6.11	0.08	5.53
04/09/11 11:43:29	16230	13.68	10.64	5.62	0.05	5.54
04/09/11 11:43:59	16260	13.68	11.92	4.68	0.03	5.55
04/09/11 11:44:29	16290	13.68	13.69	4.90	0.05	5.56
04/09/11 11:44:59	16320	13.71	14.51	5.00	0.08	5.52
04/09/11 11:45:29	16350	13.73	12.39	5.40	0.09	5.51
04/09/11 11:45:59	16380	13.72	10.35	5.79	0.06	5.53
04/09/11 11:46:29	16410	13.71	9.52	5.66	0.08	5.53
04/09/11 11:46:59	16440	13.69	9.69	5.44	0.08	5.54
04/09/11 11:47:29	16470	13.68	10.31	4.86	0.04	5.57
04/09/11 11:47:59	16500	13.67	11.05	4.31	0.04	5.57
04/09/11 11:48:29	16530	13.68	11.35	4.41	0.07	5.56
04/09/11 11:48:59	16560	13.72	10.89	5.12	0.05	5.54
04/09/11 11:49:29	16590	13.75	9.78	6.03	0.04	5.51
04/09/11 11:49:59	16620	13.75	8.54	6.86	0.02	5.50
04/09/11 11:50:29	16650	13.73	7.95	6.59	0.00	5.53
04/09/11 11:50:59	16680	13.72	8.18	5.65	0.00	5.54
04/09/11 11:51:29	16710	13.70	8.95	4.91	0.03	5.54
04/09/11 11:51:59	16740	13.71	9.79	4.72	0.03	5.56
04/09/11 11:52:29	16770	13.73	10.25	4.84	0.06	5.54
04/09/11 11:52:59	16800	13.73	9.99	5.32	0.04	5.53
04/09/11 11:53:29	16830	13.72	9.52	5.28	0.03	5.56
04/09/11 11:57:59	17100	13.70	10.36	5.15	0.10	5.55
04/09/11 11:58:29	17130	13.73	10.49	5.44	0.08	5.55
04/09/11 11:58:59	17160	13.73	10.06	5.75	0.08	5.54
04/09/11 11:59:29	17190	13.70	9.65	5.98	0.06	5.56
04/09/11 11:59:59	17220	13.69	9.44	5.75	0.13	5.59
04/09/11 12:00:29	17250	13.68	9.63	5.34	0.18	5.58
04/09/11 12:00:59	17280	13.68	10.10	4.86	0.15	5.60
04/09/11 12:01:29	17310	13.67	10.48	4.96	0.14	5.61
04/09/11 12:01:59	17340	13.68	9.67	5.09	0.17	5.60
04/09/11 12:02:29	17370	13.68	8.58	5.31	0.14	5.62
04/09/11 12:02:59	17400	13.67	8.04	5.29	0.15	5.63
04/09/11 12:03:29	17430	13.68	8.34	5.20	0.17	5.62
04/09/11 12:03:59	17460	13.70	9.18	5.00	0.12	5.61
04/09/11 12:04:29	17490	13.73	9.07	5.58	0.13	5.59
04/09/11 12:04:59	17520	13.75	8.75	6.65	0.17	5.56
04/09/11 12:05:29	17550	13.73	8.79	6.89	0.14	5.56
04/09/11 12:05:59	17580	13.71	9.03	6.34	0.13	5.59
04/09/11 12:06:29	17610	13.71	10.14	5.74	0.15	5.60
04/09/11 12:06:59	17640	13.71	11.13	5.16	0.10	5.61
04/09/11 12:07:29	17670	13.71	12.25	4.96	0.11	5.61
04/09/11 12:07:59	17700	13.72	12.48	5.61	0.15	5.59
04/09/11 12:08:29	17730	13.74	11.78	6.14	0.13	5.58

Florida Power and Light  
 April 9, 2011  
 Mitsubishi, 501G, Unit 3B  
 West County Energy Center

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,691	gal/hr

**Weather Data**

Barometric Pressure	30.15
Relative Humidity	43
Ambient Temperature	86
Specific Humidity	0.011325

**Unit Data**

Unit Load	211.5	megawatts
Heat Input	2,063	MMBtu/hr
Combustor Inlet Pressure	260	psig
Ammonia Injection Rate	444	lb/hr
Meas. Stack Moisture	8.4	%
Stack Exhaust Flow (M19)	55,245,283	SCFH

Data from: Run 1 NH3

**Fuel Oil Load, Run - 1**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
04/09/11 12:08:59	17760	13.72	10.89	5.72	0.12	5.61
04/09/11 12:09:29	17790	13.69	10.09	4.97	0.13	5.62
04/09/11 12:09:59	17820	13.71	9.69	4.88	0.10	5.60
04/09/11 12:10:29	17850	13.71	8.90	5.24	0.06	5.62
04/09/11 12:10:59	17880	13.73	7.74	5.28	0.10	5.60
04/09/11 12:11:29	17910	13.74	6.82	5.82	0.10	5.58
04/09/11 12:11:59	17940	13.74	6.42	6.54	0.08	5.58
04/09/11 12:12:29	17970	13.72	6.52	6.28	0.10	5.60

**RAW AVERAGE**

O<sub>2</sub> 13.68    NOx 8.63    CO 5.67    VOC 0.08    CO<sub>2</sub> 5.52

	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
	(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)
Serial Number:	INST-N2-0001	INST-N2-0001	INST-CO-0015	INST-TH-0012	INST-C2-0009
Initial Zero	0.03	0.11	-0.08	-0.40	0.00
Final Zero	0.13	0.11	-0.16	-0.24	0.26
Avg. Zero	0.08	0.11	-0.12	-0.32	0.13
Initial UpScale	12.12	12.21	12.06	2.80	8.96
Final UpScale	12.18	12.05	11.89	2.92	9.19
Avg. UpScale	12.15	12.13	11.98	2.86	9.08

**Upscale Cal Gas**

O<sub>2</sub> 12.10    NOx 12.10    CO 12.10    VOC 3.10    CO<sub>2</sub> 8.91

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm/% dry basis)	13.63	8.58	5.79	0.40	5.37
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	6.97	4.70	0.32	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISO)	N/A	7.08	4.78	0.33	N/A
Emission Rate (lb/hr)	N/A	56.62	23.25	0.92	N/A
Emission Rate (tons/year) at 500 hr/yr	N/A	14.16	5.81	0.23	N/A
Emission Rate (lb/MMBtu)	N/A	0.027	0.011	0.000	N/A

Florida Power and Light  
 April 9, 2011  
 Mitsubishi, 501G, Unit 3B  
 West County Energy Center

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,509	gal/hr

**Weather Data**

Barometric Pressure	30.14
Relative Humidity	39
Ambient Temperature	90
Specific Humidity	0.011667

**Unit Data**

Unit Load	208.3	megawatts
Heat Input	2,039	MMBtu/hr
Combustor Inlet Pressure	258	psig
Ammonia Injection Rate	438	lb/hr
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	54,658,489	SCFH

Data from: Run 2 NH3

**Fuel Oil Load, Run - 2**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
04/09/11 12:37:29	19470	13.70	10.00	5.61	0.26	5.66
04/09/11 12:37:59	19500	13.70	10.75	5.37	0.28	5.65
04/09/11 12:38:29	19530	13.70	11.36	5.17	0.30	5.67
04/09/11 12:38:59	19560	13.72	11.63	5.26	0.30	5.66
04/09/11 12:39:29	19590	13.72	11.01	6.01	0.33	5.65
04/09/11 12:39:59	19620	13.70	10.21	6.13	0.35	5.66
04/09/11 12:40:29	19650	13.69	9.88	5.60	0.33	5.69
04/09/11 12:40:59	19680	13.68	10.23	4.95	0.37	5.70
04/09/11 12:41:29	19710	13.69	10.68	5.00	0.35	5.69
04/09/11 12:41:59	19740	13.72	10.39	5.92	0.33	5.68
04/09/11 12:42:29	19770	13.72	9.71	6.39	0.35	5.68
04/09/11 12:42:59	19800	13.70	9.32	6.14	0.34	5.68
04/09/11 12:43:29	19830	13.70	9.55	5.76	0.38	5.70
04/09/11 12:43:59	19860	13.69	9.53	5.40	0.40	5.69
04/09/11 12:44:29	19890	13.70	8.25	5.25	0.38	5.67
04/09/11 12:44:59	19920	13.71	7.12	5.30	0.35	5.68
04/09/11 12:45:29	19950	13.71	6.87	5.64	0.36	5.67
04/09/11 12:45:59	19980	13.72	6.76	5.66	0.33	5.66
04/09/11 12:46:29	20010	13.72	7.15	5.54	0.33	5.67
04/09/11 12:46:59	20040	13.71	7.94	5.47	0.36	5.68
04/09/11 12:47:29	20070	13.72	8.72	5.46	0.35	5.66
04/09/11 12:47:59	20100	13.72	9.48	5.49	0.37	5.67
04/09/11 12:48:29	20130	13.72	9.88	5.73	0.36	5.68
04/09/11 12:48:59	20160	13.73	9.91	5.91	0.35	5.67
04/09/11 12:49:29	20190	13.72	9.28	5.77	0.35	5.69
04/09/11 12:49:59	20220	13.71	8.82	5.31	0.35	5.71
04/09/11 12:50:29	20250	13.71	8.73	5.14	0.34	5.70
04/09/11 12:50:59	20280	13.71	8.59	5.20	0.33	5.70
04/09/11 12:51:29	20310	13.71	8.32	5.19	0.34	5.71
04/09/11 12:51:59	20340	13.71	7.86	5.23	0.32	5.69
04/09/11 12:55:59	20580	13.71	10.68	4.59	0.44	5.74
04/09/11 12:56:29	20610	13.71	10.68	4.75	0.41	5.73
04/09/11 12:56:59	20640	13.73	10.16	5.05	0.44	5.72
04/09/11 12:57:29	20670	13.73	9.63	5.62	0.42	5.72
04/09/11 12:57:59	20700	13.72	12.42	5.88	0.47	5.72
04/09/11 12:58:29	20730	13.73	19.33	5.61	0.49	5.72
04/09/11 12:58:59	20760	13.73	23.88	5.96	0.47	5.74
04/09/11 12:59:29	20790	13.73	22.67	5.86	0.44	5.73
04/09/11 12:59:59	20820	13.73	16.48	5.80	0.46	5.73
04/09/11 13:00:29	20850	13.71	11.57	5.54	0.42	5.76
04/09/11 13:00:59	20880	13.70	9.36	5.17	0.43	5.76
04/09/11 13:01:29	20910	13.69	8.09	5.02	0.46	5.76
04/09/11 13:01:59	20940	13.67	7.42	4.84	0.47	5.78
04/09/11 13:02:29	20970	13.73	7.78	5.25	0.41	5.75
04/09/11 13:02:59	21000	13.75	8.13	6.11	0.39	5.73
04/09/11 13:03:29	21030	13.74	8.43	6.54	0.42	5.73
04/09/11 13:03:59	21060	13.73	8.41	5.97	0.41	5.74
04/09/11 13:04:29	21090	13.69	9.08	5.25	0.42	5.75
04/09/11 13:04:59	21120	13.69	10.33	4.81	0.41	5.77
04/09/11 13:05:29	21150	13.69	11.11	4.81	0.38	5.77
04/09/11 13:05:59	21180	13.70	11.23	4.90	0.37	5.75
04/09/11 13:06:29	21210	13.72	10.48	5.28	0.37	5.75
04/09/11 13:06:59	21240	13.73	9.47	5.70	0.36	5.73
04/09/11 13:07:29	21270	13.73	8.68	6.17	0.40	5.72
04/09/11 13:07:59	21300	13.72	8.19	6.06	0.40	5.75
04/09/11 13:08:29	21330	13.71	8.27	5.71	0.41	5.75

Florida Power and Light  
 April 9, 2011  
 Mitsubishi, 501G, Unit 3B  
 West County Energy Center

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,509	gal/hr

**Weather Data**

Barometric Pressure	30.14
Relative Humidity	39
Ambient Temperature	90
Specific Humidity	0.011667

**Unit Data**

Unit Load	208.3	megawatts
Heat Input	2,039	MMBtu/hr
Combustor Inlet Pressure	258	psig
Ammonia Injection Rate	438	lb/hr
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	54,658,489	SCFH

Data from: Run 2 NH3

Fuel Oil Load, Run - 2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
04/09/11 13:08:59	21360	13.72	8.82	5.62	0.41	5.74
04/09/11 13:09:29	21390	13.73	9.32	5.81	0.40	5.75
04/09/11 13:09:59	21420	13.72	9.53	5.99	0.39	5.75
04/09/11 13:10:29	21450	13.71	9.69	5.62	0.37	5.75
04/09/11 13:17:29	21870	13.67	8.60	5.23	0.54	5.85
04/09/11 13:17:59	21900	13.68	8.75	5.27	0.52	5.86
04/09/11 13:18:29	21930	13.69	8.63	5.73	0.57	5.86
04/09/11 13:18:59	21960	13.68	8.36	6.27	0.59	5.84
04/09/11 13:19:29	21990	13.68	8.09	6.21	0.57	5.86
04/09/11 13:19:59	22020	13.68	7.72	5.85	0.59	5.86
04/09/11 13:20:29	22050	13.68	6.63	5.79	0.60	5.84
04/09/11 13:20:59	22080	13.65	5.87	5.75	0.55	5.87
04/09/11 13:21:29	22110	13.65	6.11	5.49	0.52	5.86
04/09/11 13:21:59	22140	13.67	6.70	5.53	0.54	5.83
04/09/11 13:22:29	22170	13.66	7.63	5.66	0.52	5.84
04/09/11 13:22:59	22200	13.67	8.46	5.79	0.53	5.83
04/09/11 13:23:29	22230	13.68	8.91	6.08	0.56	5.80
04/09/11 13:23:59	22260	13.68	9.19	6.08	0.54	5.82
04/09/11 13:24:29	22290	13.66	9.22	5.98	0.53	5.84
04/09/11 13:24:59	22320	13.65	9.03	5.65	0.59	5.84
04/09/11 13:25:29	22350	13.69	8.58	5.48	0.50	5.83
04/09/11 13:25:59	22380	13.68	7.98	6.34	0.53	5.83
04/09/11 13:26:29	22410	13.65	7.10	6.71	0.54	5.83
04/09/11 13:26:59	22440	13.62	6.70	6.58	0.50	5.86
04/09/11 13:27:29	22470	13.65	6.64	6.42	0.50	5.86
04/09/11 13:27:59	22500	13.65	6.91	6.21	0.50	5.84
04/09/11 13:28:29	22530	13.66	7.27	6.44	0.50	5.85
04/09/11 13:28:59	22560	13.66	7.90	6.29	0.54	5.86
04/09/11 13:29:29	22590	13.69	8.47	6.51	0.54	5.84
04/09/11 13:29:59	22620	13.69	8.46	6.85	0.52	5.85
04/09/11 13:30:29	22650	13.66	8.36	6.54	0.53	5.87
04/09/11 13:30:59	22680	13.64	8.43	5.69	0.52	5.88
04/09/11 13:31:29	22710	13.65	8.44	5.11	0.48	5.89
04/09/11 13:31:59	22740	13.67	7.36	5.47	0.52	5.88
04/09/11 13:59:29	24390	13.66	9.42	6.04	0.91	5.74
04/09/11 13:59:59	24420	13.65	8.40	5.78	0.90	5.76
04/09/11 14:00:29	24450	13.63	8.24	5.17	0.86	5.77
04/09/11 14:00:59	24480	13.64	8.52	5.03	0.84	5.79
04/09/11 14:01:29	24510	13.64	8.69	5.25	0.84	5.80
04/09/11 14:01:59	24540	13.66	8.76	5.92	0.82	5.78
04/09/11 14:02:29	24570	13.67	9.18	6.09	0.78	5.80
04/09/11 14:02:59	24600	13.65	10.29	5.95	0.80	5.81
04/09/11 14:03:29	24630	13.64	10.90	5.59	0.77	5.82
04/09/11 14:03:59	24660	13.64	11.71	5.41	0.74	5.85
04/09/11 14:04:29	24690	13.65	12.65	5.58	0.75	5.82
04/09/11 14:04:59	24720	13.67	12.57	6.03	0.73	5.81
04/09/11 14:05:29	24750	13.66	11.58	6.29	0.71	5.83
04/09/11 14:05:59	24780	13.64	10.21	5.67	0.71	5.84
04/09/11 14:06:29	24810	13.63	8.81	5.10	0.67	5.84
04/09/11 14:06:59	24840	13.65	8.49	5.00	0.64	5.85
04/09/11 14:07:29	24870	13.67	7.89	5.73	0.66	5.84
04/09/11 14:07:59	24900	13.67	7.16	6.14	0.64	5.84
04/09/11 14:08:29	24930	13.65	6.67	6.08	0.67	5.87
04/09/11 14:08:59	24960	13.64	6.68	5.52	0.69	5.87
04/09/11 14:09:29	24990	13.63	6.96	4.97	0.67	5.89
04/09/11 14:09:59	25020	13.64	7.38	4.96	0.65	5.89

**Florida Power and Light  
April 9, 2011  
Mitsubishi, 501G, Unit 3B  
West County Energy Center**

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,509	gal/hr

**Weather Data**

Barometric Pressure	30.14
Relative Humidity	39
Ambient Temperature	90
Specific Humidity	0.011667

**Unit Data**

Unit Load	208.3	megawatts
Heat Input	2,039	MMBtu/hr
Combustor Inlet Pressure	258	psig
Ammonia Injection Rate	438	lb/hr
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	54,658,489	SCFH

Data from: Run 2 NH3

**Fuel Oil Load, Run - 2**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
04/09/11 14:10:29	25050	13.65	7.53	5.19	0.66	5.88
04/09/11 14:10:59	25080	13.66	7.48	5.47	0.66	5.88
04/09/11 14:11:29	25110	13.66	6.97	5.86	0.61	5.89
04/09/11 14:11:59	25140	13.66	6.58	6.01	0.62	5.88
04/09/11 14:12:29	25170	13.67	6.57	5.81	0.62	5.89
04/09/11 14:12:59	25200	13.66	6.84	5.48	0.60	5.91
04/09/11 14:13:29	25230	13.64	7.24	5.14	0.61	5.92
04/09/11 14:13:59	25260	13.63	7.66	4.83	0.59	5.93
<b>RAW AVERAGE</b>		<b>13.69</b>	<b>9.18</b>	<b>5.64</b>	<b>0.50</b>	<b>5.78</b>

	Serial Number:	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
		(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)
Bias	INST-N2-0001	0.13	0.11	-0.16	-0.24	0.26
	INST-N2-0001	0.06	0.09	-0.06	-0.12	0.52
	INST-CO-0015	0.10	0.10	-0.11	-0.18	0.39
	INST-TH-0012	12.18	12.05	11.89	2.92	9.19
	INST-C2-0009	12.12	12.04	11.88	3.18	9.48
		12.15	12.05	11.89	3.05	9.34
	Upscale Cal Gas	12.10	12.10	12.10	3.10	8.91

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm/% dry basis)	13.64	9.20	5.81	0.70	5.37
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	7.48	4.72	0.57	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISO)	N/A	7.56	4.77	0.58	N/A
Emission Rate (lb/hr)	N/A	60.05	23.06	1.59	N/A
Emission Rate (tons/year) at 500 hr/yr	N/A	15.01	5.77	0.40	N/A
Emission Rate (lb/MMBtu)	N/A	0.029	0.011	0.001	N/A

Florida Power and Light  
 April 9, 2011  
 Mitsubishi, 501G, Unit 3B  
 West County Energy Center

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,395	gal/hr

**Weather Data**

Barometric Pressure	30.11
Relative Humidity	42
Ambient Temperature	90
Specific Humidity	0.012585

**Unit Data**

Unit Load	206.3	megawatts
Heat Input	2,024	MMBtu/hr
Combustor Inlet Pressure	256	psig
Ammonia Injection Rate	437	lb/hr
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	53,929,012	SCFH

Data from: Run 3 NH3

**Fuel Oil Load, Run - 3**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
04/09/11 14:30:29	26250	13.63	7.69	5.62	0.33	5.84
04/09/11 14:30:59	26280	13.64	7.94	6.16	0.33	5.87
04/09/11 14:31:29	26310	13.63	8.66	6.16	0.30	5.87
04/09/11 14:31:59	26340	13.63	8.79	5.80	0.29	5.88
04/09/11 14:32:29	26370	13.62	8.77	5.65	0.32	5.91
04/09/11 14:32:59	26400	13.63	8.76	5.79	0.28	5.90
04/09/11 14:33:29	26430	13.62	8.55	5.79	0.28	5.91
04/09/11 14:33:59	26460	13.62	8.84	5.65	0.27	5.92
04/09/11 14:34:29	26490	13.64	9.30	5.59	0.24	5.90
04/09/11 14:34:59	26520	13.63	9.70	5.78	0.28	5.90
04/09/11 14:35:29	26550	13.63	9.85	5.89	0.27	5.92
04/09/11 14:35:59	26580	13.64	9.82	5.93	0.28	5.90
04/09/11 14:36:29	26610	13.65	8.58	5.99	0.31	5.91
04/09/11 14:36:59	26640	13.64	7.59	5.97	0.29	5.92
04/09/11 14:37:29	26670	13.64	6.71	5.87	0.27	5.91
04/09/11 14:37:59	26700	13.63	6.28	5.57	0.24	5.93
04/09/11 14:38:29	26730	13.62	6.26	5.28	0.22	5.94
04/09/11 14:38:59	26760	13.63	6.55	5.32	0.23	5.92
04/09/11 14:39:29	26790	13.62	6.79	5.36	0.24	5.95
04/09/11 14:39:59	26820	13.62	6.48	5.45	0.23	5.95
04/09/11 14:40:29	26850	13.63	6.31	5.43	0.23	5.95
04/09/11 14:40:59	26880	13.63	6.33	5.44	0.26	5.97
04/09/11 14:41:29	26910	13.63	6.42	5.50	0.23	5.96
04/09/11 14:41:59	26940	13.63	6.23	5.44	0.22	5.96
04/09/11 14:42:29	26970	13.63	5.90	5.31	0.23	5.97
04/09/11 14:42:59	27000	13.63	5.93	5.36	0.22	5.95
04/09/11 14:43:29	27030	13.63	6.34	5.48	0.22	5.95
04/09/11 14:43:59	27060	13.62	6.99	5.39	0.22	5.97
04/09/11 14:44:29	27090	13.64	7.78	5.36	0.20	5.96
04/09/11 14:44:59	27120	13.65	8.32	5.74	0.19	5.94
04/09/11 14:49:29	27390	13.62	7.43	5.24	0.23	5.91
04/09/11 14:49:59	27420	13.62	8.02	5.14	0.28	5.91
04/09/11 14:50:29	27450	13.63	8.08	5.28	0.26	5.89
04/09/11 14:50:59	27480	13.64	8.02	5.66	0.24	5.89
04/09/11 14:51:29	27510	13.64	7.69	5.78	0.27	5.88
04/09/11 14:51:59	27540	13.63	7.37	5.93	0.24	5.86
04/09/11 14:52:29	27570	13.61	7.37	5.91	0.21	5.89
04/09/11 14:52:59	27600	13.58	7.53	5.29	0.22	5.91
04/09/11 14:53:29	27630	13.62	7.47	5.39	0.19	5.87
04/09/11 14:53:59	27660	13.64	6.95	6.38	0.17	5.86
04/09/11 14:54:29	27690	13.65	6.67	6.77	0.19	5.85
04/09/11 14:54:59	27720	13.62	6.32	6.28	0.13	5.88
04/09/11 14:55:29	27750	13.60	6.11	5.38	0.14	5.89
04/09/11 14:55:59	27780	13.60	6.12	5.28	0.18	5.88
04/09/11 14:56:29	27810	13.58	6.27	5.53	0.15	5.90
04/09/11 14:56:59	27840	13.57	6.48	5.42	0.15	5.92
04/09/11 14:57:29	27870	13.63	6.40	6.18	0.15	5.88
04/09/11 14:57:59	27900	13.62	6.30	6.92	0.14	5.89
04/09/11 14:58:29	27930	13.59	6.87	6.51	0.11	5.90
04/09/11 14:58:59	27960	13.58	7.91	5.91	0.12	5.92
04/09/11 14:59:29	27990	13.56	8.62	5.86	0.11	5.92
04/09/11 14:59:59	28020	13.58	8.82	5.91	0.10	5.89
04/09/11 15:00:29	28050	13.59	8.70	6.01	0.09	5.93
04/09/11 15:00:59	28080	13.58	7.78	5.77	0.08	5.91
04/09/11 15:01:29	28110	13.56	7.22	5.63	0.08	5.92
04/09/11 15:01:59	28140	13.55	6.88	5.42	0.06	5.94

Florida Power and Light  
 April 9, 2011  
 Mitsubishi, 501G, Unit 3B  
 West County Energy Center

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,395	gal/hr

**Weather Data**

Barometric Pressure	30.11
Relative Humidity	42
Ambient Temperature	90
Specific Humidity	0.012595

**Unit Data**

Unit Load	206.3	megawatts
Heat Input	2,024	MMBtu/hr
Combustor Inlet Pressure	256	psig
Ammonia Injection Rate	437	lb/hr
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	53,929,012	SCFH

Data from: Run 3 NH3

**Fuel Oil Load, Run - 3**

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
04/09/11 15:02:29	28170	13.57	6.52	5.47	0.04	5.91
04/09/11 15:02:59	28200	13.60	6.83	5.75	0.05	5.91
04/09/11 15:03:29	28230	13.61	7.15	6.32	0.05	5.89
04/09/11 15:03:59	28260	13.58	7.55	6.43	0.02	5.91
04/09/11 15:11:59	28740	13.57	8.57	5.22	0.02	5.95
04/09/11 15:12:29	28770	13.55	8.90	5.44	0.02	5.93
04/09/11 15:12:59	28800	13.53	9.25	5.21	0.04	5.96
04/09/11 15:13:29	28830	13.53	9.16	5.22	0.03	5.96
04/09/11 15:13:59	28860	13.54	8.99	5.75	0.01	5.95
04/09/11 15:14:29	28890	13.56	9.12	6.02	0.01	5.95
04/09/11 15:14:59	28920	13.56	9.60	6.47	0.00	5.93
04/09/11 15:15:29	28950	13.54	10.36	6.52	0.00	5.96
04/09/11 15:15:59	28980	13.54	10.88	5.96	0.01	5.97
04/09/11 15:16:29	29010	13.56	10.08	6.02	0.04	5.94
04/09/11 15:16:59	29040	13.55	9.23	6.11	0.01	5.95
04/09/11 15:17:29	29070	13.49	8.99	5.72	-0.01	5.97
04/09/11 15:17:59	29100	13.51	8.88	5.72	-0.01	5.98
04/09/11 15:18:29	29130	13.50	8.77	6.01	-0.03	5.97
04/09/11 15:18:59	29160	13.49	8.71	5.94	-0.03	5.99
04/09/11 15:19:29	29190	13.50	8.93	6.11	-0.03	6.00
04/09/11 15:19:59	29220	13.49	9.28	6.22	-0.03	6.00
04/09/11 15:20:29	29250	13.54	9.75	6.17	-0.01	5.99
04/09/11 15:20:59	29280	13.57	10.06	6.99	0.00	5.95
04/09/11 15:21:29	29310	13.55	9.84	7.69	-0.01	5.97
04/09/11 15:21:59	29340	13.54	9.79	7.11	-0.02	5.98
04/09/11 15:22:29	29370	13.62	9.84	6.57	0.01	6.00
04/09/11 15:22:59	29400	13.61	9.37	6.39	0.00	6.02
04/09/11 15:23:29	29430	13.50	8.91	5.64	0.00	5.99
04/09/11 15:23:59	29460	13.52	8.59	5.58	0.01	5.99
04/09/11 15:24:29	29490	13.55	8.40	6.13	0.01	5.99
04/09/11 15:24:59	29520	13.56	8.54	6.71	0.01	5.97
04/09/11 15:25:29	29550	13.51	8.51	6.34	0.01	6.03
04/09/11 15:25:59	29580	13.49	7.96	5.78	0.01	6.05
04/09/11 15:26:29	29610	13.50	7.18	5.71	0.01	6.06
04/09/11 15:30:29	29850	13.49	8.91	6.81	-0.03	6.07
04/09/11 15:30:59	29880	13.51	9.64	7.05	-0.02	6.06
04/09/11 15:31:29	29910	13.51	9.77	7.48	-0.03	6.05
04/09/11 15:31:59	29940	13.53	10.46	7.41	-0.04	6.05
04/09/11 15:32:29	29970	13.52	10.89	7.28	0.00	6.05
04/09/11 15:32:59	30000	13.55	11.08	6.95	0.00	6.04
04/09/11 15:33:29	30030	13.57	11.48	7.40	0.00	6.03
04/09/11 15:33:59	30060	13.55	11.57	7.21	0.00	6.03
04/09/11 15:34:29	30090	13.55	11.58	6.37	0.00	6.06
04/09/11 15:34:59	30120	13.55	11.53	6.05	-0.04	6.05
04/09/11 15:35:29	30150	13.57	11.01	5.95	-0.06	6.02
04/09/11 15:35:59	30180	13.58	10.23	6.15	-0.06	6.03
04/09/11 15:36:29	30210	13.59	9.17	6.27	-0.04	6.01
04/09/11 15:36:59	30240	13.57	7.62	6.12	-0.03	6.03
04/09/11 15:37:29	30270	13.57	7.07	5.89	-0.03	6.04
04/09/11 15:37:59	30300	13.57	6.83	5.62	-0.06	6.04
04/09/11 15:38:29	30330	13.55	6.87	5.55	-0.08	6.09
04/09/11 15:38:59	30360	13.55	6.25	5.39	-0.11	6.10
04/09/11 15:39:29	30390	13.53	5.51	5.51	-0.10	6.12
04/09/11 15:39:59	30420	13.53	5.11	5.42	-0.08	6.16
04/09/11 15:40:29	30450	13.58	5.06	6.39	-0.06	6.10
04/09/11 15:40:59	30480	13.57	5.47	7.66	-0.04	6.13



Florida Power and Light  
 April 9, 2011  
 Mitsubishi, 501G, Unit 3B  
 West County Energy Center

**Fuel Data**

Fuel Fd factor	9,308	SCF exh/MMBtu
Fuel Heating Value (LHV)	983,660	Btu/SCF fuel
Turbine Fuel Flow	15,395	gal/hr

**Weather Data**

Barometric Pressure	30.11
Relative Humidity	42
Ambient Temperature	90
Specific Humidity	0.012595

**Unit Data**

Unit Load	206.3	megawatts
Heat Input	2,024	MMBtu/hr
Combustor Inlet Pressure	256	psig
Ammonia Injection Rate	437	lb/hr
Meas. Stack Moisture	8.7	%
Stack Exhaust Flow (M19)	53,929,012	SCFH

Data from: Run 3 NH3

Fuel Oil Load, Run - 3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O <sub>2</sub> (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	CO <sub>2</sub> (%)
04/09/11 15:41:29	30510	13.56	6.45	7.27	-0.01	6.16
04/09/11 15:41:59	30540	13.61	7.59	6.94	-0.02	6.12
04/09/11 15:42:29	30570	13.62	8.31	7.12	-0.04	6.13
04/09/11 15:42:59	30600	13.60	9.55	6.94	-0.06	6.13
04/09/11 15:43:29	30630	13.57	11.06	6.00	-0.06	6.12
04/09/11 15:43:59	30660	13.55	12.32	5.20	-0.09	6.14
04/09/11 15:44:29	30690	13.58	11.84	5.15	-0.09	6.10
04/09/11 15:44:59	30720	13.54	9.29	5.22	-0.07	6.10

**RAW AVERAGE**

O<sub>2</sub> 13.58 NOx 8.25 CO 5.98 VOC 0.09 CO<sub>2</sub> 5.97

Serial Number:	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
	(%)	(ppmvd)	(ppmvd)	(ppmvw)	(%)
INST-N2-0001	0.06	0.09	-0.06	-0.12	0.52
Initial Zero	0.02	0.09	-0.13	-0.41	0.63
Final Zero	0.04	0.09	-0.10	-0.27	0.58
Avg. Zero					
Initial UpScale	12.12	12.04	11.88	3.18	9.48
Final UpScale	12.06	12.10	11.90	3.05	9.62
Avg. UpScale	12.09	12.07	11.89	3.12	9.55

Bias

**Upscale Cal Gas**

O<sub>2</sub> 12.10 NOx 12.10 CO 12.10 VOC 3.10 CO<sub>2</sub> 8.91

EMISSIONS DATA	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>
Corrected Raw Average (ppm/% dry basis)	13.60	8.24	6.14	0.33	5.36
Concentration (ppm@ 15%O <sub>2</sub> )	N/A	6.66	4.96	0.27	N/A
Concentration (ppm@ 15%O <sub>2</sub> & ISO)	N/A	6.85	5.11	0.28	N/A
Emission Rate (lb/hr)	N/A	53.07	24.05	0.75	N/A
Emission Rate (tons/year) at 500 hr/yr	N/A	13.27	6.01	0.19	N/A
Emission Rate (lb/MMBtu)	N/A	0.026	0.012	0.000	N/A

**TEST RESULTS**

**NH<sub>3</sub> Emissions  
Fuel Oil Load**

**CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE**

Source Information	
<b>Plant Name</b>	West County Energy Center
<b>Sampling Location</b>	Unit 3B
<b>Fuel Type</b>	Oil, Distillate

Test Information			
<b>Project #</b>		bv-10-westcounty.fl-comp#2	
<b>Operator</b>		MV	
<b>Date for Preliminary Run</b>	(mm/dd/yy)	04/09/11	
<b>Standard Temperature</b>		68	°F
<b>Standard Pressure</b>		29.92	in Hg
<b>Required Sample Vol.</b>	indust. spec.	35	scf
<b>Run Duration</b>	chk Subpart	60	minutes
<b>Unit Number</b>		3B	
<b>Base Run Number</b>		Fuel Oil	
<b>Number of Ports Available</b>		4	
<b>Number of Ports Used</b>		4	
<b>Port Inside Diameter</b>		6.00	in
<b>Stack Shape</b>		Circular	

Test Equipment Information					
Run		1	2	3	
<b>Test Date</b>	(mm/dd/yy)	04/09/11	04/09/11	04/09/11	
<b>Load</b>	% or w/DB	Fuel Oil	Fuel Oil	Fuel Oil	
<b>Fuel F-Factor</b>		9308.23	9308.23	9308.23	dscf/MMBtu
<b>Meter Box Number</b>	from ACS	SAMP-CP-0010	SAMP-CP-0010	SAMP-CP-0010	
<b>Meter Calibration Factor</b>	(Y)	0.991	0.991	0.991	
<b>Orifice Meter Coefficient</b>	( $\Delta H_{\text{or}}$ )	1.745	1.745	1.745	in H <sub>2</sub> O
<b>Pitot Identification</b>	from ACS	SAMP-HP-0001	SAMP-HP-0001	SAMP-HP-0001	
<b>Pitot Tube Coefficient</b>	(C <sub>p</sub> )	0.840	0.840	0.840	
<b>Nozzle Number</b>	from ACS	I8	I8	I8	
<b>Nozzle Diameter</b>	(D <sub>n</sub> )	0.230	0.230	0.230	in
<b>Probe Number</b>	from ACS	SAMP-HP-0001	SAMP-HP-0001	SAMP-HP-0001	
<b>Probe Length</b>		120.0	120.0	120.0	in
<b>(SS, Glass ....) Liner Material</b>	from list	inconel	inconel	inconel	
<b>Sample Case / Oven Number</b>	from ACS	SAMP-BH-0025	SAMP-BH-0025	SAMP-BH-0025	
<b>Impinger Case Number</b>	from ACS	SAMP-BC-0021	SAMP-BC-0020	SAMP-BC-0021	

Testing Company Information	
<b>Company Name</b>	Air Hygiene International, Inc. (Tulsa, Oklahoma)
<b>Address</b>	5634 S. 122nd East Avenue, Suite F
<b>City, State Zip</b>	Tulsa, Oklahoma 74146
<b>Project Manager</b>	Jake Fahlenkamp
<b>Phone Number</b>	(918) 307-8865
<b>Fax Number</b>	(918) 307-9131

**METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	04/09/11
<b>Sampling Location</b>	Unit 3B	<b>Stack Type</b>	Circular
<b>Operator</b>	MV	<b>Ports Available</b>	4
<b>Project #</b>	bv-10-westcounty.fl-comp#2	<b>Ports Used</b>	4
<b>Stack Size</b>	Large (>24 inch diameter)	<b>Port ID (inches)</b>	6.00


Circular Stack or Duct Diameter			
<b>Distance to Far Wall of Stack</b>	(L <sub>fw</sub> )	282.38	in
<b>Distance to Near Wall of Stack</b>	(L <sub>nw</sub> )	19.00	in
<b>Diameter of Stack</b>	(D)	263.38	in
<b>Area of Stack</b>	(A <sub>s</sub> )	378.35	ft <sup>2</sup>

Distance from Port to Disturbances			
<b>Distance Upstream</b>	(A)	144.00	in
<b>Diameters Upstream</b>	(A <sub>D</sub> )	0.55	diameters
<b>Distance Downstream</b>	(B)	531.75	in
<b>Diameters Downstream</b>	(B <sub>D</sub> )	2.02	diameters

Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of <sup>1</sup> Traverse Points	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 <sup>2</sup>	8 or 12 <sup>2</sup>
<b>Upstream Spec</b>		24	16
<b>Downstream Spec</b>		24	16
<b>Traverse Pts Required</b>		24	16

<sup>1</sup> Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.

<sup>2</sup> 8 for Circular Stacks 12 to 24 inches  
12 for Circular Stacks over 24 inches



Number of Traverse Points Used			
4	Ports by	6	Across
24	Pts Used	24	Required

Method 1 Tra  12 Point PM Tra  Velocity

Location of Traverse Points in Circular Stacks										
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point)									
Number	Number of Traverse Points Across the Stack									
	2	4	6	8	10	12	14	16	18	
1	.146	.067	.044	.032	.026	.021	.018	.016	.014	
2	.854	.250	.146	.105	.082	.067	.057	.049	.044	
3		.750	.296	.194	.146	.118	.099	.085	.075	
4		.933	.704	.323	.226	.177	.146	.125	.109	
5			.854	.677	.342	.250	.201	.169	.146	
6			.956	.806	.658	.356	.269	.220	.188	
7				.895	.774	.644	.366	.283	.236	
8				.968	.854	.750	.634	.375	.296	
9					.918	.823	.731	.625	.382	
10					.974	.882	.799	.717	.618	
11						.933	.854	.780	.704	
12							.979	.901	.831	.764

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.021	5 4/8	24 4/8
2	0.067	17 5/8	36 5/8
3	0.118	31 1/8	50 1/8
4	0.177	46 5/8	65 5/8
5	0.250	65 7/8	84 7/8
6	0.356	93 6/8	112 6/8
7			
8			
9			



**METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	04/09/11		
<b>Sampling Location</b>	Unit 3B	<b>Operator</b>	MV		
<b>Project #</b>	bv-10-westcounty.fl-comp#2	<b># of Ports Used</b>	1 (gas probe)		
<b>Fuel Type</b>	Oil, Distillate	<b>Min. Fuel Factor</b>	1.260	<b>Max. Fuel Factor</b>	1.413

**Gas Analysis Data**

<b>Run Number</b>	<b>Fuel Oil-1</b>		<b>Run Start Time</b>		11:00	<b>Run Stop Time</b>		12:13
<b>Sample Analysis Time</b>	<b>CO<sub>2</sub> Conc.</b>	<b>O<sub>2</sub> Conc.</b>	<b>CO Conc.</b>	<b>N<sub>2</sub> Conc.</b>	<b>Dry Molecular Weight</b>	<b>Calculated Fuel Factor</b>	<b>Excess Air</b>	<b>Fuel Factor in Range</b>
	(%CO <sub>2</sub> )	(%O <sub>2</sub> )	(ppmCO)	(%N <sub>2</sub> )	(M <sub>d</sub> )	(F <sub>o</sub> ) <sub>avg</sub>	(%EA) <sub>avg</sub>	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:13	5.4	13.6	5.8	81.0	29.40	1.354	175.8	YES

**Gas Analysis Data**

<b>Run Number</b>	<b>Fuel Oil-2</b>		<b>Run Start Time</b>		12:37	<b>Run Stop Time</b>		14:15
<b>Sample Analysis Time</b>	<b>CO<sub>2</sub> Conc.</b>	<b>O<sub>2</sub> Conc.</b>	<b>CO Conc.</b>	<b>N<sub>2</sub> Conc.</b>	<b>Dry Molecular Weight</b>	<b>Calculated Fuel Factor</b>	<b>Excess Air</b>	<b>Fuel Factor in Range</b>
	(%CO <sub>2</sub> )	(%O <sub>2</sub> )	(ppmCO)	(%N <sub>2</sub> )	(M <sub>d</sub> )	(F <sub>o</sub> ) <sub>avg</sub>	(%EA) <sub>avg</sub>	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:38	5.4	13.6	5.8	81.0	29.40	1.352	176.2	YES

**Gas Analysis Data**

<b>Run Number</b>	<b>Fuel Oil-3</b>		<b>Run Start Time</b>		14:30	<b>Run Stop Time</b>		15:47
<b>Sample Analysis Time</b>	<b>CO<sub>2</sub> Conc.</b>	<b>O<sub>2</sub> Conc.</b>	<b>CO Conc.</b>	<b>N<sub>2</sub> Conc.</b>	<b>Dry Molecular Weight</b>	<b>Calculated Fuel Factor</b>	<b>Excess Air</b>	<b>Fuel Factor in Range</b>
	(%CO <sub>2</sub> )	(%O <sub>2</sub> )	(ppmCO)	(%N <sub>2</sub> )	(M <sub>d</sub> )	(F <sub>o</sub> ) <sub>avg</sub>	(%EA) <sub>avg</sub>	
hh:mm	%	%	ppm	%	lb/lb-mole		%	
01:17	5.4	13.6	6.1	81.0	29.40	1.362	174.5	YES

**METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	04/09/11
<b>Sampling Location</b>	Unit 3B	<b>Operator</b>	MV
<b>Project #</b>	bv-10-westcounty.fl-comp#2	<b>Ports Used</b>	4

Moisture Content Data								
Run Number	Fuel Oil-1		Run Start Time			Run Stop Time		
			11:00			12:13		
<b>Meter Box Number</b>	SAMP-CP-0010		<b>Meter Cal Factor</b>			(Y)	0.991	
<b>Total Meter Volume</b>	(V <sub>m</sub> )	42.960	dcf	<b>Barometric Pressure</b>			(P <sub>b</sub> )	30.15 in Hg
<b>Average Stack Temp</b>	(t <sub>s</sub> ) <sub>avg</sub>	237	°F	<b>Stack Static Pressure</b>			(P <sub>static</sub> )	0.76 in H <sub>2</sub> O
<b>Average Meter Temp</b>	(t <sub>m</sub> ) <sub>avg</sub>	83	°F	<b>Avg Orifice Pressure</b>			(ΔH) <sub>avg</sub>	1.68 in H <sub>2</sub> O
	<b>Impinger 1</b>	<b>Impinger 2</b>	<b>Impinger 3</b>	<b>Impinger 4</b>	<b>Impinger 5</b>	<b>Impinger 6</b>	<b>Impinger 7</b>	<b>Impinger 8</b>
	(g)	(g)	(g)	(g)				
<b>Contents</b>		H <sub>2</sub> SO <sub>4</sub>	H <sub>2</sub> SO <sub>4</sub>	-	Sil Gel			
<b>Final Value</b>	(V <sub>f</sub> ),(W <sub>f</sub> )	801.40	792.70	617.50	856.20			
<b>Initial Value</b>	(V <sub>i</sub> ),(W <sub>i</sub> )	751.60	775.90	612.80	845.60			
<b>Net Value</b>	(V <sub>n</sub> ),(W <sub>n</sub> )	49.8	16.8	4.7	10.6			
Results								
<b>Total Weight</b>	(W <sub>t</sub> )	81.90	g	<b>Water Vol Weighed</b>			(V <sub>wsg(std)</sub> )	3.862 scf
<b>Std Meter Volume</b>	(V <sub>m(std)</sub> )	41.876	dscf	<b>Sat. Moisture Content</b>			(B <sub>ws(svp)</sub> )	100.00 %
<b>Calc Moisture Content</b>	(B <sub>ws(calc)</sub> )	8.44	%	<b>Final Moisture Content</b>			(B <sub>ws</sub> )	8.44 %

Moisture Content Data								
Run Number	Fuel Oil-2		Run Start Time			Run Stop Time		
			12:37			14:15		
<b>Meter Box Number</b>	SAMP-CP-0010		<b>Meter Cal Factor</b>			(Y)	0.991	
<b>Total Meter Volume</b>	(V <sub>m</sub> )	44.960	dcf	<b>Barometric Pressure</b>			(P <sub>b</sub> )	30.14 in Hg
<b>Average Stack Temp</b>	(t <sub>s</sub> ) <sub>avg</sub>	241	°F	<b>Stack Static Pressure</b>			(P <sub>static</sub> )	0.74 in H <sub>2</sub> O
<b>Average Meter Temp</b>	(t <sub>m</sub> ) <sub>avg</sub>	84	°F	<b>Avg Orifice Pressure</b>			(ΔH) <sub>avg</sub>	1.74 in H <sub>2</sub> O
	<b>Impinger 1</b>	<b>Impinger 2</b>	<b>Impinger 3</b>	<b>Impinger 4</b>	<b>Impinger 5</b>	<b>Impinger 6</b>	<b>Impinger 7</b>	<b>Impinger 8</b>
	(g)	(g)	(g)	(g)				
<b>Contents</b>		H <sub>2</sub> SO <sub>4</sub>	H <sub>2</sub> SO <sub>4</sub>	-	Sil Gel			
<b>Final Value</b>	(V <sub>f</sub> ),(W <sub>f</sub> )	808.40	757.80	610.50	814.90			
<b>Initial Value</b>	(V <sub>i</sub> ),(W <sub>i</sub> )	746.20	743.80	606.30	806.80			
<b>Net Value</b>	(V <sub>n</sub> ),(W <sub>n</sub> )	62.2	14.0	4.2	8.1			
Results								
<b>Total Weight</b>	(W <sub>t</sub> )	88.50	g	<b>Water Vol Weighed</b>			(V <sub>wsg(std)</sub> )	4.173 scf
<b>Std Meter Volume</b>	(V <sub>m(std)</sub> )	43.720	dscf	<b>Sat. Moisture Content</b>			(B <sub>ws(svp)</sub> )	100.00 %
<b>Calc Moisture Content</b>	(B <sub>ws(calc)</sub> )	8.71	%	<b>Final Moisture Content</b>			(B <sub>ws</sub> )	8.71 %

Moisture Content Data								
Run Number	Fuel Oil-3		Run Start Time			Run Stop Time		
			14:30			15:47		
<b>Meter Box Number</b>	SAMP-CP-0010		<b>Meter Cal Factor</b>			(Y)	0.991	
<b>Total Meter Volume</b>	(V <sub>m</sub> )	44.920	dcf	<b>Barometric Pressure</b>			(P <sub>b</sub> )	30.11 in Hg
<b>Average Stack Temp</b>	(t <sub>s</sub> ) <sub>avg</sub>	238	°F	<b>Stack Static Pressure</b>			(P <sub>static</sub> )	0.75 in H <sub>2</sub> O
<b>Average Meter Temp</b>	(t <sub>m</sub> ) <sub>avg</sub>	86	°F	<b>Avg Orifice Pressure</b>			(ΔH) <sub>avg</sub>	1.81 in H <sub>2</sub> O
	<b>Impinger 1</b>	<b>Impinger 2</b>	<b>Impinger 3</b>	<b>Impinger 4</b>	<b>Impinger 5</b>	<b>Impinger 6</b>	<b>Impinger 7</b>	<b>Impinger 8</b>
	(g)	(g)	(g)	(g)				
<b>Contents</b>		H <sub>2</sub> SO <sub>4</sub>	H <sub>2</sub> SO <sub>4</sub>	-	Sil Gel			
<b>Final Value</b>	(V <sub>f</sub> ),(W <sub>f</sub> )	813.00	787.60	616.20	854.40			
<b>Initial Value</b>	(V <sub>i</sub> ),(W <sub>i</sub> )	749.80	774.40	613.30	846.30			
<b>Net Value</b>	(V <sub>n</sub> ),(W <sub>n</sub> )	63.2	13.2	2.9	8.1			
Results								
<b>Total Weight</b>	(W <sub>t</sub> )	87.40	g	<b>Water Vol Weighed</b>			(V <sub>wsg(std)</sub> )	4.121 scf
<b>Std Meter Volume</b>	(V <sub>m(std)</sub> )	43.495	dscf	<b>Sat. Moisture Content</b>			(B <sub>ws(svp)</sub> )	100.00 %
<b>Calc Moisture Content</b>	(B <sub>ws(calc)</sub> )	8.65	%	<b>Final Moisture Content</b>			(B <sub>ws</sub> )	8.65 %

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	West County Energy Center
Sampling Location	Unit 3B
Project #	bv-10-westcounty-fl-comp#2

Date	04/09/11
Operator	MV
Run Number	Fuel Oil-1

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient	(C <sub>p</sub> )	0.840	
Average Stack Temp	(t <sub>s</sub> )	238.9	*F
Average Meter Temp	(t <sub>m</sub> )	83.1	
Orifice Meter Coefficient	(ΔH <sub>0</sub> )	1.745	in H <sub>2</sub> O
Square Root ΔP	(ΔP <sup>1/2</sup> <sub>exp</sub> )	0.94	in H <sub>2</sub> O
Stack Moisture Content	(B <sub>ws</sub> )	8.44	%
Stack Dry Molecular Weight	(M <sub>d</sub> )	29.40	lb/lb-mole
Estimated Orifice Flow Rate	(Q <sub>m</sub> )	0.75	acfm
ΔP to ΔH IsoKinetic Factor	(K)	1.97	

Leak Checks					
Train	Pre	0.000	ft <sup>3</sup> /min@	15.0	in Hg
PASS	Post	0.000	ft <sup>3</sup> /min@	15.0	in Hg
Pitot	Pre (+)	5.0	in H <sub>2</sub> O for	30.0	sec
PASS	Pre (-)	5.0	in H <sub>2</sub> O for	30.0	sec
	Post (+)	5.0	in H <sub>2</sub> O for	30.0	sec
	Post (-)	5.0	in H <sub>2</sub> O for	30.0	sec

Sampling Equipment		
Meter Box Number	SAMP-CP-0010	
Meter Cal Factor	(Y)	0.991
Nozzle Number	I8	
Average Nozzle Diameter	(D <sub>no</sub> )	0.2300 in
Suggested Nozzle Diameter	(D <sub>no</sub> )	0.2170 in
Probe Number	SAMP-HP-0001	
Probe Length	120 in	
Liner Material	inconel	
Sample Case / Oven Number	SAMP-BH-0025	
Impinger Case Number	SAMP-BC-0021	

Pressures		
Barometric Pressure	(P <sub>b</sub> )	30.15 in Hg
Stack Static Pressure	(P <sub>static</sub> )	0.76 in H <sub>2</sub> O
Absolute Stack Pressure	(P <sub>a</sub> )	30.21 in Hg
Absolute Meter Pressure	(P <sub>m</sub> )	30.28 in Hg

Nozzle Measurements			
Pre	0.230	0.230	PASS
Post	0.230	0.230	PASS

Run Time			
Start	11:00	End	12:13

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	751.6	775.9	612.8	845.8				
Post	601.4	792.7	617.5	856.2				

Wash Volumes					ml
					ml

Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V <sub>d</sub> )	Velocity Head (ΔP)	Desired Orifice ΔH (ΔH <sub>d</sub> )	Actual Orifice ΔH (ΔH <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (≤68°F)	Cond. Temp (5-7°F)	CPM Filter Temp (-±-°F)	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>me</sub> )	Pump Vacuum	Square Root ΔP (ΔP <sup>1/2</sup> )	Local Stack Velocity (V <sub>s</sub> )	Cumul. Meter Volume (V <sub>m</sub> ) <sub>std</sub>	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m</sub> ) <sub>std</sub>
	min	hh:mm:ss	ft <sup>3</sup>	in H <sub>2</sub> O	in H <sub>2</sub> O	in H <sub>2</sub> O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H <sub>2</sub> O)	ft/sec	dscf	%	dscf
A-1	0.0	00:00:00	265.150	0.82	1.818	1.50	236	248	260	68			77	74	5.0	0.91	58.53	1.611	90.7	38.660
A-2	2.5	00:02:30	266.780	0.83	1.838	1.60	235	240	258	66			80	75	5.0	0.91	58.84	3.393	95.5	40.720
A-3	5.0	00:05:00	268.590	0.86	1.697	1.60	237	245	255	65			81	76	5.0	0.93	59.98	5.094	94.8	40.751
A-4	7.5	00:07:30	270.320	0.85	1.677	1.60	238	242	260	64			82	77	5.5	0.92	59.68	6.723	93.7	40.335
A-5	10.0	00:10:00	271.980	0.76	1.499	1.50	233	255	261	64			81	76	5.5	0.87	56.23	8.334	93.8	40.004
A-6	12.5	00:12:30	273.620	0.77	1.519	1.50	232	252	260	65			89	76	5.5	0.88	56.55	9.895	93.3	39.580
B-1	15.0	00:15:00	275.220	0.94	1.855	1.80	239	260	262	66			88	77	6.0	0.97	62.80	11.681	93.4	40.051
B-2	17.5	00:17:30	277.050	0.93	1.835	1.80	238	261	263	64			87	76	6.0	0.96	62.42	13.442	93.4	40.325
B-3	20.0	00:20:00	278.850	0.94	1.855	1.80	239	247	260	66			88	77	6.0	0.97	62.80	15.199	93.3	40.531
B-4	22.5	00:22:30	280.650	0.97	1.914	1.80	235	255	263	67			87	78	6.5	0.98	63.61	16.976	93.2	40.742
B-5	25.0	00:25:00	282.470	0.94	1.855	1.80	236	254	261	66			86	78	6.0	0.97	62.67	18.695	92.9	40.790
B-6	27.5	00:27:30	284.230	0.93	1.835	1.80	232	255	262	67			84	77	6.0	0.96	62.15	20.410	92.7	40.820
C-1	30.0	00:30:00	285.980	0.95	1.874	1.80	240	248	260	68			89	80	6.5	0.97	63.18	22.248	93.0	41.074
C-2	32.5	00:32:30	287.870	0.96	1.894	1.80	239	248	259	67			92	80	6.5	0.98	63.47	24.004	92.9	41.149
C-3	35.0	00:35:00	289.680	0.95	1.874	1.80	241	252	257	65			90	80	6.5	0.97	63.23	25.850	93.2	41.360
C-4	37.5	00:37:30	291.580	1.10	2.170	2.10	243	258	259	64			91	82	6.5	1.05	68.13	27.722	93.1	41.583
C-5	40.0	00:40:00	293.510	1.00	1.973	1.90	242	257	259	65			92	83	7.0	1.00	64.91	29.521	93.0	41.677
C-6	42.5	00:42:30	295.370	1.10	2.170	2.10	233	259	258	68			93	82	7.0	1.05	67.64	31.496	93.2	41.995
D-1	45.0	00:45:00	297.410	0.80	1.578	1.50	235	263	258	67			89	81	7.0	0.89	57.77	33.360	93.9	42.139
D-2	47.5	00:47:30	299.330	0.78	1.539	1.50	240	261	259	68			88	81	5.5	0.88	57.25	35.149	94.4	42.178
D-3	50.0	00:50:00	301.170	0.79	1.559	1.50	241	260	258	67			87	80	6.0	0.89	57.66	36.862	94.6	42.128
D-4	52.5	00:52:30	302.930	0.76	1.499	1.40	233	257	259	66			93	82	5.5	0.87	56.23	38.486	94.6	41.984
D-5	55.0	00:55:00	304.610	0.74	1.460	1.40	237	255	257	67			92	81	5.5	0.86	55.64	40.170	94.9	41.917
D-6	57.5	00:57:30	306.350	0.70	1.381	1.30	232	255	258	66			93	82	5.0	0.84	53.92	41.871	95.2	41.871
Last Pt	60.0	01:00:00	308.110																	
Final Val	60.0	01:00:00	308.110											Max Vac	7.0	Final Values		41.871	95.2	
Average Values				0.88		1.68	237	254	259	66			87	79		0.94	60.64			



CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	West County Energy Center
Sampling Location	Unit 3B
Project #	bv-10-westcounty.fl-comp#2

Date	04/09/11
Operator	MV
Run Number	Fuel Oil-2

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient (C <sub>p</sub> )	0.840		
Average Stack Temp (t <sub>s</sub> )	240.6	*F	
Average Meter Temp (t <sub>m</sub> )	84.4		
Orifice Meter Coefficient (C <sub>o</sub> )	1.745	in H <sub>2</sub> O	
Square Root ΔP (ΔP <sup>1/2</sup> <sub>imp</sub> )	0.94	in H <sub>2</sub> O	
Stack Moisture Content (B <sub>st</sub> )	8.71	%	
Stack Dry Molecular Weight (M <sub>d</sub> )	29.40	lb/lb-mole	
Estimated Orifice Flow Rate (Q <sub>o</sub> )	0.70	acfm	
ΔP to ΔH Isokinetic Factor (K)	1.96		

Leak Checks					
Train	Pre	0.000	ft <sup>3</sup> /min@	15.0	in Hg
PASS	Post	0.000	ft <sup>3</sup> /min@	15.0	in Hg
Pitot	Pre (+)	5.0	in H <sub>2</sub> O for	30.0	sec
PASS	Pre (-)	5.0	in H <sub>2</sub> O for	30.0	sec
	Post (+)	5.0	in H <sub>2</sub> O for	30.0	sec
	Post (-)	5.0	in H <sub>2</sub> O for	30.0	sec

Sampling Equipment			
Meter Box Number	SAMP-GP-0010		
Meter Cal Factor	(Y)	0.991	
Nozzle Number	I8		
Average Nozzle Diameter (D <sub>no</sub> )	0.2300	in	
Suggested Nozzle Diameter (D <sub>s</sub> )	0.2092	in	
Probe Number	SAMP-HP-0001	in	
Probe Length	120	in	
Liner Material	inconel		
Sample Case / Oven Number	SAMP-BH-0025		
Impinger Case Number	SAMP-BC-0020		

Nozzle Measurements				
Pre	0.230	0.230	0.230	PASS
Post	0.230	0.230	0.230	PASS

Pressures		
Barometric Pressure (P <sub>b</sub> )	30.14	in Hg
Stack Static Pressure (P <sub>stac</sub> )	0.74	in H <sub>2</sub> O
Absolute Stack Pressure (P <sub>s</sub> )	30.19	in Hg
Absolute Meter Pressure (P <sub>m</sub> )	30.27	in Hg

Run Time			
Start	12:37	End	14:15

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	746.2	743.8	606.3	806.8				
Post	808.4	757.8	610.5	814.9				

Wash Volumes					ml
--------------	--	--	--	--	----

Traverse Point #	Sampling Time (θ)	Timer Time	Reading (V <sub>m</sub> )	Velocity Head (Δp)	Desired Orifice ΔH (ΔH <sub>d</sub> )	Actual Orifice ΔH (ΔH <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (568°F)	Cond. Temp (5-°F)	CPM Filter Temp (-3-°F)	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>mo</sub> )	Pump Vacuum	Square Root ΔP (ΔP <sup>1/2</sup> )	Local Stack Velocity (v <sub>s</sub> )	Cumul. Meter Volume (V <sub>m</sub> ) <sub>std</sub>	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m</sub> ) <sub>std</sub>	
	min	hh:mm:ss	ft <sup>3</sup>	in H <sub>2</sub> O	in H <sub>2</sub> O	in H <sub>2</sub> O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H <sub>2</sub> O)	ft/sec	dscf	%	dscf	
A-1	0.0	00:00:00	309.130	0.79	1.546	1.60	235	265	266	68			88	80	6.0	0.89	57.45	1.712	98.4	41.087	
A-2	2.5	00:02:30	310.890	0.76	1.488	1.50	236	264	268	65			87	81	6.0	0.87	56.39	3.521	102.4	42.249	
A-3	5.0	00:05:00	312.750	0.77	1.507	1.50	237	266	264	61			88	82	5.5	0.88	56.80	5.384	104.6	43.076	
A-4	7.5	00:07:30	314.670	0.75	1.468	1.50	238	265	267	60			87	81	5.0	0.87	56.10	7.193	105.2	43.160	
A-5	10.0	00:10:00	316.530	0.69	1.351	1.40	239	260	262	60			88	80	5.0	0.83	53.85	8.807	104.1	42.274	
A-6	12.5	00:12:30	318.190	0.68	1.331	1.40	241	260	258	60			89	80	5.0	0.82	53.53	10.439	103.7	41.756	
B-1	15.0	00:15:00	319.870	1.00	1.957	2.00	238	261	259	58			88	83	6.0	1.00	64.78	12.420	103.4	42.582	
B-2	17.5	00:17:30	321.910	1.00	1.957	2.00	239	256	254	57			87	81	6.0	1.00	64.82	14.387	103.0	43.160	
B-3	20.0	00:20:00	323.930	1.10	2.153	2.10	241	255	257	58			88	80	6.5	1.05	68.08	16.315	102.0	43.506	
B-4	22.5	00:22:30	325.910	1.10	2.153	2.10	233	248	253	57			87	81	6.5	1.05	67.69	18.419	102.0	44.204	
B-5	25.0	00:25:00	328.070	1.10	2.153	2.10	238	247	251	58			88	83	6.5	1.05	67.94	20.429	101.7	44.572	
B-6	27.5	00:27:30	330.140	1.10	2.153	2.10	239	247	252	58			88	82	6.5	1.05	67.99	22.451	101.4	44.902	
C-1	30.0	00:30:00	332.220	0.90	1.762	1.80	241	245	251	61			87	80	6.0	0.95	61.58	24.253	101.1	44.775	
C-2	32.5	00:32:30	334.070	0.95	1.859	1.90	242	252	256	62			88	81	6.0	0.97	63.32	26.072	100.7	44.694	
C-3	35.0	00:35:00	335.940	0.97	1.899	1.90	239	251	256	62			88	80	6.0	0.98	63.84	27.989	100.7	44.783	
C-4	37.5	00:37:30	337.910	1.00	1.957	1.90	241	255	253	59			88	81	6.0	1.00	64.92	29.866	100.4	44.799	
C-5	40.0	00:40:00	339.840	1.00	1.957	1.90	240	255	252	58			87	80	6.5	1.00	64.87	31.708	100.1	44.764	
C-6	42.5	00:42:30	341.730	1.10	2.153	2.10	244	257	258	57			88	79	6.5	1.05	68.23	33.764	100.1	45.019	
D-1	45.0	00:45:00	343.840	0.78	1.527	1.50	243	248	261	64			87	81	6.0	0.88	57.41	35.369	99.8	44.677	
D-2	47.5	00:47:30	345.490	0.80	1.566	1.60	241	247	260	65			88	82	6.5	0.89	58.06	37.010	99.6	44.412	
D-3	50.0	00:50:00	347.180	0.81	1.585	1.60	246	261	264	63			89	83	6.5	0.90	58.63	38.686	99.4	44.213	
D-4	52.5	00:52:30	348.910	0.78	1.527	1.50	248	260	263	64			88	81	6.0	0.88	57.62	40.406	99.4	44.079	
D-5	55.0	00:55:00	350.680	0.71	1.390	1.40	248	261	262	62			87	80	6.0	0.84	54.97	42.022	99.4	43.849	
D-6	57.5	00:57:30	352.340	0.69	1.351	1.40	248	265	264	64			88	81	6.0	0.83	54.19	43.721	99.7	43.721	
Last Pt	60.0	01:00:00	354.090																		
Final Val	60.0	01:00:00	354.090												Max Vac	6.5		Final Values	43.721	99.7	
Average Values				0.89		1.74	241	256	259	61			88	81			0.94	60.96			

CTM 027 (AMMONIA) SOURCE SAMPLING TITLE PAGE ISOKINETIC SAMPLING DATA

Plant Name	West County Energy Center
Sampling Location	Unit 3B
Project #	bv-10-westcounty.fl-comp#2

Date	04/09/11
Operator	MV
Run Number	Fuel Oil-3

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Coefficient	(C <sub>p</sub> )	0.840	
Average Stack Temp	(t <sub>s</sub> )	238.2	*F
Average Meter Temp	(t <sub>m</sub> )	86.2	
Orifice Meter Coefficient	(K <sub>o</sub> )	1.745	in H <sub>2</sub> O
Square Root ΔP	(ΔP <sup>1/2</sup> <sub>avg</sub> )	0.96	in H <sub>2</sub> O
Stack Moisture Content	(B <sub>st</sub> )	8.65	%
Stack Dry Molecular Weight	(M <sub>st</sub> )	29.40	lb/lb-mole
Estimated Orifice Flow Rate	(Q <sub>o</sub> )	0.73	acfm
ΔP to ΔH Isokinetic Factor	(K)	1.97	

Leak Checks					
Train	Pre	0.000	ft <sup>3</sup> /min@	15.0	in Hg
PASS	Post	0.000	ft <sup>3</sup> /min@	15.0	in Hg
PHot	Pre (+)	5.0	in H <sub>2</sub> O for	30.0	sec
PASS	Pre (-)	5.0	in H <sub>2</sub> O for	30.0	sec
	Post (+)	5.0	in H <sub>2</sub> O for	30.0	sec
	Post (-)	5.0	in H <sub>2</sub> O for	30.0	sec

Sampling Equipment			
Meter Box Number	SAMP-CP-0010		
Meter Cal Factor	(Y)	0.991	
Nozzle Number	18		
Average Nozzle Diameter	(D <sub>no</sub> )	0.2300	in
Suggested Nozzle Diameter	(D <sub>no</sub> )	0.2118	in
Probe Number	SAMP-HP-0001		
Probe Length	120		
Liner Material	inconel		
Sample Case / Oven Number	SAMP-BH-0025		
Impinger Case Number	SAMP-BC-0021		

Pressures			
Barometric Pressure	(P <sub>b</sub> )	30.11	in Hg
Stack Static Pressure	(P <sub>static</sub> )	0.75	in H <sub>2</sub> O
Absolute Stack Pressure	(P <sub>s</sub> )	30.17	in Hg
Absolute Meter Pressure	(P <sub>m</sub> )	30.24	in Hg

Nozzle Measurements			
Pre	0.230	0.230	PASS
Post	0.230	0.230	PASS

Run Time			
Start	14:30	End	15:47

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	749.8	774.4	613.3	846.3				
Post	813.0	787.6	616.2	854.4				

Wash Volumes					ml
					ml

Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V <sub>m</sub> )	Velocity Head (Δp)	Desired Orifice ΔH (ΔH <sub>d</sub> )	Actual Orifice ΔH (ΔH <sub>a</sub> )	Stack Temp (t <sub>s</sub> )	Probe Temp (248±25°F)	Filter Temp (248±25°F)	Impinger Exit Temp (568°F)	Cond. Temp (S-°F)	CPM Filter Temp (-I-°F)	Meter Inlet Temp (t <sub>m</sub> )	Meter Outlet Temp (t <sub>mo</sub> )	Pump Vacuum	Square Root ΔP (ΔP <sup>1/2</sup> )	Local Stack Velocity (v <sub>s</sub> )	Cumul. Meter Volume (V <sub>m</sub> ) <sub>242</sub>	Cumul. Percent IsoKinetic (I)	Est-Run Meter Volume (V <sub>m</sub> ) <sub>242</sub>
	min	hh:mm:ss	ft <sup>3</sup>	in H <sub>2</sub> O	in H <sub>2</sub> O	in H <sub>2</sub> O	°F	°F	°F	°F	°F	°F	°F	°F	in Hg	√(in H <sub>2</sub> O)	ft/sec	dsf	%	dsf
A-1	0.0	00:00:00	354.640	0.81	1.598	1.60	234	227	255	67			88	84	6.0	0.90	58.16	1.714	97.2	41.128
A-2	2.5	00:02:30	356.410	0.85	1.677	1.70	238	234	250	66			87	81	6.0	0.92	59.75	3.483	97.2	41.559
A-3	5.0	00:05:00	358.210	0.84	1.657	1.70	239	250	258	62			88	80	6.0	0.92	59.44	5.310	99.3	42.480
A-4	7.5	00:07:30	360.110	0.85	1.677	1.70	240	252	257	63			87	80	6.0	0.92	59.83	7.051	98.7	42.309
A-5	10.0	00:10:00	361.900	0.78	1.539	1.50	242	255	256	60			88	81	6.0	0.88	57.40	8.750	98.7	42.000
A-6	12.5	00:12:30	363.650	0.75	1.480	1.40	245	257	254	60			89	83	6.0	0.87	56.40	10.347	98.1	41.387
B-1	15.0	00:15:00	365.300	0.95	1.874	1.80	244	257	252	65			88	81	6.5	0.97	63.43	12.173	97.9	41.735
B-2	17.5	00:17:30	367.180	0.98	1.934	1.90	245	251	259	61			89	84	6.5	0.99	64.47	14.080	98.0	42.239
B-3	20.0	00:20:00	369.150	0.99	1.953	1.90	248	255	258	60			88	81	6.5	0.99	64.94	16.013	96.3	42.702
B-4	22.5	00:22:30	371.140	1.00	1.973	1.90	250	254	251	61			87	80	6.5	1.00	65.36	17.931	98.4	43.034
B-5	25.0	00:25:00	373.110	1.10	2.170	2.10	230	251	258	62			93	84	7.5	1.05	67.58	19.648	97.1	42.869
B-6	27.5	00:27:30	374.890	1.10	2.170	2.10	233	252	260	62			92	83	7.5	1.05	67.72	21.456	96.3	42.912
C-1	30.0	00:30:00	376.760	0.95	1.874	1.90	237	245	263	64			91	84	7.5	0.97	63.12	23.292	96.3	43.000
C-2	32.5	00:32:30	378.660	1.00	1.973	2.00	238	244	264	63			92	84	7.5	1.00	64.80	25.204	96.4	43.206
C-3	35.0	00:35:00	380.640	1.10	2.170	2.10	234	246	256	61			93	84	7.5	1.05	67.77	27.105	96.2	43.368
C-4	37.5	00:37:30	382.610	1.10	2.170	2.10	232	244	251	62			93	84	7.5	1.05	67.67	29.025	96.0	43.537
C-5	40.0	00:40:00	384.600	1.20	2.368	2.30	236	247	252	63			91	82	8.0	1.10	70.89	30.943	95.6	43.685
C-6	42.5	00:42:30	386.580	1.20	2.368	2.30	230	243	249	61			90	80	8.0	1.10	70.58	33.110	95.9	44.147
D-1	45.0	00:45:00	388.810	0.75	1.480	1.40	234	241	263	68			90	82	6.5	0.87	55.96	34.613	96.1	43.975
D-2	47.5	00:47:30	390.570	0.85	1.677	1.70	237	242	267	63			91	84	6.0	0.92	59.70	36.697	96.6	44.036
D-3	50.0	00:50:00	392.520	0.88	1.736	1.70	236	240	260	64			90	85	6.0	0.94	60.70	38.290	96.2	43.760
D-4	52.5	00:52:30	394.170	0.80	1.578	1.60	238	241	267	62			91	82	6.5	0.89	57.96	39.944	96.1	43.575
D-5	55.0	00:55:00	395.860	0.80	1.578	1.60	238	240	263	61			90	83	6.5	0.89	57.96	41.686	96.2	43.477
D-6	57.5	00:57:30	397.660	0.75	1.480	1.50	239	241	265	60			92	85	6.5	0.87	56.16	43.497	96.7	43.497
Last Pt	60.0	01:00:00	399.560																	
Final Val	60.0		399.560												Max Vac	8.0	Final Values	43.497	96.7	
Average Values				0.93		1.81	238	246	258	63			90	83		0.96	62.41			
													86							

**SAMPLE RECOVERY AND INTEGRITY DATA SHEET**

<b>Plant Name</b>	West County Energy Center	<b>Date</b>	04/09/11
<b>Sampling Location</b>	Unit 3B	<b>Operator</b>	MV
<b>Project #</b>	bv-10-westcounty.fl-comp#2		

Run History Data				
Run Number	Fuel Oil-1	Fuel Oil-2	Fuel Oil-3	
<b>Run Start Time</b>	11:00	12:37	14:30	(hh:mm)
<b>Run Stop Time</b>	12:13	14:15	15:47	(hh:mm)
<b>Train Prepared By</b>	MV	MV	MV	
<b>Train Recovered By</b>	MV	MV	MV	
<b>Recovery Date</b>	04/09/11	04/09/11	04/09/11	(mm/dd/yy)
<b>Relinquished By</b>	MV	MV	MV	
<b>Received By</b>	MV	MV	MV	
<b>Relinquished Date</b>	04/09/11	04/09/11	04/09/11	(mm/dd/yy)
<b>Relinquished Time</b>	12:13	14:15	15:47	(hh:mm)

Equipment Identification Numbers			
<b>Impinger Case</b>	SAMP-BH-0025	SAMP-BH-0025	SAMP-BH-0025
<b>Sample Box</b>	SAMP-BC-0021	SAMP-BC-0020	SAMP-BC-0021

Sample Blank Taken  YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Weight					
<b>Final Weight</b>	(W <sub>f</sub> )	2211.6	2176.7	2216.8	g
<b>Initial Weight</b>	(W <sub>i</sub> )	2140.3	2096.3	2137.5	g
<b>Net Weight</b>	(W <sub>n</sub> )	71.3	80.4	79.3	g
<b>Comments</b>					
Impinger 4 - Silica Gel Weight					
<b>Final Weight</b>	(W <sub>f</sub> )	856.2	814.9	854.4	g
<b>Initial Weight</b>	(W <sub>i</sub> )	845.6	806.8	846.3	g
<b>Net Weight</b>	(W <sub>n</sub> )	10.6	8.1	8.1	g
<b>Comments</b>					
Total Water Collected					
<b>Total Weight</b>	(W <sub>tc</sub> )	81.9	88.5	87.4	g
<b>Total Volume</b>	(V <sub>tc</sub> )	82.0	88.7	87.6	ml

**CTM 027 (AMMONIA) - RESULTS**

<b>Plant Name</b>	West County Energy Center
<b>Sampling Location</b>	Unit 3B
<b>Project #</b>	bv-10-westcounty.fl-comp#2

<b>Historical Data</b>	<b>Fuel Oil-1</b>	<b>Fuel Oil-2</b>	<b>Fuel Oil-3</b>	<b>Average</b>	<b>Units</b>
Run Start Time	11:00	12:37	14:30		hh:mm
Run Stop Time	12:13	14:15	15:47		hh:mm
Test Date	04/09/11	04/09/11	04/09/11		mm/dd/yy
Meter Calibration Factor	0.991	0.991	0.991		
Pitot Tube Coefficient	0.840	0.840	0.840		
Average Nozzle Diameter	0.230	0.230	0.230		in
<b>Stack Test Data</b>	<b>Fuel Oil-1</b>	<b>Fuel Oil-2</b>	<b>Fuel Oil-3</b>	<b>Average</b>	<b>Units</b>
Initial Meter Volume	265.150	309.130	354.640		ft <sup>3</sup>
Final Meter Volume	308.110	354.090	399.560		ft <sup>3</sup>
Total Meter Volume	42.960	44.960	44.920	44.280	ft <sup>3</sup>
Total Sampling Time	60.00	60.00	60.00	60.00	min
Average Meter Temperature	83.13	84.35	86.23	84.57	°F
Average Stack Temperature	236.92	240.63	238.21	238.58	°F
Barometric Pressure	30.15	30.14	30.11	30.13	in Hg
Stack Static Pressure	0.76	0.74	0.75	0.75	in H <sub>2</sub> O
Absolute Stack Pressure	30.21	30.19	30.17	30.19	in Hg
Average Orifice Pressure Drop	1.68	1.74	1.81	1.74	in H <sub>2</sub> O
Absolute Meter Pressure	30.28	30.27	30.24	30.26	in Hg
Avg Square Root Pitot Pressure	0.94	0.94	0.96	0.95	√(in H <sub>2</sub> O)
<b>Moisture Content Data</b>	<b>Fuel Oil-1</b>	<b>Fuel Oil-2</b>	<b>Fuel Oil-3</b>	<b>Average</b>	<b>Units</b>
Impinger Water Weight Gain	71.30	80.40	79.30	77.00	g
Silica Gel Weight Gain	10.60	8.10	8.10	8.93	g
Total Water Volume Collected	82.05	88.66	87.56	86.09	ml
Standard Water Vapor Volume	3.86	4.17	4.12	4.05	scf
Standard Meter Volume	41.9	43.7	43.5	43.0	dscf
Calculated Stack Moisture	8.44	8.71	8.65	8.60	%
Saturated Stack Moisture	100.00	100.00	100.00	100.00	%
Reported Stack Moisture Content	8.44	8.71	8.65	8.60	%

**CTM 027 (AMMONIA) - RESULTS**

<b>Plant Name</b>	West County Energy Center
<b>Sampling Location</b>	Unit 3B
<b>Project #</b>	bv-10-westcounty.fl-comp#2

<b>Gas Analysis Data</b>	<b>Fuel Oil-1</b>	<b>Fuel Oil-2</b>	<b>Fuel Oil-3</b>	<b>Average</b>	<b>Units</b>
Carbon Dioxide Content	5.4	5.4	5.4	5.4	%
Oxygen Content	13.6	13.6	13.6	13.6	%
Carbon Monoxide Content	5.8	5.8	6.1	5.9	ppm
Nitrogen Content	81.0	81.0	81.0	81.0	%
Stack Dry Molecular Weight	29.40	29.40	29.40	29.40	lb/lb-mole
Stack Wet Molecular Weight	28.44	28.41	28.41	28.42	lb/lb-mole
Calculated Fuel Factor	1.354	1.352	1.362	1.356	
Fuel F-Factor	9308.23	9308.23	9308.23	9308.23	dscf/MMBtu
Percent Excess Air	175.8	176.2	174.5	175.5	%
<b>Volumetric Flow Rate Data</b>	<b>Fuel Oil-1</b>	<b>Fuel Oil-2</b>	<b>Fuel Oil-3</b>	<b>Average</b>	<b>Units</b>
Average Stack Gas Velocity	60.64	60.96	62.41	61.33	ft/sec
Stack Cross-Sectional Area	378.35	378.35	378.35	378.35	ft <sup>2</sup>
Actual Stack Flow Rate	1,376,541	1,383,866	1,416,683	1,392,363	acfm
Wet Standard Stack Flow Rate	63,172	63,148	64,806	63,709	wkscfh
Dry Standard Stack Flow Rate	57,838,311	57,645,887	59,197,585	58,227,261	dscfh
Percent of Isokinetic Rate	95.2	99.7	96.7	97.2	%
<b>Ammonia Analysis (CTM-027)</b>	<b>Fuel Oil-1</b>	<b>Fuel Oil-2</b>	<b>Fuel Oil-3</b>	<b>Average</b>	<b>Units</b>
Sample Number (Front Half)	02	04	06		
Sample Number (Back Half)	03	05	07		
Lab Log Number (Front Half)	U3B-R1-1	U3B-R2-1	U3B-R3-1		
Lab Log Number (Back Half)	U3B-R1-2	U3B-R2-2	U3B-R3-2		
Front Half Results (C <sub>f</sub> )	7.6760	4.5180	4.6900	5.6280	mg/l
Back Half Results (C <sub>b</sub> )	0.0000	0.0000	0.0000	0.0000	mg/l
Practical Quantitation Limit	0.1000	0.1000	0.1000	0.1000	mg/l
Blank Results	0.0000	0.0000	0.0000	0.0000	mg/l
Front Half Sample Volume	150	150	150	150	ml
Back Half Sample Volume	150	150	150	150	ml
Volume of NH <sub>3</sub>	0.00151	0.00089	0.00093	0.00111	L
NH <sub>3</sub> Concentration	1.28	0.72	0.75	0.92	ppmvd
NH <sub>3</sub> Concentration	1.04	0.59	0.61	0.74	ppm@15%O <sub>2</sub>

**TEST RESULTS**

**Opacity  
Fuel Oil Load**

Company: Florida Power and Light Equipment: Mitsubishi 501G, Unit U3B Fuel Oil Location: West County Energy Center Date: April 9, 2011 Project #: bv-10-westcounty.fl-comp#2						Run 1	Average Opacity: 0.00 % Maximum Opacity: 0 % 6 Minute Average: 0.00 % 6 Minute Maximum: 0.00 % Max Time w/ Opacity: 0.00 minutes				
TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

<b>Company:</b> Florida Power and Light <b>Equipment:</b> Mitsubishi 501G, Unit U3B Fuel Oil <b>Location:</b> West County Energy Center <b>Date:</b> April 9, 2011 <b>Project #:</b> bv-10-westcounty.fl-comp#2						Run 2	<b>Average Opacity:</b> 0.00 % <b>Maximum Opacity:</b> 0 % <b>6 Minute Average:</b> 0.00 % <b>6 Minute Maximum:</b> 0.00 % <b>Max Time w/ Opacity:</b> 0.00 minutes				
TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00



**Company:** Florida Power and Light  
**Equipment:** Mitsubishi 501G, Unit U3B Fuel Oil  
**Location:** West County Energy Center  
**Date:** April 9, 2011  
**Project #:** bv-10-westcounty.fl-comp#2

Run 3

**Average Opacity:** 0.00 %  
**Maximum Opacity:** 0 %  
**6 Minute Average:** 0.00 %  
**6 Minute Maximum:** 0.00 %  
**Max Time w/ Opacity:** 0.00 minutes


TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	0	0.00	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	0	0.00	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	0	0.00	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	0	0.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	0	0.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	0	0.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	0	0.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	0	0.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	0	0.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	0	0.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	0	0.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	0	0.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	0	0.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	0	0.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	0	0.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	0	0.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	0	0.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	0	0.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	0	0.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	0	0.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	0.00	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	0.00	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	0.00	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	0.00	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	0.00	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	0.00	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	0.00	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	0.00	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	0.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	0.00	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	0.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	0.00	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	0.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	0.00	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	0.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	0.00	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	0.00	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	0.00	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	0.00	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.00	39.75	0	0.00	54.75	0	0.00
10.00	0	0.00	25.00	0	0.00	40.00	0	0.00	55.00	0	0.00
10.25	0	0.00	25.25	0	0.00	40.25	0	0.00	55.25	0	0.00
10.50	0	0.00	25.50	0	0.00	40.50	0	0.00	55.50	0	0.00
10.75	0	0.00	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	0	0.00	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	0	0.00	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	0	0.00	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	0	0.00	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	0	0.00	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	0	0.00	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	0	0.00	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	0	0.00	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	0	0.00	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	0	0.00	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	0	0.00	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	0	0.00	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	0	0.00	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	0	0.00	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	0	0.00	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	0	0.00	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

Company: Florida Power and Light  
Equipment: Mitsubishi 501G, Unit U3B Fuel Oil  
Location: West County Energy Center  
Date: April 9, 2011  
Project #: bv-10-westcounty.fl-comp#2


Run 1

Average Opacity: 0.00 %  
Maximum Opacity: 0 %  
6 Minute Average: 0.00 %  
6 Minute Maximum: 0.00 %  
Max Time w/ Opacity: 0.00 minutes

**OPACITY READINGS  
(15 second intervals)**



**OPACITY RESULTS  
(6 minute averages)**




Company: Florida Power and Light  
Equipment: Mitsubishi 501G, Unit U3B Fuel Oil  
Location: West County Energy Center  
Date: April 9, 2011  
Project #: bv-10-westcounty.fl-comp#2


Run 2

Average Opacity: 0.00 %  
Maximum Opacity: 0 %  
6 Minute Average: 0.00 %  
6 Minute Maximum: 0.00 %  
Max Time w/ Opacity: 0.00 minutes

**OPACITY READINGS  
(15 second intervals)**



**OPACITY RESULTS  
(6 minute averages)**




Company: Florida Power and Light  
Equipment: Mitsubishi 501G, Unit U3B Fuel Oil  
Location: West County Energy Center  
Date: April 9, 2011  
Project #: bv-10-westcounty.fl-comp#2


Run 3

Average Opacity: 0.00 %  
Maximum Opacity: 0 %  
6 Minute Average: 0.00 %  
6 Minute Maximum: 0.00 %  
Max Time w/ Opacity: 0.00 minutes

### OPACITY READINGS (15 second intervals)



### OPACITY RESULTS (6 minute averages)



Method Used (Circle One) Method 9 203A 203B Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Form Number \_\_\_\_\_ Page 1 of 2

Company Name FLORIDA POWER AND LIGHT  
 Facility Name WEST COUNTY ENERGY CENTER  
 Street Address LOSOS STATE ROAD 80  
 City LUXAHATCHEE State FL Zip 32170

Continued on Form Number \_\_\_\_\_

Process FUEL OIL Unit # 3B Operating Mode BASE  
 Control Equipment HRS6 Operating Mode BASE

Observation Date 4-9-11 Time Zone EDT Start Time 12:00 End Time 13:00


Describe Emissions Point  
MIDDLE STACK IN GROUP OF 3 ON BLOCK 3 (3B)  
 Height of Emiss. Pt. Start 600 A End SAME Height of Emiss. Pt. Rel. to Observer Start 600 A End SAME  
 Distance to Emiss. Pt. Start 300 A End SAME Direction to Emiss. Pt. (Degrees) Start 350 End SAME

Min.	Sec.	Time Zone				Comments
		0	15	30	45	
1	0	0	0	0	0	
2	0	0	0	0	0	
3	0	0	0	0	0	
4	0	0	0	0	0	
5	0	0	0	0	0	
6	0	0	0	0	0	
7	0	0	0	0	0	
8	0	0	0	0	0	
9	0	0	0	0	0	
10	0	0	0	0	0	
11	0	0	0	0	0	
12	0	0	0	0	0	
13	0	0	0	0	0	
14	0	0	0	0	0	
15	0	0	0	0	0	
16	0	0	0	0	0	
17	0	0	0	0	0	
18	0	0	0	0	0	
19	0	0	0	0	0	
20	0	0	0	0	0	
21	0	0	0	0	0	
22	0	0	0	0	0	
23	0	0	0	0	0	
24	0	0	0	0	0	
25	0	0	0	0	0	
26	0	0	0	0	0	
27	0	0	0	0	0	
28	0	0	0	0	0	
29	0	0	0	0	0	
30	0	0	0	0	0	

Vertical Angle to Obs. Pt. Start 17 End SAME Direction to Obs. Pt. (Degrees) Start 350 End SAME  
 Distance and Direction to Observation Point from Emission Point Start 0/0 End SAME

Describe Emissions  
 Start N/A End SAME Water Droplet Plume Start NONE End -  
 Emission Color Start N/A End SAME

Describe Plume Background  
 Start CLOUDY SKY End SAME Sky Conditions Start SCATTERED End SAME  
 Background Color Start BLUE/WHITE End SAME Wind Direction Start E End SAME  
 Wind Speed Start 3 mph End 6 mph Ambient Temp. Start 60 End 63 Wet Bulb Temp. 69 RH Percent 61/70



Observer's Name (Print) SIDNEY GASTON  
 Observer's Signature [Signature] Date 4-9-11  
 Organization AIR HYGIENE  
 Certified By EPA Date 10-19-10

Additional Information \_\_\_\_\_

Method Used (Circle One)  
 Method 9    203A    203B    Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Form Number \_\_\_\_\_ Page 2 of 2

Company Name FLORIDA POWER AND LIGHT  
 Facility Name WEST COUNTY ENERGY CENTER  
 Street Address 20505 STATE ROAD 80  
 City LOXAHATCHEE State FL Zip 33470

Continued on Form Number \_\_\_\_\_

Process FUEL OIL Unit # 3B Operating Mode BASE  
 Control Equipment HRSA Operating Mode BASE

Observation Date 4-9-11 Time Zone EDT Start Time 12:00 End Time 1:30:00

Describe Emissions Point  
MIDDLE STACK IN GROUP OF 3 ON BLOCK 3 (3B)  
 Height of Emiss. Pt. Start 150 FT End SAME Height of Emiss. Pt. Rel. to Observer Start 150 FT End SAME  
 Distance to Emiss. Pt. Start 300 FT End SAME Direction to Emiss. Pt. (Degrees) Start 335° End SAME


Min.	Sec.	0	15	30	45	Comments
------	------	---	----	----	----	----------

Vertical Angle to Obs. Pt. Start 17° End SAME Direction to Obs. Pt. (Degrees) Start 335° End SAME  
 Distance and Direction to Observation Point from Emission Point Start 0° 0' End SAME

1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	0	0	0	0	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Start N/A End SAME Water Droplet Plume Start NONE End -

Describe Plume Background Stack GLASSY End SAME Sky Conditions Start SCATTERED End SAME  
 Background Color Start PALE WHITE End SAME Wind Speed Start 3 mph End 4 mph Wind Direction Start ENE End SAME  
 Ambient Temp. Start 86° End 83° Wet Bulb Temp. Start 61° End 61° RH Percent 70



Observer's Name (Print) SADNEY GASTON

Additional Information \_\_\_\_\_

Observer's Signature \_\_\_\_\_ Date 4-9-11

Organization AIR HYGIENE

Certified By ETA Date 10-19-10

Method Used (Circle One)  
 Method 9 203A 203B Other: \_\_\_\_\_

Company Name  
**FLORIDA POWER AND LIGHT**  
 Facility Name  
**WEST COUNTY ENERGY CENTER**  
 Street Address  
**20505 STATE ROAD 80**  
 City State Zip  
**LOXAHATCHEE FL 33470**


Process  
**FUEL OIL** Unit # **3B** Operating Mode **BASE**  
 Control Equipment **HRSG** Operating Mode **BASE**

Describe Emissions Point  
**MIDDLE STACK IN GROUP OF 3 ON BLOCK 3 (B)**  
 Height of Emiss. Pt. Start **150** End **SAME** Height of Emiss. Pt. Rel. to Observer Start **150 ft** End **SAME**  
 Distance to Emiss. Pt. Start **300** End **SAME** Direction to Emiss. Pt. (Degrees) Start **335** End **SAME**

Vertical Angle to Obs. Pt. Start **170** End **SAME** Direction to Obs. Pt. (Degrees) Start **335** End **SAME**  
 Distance and Direction to Observation Point from Emission Point Start **0 0** End **SAME**

Describe Emissions  
 Start **N/A** End **SAME** Water Droplet Plume Start **NONE** End **—**  
 Emission Color Start **N/A** End **SAME**

Describe Plume Background  
 Start **CLOUDY SKY** End **SAME** Sky Conditions Start **SCATTERED** End **SAME**  
 Background Color Start **WHITE** End **SAME** Wind Speed Start **6 mph** End **—** Wind Direction Start **ENE** End **SAME**  
 Ambient Temp. Start **83** End **—** Wet Bulb Temp. Start **71** End **—** RH Percent **67**



Latitude **80° 22' 34" N** Longitude **80° 26' 41" W** Declination

Additional Information

**VISUAL EMISSIONS OBSERVATION FORM**

Form Number \_\_\_\_\_ Page **1** of **2**  
 Continued on Form Number \_\_\_\_\_

Observation Date	Time Zone	Start Time	End Time			
<b>4-9-11</b>	<b>EDT</b>	<b>13:00</b>	<b>14:00</b>			
Min.	Sec.	0	15	30	45	Comments
1	0	0	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	0		
9	0	0	0	0		
10	0	0	0	0		
11	0	0	0	0		
12	0	0	0	0		
13	0	0	0	0		
14	0	0	0	0		
15	0	0	0	0		
16	0	0	0	0		
17	0	0	0	0		
18	0	0	0	0		
19	0	0	0	0		
20	0	0	0	0		
21	0	0	0	0		
22	0	0	0	0		
23	0	0	0	0		
24	0	0	0	0		
25	0	0	0	0		
26	0	0	0	0		
27	0	0	0	0		
28	0	0	0	0		
29	0	0	0	0		
30	0	0	0	0		

Observer's Name (Print) **SIDNEY GASTON**  
 Observer's Signature \_\_\_\_\_ Date **4-9-11**  
 Organization **AIR HYGIENE**  
 Certified By **ETA** Date **10-11-10**

Method Used (Circle One)  
 Method 9    203A    203B    Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Form Number \_\_\_\_\_ Page 2 of 2  
 Continued on Form Number \_\_\_\_\_

Company Name  
**FLORIDA POWER AND LIGHT**

Facility Name  
**WEST COUNTY ENERGY CENTER**

Street Address  
**20505 STATE ROAD 80**

City  
**LOXAHATCHEE** State **FL** Zip **33470**

Observation Date  
**4-9-11** Time Zone  
**EDT** Start Time  
**13:00** End Time  
**14:00**

Process  
**FUEL OIL** Unit # **3B** Operating Mode  
**BASE**

Control Equipment  
**HRSG** Operating Mode  
**BASE**

min	Sec	Time Zone				Comments
		0	15	30	45	
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11		0	0	0	0	
12		0	0	0	0	
13		0	0	0	0	
14		0	0	0	0	
15		0	0	0	0	
16		0	0	0	0	
17		0	0	0	0	
18		0	0	0	0	
19		0	0	0	0	
20		0	0	0	0	
21		0	0	0	0	
22		0	0	0	0	
23		0	0	0	0	
24		0	0	0	0	
25		0	0	0	0	
26		0	0	0	0	
27		0	0	0	0	
28		0	0	0	0	
29		0	0	0	0	
30		0	0	0	0	

Describe Emission Point  
**MIDDLE STACK IN GROUP OF 3 ON BLOCK 3 (B)**

Height of Emiss. Pt. Start **150 FT** End **SAME** Height of Emiss. Pt. Rel. to Observer Start **150 FT** End **SAME**

Distance to Emiss. Pt. Start **300 FT** End **SAME** Direction to Emiss. Pt. (Degrees) Start **335°** End **SAME**

Vertical Angle to Obs. Pt. Start **7°** End **SAME** Direction to Obs. Pt. (Degrees) Start **305°** End **SAME**

Distance and Direction to Observation Point from Emission Point Start **0°** End **SAME**

Describe Emissions  
Start **N/A** End **SAME**

Emission Color Start **N/A** End **SAME** Water Droplet Plume Start **NONE** End **-**

Describe Plume Background  
Start **CLOUDY SKY** End **SAME**

Background Color Start **WHITE** End **SAME** Sky Conditions Start **SCATTERED** End **SAME**

Wind Speed Start **EMPH** End **EMPH** Wind Direction Start **ENE** End **SAME**

Ambient Temp. Start **83°** End **83°** Wet Bulb Temp. **71°** RH Percent **67%**

Source Layout Sketch

Observer

150 FEET

300 FEET

140°

Sun Position Line

Stack with Plume

Sun

Wind

Latitude **00°22'34.152641''N** Longitude \_\_\_\_\_

Declination \_\_\_\_\_

Observer's Name (Print)  
**SIDNEY GASTON**

Observer's Signature  
*[Signature]* Date  
**4-9-11**

Organization  
**AIR HYGIENE**

Certified By  
**ETA** Date  
**10-11-10**

Additional Information



Method Used (Circle One)  
 Method 9 203A 203B Other: \_\_\_\_\_

### VISUAL EMISSIONS OBSERVATION FORM

Company Name  
**FLORIDA POWER AND LIGHT**  
 Facility Name  
**WEST COUNTY ENERGY CENTER**  
 Street Address  
**25505 STATE ROAD 80**  
 City  
**LOXAHATCHEE FL 33470**

Form Number \_\_\_\_\_ Page **1** of **2**  
 Continued on Form Number \_\_\_\_\_

Process  
**FUEL OIL** Unit # **3B** Operating Mode **BASE**  
 Control Equipment  
**HBO** Operating Mode **BASE**

Observation Date  
**4-9-11** Time Zone  
**EDT** Start Time  
**14:00** End Time  
**15:00**


Describe Emissions Point  
**MIDDLE STACK IN GROUP OF 3 ON BLOCK 3 (B)**  
 Height of Emiss. Pt. Start **150 FT** End **SAME** Height of Emiss. Pt. Ref. to Observer Start **150 FT** End **SAME**  
 Distance to Emiss. Pt. Start **300 FT** End **SAME** Direction to Emiss. Pt. (Degrees) Start **335°** End **SAME**

Min.	Sec.	0	15	30	45	Comments
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11		0	0	0	0	
12		0	0	0	0	
13		0	0	0	0	
14		0	0	0	0	
15		0	0	0	0	
16		0	0	0	0	
17		0	0	0	0	
18		0	0	0	0	
19		0	0	0	0	
20		0	0	0	0	
21		0	0	0	0	
22		0	0	0	0	
23		0	0	0	0	
24		0	0	0	0	
25		0	0	0	0	
26		0	0	0	0	
27		0	0	0	0	
28		0	0	0	0	
29		0	0	0	0	
30		0	0	0	0	

Vertical Angle to Obs. Pt. Start **17°** End **SAME** Direction to Obs. Pt. (Degrees) Start **335°** End **SAME**  
 Distance and Direction to Observation Point from Emission Point Start **0°** End **SAME**

Describe Emissions  
 Start **N/A** End **SAME** Water Droplet Plume Start **NONE** End **SAME**

Describe Plume Background  
 Start **CLUDY/GRY** End **SAME** Sky Conditions Start **SCATTERED** End **SAME**  
 Background Color Start **WHITE** End **SAME** Wind Speed Start **12 mph** End **12 mph** Wind Direction Start **ENE** End **SAME**  
 Ambient Temp. Start **83°** End **83°** Wet Bulb Temp. **70°** RH Percent **66%**



Observer's Name (Print)  
**ZIDNEY GASTON**  
 Observer's Signature \_\_\_\_\_ Date **4-9-11**  
 Organization  
**ATR HYGIENE**  
 Certified By  
**ETA** Date **10-11-10**

Additional Information

Method Used (CERCLA Org)  
 Method 9 203A 203B Other: \_\_\_\_\_

Company Name  
**FLORIDA POWER AND LIGHT**  
 Facility Name  
**WEST COUNTY ENERGY CENTER**  
 Street Address  
**20005 STATE ROAD 80**  
 City  
**LOXAHATCHEE** State **FL** ZIP **33470**


Process  
**FUEL OIL** Unit # **3B** Operating Mode **BASE**  
 Control Equipment  
**HPSG** Operating Mode **BASE**

Describe Emissions Point  
**MIDDLE STACK IN GROUP OF 3 ON BLOCK 3 (B)**  
 Height of Emiss. Pt  
 Start **100 FT** End **SAME** Height of Emiss. Pt Rel. to Observer  
 Start **100 FT** End **SAME**  
 Distance to Emiss. Pt  
 Start **300 FT** End **SAME** Direction to Emiss. Pt (Degrees)  
 Start **335** End **SAME**

Vertical Angle to Obs. Pt  
 Start **10** End **SAME** Direction to Obs. Pt (Degrees)  
 Start **335** End **SAME**  
 Distance and Direction to Observation Point from Emission Point  
 Start **0** End **88** End **SAME**

Describe Emissions  
 Start **N/A** End **SAME**  
 Emission Color  
 Start **N/A** End **SAME** Water Droplet Plume  
 Start **NONE** End **-**

Describe Plume Background  
 Start **CLOUDY SKY** End **SAME**  
 Background Color  
 Start **WHITE** End **SAME** Sky Conditions  
 Start **SCATTERED** End **SAME**  
 Wind Speed  
 Start **1 mph** End **1 mph** Wind Direction  
 Start **ESE** End **SAME**  
 Ambient Temp  
 Start **83** End **83** Wet Bulb Temp  
 Start **70** RH Percent  
 Start **66%**



Additional Information

**VISUAL EMISSIONS OBSERVATION FORM**

Form Number \_\_\_\_\_ Page **2** of **2**

Continued on Form Number \_\_\_\_\_

Obs. No.	Sec.	Time Zone				Comments
		0	15	30	45	
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11		0	0	0	0	
12		0	0	0	0	
13		0	0	0	0	
14		0	0	0	0	
15		0	0	0	0	
16		0	0	0	0	
17		0	0	0	0	
18		0	0	0	0	
19		0	0	0	0	
20		0	0	0	0	
21		0	0	0	0	
22		0	0	0	0	
23		0	0	0	0	
24		0	0	0	0	
25		0	0	0	0	
26		0	0	0	0	
27		0	0	0	0	
28		0	0	0	0	
29		0	0	0	0	
30		0	0	0	0	

Observer's Name (Print)  
**SIDNEY GASTON**  
 Observer's Signature  
**[Signature]** Date **4-9-11**  
 Organization  
**AIR HYGIENE**  
 Certified By  
**ETA** Date **10-11-10**

**CALCULATIONS**

**EXAMPLE CALCULATIONS (INFORMATION)**

**Specific Humidity (RH<sub>sp</sub>)**

Note: RH<sub>sp</sub> (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} (lb/lb) = \left[ \left( \frac{gr}{lb} \right) \times \frac{lb}{7000 gr} \right]$$

$$RH_{sp} = \frac{79.28 gr}{lb} \times \frac{1 lb}{7000 gr} = 0.011325 \frac{lb H_2O}{lb Air}$$

**Combustor Inlet Pressure / Compressor Discharge Pressure (CIP / CDP)**  
(corrected from gauge to atmospheric pres. and conv. to mm Hg.)

Note: CIP / CDP (psig) is a value obtained from the source operator.

$$CIP / CDP = \left[ (psig + P) \times \frac{51.71493 mmHg}{1 psi} \right]$$

$$CIP / CDP = [260.4 psig + 14.8083] \times \frac{51.71493 mmHg}{1 psia} = 14,230 mmHg (abs)$$

**Heat Rate (MMBtu/hr)**

$$Heat Rate = \frac{983,660.32 Btu}{SCF} \times \frac{2,097.57 SCF}{hr} \times \frac{MMBtu}{10^6 Btu} = \frac{2,063.29 MMBtu}{hr}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (CALIBRATION)**

**Analyzer Calibration Error**

RM 7E, (12-17-09), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left( \frac{C_{Dr} - C_r}{CS} \right) \times 100$$

Eq. 7E-1

$$ACE = \frac{12.35 ppm - 12.10 ppm}{23.60 ppm} \times 100 = 1.06 \%$$

**Calibration Error and Estimated Point, RM 25A, THC Analyzer**

RM 25A, (12-17-09), 8.4 Calibration Error Test. Immediately prior to the test series (within 2 hours of the start of the test), introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response. Then introduce low-level and mid-level calibration gases successively to the measurement system. ... These differences must be less than 5 percent of the respective calibration gas value. (calc for THC analyzer mid gas, if applicable)

$$E_p = \frac{C_{Dr(H)} - C_{Dr(L)}}{C_{V(H)} - C_{V(L)}} \times C_{Dr(M)} + C_{Dr(L)}$$

Eq. of a line  
y=mx+b

$$E_p = \frac{8.63 ppm - 0.11 ppm}{8.46 ppm - 0.00 ppm} \times 4.76 ppm + 0.11 = 4.90 ppm$$

$$ACE = \left( \frac{C_{Dr} - C_r}{CS} \right) \times 100$$

Eq. 7E-1

$$ACE_{THC} = \frac{4.79 ppm - 4.90 ppm}{4.76 ppm} \times 100 = -2.39 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)**

**System Bias**

RM 7E, (12-17-09), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left( \frac{C_s - C_{Dir}}{CS} \right) \times 100 \quad \text{Eq. 7E-2} \quad SB = \frac{12.21 \text{ ppm} - 12.35 \text{ ppm}}{23.60 \text{ ppm}} \times 100 = -0.59 \%$$

**Drift Assessment**

RM 7E, (12-17-09), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = |SB_{Final} - SB_i| \quad \text{Eq. 7E-4} \quad D = | -1.27 \% - -0.59 \% | = 0.68 \%$$

**Alternative Drift and Bias**

RM 7E, (12-17-09), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs - Cdir| is ≤ 0.5 ppmv or |Cs - Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = |C_s - C_{Dir}| \quad \text{Eq. Section 13.2 and 13.3} \quad SB / D_{Alt} = | 12.21 \text{ ppm} - 12.35 \text{ ppm} | = 0.14 \text{ ppm}$$

**Bias Adjusted Average**

RM 7E, (12-17-09), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5b. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{ME} - C_O) \times \left( \frac{C_M}{C_M - C_O} \right) \quad \text{Eq. 7E-5b} \quad C_{Gas} = \left( 8.63 \text{ ppm} - 0.11 \text{ ppm} \right) \times \left( \frac{12.10 \text{ ppm}}{12.13 \text{ ppm} - 0.11 \text{ ppm}} \right) = 8.58 \text{ ppm}$$

**EXAMPLE CALCULATIONS (RUNS)**

**Stack Exhaust Flow (Qs) - RM19**

$$Q_s = \left( \frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left( \frac{20.9\%}{20.9\% - C_{O_2(O_2)}} \right) \quad Q_s = \frac{9,308.23 \text{ SCF}}{\text{MMBtu}} \times \frac{2,097.57 \text{ SCF}}{\text{hr}} \times \frac{983,660.32 \text{ Btu}}{\text{SCF}} \times \frac{\text{MMBtu}}{10^6 \text{ Btu}} \times \left( \frac{20.90\%}{20.9\% - 13.6\%} \right) = 55,245,283.07 \text{ SCFH}$$

**Diluent-Corrected Pollutant Concentration, O<sub>2</sub> Based**

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O<sub>2</sub> Concentration. Calculate the O<sub>2</sub> corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable)

$$C_{adj} = C_{Gas(O_2)} \times \left( \frac{20.9\% - AdjFactor}{20.9\% - C_{O_2(O_2)}} \right) \quad \text{Eq. 20-4} \quad C_{adj} = 8.58 \text{ ppm} \times \left( \frac{20.9\% - 15.00\%}{20.9\% - 13.63\%} \right) = 6.97 \text{ ppm@15\%O}_2$$

**Diluent-Corrected Pollutant Concentration Corrected to ISO Conditions**

40CFR60.335(b)(1), Conversion for conc. at ISO Conditions (68°F, 1 atm). Calculate, as follows: (calc for NOx@15% with Run 1 data, if applicable)

$$C_{ISO} = C_{adj} \times \sqrt{\frac{P_a}{P_s}} \times e^{(19 \times (H_c - 4,600))} \times \left( \frac{288}{T_a} \right)^{1.33} \quad C_{ISO} = 6.97 \text{ ppm@15\%O}_2 \times \sqrt{\frac{260.4 \text{ psig} + 14.69232 \text{ psi}}{260.4 \text{ psig} + 14.8083 \text{ psi}}} \times \left( \frac{288 \text{ K}}{303 \text{ K}} \right)^{1.33} = 7.08 \text{ ppm@15\% and ISO}$$

(19 x (0.011325 lb/lb-0.00633))

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (RUNS)**

**Emissions Rate (lb/hr)**

Calculation for pound per hour emission rate. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{gas}}{10^6} \times \frac{Q_s \times MW}{G} \qquad E_{lb/hr} = \frac{8.58 \text{ ppm}}{10^6 \text{ ppm/part}} \times \frac{55,245,283 \text{ SCFH} \times 46.01 \text{ lb/lb-mol}}{385.23 \text{ SCF/lb-mol}} = \frac{56.62 \text{ lb}}{\text{hr}}$$

**Emissions Rate (ton/year)**

Calculation for tons per year emission rate based on 500 hours per year. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{ton/yr} = \frac{E_{lb/hr} \times \text{hr}_{year}}{2000} \qquad E_{ton/yr} = \frac{56.62 \text{ lb}}{\text{hr}} \times \frac{500 \text{ hr}}{\text{year}} \times \frac{\text{ton}}{2000 \text{ lb}} = \frac{14.16 \text{ ton}}{\text{year}}$$

**Emissions Rate (lb/MMBtu)**

RM 19, (12-17-09), 12.2 Emission Rates of PM, SO<sub>2</sub>, and NOx. Select from the following sections the applicable procedure to compute the PM, SO<sub>2</sub>, or NOx emission rate (E) in ng/J (lb/million Btu). (calc for NOx gas Run 1, if applicable)

**Oxygen Based**

12.2.1 Oxygen-Based F Factor, Dry Basis. When measurements are on a dry basis for both O<sub>2</sub> (%O<sub>2</sub>d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{gas} \times F_d \text{ Factor} \times \text{Conv}_c \times 20.9\%}{20.9\% - C_{gas(O_2)}} \qquad \text{Eq. 19-1}$$

$$E_{lb/MMBtu} = \frac{8.58 \text{ ppm} \times 9,308.23 \text{ SCF/MMBtu} \times 0.0000001194 \text{ lb/ppm} \cdot \text{ft}^3 \times 20.9\%}{20.9\% - 13.63\%} = \frac{0.027 \text{ lb}}{\text{MMBtu}}$$

**Conversion Constant**

Conv<sub>c</sub> for NOx

$$\text{Conv}_c (\text{lb} / \text{ppm} \cdot \text{ft}^3) = \frac{MW}{10^6} \qquad \text{Conv}_c = \frac{46.01 \text{ lb}}{\text{lb} \cdot \text{mole}} \times \frac{\text{lb} \cdot \text{mole}}{385.23 \text{ SCF}} = \frac{0.0000001194 \text{ lb}}{\text{ppm} \cdot \text{ft}^3}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:**

ACE = Analyzer calibration error, percent of calibration span.  
B<sub>WS</sub> = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.  
C<sub>avg</sub> = Average *unadjusted* gas concentration indicated by data recorder for the test run.  
C<sub>D</sub> = Pollutant concentration adjusted to dry conditions.  
C<sub>Dr</sub> = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.  
C<sub>Gas</sub> = Average effluent gas concentration adjusted for bias.  
C<sub>M</sub> = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.  
C<sub>MA</sub> = Actual concentration of the upscale calibration gas, ppmv.  
C<sub>O</sub> = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.  
C<sub>S</sub> = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.  
C<sub>SS</sub> = Concentration of NO<sub>x</sub> measured in the spiked sample.  
C<sub>spike</sub> = Concentration of NO<sub>x</sub> in the undiluted spike gas.  
C<sub>calc</sub> = Calculated concentration of NO<sub>x</sub> in the spike gas *diluted in the sample*.  
C<sub>v</sub> = Manufacturer certified concentration of a calibration gas (low, mid, or high).  
C<sub>w</sub> = Pollutant concentration measured under moist sample conditions, wet basis.  
CS = Calibration span.  
D = Drift assessment, percent of calibration span.  
E<sub>p</sub> = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.  
Eff<sub>NO<sub>2</sub></sub> = NO<sub>2</sub> to NO converter efficiency, percent.  
H = High calibration gas, designator.  
L = Low calibration gas, designator.  
M = Mid calibration gas, designator.  
NOFinal = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.  
NOxCorr = The NO<sub>x</sub> concentration corrected for the converter efficiency.  
NOxFinal = The final NO<sub>x</sub> concentration observed during the converter efficiency test in Section 16.2.2.  
NOxPeak = The highest NO<sub>x</sub> concentration observed during the converter efficiency test in Section 16.2.2.  
Q<sub>spike</sub> = Flow rate of spike gas introduced in system calibration mode, L/min.  
Q<sub>total</sub> = Total sample flow rate during the spike test, L/min.  
R = Spike recovery, percent.  
SB = System bias, percent of calibration span.  
SB<sub>i</sub> = Pre-run system bias, percent of calibration span.  
SB<sub>f</sub> = Post-run system bias, percent of calibration span.  
SB / D<sub>ab</sub> = Alternative absolute difference criteria to pass bias and/or drift checks.  
SCE = System calibration error, percent of calibration span.  
SCE<sub>i</sub> = Pre-run system calibration error, percent of calibration span.  
SCE<sub>f</sub> = Post-run system calibration error, percent of calibration span.  
Z = Zero calibration gas, designator.

**40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:**

P<sub>r</sub> = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg  
P<sub>s</sub> = observed combustor inlet absolute pressure at test, mm Hg  
H<sub>a</sub> = observed humidity of ambient air, g H<sub>2</sub>O/g air  
e = transcendental constant, 2.718  
T<sub>a</sub> = ambient temperature, K

**Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:**

bhp = brake horsepower  
hp = horsepower  
Q<sub>sys</sub> = system flow (lpm)  
Q<sub>m</sub> = matrix spike flow (lpm)

**RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:**

AdjFactor = Percent oxygen or carbon dioxide adjustment applied to a target pollutant  
 $B_{wa}$  = Moisture fraction of ambient air, percent  
 Btu = British thermal unit  
 $\%C$  = Concentration of carbon from an ultimate analysis of fuel, weight percent.  
 $\%CO_{2d}, \%CO_{2w}$  = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.  
 CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.  
 E = Pollutant emission rate, ng/J (lb/million Btu).  
 $E_a$  = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).  
 $E_{so}, E_{si}$  = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).  
 $E_{sg}$  = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).  
 $E_{so}$  = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).  
 $E_{ci}$  = Pollutant rate in combined effluent, ng/J (lb/million Btu).  
 $E_{co}$  = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).  
 $E_p$  = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).  
 $E_{pi}$  = Average inlet SO<sub>2</sub> rate for each sampling period d, ng/J (lb/million Btu).  
 $E_{gt}$  = Pollutant rate from gas turbine, ng/J (lb/million Btu).  
 $E_{ga}$  = Daily geometric average pollutant rate, ng/J (lb/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 $E_{ga}, E_{gi}$  = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 $E_h$  = Hourly average pollutant, ng/J (lb/million Btu).  
 $E_{hj}$  = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O<sub>2</sub>.  
 EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.  
 Fc = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19  
 $F_a, F_w, F_c$  = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).  
 ft<sup>3</sup> = cubic feet  
 G = ideal gas conversion factor  
 (385.23 SCF/lb-mol at 68 deg F & 14.696 psia)  
 GCM = gross Btu per SCF (constant, compound based)  
 GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).  
 $GCV_p, GCV_r$  = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).  
 $\%H$  = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.  
 $H_s$  = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).  
 $H_g$  = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).  
 $\%H_2O$  = Concentration of water from an ultimate analysis of fuel, weight percent.  
 $H_t$  = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).  
 K = volume of combustion component per pound of component (constant)  
 K = Conversion factor, 10<sup>-5</sup> (kJ/J)/(%) [10<sup>5</sup> Btu/million Btu].  
 $K_c = (9.57 \text{ scm/kg})/\%$  [(1.53 scf/lb)/%].  
 $K_{co} = (2.0 \text{ scm/kg})/\%$  [(0.321 scf/lb)/%].  
 $K_{od} = (22.7 \text{ scm/kg})/\%$  [(3.64 scf/lb)/%].  
 $K_{ow} = (34.74 \text{ scm/kg})/\%$  [(5.57 scf/lb)/%].  
 $K_p = (0.86 \text{ scm/kg})/\%$  [(0.14 scf/lb)/%].  
 $K_r = (2.85 \text{ scm/kg})/\%$  [(0.46 scf/lb)/%].  
 $K_s = (3.54 \text{ scm/kg})/\%$  [(0.57 scf/lb)/%].  
 $K_{diff} = 2 \times 10^4 \text{ Btu/Mt}\%$ -MMBTU  
 $K_w = (1.30 \text{ scm/kg})/\%$  [(0.21 scf/lb)/%].  
 lb = pound  
 ln = Natural log of indicated value.  
 $L_p, L_r$  = Weight of the product and raw fuel lots, respectively, metric ton (ton).  
 $\%N$  = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.  
 $M\%$  = mole percent  
 mol = mole  
 MW = molecular weight (lb/lb-mol)  
 $MW_{AIR}$  = molecular weight of air ( 28.9625 lb/lb-mole)<sup>1</sup>  
 NCM = net Btu per SCF (constant based on compound)  
 $\%O$  = Concentration of oxygen from an ultimate analysis of fuel, weight percent.  
 $\%O_{2d}, \%O_{2w}$  = Concentration of oxygen on a dry and wet basis, respectively, percent.  
 $P_a$  = barometric pressure, in Hg  
 $P_s$  = Potential SO<sub>2</sub> emissions, percent.  
 $\%S$  = Sulfur content of as-fired fuel lot, dry basis, weight percent.  
 $S_d$  = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).  
 $\%S_f$  = Concentration of sulfur from an ultimate analysis of fuel, weight percent.  
 $S(\text{wt}\%)$  = weight percent of sulfur, per lab analysis by appropriate ASTM standard  
 $S_i$  = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).  
 $S_o$  = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).  
 $\%S_p, \%S_r$  = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.  
 SCF = standard cubic feet  
 SH = specific humidity, pounds of water per pound of air  
 $t_{0.95}$  = Values shown in Table 19-3 for the indicated number of data points n.  
 $T_{amb}$  = ambient temperature, °F  
 W/D Factor = 1.0236 = conv. at 14.696 psia and  
 68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)  
 $X_{CO_2}$  = CO<sub>2</sub> Correction factor, percent.  
 $X_k$  = Fraction of total heat input from each type of fuel k.



# Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

## Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

### ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) = 46.01  
 Molecular Weight of CO (lb/lb-mole) = 28.00  
 Molecular Weight of SO<sub>2</sub> (lb/lb-mole) = 64.00  
 Molecular Weight of THC (propane) (lb/lb-mole) = 44.00  
 Molecular Weight of VOC (methane) (lb/lb-mole) = 16.00  
 Molecular Weight of NH<sub>3</sub> (lb/lb-mole) = 17.03  
 Molecular Weight of HCHO (lb/lb-mole) = 30.03

### 40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx = 0.0000001194351  
 Conversion Constant for CO = 0.000000726839  
 Conversion Constant for SO<sub>2</sub> = 0.0000001661345  
 Conversion Constant for THC = 0.0000001142175  
 Conversion Constant for VOC (methane) = 0.000000415336  
 Conversion Constant for NH<sub>3</sub> = 0.000000442074  
 Conversion Constant for HCHO = 0.000000779534

NOTE: units are lb/ppm\*ft<sup>3</sup>

## Formulas:

1. Corrected Raw Average (C<sub>Gas</sub>), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_O) \times \left( \frac{C_M}{C_M - C_O} \right)$$

2. Correction to % O<sub>2</sub>, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(O_2)} \times \left( \frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right)$$

3. Correction to % O<sub>2</sub> and ISO Conditions

$$C_{ISO} = C_{adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_C - 0.00633))} \times \left( \frac{288}{T_o} \right)^{1.53}$$

4. Method 19 stack exhaust flow (scfh)

$$Q_s = \left( \frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left( \frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

5. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_s \times MWF}{G}$$

6. Emission Rate in tons per year

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000}$$

7. Emission Concentration in lb/MMBtu (O<sub>2</sub> based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d Factor \times Conv_c \times 20.9\%}{20.9\% - C_{Gas(O_2)}}$$

8. Emission Concentration in g/hp\*hr

$$E_{g/hp-hr} = \frac{E_{lb/hr} \times 453.6}{mmv \times 1314.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp}$$

## RATA SHEET CALCULATIONS

d = Reference Method Data - CEMS Data

S<sub>d</sub> = Standard Deviation

CC = Confident Coefficient

n = number of runs

t<sub>0.025</sub> = 2.5 percent confidence coefficient T-values

RA = relative accuracy

ARA = alternative relative accuracy

BAF = Bias adjustment factor

n	t	n	t	n	t
2	12.706	7	2.447	12	2.201
3	4.303	8	2.365	13	2.179
4	3.182	9	2.306	14	2.160
5	2.776	10	2.262	15	2.145
6	2.571	11	2.228	16	2.131

1. Difference

$$d = \sum_{i=1}^n d_i$$

2. Standard Deviation

$$S_d = \sqrt{\frac{\sum_{i=1}^n d_i^2 - \frac{\left( \sum_{i=1}^n d_i \right)^2}{n}}{n-1}}$$

3. Confident Coefficient

$$CC = t_{0.025} \times \frac{S_d}{\sqrt{n}}$$

4. Relative Accuracy

$$RA = \frac{|d_{avg}| + |CC|}{RM_{avg}} \times 100$$

5. Alternative Relative Accuracy

$$ARA = \frac{|d_{avg}| + |CC|}{AS} \times 100$$

5. Bias Adjustment Factor

$$BAF = 1 + \left( \frac{|d_{avg}|}{CEM_{avg}} \right)$$

**EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)**

**Diameter of Stack (in.)**

$$D(\text{in.}) = L_{fv} - L_{mv}$$

$$D(\text{in.}) = 282.38 \text{ in.} - 19.00 \text{ in.} = 263.38 \text{ in.}$$

**Stack Diameters Downstream**

$$B_D(\text{dia.}) = \frac{B}{D}$$

$$B_D(\text{dia.}) = \frac{531.75 \text{ in.}}{263.38 \text{ in.}} = 2.02 \text{ diameters}$$

**Area of Stack (ft<sup>2</sup>)**

$$A_s(\text{ft}^2) = \pi \times \left( \frac{D}{2 \times 12} \right)^2$$

$$A_s(\text{ft}^2) = 3.14 \times \left( \frac{263.38 \text{ in.}}{2 \times 12 \text{ in./ft}} \right)^2 = 378.35 \text{ ft}^2$$

**Stack Diameters Upstream**

$$A_D(\text{dia.}) = \frac{A}{D}$$

$$A_D(\text{dia.}) = \frac{144.00 \text{ in.}}{263.38 \text{ in.}} = 0.55 \text{ diameters}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (Reference Method 3a) [Values from Run 1 test]**

**Carbon Monoxide Concentration (%)**

$$\%CO = \frac{ppmCO}{10,000}$$

$$\%CO (\%) = \frac{5.79 \text{ ppm}}{10,000 \text{ ppm/\%}} = 0.000579 \%$$

**Nitrogen Concentration (%)**

$$\%N_2 = 100 - \%CO_2 - \%O_2 - \%CO$$

$$\%N_2 (\%) = 100 - 5.37 \% - 13.63 \% - 5.79 / 10,000 \% = 81 \%$$

**Stack Dry Molecular Weight (lb/lb-mole)**

$$M_d (\text{lb/lb-mol}) = \sum \left( \frac{MW_{comp}}{100} \times \%component \right)$$

$$M_d (\text{lb/lb-mol}) = \left( \frac{44 \text{ lb/lb-mol}}{100} \times 5.37 \% \right) + \left( \frac{32 \text{ lb/lb-mol}}{100} \times 13.63 \% \right) + \left( \frac{28 \text{ lb/lb-mol}}{100} \times \left[ \frac{5.79}{10,000} + 81.00 \right] \right) = \frac{29.40 \text{ lb}}{\text{lb-mol}}$$

**Stack Wet Molecular Weight (lb/lb-mole)**

$$M_s (\text{lb/lb-mol}) = \left[ M_d \times \left( 1 - \frac{B_{WS}}{100} \right) \right] + \left[ MW_{H_2O} \times \frac{B_{WS}}{100} \right]$$

$$M_s (\text{lb/lb-mol}) = \left\{ \frac{29.40 \text{ lb}}{\text{lb-mol}} \times \left( 1 - \frac{8.44 \%}{100} \right) \right\} + \left\{ \frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{8.44 \%}{100} \right\} = \frac{28.44 \text{ lb}}{\text{lb-mol}}$$

**Average Calculated Fuel Factor (F<sub>o</sub>)**

$$F_{o(avg)} = \frac{[20.9 - (\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}{[(\%CO_2)_{avg} + (\%CO)_{avg}]}$$

$$F_{o(avg)} = \frac{20.9\% - 13.63\% - (0.5 \times 0.001\%)}{5.37\% + 0.001\%} = 1.350$$

**Average Excess Air (%)**

$$\%EA_{avg} (\%) = \frac{100 \times [(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}{(0.264 \times (N_2)_{avg}) - [(\%O_2)_{avg} - (0.5 \times (\%CO)_{avg})]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{ 13.63 \% - (0.5 \times 0.001 \%) \}}{(0.264 \times 81.00 \%) - \{ 13.63 \% - (0.5 \times 0.001 \%) \}} = 175.79 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (Reference Method 2) [Values from Run 1 test]**

**Absolute Stack Pressure (in. Hg)**

$$P_s (\text{in. Hg}) = P_b + \frac{P_{\text{static}}}{13.6}$$

$$P_s (\text{in. Hg}) = 30.15 \text{ in. Hg} + \frac{0.76 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 30.21 \text{ in. Hg}$$

**Average Stack Gas Velocity (ft/sec)**

$$v_s (\text{ft/sec}) = K_p \times C_p \times (\sqrt{\Delta p})_{\text{avg}} \times \sqrt{\frac{(t_s)_{\text{avg}} + T_u}{P_s \times M_s}}$$

$v_{sl}$  (ft/sec) =

$$\left( \frac{85.49 \text{ ft (lb/lb-mol)(in. Hg)}}{\text{sec} (\text{°R})(\text{in. H}_2\text{O})} \right)^{1/2} \times 0.84 \times 0.94 \text{ in. H}_2\text{O}^{1/2} \times \sqrt{\frac{236.92 + 460 \text{ °R}}{30.21 \text{ in. Hg} \times 28.44 \text{ lb/lb-mol}}} = \frac{60.6 \text{ ft}}{\text{sec}}$$

**Average Stack Dry Standard Flow Rate (dscfh)**

$$Q_{sd} (\text{dscfh}) = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100}\right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sd} (\text{dscf/hr}) = \frac{3600 \text{ sec}}{\text{hr}} \times \left(1 - \frac{8.44 \%}{100}\right) \times \frac{60.64 \text{ ft}}{\text{sec}} \times 378.35 \text{ ft}^2 \times \frac{68.00 + 460 \text{ °R}}{236.92 + 460 \text{ °R}} \times \frac{30.21 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{57,838,311.26 \text{ dscf}}{\text{hr}}$$

**Average Stack Wet Flow Rate (acfm)**

$$Q_{aw} (\text{acfm}) = 60 \times v_s \times A_s$$

$$Q_{aw} (\text{acf/min}) = \frac{60 \text{ sec}}{\text{min}} \times \frac{60.64 \text{ ft}}{\text{sec}} \times 378.35 \text{ ft}^2 = \frac{1,376,540.92 \text{ acf}}{\text{min}}$$

**Average Stack Wet Standard Flow Rate (ascfh)**

$$Q_{sw} (\text{ascfh}) = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sw} (\text{ascf/hr}) = \frac{60 \text{ min}}{\text{hr}} \times \frac{1,376,540.92 \text{ acf}}{\text{min}} \times \frac{68.00 + 460 \text{ °R}}{236.92 + 460 \text{ °R}} \times \frac{30.21 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{63,171,819.31 \text{ ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (Reference Method 4) [Values from Run 1 test]**

**Water Volume Weighed (scf)**

$$V_{wsg(std)} (scf) = W_i \times K_s$$

$$V_{wsg(std)} = 81.90 \text{ g} \times 0.04715 \text{ ft}^3/\text{g} = 3.860 \text{ scf}$$

**Standard Meter Volume (dscf)**

$$V_{m(std)} (dscf) = \frac{K_1 \times Y \times V_m \times \left( P_b + \frac{\Delta H_{avg}}{13.6} \right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65 \text{ }^\circ\text{R}}{\text{in. Hg}} \times 0.99 \times 42.96 \text{ dcf} \times \left( 30.15 \text{ in. Hg} + \frac{1.68 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}} \right) = 41.88 \text{ dscf}$$

$$83.13 \text{ }^\circ\text{F} + 460 \text{ }^\circ\text{R}$$

**Calculated Moisture Content (%)**

$$B_{ws(calc)} (\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{3.86 \text{ dscf}}{3.86 \text{ dscf} + 41.88 \text{ dscf}} = 8.44 \%$$

**Saturated Moisture Content (%)**

$$B_{ws(svp)} (\%) = 100 \times \frac{10^{\frac{6.691 - \frac{3144}{t_s(avg) + 390.86}}{P_b + \frac{P_{static}}{13.6}}}}{\leq 100}$$

$$B_{ws(svp)} = 100 \times \frac{10^{\left( 6.691 - \frac{3144}{236.92 \text{ }^\circ\text{F} + 390.86} \right)}}{30.15 \text{ in. Hg} + \frac{0.76 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}}} \leq 100 = 100.00 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (Isokinetic Sampling) [Values from Run 1 test]**

**Desired Orifice (in. H<sub>2</sub>O)** (first point)

$$\Delta H_d (\text{in. H}_2\text{O}) = K \times \Delta p$$

$$\Delta H_d (\text{in. H}_2\text{O}) = 1.97 \times$$

$$0.82 \text{ in. H}_2\text{O} = 1.62 \text{ in. H}_2\text{O}$$

**Absolute Meter Pressure (in. Hg)**

$$P_m (\text{in. Hg}) = P_b + \frac{\Delta H @}{13.6}$$

$$P_m (\text{in. Hg}) = 30.15 \text{ in. Hg} + \frac{1.75 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 30.28 \text{ in. Hg}$$

**Recommended Nozzle Diameter (in.)**

$$D_m (\text{in.}) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left[ \frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}} \right] \times \left[ \frac{M_d \times \left( 1 - \frac{B_{ws}}{100} \right) + \left( 18 \times \frac{B_{ws}}{100} \right)}{P_s \times \Delta p_{avg}} \right]}$$

$$D_{ni} (\text{in.}) = \frac{0.03575 (\text{lb-mole} \cdot \text{in. H}_2\text{O})^{1/2} \cdot \text{min} \cdot \text{in.}^2}{\text{acf} \cdot \text{in. Hg}^{3/4} \cdot \text{lb}^{1/2}} \times 0.75 \text{ acf} \times 30.28 \text{ in. Hg} \times \left( \frac{1 - \frac{0.00 \%}{100}}{1 - \frac{8.44 \%}{100}} \right) \times \left[ \frac{29.40 \text{ lb}}{\text{lb-mole}} \times \left( 1 - \frac{8.44 \%}{100} \right) + \left( \frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{8.44 \%}{100} \right) \right] \times \left( \frac{1 - \frac{8.44 \%}{100}}{1 - \frac{0.00 \%}{100}} \right)^2 \times \frac{83.13 \text{ }^\circ\text{F} + 460^\circ\text{R}}{236.92 \text{ }^\circ\text{F} + 460^\circ\text{R}} \times 0.84 \times \frac{30.21 \text{ in. Hg}}{0.94 \text{ in. H}_2\text{O}} = 0.220 \text{ in.}$$

**$\Delta p$  to  $\Delta H$  Isokinetic Factor**

$$K = C_k \times C_p^2 \times \Delta H @ \times D_{ni}^4 \times \left[ \frac{M_d \times \left( 1 - \frac{B_{wm}}{100} \right) + \left( 18 \times \frac{B_{wm}}{100} \right)}{M_d \times \left( 1 - \frac{B_{ws}}{100} \right) + \left( 18 \times \frac{B_{ws}}{100} \right)} \right] \times \left[ \frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}} \right] \times \left( \frac{t_m + T_u}{t_s + T_u} \right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. H}_2\text{O} \cdot \text{in.}^4} \times 0.84^2 \times 1.75 \text{ in. H}_2\text{O} \times 0.23^4 \times \left( \frac{1 - \frac{8.44 \%}{100}}{1 - \frac{0.00 \%}{100}} \right)^2 \times \frac{83.13 \text{ }^\circ\text{F} + 460^\circ\text{R}}{236.92 \text{ }^\circ\text{F} + 460^\circ\text{R}} \times \left( \frac{1 - \frac{8.44 \%}{100}}{1 - \frac{0.00 \%}{100}} \right) \times \frac{30.21 \text{ in. Hg}}{30.28 \text{ in. Hg}} = 1.97$$

**Cumulative Percent Isokinetic (%)** (first point)

$$I(\%) = \frac{K_1 \times ((t_s)_{avg} + T_u) \times V_{m(std)}}{\left( \Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left( \frac{D_{nd}}{2} \times \frac{1}{12} \right)^2 \right) \times \left( 1 - \frac{B_{ws}}{100} \right)}$$

$$I(\%) = \frac{0.0945 \text{ min} \cdot \text{in. Hg}}{\text{sec} \cdot \text{R}} \times (236.00 \text{ }^\circ\text{F} + 460^\circ\text{R}) \times 1.61 \text{ dscf}}{2.50 \text{ min} \times \frac{58.53 \text{ ft}}{\text{sec}} \times 30.21 \text{ in. Hg} \times 3.14 \times \left( \frac{0.23 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}} \right)^2 \times \left( 1 - \frac{8.44 \%}{100} \right)} = 90.74 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

**EXAMPLE CALCULATIONS (CTM-027 Ammonia Analysis) [Values from Run 1 test]**

**Dry Gas Meter Volume (L)**

$$(V_m)_{dstdL} (L_{dstd}) = (V_m)_{dscf} \times 28.31685$$

$$V_m (L) = 41.88 \text{ dscf} \times 28.31685 \text{ L/dscf} = 1185.80 \text{ L}$$

**Volume of NH<sub>3</sub> (L)**

$$V_a (L) = \frac{N \times S}{MW \times 1000} \times 22.4$$

$$\left( \frac{7.68 \text{ mg}}{\text{L}} \times \frac{150.00 \text{ ml}}{1} \times \frac{\text{L}}{1000 \text{ ml}} \times \frac{22.4 \text{ L ideal gas}}{\text{g-mol substance}} \times \frac{\text{g-mol NH}_3}{17.03 \text{ g}} \times \frac{\text{g}}{1000 \text{ mg}} \right) +$$

$$\left( \frac{0.00 \text{ mg}}{\text{L}} \times \frac{150.00 \text{ ml}}{1} \times \frac{\text{L}}{1000 \text{ ml}} \times \frac{22.4 \text{ L ideal gas}}{\text{g-mol substance}} \times \frac{\text{g-mol NH}_3}{17.03 \text{ g}} \times \frac{\text{g}}{1000 \text{ mg}} \right) = 0.00151 \text{ L}$$

**NH<sub>3</sub> Concentration (ppmvd)**

$$C_{NH_3} (\text{ppmvd}) = \frac{V_{a(\text{front})} + V_{a(\text{back})}}{(V_m)_{dstdL}} \times 10^6$$

$$C_{NH_3} (\text{ppmvd}) = \frac{0.00 \text{ L}}{1185.80 \text{ L}} \times 10^6 = 1.28 \text{ ppmvd}$$

**NH<sub>3</sub> Concentration (ppmvd@15%O<sub>2</sub>)**

$$C_{adj} = C_{Gas(\text{Target})} \times \left( \frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right)$$

$$C_{adj} = 1.28 \text{ ppmvd} \times \left( \frac{20.9\% - 15.00\%}{20.9\% - 13.6\%} \right) = 1.04 \text{ ppmvd@15\%O}_2$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

## Nomenclature

- %CO = carbon monoxide concentration (%)
- %CO<sub>2</sub> = carbon dioxide concentration (%)
- %N<sub>2</sub> = nitrogen concentration (%)
- %O<sub>2</sub> = oxygen concentration (%)
- %O<sub>2,wet</sub> = Oxygen content of gas stream, % by volume of wet gas. (Note: The oxygen percentage used in Method 201A, Equation 3 is on a wet gas basis. That means that since oxygen is typically measured on a dry gas basis, the measured percent O<sub>2</sub> must be multiplied by the quantity (1 - B<sub>ws</sub>) to convert to the actual volume fraction. Therefore, %O<sub>2,wet</sub> = (1 - B<sub>ws</sub>) \* %O<sub>2,dry</sub>)
- (%EA)<sub>avg</sub> = average excess air (%)
- (F<sub>o</sub>)<sub>avg</sub> = average calculated fuel factor
- $[(\Delta p)^{0.5}]_{avg}$  = Average of square roots of the velocity pressures measured during the preliminary traverse, inches W.C.
- μ = Gas viscosity, micropoise
- 12.0 = Constant calculated as 60 percent of 20.5 square inch cross-sectional area of combined cyclone head, square inches
- 17.03 = mg/milliequivalents for ammonium ion
- 22.4 = liters of ideal gas per mol of substance at 0°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)
- 5.02 x 10<sup>4</sup> = constant derived from the molecular weight and correcting standard temperature and pressure (ref. Bay Area Air Quality Management District, Source Test Procedure ST-1B, Ammonia Integrated Sampling, Adopted January 20, 1982, Regulation 7-303)
- A = distance upstream (in.)
- A<sub>D</sub> = stack diameters upstream (dia.)
- A<sub>n</sub> = Area of nozzle, square feet
- A<sub>s</sub> = area of stack (ft<sup>2</sup>)
- B = distance downstream (in.)
- B<sub>D</sub> = stack diameters downstream (dia.)
- b<sub>f</sub> = Average blockage factor calculated in Equation 26, dimensionless
- B<sub>wm</sub> = meter moisture content (%)
- B<sub>ws</sub> = stack moisture content (%)
- C = Cunningham correction factor for particle diameter, D<sub>p</sub>, and calculated using the actual stack gas temperature, dimensionless
- C<sub>1</sub> = -150.3162 (micropoise)
- C<sub>2</sub> = 18.0614 (micropoise/K<sup>0.5</sup>) = 13.4622 (micropoise/R<sup>0.5</sup>)
- C<sub>3</sub> = 1.19183 × 10<sup>6</sup> (micropoise/K<sup>2</sup>) = 3.86153 × 10<sup>6</sup> (micropoise/R<sup>2</sup>)
- C<sub>4</sub> = 0.591123 (micropoise)
- C<sub>5</sub> = 91.9723 (micropoise)
- C<sub>6</sub> = 4.91705 × 10<sup>-5</sup> (micropoise/K<sup>2</sup>) = 1.51761 × 10<sup>-5</sup> (micropoise/R<sup>2</sup>)
- C<sub>a</sub> = Acetone blank concentration, mg/mg
- C<sub>b</sub> = Concentration of NH<sub>3</sub> ion in the back half of train (breakthrough)
- C<sub>f</sub> = Concentration of NH<sub>3</sub> ion in the front half of train (main catch)
- C<sub>fPM10</sub> = Conc. of filterable PM<sub>10</sub>, gr/dscf
- C<sub>fPM2.5</sub> = Conc. of filterable PM<sub>2.5</sub>, gr/dscf
- C<sub>k</sub> = K Factor Constant, 849.8



## Nomenclature

- $C_n$  = nozzle diameter constant, 0.03575
- $C_p'$  = Coefficient for the pitot used in the preliminary traverse, dimensionless
- $C_p$  = Pitot coefficient for the combined cyclone pitot, dimensionless
- $C_{cpm}$  = Concentration of the condensable PM in the stack gas, dry basis, corrected to standard conditions, milligrams/dry standard cubic foot.
- $C_r$  = Re-estimated Cunningham correction factor for particle diameter equivalent to the actual cut size diameter and calculated using the actual stack gas temperature, dimensionless
- $D_{50}$  = Particle cut diameter, micrometers
- $D_{50(N+1)}$  =  $D_{50}$  value for cyclone IV calculated during the N+1 iterative step, micrometers
- $D_{50-1}$  = Re-calculated particle cut diameters based on re-estimated  $C_r$ , micrometers
- $D_{50LL}$  = Cut diameter for cyclone I corresponding to the 2.25 micrometer cut diameter for cyclone IV, micrometer
- $D_{50N}$  =  $D_{50}$  value for cyclone IV calculated during the Nth iterative step, micrometers
- $D_{50T}$  = Cyclone I cut diameter corresponding to the middle of the overlap zone shown in Method 201A, Figure 10 of Section 17, micrometers
- $D_e$  = equivalent stack diameter (in.)
- $\Delta H@$  =  $\Delta H @ 0.75$  scfm (in. H<sub>2</sub>O)
- $\Delta H_{avg}$  = average orifice pressure (in. H<sub>2</sub>O)
- $D_n$  = Inner diameter of sampling nozzle mounted on Cyclone I, inches
- $D_{na}$  = actual nozzle diameter (in.)
- $D_p$  = Physical particle size, micrometers
- $\Delta p$  = velocity head (in. H<sub>2</sub>O)
- $\Delta p_1$  = velocity head at first current traverse point (in. H<sub>2</sub>O)
- $\Delta p'_1$  = velocity head at first preliminary traverse point (in. H<sub>2</sub>O)
- $\Delta p_{avg}$  = average pitot tube differential pressure (in. H<sub>2</sub>O)
- $\Delta p_n$  = velocity head at subsequent current traverse point (in. H<sub>2</sub>O)
- $\Delta p_{RM2}$  = method 2 velocity head (in. H<sub>2</sub>O)
- $D_s$  = diameter of stack (in.)
- $F_d$  = fuel f-factor (dscf/MMBtu)
- $f_{O_2}$  = stack gas fraction of O<sub>2</sub>, by volume, dry basis
- $I$  = Percent isokinetic sampling, dimensionless
- $K_1$  = standard volume correction, 17.65°R/in. Hg
- $K_4$  = isokinetic conversion constant, 0.0945min•in.Hg/sec•°R
- $K_5$  = water mass to std water vapor, 0.04715 ft<sup>3</sup>/g
- $K_p$  = 85.49, ((ft/sec)/(pounds/mole -°R))
- $L$  = length of stack (in.)
- $L_{fw}$  = distance to far wall of stack (in.)
- $L_{nw}$  = distance to near wall of stack (in.) [reference]
- $m_{\#x}$  = weight measurements (g)
- $M_1$  = Milligrams of PM collected on the filter, less than or equal to 2.5 micrometers
- $M_2$  = Milligrams of PM recovered from Container #2 (acetone blank corrected), greater than 10 micrometers
- $M_3$  = Milligrams of PM recovered from Container #3 (acetone blank corrected), less than or equal to 10 and greater than 2.5 micrometers

## Nomenclature

- $M_4$  = Milligrams of PM recovered from Container #4 (acetone blank corrected), less than or equal to 2.5 micrometers
- $m_a$  = Mass of residue of acetone after evaporation, mg
- $m_c$  = Mass of the  $\text{NH}_4^+$  added to sample to form ammonium sulfate, mg
- $m_{\text{cpm}}$  = Mass of the total condensable PM, mg
- $M_d$  = Molecular weight of dry gas, pounds/pound mole
- $m_{\text{fb}}$  = Mass of total CPM in field train recovery blank, mg
- $m_{\text{fx}}$  = final weight, avg of last two measurements (g)
- mg = Milligram
- mg/L = Milligram per liter
- $m_i$  = Mass of inorganic CPM, mg
- $m_{\text{ib}}$  = Mass of inorganic CPM in field train recovery blank, mg
- $M_n$  = total particulates (mg)
- $m_o$  = Mass of organic CPM, mg
- $m_{\text{ob}}$  = Mass of organic CPM in field train blank, mg
- $m_r$  = Mass of dried sample from inorganic fraction, mg
- $m_{\text{tx}}$  = tare weight (g)
- MW = molecular weight (lb/lb-mole)
- $M_w$  = Molecular weight of wet gas, pounds/pound mole
- N = Normality of ammonium hydroxide titrant
- $N_a$  = null angle (deg.)
- $N_{\text{re}}$  = Reynolds number, dimensionless
- $N_{\text{tp}}$  = Number of iterative steps or total traverse points
- $P_b = P_{\text{bar}}$  = barometric pressure (in. Hg)
- $P_{\text{bar}}$  = barometric pressure (in. Hg)
- ppmCO = carbon monoxide concentration (ppm)
- ppmv = Parts per million by volume
- ppmw = Parts per million by weight
- $P_s$  = absolute stack pressure (in. Hg)
- $P_{\text{static}}$  = static pressure (in.  $\text{H}_2\text{O}$ )
- $P_{\text{std}}$  = standard pressure, 29.92 in. Hg
- $\Theta$  = total sampling time (min)
- $Q_{\text{aw}}$  = average stack wet flow rate (ascf/min)
- $Q_1$  = Sampling rate for cyclone I to achieve specified  $D_{50}$
- $Q_m$  = estimated orifice flow rate, 0.750 acfm, else  $V_m/Q$  from previous run
- $Q_s$  = Sampling rate for cyclone I to achieve specified  $D_{50}$
- $Q_{\text{s(std)}}$  = total cyclone flow rate at standard conditions (dscf/min)
- $Q_{\text{sd}}$  = dry standard stack flow rate (dscfm)
- $Q_{\text{sST}}$  = Dry gas sampling rate through the sampling assembly, dscfm
- $Q_{\text{sw}}$  = wet standard stack flow rate (ascfm)
- $R_{\text{max}}$  = Nozzle/stack velocity ratio parameter, dimensionless
- $R_{\text{min}}$  = Nozzle/stack velocity ratio parameter, dimensionless
- $t_1$  = Sampling time at point 1, min
- $t_m$  = average gas meter temperature ( $^{\circ}\text{F}$ )

## Nomenclature

- $t_m$  = average meter temperature ( $^{\circ}\text{F}$ )
- $T_m$  = Meter box and orifice gas temperature,  $^{\circ}\text{R}$
- $t_n$  = Sampling time at point n, min
- $t_r$  = Total projected run time, min
- $T_s$  = Absolute stack gas temperature,  $^{\circ}\text{R}$
- $T_{std}$  = standard temperature,  $68^{\circ}\text{F}$ ,  $528^{\circ}\text{R}$
- $T_u$  = absolute temperature offset,  $460^{\circ}\text{R}$
- $V_a$  = Volume of acetone blank, ml
- $V_{aw}$  = Volume of acetone used in sample recovery wash, ml
- $V_b$  = Volume of aliquot taken for IC analysis, ml
- $V_c$  = Quantity of water captured in impingers and silica gel, ml
- $V_f$  = final impinger volume (ml)
- $V_i$  = initial impinger volume (ml)
- $V_{ic}$  = Volume of impinger contents sample, ml
- $V_m$  = Dry gas meter volume sampled, acf
- $V_{m(std)}$  = standard meter volume (dscf)
- $v_{max}$  = Maximum gas velocity calculated from Equations 18 or 19, ft/sec
- $v_{max}$  = maximum nozzle velocity (ft/sec)
- $V_{mf}$  = final dry gas meter reading (dcf)
- $V_{mi}$  = initial dry gas meter reading (dcf)
- $v_{min}$  = Minimum gas velocity calculated from Method 201A, Equations 16 or 17, ft/sec
- $V_{ms}$  = Dry gas meter volume sampled, corrected to standard conditions, dscf
- $v_n$  = Sample gas velocity in the nozzle, ft/sec
- $v_{org}$  = organics wash volume (ml)
- $V_p$  = Volume of water added during train purge
- $v_s$  = average stack gas velocity (ft/sec)
- $v_{sl}$  = local velocity (ft/sec)
- $V_t$  = total impinger volume (ml) =  $;(V_f - V_i)$
- $V_t$  = Volume of  $\text{NH}_4\text{OH}$  titrant, ml
- $V_{w(std)}$  = volume of water vapor in gas sample at standard conditions (scf)
- $v_x$  = blank volume (ml)
- $W$  = width of stack (in.)
- $W_{2,3,4}$  = Weight of PM recovered from Containers #2, #3, and #4, mg
- $W_a$  = Weight of blank residue in acetone used to recover samples, mg
- $W_f$  = final impinger weight (g)
- $W_i$  = initial impinger weight (g)
- $W_t$  = total impinger weight (g) =  $;(W_f - W_i)$
- $w_x$  = blank weight of solids (g)
- $Y$  = meter calibration factor (a.k.a gamma)
- $Z$  = Ratio between estimated cyclone IV  $D_{50}$  values, dimensionless
- $\gamma$  = Dry gas meter gamma value, dimensionless
- $\Delta H$  = Meter box orifice pressure drop, inches W.C.
- $\Delta H@$  = Pressure drop across orifice at flow rate of 0.75 scfm at standard conditions, inches W.C.  
(Note: Specific to each orifice and meter box.)

## Nomenclature

- $\Delta p_1$  = Velocity pressure measured at point 1, inches W.C.
- $\Delta p_{avg}$  = Average velocity pressure, inches W.C.
- $\Delta p_m$  = Observed velocity pressure using S-type pitot tube in preliminary traverse, inches W.C.
- $\Delta p_{max}$  = Maximum velocity pressure, inches W.C.
- $\Delta p_{min}$  = Minimum velocity pressure, inches W.C.
- $\Delta p_n$  = Velocity pressure measured at point n during the test run, inches W.C.
- $\Delta p_s$  = Velocity pressure calculated in Method 201a, Equation 25, inches W.C.
- $\Delta p_{s1}$  = Velocity pressure adjusted for combined cyclone pitot tube, inches W.C.
- $\Delta p_{s2}$  = Velocity pressure corrected for blockage, inches W.C.
- $\theta$  = Total run time, min
- $\rho_a$  = Density of acetone, mg/ml (see label on bottle)
- $\Sigma_n$  = total number of sampling points

**APPENDIX B**  
**UNIT OPERATION PARAMETERS**

## Florida Power and Light

<b>Air Permit # :</b>	PSD-FL-396
<b>Plant Name or Location:</b>	West County Energy Center
<b>Date:</b>	April 9, 2011
<b>Project Number:</b>	bv-10-westcounty.fl-comp#2
<b>Manufacturer &amp; Equipment:</b>	Mitsubishi
<b>Model:</b>	501G
<b>Unit Number:</b>	3B
<b>Test Load:</b>	Fuel Oil
<b>Tester(s) / Test Unit(s):</b>	JF/MV/SG/TS/CM/206

	UNITS	RUN		
		1	2	3
<b>Start Time</b>	hh:mm:ss	11:00:29	12:37:29	14:30:29
<b>End Time</b>	hh:mm:ss	12:12:29	14:13:59	15:44:59
<b>Bar. Pressure</b>	in. Hg	30.15	30.14	30.11
<b>Amb. Temp.</b>	°F	86	90	90
<b>Rel. Humidity</b>	%	43	39	42
<b>Spec. Humidity</b>	lb water / lb air	0.011325	0.011667	0.012595
<b>Comb. Inlet Pres.</b>	psig	260.4	258.0	256.3
<b>Ammonia Injection Rate</b>	lb/hr	444.2	438.2	437.0
<b>Turbine Fuel Flow</b>	gal/hr	15,691	15,509	15,395
<b>Total Fuel Flow</b>	SCFH	2,098	2,073	2,058
<b>Stack Moisture</b>	% Method 4	8.4	8.7	8.7
<b>Heat Input</b>	MMBtu/hr	2063.3	2039.4	2024.4
<b>Power Output</b>	megawatts	211.5	208.3	206.3

**UNIT OPERATION PARAMETERS**

**Fuel Oil Load**

Unit 3 Emissions Testing

	Combustor Inlet Pressure B psig	CT B Load MW	Ammonia Mass Flow CT B PPH	CT B Fuel Oil Flow lb/hr
09-Apr-11 11:00:00	261.63	213.37	431.44	112598.46
09-Apr-11 11:01:00	261.30	213.69	451.36	112579.63
09-Apr-11 11:02:00	261.48	212.01	458.59	112167.63
09-Apr-11 11:03:00	261.43	212.90	457.23	112224.97
09-Apr-11 11:04:00	261.74	214.15	426.98	112850.16
09-Apr-11 11:05:00	261.41	212.99	468.28	112534.88
09-Apr-11 11:06:00	260.98	211.68	498.71	111919.98
09-Apr-11 11:07:00	261.22	213.14	444.02	112485.73
09-Apr-11 11:08:00	261.07	212.13	452.89	112144.39
09-Apr-11 11:09:00	261.00	212.47	437.79	111987.59
09-Apr-11 11:10:00	261.21	212.56	424.45	112304.79
09-Apr-11 11:11:00	261.23	213.06	455.47	112339.44
09-Apr-11 11:12:00	261.26	212.13	469.57	112027.02
09-Apr-11 11:13:00	261.10	212.82	470.10	112251.59
09-Apr-11 11:14:00	260.91	212.47	470.39	112377.97
09-Apr-11 11:15:00	260.77	212.10	493.77	111866.58
09-Apr-11 11:16:00	260.80	211.50	471.13	111825.86
09-Apr-11 11:17:00	261.06	213.03	431.27	112297.83
09-Apr-11 11:18:00	260.97	212.07	461.11	111951.81
09-Apr-11 11:19:00	260.92	212.10	460.11	111895.58
09-Apr-11 11:20:00	260.98	213.38	430.45	112397.26
09-Apr-11 11:21:00	260.72	212.47	466.63	112007.73
09-Apr-11 11:22:00	260.40	211.58	20.40	111740.65
09-Apr-11 11:23:00	260.48	211.90	-0.34	111861.15
09-Apr-11 11:24:00	260.57	211.10	327.70	111743.80
09-Apr-11 11:25:00	260.66	211.49	565.62	111858.98
09-Apr-11 11:26:00	260.74	212.13	484.85	112073.89
09-Apr-11 11:27:00	260.60	211.95	450.24	111913.58
09-Apr-11 11:28:00	260.51	211.40	437.20	111730.08
09-Apr-11 11:29:00	260.58	211.68	456.47	111762.80
09-Apr-11 11:30:00	260.66	212.41	454.53	111990.80
09-Apr-11 11:31:00	260.53	212.23	468.98	112033.42
09-Apr-11 11:32:00	260.34	210.88	495.30	111577.29
09-Apr-11 11:33:00	260.34	211.49	481.38	111806.89
09-Apr-11 11:34:00	260.18	211.81	454.53	111894.49
09-Apr-11 11:35:00	260.01	211.07	534.19	111430.70
09-Apr-11 11:36:00	260.20	210.46	471.27	111523.59
09-Apr-11 11:37:00	260.35	211.87	399.49	111889.37
09-Apr-11 11:38:00	260.15	211.34	404.89	111816.81
09-Apr-11 11:39:00	260.02	210.73	441.96	111534.09
09-Apr-11 11:40:00	259.87	211.04	520.33	111610.54
09-Apr-11 11:41:00	259.84	211.20	448.54	111736.47
09-Apr-11 11:42:00	259.72	210.32	453.53	111364.02
09-Apr-11 11:43:00	259.76	210.68	426.51	111423.74
09-Apr-11 11:44:00	259.93	210.57	452.42	111440.60
09-Apr-11 11:45:00	260.17	210.94	459.20	111467.45
09-Apr-11 11:46:00	260.41	211.04	416.52	111806.41
09-Apr-11 11:47:00	260.47	211.46	409.47	111938.75
09-Apr-11 11:48:00	260.17	211.15	471.69	111653.42
09-Apr-11 11:49:00	260.05	211.25	470.22	111507.04
09-Apr-11 11:50:00	259.98	211.22	470.57	111584.62
09-Apr-11 11:51:00	259.92	210.55	464.17	111477.64
09-Apr-11 11:52:00	259.88	210.58	461.29	111446.71
09-Apr-11 11:53:00	259.85	211.00	439.96	111574.43
09-Apr-11 11:54:00	259.89	210.70	461.11	111327.98
09-Apr-11 11:55:00	260.01	210.91	417.87	111575.45
09-Apr-11 11:56:00	260.18	211.16	416.52	111912.45
09-Apr-11 11:57:00	259.87	210.30	466.46	111177.27
09-Apr-11 11:58:00	259.83	211.04	460.70	111492.92
09-Apr-11 11:59:00	259.94	211.28	447.72	111751.94
09-Apr-11 12:00:00	259.68	210.33	474.89	111326.82
09-Apr-11 12:01:00	259.55	209.97	459.23	111211.34
09-Apr-11 12:02:00	259.62	210.89	460.32	111423.90
09-Apr-11 12:03:00	259.56	210.33	460.47	111393.47
09-Apr-11 12:04:00	259.52	210.15	460.35	111335.91
09-Apr-11 12:05:00	259.65	210.21	460.00	111183.71
09-Apr-11 12:06:00	259.69	210.91	460.76	111596.32
09-Apr-11 12:07:00	259.70	210.52	462.87	111406.82
09-Apr-11 12:08:00	259.51	209.60	463.10	111092.66
09-Apr-11 12:09:00	259.46	210.46	460.70	111422.42
09-Apr-11 12:10:00	259.54	210.15	462.29	111286.16
09-Apr-11 12:11:00	259.20	209.70	461.76	111017.56
09-Apr-11 12:12:00	259.40	210.76	462.40	111540.27
Average	260.36	211.48	444.17	111777.08



Unit 3 Emissions Testing

	Combustor Inlet Pressure B psig	CT B Load MW	Ammonia Mass Flow CT B PPH	CT B Fuel Oil Flow lb/hr
09-Apr-11 12:37:00	258.34	210.09	448.13	111241.14
09-Apr-11 12:38:00	259.24	209.69	445.13	111250.41
09-Apr-11 12:39:00	258.97	206.94	442.25	110936.99
09-Apr-11 12:40:00	258.94	210.06	549.05	110992.78
09-Apr-11 12:41:00	258.94	209.63	439.38	111183.90
09-Apr-11 12:42:00	258.96	208.72	394.38	110763.99
09-Apr-11 12:43:00	259.06	210.06	387.74	111140.39
09-Apr-11 12:44:00	258.92	210.25	333.40	111353.37
09-Apr-11 12:45:00	258.77	208.59	450.30	110748.80
09-Apr-11 12:46:00	258.76	208.93	433.03	110840.02
09-Apr-11 12:47:00	258.73	208.75	409.41	111095.47
09-Apr-11 12:48:00	258.38	209.20	439.90	111032.98
09-Apr-11 12:49:00	258.16	207.25	482.44	110291.42
09-Apr-11 12:50:00	258.33	207.80	451.95	110444.10
09-Apr-11 12:51:00	258.75	209.43	413.47	111009.91
09-Apr-11 12:52:00	258.76	209.33	433.56	110847.86
09-Apr-11 12:53:00	258.59	208.90	467.57	110752.41
09-Apr-11 12:54:00	258.55	209.30	452.95	110865.09
09-Apr-11 12:55:00	258.44	208.47	468.04	110663.50
09-Apr-11 12:56:00	258.43	209.05	437.55	110637.52
09-Apr-11 12:57:00	258.55	209.17	435.20	110885.77
09-Apr-11 12:58:00	258.82	208.92	448.54	110731.84
09-Apr-11 12:59:00	258.54	208.75	469.34	110601.89
09-Apr-11 13:00:00	258.56	209.08	431.15	110960.06
09-Apr-11 13:01:00	258.54	208.27	517.51	110999.58
09-Apr-11 13:02:00	257.85	208.04	514.75	110516.63
09-Apr-11 13:03:00	257.68	208.70	425.28	110573.77
09-Apr-11 13:04:00	257.66	207.98	394.85	110189.56
09-Apr-11 13:05:00	257.75	206.67	407.65	109870.95
09-Apr-11 13:06:00	258.24	208.11	371.46	110580.08
09-Apr-11 13:07:00	258.02	208.53	366.71	110688.41
09-Apr-11 13:08:00	257.92	207.39	414.58	110158.53
09-Apr-11 13:09:00	257.99	208.76	435.97	110667.23
09-Apr-11 13:10:00	257.92	208.26	527.20	110551.03
09-Apr-11 13:11:00	257.82	207.89	506.41	110170.56
09-Apr-11 13:12:00	257.94	208.20	433.56	110275.45
09-Apr-11 13:13:00	258.35	209.12	378.56	110788.77
09-Apr-11 13:14:00	258.01	208.23	419.58	110551.81
09-Apr-11 13:15:00	257.99	207.83	502.70	110385.42
09-Apr-11 13:16:00	257.99	208.14	472.62	110701.36
09-Apr-11 13:17:00	257.74	207.94	439.26	110387.72
09-Apr-11 13:18:00	257.51	207.11	428.80	110081.52
09-Apr-11 13:19:00	257.55	207.95	407.95	110516.75
09-Apr-11 13:20:00	257.62	207.53	433.27	110168.91
09-Apr-11 13:21:00	257.30	207.01	452.53	110155.31
09-Apr-11 13:22:00	257.15	207.53	422.75	110291.94
09-Apr-11 13:23:00	257.43	206.95	438.38	109865.87
09-Apr-11 13:24:00	256.99	207.25	426.45	110269.23
09-Apr-11 13:25:00	257.19	207.65	486.37	110290.11
09-Apr-11 13:26:00	257.36	207.59	425.81	110228.94
09-Apr-11 13:27:00	257.01	206.30	394.55	109929.33
09-Apr-11 13:28:00	257.37	207.71	390.03	110026.23
09-Apr-11 13:29:00	257.37	206.85	494.07	109899.30
09-Apr-11 13:30:00	257.88	208.14	463.40	110296.78
09-Apr-11 13:31:00	258.12	208.29	457.70	110631.78
09-Apr-11 13:32:00	257.93	208.56	439.49	110539.02
09-Apr-11 13:33:00	257.74	207.91	471.74	110371.48
09-Apr-11 13:34:00	257.74	207.89	462.23	110305.30
09-Apr-11 13:35:00	257.85	208.17	514.57	110402.95
09-Apr-11 13:36:00	257.85	207.48	432.85	110214.80
09-Apr-11 13:37:00	257.83	207.86	401.90	110346.65
09-Apr-11 13:38:00	257.88	208.47	406.30	110494.95
09-Apr-11 13:39:00	257.85	207.68	446.68	110133.19
09-Apr-11 13:40:00	257.71	207.92	453.00	110439.34
09-Apr-11 13:41:00	257.71	207.83	436.67	110509.40
09-Apr-11 13:42:00	257.56	207.07	465.52	110015.95
09-Apr-11 13:43:00	257.77	208.39	471.69	110472.90
09-Apr-11 13:44:00	257.91	208.47	534.54	110463.25
09-Apr-11 13:45:00	257.79	207.92	487.72	110352.03
09-Apr-11 13:46:00	257.83	207.80	407.89	110288.73
09-Apr-11 13:47:00	257.89	207.95	384.74	110393.42
09-Apr-11 13:48:00	257.94	208.35	404.48	110354.18
09-Apr-11 13:49:00	258.11	208.62	444.78	110474.60
09-Apr-11 13:50:00	258.13	208.94	442.37	110653.98
09-Apr-11 13:51:00	258.07	208.41	483.08	110549.51
09-Apr-11 13:52:00	257.96	208.27	452.12	110479.55
09-Apr-11 13:53:00	257.83	207.83	453.77	110406.44
09-Apr-11 13:54:00	258.03	208.09	427.57	110336.27
09-Apr-11 13:55:00	257.96	209.11	413.23	110854.95
09-Apr-11 13:56:00	257.58	208.19	456.12	110508.23
09-Apr-11 13:57:00	257.37	207.14	218.20	110058.24
09-Apr-11 13:58:00	257.66	207.53	108.28	110135.77
09-Apr-11 13:59:00	257.81	208.87	512.04	110215.49
09-Apr-11 14:00:00	257.84	208.40	535.54	110390.23
09-Apr-11 14:01:00	257.76	207.83	503.35	110550.20
09-Apr-11 14:02:00	257.55	207.95	439.32	110327.42
09-Apr-11 14:03:00	257.52	206.55	475.68	109857.48
09-Apr-11 14:04:00	257.79	208.68	382.98	110573.08
09-Apr-11 14:05:00	257.45	208.35	402.95	110522.20
09-Apr-11 14:06:00	257.07	206.92	459.29	110111.38
09-Apr-11 14:07:00	257.09	207.08	461.05	109832.68
09-Apr-11 14:08:00	257.23	207.54	424.63	110178.27
09-Apr-11 14:09:00	257.61	207.40	414.41	110148.38
09-Apr-11 14:10:00	257.64	207.92	427.86	110332.23
09-Apr-11 14:11:00	257.82	208.11	439.26	110441.59
09-Apr-11 14:12:00	257.85	208.23	449.95	110363.13
09-Apr-11 14:13:00	258.02	208.11	436.26	110576.95
Average	257.98	208.26	438.16	110485.18

Unit 3 Emissions Testing

	Combustor Inlet Pressure B psig	CT B Load MW	Ammonia Mass Flow CT B PPH	CT B Fuel Oil Flow lb/hr
09-Apr-11 14:30:00	257.07	206.64	428.51	109934.91
09-Apr-11 14:31:00	257.01	207.07	499.36	110171.73
09-Apr-11 14:32:00	256.80	206.88	422.60	110025.44
09-Apr-11 14:33:00	256.52	206.55	396.37	109813.48
09-Apr-11 14:34:00	256.52	206.49	409.47	109715.06
09-Apr-11 14:35:00	256.55	206.34	447.42	109871.19
09-Apr-11 14:36:00	256.58	206.69	443.31	109842.71
09-Apr-11 14:37:00	256.58	206.88	432.85	109762.41
09-Apr-11 14:38:00	256.53	206.48	426.63	109699.93
09-Apr-11 14:39:00	256.68	206.09	451.42	109561.51
09-Apr-11 14:40:00	256.86	206.30	421.63	109977.29
09-Apr-11 14:41:00	257.03	206.92	414.94	110080.24
09-Apr-11 14:42:00	256.74	206.27	447.01	109747.91
09-Apr-11 14:43:00	256.76	207.25	440.90	110094.31
09-Apr-11 14:44:00	256.74	206.72	477.38	109840.88
09-Apr-11 14:45:00	256.60	206.46	447.48	109606.35
09-Apr-11 14:46:00	256.64	207.62	432.50	110157.83
09-Apr-11 14:47:00	256.64	206.35	470.33	109743.86
09-Apr-11 14:48:00	256.55	205.94	504.53	109599.49
09-Apr-11 14:49:00	256.90	207.01	461.88	110023.41
09-Apr-11 14:50:00	256.90	206.95	408.42	109836.01
09-Apr-11 14:51:00	256.67	206.37	386.21	109807.34
09-Apr-11 14:52:00	256.60	207.28	386.50	110144.88
09-Apr-11 14:53:00	256.36	206.85	437.97	109772.28
09-Apr-11 14:54:00	255.48	206.46	527.91	109800.38
09-Apr-11 14:55:00	255.95	205.62	427.98	109219.98
09-Apr-11 14:56:00	256.12	206.02	362.24	109505.51
09-Apr-11 14:57:00	256.45	206.79	356.19	109890.69
09-Apr-11 14:58:00	256.24	206.52	430.92	109701.04
09-Apr-11 14:59:00	256.15	205.45	495.83	109407.91
09-Apr-11 15:00:00	256.13	206.49	453.42	109761.77
09-Apr-11 15:01:00	256.22	206.18	443.02	109577.48
09-Apr-11 15:02:00	255.99	205.60	350.90	109213.55
09-Apr-11 15:03:00	256.23	206.11	376.69	109674.93
09-Apr-11 15:04:00	256.47	206.43	364.42	109694.22
09-Apr-11 15:05:00	256.17	205.74	438.44	109348.62
09-Apr-11 15:06:00	256.53	206.96	443.55	109916.11
09-Apr-11 15:07:00	256.60	206.12	480.20	109554.42
09-Apr-11 15:08:00	256.43	206.21	475.03	109622.76
09-Apr-11 15:09:00	256.58	207.43	435.97	109961.42
09-Apr-11 15:10:00	256.18	206.12	451.95	109798.73
09-Apr-11 15:11:00	256.13	205.60	449.42	109311.63
09-Apr-11 15:12:00	256.25	205.76	434.97	109504.41
09-Apr-11 15:13:00	256.35	206.40	425.16	109738.42
09-Apr-11 15:14:00	255.97	205.82	447.19	109647.06
09-Apr-11 15:15:00	255.60	204.99	465.05	109368.53
09-Apr-11 15:16:00	254.97	204.70	436.73	109213.89
09-Apr-11 15:17:00	255.74	204.82	402.84	109001.37
09-Apr-11 15:18:00	255.78	205.51	366.78	109314.58
09-Apr-11 15:19:00	256.39	206.15	498.77	109718.76
09-Apr-11 15:20:00	256.08	206.21	600.28	109612.09
09-Apr-11 15:21:00	255.82	205.73	417.35	109538.86
09-Apr-11 15:22:00	255.71	205.27	542.48	109193.53
09-Apr-11 15:23:00	255.83	205.82	422.40	109336.09
09-Apr-11 15:24:00	256.01	206.27	350.37	109750.26
09-Apr-11 15:25:00	256.08	206.12	431.21	109562.25
09-Apr-11 15:26:00	256.01	205.53	471.27	109387.23
09-Apr-11 15:27:00	256.22	205.95	426.39	109518.87
09-Apr-11 15:28:00	256.32	206.98	418.64	109676.70
09-Apr-11 15:29:00	256.23	206.88	428.35	109823.04
09-Apr-11 15:30:00	256.13	206.24	455.18	109648.83
09-Apr-11 15:31:00	255.86	206.18	455.24	109476.84
09-Apr-11 15:32:00	256.18	206.52	433.03	109680.04
09-Apr-11 15:33:00	256.29	206.15	432.62	109614.40
09-Apr-11 15:34:00	256.32	206.23	414.47	109662.23
09-Apr-11 15:35:00	256.37	206.46	424.60	109665.05
09-Apr-11 15:36:00	256.45	206.65	425.98	109690.27
09-Apr-11 15:37:00	256.53	206.03	479.15	109751.27
09-Apr-11 15:38:00	256.55	207.25	433.65	109982.31
09-Apr-11 15:39:00	256.36	206.62	518.51	109780.31
09-Apr-11 15:40:00	256.15	205.99	437.32	109685.12
09-Apr-11 15:41:00	256.03	206.13	428.92	109524.91
09-Apr-11 15:42:00	255.91	205.95	431.62	109490.55
09-Apr-11 15:43:00	255.78	205.65	385.15	109425.36
09-Apr-11 15:44:00	255.62	205.76	375.34	109463.73
Average	256.30	206.28	437.02	109669.85

**APPENDIX C**  
**CALIBRATION GAS CERTIFICATIONS**



AIR LIQUIDE

Air Liquide America  
Specialty Gases LLC



Scott™

# RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

## CERTIFICATE OF ACCURACY: EPA Protocol Gas

### Assay Laboratory

P.O. No.: ALAS-55510  
AIR LIQUIDE AMERICA SPECIALTY GASES LLC Project No.: 05-86523-002  
1290 COMBERMERE STREET  
TROY, MI 48083

### Customer

AIR LIQUIDE AMERICA L.P.  
AIR HYGIENE  
1319 NORTH PEORIA AVE  
TULSA OK 74106

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM019345      Certification Date: 05Apr2010      Exp. Date: 04Apr2013  
Cylinder Pressure\*\*\*: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	8.91 %	+/- 1%	Direct NIST and VSL
OXYGEN	12.1 %	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2300	01Nov2010	1D002807	23.04 %	CARBON DIOXIDE
NTRM 2350	01Dec2011	K016398	23.20 %	OXYGEN

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
PIR/2000/609015	01Apr2010	NDIR
CAI/110P/V03018	17Mar2010	PARAMAGNETIC

### ANALYZER READINGS

(Z = Zero Gas    R = Reference Gas    T = Test Gas    r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

#### CARBON DIOXIDE

Date: 09Apr2010      Response Unit: MV

Z1 = 0.00000	R1 = 100.0000	T1 = 56.20000
R2 = 100.0000	Z2 = 0.00000	T2 = 56.16000
Z3 = 0.00000	T3 = 56.24000	R3 = 100.1600
Avg. Concentration: 8.916 %		



Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999989193	
Constants:	A = -0.00227705
B = 0.142642211	C = -0.0004667
D = 0.0000133988	E = 0

#### OXYGEN

Date: 09Apr2010      Response Unit: %


Z1 = 0.00000	R1 = 23.20000	T1 = 12.11000
R2 = 23.20000	Z2 = 0.00000	T2 = 12.10000
Z3 = 0.00000	T3 = 12.09000	R3 = 23.19000
Avg. Concentration: 12.08 %		



Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999996862	
Constants:	A = -0.0380161
B = 1.001181055	C = 0
D = 0	E = 0

APPROVED BY: \_\_\_\_\_

*APR*



Air Liquide America  
Specialty Gases LLC



# RATA CLASS

*Dual-Analyzed Calibration Standard*

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

## CERTIFICATE OF ACCURACY: EPA Protocol Gas

### Assay Laboratory

P.O. No.: ALAS-56936  
AIR LIQUIDE AMERICA SPECIALTY GASES LLC Project No.: 05-88735-006  
1290 COMBERMERE STREET  
TROY, MI 48083

### Customer

AIR LIQUIDE AMERICA L.P.  
AIR HYGIENE  
1319 NORTH PEORIA AVE  
TULSA OK 74106

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM004185 Certification Date: 21Jun2010 Exp. Date: 20Jun2013  
Cylinder Pressure\*\*\*: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
CARBON DIOXIDE	19.1 %	+/- 1%	Direct NIST and VSL
OXYGEN	21.1 %	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2300	01Nov2010	1D002807	23.04 %	CARBON DIOXIDE
NTRM 2350	01Dec2011	K016398	23.20 %	OXYGEN

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
PIR/2000/609015	07Jun2010	NDIR
CAI/110P/V03018	11Jun2010	PARAMAGNETIC

### ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)


First Triad Analysis

Second Triad Analysis

Calibration Curve

#### CARBON DIOXIDE


Date: 21Jun2010	Response Unit: MV
Z1=0.00000 R1=100.0000 T1=90.42000	
R2=100.0000 Z2=0.00000 T2=90.50000	
Z3=0.00000 T3=90.50000 R3=100.0000	
Avg. Concentration: 19.07 %	



Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999986	
Constants:	A = -0.00585731
	B = 0.131065552 C = -0.0001375
	D = 1.12705E-05 E = 0

#### OXYGEN

Date: 21Jun2010	Response Unit: %
Z1=0.00000 R1=23.20000 T1=21.15000	
R2=23.20000 Z2=0.00000 T2=21.15000	
Z3=0.00000 T3=21.15000 R3=23.20000	
Avg. Concentration: 21.14 %	



Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999999	
Constants:	A = -0.00484606
	B = 0.999830474 C = 0
	D = 0 E = 0

Special Notes:

PART# AH095

APPROVED BY: \_\_\_\_\_

JEFF CROTEAU



Air Liquide America  
Specialty Gases LLC



# RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

## CERTIFICATE OF ACCURACY: Interference Free™ Multi-Component EPA Protocol Gas

**Assay Laboratory**

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: ALASG-55510

Project No.: 05-86916-005

**Customer**

AIR LIQUIDE AMERICA L.P.  
AIR HYGIENE  
1319 NORTH PEORIA AVE  
TULSA OK 74106

P

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: **AAL13310** Certification Date: **22Apr2010** Exp. Date: **21Apr2012**  
Cylinder Pressure\*\*\*: **2015 PSIG**

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
CARBON MONOXIDE	12.1 PPM	+/- 1%	Direct NIST and VSL
NITRIC OXIDE	12.1 PPM	+/- 1%	Direct NIST and VSL
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	12.1 PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September, 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2629	02Oct2010	KAL003166	25.21 PPM	CARBON MONOXIDE
	01Jun2010	KAL004325	20.36 PPM	NITRIC OXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR/0928621	02Apr2010	FTIR
ECO PHYSICS/CLD 84M/84M0359	19Apr2010	CHEMI

**ANALYZER READINGS**

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

**First Triad Analysis**

**Second Triad Analysis**

**Calibration Curve**

**CARBON MONOXIDE**

Date: 14Apr2010 Response Unit: PPM  
Z1 = -0.05307 R1 = 25.30663 T1 = 12.10338  
R2 = 25.31267 Z2 = -0.05306 T2 = 12.12388  
Z3 = -0.03830 T3 = 12.14423 R3 = 25.34334  
Avg. Concentration: 12.09 PPM

Date: 21Apr2010 Response Unit: PPM  
Z1 = -0.06291 R1 = 25.26965 T1 = 12.17129  
R2 = 25.30621 Z2 = -0.02751 T2 = 12.19590  
Z3 = 0.02191 T3 = 12.19939 R3 = 25.34779  
Avg. Concentration: 12.15 PPM

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = 9.99986E-1  
Constants: A = 0.00000E+0  
B = 8.81389E-1 C = 5.84000E-4  
D = 1.00000E-6 E = 0.00000E+0

**NITRIC OXIDE**

Date: 14Apr2010 Response Unit: MV  
Z1 = 0.00000 R1 = 20.33000 T1 = 12.05000  
R2 = 20.35000 Z2 = 0.00000 T2 = 12.05000  
Z3 = 0.00000 T3 = 12.05000 R3 = 20.34000  
Avg. Concentration: 12.11 PPM

Date: 21Apr2010 Response Unit: MV  
Z1 = 0.00000 R1 = 20.29000 T1 = 11.96000  
R2 = 20.28000 Z2 = 0.00000 T2 = 11.96000  
Z3 = 0.00000 T3 = 11.96000 R3 = 20.29000  
Avg. Concentration: 12.04 PPM

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = 0.999989  
Constants: A = 0.052499  
B = 0.998591 C = 0.000000  
D = 0.000000 E = 0.000000

Special Notes: AH072 Lot Number: 0586916005

APPROVED BY: Rob. McCrandall



Air Liquide America  
Specialty Gases LLC



# RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

## CERTIFICATE OF ACCURACY: Interference Free™ Multi-Component EPA Protocol Gas

**Assay Laboratory**

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: ALAS-56465

Project No.: 05-87288-002

**Customer**

AIR LIQUIDE AMERICA L.P.  
AIR HYGIENE  
1319 NORTH PEORIA AVE  
TULSA, OK 74106

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: **CC173507** Certification Date: **07May2010** Exp. Date: **06May2012**  
Cylinder Pressure\*\*\*: **2015 PSIG**

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
CARBON MONOXIDE	23.2 PPM	+/- 1%	Direct NIST and VSL
NITRIC OXIDE	23.4 PPM	+/- 1%	Direct NIST and VSL
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	23.6 PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2636	02Oct2011	KAL003744	240.8 PPM	CARBON MONOXIDE
NTRM 1684 1	15Oct2012	KAL004434	95.84 PPM	NITRIC OXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR//0928621	30Apr2010	FTIR
FTIR//0928621	09Apr2010	FTIR

**ANALYZER READINGS**

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**First Triad Analysis**

**Second Triad Analysis**

**Calibration Curve**

**CARBON MONOXIDE**

Date: 30Apr2010 Response Unit: PPM  
Z1=-0.00481 R1=241.9239 T1=23.39141  
R2=242.0561 Z2=-0.00195 T2=23.42998  
Z3=0.23106 T3=23.44974 R3=242.2529  
Avg. Concentration: 23.23 PPM

Date: 07May2010 Response Unit: PPM  
Z1=-0.00417 R1=240.9105 T1=23.18030  
R2=241.2416 Z2=0.00845 T2=23.21160  
Z3=0.28117 T3=23.35798 R3=241.2466  
Avg. Concentration: 23.13 PPM

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 9.99985E-1  
Constants: A = 0.00000E+0  
B = 5.06495E-1 C = 1.93000E-4  
D = 0.00000E+0 E = 0.00000E+0

**NITRIC OXIDE**

Date: 30Apr2010 Response Unit: PPM  
Z1=-0.03952 R1=95.90178 T1=23.28269  
R2=95.91071 Z2=-0.02811 T2=23.36449  
Z3=-0.00286 T3=23.37331 R3=96.05732  
Avg. Concentration: 23.33 PPM

Date: 07May2010 Response Unit: PPM  
Z1=-0.13287 R1=94.53774 T1=23.24871  
R2=95.07222 Z2=-0.00119 T2=23.38911  
Z3=0.07275 T3=23.45024 R3=95.38034  
Avg. Concentration: 23.53 PPM

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 9.99985E-1  
Constants: A = 0.00000E+0  
B = 9.98166E-1 C = 2.95000E-4  
D = 0.00000E+0 E = 0.00000E+0

Special Notes: AH074 Lot Number: 0587288002

APPROVED BY:

*Rob McCrandall*



AIR LIQUIDE

Air Liquide America  
Specialty Gases LLC



Scott™

# RATA CLASS

Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

## CERTIFICATE OF ACCURACY: EPA Protocol Gas

### Assay Laboratory

P.O. No.: 9092010  
AIR LIQUIDE AMERICA SPECIALTY GASES LLC Project No.: 05-80747-007  
1290 COMBERMERE STREET  
TROY, MI 48083

### Customer

AIR LIQUIDE AMERICA L.P.  
801 W NORTH CARRIER PKWY  
GRAND PRAIRIE TX 75050-1003

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: AAL687 Certification Date: 12Oct2009 Exp. Date: 11Oct2012  
Cylinder Pressure\*\*\*: 2000 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
METHANE	3.10 PPM	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1659 10	02Oct2013	ALM058053	9.920 PPM	METHANE

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
VARIAN/3400/7506	17Sep2009	TCD/FID

### ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)  
First Triad Analysis                      Second Triad Analysis                      Calibration Curve

#### METHANE

Date: 12Oct2009	Response Unit:AREA	
Z1=0.00000	R1=91476.00	T1=28119.00
R2=91405.00	Z2=0.00000	T2=28109.00
Z3=0.00000	T3=28107.00	R3=91478.00
Avg. Concentration: 3.100 PPM		



Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.99999124	
Constants:	A = 0.04550378
B = 0.000107911	C = 0
D = 0	E = 0

APPROVED BY:

ROBERT LESNIAK





AIR LIQUIDE

CERTIFICATION OF ANALYSIS

Interference Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121 Section 2.2, Procedure G-1

Customer: AIR HYGIENE
Location: TULSA, OK

Cylinder S/N: CC113394

Shipping Order Number: 33119767
Transfer Number: 33119767
Lot Number: SFS131210
Valve: CGA 350
Cylinder Pressure\*: 2000 PSIG
\*Cylinder should not be used when gas pressure is below 150 psig

P.O. Number: 9032901
Item Number: SGZCAH002

Assay Date: 24-Apr-2009

Expiration Date: 24-Apr-2012

Table with 3 columns: Components, Requested Concentration, Assay Concentration. Rows for Nitrogen and Methane.

Reference Standard(s) Employed For Analysis

Table with 9 columns: Certified Concentration and Uncertainty, Component, Balance, Cyl. No., SRM/PRM/Mix No., Exp. Date, Sample No., Type. Row for Methane.

Analytical Data

Table with columns: Component, Analyzer Information, Zero, Reference, Candidate, Result, Evaluation, Units, Area. Includes 'FIRST TRIAD ANALYSIS 24-Apr-2009' and 'Mean Analytical Result: 4.756 ppm'.

Analyst: [Signature] Eric Barron

Approved by: [Signature] Jason Unger



AIR LIQUIDE

Air Liquide America  
Specialty Gases LLC



Scott™

# RATA CLASS

## Dual-Analyzed Calibration Standard

1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

### CERTIFICATE OF ACCURACY: EPA Protocol Gas

#### Assay Laboratory

P.O. No.: 9081310  
AIR LIQUIDE AMERICA SPECIALTY GASES LLC Project No.: 05-79607-014  
1290 COMBERMERE STREET  
TROY, MI 48083

#### Customer

AIR LIQUIDE AMERICA L.P.  
AIR HYGIENE  
1319 NORTH PEORIA AVE  
TULSA OK 74106

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM004952 Certification Date: 08Sep2009 Exp. Date: 07Sep2012  
Cylinder Pressure\*\*\*: 1875 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
METHANE	8.46 PPM	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2751	01Nov2010	K022940	100.2 PPM	METHANE

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
VARIAN/3400/7506	17Aug2009	TCD/FID

### ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

#### METHANE


Date: 08Sep2009	Response Unit:AREA	
Z1=0.00000	R1=900184.0	T1=74841.00
R2=899931.0	Z2=0.00000	T2=74878.00
Z3=0.00000	T3=75055.00	R3=898275.0
Avg. Concentration:	8.460	PPM



Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999995113	
Constants:	A = 0.11264489
B = 0.000109556	C = 0
D = 0	E = 0

APPROVED BY:

ROBERT LESNIAK



## RECERTIFICATION OF ANALYSIS

### Interference Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121  
Section 2.2, Procedure G-1

Cylinder S/N: CC124363

Customer: AIR HYGIENE  
Location: TULSA, OK

Shipping Order Number: 33119767  
Transfer Number: 33119767  
Lot Number: SFS131619  
Valve: CGA 660  
Cylinder Pressure: 2000 PSIG  
\*Cylinder should not be used when  
gas pressure is below 150 psig

P.O. Number: 9032901  
Item Number: SGZCAH032

Assay Date: 29-Apr-2009

Expiration Date: 29-Apr-2011

Components	Requested Concentration	Assay Concentration
Nitrogen	Balance	Balance
Nitrogen Dioxide	45-50 ppm	47.6 ± 1.2 ppm

#### Reference Standard(s) Employed For Analysis

Certified Concentration and Uncertainty	Component	Balance	Cyl. No.	SRM/PRM/Mix No.	Exp. Date	Sample No.	Type
51.4 ± 1.2 ppm	Nitrogen Dioxide	Nitrogen	EB0009973	SFS119543	12-Jul-2010	BI	GMS

#### Analytical Data

Component:	Nitrogen Dioxide	FIRST TRIAD ANALYSIS 29-Jan-2009			SECOND TRIAD ANALYSIS 29-Apr-2009			Units		
		Zero	Reference	Candidate	Trial 1	Trial 2	Trial 3			
Analyzer Information	Fourier Transform IR				0.007	0.002	0.025	ppm		
Manufacturer:	MKS Instruments		INITIAL		51.223	51.248	51.247	ppm		
Model Number:	2031		ASSAY		47.290	47.394	47.422	ppm		
Serial Number:	10387278				Result	47.45	47.54	47.56	ppm	
MPR Last Calibrated:	29-Apr-2009	Evaluation	Valid	Valid	Evaluation	Valid	Valid			
Analytical Principle:	FTIR				Mean Analytical Result:	47.78	ppm	Mean Analytical Result:	47.52	ppm

Analyst: 

Tan Ngo

Approved by: 

Thuan Tran

**APPENDIX D**  
**QUALITY ASSURANCE AND QUALITY CONTROL DATA**

## QA/QC PROGRAM

Air Hygiene ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses five major areas:

1. QA reviews of reports, laboratory work, and field testing
2. Equipment calibration and maintenance
3. Chain-of-custody
4. Training
5. Knowledge of current test methods

Each of these areas is discussed individually below.

### QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

### Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program.

### Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

### Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3. A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

### Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

## COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describes each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within plus or minus two percent of the range of predicted values. NO<sub>2</sub> to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO<sub>2</sub> in a balance of nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one inch of Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

### INSTRUMENTAL ANALYSIS QUALITY ASSURANCE DATA

Date: April 9, 2011  
Company: Florida Power and Light  
Location: Loxahatchee, Florida  
Techs: JRF/MV


#### Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
April 9, 2011	1	0

Calibration Date: April 9, 2011  
 Client: Florida Power and Light


NOx Span (ppm) = 23.60

THERMO 42i-HL (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.03	0.13	0.03	YES (%)
12.10	12.35	1.06	0.25	YES (%)
23.60	23.17	-1.82	0.43	YES (%)
Linearity = 1.019				




CO Span (ppm) = 23.20

THERMO 48i (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.10	0.43	0.10	YES (%)
12.10	12.20	0.43	0.10	YES (%)
23.20	23.19	-0.04	0.01	YES (%)
Linearity = 1.005				




O<sub>2</sub> Span (%) = 21.10

THERMO 42i-HL (O <sub>2</sub> Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.01	0.05	0.01	YES (%)
12.10	12.28	0.85	0.18	YES (%)
21.10	21.47	1.75	0.37	YES (%)
Linearity = 0.983				



THC Range (ppm) = 10.5


THERMO 51C-HT (THC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail (±2,5%) <sup>1</sup>
0.00	0.11	1.05	N/A	YES
3.10	3.13	-3.29	3.23	YES
4.76	4.79	-2.39	4.90	YES
8.46	8.63	1.62	N/A	YES
Linearity = 0.973				



<sup>1</sup>zero/high based on 2% of span/low/mid based on 5% of concentration

CO<sub>2</sub> Span (%) = 19.10

THERMO 410i (CO <sub>2</sub> Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	-0.01	-0.05	0.01	YES (%)
8.91	9.12	1.10	0.21	YES (%)
19.10	19.17	0.37	0.07	YES (%)
Linearity = 0.996				



### NOx Converter Efficiency

Date: April 9, 2011

Analyzer: INST-N2-0001

RM 7E, (12-17-09), Sections 7.1.4; 8.2.4.1; 12.7; and 13.5 Introduce NO<sub>2</sub> to the analyzer and record the NOx concentration displayed. ... Calculate the converter efficiency using Equation 7E-7. The specification for converter efficiency must be met. ... Air Hygiene also references ALT-0013 for specific NO<sub>2</sub> concentration (40-60 ppm) and EPA Traceability Protocol requirements (±2%).

<b>Audit Gas:</b>	NO <sub>2</sub> Concentration (C <sub>v</sub> ), ppmvd	<b>47.60</b>
<b>Converter Efficiency Calculations:</b>		
	Analyzer Reading, NO Channel, ppmvd	<b>1.83</b>
	Analyzer Reading, NOx Channel, ppmvd	<b>48.37</b>
	Analyzer Reading, NO <sub>2</sub> Channel (C <sub>Dir(NO2)</sub> ), ppmvd	<b>46.54</b>
	Converter Efficiency, %	<b>97.77</b>

RM 7E, (08-15-06), 13.5 NO<sub>2</sub> to NO Conversion Efficiency Test (as applicable). The NO<sub>2</sub> to NO conversion efficiency, calculated according to Equation 7E-7 or Equation 7E-9, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left( \frac{C_{Dir}}{C_P} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{46.54 \text{ ppmvd}}{47.60 \text{ ppmvd}} \times 100 = 97.77\%$$

Date/Time mm/dd/yy hh:mm:ss	Elapsed Time Seconds	NOx ppmvd	NO ppmvd
04/09/11 07:55:29	2550	48.20	1.88
04/09/11 07:55:59	2580	48.23	1.87
04/09/11 07:56:29	2610	48.24	1.87
04/09/11 07:56:59	2640	48.26	1.87
04/09/11 07:57:29	2670	48.31	1.85
04/09/11 07:57:59	2700	48.34	1.84
04/09/11 07:58:29	2730	48.36	1.82
<b>04/09/11 07:58:59</b>	<b>2760</b>	<b>48.37</b>	<b>1.83</b>
04/09/11 07:59:29	2790	48.36	1.82
04/09/11 07:59:59	2820	48.36	1.82



DRIFT AND BIAS CHECK			
Strat Test Pre and Post QA/QC Check	O2	CO	NOx
Initial Zero	0.25	-0.06	0.09
Final Zero	0.47	-0.14	0.09
Avg. Zero	0.36	-0.10	0.09
Initial UpScale	12.38	12.15	12.01
Final UpScale	12.55	12.03	11.83
Avg. UpScale	12.47	12.09	11.92
Sys Resp (Zero)	0.01	0.10	0.03
Sys Resp (Upscale)	12.28	12.20	12.35
Upscale Cal Gas	12.10	12.10	12.10
Initial Zero Bias	1.14%	-0.69%	0.25%
Final Zero Bias	2.18%	-1.03%	0.25%
Zero Drift	1.04%	0.34%	0.00%
Initial Upscale Bias	0.47%	-0.22%	-1.44%
Final Upscale Bias	1.28%	-0.73%	-2.20%
Upscale Drift	0.81%	0.52%	0.76%
Alternative Sp. Alt. Min. Abs Diff			
Initial Zero	0.24	0.16	0.06
Final Zero	0.46	0.24	0.06
Initial Upscale	0.10	0.05	0.34
Final Upscale	0.27	0.17	0.52
Calibration Span	21.10	23.20	23.60
3% of Range (drift)	0.63	0.70	0.71
5% of Range (bias)	1.06	1.16	1.18

Response Time (min)	0.8	1.7	1.7
Sys. Response (min)	1.7		

Date/Time	O2	CO	NOx	INJECTIONS
mm/dd/yy hh:mm:ss	z %	s z ppm	s z ppm	s
04/09/11 09:19:49	13.80	6.42	9.82	
04/09/11 09:19:59	13.82	6.24	10.08	
04/09/11 09:20:09	13.82	6.11	10.13	
04/09/11 09:20:19	10.07	5.96	10.08	
04/09/11 09:20:29	0.92	6.11	10.13	
04/09/11 09:20:39	x 0.34	6.04	10.23	
04/09/11 09:20:49	0.29	6.08	8.16	
04/09/11 09:20:59	0.27	7.84	5.09	
04/09/11 09:21:09	0.26	9.91	6.64	
04/09/11 09:21:19	0.27	11.41	10.24	
04/09/11 09:21:29	0.26	12.00	x 11.51	x
04/09/11 09:21:39	0.25	12.12	11.83	
04/09/11 09:21:49	0.25	12.13	11.93	
04/09/11 09:21:59	0.25	12.03	11.94	
04/09/11 09:22:09	0.25	12.05	11.95	
04/09/11 09:22:19	0.24	12.13	11.98	
04/09/11 09:22:29	0.25	12.17	11.98	
04/09/11 09:22:39	0.25	12.18	11.99	
04/09/11 09:22:49	0.24	12.18	11.98	
04/09/11 09:22:59	0.24	12.08	11.98	
04/09/11 09:23:09	0.24	12.11	11.99	
04/09/11 09:23:19	0.24	12.08	12.00	
04/09/11 09:23:29	0.24	12.09	12.00	
04/09/11 09:23:39	0.23	12.06	12.01	
04/09/11 09:23:49	0.25	12.01	12.00	
04/09/11 09:23:59	0.25	12.10	12.00	
04/09/11 09:24:09	0.23	12.10	12.01	
04/09/11 09:24:19	0.24	12.16	12.00	
04/09/11 09:24:29	0.24	12.13	12.01	
04/09/11 09:24:39	0.24	12.19	12.01	x
04/09/11 09:24:49	0.24	12.12	12.02	
04/09/11 09:24:59	0.25	12.07	12.02	
04/09/11 09:25:09	2.61	12.16	12.02	
04/09/11 09:25:19	11.34	12.12	12.03	
04/09/11 09:25:29	12.26	x 11.13	12.02	
04/09/11 09:25:39	12.31	7.99	12.23	
04/09/11 09:25:49	12.34	4.50	8.94	
04/09/11 09:25:59	12.34	2.06	3.90	
04/09/11 09:26:09	12.34	0.72	1.64	
04/09/11 09:26:19	12.35	x 0.24	x 0.60	
04/09/11 09:26:29	12.36	0.00	0.24	

DRIFT AND BIAS CHECK						
Fuel Oil Load, Run - 1	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	13.68	8.63	5.67	0.08	5.52	
Corrected Average	13.63	8.58	5.79	0.40	5.37	
Initial Zero	0.03	0.11	-0.08	-0.40	0.00	
Final Zero	0.13	0.11	-0.16	-0.24	0.26	
Avg. Zero	0.08	0.11	-0.12	-0.32	0.13	
Initial UpScale	12.12	12.21	12.06	2.80	8.96	
Final UpScale	12.18	12.05	11.89	2.92	9.19	
Avg. UpScale	12.15	12.13	11.98	2.86	9.08	
Sys Resp (Zero)	0.01	0.03	0.10	0.11	-0.01	
Sys Resp (Upscale)	12.28	12.35	12.20	3.13	9.12	
Upscale Cal Gas	12.10	12.10	12.10	3.10	8.91	
Initial Zero Bias	0.09%	0.34%	-0.78%	-4.86%	0.05%	
Final Zero Bias	0.57%	0.34%	-1.12%	-3.33%	1.41%	
Zero Drift	0.47%	0.00%	0.34%	1.52%	1.36%	
Initial Upscale Bias	-0.76%	-0.59%	-0.60%	-3.14%	-0.84%	
Final Upscale Bias	-0.47%	-1.27%	-1.34%	-2.00%	0.37%	
Upscale Drift	0.28%	0.68%	0.73%	1.14%	1.20%	
Alternative Specification Abs Diff	Initial Zero	0.02	0.08	0.18	--	0.01
	Final Zero	0.12	0.08	0.26	--	0.27
	Initial Upscale	0.16	0.14	0.14	--	0.16
	Final Upscale	0.10	0.30	0.31	--	0.07
Calibration Span	21.10	23.60	23.20	10.50	19.10	
3% of Cal. Span (drift)	0.63	0.71	0.70	0.32	0.57	
5% of Cal. Span (bias)	1.06	1.18	1.16	0.53	0.96	

DRIFT AND BIAS CHECK						
Fuel Oil Load, Run - 2	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	13.69	9.18	5.64	0.50	5.78	
Corrected Average	13.64	9.20	5.81	0.70	5.37	
Initial Zero	0.13	0.11	-0.16	-0.24	0.26	
Final Zero	0.06	0.09	-0.06	-0.12	0.52	
Avg. Zero	0.10	0.10	-0.11	-0.18	0.39	
Initial UpScale	12.18	12.05	11.89	2.92	9.19	
Final UpScale	12.12	12.04	11.88	3.18	9.48	
Avg. UpScale	12.15	12.05	11.89	3.05	9.34	
Sys Resp (Zero)	0.01	0.03	0.10	0.11	-0.01	
Sys Resp (Upscale)	12.28	12.35	12.20	3.13	9.12	
Upscale Cal Gas	12.10	12.10	12.10	3.10	8.91	
Initial Zero Bias	0.57%	0.34%	-1.12%	-3.33%	1.41%	
Final Zero Bias	0.24%	0.25%	-0.69%	-2.19%	2.77%	
Zero Drift	0.33%	0.08%	0.43%	1.14%	1.36%	
Initial Upscale Bias	-0.47%	-1.27%	-1.34%	-2.00%	0.37%	
Final Upscale Bias	-0.76%	-1.31%	-1.38%	0.48%	1.88%	
Upscale Drift	0.28%	0.04%	0.04%	2.48%	1.52%	
Alternative Specification Abs Diff	Initial Zero	0.12	0.08	0.26	--	0.27
	Final Zero	0.05	0.06	0.16	--	0.53
	Initial Upscale	0.10	0.30	0.31	--	0.07
	Final Upscale	0.16	0.31	0.32	--	0.36
Calibration Span	21.10	23.60	23.20	10.50	19.10	
3% of Cal. Span (drift)	0.63	0.71	0.70	0.32	0.57	
5% of Cal. Span (bias)	1.06	1.18	1.16	0.53	0.96	

DRIFT AND BIAS CHECK						
Fuel Oil Load, Run - 3	O <sub>2</sub>	NOx	CO	VOC	CO <sub>2</sub>	
Raw Average	13.58	8.25	5.98	0.09	5.97	
Corrected Average	13.60	8.24	6.14	0.33	5.36	
Initial Zero	0.06	0.09	-0.06	-0.12	0.52	
Final Zero	0.02	0.09	-0.13	-0.41	0.63	
Avg. Zero	0.04	0.09	-0.10	-0.27	0.58	
Initial UpScale	12.12	12.04	11.88	3.18	9.48	
Final UpScale	12.06	12.10	11.90	3.05	9.62	
Avg. UpScale	12.09	12.07	11.89	3.12	9.55	
Sys Resp (Zero)	0.01	0.03	0.10	0.11	-0.01	
Sys Resp (Upscale)	12.28	12.35	12.20	3.13	9.12	
Upscale Cal Gas	12.10	12.10	12.10	3.10	8.91	
Initial Zero Bias	0.24%	0.25%	-0.69%	-2.19%	2.77%	
Final Zero Bias	0.05%	0.25%	-0.99%	-4.95%	3.35%	
Zero Drift	0.19%	0.00%	0.30%	2.76%	0.58%	
Initial Upscale Bias	-0.76%	-1.31%	-1.38%	0.48%	1.88%	
Final Upscale Bias	-1.04%	-1.06%	-1.29%	-0.76%	2.62%	
Upscale Drift	0.28%	0.25%	0.09%	1.24%	0.73%	
Alternative Specification Abs Diff	Initial Zero	0.05	0.06	0.16	--	0.53
	Final Zero	0.01	0.06	0.23	--	0.64
	Initial Upscale	0.16	0.31	0.32	--	0.36
	Final Upscale	0.22	0.25	0.30	--	0.50
Calibration Span	21.10	23.60	23.20	10.50	19.10	
3% of Cal. Span (drift)	0.63	0.71	0.70	0.32	0.57	
5% of Cal. Span (bias)	1.06	1.18	1.16	0.53	0.96	

**METERING SYSTEM DRY GAS METER CALIBRATION SHEET**

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0010

Filename: C:\Users\jahrenkamp\AppData\Local\Microsoft\Windows\Temporary Internet Files\Content.Outlook\K5ZODGNTC\SAMP-CP-0010 Calibration 3-4-11.xls\3-4-11 (5 point)

Make: Thermo Environmental

Date: 03/04/11

Model #: MST-C1

Barometric Pressure: 29.85 (in. Hg)

Serial #: 90693

Theoretical Critical Vacuum: 14.08 (in. Hg)

DRY GAS METER READINGS						
ΔH (in. H <sub>2</sub> O)	Time (min)	Volume			Initial Temperature	
		Initial (ft <sup>3</sup> )	Final (ft <sup>3</sup> )	Total (ft <sup>3</sup> )	Inlet (°F)	Outlet (°F)
0.78	17.00	91.440	100.260	8.820	84.0	79.0
1.10	12.00	100.260	107.390	7.130	77.0	77.0
1.40	10.00	107.390	114.280	6.890	75.0	75.0
2.30	10.00	114.280	123.040	8.760	75.0	75.0
3.50	10.00	123.040	133.620	10.580	75.0	74.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
77.0	77.0	15	0.3865	16.0	69.6	70.0	69.8
75.0	75.0	17	0.4454	16.0	70.0	70.0	70.0
75.0	75.0	19	0.5196	16.0	70.0	70.2	70.1
75.0	74.0	25	0.6642	15.5	70.2	70.2	70.2
77.0	74.0	30	0.8090	14.5	70.0	69.8	69.9

RESULTS				
DRY GAS METER		ORIFICE		
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL
Vm(std) (ft <sup>3</sup> )	Vm(std) (liters)	Vcr(std) (ft <sup>3</sup> )	Vcr(std) (liters)	Vcr (ft <sup>3</sup> )
8.629	244.37	8.521	241.3	8.573
7.023	198.90	6.930	196.3	6.975
6.805	192.71	6.737	190.8	6.782
8.675	245.66	8.610	243.8	8.670
10.503	297.44	10.490	297.1	10.557

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H <sub>2</sub> O)	Value (mm H <sub>2</sub> O)	Variation (in. H <sub>2</sub> O)
-0.004	0.987	1.710	43.43	-0.035
-0.004	0.987	1.823	46.31	0.078
-0.001	0.990	1.709	43.40	-0.037
0.001	0.993	1.720	43.68	-0.025
0.008	0.999	1.765	44.82	0.019
<b>AVERAGE:</b>	<b>0.991</b>	<b>1.745</b>	<b>44.33</b>	<b>PASSED</b>

Notes:

For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H<sub>2</sub>O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).

SIGNATURE: \_\_\_\_\_

*Craig McCarty*

DATE: 03/04/11 03/04/11

**METERING SYSTEM THERMOCOUPLE CALIBRATION SHEET**

**EPA Reference Method**

**Metering System Pre-Test Calibration**

**Air Hygiene Asset ID: samp-cp-0010**

Filename: C:\Users\jfhienkamp\AppData\Local\Microsoft\Windows\Temporary Internet Files\Content.Outlook\5ZODGNTC[SAMP-CP-0010 Calibration 3-4-11.xls]3-4-11 (5 point)

Make: Thermo Environmental

Date:

Model #: MST-C1

Barometric Pressure: 29.85 (in. Hg)

Serial #: 90693

Temperature (ASTM cal): 67.90 (°F)

Thermocouple	100 (°F)		600 (°F)		1200 (°F)	
	Reading	% Error	Reading	% Error	Reading	% Error
Stack	99.00	0.50	600.00	0.00	1197.00	0.25
Probe	100.00	0.00	601.00	0.17	1197.00	0.25
Filter	100.00	0.00	601.00	0.17	1197.00	0.25
Dryer	99.00	0.50	600.00	0.00	1197.00	0.25
Aux.	99.00	0.50	600.00	0.00	1197.00	0.25

Note: Calibrated against an ALTEK Thermocouple Source Series 22, direct temperature output calibrated to ASTM and IPTS standards as outlined in ALTEK Data Sheet 22.

Thermocouple	67.90 (°F)	
	Reading	(±°F)
DGM In	68.0	0.10
DGM Out	68.0	0.10

Note: Calibrated against ASTM Reference Thermometer.

SIGNATURE: Craig McCarty

DATE: 03/04/11 03/04/11

Standard for Calibration of Console Thermocouple Systems

40 CFR, Part 60

Appendix A, Method 5

10.3.2 The temperature data recorded in the field shall be considered valid. If, during calibration, the absolute temperature measured with the sensor being calibrated and the reference sensor **agree within 1.5 percent**, the temperature data taken in the field shall be considered valid.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall **agree to within ±2°F**.

**PROBE (STACK), HOTBOX (FILTER), AND GOOSENECK (EXIT) THERMOCOUPLE CALIBRATION SHEET**

EPA Reference Method

Metering System Pre-Test Calibration

Air Hygiene Asset ID(s):

Probe: samp-hp-0052

Hotbox: samp-bh-0014

Gooseneck: samp-ad-0034

Filename: C:\Users\jahrenkamp\AppData\Local\Microsoft\Windows\Temporary Internet Files\Content.Outlook\SZODGNTC\SAMP-CP-0010 Calibration 3-4-11.xls\3-4-11 (5 point)

Barometric Pressure: 29.85

Thermo-couples	Temps (°F)		Signature	Date	
	Ref	Read			
Stack	Ref	68.00	<i>Craig McCarty</i>	03/04/11	03/04/11
	Read	68.00			
	±°F	0.00			
Filter	Ref	68.00	<i>Craig McCarty</i>	03/04/11	03/04/11
	Read	68.00			
	±°F	0.00			
Exit	Ref	68.00	<i>Craig McCarty</i>	03/04/11	03/04/11
	Read	68.00			
	±°F	0.00			

Note: Calibrated against ASTM Reference Thermometer.

Standard for Calibration of Individual Thermocouples

EMC, ALT-011: After each test run series, check the accuracy (and, hence, the calibration) of each thermocouple system at ambient temperature, or any other temperature, within the range specified by the manufacturer, using a reference thermometer (either ASTM reference thermometer or a thermometer that has been calibrated against an ASTM reference thermometer). The temperatures of the thermocouple and reference thermometers shall agree to within ±2°F.

## NOZZLE CALIBRATION SHEET

**NOZZLE SET IDENTIFICATION:** SAMP-NS-0001  
**CALIBRATION DATE:** April 22, 2010  
**CALIPER NUMBER:** SAMP-DC-0011  
**NAME OF CALIBRATOR:** Jake Fahlenkamp

NOZZLE I.D.	DIAMETER	AVERAGE DIAMETER	EPA Method 5, Sec. 10.1 Criteria
I#4	0.109	0.108	PASS
	0.108		
	0.106		
I#6	0.174	0.175	PASS
	0.176		
	0.175		
I#8	0.234	0.232	PASS
	0.231		
	0.232		
I#10	0.311	0.309	PASS
	0.309		
	0.308		
I#12	0.357	0.357	PASS
	0.357		
	0.356		
I#14	0.433	0.434	PASS
	0.436		
	0.434		
I#16	0.488	0.489	PASS
	0.491		
	0.489		

**METERING SYSTEM DRY GAS METER CALIBRATION SHEET**

EPA Reference Method

Metering System Post-Test Calibration

Air Hygiene Asset ID: samp-cp-0010

Filename: C:\Users\Pandu\Desktop\Westcounty 3A finished work[SAMP-CP-0010 Calibration 3-4-11-PS.xlsx]4-26-2011 3 pts

Make: Thermo Environmental

Date: 04/26/11

Model #: MST-C1

Barometric Pressure: 29.93 (in. Hg)

Serial #: 90693

Theoretical Critical Vacuum: 14.12 (in. Hg)

**DRY GAS METER READINGS**

ΔH (in. H2O)	Time (min)	Volume			Initial Temperature	
		Initial (ft³)	Final (ft³)	Total (ft³)	Inlet (°F)	Outlet (°F)
1.40	10.00	571.100	577.935	6.835	84.0	84.0
1.40	10.00	577.935	584.760	6.825	86.0	84.0
1.40	10.00	584.760	591.580	6.820	88.0	85.0

Final Temperature		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in. Hg)	Ambient Temperature		
Inlet (°F)	Outlet (°F)				Initial (°F)	Final (°F)	Average (°F)
86.0	84.0	19	0.5196	16.0	79.2	79.1	79.2
88.0	85.0	19	0.5196	16.0	79.1	79.0	79.1
89.0	86.0	19	0.5196	16.0	79.0	79.0	79.0

**RESULTS**

DRY GAS METER		ORIFICE		
VOLUME CORRECTED Vm(std) (ft³)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (ft³)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft³)
6.650	188.33	6.698	189.7	6.840
6.625	187.63	6.698	189.7	6.839
6.605	187.06	6.699	189.7	6.839

40 CFR - CHAPTER I - PART 60  
Appendix A, Method 5  
10.3.2 Calibration After Use  
After each field use, the calibration of the metering system shall be checked by performing three calibration runs at a single, intermediate orifice setting (based on the previous field test)....Calculate the average value of the DGM calibration factor. If the value has changed by more than 5 percent, recalibrate the meter over the full range of orifice settings, as detailed in Section 10.3.1.


DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in. H2O)	Value (mm H2O)	Variation (in. H2O)
-0.004	1.007	1.704	43.29	0.002
0.000	1.011	1.703	43.24	0.000
0.003	1.014	1.699	43.16	-0.003
<b>AVERAGE:</b>	<b>1.011</b>	<b>1.702</b>	<b>43.23</b>	<b>PASSED</b>

10.3.3 Acceptable Variation in Calibration  
If the DGM coefficient values obtained before and after a test series differ by more than 5 percent, the test series shall either be voided, or calculations for the test series shall be performed using whichever meter coefficient value (i.e., before or after) gives the lower value of total sample volume.

<b>LAST 5-PT:</b>	<b>0.991</b>	<b>1.745</b>	<b>PASSED</b>	5-PT Date:
<b>% DIFF:</b>	<b>2.0%</b>	<b>2.5%</b>		03/04/11

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H<sub>2</sub>O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).

SIGNATURE



tim page

DATE: 04/26/11 04/26/11



# VISIBLE EMISSIONS EVALUATOR

This is to certify that

**SIDNEY GASTON**

met the specifications of Federal Reference Method 9 and qualifies as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, NC. This certificate is valid for six months from date of issue.

10/20/2010 DATE OF SCHOOL	390521 CERT NUMBER	TULSA, OK SCHOOL LOCATION
4/21/2011 CERTIFICATION EXP DATE		GAS748176 STUDENT ID NUMBER
<i>Jody Monk</i> Director of Training		

## EASTERN TECHNICAL ASSOCIATES

**SIDNEY GASTON**

GAS748176 STUDENT ID NUMBER

met the specifications of Federal Reference Method 9 and qualifies as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, NC. This certificate is valid for six months from date of issue and expires on the date below.

TULSA, OK SCHOOL LOCATION	10/20/2010 DATE OF SCHOOL	390521 CERT NUMBER
TULF10 LAST LECTURE	4/21/2011 CERTIFICATION EXP DATE	BEARER

Customer Support  
Debbie Scalise

debbie@smokeschool.com

Want to know when we will  
be in your area? Join our  
emailing list at  
www.smokeschool.com

919-878-3188

**APPENDIX E**  
**FUEL ANALYSIS RECORDS**

**Client:** Florida Power and Light  
**Location:** West County Energy Center  
**Date:** April 9, 2011  
**Project #:** bv-10-westcounty.fl-comp#2

**Fuel Oil - Fuel Analysis**

Characteristics of Fuel Gas	
Molecular Weight of oil =	15.410 lb/lb-mole
Btu per lb. of oil =	19,665.00 gross (HHV)
Btu per lb. of oil =	18,459.000 net (LHV)
Density of fuel oil <sup>2</sup> =	53.2889 lb/cu. ft
Density of fuel oil <sup>2</sup> =	7.1237 lb/gal
Specific Gravity =	0.8554 @ 68 deg F

Standardized to 68 deg F and 14.696 psia

Component	Wt%
carbon	85.76
oxygen	0.00
hydrogen	14.24
nitrogen	0.00
helium	0.00
sulfur	0.00
<b>Total</b>	<b>100.00</b>

Fuel Oil HHV Conv.	
HHV (Btu/lb)	19,665.00
HHV (Btu/SCF)	1,047,927

Fuel Oil LHV Conv.	
LHV (Btu/lb)	18,459.00
LHV (Btu/SCF)	983,660

<b>F-Factor (SCF dry exhaust per MMBtu [HHV]) = 9,308.23</b> (Based on EPA RM-19) at 68 deg F and 14.696 psia
--

**F-Factor Calculation:**

$$F\text{-Factor} = 1,000,000 * ((3.64 * \%H) + (1.53 * \%C) + (0.57 * \%S) + (0.14 * \%N) - (0.46 * \%O)) / GCV$$

GCV = Gross Btu per lb. of gas (HHV)

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

Density of fuel oil based on lab analysis or specific gravity multiplied by density of water at 68 deg F and 14.696 psia.

**References:**

- <sup>1</sup> ASTM D 3588
- <sup>2</sup> Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg
- <sup>3</sup> Mark's Standard Handbook for Mechanical Engineers, 10th ed. - Eugene A. Avallone, Theodore Baumeister III
- <sup>4</sup> Introduction to Fluid Mechanics, 3rd ed. - William S. Janna
- <sup>5</sup> GPA Reference Bulletin 181-86, revised 1986, reprinted 1995



HOUSTON LABORATORIES  
 8620 INTERCHANGE DRIVE  
 HOUSTON, TEXAS 77054  
 PHONE (713) 660-0901

## Certificate of Analysis

Number: 1030-2011040294-002A

Albert Septiano  
 Air Hygiene  
 5634 S. 122nd East Ave.  
 Suite F  
 Tulsa OK 74146

May 11, 2011

Sample ID: Unit 3B  
 Project Name :  
 Project Number :  
 Project Location: Tulsa, OK.  
 Sample Point:

Sampled By:  
 Sample Of: Liquid  
 Sample Date: 04/09/2011  
 Sample Condition:  
 PO / Ref. No:

### ANALYTICAL DATA

Test	Method	Result	Unit	Detection Limit	Lab Tech.	Date Analyzed
Heat of Combustion	ASTM-D-240	19665	Gross BTU / lb		EM	04/26/11
Heat of Combustion	ASTM-D-240	18459	Net BTU/lb		EM	04/26/11
Heat of Combustion	ASTM-D-240	NR	Gross BTU/Gal		EM	04/26/11
Heat of Combustion	ASTM-D-240	NR	Net BTU/Gal		EM	04/26/11
API Gravity @ 60 °F	ASTM-D-5002	36.48	°		BAC	04/15/11
Specific Gravity @ 60/60 °F	ASTM-D-5002	0.8424			BAC	04/15/11
Density @ 60 °F	ASTM-D-5002	0.8415	g/ml		BAC	04/15/11
Sulfur in Liq. Hydrocarbon by UV	ASTM-D-5453	0.0007	wt %		EM	04/26/11

**Comments:**

NR= No result  
 Sample On: 04/09/2011

Hydrocarbon Laboratory Manager

Quality Assurance: The above analyses are performed in accordance with ASTM, UOP or GPA guidelines for quality assurance, unless otherwise stated.



HOUSTON LABORATORIES  
 8920 INTERCHANGE DRIVE  
 HOUSTON, TEXAS 77054  
 PHONE (713) 660-0901

## Certificate of Analysis

Number: 1030-2011040294-002B

Albert Septiano  
 Air Hygiene  
 5634 S. 122nd East Ave.  
 Suite F  
 Tulsa OK 74146

May 03, 2011

Sample ID: Unit 3B  
 Project Name :  
 Project Number :  
 Project Location: Tulsa, OK.  
 Sample Point:

Sampled By:  
 Sample Of:  
 Sample Date: 04/09/2011  
 Sample Condition:  
 PO / Ref. No:

### ANALYTICAL DATA

Test	Method	Result	Unit	Detection Limit	Lab Tech.	Date Analyzed
Wt% of Carbon	ASTM-D-5291	85.76	wt%	0.30	EM	05/03/11
Wt% of Hydrogen	ASTM-D-5291	14.24	wt%	0.30	EM	05/03/11
Wt% of Nitrogen	ASTM-D-5291	<0.30	wt%	0.30	EM	05/03/11

**Comments:**

Sample On: 04/09/2011

Hydrocarbon Laboratory Manager

Quality Assurance: The above analyses are performed in accordance with ASTM, UOP or GPA guidelines for quality assurance, unless otherwise stated.

LOGOS #157295 6/01 WCS



Air Hygiene International, Inc.  
5634 S. 122nd East Ave, Suite F  
Tulsa, Oklahoma 74146  
(888) 461-8778  
www.airhygiene.com

### SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

Project Number:		bv-10-westcounty.fl-comp#2		Laboratory Analysis Requested:			
Person Taking Samples:		JRF					
Sample Number	Location	Date	Volume	Analysis Method			
				ASTM D 920	ASTM D 5002	ASTM D 5453-00	
01	Unit 3C	4/8		X	X	X	
02	Unit 3B	4/10		X	X	X	
email to: jake@airhygiene.com							
Sulfur reported in gr/100 dscf, wt%, and ppmw							
Report LHV and HHV							
Relinquished by: (Signature)		Date: 4/14/11	Time: 9:00	Received by: (Signature)		Date: 4/15/11	Time:
Relinquished by: (Signature)		Date:	Time:	Received by: (Signature)		Date:	Time:

Copy of Chain of Custody-AHI v1.1

**APPENDIX F**  
**STRATIFICATION TEST DATA**

Source Information	
<b>Company</b>	Florida Power and Light
<b>Plant Name</b>	West County Energy Center
<b>Equipment</b>	Mitsubishi 501G
<b>Location</b>	Loxahatchee, Florida

Test Information	
<b>Date</b>	04/09/11
<b>Project #</b>	bv-10-westcounty.fl-comp#2
<b>Unit Number</b>	3B
<b>Load</b>	Fuel Oil
<b>Number of Ports Available</b>	4
<b>Number of Ports Used</b>	4

Stack and Test Type	
<input type="radio"/> Isokinetic Traverse (Wet Chemistry Testing) <input type="radio"/> Velocity Traverse (Flow and Flow RATA Test) <input checked="" type="radio"/> <b>Stratification Traverse (Compliance Test)</b> <input type="checkbox"/> RM 20 <input type="radio"/> Stratification Traverse (RATA) <input type="checkbox"/> Part 60 <input type="checkbox"/> Part 75	<b>Circular Stack</b>

10-westcounty.fl-comp#2-U3B-strat



**METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE**

Company	Florida Power and Light	Date	04/09/11
Plant Name	West County Energy Center	Project #	bv-10-westcounty.fl-comp#2
Equipment	Mitsubishi 501G	# of Ports Available	4
Location	Loxahatchee, Florida	# of Ports Used	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L <sub>fw</sub> )	282.38	in.
Distance to Near Wall of Stack	(L <sub>nw</sub> )	19.00	in.
Diameter of Stack	(D)	263.38	in.
Area of Stack	(A <sub>s</sub> )	378.35	ft <sup>2</sup>



Distance from Disturbances to Port			
Distance Upstream	(A)	144.00	in.
Diameters Upstream	(A <sub>D</sub> )	0.55	diameters
Distance Downstream	(B)	531.75	in.
Diameters Downstream	(B <sub>D</sub> )	2.02	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of <sup>1</sup> Traverse Points		Minimum Number of Traverse Points	
Down (B <sub>D</sub> )	Up (A <sub>D</sub> )	Particulate	Velocity	Comp Stratification	
Stream	Stream	Points	Points	Criteria	Points
2.00-4.99	0.50-1.24	24	16	RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12	12 points	
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>= 2.00	8 or 12 <sup>2</sup>	8 or 12 <sup>2</sup>	Minimum Number of Traverse Points	
Upstream Spec		24	16	RATA Stratification	
Downstream Spec		24	16		
Traverse Pts Required		24	16	Criteria	Points
				Par75/60	12 RM1 pts
				75 abrv (a)	3 points
				75 abrv (b)	6 points

<sup>1</sup> Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.  
<sup>2</sup> 8 for Circular Stacks 12 to 24 inches  
 12 for Circular Stacks over 24 inches

Number of Traverse Points Used				
4	Ports by	3	Pts / port	Stratification Traverse
12	Pts Used	12	Required	(Compliance Test)

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	11 5/8	30 5/8
2	14.6%	38 4/8	57 4/8
3	29.6%	78	97
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



**STRATIFICATION TRAVERSE (COMPLIANCE TEST) RESULTS**

<b>Company</b>	Florida Power and Light		<b>Date</b>	04/09/11
<b>Plant Name</b>	West County Energy Center		<b>Project #</b>	bv-10-westcounty.fl-comp#2
<b>Equipment</b>	Mitsubishi 501G		<b># of Ports Available</b>	4
<b>Location</b>	Loxahatchee, Florida		<b># of Ports Used</b>	4

Stack Dimensions				Traverse Data			
<b>Diameter or Length of Stack</b>	(D)	263.38	in.	4	<b>Ports by</b>	3	<b>Pts / port</b>
<b>Width of Stack</b>	(W)		in.	12	<b>Pts Used</b>	12	<b>Required</b>
<b>Area of Stack</b>	(A <sub>s</sub> )	378.35	ft <sup>2</sup>	<b>Run Start</b>	9:40:29	<b>Run End</b>	10:35:59

Traverse Point	Time Per Point	Point Start Time	Point Stop Time (Reading)	O2	Percent Difference	CO	Percent Difference	NOx	Percent Difference
	min.	hh:mm:ss	hh:mm:ss	%	%	ppm	%	ppm	%
D-3	3.50	9:40:29	9:43:59	13.89	0.55%	6.35	5.91%	8.48	5.47%
D-2	3.50	9:43:59	9:47:29	13.93	0.27%	6.47	7.91%	7.56	5.97%
D-1	3.50	9:47:29	9:50:59	13.91	0.41%	5.83	2.77%	8.32	3.48%
C-3	6.50	9:50:59	9:57:29	13.95	0.13%	6.01	0.24%	8.93	11.07%
C-2	3.50	9:57:29	10:00:59	13.94	0.20%	5.37	10.44%	9.77	21.52%
C-1	3.50	10:00:59	10:04:29	13.95	0.13%	4.78	<b>20.28%</b>	9.59	19.28%
B-3	5.50	10:04:29	10:09:59	13.98	0.09%	6.38	6.41%	7.68	4.48%
B-2	3.50	10:09:59	10:13:29	13.97	0.02%	5.78	3.60%	7.43	7.59%
B-1	3.50	10:13:29	10:16:59	13.99	0.16%	6.03	0.57%	6.64	17.41%
A-3	12.00	10:16:59	10:28:59	14.01	0.30%	6.34	5.74%	8.95	11.32%
A-2	3.50	10:28:59	10:32:29	14.03	0.45%	6.17	2.90%	7.39	8.08%
A-1	3.50	10:32:29	10:35:59	14.06	<b>0.66%</b>	6.44	7.41%	5.74	<b>28.61%</b>
<b>Average</b>				13.97		6.00		8.04	

**STRAT TEST DETERMINED SAMPLE POINTS FOR CIRCULAR STACK**

<b>Company</b>	Florida Power and Light	<b>Date</b>	04/09/11
<b>Plant Name</b>	West County Energy Center	<b>Project #</b>	bv-10-westcounty.fl-comp#2
<b>Equipment</b>	Mitsubishi 501G	<b># of Ports Available</b>	4
<b>Location</b>	Loxahatchee, Florida	<b># of Ports Used</b>	4

Stack Dimensions				Traverse Data			
<b>Diameter or Length of Stack</b>	(D)	263.38	in.	4	<b>Ports by</b>	3	<b>Pts / port</b>
<b>Width of Stack</b>	(W)		in.	12	<b>Pts Used</b>	12	<b>Required</b>
<b>Area of Stack</b>	(A <sub>s</sub> )	378.35	ft <sup>2</sup>	<b>Run Start</b>	9:40:29	<b>Run End</b>	10:35:59

40 CFR 60, Appendix A, Method 7E Criteria					
Stratification Results		Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
<b>Maximum Percent Difference</b>	28.61 % for NO <sub>x</sub>				
<b>Maximum Pollutant Conc. Diff.</b>	2.30 ppm for NO <sub>x</sub>				
<b>Maximum Diluent Conc. Diff.</b>	0.09 % for O <sub>2</sub>				
<b>Stack Diameter</b>	263.38 in.		%	in.	in.
Stratification Conclusions		1			
<b>Maximum % Diff.</b>	Percent Diff. >10% Failed Stratification Test	2			
<b>Maximum Conc. Diff.</b>	Conc. Diff. > 0.5%	3			
<b>Stack Diameter</b>	D > 93.6 in.				

Use RM 1 Measurement Points and Sample Full Stack

<b>Test Type</b>	<input type="checkbox"/> Moisture, for MW	<input type="checkbox"/>
	<input type="checkbox"/> Moisture, for wet-to-dry	<input type="checkbox"/> 6.5.6(b)(2) alt. points do not apply
	<input type="checkbox"/> Gas	

