

Sheplak, Scott

From: Sheplak, Scott
Sent: Thursday, July 02, 2009 10:42 AM
To: 'Washington, Kevin'
Cc: Vielhauer, Trina; James_Stormer@doh.state.fl.us
Subject: RE: EMERGENCY GENERATORS - FPL WEST COUNTY ENERGY CENTER

Re: Facility ID No. 0990646

~~-file-~~

Thank you for the notification. They are most likely "insignificant." A copy of this e-mail will be kept on file here.

From: Washington, Kevin [mailto:Kevin.Washington@fpl.com]
Sent: Thursday, July 02, 2009 10:31 AM
To: Vielhauer, Trina; Sheplak, Scott; James_Stormer@doh.state.fl.us
Subject: EMERGENCY GENERATORS - FPL WEST COUNTY ENERGY CENTER

Trina, Scott, & Jim,

Emergency Generators have been installed at the location referenced above as part of FPL's Hurricane Hardening program. The generators provide power to two small "safe rooms" constructed for operating employees to use in the event of a significant storm. Each safe room will be powered by two 30k W Liquid Propane (LP) fired emergency generators (one primary and one back up). Generator output voltage will be 120/240V, 1-phase and will not be used to generate electricity for sale to FPL customers.

Location	Make & Model	Ignition	HP	Rated KW
Year Built	RPM	Rule Applicability		
West County Energy Center A & B	Guardian 00522-0	Spark	40	30
2006	3600	None		
	by Generac			

The generators are categorically exempt from permitting as provided by Rule 62-210.300(3)(a). They are also exempt from 40 CFR Part 60 Subparts JJJJ due to their manufacture date (2006), and from ZZZZ due to their size (<500 Hp).

When the Title V permit is applied for, both generator packages will be added as insignificant or unregulated sources.

If you have any questions or require additional information, feel free to contact me via return E:mail, or at (561) 691-2877.

Thank you,

Kevin Washington
 Project Manager
 FPL Environmental Services
 (561) 691-2877
kevin_washington@fpl.com

7/2/2009