## PASCO COGEN, LTD.

NCP DADE POWER, INC., GENERAL PARTNER

c/o Aquila East Coast Generation • 20 Waterview Blvd. • Parsippany, NJ 07054
Tel (973) 263-6950 • Fax (973) 263-6977

May 14, 2002

RECEIVED

Ms. Cindy Phillips, P.E. FDEP Bureau of Air Regulation MS 5505 2600 Blair Stone Road Tallahassee, FL 32399-2400 (850) 921-9534

MAY 17 2002

**BUREAU OF AIR REGULATION** 

RE:

Pasco Cogeneration L.P. (Pasco), Title V Permit No. 1010071-001-AV, Facility ID No. 1010071, CAA 112(j) Notification - HAPs MACT

Dear Ms. Phillips:

This letter is being submitted to the Department on behalf of the Pasco Cogeneration facility, pursuant to the notification requirements of Section 112(j) of the Clean Air Act (the MACT Hammer provisions for Industrial Boilers and Combustion Turbine units).

Pasco is physically located at 14850 Old State Road 23, Dade City, Pasco County, Florida 33526 The facility is an electric power and steam generation cogeneration facility, consisting of two combustion turbine units. The two CTs are GE LM-6000 units. Each emission unit is also equipped with supplementary HRSG Duct Burner capability. Both units are capable of firing on either natural gas or no. 2 fuel oil (the duct burners can only fire natural gas).

While we do not believe this facility will ever be a major source for hazardous air pollutants, we do want to take advantage of the protection afforded by submitting this notification to the Department at this time. With regard to the operating history of this facility, Pasco has never emitted a major amount of listed hazardous air pollutants (10 tpy per single pollutant or 25 tpy for multiple pollutants).

If there are any concerns or questions regarding this submittal, please let me know. My telephone number is (816) 527-1671 and my e-mail address is thomas.wertz@aquila.com

Sincerely,

Stephen Thomas Wertz Senior Vice President

Aquila Merchant Services

CC: Mr. Doug Neeley
Air, Pesticides and Toxics Management Division
USEPA, Region IV
61 Forsyth Street, SW
Atlanta, GA 30303-8960

cc: S. Mathews

T. Grace

L. Rajter

C. Desmaras

R. Christmas

File: 274-2010.4





7000 1670 0008 5561 5519

Ms. Cindy Phillips, P.E. FDEP Bureau of Air Regulation MS 5505 2600 Blair Stone Road Tallahassee, FL 32399-2400

32399+2400 Oi

հոքլուներիկանիուների հուների հուների հուների