From: Bradley, Chris
To: Svec, Ed
Cc: Bradley, Chris
Subject: FW: Pre-Draft Title V Renewal Documents for Bayboro Power Plant
Date: Wednesday, May 14, 2014 3:53:51 PM
Attachments: Bayboro - HI Curve.xlsx
Importance: High

Good afternoon Ed –

Comment: The Heat Input versus Ambient Temperature Curve previously submitted to DARM was incorrect. A slightly different curve has been attached for inclusion in the Final Title V Permit.

Please contact me if you have any questions.

Best regards,

Chris Bradley
Duke Energy Florida, Inc.
Office: 727.820.5962
Cell: 727.409.2477

From: Bradley, Chris
Sent: Thursday, April 24, 2014 1:59 PM
To: Svec, Ed
Cc: Dodge, Terese; Stark, Tom
Subject: RE: Pre-Draft Title V Renewal Documents for Bayboro Power Plant
Importance: High

Good morning Ed –

I have attached the documents (with comments) your previously sent to me for review as a courtesy. The comments are typically regarding those I noted in my VM this afternoon. Specifically, I would like to make it clear that

1. Each EU (four (4)) identified by the FDEP consists of two (2) CTs connected/driving one (1) generator. So there are a total of eight (8) CTs, each CT with its own stack.

2. The three (3) large portable generators (EU 012) should be removed from the permit completely. As a result, since it is the only EU you have listed in Appendix U, there will be no Appendix U in the new TV permit.

3. The page numbers on Appendix TR do not jive with one another; e.g., "Page TR-7

of 6".

4. I have attached a cleaner version of the HI Curve for the CTs for your use in Appendix HI of the TV permit.

If for any reason you need further clarification, please contact me before the draft permit is issued.

Thank you again, Ed.

Chris

From: Svec, Ed [mailto:Ed.Svec@dep.state.fl.us]
Sent: Friday, April 18, 2014 2:13 PM
To: Bradley, Chris
Subject: Pre-Draft Title V Renewal Documents for Bayboro Power Plant

*** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ***

Chris:

The attached documents are pre-drafts of the Bayboro Plant's Title V renewal. These are being sent as a courtesy for your review. Please get me any comments no later than close of business Friday the 25th . I did not know who else needs to see them, so feel free to distribute them as needed.

Thanks

Ed Svec