


RECEIVED

MAY 25 1995

Bureau of
Air Regulation



DEPARTMENT OF
ENVIRONMENTAL PROTECTION

MAY 22 1995

SITING COORDINATION

Solid Waste Energy Recovery Facility Application for Power Plant Site Certification


Volume III — Appendices

May 1995

HDR

HDR Engineering, Inc.
RTP Environmental, Inc.

Pinellas County, Florida
Resource Recovery Program



Application For
Power Plant Siting Certification

OCTOBER, 1978



BOARD OF COUNTY COMMISSIONERS

PINELLAS COUNTY, FLORIDA

315 HAVEN STREET

CLEARWATER, FLORIDA 33516

COMMISSIONERS

CHARLES E. RAINEY, CHAIRMAN
JOSEPH "JOE" WORNICKI, VICE-CHAIRMAN
JOHN CHESNUT, JR.
DON JONES
JEANNE MALCHON

October 23, 1978

State of Florida
Department of Environmental Regulation
2562 Executive Center Circle East
Montgomery Building
Tallahassee, FL 32301

ATTN: Mr. Hamilton Oven

Re: Application for Power Plant Siting Certification (PPSC)

Gentlemen:

The document enclosed herewith is Pinellas County's application for an electrical power plant siting certification, submitted in accordance with Florida Department of Environmental Regulation Chapter 17-17 Rules.

Hopefully, the information contained herein provides all that is necessary to permit a thorough evaluation of our application. If, however, you find that additional data is required, please contact me at your earliest convenience.

Sincerely,

D. F. Acenbrack, Director
Solid Waste Management

ACE:1t1
Enclosure

APPLICATION FOR CERTIFICATION
OF PROPOSED
RESOURCE RECOVERY - ELECTRICAL
GENERATING FACILITY

PREPARED FOR
PINELLAS COUNTY, FLORIDA

BY
HENNINGSON, DURHAM & RICHARDSON

WITH TECHNICAL ASSISTANCE FROM:
UOP, INC.
PINELLAS COUNTY DEPARTMENT OF SOLID WASTE

OCTOBER 1978

PERTINENT APPLICANT INFORMATION

Applicant's Official Name: Pinellas County
Address: 315 Haven Street
Clearwater, Florida 33516

Name and Title of Business Head: Charles Rainey, Chairman of Board of County Commissioners

Name and Title and Address of Representative Responsible for Obtaining Certification: Gene Jordan, Director Public Works and Utilities
315 Haven Street
Clearwater, Florida 33516

Site Location: County - Pinellas
Nearest Incorporated City - Pinellas Park
Latitude and Longitude - 27° 52' N
82° 40' W

Name Plate Generating Capacity of Proposed Facility: 50 megawatts

REMARKS: Pinellas County does not operate, maintain or construct facilities for the purpose of electric generation. Neither does Pinellas County distribute electrical energy generated at facilities operated by others. The sole purpose of the proposed facility is to dispose of solid waste and recover energy and materials. This proposed facility will afford Pinellas County a method of solid waste disposal which will substitute for the present landfilling operations.

Professional Engineer Submitting Application

Name: R. Lee Torrens
Florida Registration Number: 21274
Date: 10/23/70
Signature: *R Lee Torrens*
Address and Phone Number: Post Office Box 12744
Pensacola, Florida 32575
(904) 432-2481

(SEAL)

TABLE OF CONTENTS

- 1.0 PURPOSE OF PROPOSED FACILITY AND ASSOCIATED TRANSMISSION
- 2.0 THE SITE
- 3.0 THE PLANT
- 4.0 ENVIRONMENTAL EFFECTS OF SITE PREPARATION, PLANT AND ASSOCIATED FACILITIES CONSTRUCTION
- 5.0 ENVIRONMENTAL EFFECTS OF PLANT OPERATION
- 6.0 ENVIRONMENTAL MEASUREMENTS AND MONITORING PROGRAMS
- 7.0 ECONOMIC AND SOCIAL EFFECTS OF PLANT CONSTRUCTION AND OPERATION
- 8.0 ALTERNATIVE ENERGY SOURCES AND SITES
- 9.0 PLANT DESIGN ALTERNATIVES

REFERENCES

APPENDICES

- APPENDIX A - ASSESSMENT OF AIR QUALITY IMPACTS RESULTING FROM THE OPERATION OF THE PROPOSED SOLID WASTE RESOURCE RECOVERY FACILITY FOR PINELLAS COUNTY, FLORIDA
- APPENDIX B - COOLING TOWER - DISPERSION ANALYSIS
- APPENDIX C - APPLICATION FOR DETERMINATION OF BEST AVAILABLE CONTROL TECHNOLOGY FOR POLLUTION SOURCES (DER-PERM 12-2)
- APPENDIX D - ADDITIONAL LANDFILL INFORMATION
- APPENDIX E - LETTER OF RESPONSE FROM STATE OF FLORIDA, DIVISION OF ARCHIVES, HISTORY, AND RECORDS MANAGEMENT

LIST OF TABLES

CHAPTER 1

1.1.1 Solid Waste Inventory - 1977

CHAPTER 2

2.2.a Component Population Estimates

2.2.b Resident Population Densities

2.4.a Subterranean Hydrogeologic Characteristics
Typical of Study Area

2.4.b Characteristics of Facility Site Soil Series

2.5.4.a Chemical Characteristics of Surface Waters

2.5.4.b Chemical Characteristics of Surficial Aquifer
Water

2.5.4 Comparison of Chemical Characteristics of Landfill
Perimeter Ditch Surface Waters with Those of Other
Nearby Waterways

2.5.4.c Chemical Characteristics of Limestone Aquifer
Water

2.5.4.d Comparison of Quality Parameters from Surficial
and Surface/Deep Aquifer Water

2.6.a Temperature Means and Extremes

2.6.b Precipitation

2.6.c Monthly Relative Frequency of Occurrence -
Pasquills Stabilities - Tampa, Florida
(1971-1975)

2.6.d Climatological Dispersion Model

2.7.a Plants and Animals Common to Study Area

2.8.1.a Synopsis of Pinellas County Air Quality Data -
January 1978 to April 1978

2.8.2.a Synopsis of the Pinellas County Air Quality
Monitoring Network

LIST OF TABLES (con't)

CHAPTER 3

- 3.2.a Design Specifications of Pinellas County Resource Recovery
- 3.2.b Anticipated Analysis of Boiler Discharge Material
- 3.4.2.a Chemical Characteristics of Facility Cooling Water Influent
- 3.4.5.a Hypothetical Ion Concentration in Blowdown Waste Streams
- 3.5.4.b Characteristics of Blowdown Mixture

CHAPTER 4

- 4.1.f.1 Various Noise Pressure Levels (dB) Imparted by Facility Construction to the Nearest Residences

CHAPTER 7

- 7-1 Benefit - Cost Summary

LIST OF FIGURES

CHAPTER 1 - none

CHAPTER 2

- 2.1.a Location of the Study Area with Respect to the State of Florida
- 2.1.b Resource Recovery Site
- 2.1.c Electric Transmission Line Routing
- 2.2.a Study Area
 - 2.2.2.a Existing Land Use
 - 2.2.2.b Pinellas County Comprehensive Land Use Plan
 - 2.2.2.c Zoning in the Study Area
- 2.3.a Historical Sites Proximate to the Study Area
- 2.4.a Geological Crosssection: Vicinity of Study Area
- 2.4.b Characteristics of Study Area Overburden
- 2.4.c Soil Series of the Study Area
- 2.5.a Surface Water Features of the Study Area
- 2.5.b Hydrogeologic Cross Section in Vicinity of Study Area
- 2.5.c Depth to Saline Water
- 2.5.d Flood Prone Areas
 - 2.5.1.a Existing Site Drainage
 - 2.5.4.a Water Quality Monitoring Sites
 - 2.5.6.a Elevation of Water Table - Spring
 - 2.5.6.b Elevation of Water Table - Fall
 - 2.5.6.c Potentiometric Surface of Floridan Aquifer

LIST OF FIGURES (con't)

CHAPTER 2 (con't)

- 2.6.a Climatological Wind Rose for MacDill AFB
- 2.7.a Major Plant Communities Surrounding Site
- 2.7.b Major Plant Communities at the Facility
- 2.8.2.a Location of Proposed Facility and Pinellas County Air Quality Monitors

CHAPTER 3

- 3.0.a Materials Recovery Schematic
- 3.1.a Plant Site Layout
- 3.1.b Pinellas County Resource Recovery Plant
- 3.3.a Summary Water Flow Diagram
- 3.4.a Water Usage Flow Diagram
- 3.8.1.a Details of Proposed Transmission Line
- 3.9.a Associated Facilities

CHAPTER 4

- 4.1.c.a Estimated Scheme of Solid Waste Generation During Plant Construction
- 4.1.f.1 Hypothetical Drop off in Sound Level from Diesel Casing Radiation of 0.25 Mile Line of Trucks
- 4.1.4 Anticipated Manpower Requirements During Construction

CHAPTER 1

PURPOSE OF THE PROPOSED FACILITY AND ASSOCIATED TRANSMISSION

1.0 Background

Under an Act of the Legislature in 1975, the Board of County Commissioners increased its responsibility from handling only the unincorporated areas to solid waste disposal activities to all of Pinellas County. Early in 1976, the search for a resource recovery solution started with a feasibility study which gathered data of existing conditions and developed alternative solutions to the countywide disposal problem. Under the same legislation, a Solid Waste Technical Management Committee (TMC) was established. Members are technically qualified representatives from designated municipalities. To date the TMC has been instrumental in providing guidance to the Board of County Commissioners towards implementation of a total resource recovery system. Basic philosophy used in the program has been to provide a system which is technically and managerially sound, economically acceptable, environmentally acceptable, and financable. In short, the solution was to minimize landfill requirements at a reasonable cost to the County residents. Based on recommendations of the study, the County Commission invited private firms to indicate an interest in contracting for disposal of county refuse.

On March 1, 1977, a Request for Qualifications (RFQ) was issued. Of the 22 respondents, a list of 7 firms were offered a Request for Proposals (RFP). Technical guidelines were provided with the RFP outlining certain design criteria, solid

waste characteristics and certain baseline guaranteed solid waste quantities. Upon selection of a single contractor to negotiate with, these technical parameters would be refined and optimized during negotiations.

Following a two month evaluation of each firm's proposal, the Board of County Commissioners unanimously agreed to begin negotiations with UOP, Inc., which offered a mass burning, electrical generation system.

Pinellas County will contract with UOP, Inc. to design, construct and operate the resource recovery plant for 20 years. UOP, Inc. guarantees the capacity of the facility and will receive an operating fee to operate the plant for 20 years (with escalation factors). In turn, the County will guarantee the delivery of a minimum quantity of solid waste for 20 years (i.e. 530,000 tons per year). Penalties will be paid by either party under terms of the contracts, for failure to meet these guarantees or others stated in the contracting agreements. Any wastes processed above the guaranteed levels and below the capacity of the facility will be processed for the prescribed operating fee. The County will receive and disperse all revenues received (i.e. recovered materials revenues, electrical revenues, tipping fee) to pay all costs associated with the operation of the facility (i.e. debt service, UOP operating fee, County incurred costs, and utilities). Performance of the system above the levels as guaranteed by UOP will mean profit sharing by UOP and the County. Performance below levels guaranteed by UOP

is offset by UOP making up lost revenues due to below-guarantee performance.

The County will guarantee a minimum quantity of solid waste, which is somewhat below the total quantity available. It is anticipated that operating levels of the facility (i.e. tons per year) will always be above the guaranteed level. Therefore, the plant will operate somewhere between the guaranteed level of 530,000 tons per year and the plant capacity of 766,500 tons per year. The higher the plant useage, the lower the tipping fee to users of the facility. In this document, where discussions involve areas of potential adverse impact (i.e. air quality impacts) a plant capacity or maximum system operation sequence was included. In areas where positive impacts are discussed (i.e. savings of energy, materials) the guaranteed minimum performance levels were assumed. Therefore, this document is conservative in those areas.

At present, the County is pursuing specific interlocal agreements with the collection entities involved in the County for solid waste delivery commitments despite the fact that the local act (reference Section 1.0) mandates the County's enforceable responsibility in the matter of solid waste disposal throughout the County.

1.1 System Reliability and Demand

The system offered by UOP and presently under negotiation with Pinellas County is a mass-burning/electrical generation configuration. The UOP facility utilizes waterwall combustion units incorporating the Martin combustion system; UOP is the

licensee of the Martin system of Germany which has numerous systems operating in Europe, many generating electricity. In fact, the seven largest individual mass fired boiler units in Europe (ranging in size from 660 TDP to 1320 TPD) employ the Martin process. The two boiler, 1050 TPD unit capacity system (total capacity 14,000 tons per week) proposed for Pinellas County falls well within Martin system capabilities. The main proprietary portion of the system is a precision tooled, reverse reciprocating stoker grate made of cast chrome steel. From the dependability standpoint, there appears to be an advantage with this type of grate as the frequent unscheduled outages common to other types are markedly reduced; indeed, these grates have demonstrated remarkable service life at the Chicago Northwest facility where Martin units have been employed since 1971.

As proposed by UOP and specified by Pinellas County, UOP would design, construct, test, operate and maintain the resource recovery facility under the supervision of the County's Public Works and Utilities Department. Overall responsibility for the project (other than contractual covenants accepted by UOP) ultimately resides with the Board of County Commissioners. As previously stated, the Board has responsibility for all solid waste disposal throughout Pinellas County via an Act of Legislature which became law

in June 1975. Collection, however, is still the responsibility of each municipality. (Eleven Pinellas cities have municipal collection systems and 25 private collectors serve remaining areas.).

Regarding system financing, the County Commission had directed that both public and private financing of the system be explored. Public financing means that revenues from the sale of electricity and recovered materials would be combined with the disposal charges to pay for the bonds and contractor's operating fee. Under private financing, the revenues would be paid to the lending agency. Under this latter arrangement, the County would not own the system at the end of the 20-year contract period. Preliminary assessment of both financing methods has indicated that the County should actively pursue public financing through use of revenue bonds, under which the facility would become a County property. (Tax considerations may necessitate private ownership of the electrical production equipment.)

1.1.1 Load Analysis/Solid Waste Characterization

In 1977, approximately 570,600 tons of solid waste were generated in Pinellas County by an estimated population of 770,000 people, thus demonstrating an average per capita generation rate of 4.06 lb/cap/day (570,600 TPY x 2000 lbs/ton /

770,000 capital / 365 days/year = 4.06 lb/cap/day). Seasonal distribution of this waste generation is indicated below:

Spring Mar/May	28.4%
Summer June/Aug	24.2%
Fall Sept/Nov	24.2%
Winter Dec/Feb	23.2%

There are eleven municipal collection systems and approximately 25 private haulers. Disposal is currently handled by four sanitary landfills, a private operated landfill and six debris pits (see Table 1.1.1). All sites which handle only non-putrescible material are privately owned. Based on scale data obtained from the Toytown and Bridgeway Acres sanitary landfills for 1977, these two landfills received 84.4 percent of that year's solid waste from Pinellas County. The data further reveals that March and August are the peak months for solid waste disposal (11.1% and 9.2% of the annual total, respectively), while the load for January (7.0% of the total) represents the minimum disposal month.

1.2 Other Objectives

Primary reasons for developing the resource recovery plant are the rapidly accelerating costs and undesirable ecologic consequences resulting from conventional solid waste

TABLE 1.1.1
SOLID WASTE INVENTORY

<u>Landfill</u>	<u>1977 Quantities Tons/Year</u>	<u>% Total</u>	<u>Source of Data</u>
Toytown	334,840	58.7	City of St. Petersburg
Bridgeway Acres	146,761	25.7	Pinellas County (Wells Bros.) Weighed Data
Largo	48,000	8.4	City of Largo Estimated
Tarpon Springs	11,000	1.9	City of Tarpon Springs Estimated
Windish	30,000	5.3	Cities of Dunedin, Safety Harbor, private haulers. Estimated.
TOTAL	570,601	100.0	

landfilling in Pinellas County. Generation of electricity represents the most feasible approach to implementing such recovery operations, even though the derived power is a secondary benefit. Ultimately, most of the solid waste generated by the ever-growing population of Pinellas County will be converted to electricity via the UOP process; an additional benefit centers on the recovery from the boiler residue of such recyclable materials as aluminum, ferrous metals, heavy non-ferrous metals and aggregate. A discussion of the quantities of recovered energy and materials is found in Chapter 7.

1.3 Consequences of Delay

Negotiations have begun for both construction of the 70-80 million dollar UOP system and for contractual plant operation for a 20 year period. A contract with Florida Power Corporation for the purchase of all electrical energy produced and fed into its grid is being finalized.

The question then arises as to which tasks are critical so as to minimize potential delays of the entire program. To address this concern, a computer based Critical Path Network (CPN) of tasks and times was employed to assist all parties in completing the numerous tasks on a timely basis. This is an obvious necessity when one considers the cost of delay. Conservative calculations indicate that, at a minimum, each day of delay beyond the scheduled Notice to Proceed date will cost

\$12,000 due to the impact of inflation upon this capital intensive project.

Furthermore, landfill requirements need to be significantly curbed in order to both extend the useful life of existing disposal sites and to curtail condemnation of additional areas for subsequent landfill operations. Thus, in view of accelerating costs, the need to keep this project proceeding on schedule is of paramount importance.

CHAPTER 2

THE SITE


2.1 Site Location and Layout

2.1.1 Site Layout - The location of the proposed solid waste resource recovery facility relative to the State of Florida and to the Tampa Bay Region is illustrated in Figure 2.1.a. Figure 2.1.b details the plant facility perimeters, with abutting and adjacent properties. In addition, outlining topographic contours are shown.


2.1.2 Site Modifications - The Resource Recovery Plant site is located on approximately 20 acres, with the County's existing Bridgeway Acres Phase I landfill tract. The Phase I landfill site is situated in the northernmost 80 acres of a total 240 acres recently acquired by Pinellas County, located in the south 1/4 of the west 1/2 of Section 14, Township 30 south, Range 16 east. The segment to the south (160 acres) will become the active landfill after completion of the northern segment. Due to the necessity for uninterrupted activities, there will be a period of overlapping operations when both segments are active. This will only take place during the time of final phase-out of the northern segment.

The proposed electrical transmission line from the facility to the Florida Power Corporation Northeast Substation is shown in Figure 2.1.c.

FIGURE 2.1.a



The Location of the Study Area with Respect to the State of Florida, and the Tampa Bay Region.



LEGEND




-  RESOURCE RECOVERY SITE
-  ADDITIONAL COUNTY PROPERTY
-  CURRENT PHASE I BRIDGEWATER ACRES


FIGURE 2.1.b

RESOURCE RECOVERY SITE

TO ST. PETERSBURG
 TO TAMPA
 HWY. NO. I-275

U.S. HWY. NO. 19
 TO PINELLAS
 TO PARK

FIGURE 2.1.c



ELECTRICAL TRANSMISSION LINE ROUTING


2.1.3 Existing and Proposed Uses - All of the on-site property (resource recovery facility site) is designated for solid waste management resource recovery purposes. The phased expansion of the current County landfill operation represents a logical extension of the recent operation, located on a contiguous 200 acre parcel of land to the west of the subject Phase I site. The Phase I site has been receiving refuse since July 1977.

Adjoining property to the immediate east of the phased landfill expansion areas is owned by the City of St. Petersburg, and is currently being used for an experimental sod farm utilizing treated sludge from the city's wastewater treatment plants.

2.2 Regional Demography, Land and Water Use

2.2.1 Demography - Pinellas County, one of the more densely populated of all Florida counties, includes the City of St. Petersburg and 4 adjacent municipalities. The 1970 census lists a population of 567,751 in Pinellas County; by 1976, the population had increased by 36 percent to an estimated 771,100. More than 70 percent of the population live within the incorporated areas of Pinellas County, which are concentrated along the coastline and southern half of the County. The northeastern portion of the County is sparsely populated and comprised of swampy wetlands and agricultural areas, while the central, southern and all coastal areas are predominantly developed as residential and municipal areas. The immediate study area for the proposed Resource Recovery Facility site is depicted in Figure 2.2.a, which encompasses a five-mile radius (50,240

FIGURE 2.2.d.



STUDY AREA

acres) centered on the site. Included in the study area are the City of Pinellas Park and portions of St. Petersburg, Largo and Kenneth City and unincorporated areas outlying from these municipalities. The resident populations of the incorporated areas are shown in Tables 2.2.a and 2.2.b, which depict component permanent and seasonal estimates. The inclusion of a weighted tourist population would approximate a total population. To further estimate the resident population of the study area, reference is made to a recent population forecast prepared by the Research and Special Studies Division of the Pinellas County Planning Department. cursory analysis of delineated population distributions for 119 traffic analysis zones approximating the study area indicate a 1970 resident population of 117,200 and an extrapolated (projected) population for 1977 of 157,100; this, generally, reflects an average rate of growth. It is assumed, for purposes of this documentation, that any transient increase reflecting a localized tourist population would contribute little to total population estimate. The major concentrations of population in the study area are located in the vicinity of the City of St. Petersburg and neighboring municipalities, all within the southern half of the County.

2.2.2 Land Use - In comparison to the rest of Central Pinellas County, the immediate area surrounding the proposed facility site is virtually undeveloped (see Figure 2.2.2.a). The most proximal residential area is located roughly one mile to the southwest

TABLE 2.2.a COMPONENT POPULATION ESTIMATES
April 1, 1970 and April 1, 1977

	<u>PERMANENT POPULATION</u>		<u>SEASONAL POPULATION</u>		<u>RESIDENT POPULATION</u>		<u>% Change 1970-77</u>
	<u>1970</u>	<u>1977</u>	<u>1970</u>	<u>1977</u>	<u>1970</u>	<u>1977</u>	
Belleair	2,962	3,710	258	320	3,220	4,030	25
Belleair Beach	952	1,920	83	170	1,035	2,090	102
Belleair Bluffs	1,910	3,210	166	280	2,076	3,490	68
Belleair Shore	124	80	11	70	135	150	11
Clearwater	52,074	79,370	4,528	6,900	56,602	86,270	52
Dunedin	17,639	28,970	1,534	2,520	19,173	31,490	64
Gulfport	9,730	12,120	846	1,050	10,576	13,170	25
Indian Rocks Beach	2,666	3,860	232	340	2,898	4,200	45
Indian Shores	791	1,750	69	150	860	1,900	121
*Kenneth City	3,862	4,330	336	380	4,198	4,710	12
*Largo	22,031	51,960	1,916	4,520	23,947	56,480	136
Madeira Beach	4,158	4,740	362	410	4,520	5,150	14
North Redington Beach	768	1,410	67	120	835	1,530	83
Oldsmar	1,538	2,390	134	210	1,672	2,600	56
*Pinellas Park	22,287	31,670	1,938	2,750	24,225	34,420	42
Redington Beach	1,583	1,790	138	160	1,721	1,950	13
Redington Shores	1,733	2,550	151	220	1,884	2,770	47
Safety Harbor	3,103	4,480	270	390	3,373	4,870	44
*St. Petersburg	216,232	237,600	18,803	20,660	235,035	258,260	10
St. Petersburg Beach	8,024	10,710	698	930	8,722	11,640	35
Seminole	2,121	5,430	184	470	2,305	5,900	156
South Pasadena	2,063	4,400	179	380	2,242	4,780	113
Tarpon Springs	7,118	11,920	619	1,040	7,737	12,960	68
Treasure Island	6,120	7,750	532	670	6,652	8,420	27
Total Incorporated	391,589	518,180	34,054	45,050	425,643	563,230	32
*Total Unincorporated	<u>130,740</u>	<u>191,220</u>	<u>11,368</u>	<u>16,650</u>	<u>142,108</u>	<u>207,870</u>	<u>46</u>
TOTAL COUNTY (PINELLAS)	522,329	709,400	45,422	61,700	567,751	771,100	36

*The five-mile study area encompasses portions of these municipalities

TABLE 2.2.b RESIDENT POPULATION DENSITIES
April 1, 1970 and April 1, 1977

	1970			1970		
	<u>Population</u>	<u>Acreage</u>	<u>Persons Per Acre</u>	<u>Population</u>	<u>Acreage</u>	<u>Persons Per Acre</u>
Belleair	3,220	1,206	2.7	4,030	1,206	3.3
Belleair Beach	1,035	310	3.3	2,090	310	6.7
Belleair Bluffs	2,076	263	7.9	3,490	263	13.3
Belleair Shore	135	43	3.1	150	43	3.5
Clearwater	56,602	9,031	6.3	86,270	13,696	6.3
Dunedin	19,173	4,472	4.3	31,490	5,467	5.8
Gulfport	10,576	1,512	7.0	13,170	1,512	8.7
Indian Rocks Beach	2,898	554	5.2	4,200	554	7.6
Indian Shores	860	247	3.5	1,900	247	7.7
*Kenneth City	4,198	319	13.2	4,710	357	13.2
*Largo	23,947	4,721	5.1	56,480	8,494	6.6
Madeira Beach	4,520	519	8.7	5,150	519	9.9
North Redington Beach	835	174	4.8	1,530	174	8.8
Oldsmar	1,672	1,939	.9-	2,600	2,793	.9+
*Pinellas Park	24,225	5,022	4.8	34,420	6,409	5.4
Redington Beach	1,721	213	8.1	1,950	213	9.2
Redington Shores	1,884	229	8.2	2,770	229	12.1
Safety Harbor	3,373	654	5.2	4,870	1,594	3.1
St. Petersburg	235,035	35,476	6.6	258,260	36,029	7.2
St. Petersburg Beach	8,722	1,285	6.8	11,640	1,285	9.1
Seminole	2,305	672	3.4	5,900	846	7.0
South Pasadena	2,242	321	7.0	4,780	321	14.9
Tarpon Springs	7,737	4,228	1.8	12,960	4,938	2.6
Treasure Island	6,652	876	7.6	8,420	876	9.6
Total Incorporated	425,643	74,286	5.7	563,230	86,976	6.5
Total Unincorporated	<u>142,108</u>	<u>105,028</u>	<u>1.4</u>	<u>207,870</u>	<u>92,338</u>	<u>2.2</u>
TOTAL COUNTY	567,751	179,314	3.2	771,100	179,314	4.3

*The five-mile study area encompasses portions of these municipalities SOURCE: Pinellas County Planning Council, 1977




FIGURE 2.2.2.d


of the facility site in Pinellas Park; this represents the only significant population center to be impacted by facility construction and operation. Other land uses which characterize the immediate study area include:

- Light industrial complexes (boat manufacturing, aggregate, electronics, etc.) located along 118th Avenue North, to the northwest of the facility site.
- An abandoned shell quarry to the northeast.
- The St. Petersburg/Clearwater Airport is located approximately two and one-half miles northwest of the proposed facility (see Figure 2.2.a).
- An experimental sod farm where domestic wastewater sludges are applied is located directly east and south of the site (Figure 2.1.b).
- Former and existing landfills flank the facility site. A 200 acre tract to the west is a former County landfill phased out of putrescible landfill activities in the Fall of 1977; existing landfills occupy the area immediately surrounding the plant site (Phase I Bridge-water Acres), and the area just east of Interstate Highway 275.
- A storm drainage/environmental education center, Sawgrass Lake, is situated some two miles south of the proposed facility.
- Mangrove estuaries, designated as aquatic preserves in the Coastal Zone Management (CZM) Plan are located along the shorelines of Old Tampa Bay, over two miles northeast and five miles east of the facility site.

- ° The Florida Power Corporation Bartow Electrical Generation Plant is situated five miles east of the proposed facility on Weedon Island.

Outward from two miles of the study area more concentrated residential and commercial developments are encountered; to the south and west those areas of St. Petersburg, Largo and Kenneth City are encountered, as are the densely developed areas of Clearwater to the north.


The Comprehensive Land Use Plan for this particular area indicates the primary land usage has been designated industrial, with industrial development occurring in a large part to the west and northwest. Residential development is occurring or is being anticipated to the south and to the southwest, with very limited construction to the northeast of this particular facility. The site location is within the major identified industrial area of Pinellas County. This Comprehensive Plan attempts to isolate this major industrial area from other residential uses; it is the intent of Pinellas County to continue to support and protect this industrial complex so as to prevent incompatible residential or commercial uses from occurring in this general vicinity. Figure 2.2.2.b highlights the Pinellas Comprehensive Land Use Plan in the immediate study area. The general zoning pattern which occurs in this area (see Figure 2.2.2.c) indicates almost exclusive industrial zoning designations; minor pockets of commercial and residential



LEGEND	
	Manufacturing
	Low Density Residential
	Medium Density Residential
	Commercial
	Public/Semi-public
	Recreation/Open Space

FIGURE 2.2.2.B

FIGURE 2.2.2.c



LEGEND

A- AGRICULTURAL C-COMMERCIAL M-MANUFACTURING, INDUSTRIAL
RL- LOW DENSITY RESIDENTIAL RM- MEDIUM DENSITY RESIDENTIAL
P- PUBLIC

ZONING IN THE STUDY AREA

zoning, presently in conflict with the Comprehensive Land Use Plan, will be rezoned to an industrial classification within the near future. While the zoning effected within a two-mile radius still contains a preponderance of industrial classification, many low lying areas are zoned agricultural. The present zoning which occurs within a five-mile radius of the facility site reflects the Comprehensive Land Use Plan for Pinellas County, and, as such, provides no conflict with the proposed facility. Existing and proposed road systems will allow access to this facility without the necessity for traveling through established or proposed residential areas.

2.2.3 Water Use - The major sources of water within the five-mile study area are from County and City well fields located very remote from the site.

All water now provided by the Pinellas County water system is obtained from wells tapping the Floridan Aquifer. These wells are located in the Eldridge-Wilde Well Field (northwest corner of Pinellas and adjoining Hillsborough Counties), East Lake Road Well Field (adjacent to Lake Tarpon in northern portion of the County) and several wells drilled by developers for their own projects during the water shortage of 1973 and subsequently turned over to the County. Potable water is also obtained from the Cypress Creek Well Field located in central Pasco County. Through its wholesale and retail service areas, this Pinellas system provides approximately one-half of the potable water needs for the County's population.

PAST AND PROJECTED AVERAGE DAILY WATER
DEMAND (MGD) FOR STUDY AREA MUNICIPAL SYSTEMS

	<u>1970</u>	<u>1971</u>	<u>1972</u>	<u>1973</u>	<u>1975</u>	<u>1980</u>	<u>1990</u>
Pinellas County	23.7	28.3	31.7	-	38.4	62.2	-
Town of Largo	1.7	1.2	1.8	2.1	2.5	3.5	4.5
City of Pinellas Park	1.9	2.2	-	-	3.0	3.3	-
City of Clearwater*	2.6	3.6	4.8	-	12.1	14.0	-
City of St. Petersburg	29.0	30.0	34.0	35.0	38.0	46.0	51.0

* From Clearwater well field only; total Clearwater water supply is supplemented by wholesale purchases from Pinellas County.

The St. Petersburg Water Department obtains its water supply from four well fields: the Cosme, Odessa and Section 21 well fields in Hillsborough County and the South Pasco Well Field over 3 miles further north. Water from a fifth well field, the Cypress Creek Well Field, will be available when a 42-inch connection to the South Pasco Well Field from the 84-inch Cypress Creek main is completed.

An inventory of permitted wells near the facility site (Section 14, Township 30 South, Range 16 East), as reported by the Southwest Florida Water Management District in January 1977, identifies 19 wells, including two abandoned public supply wells, eight irrigation wells, five domestic private wells and four miscellaneous wells used for mining or other purposes. The majority of the domestic wells were recorded in Section 10, located over half a mile

northwest of the site. The wells in Section 12, 13, 22 and 24 of Township 30 South, Range 16 East, coincide with areas not developed for residential purposes, and it is thought that usage of these wells is unlikely.


2.3 Regional Historic, Scenic, Cultural and National Landmarks

An indication of public interest in the history of Pinellas County is the compiled analysis of some 120 sites of historic or archaeological significance by the Pinellas Coastal Zone Management Citizens and Technical Advisory Committee. Those historical sites within the central Pinellas area and somewhat adjacent to the study area are shown on Figure 2.3.a.

As the site is a disturbed and transitional ecosystem typical to this region of Florida, it is not considered a scenic or natural landmark. The proposed transmission line right-of-way from the resource recovery facility to the hook-up with the existing FPC transmission line will pass through more of the same kind of system and will endanger no area or location of known historic, archaeological, cultural, scenic or natural significance.

From the foregoing, it appears that the proposed resource recovery plant auxiliary systems and associated electrical transmission facilities do not impact any sites of historic, archaeological or cultural value. A letter was written to the Florida Division of Archives, History and Records Management, Bureau of Historic Sites and Properties, requesting a confirmation in writing of this observation. The response received, provided as Appendix E, confirms that no historical or archaeological site will be disturbed by the project.

FIGURE 2.3.a



HISTORICAL SITES PROXIMATE TO THE STUDY AREA

2.4 Geology

2.4.1 Subterranean Geology - The subterranean geology suggests a stratigraphy created primarily by marine mechanisms. While information is not available for extreme depths, the shallow and intermediate formations are well documented via the loggings from a large number of wells situated throughout the central Pinellas County area. In general, the region is underlain by several hundred feet of solution-riddled limestone and dolomite that comprise the following formations in ascending order: Lake City limestone, Avon Park limestone, the Ocala Group, Suwannee limestone, Tampa Formation, and Hawthorn Formation. These formations range in age from the Eocene to Miocene Epochs. Collectively, they are referred to as the Floridan Aquifer which is the principal source of nearly all municipal, industrial, and agricultural water systems in the West Central Florida area. The aquifer is overlain by Pleistocene and Holocene deposits of sand, silt and clay of varying thickness. The more permeable beds form a subsurface reservoir called the shallow aquifer. Figure 2.4.a features a geologic cross-section in the vicinity of the proposed facility; Table 2.4.a augments this illustration with discussions of pertinent hydro-geologic characteristics.

Surficial deposits (to be discussed in more detail in Section 2.4.b) in the study area are composed of Holocene formations, derived from unconsolidated sand lenses of Pleistocene

FIGURE 2.4.a

GEOLOGIC CROSSSECTION: VICINITY OF THE STUDY AREA




TABLE 2.4.a

SUBTERRANEAN HYDROGEOLOGIC CHARACTERISTICSTYPICAL OF THE STUDY AREA

Geologic			Hydrologic	
Age	Name	Character of Material	Name	Water-Bearing Characteristics
Pleistocene and Holocene	Surficial deposits 0 - 90' ^a	Brown and gray fine sand; some gravel, clay and sandy clay	Water-table Aquifer	Unconfined. Depth to water generally less than 10 feet. Yields 5 to 250 gpm. Quality generally fresh; salty near shoreline, and estuaries.
Miocene	Hawthorn Formation 0 - 90'	Chiefly green clay & silt, with sand and stringers of limestone	Confining Deposits	Generally low permeability; in places includes beds of low permeability in surficial deposits; retards leakage of water between aquifers.
	Tampa LS 100'-150'	White to cream, sandy limestone, fossiliferous		Contains water under artesian pressure; some wells flow. Recharged mainly by leakage from Water-table Aquifer. Transmissivity ranges from low to high; yields range from several hundred gpm to 5,000 gpm, and specific capacities of wells range from 30 to 600 gpm/ft drawdown. Water quality ranges from fresh and moderately hard in inland areas to high saline near the shoreline. Also saline at depths from several hundred to about 1,500 feet in inland areas.
Oligocene	Suwanee LS 0 - 300'	White, yellow and brown fine gravel limestone with chert lenses		
Eocene	Ocala Gr 80'-500'	Yellow, gray, brown, soft limestone, foraminifera.		Upper part generally poor producer; lower part good producer.

^a indicates depth of formation

Geologic			Hydrologic	
Age	Name	Character of Material	Name	Water-Bearing Characteristics
Eocene	Avon Park LS	Cream to brown, soft limestone, some zones of brown hard dolo- mite, some gypsum.		Good water-bearing zone; water quality poor in places due to high chloride and sulfate content.
	50 - 500'			
	Lake City LS			
	500'-1000'			
	Oldsmar LS	Dolomite and limestone, chert, and gypsum.		Good water-bearing zone; water quality generally poor due to high chloride and sulfate content.

marine terraces. These Pleistocene zones overlay a highly permeable strata of marine sands and shells ranging in depth from two to fifty feet within the study area. Upper Miocene deposits of sandstone, limestone and clay do not prevail at the proposed facility site although they are very common around Clearwater and other more northerly locations. The dominant formations indigenous to the study site are certain middle Miocene components, primarily the Hawthorn formation. The material composition of this layer varies from hard sandstone to sandy clay; in some areas it is calcareous and impregnated with such irregularities as phosphate and chert fragments. Isolated beds of discontinuous sand are present in the Hawthorn formation but are somewhat impermeable due to a significant clay content. Generally, the Hawthorn layer thickens as you approach the southern tip of Pinellas County with depths ranging from fifty feet at Clearwater to ninety feet near St. Petersburg (Figure 2.4.a). Beneath the Hawthorn bed lies the Tampa formation, a hard sandy limestone stratum of lower Miocene age; the thickness of this layer averages 125 feet in the study area. Underlying the Tampa formation are Oligocene age limestones more consistent and of a purer grade than those of the Tampa group. The Suwannee formation limestones in Pinellas County range in thickness from a few feet in the north to 300 feet in the south. The upper surface is eroded with numerous pinnacles

and valleys marking the interface with the overlying Tampa formation. Characteristically, the Suwannee limestone is a fine gravel limestone containing lenses of chert and can be expected to be hard and dense in some areas. This formation as well as the Tampa contain numerous solution channels. The Ocala Group limestones of the upper Eocene Age consist of three differentiable types of limestone: the Crystal River, Williston and Inglis formations. In the planning area, this entire group is a relatively thin 200 feet in thickness. Generally, the limestones of the Ocala group are soft and fossiliferous; in Pinellas County, they may contain coquina, be dolomitized or silicified, have either a pasty calcite matrix or a loosely cemented calcareous matrix, and may range from soft to medium-hard. Immediately below the Ocala group are Eocene Claiborn formations beginning at a depth of 600 feet and extending downward to 1600 feet. The associated limestones of this formation, in descending order, are the Avon Park and Lake City layers. Generally, the Claiborn group is quite fossiliferous and porous; the base of the Lake City limestone is delineated by a thick unit of porous, fine crystalline dolomite. The entire Claiborn is characterized by solution channels, boulder zones and solution cavities. Below the Claiborn group, the following formations are present:

- Lower Eocene Oldsmar limestone - 900-1100 feet thick; depth to 3200 feet.
- Paleocene Cedar Keys limestone - 1300 feet thick; depth to 4500 feet
- Upper Cretaceous Lawson limestone - Depth from 4500 feet.

2.4.2 Surficial Geology - The overburden typical of the proposed facility site is characterized by sand, marl and clay constituents as shown in Figure 2.4.b. The sandy layer is composed of shells and fine sand grading to increased clay concentration at its lower bound. The marl/clay zone becomes cherty and much stiffer with depth and is variegated with phosphate pebbles and limestone fragments. The average thickness of the sand unit is 18 feet; that for the marl/clay unit is 42 feet. The depth to the bedrock in the study area undulates from 33 to 55 feet below the land surface.

Several factors are determinants of soil characteristics in the Pinellas area: topography, parent materials, plants and animals, climate and time.

Topography has played a major role in study area soil development. Where a sufficient gradient exists, stormwater runoff transports sand and soil particles downhill. During this occurrence the constituents are intermixed and, upon deposition, classification into coarse and fine grains occurs. In flatter,




FIGURE 2.4.b.

more low lying areas where upland runoff is slowed or retained, the suspended soil particles precipitate over the indigenous substrate, thus becoming the governing soil type. As the upland soils are much more subject to leaching, natural fertility in those areas is somewhat reduced.

The parent material of study area soils is basically silica sand derived from Pleistocene marine terraces.

Organic matter is added to the soil by dead and decaying plants and animals. Plants tend to stabilize soil surfaces while the burrowing and grazing activities of animals disrupts the substrate.

The very humid, subtropical climate of the area with its inherent abundant rainfall speeds the decomposition of soil borne organic matter and facilitates the chemical weathering of soil components; soluble minerals are readily transported, modified and redeposited under such physical conditions.

The importance of time in regional soil morphogenesis can be summarized by noting that the primary soil particle of the region, silica sand, was created by the very slow weathering of very durable quartz over millions of years.


Basically, three distinct categories of soils exist within the study area. The sand-dominated and organic-dominated types are naturally occurring and mix only slightly; sand-dominated types typify higher terrain while low pockets and drainage basins are filled with the organic-dominated group.

The third category is man-made lands which are characterized as landfills, quarries and the like; the radical alterations inflicted on these areas preclude their consideration as natural entities.

With regard to the proposed facility and environs, the Felda and Eldred series dominate soil components. Figure 2.4.c outlines the soil series in the study area; Table 2.4.b features the pertinent characteristics of these two most prevalent soil series.

2.5 Hydrology

Surface Drainage - Drainage basins in the study area are typified by large bowl-like depressions delineated by low ridge lines. Runoff from the more upland areas flows in small shallow streams to larger conduits and, eventually, to the numerous contiguous bays which dot the region. Where little gradient exists (e.g., the area of the proposed facility) overland sheet flow of rainwater to shallow ponds is most common. The occurrence of water in these ponds depends to a larger extent on the water levels of the shallow aquifer. This water bearing strata is composed of Miocene clays and marls and is recharged entirely by water which has percolated through the soil column. Where a surface depression exceeds the depth to the seasonal high water table, an intermittent pond is formed; deeper depressions that pass the seasonal low water table achieve year-round permanence. Figure 2.5.a identifies the major surficial drainage features located in the study area.



SOIL SERIES OF THE STUDY AREA

FIGURE 2.4.C.
FROM S.C.S.

SOIL LEGEND

The first capital letter is the initial one of the soil name. A second capital letter, B or C, shows the slope. Most symbols without a slope letter are those of nearly level soils.

<u>SYMBOL</u>	<u>NAME</u>
Au	Astor soils
Ch	Charlotte fine sand
Ed	Elred fine sand
Fe	Felda fine sand, ponded
Ma	Man made land
Md	Man made land, sanitary fill
My	Myakka fine sand
Ok	Okeechobee muck
Om	Oldsmar fine sand
Pf	Pinellas fine sand
Pp	Pompano fine sand
Tc	Terra Ceia muck, moderately deep variant
Wa	Wabasso fine sand


TABLE 2.4.b

CHARACTERISTICS OF FACILITY SITE SOIL SERIES

	Soil Series	
	<u>Eldred</u>	<u>Felda</u>
On-site Description	65 pct.	35 pct.
SCS Description	nearly poorly drained soils on broad low ridges in the flatwoods	nearly level poorly drained soil that occupies slightly elevated areas bordering sloughs and ponds
Soil Texture	0-30" fine sand 30-35" fine sandy loam 35-62" sand, shell	0-30" fine sand 30-41" fine sandy loam, loamy fine sand 41-60" shell, sand
Water Table Depth (in.)	10-30 inches for 2 to 6 months; and within a depth of 10 inches for 1 to 2 months during wet season	10-40 inches; above 10" for 2 to 6 months
Flood Hazard	once in 5 to 20 years for 7 to 30 days	once in 5 to 20 years for 7 to 10 days
Available Moisture Capacity (in./in.)	less than 0.05 in/in for depths 0-30 inches; less than 0.10-0.15 in/in for depths 30-62 inches	less than 0.05 in/in for depths 0-30 inches; less than 0.10-0.15 in/in for depths 30-62 inches
Permeability Experienced at Depth		
	6.3-20 in/hr	0-30 in.
	.63-2.0 in/hr	30-35 in.
	6.3-20 in/hr	35-67 in.
Shrink Swell Capacity	low	low
Bearing Strength (AASHO Class.)	A3	A3

SOURCE: SCS 1978

FIGURE 2.5.d.



SURFACE WATER FEATURES OF THE STUDY AREA

Groundwater - The aquifer system underlying the study area is composed of three distinct units, as shown in Figure 2.5.b.


The surface or water table aquifer lies closest to the surface, with expected depths ranging from 13 to 23 feet (average 19 feet). Water from this aquifer is generally of good quality, except where leachate from landfills or wastewater sprayfields are encountered. As the water table aquifer is recharged exclusively by rainwater and runoff, water levels fluctuate with season. Water yield from this layer is quite small, less than 5 gallons per minute near the proposed facility site.

Segregating the surficial and upper limestone (Floridan) aquifers is a confining layer, or aquiclude, composed of marl and clay. This impermeable layer averages a thickness of 37 feet in the study area and is quite effective in minimizing aquifer intermixing. Artesian characteristics are imparted to the Floridan aquifer by this confinement of groundwater.


The upper Floridan aquifer is composed of hard chert and limestone of the Tampa formation and is quite saturated with freshwater in its upper region, grading to more saline concentrations with increased depth (see Figure 2.5.b). Recharge of this system is accomplished primarily via leakage from the shallow aquifer. Due to the forementioned properties of the confining layer, water in this aquifer is under artesian pressure; thus, wells tapping this region yield large volumes of water, ranging from several hundred to 5,000 gallons per minute. Indeed, it is from this aquifer that all regional

FIGURE 2.5.b.

HYDROGEOLOGIC CROSS SECTION IN VICINITY OF STUDY AREA



LOCATION OF HYDROGEOLOGIC SECTION "A"-"A"



LEGEND

- BOUNDARY OF HYDROLOGIC UNIT
- APPROXIMATE POSITION OF 250 mg/l ISOCHLOR IN ZONE OF DIFFUSION (1973-1974)
- ▨ CHLORIDE CONTENT OF GROUND WATER GREATER THAN 250 mg/l
- APPROXIMATE DIRECTION OF GROUND WATER FLOW


potable water is extracted (although excessive pumping and, consequently, salt water encroachment have precluded most municipal withdrawals on the Pinellas Peninsula; see Section 2.2.3). Although seasonal water table fluctuations facilitate the movement of more saline waters into the freshwater zone, aquifer water quality is good in the vicinity of the resource recovery site. Hydrologists have arbitrarily designed those waters with a chloride concentration in excess of 250 mg/l as salt or brine water, with a lesser concentration indicating freshwater; the estimated depth to the 250 mg/l isochlor is featured in Figure 2.5.c.

Flood Prone Areas - The highly permeable coarse sands of the higher elevations permit rapid internal drainage to the water table. At lower elevations where surface runoff is much slower, the highly organic soils or hardpan hold moisture and act as a reservoir of fresh water. The occasional inundation of significant portions of the study area can be blamed on the slow percolation rates of these soils and the high water table.

Figure 2.5.d identifies those portions of the study area which are subject to inundation from a 100-year tidal surge; the primary delineating criterion for flood-prone designation is the eight foot (msl) tidal elevation contour.

2.5.1 Affected Waters - Surface drainage of those areas encompassing the proposed site will be maintained on site (see Section 3.10). Discharges will occur only under high rainfall

FIGURE 2.5.c.



DEPTH TO SALINE WATER




FIGURE 2.5.d.

conditions and then only treated stormwater runoff will be discharged. Existing drainage in the area is shown on Figure 2.5.1.a. At present drainage from the site is channeled through the Roosevelt drainage basin as delineated in the Central Pinellas 201 Plan. This designated Class III watershed (Chapter 17-3, FAC) is composed of manmade arteries in its upstream areas which generally parallel county roads and superhighways. These channels gradually diffuse into the myriad of ponds and streams which characterize the shoreline mangrove estuaries. An illustration of the drainage scheme for the resource recovery site is shown in Section 3.10. As discussed in that section, all drainage will be contained on site and any discharge will be in emergency high water conditions. During these conditions, discharged treated stormwater runoff will be directed in accordance with the area-wide drainage plan currently being prepared by the County. In any case, Tampa Bay will receive any discharge from the new facility in the same general vicinity as the present drainage.

With regard to groundwater, activities associated with facility construction and operation will have a minimal impact on aquifer water quantity and quality; it is anticipated that plant incurred effects on these systems will be only locally significant. This is substantiated upon analysis of a 1976 USGS report concerning landfilling activities and groundwater plume dispersal at Toytown (approximately 1 mile east).¹ This report indicates that downgradient horizontal movement of groundwater in the study area is minimal (1 to 10 feet per year). Furthermore, on-site soil borings suggest the

¹ "Geohydrological Evaluation of a Landfill in a Coastal Area, St. Petersburg, Florida"

EXISTING STUDY AREA DRAINAGE SCHEME




FIGURE 2.5.1.d

presence of a continuous, areally significant clay/marl zone underlying the study area at an average depth of 19 feet.

More detailed discussions of plant induced water quality impacts are featured in Chapters 4, 5, and 6; the provisions regarding facility water consumption, landfilling needs and stormwater control are specified in Chapter 3. Section 2.5.4 identifies background chemical characteristics of study area surface and ground waters.

2.5.2 Water Withdrawals - Water needs for the proposed facility will be supplied by existing municipal systems (see Chapter 3). No existing or new wells in the study area will be utilized.

2.5.3 Affected Tributaries - The component streams of the Roosevelt drainage basin are the only affected tributaries pertinent to the proposed facility. As previously cited, the upper reaches of the watershed are drained by manmade canals and ditches, and shallow, natural drainage courses. Just east of Roosevelt Boulevard, these channels empty into black and red mangrove tidal zones and, ultimately, into Old Tampa Bay. Quality and quantity (flow) data on streams and estuaries in the Roosevelt basin are virtually non-existent; watershed sampling regimens have been limited to the vicinity of the Toytown and Pinellas County landfills. By extrapolating data from similar areas in Pinellas County for which a representative data base is available; one can speculate that chemical quality of those affected tributaries is generally good except where landfill and sprayfield effluents are encountered (see Section 2.5.4).

Estuarine water quality has been estimated from National Marine Fisheries Service monitors near Weedon Island, Albert Whitted Airport and Point Pinellas. Basically, nutrient data indicate no untoward conditions while dissolved oxygen concentrations ranged from 3.5 to 4.4 milliliters per liter during the six year regimen (1966-1972). All data results were consistent with expected pollutant concentrations for estuaries receiving moderate urban inflows.

2.5.4 Background Characteristics - Data reviewed to discern water quality characteristics were WATSTORE retrievals of USGS sampling efforts in the study area. Figure 2.5.4.a illustrates the array of surface water, shallow aquifer and Floridan aquifer monitoring wells from which data were examined. In most cases those monitors located upgradient of landfill and sprayfield areas were selected as being most representative of study site background conditions; however, for the Floridan aquifer evaluation, no monitor upgradient of these effluent areas contain a data base adequate enough to estimate water quality, even in a cursory sense. For this reason, and due to the forementioned relative isolation of this lower aquifer from more surficial layers, it is speculated that utilization of data from a Floridan aquifer monitor underlying the sod farm wastewater sprayfield will not be overly biased by sprayfield leachate and, consequently, will approximate background conditions.




FIGURE 2.5.4.D.

WATER QUALITY MONITORING SITES

Surface Water - Table 2.5.4.a identifies maximum, minimum and mean concentrations (mg/l) of chemical constituents from two monitors (SW-4 and SW-1, Figure 2.5.4.a) located in the perimeter ditch of the phased out Pinellas landfill. Data from Stations SW-3 and SW-2 were also examined, but it was determined that surface waters at those sites were significantly impacted by urban runoff (high concentrations of coliform and oxygen demanding substances). At SW-4 and SW-1, concentrations of the vast majority of constituents are quite low, especially in comparison with other nearby surface waters in urban locations which receive domestic wastewater effluents (see Table 2.5.4). The bacterial levels, however, indicate that fecal pollution is quite apparent with state standards (Chapter 17-3, FAC) being routinely violated. This is largely due to the prominence of high seagull populations which feed off the raw garbage of the current landfill.

Shallow Aquifer - Data from well number SF-26 (Figure 2.5.4.a) was selected for discussion; maximum, minimum and mean concentrations for representative parameters at that location are shown in Table 2.5.4.b. The data reviewed indicate significantly higher nutrient concentrations for the water table aquifer than those recorded in surface waters. As this well is located up-gradient from the sod farm wastewater sprayfield, a possible explanation for this phenomenon is contaminated plume spreading; a cursory review of the limited data from other upgradient wells (numbers SF-56, SF-65 and SF-61) supports these findings. As you would expect of waste encased in a soluble substrate, common mineral content

Table 2.5.4.a

CHEMICAL CHARACTERISTICS OF SURFACE WATERS¹

<u>Parameter</u>	<u>WATSTORE</u>	<u>Mean</u>	<u>N²</u>	<u>Max</u>	<u>Min</u>
Total Organic Nitrogen, MG/L	00605	0.99	10	1.3	0.80
Total Ammonia Nitrogen, MG/L	00610	0.08	8	0.13	0.05
Total Nitrite Nitrogen, MG/L	00615	0.0	8	0.0	0.0
Total Nitrate Nitrogen, MG/L	00620	0.0	7	0.0	0.0
Total Phosphorus, MG/L	00665	0.06	10	0.10	0.02
BOD, MG/L	00310	1.59	10	2.1	0.8
COD, MG/L	00340	52	10	73	24
Turbidity, JTU	00070	9.5	2	15	4
Color, PtCU	00080	53	3	65	40
Specific Conductance, Micromhos	00095	504	10	740	360
Dissolved Chloride, MG/L	00940	43	10	80	16
pH	00400	7.7	12	8.6	6.3
Dissolved Calcium, MG/L	00915	72	8	89	51
Dissolved Magnesium, MG/L	00925	7.1	8	11	4.2
Dissolved Potassium, MG/L	00935	3.5	8	6.0	2.1
Dissolved Sodium, MG/L	00930	29	8	54	16
Hardness, Ca MG/L	00900	210	8	270	150
Total Arsenic, MG/L	01002	1.8	10	4	0
Total Cadmium, MG/L	01027	0.2	10	1	0
Total Chromium, MG/L	01034	15	10	30	<10 ³
Total Copper, MG/L	01042	5.7	10	27	0
Total Iron, MG/L	01045	251	10	470	100
Total Lead, MG/L	01051	4.2	10	12	0
Total Mercury, MG/L	71900	0.28	10	0.8	0
Total Zinc, MG/L	01092	20	10	30	0
Confirmed Coliform MPN	31505	16,114	9	110,000	210
Fecal Coliform MPN	31615	1,074	7	4,600	21

¹Values extracted from WATSTORE; USGS stations #275218082410700 and #275217082412500, both in the Pinellas County Landfill Perimeter Ditch.

²Number of samples examined.

³4 of 10 readings were <10, or below detection limits.

Table 2.5.4.b

CHEMICAL CHARACTERISTICS OF SURFICIAL AQUIFER WATER¹

<u>Parameter</u>	<u>WATSTORE</u>	<u>Mean</u>	<u>N²</u>	<u>Max</u>	<u>Min</u>
Total Organic Nitrogen, MG/L	00605	0.77	12	0.90	0.67
Total Ammonia Nitrogen, MG/L	00610	0.34	8	0.43	0.29
Total Nitrite Nitrogen, MG/L	00615	0.004	8	0.01	0.0
Total Nitrate Nitrogen, MG/L	00620	0.04	8	0.32	0.0
Total Phosphorus, MG/L	00665	0.15	14	0.32	0.04
BOD, MG/L	00335	1.12	13	3.9	0.3
COD, MG/L	00340	74	12	110	29
Specific Conductance, Micromhos	00095	1402	15	1700	1190
Dissolved Chloride, MG/L	00940	214	13	280	170
pH	00400	7.37	13	7.7	6.6
Dissolved Calcium, MG/L	00915	134	11	160	110
Dissolved Magnesium, MG/L	00925	21	11	26	16
Dissolved Sodium, MG/L	00930	146	11	160	130
Dissolved Potassium, MG/L	00935	1.7	11	1.9	1.5
Hardness, Ca MG/L	00900	420	11	510	340
Total Arsenic, MG/L	01002	8	12	11	5
Total Cadmium, MG/L	01027	0.45	11	2	0
Total Copper, MG/L	01042	12	12	41	0
Total Chromium, MG/L	01034	11.7 ³	12	20	<10
Total Iron, MG/L	01045	6055	11	7800	4900
Total Lead, MG/L	01051	20	12	43	3
Total Mercury, MG/L	71900	0.19	12	0.9	0.0
Total Zinc, MG/L	01092	51	12	150	10
Coliform MPN	31505	184 ⁴	14	2300	<3
Fecal Coliform MPN	31615	24 ⁵	14	300	<3

¹From USGS Well #275157082401901; data from WATSTORE, 1974-1977.

²Number of samples examined.

³6 of 12 readings were <10, or below detection limits.

⁴7 of 14 readings were <3, or below detection limits.

⁵11 of 14 readings were <3, or below detection limits.

Table 2.5.4

COMPARISON OF CHEMICAL CHARACTERISTICS
OF LANDFILL PERIMETER DITCH SURFACE WATERS
WITH THOSE OF OTHER NEARBY WATERWAYS

Parameter	Landfill		Allen Creek ¹		Cross Bayou Canal ¹	
	Max	Min	Max	Min	Max	Min
BOD	2.1	0.8	5.5	1.2	15.0	2.0
NH ₃ , MG/L N	0.13	0.05	0.26	0.02	1.5	0.35
TOT-PO ₄ , MG/L PO ₄	0.10	0.02	0.90	0.19	15.5	1.0
Total Coliform	110,000	210	42,500	40	542,000	94

¹Extracted from Central Pinellas 201.

is substantially higher than that indicated for surface waters, as shown by the specific conductance readings. Indeed, as a rule, there is a direct relationship between specific conductance readings and dissolved chloride, sodium, magnesium and calcium concentrations. With regard to metals, only chromium and mercury levels in the shallow aquifer were lower than those recorded from surface waters; all other aquifer metal concentrations were substantially higher than surface readings. Finally, bacterial concentrations in the aquifer system are well below those identified from surface waters. This is to be expected upon consideration of bacterial life cycles (fecal coliform bacteria are relatively short-lived), the filtration

of organisms through the overburden, and the higher chloride content of underlying waters.

Limestones or Floridan Aquifer - Maximum, minimum and mean concentration of significant parameters from USGS well number SF-54 (see Figure 2.5.4.a) are shown in Table 2.5.4.c. In general, chemical characteristics of contained waters are quite similar to those noted from the surficial aquifer. Shown on Figure 2.5.4.d is a comparison of water quality characteristics for surface waters, surface aquifer and limestone aquifer. The primary source of recharge for the Florida aquifer is leakage from this surficial layer, although remote from the site (vicinity of the Pasco High). The higher BOD, phosphorus and nitrate nitrogen levels in the limestone aquifer (as opposed to the readings in surface and shallow aquifer waters) suggest that the current sprayfield activities (St. Petersburg sod farm) do impact groundwater in the underlying areas; this is notably pronounced for the readily soluble nitrate nitrogen species.

2.5.5 Natural Variation of Waters - As previously discussed surface water levels are a direct response to precipitation and, as a result, surficial water table levels. Other considerable influences on water level fluctuations are discharge in a general northeasterly direction to Tampa Bay, pumping of aquifer waters, tidal cycles and evapotranspiration.

Once again, no withdrawals from study area waters will be induced by installation and operation of the proposed facility. Further discussion of groundwater characteristics is presented in the following section.

2.5.6 Groundwater - The water table level in the vicinity of the proposed facility fluctuates as a result of precipitation and,

Table 2.5.4.c

CHEMICAL CHARACTERISTICS OF LIMESTONE AQUIFER WATER¹

<u>Parameter</u>	<u>WATSTORE</u>	<u>Mean</u>	<u>N²</u>	<u>Max</u>	<u>Min</u>
Total Organic Nitrogen, MG/L	00605	0.25	12	0.49	0.0
Total Ammonia Nitrogen, MG/L	00610	0.32	6	0.66	0.05
Total Nitrite Nitrogen, MG/L	00615	0.01	6	0.02	0.0
Total Nitrate Nitrogen, MG/L	00620	0.75	6	2.9	0.0
Total Phosphorus, MG/L	00665	0.31	14	0.83	0.04
BOD, MG/L	00310	2.85	13	7.3	0.7
COD, MG/L	00340	25	4	30	17
Color, PtCU	00080	11	4	20	5
Specific Conductance, Micromhos	00095	1342	12	1600	1250
Dissolved Chloride, MG/L	00940	198	11	230	160
pH	00400	7.5	13	8.0	6.7
Dissolved Calcium, MG/L	00915	126	12	150	110
Dissolved Magnesium, MG/L	00925	30	12	34	25
Dissolved Sodium, MG/L	00930	107	12	120	97
Dissolved Potassium, MG/L	00935	15	11	16	14
Hardness, Ca MG/L	00900	436	12	390	490
Total Arsenic, MG/L	01002	2	12	6	0
Total Cadmium, MG/L	01027	0.67	12	3	0
Total Chromium, MG/L	01034	11 ³	11	20	0
Total Copper, MG/L	01042	25	12	45	0
Total Iron, MG/L	01045	2562	11	4400	130
Total Lead, MG/L	01051	50	12	160	2
Total Mercury, MG/L	71900	0.19	10	0.6	0.0
Total Zinc, MG/L	01092	55	12	150	0
Coliform MPN	31505	287	9	2400	4
Fecal Coliform MPN	31615	112 ⁴	11	1100	<3

¹From USGS Well #275210082395901; WATSTORE Data, 1973-1974.

²Number of samples examined.

³3 of 11 readings were <10, or below detection limits.

⁴5 of 11 readings were <3, or below detection limits.

TABLE 2.5.4.d

COMPARISON OF QUALITY PARAMETERSFROM SURFICIAL AND SURFACE/DEEP AQUIFER WATER¹

	Surface	Surface Aquifer	Limestone Aquifer
Total Organic Nitrogen	0.99	0.77	0.25
Ammonia	0.08	0.34	0.32
Nitrate	0.00	0.04	0.75
Phosphorus	0.06	0.15	0.31
BOD	1.59	1.12	2.85
COD	52	74	25
Color	53	-	11
Conductance	504	1,402	1,342
Dissolved Chloride	43	214	198
pH	7.7	7.4	7.5
Dissolved Sodium	29	146	107
Dissolved Magnesium	7.1	21	30
Dissolved Calcium	72	134	126
Hardness	210	420	436
Arsenic	1.8	8	2
Cadmium	0.2	0.45	0.67
Chromium	15	11.7	11
Copper	5.7	12	25
Iron	251	6,055	2,562
Lead	4.2	20	50
Mercury	0.28	0.19	0.19
Zinc	20	51	55
Coliform	16,114	184	287
Fecal Coliform	1,074	24	112

¹ Mean Values, MG/L

to a lesser degree, evapotranspiration, seepage to the Floridan aquifer, pump-out by local wells and discharge to Tampa Bay. Figures 2.5.6.a and 2.5.6 b illustrate water table contours in the study area for May and October, respectively. From these figures it is evident that the water table, relatively low as a result of drier winter and early spring months, is substantially elevated by October due to the prevalence of rain during the summer months. This phenomenon is also a characteristic of the Floridan aquifer. Figure 2.5.6.c features a comparison of potentiometric surfaces in that aquifer for the months of May and September. Again, abundant summer precipitation and subsequent seepage of the rainwater through the confining deposits increases local artesian pressures, thus expanding the areal coverage of the five foot contour in Pinellas County.

Data concerning aquifer transmissivity and flow velocity are available for the Toytown landfill, located approximately one mile east of the proposed facility. From this information, based on direct monitoring of on-site wells, a languid, northeastward flow of groundwater from the study area has been noted. Due to the extreme gentleness of the water table gradient and the low horizontal hydraulic conductivity of the water bearing strata, the velocity of groundwater from Toytown to the bay has been estimated at one (1) foot per year, assuming a four foot water table head at the northeast boundary of the landfill property and an effective porosity of 0.31. Assuming these conditions it is estimated




FIGURE 2.5.6.a.






FIGURE 25.6.b.

FIGURE 2.5.6.c.



POTENTIOMETRIC SURFACE OF FLORIDIAN AQUIFER

that a minimum of 10,000 years will elapse before water seeping from the proposed facility site into the groundwater will reach Tampa Bay. Leakage from the surface aquifer through the confining bed into the Floridan aquifer has also been estimated for the Toytown landfill. By utilizing Darcy's Law the seepage rate at Toytown was calculated at 15,100 gallons per day or 5.5 million gallons per year; average leakage through a one foot square of confining bed soil column is estimated at 0.0014 gallons per day. Furthermore, vertical groundwater velocity through the confining bed has been estimated at 0.00074 feet per day, under steady state conditions. With these factors in mind, leachate from landfilling activities would take approximately 100 years to flow through the confining bed into the Floridan Aquifer.

2.6 Meteorology

Temperature - The St. Petersburg/Clearwater region is classified as sub-tropical with temperatures being heavily modified by the Gulf and coastal waters surrounding the peninsula. Mean daily maximum temperatures during the four summer months of July, July, August and September are near 90°F. These maxima drop to just over 70°F for the winter months. Minimum temperatures during summer are in the mid 70's ranging to the mid-50's for the winter (see Table 2.6.a). Extreme highs and lows are rare due to the modifying influence of the surrounding water. The record highest temperature for a period of 25 years

TABLE 2.6.1

Temperature Means and Extremes (°F).

1st Entry - Tampa, Florida (Period of Record is: 1941 - 1970)

2nd Entry - St. Petersburg, Fla. (Period of Record is: 1951 - 1974)

Month	Monthly Mean	Average Daily Maximum	Average Daily Minimum	Record Maximum	Record Minimum
January	60.4	70.6	50.1	84	23
	62.2	70.3	54.1	85	29
February	61.8	71.9	51.7	88	24
	63.2	71.4	55.1	86+	32
March	66	76.1	55.9	91	34
	67.6	75.6	59.5	88	39+
April	72	82.4	61.6	93	40
	73.2	81.3	65	91+	49+
May	77.2	87.5	66.9	98	49
	78.4	86.6	70.2	96	56+
June	81	89.9	72	98	61
	81.7	89.1	74.3	98	61
July	81.9	90.1	73.7	97	63
	82.9	89.9	75.8	97+	66
August	82.2	90.4	74.0	98	67
	82.9	89.9	75.8	97	66
Sept.	80.8	89	72.6	96	59
	81.6	88.6	74.6	95+	62
Oct.	74.7	83.9	65.5	94	40
	75.9	83.3	68.5	96	47
November	66.8	77.1	56.4	90	23
	68.7	76.7	60.7	89	35+
December	61.6	72.0	51.2	86.	18
	63.4	71.5	55.3	84+	22
Annual	72.2	81.7	62.6	98	18
	73.5	81.2	65.7	98	22

between 1951 to 1974 was 98°F in June of 1964 while the record low was 22°F in December 1962. The maximum frost probability during any winter season is 30%.

Precipitation (Table 2.6.b) - The dominant climatological feature of the region is its summertime thunderstorm season. During the months of June, July, August and September, the Tampa Bay area experiences an average of 90 days with thundershower activity. This produces mean monthly rainfall amounts between 6 and 9 inches. A secondary maximum of just over 4 inches occurs in March while the winter months of November through January contribute between 2 and 3 inches. The late Spring months of April and May are also relatively dry with averages below 3 inches. Snowfall contributions are negligible. Only trace amounts have been recorded for the months of January and February during the 25 year period of record. The occurrence of fog is generally limited to the cooler season of the year. The mean number of days with heavy fog are 6 and 5 respectively for January and December while during the summer months, a mean of less than one day has been recorded.

Severe Storms - The risk of a hurricane moving in from the Gulf of Mexico has been greatest in June and October. A tropical storm of July 28-29, 1960, brought the Tampa Bay region its heaviest rain: 12.11 inches in 24 hours. The most destructive and highest tide occurred during the Gulf hurricane of October 21, 1921 when a tide level of 10.5 feet above mean low water was

TABLE 3.6.5
Precipitation (inches)

1st Entry - Tampa, Fla. (Period of record is 1941 - 1970)
2nd Entry - St. Petersburg, Fla. (Period of record is 1951 - 1974)

Month	Mean	Record Monthly Rainfall	Record Daily Rainfall
January	2.33	8.02	3.29
	2.41	5.91	3.6
February	2.86	7.95	3.25
	3.35	8.26	4.1
March	3.89	12.64	5.20
	4.15	11.33	3.4
April	2.10	6.59	3.70
	2.58	8.45	5.05
May	2.41	8.13	4.10
	2.92	10.64	3.75
June	6.49	13.75	5.53
	6.65	23.00	9.14
July	8.43	20.59	12.11
	8.43	16.46	6.72
August	8.0	18.59	5.37
	8.94	17.93	5.3
September	6.35	13.04	4.67
	7.70	18.60	5.4
October	2.54	7.36	2.54
	3.35	14.12	3.39
November	1.79	6.12	4.22
	2.26	6.85	4.4
December	2.19	6.66	3.28
	<u>2.51</u>	<u>6.77</u>	<u>3.3</u>
Annual	49.38	20.59	12.11
	55.25	23.00	9.14

recorded. A maximum wind speed of over 75 mph sustained for a period of 5 minutes resulted during passage of the Labor Day hurricane in September, 1935.

Atmospheric Stability (Table 2.6.c) - Stability in the atmosphere is an important consideration when studying the dispersion of pollutants. It provides for a measure of vertical mixing similar to the manner in which wind is used to calculate horizontal transport. Highly stable atmospheres inhibit the vertical distribution of a pollutant laden bubble or stream of hot air exiting a boiler stack whereas an unstable atmosphere allows warm plumes to reach considerable heights. Generally speaking, stability is weakened (more unstable) when a colder air mass moves over warmer surfaces or when strong solar insolation warms the surface. Stability increases when surface cooling occurs such as during clear nights or when a warm air mass moves over a colder surface. Over land surfaces, maximum stabilities usually occur near sunrise, especially when wind speeds are light. Frequently a temperature inversion will develop as a result of night time radiative surface cooling. This serves as an effective barrier against vertical mixing which results in the trapping of pollutants in a relatively shallow layer above the earth's surface.

Land-Sea Breeze Effects - Land surfaces near relatively large bodies of water are subject to a circulation pattern known as Land-Sea Breezes. Since land surfaces warm up quickly

TABLE 2.6.c

MONTHLY RELATIVE FREQUENCY OF OCCURRENCE - PASQUILL'S STABILITIES
TAMPA, FLORIDA (1971 - 1975)

MONTH	Pasquill's Stability Class (% Relative Frequency)							
	A	B	C	D	E	F	G	H
January	0.	2.66	12.66	22.18	23.95	14.52	17.98	6.05
February	0.	3.13	9.55	24.82	24.91	17.59	14.55	5.45
March	0.	2.58	13.47	21.46	23.22	16.77	16.37	6.13
April	0.17	5.0	14.17	22.33	18.67	18.92	14.58	6.16
May	0.08	6.94	20.32	22.66	14.84	16.45	13.95	4.76
June	0.17	10.75	21.50	17.58	17.16	15.50	13.42	3.92
July	0.56	10.65	20.32	18.47	12.26	17.74	15.24	4.76
August	0.56	13.31	15.89	14.60	11.13	20.40	19.84	4.27
September	0.58	8.33	13.67	14.92	13.67	21.33	23.42	4.08
October	0.08	5.32	13.07	19.03	14.27	18.23	23.63	6.37
November	0.	2.83	14.83	19.83	17.92	18.17	21.75	4.67
December	0.	2.02	13.15	22.33	21.69	15.16	18.31	7.34

due to solar insolation and cool quickly under nocturnal radiation, the resultant temperature differences between land and water surfaces produce off-shore breezes at night and on-shore breezes during the day when prevailing synoptic wind conditions do not override this effect. Pinellas County is effectively surrounded on three sides by water which serves to enhance the land-sea breeze effect. Thus, when synoptic winds are light, there is a general outflow of surface air from the peninsula at night and an inflow during day time. Inflow during the day results in wind convergence and rising air which promotes good vertical transport and an increase in convective shower activity. Conversely, at night, surface outflow causes subsidence over the peninsula which increases the stability, thus inhibiting convective shower development. Prevailing wind patterns affecting the Pinellas peninsula are featured in Figure 2.6.a (monthly wind roses are featured in Figures 2.6.b through 2.6.d); Table 2.6.d identifies joint wind speed-stability-direction frequencies calculated from the 1970-1975 Tampa Airport data base.

2.7 Ecology

The discussion of ambient ecology will focus on that area shown in Figure 2.7.a, with special emphasis on those areas which will be impacted by construction and operation of the proposed resource recovery plant and associated facilities (Figure 2.7.b).

The proposed site is within a tract of land owned by Pinellas County and leased to private concerns as a sanitary landfill. This area of Pinellas County is typified by undeveloped




FIGURE 2.6.a

CLIMATOLOGICAL WIND ROSE FOR MACDILL AFB (1941-1972)

NOTE: Barb length indicates relative frequency; numbers indicate average wind speed in knots.

FIGURE 2.6.b.
MONTHLY WIND ROSES
McDILL AFB, 1942-1972







FIGURE 2.6.b.
MONTHLY WIND ROSES
McDILL AFB, 1942-1972




MAY CALM-9.8%



JUN. CALM-11.9%




JUL. CALM-14.3%




AUG. CALM-16.0%


FIGURE 2.6.b.
MONTHLY WIND ROSES
McDILL AFB, 1942-1972




SEP. CALM - 10.3%



OCT. CALM - 8.4%



NOV. CALM - 9.4%



DEC. CALM - 10.0%

TABLE 2.6.d

PINELLAS COUNTY MODEL (USES 1971-1974 STAR DATA - JOINT FREQUENCY FUNCTION)

RUN 6

METEOROLOGICAL JOINT FREQUENCY FUNCTION

STABILITY CLASS 1

WIND SPEED CLASS

WIND DIRECTION	SECTOR	WIND SPEED CLASS					
		1	2	3	4	5	6
N	1	.000020	.000140	0.000000	0.000000	0.000000	0.000000
NNE	2	.000020	.000140	0.000000	0.000000	0.000000	0.000000
NE	3	.000020	.000140	0.000000	0.000000	0.000000	0.000000
ENE	4	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
E	5	.000020	.000140	0.000000	0.000000	0.000000	0.000000
ESE	6	.000010	.000070	0.000000	0.000000	0.000000	0.000000
SE	7	.000010	.000070	0.000000	0.000000	0.000000	0.000000
SSE	8	.000010	.000070	0.000000	0.000000	0.000000	0.000000
S	9	.000100	.000140	0.000000	0.000000	0.000000	0.000000
SSW	10	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
SW	11	.000040	.000210	0.000000	0.000000	0.000000	0.000000
WSW	12	.000020	.000140	0.000000	0.000000	0.000000	0.000000
W	13	.000100	.000140	0.000000	0.000000	0.000000	0.000000
WNW	14	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
NW	15	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000
NNW	16	.000010	.000070	0.000000	0.000000	0.000000	0.000000

STABILITY CLASS 2

WIND SPEED CLASS

WIND DIRECTION	SECTOR	WIND SPEED CLASS					
		1	2	3	4	5	6
N	1	.000220	.001440	.000890	0.000000	0.000000	0.000000
NNE	2	.000290	.001510	.001230	0.000000	0.000000	0.000000
NE	3	.000370	.001510	.000620	0.000000	0.000000	0.000000
ENE	4	.000420	.001160	.000960	0.000000	0.000000	0.000000
E	5	.000670	.003220	.002670	0.000000	0.000000	0.000000
ESE	6	.000970	.002120	.001300	0.000000	0.000000	0.000000
SE	7	.000430	.001440	.001370	0.000000	0.000000	0.000000
SSE	8	.000300	.001710	.001300	0.000000	0.000000	0.000000
S	9	.000600	.001700	.001370	0.000000	0.000000	0.000000
SSW	10	.000360	.001440	.001440	0.000000	0.000000	0.000000
SW	11	.000440	.001580	.002740	0.000000	0.000000	0.000000
WSW	12	.000180	.002120	.004250	0.000000	0.000000	0.000000
W	13	.000680	.003360	.005960	0.000000	0.000000	0.000000
WNW	14	.000270	.001030	.000620	0.000000	0.000000	0.000000
NW	15	.000250	.000680	.000340	0.000000	0.000000	0.000000
NNW	16	.000470	.000750	.000620	0.000000	0.000000	0.000000

CLIMATOLOGICAL DISPERSION MODEL

TABLE 2.6.d
(cont.)

PINELLAS COUNTY MODEL (USES 1971-1974 STAR DATA - JOINT FREQUENCY FUNCTION)
RUN 6

METEOROLOGICAL JOINT FREQUENCY FUNCTION

STABILITY CLASS 3

WIND SPEED CLASS

WIND DIRECTION	SECTOR	1	2	3	4	5	6
N	1	.000260	.000750	.003770	.000270	0.000000	0.000000
NNE	2	.000220	.001370	.003700	.000620	0.000000	0.000000
NE	3	.000280	.001230	.004520	.000550	0.000000	0.000000
ENE	4	.000430	.002530	.007670	.001100	0.000000	0.000000
E	5	.000690	.004660	.010550	.002050	0.000000	0.000000
ESE	6	.000250	.001990	.006230	.000890	0.000000	0.000000
SE	7	.000360	.001370	.006920	.000270	0.000000	0.000000
SSE	8	.000320	.001850	.006920	.000750	0.000000	0.000000
S	9	.000220	.001440	.005960	.001230	0.000000	.000070
SSW	10	.000270	.001030	.005620	.002120	0.000000	0.000000
SW	11	.000090	.001580	.005340	.001230	0.000000	0.000000
WSW	12	.000260	.002190	.008490	.001030	0.000000	0.000000
W	13	.000180	.001990	.017260	.006640	.000210	0.000000
WNW	14	.000200	.001100	.002810	.001230	.000070	.000070
NW	15	.000090	.000270	.002190	.000620	.000140	0.000000
NNW	16	.000120	.000820	.002050	.000750	.000210	0.000000

STABILITY CLASS 4

WIND SPEED CLASS

WIND DIRECTION	SECTOR	1	2	3	4	5	6
N	1	.000010	.000960	.002670	.004660	.000410	0.000000
NNE	2	.000010	.001300	.002740	.003290	.000140	0.000000
NE	3	.000010	.001370	.004180	.005750	.000210	.000070
ENE	4	.000090	.002330	.006370	.006850	.000410	0.000000
E	5	.000040	.005750	.009930	.008700	.000410	0.000000
ESE	6	.000090	.002400	.004040	.006230	0.000000	0.000000
SE	7	.000150	.001990	.004380	.004660	.000070	0.000000
SSE	8	.000020	.002260	.004450	.005270	.000210	0.000000
S	9	.000160	.002330	.004860	.007670	.000410	.000070
SSW	10	.000150	.001030	.003490	.006300	.000550	0.000000
SW	11	.000010	.000960	.002400	.002810	.000140	0.000000
WSW	12	.000010	.000890	.003080	.004320	.000070	0.000000
W	13	.000010	.001230	.007190	.017190	.000210	0.000000
WNW	14	0.000000	.000480	.001990	.005340	.000000	.000210
NW	15	0.000000	.000000	.001990	.005680	.000000	.000340
NNW	16	0.000000	.000000	.001990	.005680	.000000	.000340

CLIMATOLOGICAL DISPERSION MODEL

TABLE 2.6.d
(cont.)

PINELLAS COUNTY MODEL (USES 1971-1974 STAR DATA - JOINT FREQUENCY FUNCTION)

RUN 6

METEOROLOGICAL JOINT FREQUENCY FUNCTION

STABILITY CLASS 5		WIND SPEED CLASS					
WIND DIRECTION	SECTOR	1	2	3	4	5	6
N	1	.000550	.001230	.007260	.003560	0.000000	0.000000
NNE	2	.000230	.001850	.004590	.003560	.000140	0.000000
NE	3	.000540	.001920	.006100	.004860	.000070	0.000000
ENE	4	.000780	.002120	.009180	.003220	.000070	0.000000
E	5	.001010	.003080	.014790	.005890	.000070	0.000000
ESE	6	.000350	.001510	.008840	.001990	.000140	0.000000
SE	7	.000290	.001710	.007400	.002330	.000140	0.000000
SSE	8	.000300	.000960	.006440	.002740	.000070	.000070
S	9	.000560	.002260	.007600	.002810	.000340	0.000000
SSW	10	.000110	.000410	.003360	.001710	0.000000	0.000000
SW	11	.000230	.000960	.001230	.001030	.000070	0.000000
WSW	12	.000100	.000340	.003150	.001510	0.000000	0.000000
W	13	.000170	.001100	.007880	.003010	.000070	0.000000
WNW	14	.000420	.000550	.003560	.003290	.000550	.000070
NW	15	.000170	.001160	.003840	.003290	0.000000	.000140
NNW	16	.000210	.000680	.004730	.002950	.000070	0.000000

STABILITY CLASS 6		WIND SPEED CLASS					
WIND DIRECTION	SECTOR	1	2	3	4	5	6
N	1	.001430	.004040	.001990	0.000000	0.000000	0.000000
NNE	2	.001590	.004250	.001960	0.000000	0.000000	0.000000
NE	3	.002300	.006670	.002260	0.000000	0.000000	0.000000
ENE	4	.003870	.011210	.003150	0.000000	0.000000	0.000000
E	5	.004900	.017100	.004250	0.000000	0.000000	0.000000
ESE	6	.003010	.007420	.001920	0.000000	0.000000	0.000000
SE	7	.002160	.004310	.001870	0.000000	0.000000	0.000000
SSE	8	.001010	.004250	.001140	0.000000	0.000000	0.000000
S	9	.001200	.003450	.000870	0.000000	0.000000	0.000000
SSW	10	.000390	.001440	.000620	0.000000	0.000000	0.000000
SW	11	.000540	.002350	.000460	0.000000	0.000000	0.000000
WSW	12	.000490	.001440	.000550	0.000000	0.000000	0.000000
W	13	.001200	.002370	.001600	0.000000	0.000000	0.000000
WNW	14	.000730	.002490	.001210	0.000000	0.000000	0.000000
NW	15	.001130	.004820	.002260	0.000000	0.000000	0.000000
NNW	16	.001300	.003190	.001420	0.000000	0.000000	0.000000





FIGURE 2.7d.

MAJOR PLANT COMMUNITIES SURROUNDING SITE

FIGURE 2.7.b.



MAJOR PLANT COMMUNITIES AT THE FACILITY SITE

- | | |
|---|--|
|  PINE-FLATWOODS |  STANDING WATER (CANALS, LAKES) |
|  WET-WEATHER PONDS AND DITCHES |  AREAS CURRENTLY OR PREVIOUSLY DISTURBED BY MAN |

land, pasturage and light industrial sites. Portions of the facility site, as well as contiguous tracts, have been mechanically disturbed due to landfill operation.

Four distinct plant communities can be found within the study area: the pine flatwoods, wet weather ponds, permanent ponds and disturbed areas.

The pine flatwoods community is the dominant ecosystem and occupies those sites which are slightly more elevated and less disturbed by man than surrounding areas. Generally, the flatwoods are situated on poorly drained, acidic sands of marine origin. An organic hardpan usually underlies the surface at a depth of from 2 to 3 feet rendering these sites poor aquifer rechargers; runoff is directed to adjacent lowlands and wet weather ponds where groundwater interactions are intimate. The South Florida slash pine forms the primary canopy of this woodland community, with scattered specimens of oaks, American holly and persimmon found in better drained locations. The understory is composed primarily of wax myrtle, saw palmetto and gallberry; species of wiregrass and panicgrass flourish on the forest floor. With respect to wildlife, the pine flatwoods offer habitat and forage to a wide variety of animals, among them such important sport species as the bobwhite quail, mourning dove and cottontail rabbit. The disturbed nature of site environs precludes the occurrence of larger mammals in the study area, notably the black bear and white-tailed deer. The terminal trophic level in the study area pine flatwoods is probably occupied by the

grey fox and stray dogs. A listing of animals and plants common to the study area is featured in Table 2.7.a.

Surficial outcroppings of the water table aquifer are quite common to lower elevations in the study area, especially during the rainier summer and fall months. At these sites a unique biological community, the wet weather pond, is found. This habitat is a relatively harsh environment for organisms to colonize due to the physiological stresses incurred by the intermittent occurrence of standing water. The vegetation in these areas is composed of several sedges and rushes, with willows and (in semi-disturbed areas) Brazilian pepper trees fringing the littoral. In ponds with maximal duration periods of standing water, cattails and maidencane may be found. The occurrence of animal species, with the exception of a few hardy insects and amphibians is greatly regulated by the presence of water in the pond. For example, during wet periods, large numbers of wading birds (egrets, bittern, etc.) and mammals (raccoon, etc.) frequent these areas to feed and drink; the ubiquitous mosquito fish is also prevalent during such times. In contrast the dry season yields little in the way of species diversity with transient occurrences of pine flatwoods' organisms most common. During dry periods those endemic insects must enter a dormant state until standing water returns; adaptations by vegetation, primarily with respect to root structure and stoma functions, permit continued absorption of soil moisture while suppressing transpirational water losses.

TABLE 2.7.a

PLANTS AND ANIMALS COMMON TO THE STUDY AREA

	Pine Flatwood	Wet Weather Pond	Permanent Ponds	Disturbed Areas	Observed On Site
<u>PLANTS</u>					
South Fla. Slash Pine <u>Pinus elliotii var. densa</u>	C	N	N	N	yes
Runner Oak <u>Quercus pumila</u>	S	N	N	N	yes
Laurel Oak <u>Quercus laurifolia</u>	S	N	N	N	yes
American Holly <u>Ilex opaca</u>	S	N	N	N	yes
Persimmon <u>Diospyros virginiana</u>	S	N	N	N	yes
Wax Myrtle <u>Myrica cerifera</u>	C	N	N	N	yes
Dahoon Holly <u>Ilex cassine</u>	S	S	N	N	yes
Gallberry <u>Ilex glabra</u>	C	N	N	N	yes
Winged Sumac <u>Rhus copallina</u>	S	N	N	N	yes
Coastal Plains Willow <u>Salix caroliniana</u>	N	S	C	N	yes
Saw Palmetto <u>Serenoa repens</u>	C	S	N	N	yes
Duck Weed <u>Lemna</u> spp.	N	N	C	N	yes

C = very common

S = scattered occurrences

N = infrequent or no occurrences

TABLE 2.7.a (cont.)

	Pine Flatwood	Wet Weather Pond	Permanent Ponds	Disturbed Areas	Observed On Site
Poke Berry <u>Phytolacca americana</u>	S	N	N	S	yes
Brazilian Pepper <u>Schinus terebinthifolius</u>	N	S	S	C	yes
Wiregrass <u>Aristida stricta</u>	C	S	N	N	yes
Virginia Creeper <u>Parthenocissus quinquefolia</u>	C	N	N	N	yes
Lantana <u>Lantana involucrata</u>	N	N	N	C	yes
Panicgrass <u>Panicum</u> spp.	S	C	N	S	yes
Johnson Grass <u>Sorghum halpense</u>	N	N	N	C	yes
Baccharis <u>Baccharis</u> spp.	S	N	N	N	yes
Dog Fennel <u>Eupatorium</u> spp.	N	N	N	C	yes
Aster <u>Aster</u> spp.	S	N	N	C	yes
Sedges <u>Carex</u> spp.	S	C	C	S	yes
Paw Paw <u>Asimina</u> spp.	S	N	N	S	yes
Arrowleaf <u>Sagittaria</u> spp.	N	S	C	N	yes

C = very common

S = scattered occurrences

N = infrequent or no occurrences

TABLE 2.7.a (cont.)

	Pine Flatwood	Wet Weather Pond	Permanent Ponds	Disturbed Areas	Observed On Site
Cattails Family Typhoaceae	N	C	C	N	yes
Rushes <u>Juncus</u> spp.	N	C	C	N	yes
Sawgrass <u>Caladium jamicensus</u>	N	C	C	N	yes
Maidencane <u>Panicum</u> spp.	N	S	C	N	yes
<u>FISHES</u>					
Eastern Mosquito Fish <u>Gambusia affinis</u>	N	S	C	N	yes
Sunfish <u>Lepomis</u> spp.	N	N	C	N	yes
Gar <u>Lepisosteus</u> spp.	N	N	C	N	yes
Black Bass <u>Micropterus salmoides</u> <u>floridanus</u>	N	N	C	N	no
Top Minnows <u>Fundulus</u> spp.	N	N	C	N	no
<u>AMPHIBIANS</u>					
American Toad <u>Bufo americanus</u>	S	S	N	S	no

C = very common
S = scattered occurrences
N = infrequent or no occurrences

TABLE 2.7.a (cont.)

	Pine Flatwood	Wet Weather Pond	Permanent Ponds	Disturbed Areas	Observed On Site
Spring Peeper <u>Hyla crucifer</u>	C	C	S	N	no
Green Tree Frog <u>Hyla cinerea</u>	C	C	S	N	no
<u>REPTILES</u>					
Eastern Diamondback Rattlesnake <u>Crotalus adamanteus</u>	C	S	N	N	yes
Ground Rattlesnake <u>Sistrurus milarius barbouri</u>	C	S	N	N	no
Corn snake <u>Elaphe guttata guttata</u>	C	S	N	S	no
Yellow Rat Snake <u>Elaphe obsoleta</u> <u>quadriuttata</u>	C	S	N	S	no
Gopher Tortoise <u>Gopherus polyphemus</u>	C	N	N	N	yes
Ground Skink <u>Lygoroma laterale</u>	C	S	N	N	yes
American Alligator <u>Alligator mississippiensis</u>	N	N	S	N	no
Green Anole <u>Anolis carolinensis</u> <u>carolinensis</u>	C	S	N	S	no

C = very common
 S = scattered occurrences
 N = infrequent or no occurrences

TABLE 2.7.a (cont.)

	Pine Flatwood	Wet Weather Pond	Permanent Ponds	Disturbed Areas	Observed On Site
<u>BIRDS</u>					
Mourning Dove <u>Zenaida macroura</u>	C	S	N	N	yes
Fish Crow <u>Corvus ossifragus</u>	C	S	S	C	yes
Pine Warbler <u>Dendroica pinus</u>	C	S	N	N	no
Black Vulture <u>Coragyps atratus</u>	S	S	S	S	no
White Eyed Vired <u>Vireo griseus</u>	S	S	N	N	no
Bob-White Quail <u>Colinus virginianus</u>	C	N	N	N	no
White Ibis <u>Eudocimus albus</u>	N	S	S	N	yes
Rufous Sided Towhee <u>Pipilo erythrophthalmus</u>	S	S	N	N	yes
Red Winged Blackbird <u>Agelaius phoeniceus</u>	N	S	C	N	yes
Mockingbird <u>Mimus polyglottus</u>	C	S	N	N	no
Gulls <u>Larus spp.</u>	N	S	S	C	yes
Killdeer <u>Charadrius vociferus</u>	N	S	S	S	yes

C = very common

S = scattered occurrences

N = infrequent or no occurrences

TABLE 2.7.a (cont.)

	Pine Flatwood	Wet Weather Pond	Permanent Ponds	Disturbed Areas	Observed On Site
Cardinal <u>Richmondena cardinalis</u> <u>floridana</u>	C	S	N	N	Yes
Blue Jay <u>Cyanocitta cristata cristata</u>	C	S	N	N	Yes
American Coot <u>Fulica americana</u>	N	S	C	N	Yes
Florida Gallinule <u>Gallinula chloropus</u> <u>cachinnans</u>	N	S	C	N	Yes
Purple Gallinule <u>Porphyryla martinica</u>	N	S	S	N	no
American Egret <u>Casmerodius albus egretta</u>	N	S	S	N	yes
American Bittern <u>Botaurus lentiginosus</u>	N	S	S	N	no
<u>MAMMALS</u>					
Field Mouse <u>Peromyscus floridanus</u>	C	S	N	S	no
Cotton Rat <u>Sigmoden hispidus</u>	C	S	S	S	yes
Cottontail Rabbit <u>Sylvilagus floridanus</u>	C	S	N	N	yes
Marsh Rabbit <u>Sylvilagus palustris</u>	C	C	S	N	yes

C = very common
S = scattered occurrences
N = infrequent or no occurrences

TABLE 2.7.a (cont.)

	Pine Flatwood	Wet Weather Pond	Permanent Ponds	Disturbed Areas	Observed On Site
Raccoon <u>Procyon lotor</u>	C	S	S	S	no
Opossum <u>Didelphs marsupialis</u>	C	S	N	S	no
Armadillo <u>Dasypus novemcinctus</u>	C	S	N	S	yes
Grey Fox <u>Urocyon cinereoargenteus</u>	S	S	N	N	no
Southeastern Pocket Gopher <u>Geomys floridanus</u>	C	S	N	S	no
Striped Skunk <u>Mephitis mephitis</u>	C	S	N	S	no
Short-Tailed Shrew <u>Blarina brevicauda</u>	C	S	N	N	no
Bats <u>Myotis</u> spp.	S	N	N	N	no

C = very common

S = scattered occurrences

N = infrequent or no occurrences

In many areas within the study area surface excavations for landfilling, quarry operations and drainage have produced permanent ponds, canals, and marshes with sufficient depths so that a perennial water level is maintained. In most cases, due to the highly enriched nature of landfill runoff and leachate, these water bodies are quite eutrophic, thus heavily vegetated. In some areas, notably in perimeter canals, lush growths of duck weed permeate the water column from shore to shore. The littoral zone of larger ponds is almost exclusively composed of emergent plants such as sawgrass, cattails and maidencane. Rushes and sedges often occur in the superlittoral area between high and low water zones. Animals residing in the pond/marsh habitat are those typically associated with such systems in the Florida peninsula. Specifically, wading birds, such as the American egret and bittern, are frequently noted in the littoral zone among cattails and sawgrass; these carnivores also frequent the shallow rush areas in search of snails and frogs. Non-migratory waterfowl, in essence the American coot, are quite abundant in deeper ponds where heavy growths of aquatic weeds prevade. Gallinules, while not as common, could be seen walking on the thick mats of duck weed in search of small fish and insects. While first hand observation of the American alligator was not reported, it is speculated that, given the habitat and food supply found in the large pond one-half mile west of the facility site, the probability of occurrence of this species is quite high; this factor also pertains to other aquatic

herpetiforme animals such as the bullfrog, the cottonmouth mocassin and the painted turtle. Based on observations of juvenile sunfish and an adult alligator gar in perimeter canals, it is further conjectured that those fishes typical of eutrophic coastal plain ponds will be found in most permanent study area waters. Indeed, discussions with a local fisherman reveal that hefty black bass have been caught in the large pond located west of the facility site. Mammals which frequent the pond shorelines are the marsh rabbit, the opossum and, most commonly, the raccoon.

Disturbed tracts of land abound in the study area and consist of active landfill sites, quarry pits and abandoned but revegetated dumps. As is typical of such areas in South Florida, the Brazilian pepper and melaleuca trees dominate this altered terrain. Understory, when present (as Brazilian pepper often forms dense thickets, thus inhibiting sunlight penetration), is usually comprised of Johnson grass, poke berry and lantana. While the berries of the Brazilian pepper do attract large numbers of birds, most notably migratory robins, this monospecific habitat is generally considered to be of marginal value with respect to the propagation and sustenance of wildlife. The dominant animals occurring in disturbed areas are typified by raccoons, stray dogs, rats and a large variety of avian scavengers, primarily sea gulls.

2.7.1 Important Species - Several game species of animals are common to the study area; specifically, these are the bob-white quail, the mourning dove, the cottontail rabbit, the large mouth

bass and the bluegill sunfish. Incidences of migratory waterfowl in the study area are not reported although there is a distinct possibility of such occurrences.

Except for the fishes and waterfowl, all important game species can be found in the pine flatwoods community. The bobwhite quail constructs nests in drier ground locations, such as the base of a tree or fence post; these birds will forage on such flatwood delicacies as palmetto berries and gallberries. The mourning dove nests in pine boughs within the tree canopy; dove also frequent wet weather ponds and roadways, in search of water. The primary food supply for these birds is composed of seeds, small grains and berries. The cottontail rabbit, like the quail, nests on the ground in drier locations. It feeds primarily on grass shoots and other succulent vegetation; however, predation on insects is not uncommon. The large mouth bass, as well as other Centrarchid fishes, are found primarily in the large permanent pond located west of the proposed facility. Migration or colonization by larger specimens into perimeter canals is probably inhibited by water level fluctuations and weed blockages. As is reported from many South Florida systems, the highly productive, eutrophic nature of the ponds and canals yield large populations of bream and bluegill due to abundant food supplies (insects, minnows) and readily available refuges from predation (weeds). This overpopulation, though, severely limits the growth of individual specimens, thus the desirability of these organisms from a sportfishing standpoint is lessened.

Specimens of black bass, on the other hand, reach substantial (greater than 5 pounds) weights; their population, though, is restricted by an abundant yet elusive prey, intraspecific cannibalism and the limited availability of optimum breeding sites.

Within the study area two rare, endangered or threatened species are thought to occur. As previously cited, the threatened American alligator probably inhabits the large study area permanent pond. The wood ibis has also been noted in the general vicinity of the study area and, during the rainy season, could frequent the wet weather ponds. Nevertheless, local nesting or prolonged residency by this endangered bird is not reported.

2.7.2 Abundance of Organisms - The organisms which habitate the pine flatwoods community appear to be present in balanced proportions except for the absence of larger consumers, such as deer and bobcats. The extirpation of such organisms is usually attributed to those man-induced stresses discussed in the next section.

Aquatic communities contain a conventional trophic structure with a relatively stable species fluctuation. The excessive vegetation in certain areas can contribute to untoward conditions, notably algal die-offs and oxygen depletion. This, in many areas, could seriously alter the localized fauna, although recovery from such stresses is generally quite rapid.

Animals and plants invading disturbed areas are very habitat specific and usually number only a few species. The monospecific nature of these disturbed zones makes them very unstable, thus poor habitat for other organisms.

2.7.3 Pre-Existing Stresses - As cited throughout this section, much of the study area has been substantially modified by landfilling and mining activities. Even the large pond, referenced in preceding sections, occurs on an abandoned landfill tract. By this, the highly nutrified nature of surface waters is quite understandable. However, as the health and productivity of that community lie in apparent equilibrium, the capabilities of natural systems to assimilate excessive organic waste loads is amply demonstrated.

Perhaps the most influential factor imparted to study area plant communities is the general lowering of the water table by surface excavations. If the degree of level reduction is small (as is the case for the study area) then the pine flatwoods community would not be as adversely affected as would the wet weather pond system.

Finally, a unique fauna of animals, primarily birds, have developed a trenchant dependence on landfills for a source of food. Indeed, the Toytown landfill (a mile to the east) is a popular study site for ornithologists during Christmas bird surveys.

2.8 Ambient Air

2.8.1 Baseline Data

° General

Analyzing the 1977 and 1978 data, ambient levels are below the Florida Ambient Air Quality Standards. While data obtained during the first four months of 1978 (Table 2.8.1.a) indicate that particulate levels are increasing, this factor is mitigated upon realization that higher levels of air pollution are typically measured during the winter months when air stagnations are common and worse case situations occur. Although 1977 data are not available for comparison, an arithmetic average from June 1977 to April 1978 reveals that all stations are below the annual particulate standard of 60 micrograms per cubic meter.

° Carbon Monoxide

Carbon monoxide is a colorless, odorless gas ultimately produced by incomplete combustion, primarily of carbonaceous compounds. Large amounts of this gas can be fatal, while lesser amounts can produce fatigue, headache, dizziness and general disorientation.

Available data imply that Pinellas County does not have a carbon monoxide problem. The one and eight hour standards were not exceeded in 1976 or 1977 at either of the two monitoring locations. Carbon monoxide levels have remained fairly static,

Table 2.8.1.a

SYNOPSIS OF PINELLAS COUNTY AIR QUALITY DATA

FROM JANUARY 1978 TO APRIL 1978

<u>Site</u>	<u>Concentration: ug/m³</u>						
	<u>Nitrogen Dioxide</u>		<u>Sulfur Dioxide</u>		<u>TSP</u>		<u>AM (Avg.)</u>
	<u>24 Hr. Max</u>	<u>2nd Max</u>	<u>24 Hr. Max</u>	<u>2nd Max</u>	<u>24 Hr. Max</u>	<u>2nd Max</u>	
Airport	66	42	40	7	66	62	46
Largo	51	31	3	2	86	75	49
Oakhurst	55	48	35	31	80	69	45
Koger	60	58	49	47	94	85	56
Woodlawn	72	55	51	21	112	80	61

although a slight decrease, probably due to better emission control on automobiles, has been noted. A major factor attributing to the low ambient carbon monoxide levels is the County's level topography and strong land-sea breezes which aid in the dispersion of air pollutants.

A synopsis of carbon monoxide levels in Pinellas County is given below:

Florida Ambient Air Quality Standard:

1. Nine (9) parts per million (ppm) - maximum 8 hour concentration not to be exceeded more than once per year.
2. Thirty-five (35) parts per million (ppm) - maximum one hour concentration not to be exceeded more than once per year.

	<u>1 Hour Maximum (ppm)</u>		<u>8 Hour Maximum (ppm)</u>	
	<u>*1976</u>	<u>1977</u>	<u>*1976</u>	<u>1977</u>
Clearwater	13.2	14.0	7.2	5.8
Oakhurst	-	15.5	-	5.7

* Data collection began in July 1976.

◦ Hydrocarbons

Studies conducted on the health effects of hydrocarbons have not demonstrated direct adverse effects. However, it has been shown that ambient levels of ozone are a direct function of hydrocarbon concentrations. Data correlation experiments have divulged that hydrocarbon concentrations in excess of 240 parts per billion for the 3-hour period from 6:00

to 9:00 a.m. correlate to ozone concentrations of about 100 parts per billion, occurring two to four hours later. Based on these findings, a standard for hydrocarbons (excluding methane) was set at a maximum 3-hour (6 - 9 a.m.) concentration of 240 parts per billion.

A Bendix Model 8201 flame ionization detection instrument measures reactive hydrocarbons (total hydrocarbons minus methane) at the Clearwater site. During 1977, the hydrocarbon standard was exceeded approximately 95% of the time.

° Nitrogen Dioxide

Nitrogen dioxide, a reddish-brown gas, can be produced by high temperature combustion such as the burning of gasoline in an automobile. The State of Florida has an established annual standard for this pollutant of 100 micrograms per cubic meter annual arithmetic mean; however, at the present time, there is not a short term standard for nitrogen dioxide, although 250 micrograms per cubic meter for a 24-hour maximum has been proposed.

A summary of nitrogen dioxide data obtained in Pinellas County is provided below:

Florida Ambient Air Quality Standard

1. 100 micrograms per cubic meter ($\mu\text{g}/\text{m}^3$) annual arithmetic mean.

*Bubbler Data - concentration ug/m³

	<u>24 Hour Maximum</u>	<u>2nd Maximum</u>	<u>Average</u>
Airport	49	44	32
East Lake	29	25	20
Koger	66	60	37
Largo	53	50	27
Oakhurst	62	56	27
Safety Harbor	53	44	18
Tarpon Springs	32	30	15

* Annual arithmetic mean cannot be computed.
Sampling did not begin until June 1977.

Continuous Data - concentration ug/m³

	<u>1 Hour Maximum</u>	<u>24 Hour Maximum</u>	<u>2nd 24 Hour Maximum</u>
Fencon	132	63	59
East Lake	47	27	16

o Ozone

Ozone, a colorless, pungent gas, can cause coughing, choking, headaches, and severe fatigue. In animal studies, it has been shown to lower the body's resistance to infection. It can damage the leaves of plants, crack rubber, and deteriorate fabrics.

Ozone formation is a photochemical reaction between solar radiation and nitrogen dioxide in the presence of some

hydrocarbons. The primary anthropogenic source of hydrocarbons and nitrogen dioxide is the automobile.

Reviewing the available ozone data, Pinellas County has a countywide oxidant problem. During the ozone season (April - October) the Florida Ambient Air Quality Standard has been exceeded many times at each monitoring station. Although the resource recovery facility does emit hydrocarbon (35 tons/year), the overall impact of this facility on ozone production will be insignificant. A recent hydrocarbon emissions inventory has been completed and the total emissions for the County excluding highway mobile sources is 7200 metric tons. Assuming that point sources are responsible for 50 percent of the hydrocarbon emission, the facility will emit approximately 0.2 of a percent of all hydrocarbons in Pinellas County.

In Pinellas County, ozone concentration can be summarized as follows:

Florida Ambient Air Quality Standard

1. 80 parts per billion (ppb) - maximum 1 hour concentration, not to be exceeded more than once per year.

Concentration - PPB

	1 Hour Maximum		2nd Maximum		Number of Hours Exceeded Standard	
	*1976	1977	*1976	1977	*1976	1977
East Lake	-	175	-	125	-	37
Fencon	-	105	-	100	-	25
Koger	69	160	69	150	0	31
Oakhurst	64	135	64	130	0	65
Tarpon Springs	77	120	69	115	0	94

* Sampling began July 1976 and continued through December 1976.

◦ Sulfur Dioxide

Sulfur dioxide comes primarily from the combustion of sulfur-containing fossil fuels. It is a heavy, pungent, colorless gas that combines easily with water vapor to become sulfurous acid (H_2SO_3). In the presence of atmospheric oxygen, this compound becomes the more corrosive, irritating sulfuric acid (H_2SO_4). Sulfuric acid, a strong oxidizing agent, is destructive to bodily tissues. It destroys lung tissue and also weakens this organ's cleansing and protection mechanisms.

On a county-wide basis, sulfur dioxide concentrations are well below state standards; however, a chronic problem area is noted in northern Pinellas County in the vicinity of Tarpon Springs. Three localized sources, a chemical plant, an asphalt batching unit and a power plant are responsible for this situation.

A synopsis of sulfur dioxide data is featured below:

Florida Ambient Air Quality Standard

1. 60 micrograms per cubic meter (ug/m^3) annual arithmetic mean.
2. 260 micrograms per cubic meter (ug/m^3) - maximum 24-hour concentration, not to be exceeded more than once per year.
3. 1300 micrograms per cubic meter (ug/m^3) - maximum 3-hour concentration, not to be exceeded more than once per year.

Bubbler Data

Concentration - ug/m³

	<u>24 Hr. Maximum</u>		<u>2nd Maximum</u>		<u>Average</u>		<u>Number of Times Exceeded Standard 24 Hour Standard</u>	
	<u>1976</u>	<u>1977*</u>	<u>1976</u>	<u>1977*</u>	<u>1976</u>	<u>1977*</u>	<u>1976</u>	<u>1977</u>
Airport	-	13	-	5	-	2	-	0
East Lake	-	2	-	0	-		-	0
Koger	41	50	25	45	14	9	0	0
Largo	165	29	13	23	15	4	0	0
Oakhurst	26	62	13	30	6	5	0	0
Safety Harbor	7	21	4	15	3	2	0	0
Tarpon Springs	367	303	286	281	53	42	2	2

Continuous Data

Concentration ug/m³

	<u>24 Hour Maximum</u>	<u>2nd Maximum</u>	<u>Number of Times Exceeded 24 Hour Standard</u>
	Tarpon Springs	720	550
	<u>3 Hour Maximum Average</u>	<u>2nd Maximum</u>	<u>Number of Times Exceeded 3 Hour Standard</u>
	1898	1545	4

NOTE: Thermo Electron Model 43 with hydrocarbon cutter was installed at Tarpon Springs July 1, 1977.

* Sampling was resumed June 1977.

◦ Total Suspended Particulates

Suspended particulate matter is a name for airborne dirt, including airborne solid or liquid bodies smaller than 100 microns.

Particulate matter by itself or in association with other pollutants may irritate the human respiratory tract by mechanical abrasion, similar to the irritation caused by a speck of dirt in the eye. Small particulate matter (less than 10 microns) can penetrate deep into the lungs and destroy lung tissue.

An analysis of data indicates that county-wide TSP levels are moderate. The Safety Harbor site has recorded several high values; however, they are considered biased, as the site is located adjacent to a school being remodeled. Values from the Tarpon Springs site, located in an industrial area, have exceeded the standard once.

A review of the TSP data for Pinellas County is summarized below:

Florida Ambient Air Quality Standard

1. 60 micrograms per cubic meter - annual geometric mean.
2. 150 micrograms per cubic meter - maximum 24-hour concentration, not to be exceeded more than once per year.

TSP
Concentration ug/m³

	<u>24 Hr. Maximum</u>		<u>2nd Maximum</u>		<u>Average</u>		<u>Number of Times Exceeded Standard</u>	
	<u>1976</u>	<u>1977</u>	<u>1976</u>	<u>1977</u>	<u>1976</u>	<u>1977</u>	<u>1976</u>	<u>1977</u>
Airport	-	73	-	60	-	41	-	0
Koger	72	76	67	69	43	47	0	0
Largo	71	72	69	70	38	41	0	0
Oakhurst	77	74	67	74	40	42	0	0
Safety Harbor	95	201	74	161	41	67	0	3
Tarpon Springs	230	178	155	139	74	69	2	1

2.8.2 Data Source

The air quality data collected by the Pinellas County Department of Environmental Management, Air and Water Quality Division, were utilized to assess baseline ambient air quality conditions.

County monitoring sites which assess the air quality in the vicinity of the proposed facility are: Airport, Koger, Largo, Oakhurst, and Woodlawn (Figure 2.8.2.a). Nitrogen dioxide, sulfur dioxide and particulates are measured once every six days for twenty-four hours at each of the above locations. Federal reference procedures are used for sample collection and analysis. Bubblers have been temperature controlled since June 1977.

With regard to specific methodologies for the previously discussed pollutants (Section 2.8.1), the following statements are offered:

FIGURE 2.8.2.d.

**LOCATION OF PROPOSED FACILITY
AND PINELLAS COUNTY AIR QUALITY MONITORS**




Table 2.8.2.a

SYNOPSIS OF THE PINELLAS COUNTY

AIR QUALITY MONITORING NETWORK

	TSP	SO ₂	NO ₂	CO	O ₃	HC	Wind Speed Direction
1. Tarpon Springs	I	C,I	I	N	C	N	C
2. Safety Harbor	I	I	I	N	N	N	N
3. Clearwater	N	N	N	C	N	C	N
4. Largo	I	I	I	N	N	N	N
5. Koger	I	I	I	N	C	N	C
6. Oakhurst	I	I	I	C	C	N	N
7. East Lake	N	I	C,I	N	C	N	C
8. Fencon	N	N	C	N	C	N	N
9. Airport	I	I	I	N	N	N	N

C = Continuous Instrument

I = Intermittent Samplers

N = Not Monitored

- Carbon monoxide is monitored by an electronic instrument using a technique known as non-dispersive infrared spectrophotometry. In 1977 carbon monoxide was monitored at two sites in Pinellas County. The Clearwater site, which is located near the intersection of Gulf to Bay and U. S. 19, monitors pollution levels at one of the busiest intersections in the county.

- The concentration of nitrogen dioxide in the ambient air is measured by two techniques. One, an electronic analyzer, operates continuously, 24 hours a day, and uses a chemiluminescent principle. The sodium arsenite method is used by intermittent samplers. Intermittent samplers operate once every six days for twenty-four hours. Nitrogen dioxide sampling was initiated in 1977. The downtown Clearwater site (Fencon) measures ambient levels of nitrogen dioxide by the chemiluminescent method. Although this site did not begin operation until April, the trend indicates that downtown Clearwater does not have a nitrogen dioxide problem. The other seven sites which measure nitrogen dioxide also indicate low levels of nitrogen dioxide pollution.

- Ozone concentrations are continuously monitored by the chemiluminescent method. Comparing 1977 data to 1976 data, certain discrepancies are apparent. The only explanations given as to the absence of violations in 1976 are incorrect calibration procedures and general inexperience in ozone monitoring. Calibration methods were changed in April 1977 from the potassium iodide method to gas phase titration.

◦ Sulfur dioxide is measured by two techniques; intermittent sampling (bubbler) and continuous sampling (electronic instrumentation). Intermittent samplers operate once every six days for twenty-four hours, measuring the sulfur dioxide concentration as dissolved in the bubbler solution. In contrast, the continuous instrument utilizes a method called pulsed fluorescence. Operating twenty-four hours a day and seven days a week, the continuous instrument can provide data for a variety of time periods any day. Sulfur dioxide sampling began July 1976. In January 1977, however, sulfur dioxide sampling was discontinued until temperature control devices could be ordered and installed. During the interim, a quality control program was implemented to give validity to the data collected.

◦ Total suspended particulate is monitored with a high volume sampler. Particulate sampling did not begin until July 1976. In January 1977 the TSP network was temporarily shut down (it was restarted in April) to implement a quality assurance program. Therefore, both 1976 and 1977 regimens have insufficient particulate data to compute a true annual geometric mean. The column labeled average is an arithmetic mean for existing data in each year.

CHAPTER 3

THE PLANT

3.0 The primary purpose of the facility described in this chapter will be to dispose of municipal solid waste material (as an alternative to conventional landfilling) while recovering certain marketable materials and generating electrical energy. In light of this primary objective, the facility will display many characteristics dissimilar to those of a conventional fossil fuel fired generating facility. To illustrate important aspects of the facility the following process description is presented ahead of the standard sequence of items in this Chapter 3.

The plant is designed to receive and process garbage, rubbish, refuse and other discarded solid or semi-solid materials resulting from domestic, commercial, industrial, agricultural and governmental operations. It will not process solids or dissolved materials in domestic sewage or other significant pollutants in water resources such as silt, dissolved or suspended solids in industrial wastewater effluents, dissolved materials in irrigation return flows, or other common water pollutants. Pathological, biological and other hazardous wastes will not be processed in the facility. All waste material received at the facility will be burned in the boilers in "as-received" form with the exception of oversized materials which will be sheared into processible size and materials classified

as non-processible which will be returned to the county landfill. Non-processible items include the aforementioned waste not to be processed plus non-combustible construction and demolition debris.

Commercial collection and transfer vehicles will enter the facility site along the northern boundary of the property. Private citizens wishing to use the facility will enter the site along a parallel road which will be separated from the roadway used by the larger collection and transfer vehicles. There will be a private citizen dumping area provided (see Figure 3.1.a) where any private citizen can dump refuse into transfer trailers which in turn will be hauled over the scales and into the tipping area by plant personnel. This will eliminate potential hazards resulting from having private automobiles maneuvering with the large vehicles using the facility.

Two 60-ton capacity, 10 feet by 60 feet platform, electronic truck scales will be provided to weigh the incoming waste trucks. A pre-punched card for each truck will be stored in the scale house. The card will have a truck number, district or other source, tare weight, and other pertinent information.

Upon arrival at the scale, one of two scalesmen will remove the truck's card from a rack, insert it into the scale mechanism, and press the weigh button. In just a few seconds the truck will be weighed and a ticket will be printed showing truck number, source, time, gross tare and net weight, date

and time. This ticket will be given to the driver. Simultaneously, the same information will be printed on a ledger in the office. The equipment will be suitable for producing punched tape, punched cards, or other hard copy data processing material.

The scale operators will direct the incoming load of material to the resource recovery facility (or to the county landfill operation in the case where non-processibles are delivered).

The trucks directed to the resource recovery facility will proceed directly to an enclosed tipping floor and will discharge the refuse material at one of twelve (12) tipping bays into the refuse storage pit.

The volumetric capacity of the pit, using mounded storage configuration, is approximately 22,000 cubic yards or 7,700 tons of solid waste. This provides sufficient storage for three to four days of all incoming material.

Two overhead cranes will lift the material from the pit to the charging hopper of the boiler. The operator will mix and sort the pit material as required to provide the best possible fuel mixture in the boiler. Non-processible material that inadvertently is delivered to the pit will be removed by the crane for alternate disposal.

The combustion, steam generation and electrical generation processes are described in detail in Sections 3.1 through 3.10 below.

Since a major objective of the facility is to recover certain marketable materials from the waste stream, the residue leaving the boiler is processed in a manner uncommon to normal fossil fuel electrical generating practices. A schematic diagram of the materials recovery system is shown in Figure 3.0.a.

Combustion residue initially falls into a vibrating conveyor from the ash discharger. A grizzly screen is located so as to keep most massive (over 10" x 10") pieces from damaging the conveyor. These massive pieces are hand-picked for metals; non-metallics are landfilled (residues).

Upon entering the materials recovery building, the residue is sized at the end of the primary residue conveyor. First, the -2" material drops out, then the -10" + 2" fraction, leaving any remaining +10" objects which the grizzly screen may have missed. The massive pieces are handled as above.

Prior to the initial sizing operation, a diverter chute has been provided so that repairs can be effected downstream while the combustion units continue to operate normally.

The -10" + 2" residue falls from the primary residue conveyor to another vibrating conveyor. This fraction, primarily tin cans, is conveyed to a magnetic separator which removes the ferrous metal and deposits it on a belt conveyor. This ferrous metal is then transported to a storage/shipping/further processing as required. The -2" residue from the primary residue conveyor falls to another vibrating conveyor which moves the residue to a second sizing operation. At this point, the fine

residue/ash is removed, combined with moistened electrostatic precipitator flyash and belt conveyed further downstream.

The remainder of the -2" residue moves via another vibrating conveyor to a magnetic separator, which removes the miscellaneous small ferrous metal to a belt conveyor for transporting to storage/shipping.

The non-magnetic material next travels by belt conveyor to a size reduction unit which breaks up the friable materials. From size reduction, the stream moves to a sizing operation which removes the larger metallics from the shattered friables and undersize metallics.

The larger metallics are elevated by bucket elevator to a heavy media unit. This heavy media system uses a ferrofluid to achieve an effective specific gravity of 3.0 or more. Under these conditions, the aluminum present floats, while the heavy nonferrous metals sink. Both fractions are recovered as clean products and move by belt conveyor to storage/shipping.

The undersize from the sizing operation proceeds by belt conveyor to a mineral jig which serves to segregate the heavy non-ferrous metals from the aluminum-aggregate fraction. This jig also produces a fine aggregate product which is dewatered and mixed with the fine residue/flyash stream. After dewatering, the heavy nonferrous jig product moves by belt conveyor so as to combine with the heavy nonferrous from the heavy media system.




FIGURE 3.0.D.

MATERIALS RECOVERY SCHEMATIC

The glass and remaining recoverable aluminum are also dewatered and then belt conveyed to a size reduction unit which crushes the friable glass, ceramic, etc. The aluminum tends to flatten into flakes during this operation.

A belt conveyor takes the crushed and flattened material to a final sizing step, where the aluminum is recovered and moves by belt conveyor to storage/shipping/further processing. The undersize falls to the aggregate belt conveyor where it combines with the fine aggregate, fine residue and flyash previously produced. This material is suitable for use as the aggregate portion of asphalt.

The materials handling system is adaptable to the addition of recovery equipment for other materials, such as glass, as market demands make such measures economically viable.

3.1 External Appearance

Figure 3.1.a shows the general layout of the facility at the site and indicates the locations where liquid and gaseous waste leave the plant site perimeter.

An artist's rendition of the exterior appearance of the resource recovery plant is presented in Figure 3.1.b. The buildings will consist of steel framed structures providing required clear spans for efficient function of the processes. The facade of the structures will have prefabricated modular siding capable of providing a pleasing aesthetic effect.

Roofing systems will be constructed of components that will insulate the roof deck, span the structural elements, and




FIGURE 3.1.0

PLANT SITE LAYOUT

PINELLAS COUNTY RESOURCE RECOVERY PLANT




FIGURE 3.1.b.

provide a weathertight surface. Concrete floor surfaces will be sealed and hardened to permit proper maintenance and operation in each process area.

Plant offices and employee areas will be the standard materials used for such construction.

3.2 Fuel

The generating plant will use municipal solid waste for fuel as discussed in the introduction remarks (Section 3.0). No provision is made for auxiliary fuel. However, the plant could be modified to burn alternate refuse material (sawdust, bark, paper, etc.) or coal, if found necessary in the future.

Table 3.2.a shows the characteristics of solid waste as used in the design criteria. Table 3.2.b shows the design analysis of the residue as discharged from the boiler.

UOP (the contractor) has designed the resource recovery facility to guarantee a capacity of 14,000 tons of solid waste per week. The boiler design is the limiting factor although a balanced design concept has been used throughout the facility to match all portions at this design size. Listed below are the projected quantities of solid waste for Pinellas County for three of the project years:

<u>Year</u>	<u>Quantity (Tons)</u>
1980	592,690
1990	676,455
2000	776,400

TABLE 3.2.a

DESIGN SPECIFICATION OF
PINELLAS COUNTY RESOURCE RECOVERY

ANALYSIS (WET BASIS) %

Carbon	27.03
Hydrogen	3.67
Nitrogen	.21
Sulphur	.14
Chlorine	.16
Oxygen	20.29
Ash	18.5
Water	30.0
BTU per pound (dry)	7143
BTU per pound (as fired)	5000

TABLE 3.2.b

ANTICIPATED ANALYSIS OF
BOILER DISCHARGE MATERIAL

% BY WEIGHT (WET)

Metals	34.5
Glass, Ceramics	37.65
Stone and Dirt	
Ash	9.69
Unburned Carbon	3.15
Moisture	15

These estimated quantities are based on the 1977 population projections for the three project years and a 4 lbs/capita/day waste generation rate. The facility was sized to accommodate the current and future solid waste needs for the county, with accommodations for peak periods.

The projection of solid waste is highly speculative and any deviations in the projections stated above will be tracked closely. If and when solid wastes are available in such quantities to justify expansion, the plant boiler capabilities will be expanded in a prudent fashion.

The solid waste material will be delivered to the facility by packer trucks or transfer vehicle as are presently employed in waste handling practice.

The fuel will be stored in the refuse storage pit as mentioned in Section 3.0 above. The design size for pit storage is based upon historic availability of refuse burning equipment and the relative difficulty of storing wastes for extended periods of time.

The quality of the fuel was presented in Table 3.2.a.

The County has by law the right to dispose of or have disposed of all of the solid waste within the boundaries of the county. The design tonnage capacity of the facility closely approximates the guaranteed tonnages (with peaking factors) which the County can be assured of being delivered in the immediate future (reference Chapter 1 for further discussion of this matter).

3.3 Plant Water Use

Figure 3.3.a presents the design water use rates for normal and peak load operation of the facility. Heat dissipation, sanitary, chemical waste and process water systems are shown. Also shown are the sources of water for various supply sources. Flows which will occur during a plant shutdown are shown in double parentheses on Figure 3.3.a.

3.4 Heat Dissipation System

The electric generating portion of the resource recovery facility will use water cooled condensers to condense the low pressure steam discharged from the turbine. The cooling water will circulate at a rate of approximately 37,500 gpm and will leave the condenser at approximately 110°F. The cooling water will pass through a wet mechanical draft cross-flow cooling tower for the dissipation of the waste heat. Presented in Figure 3.4.a is a flow diagram of the circulating water using the cooling tower system. The design outlet temperature of the tower is 86°F with an ambient wet bulb temperature of 79°F. The cooling tower system will dissipate 450 million BTU/hr at the normal operating rate. A typical analysis of the cooling tower supply water is presented in Table 3.4.2.a.

3.4.1 Intake and Outfall

Since the supply and discharge points for the facility are "hard-connected" to existing facilities as shown in Figures 3.1.a and 3.9.a, no intake or outfall exists in the normal sense.




FIGURE 3.3.d.

SUMMARY WATER FLOW DIAGRAM




FIGURE 3.4.d.

WATER USAGE FLOW DIAGRAM

TABLE 3.4.2.a

CHEMICAL CHARACTERISTICS OF FACILITY COOLING WATER INFLUENT ¹			
<u>Chemical Constituent</u>	<u>Potable Supply Pinellas County</u>	<u>Non-Potable Supply 1 (St. Petersburg NE STP)</u>	<u>Non-Potable Supply 2 (Largo STP)</u>
pH	7.7	7.0	7.1
Total hardness as ppm CaCO ₃	124	412	248
Calcium hardness as ppm CaCO ₃	108	282	232
Total Alkalinity as ppm CaCO ₃	90	240	252
P-Alkalinity as ppm CaCO ₃	0	0	0
OH-Alkalinity as ppm CaCO ₃	0	0	0
Total dissolved solids, ppm	20	1350	685
Suspended solids, ppm	10	30	7
Conductivity, micromhos/cm	268	2390	938
Calcium, ppm Ca	43	113	93
Magnesium, ppm Mg	4	32	4
Ferric iron, ppm Fe	<.05	.29	.11
Bicarbonate, ppm HCO ₃	110	293	307
Carbonate, ppm CO ₃	0	0	0
Sulfate, ppm SO ₄	0	65	50
Chloride, ppm Cl	26	528	106
Silica, ppm SiO ₂	16	20	21
Aluminum, ppm Al	<.1	<.1	<.1
Zinc, ppm Zn	.05	.06	.12
Ortho phosphate, ppm PO ₄	0	4	9

¹ Based on most recent water analysis reports from each treatment plant

A future alternative source of cooling water, stormwater runoff from the resource recovery site, is being considered. In this case, however, stormwater runoff will be used as evaporative make-up to the cooling towers and no discharge will take place.

3.4.2 Source of Cooling Water

Cooling tower make-up water will be obtained from (1) the City of St. Petersburg tertiary treatment plant effluent system, (2) the City of Largo sewage effluent (treated to land disposal quality) and (3) an optional source contemplated in stormwater runoff from the resource recovery site. Quantities available from (1) and (2) are sufficient to supply the requirements individually. The St. Petersburg supply will be the primary source with the Largo system as a back-up supply. Stormwater runoff will only be utilized for a portion of the make-up (due to insufficient volumes) if this source is utilized. Characteristics of the St. Petersburg and Largo supplies are shown on Table 3.4.2.a. Figure 3.3.a presents the quantities and temperatures (potable only) of sources of supply water.

3.4.3 System Design

The cooling system has been designed with capacity to condense the exhausted steam from the turbine when operating at the full steam rate of both boilers. In the event that the turbo-generator equipment is not in operation, a separate, high pressure, bypass condenser is provided to condense the steam

from one boiler. The cooling tower system will also have capacity to provide for this contingency. This bypass condenser will provide refuse disposal and materials recovery capability at 50% design rate of the facility when electrical generation is not possible. The design rate of heat dissipation for the facility is 450,000,000 BTU/hour or 37,500 tons of cooling.

The quantities of water withdrawn from sources of supply are shown in Figure 3.3.a. The average potable withdrawal is 116 gpm (maximum = 123 gpm and minimum = 75 gpm). The average non-potable withdrawal is 1060 gpm (maximum = 1211 gpm and minimum = 415 gpm).

The consumptive useage rate for the system is shown in Figure 3.3.a. The consumptive use of water by the facility is in the form of cooling tower losses. Cooling tower losses are in the form of evaporation and drift. The average evaporative loss will be 707 gpm (minimum = 267 gpm and maximum = 779 gpm) and the average drift loss will be 37 gpm (minimum = 14 gpm and maximum = 41 gpm).

The location of the cooling towers is shown on the facility layout (Figure 3.1.a). The cooling tower system will consist of a four (4) cell group of Class 600 Marley cross flow towers or approved substitutes. The average blow down rate for the towers is 316 gpm (minimum = 119 gpm and maximum = 347 gpm). The cooling tower blow down will accumulate along with the boiler demineralization back flush water (average flow 6 gpm, minimum = 3 gpm, maximum = 7 gpm) and the boiler

blow down water (average flow 23 gpm, minimum = 8 gpm, maximum = 24 gpm) for a total process blow down average flow of 345 gpm (minimum = 130 gpm, maximum = 378 gpm). The water that is used to quench the residue discharged from the boiler grates will be drawn from the process blow down cumulative flow. The remaining average process discharge rate will be 325 gpm as shown on Figure 3.3.a. Minimum and maximum process flows are 121 gpm and 358 gpm, respectively. Sanitary flow discharge at a rate of 50 gpm will be added to the process flow discharge for an average total discharge of 375 gpm (minimum = 164 gpm, maximum = 409 gpm).

The physical and chemical characteristics of the water in the cooling system as well as potable water supplies are presented in Table 3.4.2.a.

The cooling water increases in temperature by 24°F from 86°F to 110°F in the process of condensing the exhaust steam from the turbine. The water is then cooled by evaporation in the cooling tower. The flow rate through the cooling tower is 37,500 gpm and the evaporation rate from the tower will average 707 gpm or approximately 1.9% of the circulation rate. No intake structure is anticipated at this time since the cooling water will be drawn from a pressurized main which carries non-potable water and the potable water supply will also be drawn from a pressurized main. The maximum temperature of water at the facility boundary POD is 92°F. This plant effluent will be pumped to the Pinellas Park lift station shown on Figure 3.9.a; from there it will enter the Pinellas

County sewage treatment system. After transporting and mixing with existing flows, very little elevation in temperature will remain.

3.4.4 Dilution System

No dilution of the effluent will be required prior to the discharge to the municipal sewage treatment facility. Provision will be made within the facility to adjust the pH of the effluent as required prior to discharge. A stabilizing tank will hold water prior to discharge to assure that no instantaneous "spikes" in the pH level occur of the discharge effluent.

3.4.5 Blowdown and Trash Disposal

Blowdown will occur at the boilers, the cooling towers and the demineralizers as described in Section 3.4.3 above. This cumulative flow, less than 20 gpm, to the residue quench is discharged after neutralization and stabilization to the municipal sewage treatment plant. The characteristics of this cumulative blowdown flow which will be transported to the sanitary sewer system are shown in Tables 3.4.5.a and 3.4.5.b.

3.4.6 Injection Wells

No injection wells are proposed for this project.

3.5 Chemical and Biocide Waste

Both anti-corrosion and anti-fouling agents will be used in the facility in the boilers and in the cooling towers. These are listed below:

TABLE 3.4.5.a

HYPOTHETICAL ION CONCENTRATION IN BLOWDOWN WASTE STREAMS, PPM			
I. Demineralizer Blowdown II. Boiler Blowdown III. Cooling Tower Blowdown			
Chemical Constituents	I	II	III
Calcium as CaCO ₃	2294	0	210
Magnesium as CaCO ₃	274	0	90
Iron as CaCO ₃		0	2
Sodium as CaCO ₃	1609	6	2004
TOTAL CATIONS	4177	6	2306
Bicarbonate as CaCO ₃	2465	0	150
Carbonate as CaCO ₃	0	0	0
Hydroxide as CaCO ₃	993	6	0
Sulfate as CaCO ₃	34	0	447
Chloride as CaCO ₃	377	0	1542
Fluoride as CaCO ₃	-	0	6
Nitrate as CaCO ₃	-	0	102
Phosphate as CaCO ₃	-	0	54
TOTAL ANIONS	3870	6	2310
pH	7	10	8.0
Silica as CaCO ₃			
TDS as CaCO ₃	~4000	~1000 ^A	~2400 ^B

Chemical additions to treated water included in blowdown.

1. Demineralizer Blowdown-approx. 68 lb. NaOH to neutralize.
2. Boiler Blowdown-Sodium di- and tri-phosphates to establish a hexametophosphate residual of -18 ppm and hydrazine.
3. Cooling Tower Blowdown-approx. 185 lb/day 66° BeH₂SO₄ to reduce alkalinity; approx. residuals of 100 ppm of scale inhibitor and a dispersant.

A Assume 18 ppm sodium hexametaphosphate in BFW
18 ppm x 50 cycles of concentration = 900 ppm added to TDS

B Add approx. 100 ppm for scale inhibitor and dispersant.

SOURCE: UOP, Inc.

TABLE 3.4.5.b

CHARACTERISTICS OF BLOWDOWN MIXTURE					
	I. Demineralizer Blowdown		IV. Sum of I, II and III		
	II. Boiler Blowdown		V. Estimated Concentrations		
	III. Cooling Tower Blowdown		in Mixture		
Chemical Constituents	I lbs/day	II lbs/day	III lbs/day	IV lbs/day	V ppm
Calcium, as CaCO ₃	135	0	218	353	243
Magnesium as CaCO ₃	16	0	93	109	75
Iron as CaCO ₃	< .1	0	2	2	1
Sodium as CaCO ₃	95	1	2082	2178	1500
TOTAL CATIONS	246	1	2395	2642	1818
Bicarbonate as CaCO ₃	146	0	156	302	208
Hydroxide as CaCO ₃	58	1	0	59	41
Sulfate as CaCO ₃	2	0	464	466	321
Chloride as CaCO ₃	22	0	1602	1624	1118
Fluoride as CaCO ₃	< 1	0	6	7	5
Nitrate as CaCO ₃	-	0	106	106	73
Phosphate as CaCO ₃	-	0	56	56	38
TOTAL ANIONS	229	1	2390	2620	1803
pH	7.0	10.0	8.0	7.9	7.9
TDS	~240	~216	~2480	~2937	~2021

SOURCE: UOP, Inc.

a. Corrosion Inhibitors

(1) Boiler

- Hydrazine-oxygen scavenger.

Concentration in the boiler will be maintained at 1.5 ppm.

(2) Cooling Tower

- Non-polluting polysilicate/organic polymer-based corrosion inhibitors plus scale and foulant control (Zimmite ZD-300 series or equivalent) (or chemicals under b).

b. Chemical and Biological Anti-fouling Agent

(1) Boiler

- Deposition and caustic corrosion control - sodium Di- and Tri-Phosphates 10 ppm.

(2) Cooling Tower

- Scale and corrosion inhibitor and dispersant-polyester (Nalco 7350,7351 or equivalent)
- Biocide - Chlorine may be added on an intermittent basis.

Treatment of blowdowns of these two water systems will be limited to neutralization and stabilization as described in Section 3.4.4 above.

3.6 Sanitary and Other Waste Systems

3.6.1 Volumes and Qualities

With 52 employees plus visitors, the anticipated level of sanitary waste will be 3000 gpd. The concentration of

material in this sanitary waste will closely approximate that of domestic sanitary waste.

3.6.2 Treatment and Disposal

Sanitary wastes generated by the lavatory and shower facilities used by plant employees and visitors will be transported by pipe along with the blowdown wastes to the Pinellas Park lift station (which is connected to the Pinellas County treatment system). No on-site treatment of the sanitary waste will be performed.

3.6.3 Solid Wastes

The facility will generate 11,130 tons per year of unusable residue (at guaranteed level of 530,000 tons per year at 2.1 percent residue) from the materials handling facility. This material along with a small amount of unusable and incom-bustable waste from the plant will be trucked to the sanitary landfill for disposal by burial. The composition of the residue is anticipated to be the following (wet basis):

<u>Constituent</u>	<u>% by Weight</u>
Metals	7
Glass, ceramics	54
Stone and sand	
Ash	14
Unburned Carbon	4
Moisture	21

Additional information on the disposal of this residue is presented in Section 3.10 and Appendix D.

3.7 Air Emissions

3.7.1 Sources

The air emissions sources from the resource recovery facility are the two (2) refuse fuel fired boilers. Combustion of the refuse fuel will result in emissions of particulate matter and sulfur dioxide. The two applicable emission-limiting regulations are as follows:

1. Florida Administrative Code Chapter 17-2.04(6)(a)1
 - a. Particulate matter - 0.08 grains per standard cubic foot dry gas corrected to 50 percent excess air.
 - b. Odor - There shall be no objectionable odor.
2. 40 CFR Part 60
 - 60.52 - Standard for particulate matter. No gas discharged which exceeds 0.18 grains per dry standard cubic meter (= .08 gr/dscf) corrected to 12% CO₂.

To meet or exceed this limit of particulate emission a three field electrostatic precipitator will be utilized. The anticipated emissions characteristic from the facility using the three field electrostatic precipitator are displayed in Table 4 in Appendix A..

3.7.2 Stack and Unit Sizes

There will be one (1) stack located as shown in Figure 3.1.a. The internal diameter of the 9'-0" stack is constant from bottom to top. This dimension is 2.74 m and the height above the ground is 161 feet (49.07 m).

There will be two (2) boilers rated at 1050 tons per day at a nominal 5000 BTU per pound higher heating value of the refuse fuel. A single 50 megawatt generator will be utilized. The maximum sustained heat rate is 18,000,000 BTU/MWH.

3.7.3 Emission Rate

The data on gas volume, velocities, total mass flow, chemical composition and stack gas exit temperature is presented in Appendix A (presentation of operational impacts on air quality).


3.8 Directly Associated Transmission Lines

3.8.1 Route and Size

The proposed 230 KV transmission line will link the switchyard at the resource recovery plant with Florida Power Corporation's Northeast Substation; this latter facility lies approximately 1.25 miles southeast of plant site. Figure 3.8.1.a features the anticipated routing of this transmission line and details the alignment of the power line right of way with 28th Street and the existing FPC facilities.

The tubular steel towers will be of vee type "C" design with appropriate distribution attachments. Three transmission (230 KV) and three distribution conductors (12 KV) will be provided; the vertical separation of transmission conductors will be 12', while that of the distribution system will be approximately 3'. An overhead ground and a distribution neutral will be installed with the lowest span (the distribution neutral) situated 28' off the ground on the pole. Where required to maintain the minimum vertical

FIGURE 3.8.1.A



DETAILS OF PROPOSED TRANSMISSION LINE

clearance for the distribution conductors mid span poles, with estimated heights of 40', will be erected. As transmission conductor spans will be specified at 700', it is estimated that 19 such towers will be required for the entire length. Guying of corner poles will consist of tubular steel guy stubs with multi-helix screw-type anchoring.

Access and maintenance of the power lines and right of way will be provided through primitive roadways within the clear zone.

3.8.2 Land Use Impacts

As more thoroughly discussed in Section 4.3.2, the associated transmission lines will span undeveloped, often highly disturbed terrain. All of the affected land is zoned either as manufacturing or semi-public classifications. An exception to this is the tract immediately south of the county property abutting the west side of 28th Street. This parcel, while currently designated as a low density residential area, is expected to be maintained as open space (or buffer) via an alteration of the existing zoning scheme (see Section 2.2.2).

All vegetation will be removed from the power line right of way; routine maintenance practices will limit understory growth to low brush and shrubs. In essence, the proposed power line right of way will assume the same visual characteristics as imparted by that of the larger existing FPC

transmission line. It will not be necessary to demolish any man-made structures nor effectuate significant topographic alterations to accommodate the power line.

3.8.3 Beneficial Uses

At present, there are no plans for alternative utilization of the proposed power plant right of way.

3.8.4 Visibility

It is anticipated that the proposed transmission line will be apparent from several well travelled roads for much of its length. It will, however, be overshadowed by the existing, much more ominous FPC power line which it will parallel for much of its route. Specific thoroughfares at which the transmission lines will probably be visible are as follows:

- U. S. Highway 19 near 49th Street North interchange - visible upon close observation only as the larger FPC lines bisect the line of sight.
- Gandy Bridge Boulevard near 28th Street and I-275 - visible upon close observation as the proposed lines are immediately behind the larger existing ones.
- I-275 - very visible as the proposed lines will cross this superhighway, again very close to the existing FPC conductors.

In addition where the proposed lines parallel 28th Street, they will be distinct to viewers residing in the outer perimeter of the mainlands of Tamarac Subdivision (in the vicinity of

101st Terr. and 34th Wy., North). The distance to the right of way from these houses is estimated at 0.64 mile.

3.8.5 Associated Transmission Structures

No related electrical transmission structures (i.e. substations) other than those described above and the switchyard at the plant are proposed in this application. The switchyard located at the plant site will be used to step up the 13.8 KV turbogenerator voltage to the 230 KV transmission voltage.

3.9 Associated Facilities

In addition to the construction of the resource recovery facilities as defined within the fenced boundary (shown in Figure 3.1.a) and the power transmission line (described in Section 3.8), several associated facilities will be constructed. These are listed below:

- a. Extension of 114th Avenue and 110th Avenue.
- b. Non-potable water line extension.
- c. Potable water line extension.
- d. Pinellas Park sewer line connection.
- e. Landfill
- f. Spray irrigation field.
- g. Stormwater holding and treatment system.

These associated facilities are shown in Figure 3.9.a.

3.9.1 Purpose and Location

- a. 114th Avenue will be extended to the west from its present effective end on 28th Avenue. 110th Avenue will be extended to the west from 28th Avenue to

the plant exit. These extensions will provide access to and egress from the resource recovery facility.

- b. The St. Petersburg treated wastewater line will be extended from a point at 102nd Avenue and 16th Street (approximately 1,500 feet east of Interstate 75). This water will be used in the facility for cooling tower and other non-potable needs. A line to connect to the Largo non-potable water system is also being contemplated.
- c. Potable water line extension - A water line will be extended to the facility site from the existing Pinellas Park main now terminating on 118th Avenue approximately 1600 feet west of 34th Street. This water will be used for sanitary purposes and as boiler make-up water.
- d. Pinellas Park sewer line connection - A sewer line will be constructed from the facility site to the existing lift station as shown in Figure 3.9.a. This line will carry the composite sanitary and process effluent from the facility.
- e. The landfill as located on Figure 3.9.a will be used to dispose of residue resulting from the materials handling operations on the boiler ash. In addition, this landfill will be used to dispose of raw refuse

when the plant is not operational during emergency conditions. This latter situation is anticipated to be quite rare. During times of raw refuse land-filling, the operation is expected to take place in the same fashion that current landfill practices take place at the County landfill (Phase I Bridge-water Acres). The residues will be landfilled in a similar fashion with the exception that daily cover will not be applied. More detailed information regarding the intended landfill operation is presented in Appendix D.

- f. A spray irrigation field, as shown on Figure 3.9.a, will be required to dispose of treated stormwater runoff, as required from the site. More information on this item is presented in Section 3.10 and Appendix D.
- g. A stormwater holding pond and treatment facility, as shown on Figure 3.9.a, will be utilized to contain and treat, as required, the stormwater runoff from the plant site as well as the landfill area and completed landfill area on the resource recovery site. More information on this system is provided in Section 3.10 below.

3.9.2 Maps

The location of each of the above mentioned associated facilities is shown on Figure 3.9.a.




FIGURE 3.9.d

3.9.3 Land Type and Uses

The land on which the associated facilities will be constructed is generally undeveloped and zoned for light industrial use. The land on which the access road will be constructed is designated for solid waste management purposes. The other associated facilities which will be constructed are presently County rights-of-way.

3.9.4 Visibility

After construction none of the utility lines will be visible since all of the pipelines will be installed below grade and the disturbed area will be planted with grass and will eventually revegetate with native flora. The road will be visible from 28th Street, as well as some aspects of the landfilling activities at certain times.

3.10 On-Site Drainage System

3.10.1 Overall Drainage Plan

Generally, all stormwater runoff will be collected from all functional areas (i.e. plant site and landfill) on the site as they are being used. Collected runoff will be treated and disposed of by landspreading in the designated areas. Treatment will consist of aeration, contact with water hyacinth and chlorination. Water hyacinth will be harvested, dried and utilized as a fertilizer supplement by the County.

3.10.2 Drainage During Construction

Runoff from the plant construction site will be collected and transported to a collection ditch on the south side of the

facility. This ditch flows to the main holding lagoon. From this holding lagoon, the water will be pumped, as necessary, to the treatment area and subsequent land disposal. If dewatering is required during construction, all resulting flows will also be directed to the drainage ditch and holding lagoon.

3.10.3 Drainage During Operation

During operation, two major areas are of concern with regard to drainage, plant site drainage and drainage from landfill operations. The overall drainage plan will apply to both activities, with emphasis on zero discharge, except during extremely high rainfall conditions and then only discharge of treated landspreading runoff.

All drainage from the plant site will be directed to a collection ditch to the south. From there, the water will be treated and landsprayed as required.

During landfilling operations, water which is collected directly in an open cell will be transported directly to the oxidation pond. This water will have had direct contact with raw refuse and residue and will not enter the surface runoff collection system. Water from above grade landfill operations as well as completed landfill areas will migrate to the series of collection ditches which lie around the perimeter of the active landfill areas. From these collection ditches, this water will be directed to the holding pond and will be treated and landsprayed as required.

3.10.4 Stormwater Treatment Facilities

Shown on Figure LP-1 of Appendix D are the stormwater treatment facilities . The major units within the stormwater treatment facility are:

1. Aerated lagoon - 422,081 gallon capacity, 1 day detention time @ 300 gpm flow.
2. Hyacinth pond #1 and #2 - 6.85 days detention time operated in parallel, 13.7 days detention operated in series, at 300 gpm flow.
3. Chlorine contact chamber - 15 min. detention time at 300 gpm flow.
4. High head irrigation pump station - one 170 gpm pump with space of additional pump to match 300 gpm system capacity.
5. Irrigation system - portable aluminum restrainer joint irrigation pipe with irrigation guns. Irrigation field of 56.34 acres (with system 250' buffer zones not included), which has design capabilities of 300 gpm to 600 gpm at application rates of 2 inches per week and 4 inches per week, respectively.

Drainage from the spray irrigation field will migrate to a ditch which surrounds the field on the sides. The only provision for discharge will be an emergency overflow structure in the southeast corner of the ditch in the case of extreme rainfall occurrences.

3.10.5 Optional Systems

Options to the aforementioned drainage plan are:

1. The use of the optional spray irrigation field (see Figure LP-1, Appendix D). This heavily wooded 40 acre area is higher in elevation than the proposed irrigation field and could be used in the event of high water table conditions.
2. The use of stormwater runoff as cooling water make-up. Stormwater could be used directly from the 22 acre holding lagoon or after treatment and chlorination. The quality of the untreated stormwater runoff would dictate whether or not treatment would be required prior to use as cooling water make-up. The approximate cooling water make-up requirements are 415 to 1211 gpm; therefore, the stormwater, if utilized, would be a supplement to the treated wastewater as noted in Section 3.4.2. The implementation of this option could assure a zero discharge operation and alleviate the use of the landspraying operations.

CHAPTER 4

ENVIRONMENTAL EFFECTS OF SITE PREPARATION, PLANT AND ASSOCIATED FACILITIES CONSTRUCTION

4.1 Site Preparation and Plant Construction

4.1.a Impact on Land Use - As discussed in Section 2.2.2 of this report, much of the existing land use at the proposed facility site is characterized by terrain greatly altered by land-filling and excavating activities. The area adjacent to the facility site on its eastern perimeter is utilized as an experimental sludge sprayfield. A 230 kilovolt transmission line will parallel 28th Street North, southward from the facility for approximately 1.0 miles until the existing Florida Power Corporation transmission lines are encountered; proposed facility transmission lines will then parallel the existing FPC lines eastwardly to the Northeast Electrical Generation Substation. Again, the current land uses to be impacted by power line construction are predominately undeveloped and/or highly disturbed areas.

Construction of the resource recovery plant and associated facilities will necessitate an irreversible commitment of approximately 240 acres of land currently zoned for manufacturing purposes. The resource recovery plant will be constructed upon 20 acres of an 80 acre tract just north of 110th Avenue North, and west of 28th Street North. A 160 acre tract just south of the plant site and 110th Avenue North will be reserved for disposal of residues generated by facility operations and stormwater runoff control. Conversion of this tract to landfill purposes will entail the destruction of a basically undisturbed pine

flatwoods stand; it is anticipated that adverse impacts on associated biota are minimal as there is an ample amount of similar terrain located adjacent to this particular expanse. Most of the terrain around the 20 acre plant site is highly disturbed land; conversion of this tract to a landscaped and maintained electrical generation plant represents a positive step in eliminating the current landfilling which attracts gulls, flies and other disease vectors.

The most significant impact on land use centers is the cessation of raw refuse landfilling upon initiation of plant operation. At present solid waste generation rates, the twenty acre plant site would be consumed for landfilling in little more than one year. The implementation of resource recovery operations will greatly reduce the large and growing need for an expensive, dwindling resource in Pinellas County, namely land. It should also be noted that land utilized as a landfill is a poor site for future construction due to potential settlement and effluent gas generation. Excluding lands from future landfilling sites promotes the availability of areas for industrial expansion in that neighborhood.

During construction phases, a large traffic volume associated with the building of the plant will be noted along certain roadways serving the site. It is anticipated that work force and heavy equipment traffic will utilize 118th Avenue North and 34th Street North to gain access to the site and its environs. In each case, the land uses abutting these roadways are composed of manufacturing or undeveloped sites and are, therefore, compatible with the expected increases in traffic.

The closest residential boundary to the proposed facility is located approximately a mile to the southwest in Pinellas Park. Construction of the facility should have no great negative impact on this area; contrarily, a positive effect on land value could result with conversion of the land use to a more desirable processing plant. In addition, there is a parcel of land abutting the southern perimeter of the 160 acre landfill expansion area which, according to the Pinellas County Comprehensive Land Use Plan, is designated for medium density residential development. Current plans, however, promulgated by local planning agencies state that this tract can be expected to be at least partially rezoned for industrial purposes which will provide a buffer between the inert residue landfill and possible future residences.

4.1.b Impact on Water Use - Construction water needs mainly include usages for potable supplies, hydraulic equipment, equipment maintenance and sanitary needs.

For the estimated thirty-two (32) month construction period total water needs will approximate 75,000-100,000 gallons per day during peak periods. The majority of this water will be employed for such activities as concrete mixing, building and equipment cleaning and work force potable supplies. All such water will be obtained from the Pinellas Park potable water system.

Sanitary wastewater needs will be handled by a portable toilet contractor, thus precluding any necessary use of municipal facilities directly.

In any case, no on-site surficial or groundwater supplies will be impacted by facility construction water needs. A well point system will extract water from the water table aquifer only at the plant site; this water will be channeled into the perimeter canals without any modifications or withdrawals by construction activities.

4.1.c Impact on Water Quality - Construction of the proposed plant facility will entail the movement of approximately 260,000 cubic yards of fill material at the facility site and along traffic arteries. Additional material will be displaced as perimeter canals are prepared, however the material excavated will be stockpiled alongside these canals for the construction of the sight screening levee. This will facilitate the introduction of sediment and particulate-borne pollutants into perimeter canals. The extent of sedimentation is, no doubt, ameliorated due to the coarse nature (thus low erodibility) of the on-site soils and the nearly flat characteristic of the terrain. It was also noted during on-site visitations following storm events that much of the sedimentation in neighborhood drainage ditches was the result of road bed and road shoulder erosion. As the extent of traffic on these roadways will substantially increase during the construction phase, relative sediment contributions from this source can be expected to increase.

Activities will begin almost immediately, upon promulgation of a "notice to proceed" with construction, which will reduce subsurface water volumes at the site of the resource recovery plant. This will be accomplished through use of a well point system; water extracted from the water table aquifer by this

method will be diverted to surficial canals which receive site storm runoff. No dewatering is anticipated for the construction of the perimeter canals and sight screen levee. As noted in Sections 2.4 and 2.5 of this report, the chemical quality of surficial aquifer waters is characteristically more mineralized than surface waters and contains relatively high concentrations of dissolved nitrogen species. The introduction of more nitrified water into perimeter canals could enhance the already untoward clogging of the waterways by noxious weeds. On the other hand, the high bacterial concentrations which typify study area surface waters could be greatly diluted and attenuated by the introduction of large volumes of harder, more saline aquifer waters.

Erosion from construction sites yields an effluent which is generally high in hydrocarbon and synthetic waste concentrations; most notable of these constituents are oils and greases, paving and sealing compounds, pesticides and rodenticides, and cleaning fluids. By applying prudent erosion control measures these factors can be substantially mitigated as on-site terrain is quite level and, consequently, less subject to erosion.

4.1.d Impact on Air Quality - Air pollutants associated with construction of the facilities will originate from vehicular and heavy equipment exhaust emissions, open burning of land clearing debris, and other fugitive sources, notably roadway dust and dirt.

Exhaust emissions from internal combustion engines contribute significant volumes of nitrogen oxides and hydrocarbons to the atmosphere. It has been estimated that 86 percent of the carbon monoxide originating from mobile sources in the nation can be attributed to internal combustion, gasoline vehicles.¹

¹ Cavender, et al.

Diesel engines contribute less than one percent of that pollutant. Other relative contributions include: nitrogen oxides - gasoline engines 67 percent, diesel engines 11 percent, hydrocarbons - gasoline engines 85 percent, diesel engines 0.5 percent. By tempering these estimates with data projecting the number of gasoline versus diesel powered vehicles included in these estimates (100 million versus 8 million, respectively), one can see that while relative nitrogen oxide emissions from both sources are quite similar, diesel engines contribute far less carbon monoxide and hydrocarbons per unit of operation. This is due to the high compression and temperatures inherent to diesel operations and, thus, more efficient combustion. The impacts imparted by the emissions of heavy equipment characteristic of facility construction will not adversely affect ambient air quality to an appreciable degree. The small quantity of emissions coupled with the short term nature of construction activities will produce very minor and quite localized elevations in certain pollutant concentrations, notably nitrogen oxides. Probably the most substantial mobile source of air pollution associated with facility construction will be those emissions generated by the labor force vehicles as they enter and leave the facility site. Again, though, this impact is short-lived and will probably have little effect on ambient carbon monoxide, hydrocarbon and nitrogen oxide concentrations.

With regard to open burning, it is estimated that some 70 pine trees with diameters (at breast height) averaging 12 inches will be removed, piled into windrows and burned during the construction of the plant. The

debris will be further augmented by understory vegetation and scattered brush. All open burning of land clearing debris will be conducted in accordance with those stipulations provided in State (Chapter 17-5.07 FAC) and County (ORD 76-18) rules. Specifically, both State and County requirements mandate that at least one of the following alternatives is satisfied:

(a) The open burning is fifty yards or more from any occupied building or public highway and is performed between 9:00 a.m. (standard time) and one hour before sunset;

(b) At other times when:

1. The open burning is fifty yards or more from any occupied building or public highway and a forced draft system is used; or,

2. The open burning is five hundred yards or more from any occupied building or a public highway and the Department has given permission because of reasonable assurance that atmospheric and meteorological conditions in the vicinity of the burning will allow good and proper diffusion and dispersment of air pollutants; or,

(c) The burning is conducted under the supervision of the Department of Transportation, a forced draft is used, and visibility on roadways is not artificially reduced to less than 500 feet.

Other stated requirements are:

(1) If the burning site is situated in a rural area or is adjacent to or near forest, grass, woods, wild lands or marshes, the Division of Forestry shall be notified and consulted prior to any burning.

(2) All open burning under this section shall be conducted in the following manner:

(a) The piles of materials to be burned shall be of such size that the burning will be completed within the designated time given in paragraph 17-5.07(2)(a).

(b) The moisture content and composition of the material to be burned shall be favorable to good burning which will minimize air pollution.

(c) The starter fuel and materials to be ignited shall not emit excessive visible emissions when burned.

In addition, the Pinellas County Code specifies that smoke from open burning will not reduce visibility on traffic arteries or in airport approach corridors to less than 500 feet. As the volume and duration of such burning will be quite small, it is not anticipated that any long term adverse impacts will be rendered. Compliance with the above listed regulations will mitigate any short term untoward emissions of such refuse-related pollutants as carbon monoxide, hydrocarbons and particulate matter.

The most significant source of air pollution associated with plant construction will, no doubt, be fugitive dust. Site preparation activities such as excavating, scraping, filling and compacting generate substantial volumes of dust which ultimately become suspended in the atmosphere. Truck traffic moving in and out of the facility will further aggravate this particulate situation. Estimates by the EPA indicate that suspended dust levels from heavy construction activities proximate 1.2 tons per acre per month of construction activity; with this information, an estimated 451 tons of dust could be generated during the 21 months of actual heavy construction. The ameliorating techniques to be employed by the contractor are discussed in Section 4.1.6.

4.1.e Solid Waste Generation and Disposal - During the process of plant construction a substantial volume of debris will be generated; these wastes will be generally composed of paper, vegetative matter, scrap metals and lumber, concrete and miscellaneous liquids (e.g., oil, hydraulic fluid, etc.)

It is estimated that as many as 70¹ pine trees and associated understory (i.e., wiregrass, saw palmetto) will be removed during plant site preparation; conservatively speaking, this could result in 1800¹ cubic yards of cleared debris which will be either windrowed and burned, or landfilled at the adjacent disposal site. With regard to non-vegetative solid waste it is projected that nearly 63¹ tons of solid waste will be generated by the construction work force during the 32 month work regime. Of these wastes, recyclable materials (e.g., scrap metals, oil, etc.) will be recovered whenever feasible; all other wastes will be disposed of in the adjacent county landfill. Figure 4.1.c.a presents a graphical interpretation of estimated solid waste generation during plant construction.




FIGURE 4.1.c.a
ESTIMATED SCHEME OF
SOLID WASTE GENERATION
DURING PLANT CONSTRUCTION

¹ HDR estimate

4.1.f Ambient Noise Levels - Due to the limited scope of this study, and to the already disturbed nature of the facility site and environs, calculations of ambient noise levels featured in this section and in Chapter Five incorporate certain principles and assumptions presented in various acoustical engineering treatises and publications.^{1,2}

Basically, estimates of noise levels are premised on the logarithmic measures of pressure and acceleration; a logarithmic scale is most suitable for these purposes in part because of the extremely large range of pertinent levels and in part because the ear perceives loudness in a logarithmic, not linear, fashion. This logarithmic measure of pressure is termed the pressure level and is expressed in decibels (dB). Studies relative to the geometric propagation of sound reveal that, in a general sense, the attenuation of pressure levels as you move outward from the noise source is highly dependent on the magnitude of the noise and the single or multiple, fixed or mobile nature of the source. Representative noise levels for various types of construction equipment are featured below.

Noise Levels (dB) of Common Construction Equipment


Front Loader	- 79	Crane	- 83
Backhoe	- 85	Derrick	- 88
Bulldozer	- 80	Pump	- 76
Tractor	- 80	Generator	- 78
Scraper	- 88	Compressor	- 81
Grader	- 85	Pile Driver	- 101
Truck	- 91	Jack Hammer	- 88
Paver	- 89	Pneumatic Tools	- 86
Concrete Mixer	- 82	Saw	- 78
Concrete Pump	- 83	Vibrator	- 76

NOTE: Measured at fifty feet
From Bolt, Beranek and Newman, 1971

¹Lyon
²Warring, et al

At close distances ($\leq 10'$) sound pressure is characterized by plane waves with little reduction in loudness; outward from 10 feet to a margin of thirty feet, the spreading of sound follows a spherical distribution with an attenuation rate of 6 dB per doubling of distance (6 dB/dd). If multiple sources are involved, say a line of heavy trucks moving along a landfill road, noise decreases become difficult to quantify due to the complicated nature of the source. At distances from 30 to 1,000 feet, sound wave propagation from such multiple, mobile sources is more similar to the cylindrical distributions characteristic of aircraft noise and sonic booms; thus an attenuation factor of 3 dB/dd is commonly employed in this range. Outward from 1,000 feet noise again decreases in a spherical manner, consequently a drop-off rate of 6 dB/dd is utilized at these distances. Again, the assumptions presented in this discussion are very general; real life situations are comprised of a variety of attenuation parameters which function in a complicated, yet precise manner. Figure 4.1.f.1 features a hypothetical scheme of sound level attenuation from multiple, mobile sources. To a lesser extent other factors influence the reduction in loudness; among these are vegetation, physical barriers, air viscosity, molecular absorption, air temperature and humidity. Studies by Embleton, and Wierner and Keast illustrate that a grove of woods can attenuate sound pressure levels by factors of from 1 to 9 dB/100' of woods; there was no significant difference in such rates for deciduous versus evergreen species. The shear viscosity of air accounts for sound reduction, which generally

FIGURE 4.1.f.1.



varies with the square of the frequency; molecular absorption, a seemingly intangible variable, is thought to provide approximately 10 percent of the attenuation incurred by vegetative barriers. Bulk viscosity of the air is caused by the compressional relaxation of air molecules; this relaxation, due to the vibration of oxygen molecules in the medium is highly dependent on such physical variables as temperature and humidity. Generally, a decrease in temperature produces a proportionate decrease in relative humidity; the ranges of relative humidity from 5 to 20 percent offer the greatest attenuation rates, depending on the frequency of the sound. As a whole, though, the magnitude of such factors is small with a coefficient of 0.085 for a 12.5 KHz sound noted.

When discussing noise impacts induced by facility construction one should be keenly aware of conditions endemic to the study area which greatly influence noise levels as perceived in adjacent residential areas. The general site area itself is located on highly disturbed terrain which has been subjected to landfilling activities for a number of years; thus noise from incoming and outgoing truck traffic and heavy equipment is commonplace. In addition, the location of the landfill and adjacent residential areas is within the aircraft approach zone to runway 35R of the St. Petersburg/Clearwater International Airport. All of this implies that noise levels in excess of background conditions for residential areas, and similar to construction oriented sources, already occur at the nearest residential area, approximately 0.8 mile to the southwest. Assuming that a background noise level

for this residential area approximates 55 dB, a theoretical¹ increase in pressure level to 75 dB could be incurred by the operation of four trash haul trucks, two dragline cranes and one bulldozer in a fairly concentrated area of the site; this situation represents actual landfill practices. Initiation of construction and site preparation will mean an influx of similar equipment, in similar numbers. Based on the operation of two bulldozers, two scrapers and two graders in a spatially concise area, the noise level in the residential subdivision could be elevated to 69 dB. In another case, where one crane, one compressor, two trucks and five saws are operating (again, in a localized area), the residential noise level would be elevated to 71 dB. For each construction case, the imparted noise levels fall below those increments currently incurred by landfilling operations. During construction, though, landfilling and construction activities will occur simultaneously; the worst case noise source for such a situation will probably be due to lines of heavy truck traffic moving along 118th Avenue North. Assuming a case where nine trucks are equally spaced at 100 foot intervals along 800 feet of this road, the noise imparted to the nearest residences (1.015 miles south) is estimated at 49 dB, or approximately 6 dB below background levels; the interaction of noise in that area will probably result in a 1 dB increase over background. Table 4.1.f.1 summarizes the estimates of noise levels imparted to the closest residences.

¹ Less attenuation by trees, air viscosity and molecular absorption.

TABLE 4.1.f.1

VARIOUS NOISE PRESSURE LEVELS (dB) IMPARTED BY FACILITY CONSTRUCTION TO THE NEAREST RESIDENCES				
<u>Activity</u>	<u>Equipment</u>	<u>Combined Noise Level¹</u>	<u>Distance to Residences</u>	<u>Incurred Noise Level</u>
Landfilling	2 cranes 4 trash trucks 1 bulldozer	100	4287'	75
Site Preparation	2 bulldozers 2 scrapers 2 graders	94	4287'	69
Building Erection	1 crane 1 compressor 2 trucks 5 saws	96	4287'	71
Congested Truck Traffic on 118th Ave. N.	9 heavy trucks ²	82.1	5359'	49

¹ Measured fifty feet from the source(s)

² At 80 dB each

4.1.1 Construction Areas

A schematic illustration of areas to be directly affected by construction related activities is shown in Figure 4.1.1.a. Basically, portions of the overall site immediately south of 110th Avenue North will be utilized as a primary materials laydown and storage area; alternative laydown sites include the land directly north of the oxidation pond and the eventual location of the refuse handling area. That portion of land just north of 110th Avenue North and adjacent (on the west side) to the oxidation pond will serve as a staging area for subsequent construction activity. As materials delivery trucks will enter the construction site from 28th Street North on 110th Avenue North, it will be necessary to construct several access roads to the laydown area south of 110th Avenue. In this process culverts will be installed in the drainage ditch abutting 110th Avenue on its southern boundary. By utilizing an easterly approach to the construction site from 28th Street North, there will be no interference with ongoing landfilling activities as trash trucks will continue to enter the site from the existing western approach. The addition of 114th Avenue North and other facility roads (see Figure 3.1.a) will occur towards the latter phases of plant construction.

For the completion of all the above listed activities no significant adverse impacts are noted. The only undisturbed area to be impacted is the pine flatwood stands south of 110th Avenue designated as a materials laydown area. As it is the intent of the County's contractor to maintain as much of the existing tree canopy in that area as possible for sound attenuation and aesthetic enhancement,




FIGURE 4.1.1.d.

AREAS IMPACTED BY CONSTRUCTION ACTIVITIES



site alterations will impart short term effects and will not greatly modify the terrain. Wildlife inhabiting these areas can find significant tracts of similar habitat directly adjacent to the laydown areas. Furthermore, much of that area south of 110th Avenue could be converted to a landfill for the disposal of inert boiler residue generated by recovery operations; thus clearing activities associated with construction may simply precede more extensive site alterations.

With regard to the disposal of solid and liquid wastes, debris including paper, concrete and plastic will be landfilled at the adjacent disposal site. Likewise, vegetative matter will be buried or open burned as permitted by local regulations. Scrap metals and many deleterious liquids (e.g., oil, hydraulic fluid, etc.) will be recovered and removed by selected contractors.

4.1.2 Land Impact -

As extensive soil borings of the plant construction site are lacking at this time, detailed data on site excavations and fill amounts are not available. Very conservative estimates assume that an average three foot backfill will be necessary to bring the surface elevation to an appropriate level; thus some 58,000 cubic yards of soil will be stripped and replaced by 166,800 cubic yards of material. In addition, approximately 84,400 cubic yards of fill will be needed to provide the proper elevations for the tipping area and drive-up ramp. Local soil and bedrock characteristics indicate that conventional mechanical means of site excavation are quite feasible, thereby precluding any possible need for explosives.

As discussed in a previous section, solid wastes generated by construction activities will be properly disposed of in the adjacent county landfill; scrap metals and other recyclable materials will be recovered. In all cases no adverse impacts, either long or short term, are noted.

The acts of stripping and filling of the construction site will produce locally significant dust clouds; the volume of such particulate matter is difficult to quantify but will probably approximate those levels generated by the trucks, cranes and dozers associated with the existing landfill. As landfilling and construction will occur simultaneously it is anticipated that dust levels affecting nearby roadways (i.e., 28th Street and 110th Avenue) will be aggravated. Section 4.1.6 of this document discusses the methodologies to be employed in mitigating ambient dust concentrations.

4.1.3 Impact on Human Populations -

The closest residential area to the proposed facility site is located in Pinellas Park with the nearest houses situated roughly 0.8 of a mile southwest of the plant site. Analysis of noise calculations (Section 4.1.f) reveals that sound levels imparted to this area by facility construction will be essentially the same as those already experienced from landfilling activities. As construction operations will occur only during daylight hours of the regular work week (7:30 a.m. - 3:30 p.m., Monday - Saturday), aggravating noise is not anticipated at any residential area.

Commuter vehicles associated with the construction labor force will enter the site via the following routes:

- a. Eastward from 49th Street North on 118th Avenue North.
- b. Northward on 28th Street North from Gandy Bridge Blvd.
- c. Southward on 34th Street North from Ulmerton Road.

The 118th Avenue North route will probably serve most of the traffic and passes through industrial (light manufacturing) and undeveloped areas; the other routes are unpaved roadways which traverse undeveloped lands and a few construction sites. In no case will construction related traffic be directed through any residential or commercial areas.

The County's contractor has specified that the plant construction work force will be composed primarily of local tradesmen and mechanics (see Section 4.1.4). This precludes the possibility of complications arising from the housing, schooling, etc. of work force personnel and dependents.

There has been some public comment regarding the aesthetic impact of constructing and operating the facility and its associated exhaust stack. It should be noted that the plant itself will incorporate pleasing architectural concepts designed to enhance its visual appeal; the planned landscaping scheme will further augment the situation. In any case, one must not forget that the construction and ultimate operation of the resource recovery system will signal the end of raw refuse landfills except for emergency situations.

4.1.4 Work Force -

A representation of construction operations and manpower loading is featured in Figure 4.1.4. The County's Contractor estimates

as many as 290 persons at one time will be directly involved in the erection of the plant; it is anticipated that all tradesmen will come from local labor pools as the necessary skills are available.

4.1.5 Impact on Accessibility -

The initial analysis described in Section 2.3 of this report indicates no cultural, historical or archaeological sites were located within the study area; consequently no activity associated with plant construction will inhibit accessibility to such an area.

Confirmation of these findings presented in Section 2.3 by the Bureau of Historic Sites and Properties is featured as Appendix E.


4.1.6 Mitigating Measures -

Construction of the resource recovery plant for Pinellas County will involve the alteration of approximately 20 acres of previously disturbed terrain; in addition, some 40 acres of adjacent land will be affected by access road construction (114th Avenue) and building material storage. By the very nature of these activities a certain amount of wind and water erosion are inevitable. To minimize the adverse impacts of dust and other suspended matter on the ambient environment, several ameliorating techniques will be employed. With regard to dust control, water sprays will be applied on problem sites as necessary; considering that the typical soil components of the site are quite coarse, and that rainfall is generally abundant, the number of water spray

MECHANICAL COMPLETION →

- LEGEND**
- CIVIL
 - BUILDING
 - MECHANICAL
 - BOILER
 - ELECTRICAL
 - MISC.

MINIMAL PERSONNEL REQUIRED DURING FIRST 10 MONTHS



300
290
280
270
260
250
240
230
220
210
200
190
180
170
160
150
140
130
120
110
100
90
80
70
60
50
40
30
20
10
0

MANPOWER (NO. OF MEN)

NOTE: BASED ON PLANT CAPACITY OF 100 TONS/DAY

MONTHS

SOURCE: UOP, Inc.

ANTICIPATED. MANPOWER REQUIREMENTS DURING CONSTRUCTION

treatments can be expected to be few. Soil erosion via stormwater runoff will be significant despite the coarse soil particle size and nearly level terrain found at the site; the highest potential for erosion will occur along roadways and such elevated areas as the tipping floor and its vehicle access ramps. By employing the universal soil loss equation, soil losses for a common storm event (2 inches in one hour) at the most critical sites were estimated. Assuming no mitigating measures are employed on berm slopes, soil losses for that storm will approximate 2.0 tons per acre; by contouring slopes and applying hay mulches (one ton of hay per acre) erosional losses are reduced to 0.2 tons per acre. As soil loss imparts adverse economic and environmental consequences, preventative strategies will be incorporated into the project construction scheme.

As previously discussed, as much of the indigenous tree canopy will be maintained as is practical; in any case, the site environs will be suitably landscaped to enhance aesthetic appeal, provide noise attenuation and minimize erosion.

Truck traffic in and out of the construction site will be directed to 118th Avenue North. As this route currently serves similar vehicular traffic, any possible re-routing is deemed unnecessary.

4.1.7 Benefits from Construction -

The obvious benefit from plant construction centers on the creation of several hundred jobs for area residents during the project duration; this not only provides direct wages to local tradesmen, it also stimulates local economies by circulating

additional revenues into area businesses and services. This is especially important for such construction oriented concerns as equipment rental firms, building materials suppliers and specialty subcontractors.

A direct and profound effect of constructing the plant will be the eventual elimination of environmentally costly landfill activities. Upon commencement of plant operations the life expectancy of land available for residue disposal will be dramatically extended; thus the ultimate fate of putrescible solid waste in Pinellas County will not be as a possible groundwater pollutant but a valuable fuel for the generation of electricity.

4.1.8 Impact on Water Bodies and Uses -

As the facility is to be located some distance from any large waterway, and as all plant associated water schemes (i.e., potable supplies, cooling tower makeup, etc.) are basically separated from the study area surface and groundwaters, erosion to exposed soil surfaces and, possibly, intermixing of surface waters with more nutrient enriched surficial aquifer waters present the most probable sources of untoward effects.

Sedimentation as a result of water and wind erosion may be locally significant in those existing drainage ditches which parallel 28th Street North and 110th Avenue North. Based on the large size of eroded particle, the languid characteristics of drainage ditch flow and on first hand observations following storm events, particulates entering the ditch via runoff will precipitate and settle near the runoff inlet; as these waterways are quite shallow (less

than 18" depth maximum) chronic sedimentation could fill the channel thus reducing its ability to conduct stormwater away from upland areas.

Efforts to mitigate site erosion have been discussed in Section 4.1.6; regardless of these strategies some sedimentation into fringing canals is inevitable. The aquatic weeds which colonize these ditches are either emergent (cattails) or floating (duck weed); this latter type forms thick mats over most surfaces and greatly inhibits light penetration to any potential benthic flora. Thus the addition of sediment to the ditches (in the anticipated quantities) and the resultant increase in water column turbidity will do little to alter existing plant populations. With this in mind, dependent organisms (e.g., epiphytes, primary consumers, etc.) will not be greatly impacted.

The detailed soil borings necessary prior to site preparation are not available at the time of this writing; consequently, the need for and, thusly, the volume of subsurface drainage via a wellpoint system are not known. Assuming that some pumping will be required certain adverse impacts could be incurred if the pumpate were directly discharged to surface waters. As surficial aquifer waters exhibit higher concentrations of nutrients and common metals than those recorded in surface waters (see Table 2.5.4.d) the introduction of this nutrified flow could further enrich surface water, thereby enhancing the growth of noxious weeds. To prevent the introduction of aquifer water into drainage ditches, wellpoint flows will probably be pumped to the combination stormwater retention or alternative cooling water supply pond identified in Sections

3.4 and 3.10 of this document. In any event, wellpoint pumping will be of short duration, thus any adverse impacts will be relatively short-lived.

Of circumstantial importance to the construction of the resource recovery plant are the plans by Pinellas County to alter the natural drainage scheme which serves the plant site. Essentially, water entering the canal which abuts 110th Avenue North originates to the west and south. It has been proposed that all flow entering the canal west of 34th Street North be diverted west and north (through the completed landfill perimeter ditch) by imposing an artificial barrier in the 110th Street ditch near 34th Street. This will be performed during the preparation of the perimeter canals and sight-screening levee. With this change, water flowing into the 110th Street ditch will come exclusively from the facility site. This fits into the overall drainage scheme for the plant (see Section 3.10) in that all plant generated runoff, and only such runoff, will be routed to the retention basin for subsequent storage, landspraying or emergency withdrawal as cooling water.

4.3 Construction of Directly Associated Transmission Facilities

4.3.1 Permanent Changes to Vegetation, Wildlife and Aquatic Life

Construction of the transmission lines will warrant the permanent displacement of vegetation and, consequently, inhabiting wildlife; it is estimated that nearly nine acres of pine flatwood, Brazilian pepper or previously disturbed terrain will be affected. As the transmission line right of way is juxtaposed with 28th Street North and the existing Florida Power transmission lines

for its entire length, the area of direct impact is already subject to considerable duress by roadway traffic and power line right of way maintenance.

Specifically, the transmission lines will traverse pine flatwoods terrain from the resource recovery plant southward on 28th Street to a point where County owned property on the western side of 28th Street ends; there the right of way crosses to the east side of this roadway. The vegetation existing on the east side of 28th Street is strikingly more disturbed and is characterized by Brazilian pepper trees, lantana and Johnson grass. Very near and just north of the crossing of 28th Street by the existing FPC power lines is a natural drainageway or, more appropriately, a slough; flora in this area are dominated by the coastal plains willow with scattered specimens of maple (Acer sp.). Field observations of this community indicate that some factor has caused extensive die-offs of the willows and understory in recent times; the affected flora are characterized by wholesale leaf mortality typical of those conditions induced by a wildfire; other evidence of fire (e.g. charred wood) was not noted. Once the proposed transmission line junctions the existing FPC right of way, the proposed route will parallel the existing lines, but just to the north. Terrain encountered in this length from 28th Street to the FPC northeast substation is highly disturbed land typified by Brazilian pepper trees and lantana; the transmission lines will also cross Interstate 275 in this span.

Construction activities associated with power line erection include clearing of right of way, installing pole

foundations, raising and securing the towers and stringing the conductors. Land clearing will be quite extensive in the affected areas as all trees must be removed; this will be accomplished by mechanical (e.g. by bulldozer) rather than chemical (e.g. herbicides) means. Once the project is completed, subsequent right of way maintenance will be rendered by mowing the understory; small bushes and shrubs will be permitted. After the right of way is cleared the tower foundations will be laid, the poles erected and transmission hardware placed; these latter activities will have little or no impact to surrounding terrain in lieu of the drastic disturbances incurred by site clearing.

Two factors greatly mitigate the long term adverse impacts of such habitat destruction as described above. First, wildlife living in the impact area will find a substantial amount of similar habitats directly adjacent to the power line right of way. Second, the impact areas are already greatly affected by unnatural stresses such as roadway traffic (on 28th Street) and power line right of way maintenance; in fact, much of this land is occupied by biologically unproductive habitat, such as Brazilian pepper, typical of highly disturbed conditions. It is speculated that the activities of the waste water sprayfield along 28th Street are principal determinants of the biological scheme in that local area. By this the sprayfield is directly chargeable with the patterns and alterations of the associated biota. Thus it is felt that removal of pine and Brazilian

pepper stands in areas near the sod farm, while causing some stresses, will not substantially impact endemic wildlife as the basis of their lifestyles (i.e. the sprayfield) is not altered.

4.3.2 Extent of Impact on Sensitive Areas

Power line right of way will be maintained at an effective width of forty (40) feet for its entire length. With regard to actual lengths of right of way to be constructed on each type of terrain the following breakdown is offered:

- Pine flatwoods - 600' along the southern side of 110th Avenue North and then 2700' along the western side of 28th Street North. The distance from pole centerline to the abutting edge of roadway right of way is 10'. Estimated affected pine flatwoods, 132,000sq. ft. or 3.03 acres. The density of trees in the impact area is not large with a one tree per 5000sq. ft. relationship representative.
- Brazilian pepper and other disturbed vegetation - 2000' along the eastern side of 28th Street North then 3050' along the northern perimeter of the existing FPC power line right of way to the FPC northeast substation. This vegetation is essentially continuous with the exception of 400' where Highway I-275 is crossed. Total estimated affected land is 202,000 sq. ft. or 4.64 acres.

Probably the most sensitive condition which the transmission line will impact centers on the visibility of the structures at residences to the west of 28th Street (the mainlands of Tamarac, situated 0.64 miles distant). Due to the levelness of

the terrain and the limited screening afforded by trees the power lines will be very obvious, especially where they parallel 28th Street. In retrospect, the selection of the proposed transmission line route is based on an analysis of least impact/economic feasibility criteria; thus the proposed orientation is presented as the most sound from all practical standpoints. Therefore, the adverse impact of tower visibility at nearby residences is deemed unavoidable. However, the presence of a much larger power line and right of way already transecting these same residences (see Figure 2.2.2.a) mitigates considerably the initial implications of proposed line erection.

4.3.3 New Roads

Clearing associated with transmission line construction has been discussed in previous sections; essentially a 40' wide right of way will be established and maintained. Access to power lines will be rendered via service roads within the clear area. It is not anticipated that any new roads will be constructed.

4.3.4 Erosion

As all construction activity will occur on level sites, runoff produced erosion will be negligible. Exhaustive erosion control will not be implemented unless conditions arise which warrant such applications. In such cases mulching with hay will generally be practiced.

4.3.5 Impact on Agriculture

The construction of the transmission facilities will not affect any existing or projected agricultural activities.

4.3.6 Mitigative Measures

As transmission line erection is of minor magnitude in relation to recovery plant construction, considerable adverse impacts, such as water and wind erosion, are not anticipated. Should conditions warrant control application (e.g. during unusually wet or dry periods) the techniques for erosion and dust control discussed in Section 4.1.6 will be exercised. Debris from right of way clearing will probably be windrowed and burned (again in accordance with local regulations); any non-processible wastes (concrete, lumber, plastics) will be land-filled at the existing county solid waste disposal site.

No activity associated with plant and associated transmission line construction will adversely impact a rare or endangered species. The eventual enhancement of surficial and aquifer water quality as a direct result of the termination of putrescible waste disposal practices will benefit important (i.e. sport, endangered, etc.) species in the study area and in watershed termini.

4.4 Resources Committed

Construction of the resource recovery plant will necessitate the permanent alteration of approximately 30 acres of land. Most of this land is composed of the pine flatwoods community while lesser tracts are characterized by man-induced disturbances (e.g. landfills) and subsequently established vegetation (e.g. Brazilian pepper, lantana, etc.). When evaluating the impacts of losing such terrain as wildlife habitat one should

be keenly aware of the alternative situation; that is, the consequences of continued solid waste disposal by landfilling and the extremely large expanses of identical habitat which will be destroyed. In essence, by switching to the proposed resource recovery method over conventional solid waste handling techniques, the amount of land needed to meet the crecive demand of waste disposal in Pinellas County is drastically reduced.

Long term economic benefits also are probable by construction of the proposed facilities in lieu of the continuation of current landfilling practices. Analysis has shown (reference Chapter 7) that a savings of over 50 million dollars could be realized over a 20 year operating period. While this figure is abstract, it does illustrate the potential economic impact of selecting the resource recovery option in addition to the social and environmental factors.

CHAPTER 5

ENVIRONMENTAL EFFECTS OF PLANT OPERATION

5.1 Effects of the Operation of the Heat Dissipation System

5.1.1 Temperature Effect on Receiving Body of Water

As presented in Chapter 3, cooling water make-up for the mechanical draft cooling towers will come from the City of St. Petersburg and City of Largo non-potable water supplies (treated wastewater effluent). Make-up water may be withdrawn from the stormwater retention pond just south of 110th Avenue (see Figure 4.1.1a), if water levels approach overflow conditions. Cooling tower blowdown will either be further utilized (as residue quench water) and ultimately discharged into the Pinellas Park domestic sewer line, or mechanically entrained or evaporated to the atmosphere. No related effluent will be discharged to any hydrologic unit, be it surficial or ground water. With this, discussions of thermal impacts on receiving waters are not germane to this application.

5.1.2 Thermal Limits - See Section 5.1.1.

5.1.3 Effects on Aquatic Life - See Section 5.1.1.

5.1.4 Effects and Implication of Entrainment

Following prolonged periods of excessive rainfall the water level of the retention pond may approach an overflow condition; to prevent such spillage and subsequent flooding (thereby retaining all stormwater on site) it will be necessary to pump the excess to an alternative fate. So that the overall

drainage design will continue to be site oriented and closed to adjacent surface waters, it is being considered that such excess flows be diverted to the cooling tower as an auxiliary make-up supply. Once the optimum pond water level is achieved, cooling water withdrawals will cease.

The 22 acre pond was originally a borrow pit which has subsequently filled with water via seepage from the water table aquifer. It is estimated that the average depth of the rectangular pond approximates 5 feet. Empirical data on pond water quality are lacking; however, it is probable (from field observations) that nutrient concentrations are in relative imbalance with system assimilative capacities. This phenomenon is also evident in all study area surface waters. As the pond is located upgradient of both existing and former landfills, an absolute source of nutrients is not readily discernable; two potential contributors, however, are speculated. First, the water table at the pond site could be affected by a landfill leachate plume which migrates into pond waters during excessive wet periods. Second (and more probable) large flocks of seagulls very frequently concentrate on and around the pond; wastes from these birds are high in nitrates and phosphorus and could conceivably exacerbate nutrient concentrations in this lentic system. In either case, based on the visual similarities of this pond to adjacent surface waters (with respect to obvious eutrophic characteristics) it is assumed that data from the perimeter ditch (Table 2.5.4.a) are likewise representative of pond conditions.

Approximately 50 percent of the pond littoral zone is moderately vegetated with cattails; the remaining shoreline is composed of exposed soil. While submergent vegetation (i.e. macrophytes) is profuse in many areas, it appears that the unidentified specie(s) suffer(s) from photosynthetic stress incurred by enwrapping growths of epiphytic algae. This same excessive algal growth covers all of the observed benthic substrate. With regard to endemic fauna, it is speculated that pond fish species will be restricted to typical eutrophic organisms, specifically, the Poeciliidae and Centrarchidae; Several unidentified amphibians (frogs) and reptiles (turtles) were also observed. The pond is probably most significant to birds, especially those hundreds of seagulls which often invade the pond surface.

With these ecologic conditions in mind and in lieu of the very limited water withdrawals proposed (i.e. only to regulate pond levels), it is anticipated that implications of entrainment, impingement and entrapment will not severely stress the functional aspects of the pond ecosystem. As algal concentrations and vegetative debris within the pond are substantial, sophisticated screens, representing the best available technology will be installed at the cooling water intake, thereby minimizing adverse environmental impact (in accordance with Section 316.b, PL 92-500) and potential interruption of the cooling tower processes.

5.1.5 Biological Effect of Modified Circulation

The retention pond in question is a closed, very shallow surficial water body. With this it can be stated that circulation within the pond, while limited, is probably in direct response to wind conditions and, to a lesser degree, groundwater flow; thermal stratification is not probable, thus seasonal mixing is not a plausible factor. The limited withdrawals of water proposed will produce short-term modifications of an already restricted circulation. At a maximum pumping rate of 300 GPM the impact of altered flow will probably prevade through most of the pond. Turbidity and sedimentation from scouring will be confined to the immediate vicinity of intake structure. However, given that the withdrawals will occur only when water levels are excessive, overall long-term alterations in ecologic schemes due to such phenomena are deemed negligent.

5.1.6 Plant Operation Effects

As previously discussed, utilization of pond water will not occur with any degree of regularity; it is reasonable to assume that no withdrawals will occur for months, possibly years, at a time. Thus, the relative dependence of the pond ecosystem on plant operation will be basically non-existent.

5.1.7 Effects of Offstream Cooling

The potential for fogging from cooling tower emissions was evaluated by analyzing the saturation deficit with respect to ambient meteorologic conditions (STAR program) and cooling tower emission specifications. Based on this analysis, plant

induced fog is anticipated to occur at an average rate of 14.08 days per month with heaviest occurrences noted during the winter months. As this potential is measured at the stack outlet, fogging in outlying areas is expected to decrease as a function of the ambient saturation deficit.

Section 5.2.2 and Appendix B of this application feature the expected disposition of mechanically entrained water droplets in the environment; the dispersion of this water is considered significant in that the droplets will contain the chemical constituents of the cooling tower make-up supply.

5.2 Effects of Chemical and Biocide Discharge

5.2.1 Aquatic Discharge from Industrial Type Wastes

Corrosion inhibitors and anti-fouling agents, as identified in Section 3.5, will be collected in the cooling tower and boiler blowdowns. These wastestreams (with an average combined flow of 339 gpm - Figure 3.3.a) will be augmented by flow from the demineralizer backwash (average flow of 6 gpm). All wastes will be temporarily stored in a holding tank, monitored and stabilized for pH and, with the exception of a 20 gpm flow diverted as a residue quench supply, eventually discharged to the Pinellas Park sanitary sewer system. All domestic wastewater and effluent from tipping area washdown will likewise be routed to the above cited holding tank for stabilization and discharge. No process or sanitary wastewater will be discharged to any surficial or ground water. Impacts of the proposed stormwater treatment system are discussed in Section 5.3

5.2.2 Cooling Tower Blowdown and Drift

Cooling tower blowdown is discussed in Section 5.2.1 above as a constituent of aquatic discharge from the plant.

Drift on the other hand is that portion of the cooling system flow stream which is entrained in the forced air stream in the tower and which is carried out of the tower in the rising plume. This drift discharge unlike the evaporated portion of the plume has physical and chemical characteristics the same as those of the cooling system water (see Table 3.4.5.a). The drift discharge flow rate will average 37 gpm. The droplets within the drift stream will be deposited on the terrain about the point of discharge at radii varying with meteorologic conditions. The most compact profiles of distribution will occur during both very low velocity winds and very high velocity winds. A detailed discussion in Appendix B presents the effects of wind velocity and temperature on areas over which the droplets are deposited. A typical example based on average January conditions shows the deposition of drift in the following manner:

<u>Cumulative % of drift</u>	<u>radius to deposition (km)</u>
2	.075
11	.091
27	.123
48	.191
70	.413
90	2.1

5.2.3 Effects on Sources of Drinking Water

Potable water will be withdrawn at an average rate of 116 gpm from the Pinellas Park water supply. An estimated 66 gpm of this flow will be used as boiler feed water make-up with the remainder utilized for resident potable and sanitary needs. At such a small flow rate no adverse impacts on local water supplies (which are obtained remote from the site) are noted.

5.3 Effects of Sanitary and Other Wastes

As discussed in Section 3.6, discharges to the Pinellas Park sewer line will be composed of sanitary and process blowdown wastes. It is estimated that the total effluent flow will average 375 gpm.

A unique feature of system design is the provisions made for the storage and treatment of site generated stormwater runoff and landfill cell water; pertinent details are presented in Section 3.10. As a result of drainage system operation, essentially no water will be discharged from the plant site (including landfills) into any surficial watershed or aquifer except in the event of extremely heavy rainfall.

Two options for emergency flood control are proposed. First, as discussed in Section 5.1.4, excessive water will be diverted to the 22 acre retention pond for subsequent utilization as cooling water make-up. The second alternative centers on an emergency spillway situated in the perimeter ditch at the extreme southeast corner of the sprayfield. Theoretically,

the sprayfield water which would be discharged at that point will be of higher chemical quality than that cited in the receiving 28th Street ditch. This is due to the treatment afforded in the oxidation/hyacinth/chlorination ponds and the further dilution of this water by rainfall. Based on the expected good quality of discharged water (as opposed to ambient receiving surface waters) and of the low probability of such discharges occurring, adverse impacts to surficial waters are not apparent. Likewise, the chemical characteristics of the sprayfield effluent should not exacerbate water quality in the underlying water table aquifer. On the contrary, by applying the treated water to the soil as proposed, some amelioration of poor water quality in the surficial aquifer underlying the sod farm is possible. In light of the water quality data from shallow wells beneath the sod farm (which indicate poorer quality water than noted in surface waters - see Table 2.5.4.d), and as the groundwater gradient slopes toward the sod farm from the proposed sprayfield, the dilution and subsequent improvement of adjacent groundwater quality due to spray irrigation is a conceivable assumption.

The hardware to be utilized at the sprayfield proper is discussed in Section 3.10. With regard to high pressure jet sprays, untoward impacts are historically attributed to the downwind drift of fine spray particles. In addition, the visual impact of a sprayfield often fosters antagonistic reactions from nearby residents. Selection of appropriate nozzle apertures

coupled with prudent operation and maintenance programs can drastically reduce fine aerosol production, thus greatly limiting areal dispersion. The proposed construction of a 20 foot berm around the sprayfield, subsequently planted with fast growing evergreen trees (i.e. red cedar, slash pine), will further attenuate the drift of fine aerosols off of sprayfield properties while visually screening the sprayfield from any nearby residences.

Certain characteristics of hyacinth (Eichhornia crassipes) usage as a biological waste filter warrant consideration so as to minimize potential adverse environmental impact.

The ability of this floating vascular plant to efficiently reduce suspended solids, nitrogen species and oxygen demanding substances in waste streams is well documented; these plants have also demonstrated promising results with regard to metals uptake and pH stabilization. It is anticipated that the hyacinth pond substrate will contain water originating primarily from stormwater runoff and inert residue landfill cell water. Typical parameters associated with runoff include suspended and volatile solids, Kjeldahl nitrogen, biochemical and chemical oxygen demands and total organic carbon. As the site will accommodate a heavy flow of truck traffic heavy metals such as lead and chromium will probably enter the runoff stream in considerable quantities. With this it can be assumed that the hyacinths harvested from the pond will contain some traces of these potential toxins. To minimize possible ill effects

fertilizer and mulch rendered from the hyacinths should be applied judiciously to non-edible plantings, such as landscape vegetation. If hyacinth metal concentrations approach hazardous levels, disposal should be accomplished by incineration in the resource recovery plant. A viable alternative for such cases centers on the incineration of hyacinths to generate methane gas; heavy metals are subsequently recovered from the waste stream. This option, while having seen limited application, represents a feasible consideration should a chronic metal problem persist and a materials recovery scheme be sought.

The very rapid growth of hyacinths in a suitable medium is further characterized by the continuous shedding of root tissue. This material settles to the bottom and can rapidly accumulate to problem levels. While data on the chemical constituents of this material are lacking, it is speculated that assimilated nutrients and absorbed metals will also be present in this settled detritus. Disposal of this precipitate then must be accomplished either by landspreading or incineration and landfilling, depending on the toxicity of the material.

Other potential problems associated with hyacinth ponds include mosquito propogation, putrid odor production and hyacinth predation.

Mosquito populations have been effectively suppressed by the introduction of predatory species to the pond; such organisms include the eastern mosquitofish (Gambusia affinis) and dragonfly nymphs (Order Odonata). It has also been noted

that even slight circulation of the water column is effective in discouraging the female mosquito from depositing eggs. This factor could be jointly employed for anthropod control and for increased nutrient uptake efficiency by the hyacinths. That is, studies have shown that nutrients tend to stratify near the surface. A slight turbulence in the water column enhances nutrient flow through the root zone, thereby facilitating absorption.

With regard to odor problems, hyacinths allowed to completely blanket the water surface will greatly inhibit sunlight penetration to euphotic algae and benthic macrophytes. A reduction in photosynthesis and, consequently, the dissolved oxygen concentration will subsequently occur. When oxygen levels fall below the 2-3 ppm productivity range by anaerobic bacteria in the benthic sediments, detritus and hyacinth roots are stimulated with the resultant generation of pungent hydrogen sulfide gas. To minimize such occurrences hyacinth growth will be regulated in a manner which permits adequate illumination of subneustonic areas. If such control is considered infeasible oxygen levels could be maintained by outfitting the pond with aeration equipment.

Experimental applications of hyacinth filtration indicate that predation on these succulent plants by coots (Fulica americana) and nutria (Myocastor coypus) can greatly inhibit hyacinth productivity and, thus, the operational efficiency of the system. On-site observations reveal that while coots do frequent study area ponds, they prefer to forage on the more

abundant duck weed than on the hyacinths which occur in scattered clusters. Nutria are not known to occur at the site. A successful method for limiting such predation involves the utilization of scare sirens or horns.

5.4 Effects of Air Emissions

For both the Prevention of Significant Deterioration (PSD) and the Ambient Air Quality Standard (AAQS) evaluations it is concluded that the air quality impacts associated with emissions from the Pinellas Solid Waste Resource Recovery Facility will be minimal. It should be noted that, in accordance with Part 52, 1977 Amendments to the Clean Air Act (as promulgated on June 19, 1978) the area of significant impact of the proposed facility is virtually non-existent.

A detailed assessment of expected impacts is presented as Appendix A.

5.5 Effects of Operation and Maintenance of the Directly Associated Transmission System

5.5.1 Effects of Operation and Maintenance

There are no impacts associated with the operation of the transmission line which are considered significant. Conversations with transmission engineers of the Florida Power Corporation reveal that no problems (e.g. fire, vandalism, noise) have been associated with existing FPC power lines. Bird collision with aerial hardware is an unavoidable circumstance, although actual quantification of the problem is

non-existent. Based on the preliminary sizing of the proposed transmission line, it is anticipated that some mortality will occur.

All power line rights of way are maintained by mowing; herbicides and fire are not employed. Allowed vegetation in the clear zones is limited to low bushes and shrubs. As is typical for the geographic area, cleared areas will probably be revegetated by the prolific Brazilian pepper tree. Indeed, these trees form low dense thickets under existing FPC lines in the study area. Where the proposed transmission line transects disturbed vegetation areas (see Section 4.3.2) no substantial long-term changes in the biota are noted; however, installation of the power line along the west side of 28th Street will bring about the eventual displacement of pine flatwoods habitat with less productive communities, notably the Brazilian pepper coppice. The long-term adverse impacts on endemic fauna are greatly mitigated, though, by the availability of considerable pine flatwoods habitat in directly adjacent areas.

As discussed in Section 4.3.2 the visibility of the transmission line at nearby residences represents a major consideration. Again, though, the proposed route represents the most economically and environmentally sound alternative posed. By juxtaposing the proposed power line with the existing structures, unsightly aspects are essentially concentrated.

5.5.2 Effects of Public Access

The entire route of the proposed transmission line will cover terrain already accessible (although somewhat limited)

to the public; specifically, via 28th Street or the existing FPC right of way. Thus, no resultant adverse impacts on the surrounding biota are projected.

5.6 Directly Associated Facilities and Other Effects

5.6.1 Effects of Directly Associated Facilities

Upon commencement of plant operations it is estimated that 2.1 percent of the total incoming solid waste volume will require landfilling; Section 3.6.3 identifies the expected materials composition of the resultant inert residue to be subsequently landfilled. Provisions are also included for the handling of non-processible wastes (e.g. demolition debris) and the emergency landfill disposal of unprocessed solid waste in the event of partial or total plant shutdown. The specifications for the receiving landfills are presented as Appendix D of this application.

Adverse impacts associated with landfilling center on the contamination of critical hydrologic units through leachate infiltration. Due to the hydraulic characteristics of aquifer systems, leachate plumes can continue to impact groundwater quality long after the termination of putrescible waste disposal. Short term improvements in aquifer water quality, then, are not expected following initial plant start-up; rather gradual melioration, compounding with increased time, is more likely.

5.6.2 Other Plant Effects

Noise levels incurred by a worst case situation of heavy truck traffic were estimated in Section 4.1.f. The

results of this analysis indicate no significant increases in ambient noise at the nearest residences. With regard to plant operation, the loudest exposed source is the turbine generator with an expected sound pressure level of 85 dBA (measured at the unit). With this in mind, and employing the same methodology as demonstrated in Section 4.1.f, this unit could impart a noise level of 48 dBA to nearest residences; again, assuming a residential area background level of 55 dBA, it is estimated that, at most, an increase in noise of 1 dBA is a very conservative appraisal. As the turbogenerator will be enclosed in louvered panels and as some trees do screen the noise source, further attenuation is highly probable.

There is also some concern regarding the visibility of the plant at nearby residences and thoroughfares. The UOP plant features several options for architectural masking designed to enhance aesthetic appeal; moreover on-site roadways and plant grounds will be landscaped. While some individuals still maintain that any industrial facility is unsightly, the alternative choice (i.e. continued landfilling of solid wastes) offers only vistas of seagulls, garbage mounds and blowing trash.

5.7 Resources Committed

Construction and operation of the solid waste resource recovery plant represent a major commitment of capital and real estate to solve a crecive problem in Pinellas County. As discussed in Section 7.1, the monetary costs of the proposed

plant could be greatly exceeded if landfilling of solid wastes was the selected alternative. By drastically reducing land requirements for accommodating solid waste generation, larger undeveloped tracts in the study area can be economically developed or reserved as wildlife habitat.

5.7.1 Lost Revenues

It is apparent that the cessation of landfill disposal of solid waste will be cataclysmic to dependent scavengers, primarily the seagulls. As such large populations of these animals derive most of their sustenance from wastes at the site and nearby at Toytown, the fate of a large number of organisms is uncertain. As it is not probable that alternative food supplies are readily available in the surrounding bay area, a reduction in species population can be expected. Since predation on most of the animals is non-existent no impacts to higher trophic level organisms will occur. In any case, the types of species affected occur in great abundance throughout the bay system, the Gulf Coast and the Coastal Plains Biome; therefore, localized population reductions will not directly or indirectly compromise the perpetuation of any species.

With regard to energy supplies the amount of fossil fuel necessary to generate the equivalent electricity produced by the plant from solid waste is discussed in Section 8.2; operation of this plant, then, represents a significant step in conservation of these scarce resources.

5.7.2 Land Area Lost

Implementation of the proposed resource recovery program, as opposed to continued landfill disposal, will drastically reduce the acreage required to accommodate future solid waste generation. A cost analysis of this relationship is featured in Section 7.1 of this application.

5.7.3 Changes in Species Population

Discussions of expected alterations due to plant construction and operation are presented in Chapters 4 and 5, respectively; below is a synopsis of anticipated ecologic changes:

- The Plant Site - To be modified from partially disturbed, partially wooded (pine flatwoods) site, to a landscaped industrial tract.
- Power Line Right of Way - Pine flatwoods area will be displaced by disturbed vegetation (e.g. Brazilian pepper trees).
- Exclusive food supply for landfill scavengers will be removed; considerable localized reductions in ubiquitous species populations (primarily seagulls) is anticipated.

CHAPTER 6

ENVIRONMENTAL MEASURES AND MONITORING PROGRAMS

6.1 General

This section will review those methodologies employed in the formulation of the PPSC document; in appropriate sections those monitoring programs proposed for post-construction environmental evaluation will be discussed.

6.2 Pre-Application Monitoring

With few exceptions, pre-application monitoring did not occur; baseline data collection relied primarily upon literature review, interviews with relevant technical and administrative personnel, and the expertise of the applicant and their consultant in the formulation of such evaluations. It is anticipated that the following pre-application monitoring programs will be implemented:

- On-site soil borings - for design purposes
- A hydrogeologic evaluation of the site by the United States Geological Survey

Final design borings will be performed by a certified testing laboratory; a specified contractor has not yet been designated. The U.S.G.S. has been under contract by Pinellas County for approximately 3 years gathering data pertinent to the County's landfill operation and proposed resource recovery program. A report of findings is being finalized at this time. Draft information from this report was utilized in the preparation of this document. A comprehensive listing of data sources are featured in the reference section of this

document; extracts dealing with specific figures and conclusions are documented and cited at the bottom of the respective page.

6.2.1 Surface Waters

Surface water data for the perimeter canals of the landfill were obtained from the U.S.G.S. data retrieval network (WATSTORE); this data encompassed a continual regimen with six observations from May 1975 through October 1976. A detailed study specific to the facility site is currently being prepared by the U.S.G.S. By comparing the concentrations of critical parameters with those recorded at nearby locations (Cross Bayou Canal, Toytown Landfill, etc.) and those proposed in Chapter 17-3, FAC, an assessment of water quality was provided.

6.2.2 Physical and Chemical Parameters

The U.S.G.S. monitors certain surface water quality parameters on a routine basis; these include arsenic, cadmium, chromium, lead, mercury, nitrates, ammonia, chlorides, copper and pH. In addition, the U.S.G.S. has the capability to monitor the following parameters: radium, gross alpha particle activity, selenium, silver, 2,4-E, alkalinity, aluminum, antimony, fecal coliform, beryllium, bromine, dissolved oxygen, hydrogen sulfide, iron, nickel, polychlorinated biphenyls (PCB's), zinc and phosphorus. All U.S.G.S. samples are filtered in the field; nutrient samples are analyzed in Ocala, Florida, while all other parameters are shipped to Atlanta for analysis.

6.2.3 Ecologic Parameters

Independent field investigations were conducted by qualified personnel from the Pinellas County Department of

Environmental Management and by the County's environmental consultant. As the site occupies a highly disturbed tract currently subjected to landfill activities, a comprehensive field study was deemed unnecessary. In essence, some tracts identified as pine flatwoods during the field surveys are today mounds of debris and fill material. Therefore, no attempt was made to develop such an ecologic parameter as a species diversity index; rather, it was the intent of the survey to identify the major plant communities of the site and to observe the indigenous biota, thereby developing cursory judgments on specific populations. From this initial data, evaluations of interspecific relationships, habitat characteristics, and other functional ecologic aspects (e.g., trophic structures, species/substrate dependence, etc.) were evaluated by individuals well versed in the local flora and fauna.

6.2.4 Groundwater

The data from the U.S.G.S. were also utilized for the qualitative evaluation of study area groundwaters. As well data from the plant site were insufficient at the time of this evaluation, observations from nearby wells were employed in the water quality assessment. For water table aquifer evaluation, data from U.S.G.S. well number 275157082401901, located next to 28th Street North approximately 1200 meters south of 110th Avenue North, were used; limestone aquifer water quality assessments are based on data from a St. Petersburg sod farm deep well, U.S.G.S. number 275210082395901, located some 930

meters southeast of the proposed facility site. As was discussed for surface water monitoring, the U.S.G.S. filters all samples in the field; nutrients are analyzed in Ocala; all other parameters are measured in Atlanta. The U.S.G.S. routinely monitors arsenic, cadmium, chromium, lead, mercury, and nitrates in groundwater samples; other parameters commonly evaluated include barium, fluorides, radium, gross alpha particle activity, selenium, silver, 2,4-D, toxaphene, endrin, lindane and methoxychlor.

It was the intent of the quality assessments to correlate the conclusions with those pertinent sections of Chapter 17-3, FAC (i.e., Section 17.3.101) as written prior to the submittal of this application.

6.2.5 Air Quality

The air quality data collected by the Pinellas County Department of Environmental Management, Air and Water Quality Division, were utilized to assess baseline ambient air quality conditions.

County monitoring sites which assess the air quality in the vicinity of the proposed facility are: Airport, Koger, Largo, Oakhurst, and Woodlawn (Figure 2.8.2.a). Nitrogen dioxide, sulfur dioxide and particulates are measured once every six days for twenty-four hours at each of the above locations. Federal reference procedures are used for sample collection and analysis. Bubblers have been temperature controlled since June 1977.

Specific analytical methodologies employed are featured in Section 2.8.2 of this application.

Atmospheric dispersion models represent the state of the art in air pollution and source evaluation studies. To assess the impact on ambient air quality incurred by the commencement of operations at the proposed facility, certain models comprising the EPA UNAMAP-III series were employed. Appendix A of this document provides a complete assessment of air quality impacts imparted by proposed facility air emissions including a discussion of specific model applications.

6.2.6 Geology

Geological cross sections, strata profiles and morphologic discussions were extracted from U.S.G.S. publications and reports concerning the Toytown Landfill (one mile east of the facility site) and from data assembled for a U.S.G.S report on the hydrogeologic characteristics of the facility site.

Topographic data, including flood prone area determinations, were obtained from 7.5 minute quadrangle sheets of the area.

Soils data were compiled from the Soil Conservation Service soil survey of Pinellas County.

6.2.7 Archaeology

The cursory review of historical and cultural sites of local significance is based on literary research. A portfolio of these findings and of pertinent development aspects was sent to the Bureau of Archives and Historic Records; their evaluations and response are presented as Appendix F.

6.2.8 Noise

No noise surveys have been conducted at the facility site. All calculations and assessments featured in Chapters Four and Five of this document are based on theoretical assumptions proposed in Bolt, Beranek and Newman, and Lyons.

6.3 Construction and Operational Monitoring

6.3.1 Sampling Techniques

Subsurface profiles will be determined by a certified contractor employing a standard penetration test. This technique utilizes an open-ended, split barrel sampler driven into the soil to collect samples. At each sample depth the standard 140 pound hammer, attached to the required length of drill rod, will be repeatedly raised and dropped 30 inches to drive the sampler into undisturbed soil. Driving of the sampler is continuous for either 100 blows or for 18 inches of total sampler penetration, whichever occurs first. The number of hammer blows required to drive the soil sampler each 6 inch increment is recorded. The sampler is then dislodged and brought to the surface where soil retained in the split barrel is removed and classified, with a portion sealed in a labeled jar for storage. Samples are stored a minimum of 90 days.

Hydrologic sampling will be conducted by the U. S. Geological Survey. It is anticipated that new well clusters will be drilled at the hyacinth ponds and along 28th Street just northeast of the oxidation/hyacinth ponds (north of well 26, Figure 2.5.4.a). Initially, a "shotgun" sampling regimen will

be employed to assess the baseline concentrations of those parameters cited in Sections 6.2.3.1 and 6.2.3.4; subsequent continual sampling will focus on the following critical parameters: specific conductance, dissolved solids, chloride, total organic nitrogen, ammonia nitrogen and chemical oxygen demand. Surface water sampling will probably be conducted in the proposed stormwater retention pond; the sampling regimen will be essentially the same as discussed for the well clusters. To evaluate the water budget for the proposed sprayfield and stormwater drainage system, U.S.G.S. has proposed that a rain gauge and evaporation pans be situated in pertinent areas; details of specific methodologies are at this time unavailable.

6.3.2 Modifications

Modifications to natural drainage will be indirectly monitored by the hydrologic sampling discussed in the previous section.

6.3.3 Use of Previously Gathered Data

Documentation of data sources are presented throughout the application; data reports supported by the applicant are identified in the reference section.

6.3.4 Surface Waters - See Section 6.3.1.

6.3.5 Physical and Chemical Parameters - See Section 6.3.1.

6.3.6 Ecological Parameters

No programs for monitoring the ecologic impacts of plant installation and operation are proposed.

6.3.7 Groundwater - See Section 6.3.1.

6.3.8 Air

It is proposed that air quality data measured at the airport receptor (approximately 3.22 km north) will adequately represent site conditions; monitoring methods for this receptor are presented in Section 2.8.2.

6.3.9 Geology

Soil boring will be performed as discussed in Section 6.3.1.

6.3.10 Archaeology

No pre- or post-construction archaeological monitoring will occur; as specified in Appendix E no historically or culturally significant areas will be impacted by plant construction or operation.

CHAPTER 7

ECONOMIC AND SOCIAL EFFECTS OF PLANT CONSTRUCTION AND OPERATIONS

7.0 The County has made a commitment to take a leadership role in resource recovery and to provide a system for the disposal of solid waste which is ecologically sound, will recover useable materials, will generate energy from solid waste material and will reduce the amount of land required for the final disposal of the waste. The major economic and social consequences of building and operating the facility are not readily quantifiable but, at the same time, must be weighed against monetized effects. The cost-benefit comparisons at times appear to be irrational with the costs outweighing the measurable benefits, and this represents the County's willingness to pay for these non-quantifiable benefits.

7.1 Benefits

Pinellas County, Florida, has been faced with the problems associated with land disposal for many years. Land prices have risen rapidly, land has become less available, and public resistance and regulatory control have restricted the permitting of additional landfill sites. The County's progressive leaders have seen the need to provide a more efficient method of solid waste disposal. To this end, the County has committed itself to provide a modern resource recovery facility with the following benefits as incentive.

Initially the facility will receive some 530,000 - 570,000 tons of solid waste per year (a capacity of 728,000 tons/year will be provided). Certain forms of non-combustible demolition debris will still go directly to the landfill, however, of the 530,000 - 570,000 tons processed by the facility it is anticipated that less than 3 percent (containing less than 0.2 percent putrescible matter) will ultimately have to be landfilled. This substantial reduction in the waste tonnage represents a corresponding volume reduction and, therefore, a similar savings in the amount of land annually consumed by land-filling operations.

In addition to reducing the amount of land required for solid waste disposal, conversion from landfilling of raw garbage to process residue landfilling will reduce further damage to the water table since the processed material is relatively inert (i.e. less than 0.2 percent putrescible matter) consisting of the burned out material discharged from the grate and flyash having had recoverable materials removed. Landfilling this material will have the added benefit of materially reducing the number of seagulls that are attracted to the site by the presence of raw garbage. The seagulls present a potential hazard to aircraft climbing from or descending to the St. Petersburg-Clearwater International Airport, since the site lies close to the extended main runway centerline of this airport.

As part of the waste disposal program, the plant will generate a minimum of 262 million kilowatt hours of electrical

energy per year (based on the guaranteed tonnage of 530,000 ton/year and 495 KWH/ton net output) which can be related to a reduction in the use of imported crude oil of 742,000 barrels per year. Over a 20 year period, this will amount to a minimum 14.8 million barrels. Although oil prices in the future are difficult if not impossible to predict, at present oil prices this reduction in imported crude oil conservatively will amount to a reduction of approximately \$200 million in foreign spending. This is an extremely conservative figure since no inflation was accounted for.

The recovery and recycling of marketable materials (ferrous metals and non-ferrous metals such as brass and copper) will help to abate the existing scarcity of these resources. Annually a minimum of 33,000 tons of ferrous metals, 1,600 tons of aluminum and 636 tons of heavy non-ferrous material will be recovered from the waste stream. Other materials (such as glass, aggregate material, and segregated non-ferrous metals) will be recovered at such time as is economically feasible.

In addition to providing electrical energy, reducing the requirement for imported oil, and the recovery of processed resources, these recovered resources will generate revenues which will be applied to offset the overall cost of owning and operating the facility. Although initially somewhat more expensive than landfilling, the resource recovery system of disposal, in addition to being an ecologically sound method, could become less expensive than landfilling if energy prices and real estate prices continue to rise.

To quantify the estimated cost benefits of constructing the plant, as opposed to the continued landfilling of solid waste, a cursory analysis was conducted by the County's consultant. This evaluation examined the comprehensive aspects of constructing and operating the plant over a twenty year financing period; such items included tipping or user's fees, bonding costs, recovered materials revenues, energy revenues and general overhead and maintenance. All costs were adjusted to reflect projected inflationary trends. Similiary, landfill costs were rendered through the analysis of existing and expected waste disposal costs, land requirements to meet forecasted demand, and the anticipated price of the necessary land, all in the light of inflationary trends. Based on this evaluation, it is estimated that the total net resource recovery costs to the users through 2001 are estimated to be \$62,000,000, while continued landfill disposal of solid wastes will approximate \$83,000,000 in cost to the users. Therefore, it is anticipated that an overall savings of approximately \$21,000,000 could be realized. Furthermore, at the end of the twenty year finance period Pinellas County will have purchased this complex recovery plant. Assuming proper maintenance, the twenty year old plant may be worth 50 percent of the new facility, whereby the present worth of the County owned plant could enhance the overall savings by approximately \$29,000,000; total cost savings are estimated at \$50,000,000. In addition, the advantages of selecting the resource recovery option on social and environmental factors, while abstract quantities, will certainly impart profound economic benefits.

Since the selected resource recovery system will most likely be one of the first of its kind in the United States (raw solid waste fuel to electricity), it can be expected that its operation will contribute significantly to the advancement of the resource recovery activity in the country. Reception and viewing areas provided for the public will serve as an educational tool to promote the understanding and support for this type of solid waste disposal.

The structure itself will be aesthetically pleasing with extensive landscaping on the ground surrounding the structure (refer to artist's rendering in Figure 3.1.b). The phasing out of raw refuse landfill operations which will be made possible by the existence of the facility will enhance the value and appearance of the area.

Operation of the plant will require a staff of 51 people (8 administrative, 32 operations and 11 maintenance personnel). As it is the intent of management to hire locally whenever possible, the payroll as a result of their employment is a benefit to be counted. An estimated annual payroll of \$765,000 will put \$15.3 million in present worth dollars into the local economy over a 20-year period.

On a short-term basis, the plant construction will provide the benefits of a \$60,000,000 construction project in the area. This will provide jobs for local construction labor, as well as an input to the local economy through the purchase of construction materials and services.

7.2 Costs

The land on which the facility will be built, although presently owned by the County, must be counted as a cost associated with obtaining the facility. Approximately 20 acres of industrial zoned land will be utilized exclusively for the facility and restricted from other uses. At an estimated \$15,000/acre this amounts to \$600,000. It should be noted, however, that this land is presently within the permitted landfill area (Bridgewater Acres Phase I). If landfilling were to continue as is the existing practice, this area would be consumed in approximately two (2) years and its monetary value as industrial land would be severely reduced, since heavy construction on landfilled property is not generally practical.

The cost of site preparation, construction of access roads, construction of the facility, utilities extension and all other legal, administrative and financing costs are estimated to be approximately \$80 million. These costs are expected to be financed by the County. A variety of financing arrangements are being investigated to determine the most suitable method. As a breakdown of cost plus interest is not available at the present time. It is impossible to compute the total cost discounted to present dollar value. The figures below indicate an approximate breakdown of the cost as available at this time.

(all costs subject to minor change during final negotiations and bond sales)

	<u>\$ x 1,000</u>
Contractor Cost	\$58,649
Permits & Fees	1,801
Additional County Costs	<u>2,125</u>
TOTAL CAPITAL COSTS	62,575 ^a
Bond Costs	<u>14,642</u>
TOTAL BOND ISSUE	\$77,217

^a contains escalation allowances

In addition to the initial cost of the facility, the County will pay the operator of the facility an annual operating and maintenance fee of \$3,550,000 (based on 530,000 tons/year and 1978 costs). These costs will be adjusted periodically, in accordance with certain selected price indices, during the duration of the operating agreement. It is difficult if not impossible to estimate the present value of the operating and maintenance over the full 20 year period.

The facility will be constructed at the present landfill location. Traffic volume may be expected to increase since once the facility is operational, all of the County's waste can be expected to be delivered there. At present, approximately 26 to 32 percent of the refuse generated in the County is disposed of at this site. During the construction period there will also be an increase in traffic at the site, however, this will be of relatively short duration (32 months) and the traffic increase will generally be at the access to the site (118th Avenue) which is not a through road to the east.

As mentioned in Section 5.2.3, ecological losses, i.e. displacement of wildlife and disruption of environmental services, will be minimal and therefore have not been included in the costs of the project.

Table 7-1 summarizes the cost-benefit comparisons for the Resource Recovery Project.

TABLE 7-1
COST - BENEFIT SUMMARY

<u>RANGE</u>	<u>COUNTY</u>	<u>UOP</u>	<u>PUBLIC AT LARGE</u>
		<u>COSTS</u>	
Short range	Permits, insurance and other fees - \$1,801,500. Additional county costs for adjunct facilities - \$2,125,700	Pre-construction monies prior to progressive payments to County.	
Long range	Annual debt service on bond issue - \$7 million/yr. Initial increase in cost of solid waste disposal (estimated to be less than \$1.00/household per month above current rates - initial year). Total tipping fee revenues \$4,970,000/yr initially Operating fee to UOP (\$3,904,000/yr initially). Additional County costs (\$1,460,000/yr initially)	Maintenance and operation of Resource Recovery Facility (\$3,904,000/yr initially)	

TABLE 7-1 (con't)

<u>RANGE</u>	<u>COUNTY</u>	<u>UOP</u>	<u>PUBLIC AT LARGE</u>
Short range	Reduction in seagull hazard at St. Petersburg/Clearwater International Airport	Profit fees associated with rewarding of \$58.6 million construction project.	
	Allows "phasing-out" of numerous small landfill operations.	Public awareness of capabilities of firm to construct resource recovery facility.	
	Jobs created in County for \$58.6 million construction project.		
Long range	Efficient disposal of solid waste.	Revenue provided by 20 year operating contract.	Reduction in crude oil imports displaced by solid waste fuel and resulting reduction in foreign payments
	Large reduction in land requirements for solid waste disposal.	Marketing advantage of having a domestic plant in operation for potential clients' observation.	Reduction in habitat of pathogenic vectors.
	This method of disposal as compared with continued landfill operation will likely result in long term savings.		Prevention of further damage to the surficial aquifers.
	Less public opposition to proposed method than to continuation of landfill operation.		Facility will be used as an educational facility to inform visitors of the proposed method of resource recovery.
	Payrolls into economy (\$765,000/yr initially)		

TABLE 7-1 (con't)
 BENEFITS (con't)

RANGE	COUNTY	UOP	PUBLIC AT LARGE
Long range (con't)	<p>Revenues derived from sale of electricity to FPC (\$5,745,000/yr initially)- will likely increase due to inflationary forces.</p> <p>Revenues derived from materials and other revenues (\$1,042,000/yr initially)- will likely increase due to inflationary forces.</p> <p>Tipping fees from users of the facility (\$4,970,000/yr initially) - will be buffered from inflation due to offset effect of revenue increases</p>		

NOTE: All costs subject to minor change as a result of final negotiations and bond sales.

CHAPTER 8

ALTERNATIVE ENERGY SOURCES AND SITES

8.1 Assessments of Alternative Sites

The primary purpose of constructing the type facility described in Chapter 3 of this application is to dispose of solid waste material generated in Pinellas County. The site selected is located in the same area as the existing landfill operation on land to which the County holds title. Alternative methods of solid waste disposal were investigated to ascertain the most effective plan. Most systems investigated would have been sited at the same location as the site presently selected for the resource recovery facility. The selected site is centrally located within the County which makes it logistically effective for the delivery of solid waste. The availability of land will provide proximate landfilling for many years since the volume of solid waste will be greatly reduced by combustion in the boilers.

An alternative solid waste disposal method that was investigated consisted of shredding and classifying equipment for the preparation of a refuse derived fuel (RDF) for combustion in some existing boiler. This would effectively have been power generation at an alternate site, however no firm market for the RDF was obtained due to incompatibility of existing equipment at local power plants and other sizeable boiler installations. Additional freight to more distant locations caused the project to become economically less viable.

8.2 Alternative Fuel Analysis

As mentioned in 8.1 above, the electrical generating facility would not exist except for the fact that it provides for the disposal of the County's solid waste. For this reason, no investigation was made into alternative fuels for the generation of electrical power. The electricity generated will, however, replace power which is presently generated by other type fuels (fossil and nuclear fuels).

As a means of comparison, the benefit in oil saved is substantial, especially if expressed in terms of imported crude oil. Processible solid waste will produce an average gross generation of 550 KWH/ton. Although "in-plant" consumption of electrical power will reduce the net output to approximately 495 KWH/ton, this represents roughly 1.4 times the net electrical energy available from 1 barrel of crude oil.

On this basis and an assumed minimum annual throughput of 530,000 tons, a reduction of 742,000 barrels/year will be realized. Over the 20 year project period this will amount to 14.8 million barrels.

8.3 Reasons for Selecting Final Site and Fuel

Site Selection

1. Centrally located within the County on County owned land.
2. Close proximity to existing Florida Power Corporation substation.

3. Contiguous with existing County landfill operation allowing efficient routing of nonprocessable material from the scales to the landfill as well as affording a short haul distance for the disposal of boiler residue.

Fuel Selection:

1. The disposal of the solid waste material (which is the fuel) was the problem. The powerplant was selected as the most effective solution to the problem and no other fuels were considered.

CHAPTER 9

PLANT DESIGN ALTERNATIVES

The selection of the design of the facility was based upon a two part procurement process. Initially a request for qualifications (RFQ) was made available to any firm wishing to submit its qualifications for appraisal by the County and its agents. Twenty-two responses were made to the RFQ from which seven firms were selected as fully qualified to design, construct and operate a facility for Resource Recovery in Pinellas County. A second document, the Request for Proposals (RFP) was sent to the seven qualified firms asking for the type of facility they would propose to build and operate in the County. Prices for the facilities and the operation were also submitted in the proposal. Detailed analysis was made of each proposal with primary emphasis upon the following areas:

1. Economic Feasibility
2. Technical soundness
3. Environmental acceptability
4. Level of experience

Site visitation trips were made by the evaluation team to several domestic and European installations that had been constructed by the selected firm.



Since the design of the system is the culmination of many years of experience in solid waste systems by the selected firm, UOP, Inc., no alternatives were selected on the basis of electric generation alone.

REFERENCES

REFERENCES

- Wiener, F.M. and D. N. Keast, "Experimental Study of the Propagation of Sound Over Ground." J. Acoust. Soc. Am. 31, 1959.
- Embleton, T., "Sound Propagation in Homogeneous Deciduous and Evergreen Woods." J. Acoust. Soc. Am. 35, 1963.
- Lyon, Richard H., Lectures in Transportation Noise, MIT Press, 1973.
- U. S. Environmental Protection Agency, Noise from Construction Equipment and Operating Building Equipment and Home Appliances, prepared by Bolt, Beranek and Newman, 1971.
- American Meteorological Society, Lectures on Air Pollution and Environmental Impact Analyses, 1975
- PEDCO-Environmental, Air Quality Modeling in Hillsborough, Pinellas and Polk Counties, Florida, Volumes I and II, prepared for the U.S. E.P.A. and F.D.E.R., 1976.
- Cavender, James H., Davis S. Kircher and Alan J. Hoffman, Nationwide Air Pollutant Emission Trends 1940-1970, Publication No. AP-115, U.S. E.P.A., 1973.
- National Climatic Center, "Local Climatological Data: Hourly Observations, 1970-1974 for Tampa, Fla.", U.S. Department of Commerce, NOAA, Environmental Data Service, Asheville, N.C.
- U.S. Environmental Protection Agency, User's Manual for Single-Source (CRSTER) Model, E.P.A.-450/2-77-013, 1977.
- U.S. Environmental Protection Agency, User's Guide for the Climatological Dispersion Model, EPA-R4-73-024, 1973.
- U.S. Environmental Protection Agency, Addendum to User's Guide for Climatological Dispersion Model, EPA-450/3-77-015, 1977.
- U.S. Environmental Protection Agency, "User's Guides to the Interactive Versions of Three Point Source Dispersion Programs: PTMAX, PTDIS and PTMTP", Preliminary Draft, 1973.
- U.S. Environmental Protection Agency, Workbook of Atmospheric Dispersion Estimates, Publication No. AP-26, 1974.

FIGURE 16



POINT ROSES FOR TSP, 1985
(FROM CDMQC)

conditions, featured in Figures 5 and 6); a histograms illustrating area, background and point source contributions to the total TSP and SO₂ concentrations are presented in Figure 17.

PREVENTION OF SIGNIFICANT DETERIORATION (PSD)

To satisfy the requirements of Part 52 of the 1977 Amendments to the Clean Air Act as promulgated on June 19, 1978, an assessment of PSD increment consumption by the proposed resource recovery and all major sources permitted since January 6, 1975 was completed. The area and point source emissions inventory (CDMINP file) utilized for the CDMQC model was submitted to the Florida Department of Environmental Regulation (Tampa), the Pinellas County Department of Environmental Management and the Hillsborough County Environmental Protection Commission so that their guidance concerning the selection of post-baseline permitted facilities would be received. Based on such input, the following sources as depicted in Figure 18 have been designated as being relevant sources:

- Florida Power, Anclote - 1 unit, SO₂ and TSP
- Florida Power and Light, 2 units at Willow Point - SO₂ and TSP
- Nord Southern Dolomite - 1 unit, SO₂ only
- Gardiniers - 1 unit, SO₂ only
- Chloride Metals - 1 unit, SO₂ only
- Tampa Electrical, Big Bend - 1 unit, SO₂ and TSP

- U.S. Environmental Protection Agency, Guidelines for Air Quality Maintenance Planning and Analysis Volume 10 (Revised): Procedures for Evaluating Air Quality Impact of New Stationary Sources, EPA-450/4-77-001, 1977.
- U.S. Environmental Protection Agency, Interim Guideline on Air Quality Models, OAQPS No. 1.2-080, 1977.
- Walden Research Division of ABCOR, Inc., Handbook for UNAMAP, 1976.
- Cheremisinoff, Paul N. and Angelo C. Morresi, "Predicting Transport and Dispersion of Air Pollutants from Stacks," Pollution Engineering, 1977
- U.S. Air Force (USAFETAC) Air Weather Service (MAC), "Revised Uniform Summary of Surface Weather Observations", MacDill AFB, Florida, 1941-1972.
- Pinellas County Planning Department, Research & Special Studies Division, Population Forecasts, August 19, 1977.*
- Pinellas County Planning Department, Pinellas County Population Estimates 1970-1977, May, 1977.*
- Conery, Charles, U.S. Department of Agriculture, Soil Conservation Service (Largo), personal communication to K. S. Frahn, May 3, 1978.
- Chen, Chih Shan, The Regional Lithostratigraphic Analysis of Paleocene and Eocene Rocks of Florida, No. B45, Florida Board of Conservation, Division of Geology, Tallahassee, Florida, April 1965.
- Briley, Wild & Associates, Inc., Central Pinellas County 201 Facility Plan, Task I-IV (draft), 1978.*
- Vanatta, Earl S., Sr., et al, Soil Survey of Pinellas County, Florida, U.S. Department of Agriculture Soil Conservation Service, September 1972.
- Heath, Ralph C. and Peter C. Smith, Ground Water Resources of Pinellas County, Florida, Florida Geological Survey, Report of Investigations No. 12, Tallahassee, Florida, 1954.
- Cooke, C. Wythe, Geology of Florida, No. B29, Florida Department of Conservation, Geological Survey, Tallahassee, Florida, September 1945.
- John E. Moore, J.S. Geological Survey, Water Resources Division, Written Communication to D. F. Acenbrack, February 4, 1977.

*Prepared for applicant

- Puri, Harbans S. Stratigraphy and Zonation of the Ocala Group, Florida Geological Survey Bulletin No. 38, Tallahassee, Florida, November 1957.
- Cherry, R.N., J.W. Stewart, and J.A. Mann, General Hydrology of the Middle Gulf Area Florida, Florida Geological Survey, Report of Investigation No. 56, Tallahassee, Florida, 1970.
- Hutchinson, C.B., Stewart, J.W., Geohydrologic Evaluation of a Landfill in a Coastal Area, St. Petersburg, Florida, (Water Resource Investigations 77-78), U.S. Geological Survey, February 1978.
- U.S. Geological Survey, Map of Flood-Prone Areas, 1973.
- Air Pollution Control Association, Recognition of Air Pollution Inquiry to Vegetation, Pittsburgh, 1970.
- American Industrial Hygiene Association, Air Pollution Manual - Part 1, 1960.
- Bishop, Ernest W., and Lawrence L. Dee, Jr., Rocks and Minerals of Florida: A Guide to Identification, Occurrence, Production and Use, Florida Geological Survey, Special Publication No. 8, Tallahassee, 1961.
- Davis, John H., Jr., The Peat Deposits of Florida, Their Occurrence, Development and Uses, Florida Geological Survey, Geological Bulletin No. 30, Tallahassee, Florida, 1946.
- Eco Impact, Inc., An Ecological Reconnaissance of Clearwater Bay Estuarine Ecosystem, Gainesville, Florida, 1973.
- Pinellas County Planning Department, Zoning Maps for Pinellas County, 1978.*
- U.S. Environmental Protection Agency, Guideline for Evaluating the Adverse Impact of Cooling Water Intake Structures on the Aquatic Environment, 1977
- U.S. Environmental Protection Agency, Biological Field and Laboratory Methods for Measuring the Quality of Surface Waters and Effluents, EPA-670/4-73-001, 1973
- UOP Solid Waste Systems, "Proposal for Solid Waste Recovery Program for Pinellas County, Florida", 1977.*

* Prepared for applicant

Pinellas County, Florida, "Request for Proposals" for a Solid Waste Resource Recovery Program, prepared in July 1977.*

Henningson, Durham and Richardson, Solid Waste Energy and Resource Recovery for Pinellas County, Florida, prepared for the Board of County Commissioners, Pinellas County, Florida, May 1976.*

Wolverton, B.C. and R.C. McDonald, Water Hyacinths for Upgrading Sewage Lagoons to Meet Advanced Wastewater Treatment Standards: Parts 1 and 2. NASA Technical Memoranda TM-X-72729 and TM-X-72730, October 1975 and 1976, respectively.

Texas Department of Health Resources, Water Hyacinth Culture for Wastewater Treatment, Austin, 1976.

* Prepared for applicant

APPENDIX A

ASSESSMENT OF AIR QUALITY IMPACTS RESULTING
FROM THE OPERATION OF THE PROPOSED SOLID WASTE
RESOURCE RECOVERY FACILITY FOR PINELLAS COUNTY, FLORIDA

APPENDIX A

ASSESSMENT OF AIR QUALITY IMPACTS
RESULTING FROM THE OPERATION OF
THE PROPOSED SOLID WASTE RESOURCE RECOVERY
FACILITY FOR PINELLAS COUNTY, FLORIDA

SEPTEMBER 1978

PREPARED BY
HENNINGSON, DURHAM & RICHARDSON

PURPOSE

It is the intent of this air quality analysis to identify the nature and characteristics of air emissions generated by the proposed solid waste resource recovery facility for Pinellas County and their impacts on the Ambient Air Quality Standards (AAQS) for total suspended particulate (TSP) and sulfur dioxide (SO₂) concentrations. The calculated consumption of Prevention of Significant Deterioration (PSD) increment by this facility and those pertinent major air pollution sources permitted since January 6, 1975, will also be estimated.

METHODOLOGY

° Atmospheric Dispersion Models -

The application of dispersion models represents the state of the art in air pollution and source evaluation studies. To assess the impact on ambient air quality incurred by the commencement of operations at the proposed facility, certain models comprising the EPA UNAMAP-III series were employed. Specifically, the following applications were conducted:

1. PTMAX - The maximum allowable emission rates for both SO₂ and TSP from the resource recovery facility were input; the areas of maximum concentration for a variety of wind speeds and atmospheric stabilities were thus determined.

The derived calculations of distances to maximum concentrations were cardinal factors in the selection of receptor ring distances for the CRSTER model.

2. CRSTER - This single source model was utilized to delineate the spatial and temporal distribution of both SO₂ and TSP concentrations on a specific receptor array for a one year period. Pollutant interactions of the resource recovery facility with those sources permitted since January 6, 1975, were also estimated via the CRSTER model. These were rendered by inputting each other facility's emission parameters and establishing a receptor array which coincided with the "hot spots" from the resource recovery facility. Finally, CRSTER was employed to demonstrate the potential TSP emissions from the facility (i.e., without electrostatic precipitators) as well as to evaluate the effectiveness of employing four versus three electrostatic precipitator fields; this latter effort was conducted as a part of the Best Available Control Technology (BACT) review, featured in Appendix C.

3. CDMQC - The Climatological Dispersion Model (CDM) was expanded to include a source contribution mode, internal calibration and the Larsen statistical analysis for the conversion of averaging times. This model was utilized to identify the long-term pollutant concentrations at selected receptors originating from point and area sources located in the study area. Two types of receptors were selected for

analysis. First, those air quality monitoring sites maintained by the Pinellas County Department of Environmental Management were employed for model calibration; second, receptors were specified at those areas which the CRSTER model identified as probable maximum concentration areas of pollutants generated by the resource recovery plant.


4. PTMTP - This multiple source, Gaussian plume model was utilized to demonstrate short-term pollutant concentrations incurred by the interaction of the proposed facility and those major sources permitted since January 6, 1975, under probable, worst case meteorologic conditions. Specifically, actual weather data were judiciously manipulated to simulate maximum likelihood of plume trapping atmospheric conditions; prevailing wind directions were input so as to illustrate the maximum interaction of the proposed facility and the post-baseline sources located upwind.

5. PTDIS - Using maximum emission rates for SO₂ and TSP, the model calculates selected ranges of ground level concentrations when specific meteorological input parameters are given. A single emitter is considered for each pollutant. The model uses the Gaussian and Briggs plume rise equations.

° Emissions Inventories -

The areal coverage of the emissions inventory for CDMQC model input was determined through analysis of local meteorologic conditions and model limitations (with distance), interpretation of historical reports (PEDCO, etc.), and discussion with state and private air quality modelers. Figure 1

FIGURE 1



AREAL COVERAGE OF CDMINP FILE



AREA INVENTORIED FOR AREA AND POINT SOURCES



AREA INVENTORIED FOR POINT SOURCES ONLY

identifies those areas which were evaluated for point and area sources.

All source emissions data for the 1976 inventory were obtained at the Southwest District Office of the Florida Department of Environmental Regulation. Specifically, emission rates for TSP and SO₂ and pertinent stack parameters were laboriously extracted from official agency forms¹ located in the air quality files. As a substantial amount of necessary data was not available from these sources, further consultation with agency personnel was sought. The initial compiled inventory was then contrasted and compared with the information listed in the 1976 FDER "Air Emission Source Permit Inventory" (API); 1977 update material was being processed at that time by the DER staff and was also included in the evaluation for inventory completeness. Thus, the emissions data listed in the 1976 inventory (CDMINP file) represent the latest permitted emission rate for each source's respective pollutants.

To estimate ambient air quality once the resource recovery facility becomes operational, it is necessary to project those emission rates in the 1976 CDMINP file to reflect future flows. As the scope of the air quality analysis for the PPSC precludes detailed evaluation of emission changes, those figures presented in Appendix "A" of the PEDCO report were consulted. In this study emission rates

¹ FDER "Application for Operating an Air Emission Source", and USEPA "Air Pollutant Emissions Report".

were given for 1973, 1975, 1980 and 1985. The method PEDCO employed to project emission rates is as follows:

Projected Emission Rate = Base Year Emission Rate
x Growth Factor x Control
Factor

Where: Growth Factor = Ratio of Future Production
Rate to Existing Rate

Control Factor = Ratio of Projected Emissions
per Unit Production to
Existing Emission per Unit
Production

Unfortunately, the PEDCO emissions inventory differs from the one developed for this analysis, consequently direct utilization of PEDCO projections was impossible. Therefore, an analysis of emission rate changes in the PEDCO report from 1975 to 1985 was undertaken. The overall plan for arriving at future emissions was to extrapolate those PEDCO rates of change for a particular type of source (e.g., power plant, cement batch plant, etc.) to identical or similar sources in Pinellas emissions inventory. In some cases there was good correspondence between the inventories; as a whole, though, they were markedly different. It was further decided to employ the PEDCO 1985 projections for this analysis; by this, our future emissions inventory is a 1985 projection. The 1976 and 1985 CDMINP files employed in the CDMQC model runs are featured in Appendix C.

° Calibration Data -

Air quality monitoring data were procured from the Pinellas County Department of Environmental Management, Air

and Water Quality Division. TSP and SO₂ data spanning a minimum one year period from the Koger, Airport, Oakhurst and Largo receptor sites (Figure 2) were subjected to log normal analysis and input to the CDMQC model. More detailed discussions of specific monitoring techniques and data summaries are featured in Section 2.8.2 of the PPSC document. It should be noted that the listings for SO₂ concentrations on the raw data sheets were frequently less than 5.0 ug/m³; as bubbler detection limits are generally assumed to approximate 5.0 ug/m³, all entries below this critical level were interpreted as 5.0 ug/m³. Consequently, SO₂ calibration data is somewhat inflated.


Based on technical guidance from state, municipal and private air quality principals, and on the results of an initial, uncalibrated CDMQC model run, background values of 40.0 and 0.0 ug/m³ were utilized for TSP and SO₂, respectively.

° Meteorology Data -

Hourly meteorologic data covering the five year 1970-74 observation period for Tampa WSO were input to CDMQC; 1974 data from that receptor were utilized for all CRSTER model runs. To further delineate the extraordinary effects of marine influences on the Pinellas peninsula, the data from MacDill AFB Weather Station and the St. Petersburg/Clearwater Airport were employed in the evaluation of model results.

FIGURE 2

LOCATION OF PROPOSED FACILITY
AND PINELLAS COUNTY AIR QUALITY MONITORS



LOCAL METEOROLOGICAL EFFECTS

Pinellas County is situated on a peninsula and is thus subject to a pronounced land/sea breeze effect as well as other local marine effects typical of a subtropical environment. Standard pollution models do not treat these effects. However, both the long term climatology and daily meteorological records do reflect the diurnal variations produced by these local phenomena as long as the observing stations used are within the same local regime as the pollution sources being modelled. Both the Tampa National Weather Service observing stations (surface and upper air) and the USAF Weather Station at MacDill AFB do reflect the local effects rather well. While these effects do show up on the diurnal mixing heights, diffusion calculations for a plume crossing a coastline are undoubtedly subject to considerable error. Lyons¹, and others, have studied the shoreline diffusion effects in the vicinity of the Great Lakes and have observed sharp deviations in stabilities in a shoreline environment. One would expect that these effects would be more severe in the Great Lakes region due to the larger temperature differences between the water and land surfaces. In the Tampa Bay region, the relatively shallow bays act as a heat source during night time hours which serves to inhibit the establishment of strong surface inversions that trap plumes. During

¹ Lyons, W.A., 1975, Turbulent Diffusion and Pollutant Transport in Shoreline Environments, Lectures on Air Pollution and Environmental Impact Analyses, American Meteorological Society, Boston, Massachusetts, 1975.

daytime under sunny conditions, strong heating over land causes a pronounced sea breeze effect which converges over the peninsula resulting in convective instabilities which elevate the mixing height rather quickly after onset of the seabreeze. Both of these effects serve to enhance pollutant dispersion. The only condition which could result in fumigation would be under clear night time conditions with near calm winds where strong land surface cooling produces subsidence over the peninsula. The land breeze generated would then trap the plume until it moved over warmer coastal waters where convective activity would elevate and disperse it. Under calm prevailing synoptic wind conditions, the plume would drift toward the bay and fumigation would be limited to a relatively unpopulated coastal marsh area upon onset of the land breeze effect. If a light prevailing synoptic wind with an easterly component were superimposed on these conditions, plume fumigation within a few hundred meters west of the plant site would be possible. However, advection of air from over warm water sources would produce positive buoyancy forces once overland; thus the mixing depth would increase and the fumigation potential, if any, would be limited to a relatively short distance from the source.

EXISTING CONDITIONS - CDMQC

- ° Calibration -


The receptor data discussed in the methodology section were statistically evaluated and input to CDMQC. For

each model run the observed (theoretical) concentration for particulate matter exceeded the calculated amount; thus default values (slope = 1, intercept = 0) were employed in all model calculations.

° Results -

The calculated concentrations of TSP and SO₂ at selected receptors are depicted in Figures 3 and 4, respectively; those receptors designated as "hot spots" correspond to areas of maximum pollutant concentration resulting from proposed resource recovery plant emissions. These isopleths and the pollutant roses in Figures 5 and 6 point out the substantial influence of emission sources located outside of Pinellas County. This phenomenon is due to the easterly orientation of prevailing winds (see Figure 2.6.8) and the profusion of major point sources on the eastern shore of Tampa and Hillsborough Bays (e.g., Big Bend - Port Sutton areas, etc.). Further analysis of source contributions at selected receptors (Table 1 and Figure 7) reveals the predominating impacts of point sources to SO₂ concentrations and background origins to TSP levels; the relative insignificance of area source contributions to ambient air pollution is apparent for both pollutants. With regard to specific major point sources, Tables 2 and 3, respectively, identify those emitters contributing the largest portion of the SO₂ and TSP increment to the Koger and Airport receptors. These


FIGURE 3



ESTIMATED AVERAGE ANNUAL¹ TSP CONCENTRATION—1976

¹ANNUAL ARITHMETIC MEAN (FROM CDMQC)



FIGURE 4



ESTIMATED AVERAGE ANNUAL¹ SO₂ CONCENTRATION-1976



¹ANNUAL ARITHMETIC MEAN (FROM CDMQC)

FIGURE 5




POINT ROSES FOR SO₂, 1976
(FROM CDMQC)

FIGURE 6



POINT ROSES FOR TSP, 1976
(FROM CDMQC)

FIGURE 7



HISTOGRAMS OF RELATIVE CONTRIBUTION OF TSP AND SO₂
TO SELECTED RECEPTORS, 1976

(FROM CDMQC)

TABLE 1

RELATIVE CONTRIBUTION OF TSP AND SO₂
TO SELECTED CDM MODEL RECEPTORS, 1976

RECEPTOR	UTM Coord.		Point Sources ug/m ³	Area Sources ug/m ³	Background ug/m ³	Total
	X	Y				
Oakhurst	323.14	3080.59				
TSP			0.8	0.0	40.0	40.8
SO ₂			13.4	0.0	0.0	13.5
Largo	323.55	3088.85				
TSP			0.8	0.1	40.0	41.0
SO ₂			9.9	0.0	0.0	9.9
Koger	339.85	3082.74				
TSP			1.4	0.1	40.0	41.5
SO ₂			16.2	0.0	0.0	16.3
Airport	333.50	3087.73				
TSP			1.1	0.3	40.0	41.4
SO ₂			12.4	0.0	0.0	12.5
Woodlawn	336.49	3074.28				
TSP			0.7	0.0	40.0	40.7
SO ₂			12.9	0.0	0.0	13.0
Clearwater	329.23	3095.00				
TSP			1.4	0.1	40.0	41.5
SO ₂			10.1	0.0	0.0	10.2
Site	335.26	3084.39				
TSP			1.1	0.1	40.0	41.2
SO ₂			12.8	0.1	0.0	12.9

TABLE 2

TSP AND SO ₂ CONTRIBUTIONS OF MAJOR SOURCES AT THE KOGER RECEPTOR, 1976			
	Source	Contribution ug/m ³	Percent of Total Calculated Pollutant Concentration*
◦ TSP	-Florida Power Corp., Bartow Pipeline Heater	0.49	1.19
	-Florida Power Corp., Higgins Unit #2	0.20	0.48
◦ SO ₂	-Florida Power Corp., Bartow Unit #1	1.76	10.8
	-Florida Power Corp., Bartow Pipeline Heater	1.74	10.7
	-Florida Power Corp., Bartow Unit #3	1.42	8.7
	-Tampa Electric Co.,** Big Bend Unit #1	1.37	8.4
	-Tampa Electric Co.,** Big Bend Unit #2	1.37	8.4
	-Florida Power Corp., Bartow Plant	1.34	8.2
	-Tampa Electric Co.,** Gannon Unit #6	0.87	5.4

* Including all area, point and background sources.

**Distant sources; indiscriminate acceptance of respective contributions for these stacks may compromise model limitations.

TABLE 3

TSP AND SO ₂ CONTRIBUTIONS OF MAJOR SOURCES AT THE AIRPORT RECEPTOR, 1976			
	Source	Contribution ug/m ³	Percent of Total Calculated Pollutant Concentration*
o TSP	-Florida Power Corp., Higgins Unit #2	0.35	0.84
o SO ₂	-Tampa Electric Co.,** Big Bend Unit #2	1.22	9.76
	-Tampa Electric Co.,** Big Bend Unit #1	1.22	9.79
	-Tampa Electric Co.,** Gannon Unit #6	1.21	9.73
	-Florida Power Corp., Bartow Unit #1	0.68	5.45
	-Florida Power Corp., Bartow Unit #3	0.67	5.38
	-Tampa Electric Co.,** Big Bend Unit #3	0.64	5.12

* Including all area, point and background sources.

**Distant sources; indiscriminate acceptance of respective contributions for these stacks may compromise model limitations.

data, along with the complete source contribution listing, emphasize the significance of fossil fuel power plant emissions in determining SO₂ levels in the Tampa Bay region. In actuality, it can be stated that most of the SO₂ load calculated for the proposed facility site can be traced to the Florida Power Bartow Plant and the Tampa Electric Big Bend Plant. This latter facility, situated on the eastern shore of Tampa Bay, emits the largest inventoried volume of SO₂ in the region. Another large SO₂ source, the Florida Power Anclote Plant, emits that pollutant at a rate of 1631.9 grams per second; however, the northwesterly orientation and considerable distance (over 35 km) from that power plant to the proposed facility, coupled with actual meteorologic conditions limit the impact of the Anclote emissions on the study area. Point sources contributing the most to TSP concentrations at the evaluated receptors are the Florida Power Higgins Unit #2, and the Florida Power Bartow Pipeline Heater.

THE PROPOSED RESOURCE RECOVERY PLANT

° General Specifications -

The design proposed for Pinellas County employs a two boiler, 1050 tons per day (2100 TPD combined) mass fire unit for the incineration of solid waste, the production of steam and the generation of electricity; a more detailed discussion of facility specifications is provided in Chapter 3 of the PPSC document. With regard to facility input parameters

to the atmospheric dispersion models, Table 4 identifies the stack and emission characteristics utilized. It was determined that for the Prevention of Significant Deterioration (PSD) and Ambient Air Quality Standard (AAQS) analyses, selective emission rates should be applied for calculations of various averaging time pollutant concentrations. Specifically, as augmented by Table 4:

<u>Increment Determination</u>	<u>Selected Facility Emission Rate (GM/SEC)</u>
TSP - Annual ¹	7.50
TSP - 24 Hour ¹	16.51
TSP - Potential 24 Hour & Annual	499.71
SO ₂ - Annual ¹	22.55
SO ₂ - 3 Hour and 24 Hour ¹	31.12

The emissions of the proposed solid waste resource recovery facility will in no way impact air quality in a Class I maintenance area; the most proximal such area is the Chassahowitzka National Wildlife Refuge situated over fifty miles to the north of the study area.

° Results -

1. PTMAX - The fundamental guidance for selection of CRSTER model receptor ring distances was provided by PTMAX calculations; the results for the various emission characteristics listed above were subjectively evaluated with respect to local topographic and meteorologic factors. From this,

¹ Allowable

TABLE 4

EMISSION CHARACTERISTICS OF VARIOUS CRSTER MODEL RUNS	
	Emission Rate GM/Sec.
Maximum TSP, Controlled	16.51
Average TSP, Controlled	7.50
Maximum TSP, Uncontrolled	499.71
Maximum SO ₂	31.120
Average SO ₂	22.55
Stack Data	
Height (Meters)	49.07
Diameter (Meters)	2.74
Maximum Gas Exit Velocity (Meters/Sec.)	38.16
Average Gas Exit Velocity (Meters/Sec.)	27.72
Exit Gas Temperature (Degrees K)	521.89
Ring Distances (KM) for Selected CRSTER Runs	
TSP, Annual - 0.85, 1.60, 3.00 and 5.00 KM	
TSP, 24 Hour - 0.90, 1.80, 3.50 and 6.50 KM	
SO ₂ , 3 Hour - 0.90, 1.85, 3.00 and 5.00 KM	
SO ₂ , 24 Hour - 0.90, 1.85, 3.00 and 5.00 KM	
SO ₂ , Annual - 0.85, 1.60, 2.00 and 5.00 KM	

those receptor ring distances shown in Table 4 were input to the CRSTER model runs.

2. CRSTER - The maximum pollutant concentrations and affected receptor locations for each CRSTER run is featured in Table 5. With respect to these modeling results, the following conclusions relative to the emission dispersal characteristics of the proposed facility are offered:

- Maximum SO₂ and TSP concentrations occurred primarily from 1.0 to 6.5 kilometers out from the stack site; maximum concentrations at more distant receptors were infrequent (less than 11 days per 365 days, average; no receptor at such a distance recorded a maximum in the top 50 readings for any model run).
- Maximum concentrations were recorded primarily during unstable meteorologic conditions; that is, the highest concentrations for SO₂ and TSP were noted during the noon to evening period during the summer and fall months. This phenomenon is probably attributable to the high exit temperature of the facility emissions and their ability to penetrate such stable situations as a temperature inversion layer. The mixing of exit gases in a more unstable atmosphere is characterized by both upward and downward plume dispersal, hence the recording of maximum concentrations during these periods.

TABLE 5

SYNOPSIS OF CRSTER MODEL RUNS				
	Max (UG/M ³)	Distance (KM)	Direction (°)	Allowable PSD Incr. UG/M ³
TSP, Max. Controlled 24 hour	1.69	2.0	90	37
TSP, Avg. Controlled Annual	0.09	3.0	90	19
TSP, Max. Uncontrolled 24 hour	51.03	2.0	90	--
Annual	4.32	3.8	90	--
SO ₂ , Max. 3 hour	12.82	1.9	270	512
24 hour	3.21	3.0	90	91
SO ₂ , Avg. Annual	0.29	2.0	90	20


- The maximum values recorded for the resultant concentration from facility emissions are quite small and, by themselves, do not violate the allowable PSD increment for any situation with each pollutant.

Figures 8 through 12 illustrate the isopleths of maximum concentration for each pollutant and averaging time.

1985 CONDITIONS - CDMQC

Predicated on the assumptions of emissions inventory for 1985 conditions a significant reduction in ambient SO₂ concentrations (ave. 3.31 ug/m³ per receptor) was calculated for the Pinellas peninsular; likewise a decrease in TSP levels was also estimated although the magnitude of the reduction was less significant (ave. 0.39 ug/m³ per receptor). Figures 13 and 14, respectively, feature isopleths of TSP and SO₂ concentrations for 1985 conditions. The overall trend in pollutant reduction is geared on the abatement of SO₂ emissions from fossil fuel power plants. Still, though, while the increment contribution by power plants is consistently lessened, the relative contribution (percent of total) of SO₂ by such facilities is somewhat elevated (see Tables 6 and 7). In addition, the importance of sources on the eastern shore of Tampa Bay is substantially enhanced. Figures 15 and 16 illustrate the orientation of pollutant magnitude towards those sources in Hillsborough County (compare these figures with those pollutant roses for 1976

FIGURE 8
CALCULATED MAXIMUM ANNUAL MEAN TSP
CONCENTRATION ($\mu\text{g}/\text{m}^3$), TO 5.0 KILOMETERS





 0.04 - 0.09 $\mu\text{g}/\text{m}^3$

FIGURE 9
CALCULATED MAXIMUM 24-HOUR TSP CONCENTRATION ($\mu\text{g}/\text{m}^3$)





 1.1 - 1.7 $\mu\text{g}/\text{m}^3$

FIGURE 10
CALCULATED MAXIMUM 3-HOUR SO₂ CONCENTRATION
(ug/m³) TO 5.0 KILOMETERS




 9.0 - 12.0 ug/m³

FIGURE 11
CALCULATED MAXIMUM 24 HOUR SO₂ CONCENTRATIONS,
ug/m³ TO 5.0 KILOMETERS





FIGURE 12
CALCULATED MAXIMUM ANNUAL MEAN SO₂ CONCENTRATION
(ug/m³), to 5.0 KILOMETERS





 0.16 - 0.29 ug/m³


FIGURE 13



ESTIMATED AVERAGE ANNUAL¹ TSP CONCENTRATION—1985

¹ANNUAL ARITHMETIC MEAN

FIGURE 14



ESTIMATED AVERAGE ANNUAL¹ SO₂ CONCENTRATION-1985

¹ ANNUAL ARITHMETIC MEAN

TABLE 6

TSP AND SO ₂ CONTRIBUTIONS OF MAJOR SOURCES AT THE KOGER RECEPTOR, 1985			
	Source	Contribution ug/m ³	Percent of Calculated Polluta... Concentration*
° TSP	-Florida Power Corp., Bartow Pipeline Heater	0.29	0.70
° SO ₂	-TECO Big Bend Unit #2**	1.73	16.58
	-TECO Big Bend Unit #1**	1.72	16.52
	-TECO Big Bend Unit #3**	0.92	8.85
	-Florida Power Corp., Bartow #1	0.79	7.60
	-Florida Power Corp., Bartow Pipeline Heater	0.78	7.52
	-Florida Power Corp., Bartow #3	0.64	6.11
	-Florida Power Corp., Bartow	0.60	5.76
	-TECO, Gannon Unit #6**	0.53	5.06

* Including all area background, area and point sources.

** Distant sources; indiscriminant acceptance of respective contributions from these stacks may compromise model limitations.



TABLE 7

TSP AND SO ₂ CONTRIBUTIONS OF MAJOR SOURCES AT THE AIRPORT RECEPTOR, 1985			
	Source	Contribution (ug/m ³)	Percent of Total Calculated Concentration*
° TSP	-Florida Power Higgins	0.12	0.28
° SO ₂	-TECO Big Bend Unit #2 **	1.54	18.58
	-TECO Big Bend Unit #1 **	1.53	18.54
	-TECO Big Bend Unit #3 **	0.83	9.72
	-TECO Gannon Unit #6 **	0.74	8.89
	-TECO Gannon **	0.43	5.23

* Including all background, area and point sources.


** Distant sources; indiscriminant acceptance of respective contributions may compromise model limitations.

FIGURE 15



POINT ROSES FOR SO₂, 1985
(FROM CDMQC)


FIGURE 17



HISTOGRAMS OF RELATIVE CONTRIBUTION OF TSP AND SO₂
TO SELECTED RECEPTORS, 1985

(FROM CDMQC)

FIGURE 18



AIR EMISSION SOURCES PERMITTED SINCE JANUARY 6, 1975

To determine source interaction and increment consumption two distinct methodologies were applied. First, to demonstrate absolute worst case (although highly improbable) impacts, a CRSTER model was run with receptor ring distances coinciding with the "hot spots" from each pollutant generated by the proposed facility. Maximum readings recorded within these "hot spots" from both the post-baseline source and the proposed facility will be utilized to estimate increment consumption. As meteorologic data for plume dispersal are randomly generated by the CRSTER model, the values obtained should not be taken as real-case situations; rather, they represent a worst case condition at a particular receptor and point in time. Furthermore, it should be clearly understood that the accuracy of the CRSTER model at distances greater than 15.0 KM becomes highly suspect as the probability for identical meteorologic conditions over such distances (as the model assumes) is very unlikely.

Table 8 features the pertinent data input to CRSTER for each "new" major source.

The second method involved an analysis of source interaction via the PTMTP model. Through the results of the PTMAX and CRSTER model runs the impact of the proposed facility at distances greater than 6.0 KM was judged as negligible¹, thus it was assumed that any untoward pollutant

¹ Part 52, 1977 Amendments to Clean Air Act as promulgated on June 19, 1978 identifies the limits of source impact as follows: SO₂ 24 hour, 5 ug/m³; TSP 24 hour, 5 ug/m³.

TABLE 8

MAJOR AIR EMISSION SOURCES PERMITTED SINCE
JANUARY 6, 1975, AND RELEVANT CRSTER INPUT DATA

Source	Emissions		Stack Data			
	SO ₂ (GM/Sec)	TSP (GM/Sec)	Height (M)	Diameter (M)	Flow (M/Sec)	Temp. (°C)
◦ Florida Power Corp., Anclote (Pasco County)	1631.9	58.08	152.1	3.66	49.95	143.3
◦ Florida Power & Light, Willow Point (Manatee Co.)	438.69	39.98	152.0	6.97	26.7	151.7
◦ Florida Power & Light, Willow Point (Manatee Co.)	666.2	37.71	152.0	8.05	20.7	151.7
◦ Nord Southern Dolomite (Manatee Co.)	3.22	0.22	16.76	1.22	12.9	76.7
◦ Gardiniers (Hillsborough County)	13.86	0.0	45.4	2.74	11.6	70.6
◦ Chloride Metals (Hillsborough County)	7.19	0.06	20.9	0.61	12.1	80.6
◦ Tampa Electric Co., Big Bend (Hillsborough County)	1153.0	10.32	149.4	4.57	33.0	137.1

interactions would occur downwind of the facility within the 6.0 KM limit. To demonstrate this, three wind direction ranges were input to PTMTP which encompassed those post-baseline source sites. Specifically:

<u>Wind Direction</u>	<u>Source Interaction With:</u>
NNW	FPC Anclote
E	TECO Big Bend, Gardiniers, Chloride Metals
SSE	FPC Willow (both units), Nord Southern Dolomite


The results of the PSD increment analysis via CRSTER are summarized in Table 9. As is obvious, only the FPC Anclote and TECO Big Bend exhibit significant affects and then only to SO₂ concentrations. To simply sum the increment consumption by each source to determine the remaining increment would be unsound. Since, as stated before, the post-baseline source modeling values obtained are construed as being worst case situations, they are, therefore, overestimates. However, it is quite obvious that even when utilizing these very high readings, the construction and operation of the proposed facility and resultant interactions will not violate the allowable PSD increment at any averaging time for either pollutant.

PTMTP model runs assumed static meteorologic conditions over the twenty-four hour period; that is mixing height = 400M, temperature = 295°K, and wind velocity corresponding to those for respective wind directions shown in Figure

TABLE 9


MAXIMUM CALCULATED CONCENTRATION (ug/m ³) FOR EACH 'NEW' SOURCE MAJOR EMISSION WHICH COINCIDES WITH PROPOSED FACILITY 'HOT SPOTS'					
Major Source Permitted Since 1/6/78	SO ₂ 3 Hour	SO ₂ 24 Hour	SO ₂ Annual	TSP 24 Hour	TSP Annual
Anclote	36.7	10.4	0.63	0.40	0.023
FPC Willow (Both Units)	17.4	3.80	0.39	0.37	0.030
Nord	1.77	0.22	0.01	NA*	NA*
TECO Big Bend	47.23	13.48	1.02	0.12	0.009
Gardiniers	5.84	1.59	0.10	NA*	NA*
Chloride	5.81	1.63	0.09	NA*	NA*
SYNOPSIS OF PSD INCREMENT CONSUMPTION, FROM CRSTER					
	SO ₂ 3 Hour	SO ₂ 24 Hour	SO ₂ Annual	TSP 24 Hour	TSP Annual
Proposed Facility Increment	12.82	3.21	0.29	1.69	0.09
Other Source Increment	<u>114.75</u>	<u>31.12</u>	<u>2.25</u>	<u>0.77</u>	<u>0.053</u>
Total	127.57	34.33	2.54	2.46	0.14
Allowable	512	91	20	37	19

FIGURE 19



TSP 24-HOUR MAXIMUM CONCENTRATIONS FOR VARIOUS INPUT WIND DIRECTIONS

FIGURE 20



SO₂ 24-HOUR MAXIMUM CONCENTRATIONS FOR VARIOUS INPUT WIND DIRECTIONS

2.6.a. For these constant atmospheric conditions and those wind directions previously specified (i.e., 343°, 90°, 134°) the calculated 24-hour maximum concentrations for TSP and SO₂, respectively, at the specified receptor array were rendered and are shown in Figures 19 and 20. From these data one untoward interaction is noted. In Figure 20, the model estimates that a NNW wind will convey a heavy load of SO₂ to receptors just downwind of the proposed facility site. Analysis of partial concentrations at each receptor yields the following results:

<u>Receptor</u>	<u>Total Concentration ug/m³</u>	<u>FPC Anclote Contribution ug/m³</u>	<u>Proposed Facility Contribution</u>
1	93.75	93.75	1.29 x 10 ⁻⁴
2	92.78	92.66	0.124
3	92.90	91.61	1.29
4	93.55	90.57	2.98
5	75.35	75.35	0.0
6	42.78	42.78	0.0
7	17.09	17.09	0.0
8	4.73	4.73	0.0
9	88.27	88.27	0.0
10	74.53	74.53	0.0
11	55.93	55.93	0.0
12	37.54	37.54	0.0

The above analysis reveals that although a violation of the 91 ug/m³ PSD increment is noted, the maximum contribution of the proposed facility to that level is similar to that calculated by CRSTER (3.2 ug/m³) and is thus judged as insignificant.

Once again the reviewer of these results is cautioned about the reliability of utilized models at distances greater than 10 km. A run of the PTDIS model for ranges from about 32 to 40 km for various stability classes reveals that zero concentrations are predicted for stability classes 1 through 4 (unstable to neutral). For stability classes 5 and 6 concentrations from 10⁻⁵ to 10⁻⁶ gm/m³ are calculated; however, the model cautions the user that for distances beyond 10 km under stable conditions, resultant concentrations should be reviewed with extreme caution since it is unlikely that the stability and mixing height will persist beyond this range. Indeed, the plume dispersion width at the 32 to 40 km range is computed between 1 and 1.4 km, an extremely unlikely condition. Therefore, it is highly doubtful that the calculated violation of 3 hours SO₂ increment would ever occur.

AMBIENT AIR QUALITY STANDARDS

To evaluate the impact of the proposed facility's air emissions on state ambient air quality standards the CDMQC model was employed as the primary assessment tool. Basically, CDMQC estimates annual arithmetic mean pollutant concentrations at a given set of receptors. For those receptors with input calibration data, the Larsen's statistical analysis further estimates short term (i.e., 3 and 24 hour) pollutant levels.

As the site and associated "hot spots" receptors did not include monitoring data, short term concentrations at those sites would not be rendered by CDMQC; thus it was determined to stipulate the airport receptor as being situated so as to perceive maximum facility emissions. An examination of areal dispersion of facility emissions, as rendered by CRSTER and illustrated in Figures 8 through 12, reveals that, with the exception of the SO₂ annual calculation, maximum facility emissions do approximate the airport receptor. Facility contributions to annual ambient air quality standards were extracted from the CDMQC source contribution listing for the airport receptor; short term contributions are the maximum respective concentrations as calculated by CRSTER. With regard to the conversion of annual arithmetic means to annual geometric means, review of comprehensive historical data and reports concerning air quality assessment in Florida identifies a general relationship of 92:100 for geometric to arithmetic means; therefore, all annual geometric mean figures will reflect this assumption.

The results of the AAQS evaluation are summarized in Table 10; from these data it is apparent that the standards should not be violated under specified 1985 conditions. Of cardinal importance to this assessment is the contribution of the proposed resource recovery plant to ambient pollutant concentrations; again, from Table 10, it is quite obvious that the initiation of recovery operations at the facility will not exacerbate air quality in the study area.

TABLE 10

SYNOPSIS OF CDMQC RUN, 1985,
INCLUDING PROPOSED FACILITY EMISSIONS

Pollutant	Concentration at Airport ug/m ³	Concentration at Koger ug/m ³	Maximum Contribution of Facility ug/m ³	AAQS ug/m ³	% of AAQS ⁴
° TSP					
Annual	41.2 ²	40.92	0.04	60 ¹	63%
	37.9 ³	37.9 ³			
24 Hour	96.8 ⁶	94.1 ⁶	1.7 ⁷	150 ⁵	65%
° SO ₂					
Annual	8.3 ²	10.4 ²	0.1 ^{3,4}	60 ¹	13%
	7.6 ³	9.6 ³			
24 Hour	26.4 ⁶	69.0 ⁶	3.2 ⁷	260 ⁵	10%
3 Hour	31.5 ⁶	62.9 ⁶	12.0 ⁷	1300 ⁵	2%

1 Annual Geometric Mean

2 Annual Arithmetic Mean

3 Expected Annual Geometric Mean

4 From Airport Receptor Data

5 Not to be exceeded more than once per year

6 Expected maximum concentration from Larsens statistical analysis

7 From CRSTER

CONCLUSIONS

For both the Prevention of Significant Deterioration (PSD) and the Ambient Air Quality Standard (AAQS) evaluations it is concluded that the air quality impacts associated with emissions from the Pinellas Solid Waste Resource Recovery Facility will be minimal. It should be noted that, in accordance with Part 52, 1977 Amendments to the Clean Air Act (as promulgated on June 19, 1978) the area of significant impact of the proposed facility is virtually non-existent. Specifically, the limits of significant impact are stated as 50 KM or where the respective pollutant concentration falls below a critical level. Below are listed the critical levels for each pollutant and pertinent averaging time as compared to maximum pollutant concentrations generated by the proposed plant:

<u>PSD CRITICAL LEVEL</u>	<u>FACILITY MAXIMUM</u>
° TSP	
Annual - 1 ug/m ³	0.09 ug/m ³
24 Hour - 5 ug/m ³	1.7 ug/m ³
° SO ₂	
Annual - 1 ug/m ³	0.29 ug/m ³
24 Hour - 5 ug/m ³	3.2 ug/m ³
3 Hour - 25 ug/m ³	12.0 ug/m ³

APPENDIX B

COOLING TOWER - DISPERSION ANALYSIS

APPENDIX B

COOLING TOWER - DISPERSION ANALYSIS

In operating an evaporative cooling tower, the cooling media (water) is discharged from the system by three distinct processes. They are:

1. Evaporation - This is the means by which the hot water is cooled and the heat is released to the atmosphere as latent heat (heat of vaporization) in the evaporated portion of the cooling media.

2. Blowdown - Since the cooling fluid is continuously being evaporated from the system, contaminants in the system become concentrated unless the system is flushed or diluted. This is performed on a continuous basis by dumping a certain percentage of cooling media from the system.

3. Mechanical Drift - In order to provide air movement through the water (and thereby cause evaporation) mechanically driven fans are used on the towers. This forced air movement causes a small percentage of the cooling media to be mechanically carried from the cooling media flow to the atmosphere.

For the proposed facility, 1.9 percent of the cooling waters will be evaporatively entrained into the air stream, another 0.8 percent will be discharged by blowdown and 0.1 percent will be lost as mechanical drift. The evaporative process results in pure water being released into the atmosphere. The flow from the blowdown will be discharged into the composite blowdown system and hence to the municipal waste

treatment facility or to the residue quench system. Again, evaporation will cause the quench water to enter the ambient atmosphere as pure water.

Drift, on the other hand, contains the same proportion of chemical constituents as the cooling waters. The cooling water constituents are shown in Table 3.4.5.a. The deposition of these particles on the surrounding terrain thus may adversely affect the environment.

The behavior of drift in the atmosphere will depend on droplet size meteorological conditions and on effective release heights and velocity of the droplets into the atmosphere. The release heights are a function of plume rise and particle size fall velocities. Under conditions of downwash, the release height will be at ground level. Slight downwash may occur if the ratio of tower exit air velocity to wind velocity is less than 1.5. This situation occurs 38 percent of the time in Pinellas County. Substantial downwash may occur if this ratio is less than 1.0, which occurs approximately 1 percent of the time.

For a number of reasons, wet cooling tower plumes may behave differently than dry plumes. As water vapor condenses and releases latent heat, thus increasing the temperature, buoyancy may be increased. This effect was incorporated into Briggs' dry plume equations by using "virtual" temperatures in the equations. The virtual temperature is:

$$T_v = T(1 + 0.61q)$$

where "q" is the specific humidity. The virtual temperature was approximated as

$$T_v = T \div \frac{\text{mixing ratio (grams H}_2\text{O/kg dry air)}^{a,b}}{6}$$

Otherwise, the cooling tower plume rise was calculated as a dry plume. This should be accurate, according to Briggs.

For trajectory analysis, these plume rise considerations are important because they determine the upward momentum of the drift droplets, and, for those particles small enough to be dispersed as a gas, these considerations influence gaseous dispersion. The size range of drift from a mechanical draft cooling tower is typically such that a small number of very large droplets will dominate the total mass of drift. The expected size distribution at the proposed facility is shown in Table I. The larger droplets generally have terminal fall speeds of several meters per second. For particles with diameters larger than 200 micrometers, trajectory rather than dispersion equations need to be utilized to estimate drift deposition. Since 70 percent of the drift mass was in this range, the deposition calculations have all been made utilizing trajectory techniques.

TABLE I
SIZE AND MASS DISTRIBUTION OF DRIFT PARTICLES

<u>Droplet Diameter (Micron)</u>	<u>% by Weight</u>
less than 100 micron	10
100 - 200 micron	20
200 - 300 micron	22
300 - 400 micron	21
400 - 500 micron	16
500 - 600 micron	9
greater than 600 micron	2

a Cheremisinoff, et.al.

b American Meteorological Society Lecture on Air Pollution and Environmental Impact Analysis

The exit velocity from the main stream of the plume is 1640 fpm (8.33 m/sec) at the top of the cooling tower. At this point it is assumed that all particles have the same velocity. The drift particle size distribution and terminal fall velocities are shown below.

TERMINAL FALL VELOCITIES BY DROPLET SIZE

<u>Droplet Size um</u>	<u>Term. Vel. (m/sec)</u>
100	.615
200	1.18
300	1.71
400	2.19
500	2.64
600	3.05

The effective rise of the droplets was estimated as:^a

$$h_r = h_s + \Delta h_D$$

$$\Delta h_D = 1.3 \frac{F}{u^2 V_D^2}$$

where

h_s = height of tower

F = plume buoyance factor = $\frac{gW_0 D_T^2}{4} \times \frac{T_{v0} - T_{va}}{T_{v0}}$

g = gravitational constant

W_0 = tower exit velocity

D_T = tower effective diameter

T_{v0}, T_{va} = exit and ambient virtual temperature, respectively

u = wind speed, and

V_D = terminal velocity of the particle at its initial size.

a Cheremisinoff, et.al.

The travel time for the drop particle will be the total of the following three parts:

1. T_1 - Elapsed time related to the rise of the droplet to height h_s . Estimated to be $T_1 = \Delta h \div W_0$.

2. T_2 - Time for the particle to fall (at terminal velocity) from the stream release height to the elevation of the top of the tower.

3. T_3 - Time for the particle to fall (at terminal velocity) from the elevation of the top of the lower to the ground level (60 ft. = 18.29 m).

The horizontal distance travelled during the rise and fall of the drift particle is equal to the velocity of the wind times the duration of the flight of a given size particle.

EFFECTIVE HEIGHT AND TIME OF PARTICLE RISE

<u>$T_1 = \Delta h / W_0$ (sec)</u>	<u>Diameter</u>	<u>V_T m/sec</u>	<u>$h_r = h_s + \Delta h_D$</u>
35	100 μm	.615	288
11.0	200 μm	1.18	92
6.4	300 μm	1.71	53
4.7	400 μm	2.19	39
4.0	500 μm	2.65	33
3.5	600 μm	3.05	29

The fall time is the sum of $T_2 + T_3$ which is the sum of the distances $H_T + H_d$ divided by the terminal fall velocities of the given particle size. This is shown in tabular form below.

H_d (m) = height of rise above top of tower

H_T (m) = height of top of tower = 18.3 m

<u>Particle Size</u> (μm)	<u>$H_d + H_T$</u> (m)	<u>$T_2 + T_3$</u> (sec)	<u>$T_1 + T_2 + T_3$</u> (sec)
100	306	498	533
200	110	93	104
300	71	42	48
400	57	26	31
500	51	19	23
600	47	15	19


The travel distances prior to deposition on the terrain are shown in the following table.

<u>Particle Size</u> (μm)	<u>T_{tot}</u> (sec)	<u>Distance</u> (km)
100	533	2.1
200	104	.413
300	48	.191
400	31	.123
500	23	.091
600	19	.075

Figure 1 shows the percentage of deposition of the total drift versus distance from the source.

<u>Drop Size</u> (μm)	<u>Cumulative</u> <u>% drift</u> <u>deposited</u> <u>(by wt.)</u>	<u>Distance</u> <u>to deposition</u> <u>(km)</u>
600 & greater	2%	.075
500	11%	.091
400	27%	.123
300	48%	.191
200	70%	.413
100	90%	2.1

FIGURE I



DEPOSITION DISTANCES FOR DRIFT PARTICLES

APPENDIX C

APPLICATION FOR DETERMINATION
OF BEST AVAILABLE TECHNOLOGY
FOR AIR POLLUTION SOURCES



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION
APPLICATION FOR DETERMINATION OF BEST
AVAILABLE CONTROL TECHNOLOGY FOR AIR POLLUTION SOURCES

SOURCE STATUS: (X) New () Modification

Company Name: Pinellas County County: Pinellas

Source Identification: Pinellas County Resource Recovery Facility

Source Location: Street: 28th Street and 110th Avenue City: County

UTM: East _____ North _____

Appl. Name and Title: D. F. Acenbrack, Director of Solid Waste Mgmt. Div., Pinellas County

Appl. Address: 315 Haven Street, Clearwater, Florida 33516

Appl. Phone: 813/448-2251

DEPARTMENT USE ONLY

Date Appl. Received: _____

Notice of Receipt:

Newspaper: _____ Date: _____

Florida Administrative Weekly Date: _____

BACT Determination: _____

Declared by Secretary: _____ Date: _____

BACT: _____

NOTICE OF DETERMINATION

Newspaper: _____ Date: _____

Florida Administrative Weekly Date: _____

I. DETAILED DESCRIPTION OF SOURCE

A. Describe the manufacturing process at the facility and the unit operation to be controlled. Discuss the source of emissions, existing control devices, the expected improvement in performance, and state whether the project will result in compliance with ambient air quality standards or applicable PSD increments. Attach additional sheet if necessary.

The primary function of the facility is to dispose of solid waste material generated within the county. The process involves the burning of the solid waste in two medium pressure boilers. The steam produced will be used to drive a turbine and generate electricity. The source of emission will be a single 161' stack fitted with a three field electrostatic precipitator. The project will result in compliance with both Ambient Air Quality and Prevention of Significant Deterioration Standards.

B. For this source indicate any previous DER permits, orders, and notices; including issuance dates and expiration dates.

None

C. Raw materials, fuels, and chemicals used:

DESCRIPTION	HOURLY USE	CONTAMINANTS		RELATION TO FLOW DIAGRAM
		TYPE	% WT.	
Solid Waste	83.33 ton/hr*	-- **	-- **	

* Capacity

** Not defineable

D. Process Rate

1. Total Process Input Rate: 83.33 ton/hr.

2. Product Output Rate: 41* megawatts, 5.25 ton/hr. ferrous scrap, 500 lb/hr. aluminum

* Net output after 10% in-plant useage

3. Operating Time:

a. Hrs./Day: 24 b. Days/Wk: 7 c. Wks./Yr.: 52 d. Seasons: All seasons

II. BEST AVAILABLE CONTROL TECHNOLOGY DATA

A. Emission limitations for any pollutants emitted from the source pursuant to 17-2 F.A.C.?

Yes (X) No ()

CONTAMINANT	RATE OR CONCENTRATION
Particulate Matter	.08 G/SCFD, corrected 50% excess air
Odor	No objectionable odor

Standards of performance for nonstationary sources pursuant to 40 C.F.R. Part 60 applicable to the source?

Yes () No ()

CONTAMINANT	RATE OR CONCENTRATION
Particulate Matter	0.18 gr/dscm corrected to 12% CO ₂

C. Has EPA declared the best available control technology for this class of sources? (If yes attach copy)

Yes () No () EPA ruling is pending declaring electrostatic precipitation the BACT for particulate matter on large incinerator

CONTAMINANT	RATE OR CONCENTRATION

D. What emission levels do you propose as best available control technology?

CONTAMINANT	RATE OR CONCENTRATION
Particulate Matter	.08 g/dscf @ 50% excess air

E. Describe the existing control and treatment technology (if any) New Facility

1. Control Device: N/A

2. Operating Principles: N/A

3. Efficiency: --

4. Capital Costs: --

5. Useful Life: --

6. Operating Costs: --

7. Energy: --

8. Maintenance Cost: --

9. Emissions: --

* Explain method of determining E, 3, above.
EPA Form 2040-PCRM 12-0 (Rev. 78) Page 2 of 10

3.

a. Control Device: Fabric Filter Dust Collector (bag house)

b. Operating Principles: Dust laden air enters settling chamber at the bottom of the collector (below the bags) where the reduced velocity allows heavier particles to drop from stream. The gas stream then proceeds through the particles to drop from stream. The gas stream then proceeds through the filter media which is in the form of several bags into the clean air exhaust chamber. At periodic intervals the air flow is shut off and the bags are mechanically shaken to remove the collected dust from the fabric surfaces.

c. Efficiency: Unknown since this type device has not been used on a large incinerator. d. Capital Cost: Moderate (less than FSP)

e. Life: 20 yr. f. Operating Cost: Moderate

g. Energy: High, due to high pressure drop through filter media. h. Maintenance Cost: High cost of bag replacement. Bags are susceptible to burn holes from glowing airborne embers.

i. Availability of construction materials and process chemicals: Good

j. Applicability to manufacturing processes: Not applicable at present state of the technology. Tests are presently being conducted in Saugus, Mass.

k. Ability to construct with control device, install in available space, and operate within proposed levels: The control device could be constructed within the available space, however problems with the filter materials presently available restrict this type equipment from practical application on large incinerators.

4.

a. Control Device High energy type wet scrubber dust collecting system.

b. Operating Principles: Gas enters the scrubber tangentially near the bottom of the scrubber through a dense shower of the scrubbing fluid (usually water for particulate removal). The water remains in the bottom of the scrubber and provides a dynamic seal against the system pressure. The gas is spun to remove the water droplets from the stream prior to discharge to the atmosphere. The scrubbing water is continuously withdrawn and treated prior to reuse. The sludge removed from the water stream is dried and disposed of by landfilling.

c. Efficiency: Low efficiency for particulate removal (90% est.) d. Capital Cost: Moderate

e. Life: 20 years (est.) f. Operating Cost: Moderate - high

g. Energy: High pressure drop h. Maintenance Cost: Moderate - high

i. Availability of construction materials and process chemicals: good

j. Applicability to manufacturing processes: Little success to date with wet scrubbers on incinerator type operation. Major problems - heavy plume from high temperature saturated stream,

k. Ability to construct with control device, install in available space, and operate within proposed levels: complex sludge removal requirement & ineffective particulate removal. Requires large amount of space to accommodate liquid effluent treatment.

G. Describe the control technology selected:

1. Control Device: 3 field electrostatic precipitator

2. Efficiency: 98.35

3. Capital Cost: \$2,250,000

4. Life: 20 years

5. Operating Cost: \$74,000

6. Energy: 388 KWH/hr.

7. Maintenance Cost: \$ 7,000

8. Manufacturer: UOP, Inc., Des Plaines, Illinois

9. Other locations where employed on similar processes:

a.

(1) Company: City of Harrisburg

(2) Mailing Address: 223 Walnut Street

(3) City: Harrisburg

(4) State: Pennsylvania 17101

(5) Environmental Manager: J. R. Karper, Deputy Director of Public Waste

(6) Telephone No.: 717/255-6495

(7) Emissions: Data are not available

CONTAMINANT

RATE OR CONCENTRATION

(8) Process Rate:

b.

(1) Company: City of Chicago

(2) Mailing Address: Room 300, 320 N. Clark Street

(3) City: Chicago

(4) State: Illinois 60610

(5) Environmental Manager: William C. Ryder, Chief Environmental Design Engineer

(6) Telephone No.: 312/744-8030

(7) Emissions: Data not available

CONTAMINANT

RATE OR CONCENTRATION

(8) Process Rate:

c.

(1) Company: Town of Hempstead, New York

(2) Mailing Address: 1500 Merrick Road

(3) City: Merrick

(4) State: New York 11566

(5) Environmental Manager: Joseph A. Oliviero, Deputy Commissioner of Sanitation

(6) Telephone No.: 516/378-4210

(7) Emissions: Data not available.

CONTAMINANT

RATE OR CONCENTRATION

(8) Process Rate:

d.

(1) Company:

(2) Mailing Address:

(3) City:

(4) State:

(5) Environmental Manager:

(6) Telephone No.:

(7) Emissions:

CONTAMINANT

RATE OR CONCENTRATION

(8) Process Rate:

e.

(1) Company:

(2) Mailing Address:

(3) City:

(4) State:

(5) Environmental Manager:

(6) Telephone No.:

(7) Emissions:

CONTAMINANT

RATE OR CONCENTRATION

(8) Process Rate:

10. Reason for selection and description of systems:

11. Emissions:

CONTAMINANT	RATE OR CONCENTRATION

12. Stack Parameters:

- a. Height: 161 Ft.
- b. Diameter: 9 Ft.
- c. Flow Rate: 202,960 SCFM (Avg.)
- d. Temperature: 480 °F
- e. Velocity: 90.9 FPS (Avg.)

13. Fuels:

TYPE	HOURLY USE* X 10 ³ lbs.		HOURLY HEAT INPUT MILLION BTU/HR.	
	AVG.	MAX.	AVG.	MAX.
<u>Solid Waste</u>	<u>121</u>	<u>166.6</u>	<u>605</u>	<u>833</u>

TYPE	DENSITY	%S	%N	%ASH
<u>Solid Waste</u>	<u>18 - 26 lb/ft³</u>	<u>.14</u>	<u>.21</u>	<u>18.5</u>

*Gaseous: Cu. Ft./Hr.; Liquid & Solid: Lbs./Hr.

14. Wastes generated, disposal method, cost of disposal: 18.5% of the incoming waste (by weight - wet basis) will be discharged from the boiler after the burning process. This portion will be disposed of as follows:

Material	%	Method of Disposal	Cost(Credit)/gross ton
Ferrous Metals	6.3	Sale to Metal Dealer	(\$.47)
Aluminum	.3	Sale to Metal Dealer	(\$1.04)
Heavy Non-Ferrous Metal	.12	Sale to Metal Dealer	(\$.35)
Aggregate	10.28	Used as clean fill material	(-0-)
Residue	1.5	Sanitary Landfill	(\$.36)
TOTAL COST (CREDIT)/gross ton			(\$1.50)

H. Discuss the social impact of the selected technology versus other applicable technologies. (i.e. jobs, payroll, production, taxes, energy, etc.)

Include assessment of the environmental impact of the sources. The County has seen the need to provide a more efficient method of solid waste disposal which is ecologically sound, will recover useable materials, will generate energy from waste material and will reduce the amount of land required for the final disposal of the waste. To this end, the County has committed itself to provide a modern resource recovery facility with the following benefits as incentive.

BENEFITS: Initially the facility will receive some 530,000 tons of solid waste per year (a capacity of 728,000 tons/year will be provided), of which less than 3% will ultimately have to be landfilled. This substantial reduction in the waste tonnage represents a corresponding volume reduction and therefore a similar savings in the amount of land annually consumed by landfilling operations.

In addition to reducing the amount of land required for solid waste disposal, conversion from landfilling of raw garbage to process residue landfilling will preclude further damage to the water table since the processed material is inert, consisting of the burned out material discharged from the grate and fly ash. Landfilling this material will have the added benefit of materially reducing the number of seagulls that are attracted to the site by the presence of raw garbage. The seagulls present a hazard to aircraft climbing from or descending to the nearby St. Petersburg-Clearwater International Airport.

The plant will generate 262 million kilowatt hours of electrical energy per year (based on 530,000 ton/year and 495 KWH/ton net output).

The recovery and recycling of marketable materials will help to abate the existing scarcity of these resources. Annually 33,000 tons of ferrous metals, 1,600 tons of aluminum and 636 tons of heavy nonferrous material will be recovered from the waste stream.

Since the resource recovery will be one of the first of its kind in the United States (unprocessed solid waste fuel to electricity), it can be expected that its operation will contribute significantly to the advancement of the solid waste processing activity in the country.

Operation of the plant will require a staff of 51 people (8 administrative, 32 operations and 11 maintenance personnel). As it is the intent of management to hire locally whenever possible, the payroll as a result of their employment is a benefit to be counted. An estimated annual payroll of \$765,000 will put \$15.3 million in present worth dollars into the local economy over a 20-year period.

On a short-term basis, the plant construction will provide the benefits of a \$60 million construction project in the area. This will provide jobs for local construction labor, as well as an input to the local economy through the purchase of construction materials and services. Although the facility will be owned by the County, a private contractor will operate and maintain the plant. This private operation will generate an income for the contractor which will in turn provide corporate tax revenues as provided for in the Florida Administrative Code.

COSTS: The land on which the facility will be built (approximately 20 acres of industrial zoned land) will be utilized exclusively for the facility and will be restricted from other uses. It should be noted, however, that this land is presently within the permitted landfill area. If landfilling were to continue as is the existing practice, this area would be consumed in less than two years and its monetary value as industrial land would be severely reduced, since heavy construction on landfilled property is not generally practiced.

III. ADDITIONAL ATTACHED INFORMATION

- A. Show derivation of total process input rate and product weight.

See Exhibit A, Figure A

- B. Show derivation of efficiency estimation.

See Exhibit B

- C. An 8½" x 11" flow diagram which will, without revealing trade secrets, identify the individual operations and/or processes. Indicate where raw materials enter, where solid and liquid waste exist, where gaseous emissions and/or airborne particles are evolved and where finished products are obtained.

See Figure C

- D. An 8½" x 11" plot plan showing the exact location of manufacturing processes and outlets for airborne emissions. Relate all flows to the flow diagram.

See Figure D

- E. An 8½" x 11" plot plan showing the exact location of the establishment, and points of airborne emissions in relation to the surrounding area, residences and other permanent structures and roadways.

See Figure E

- F. Attach all scientific, engineering, and technical material, reports, publications, journals, and other competent relevant information describing the theory and application of the requested best available control technology.

Environmentally, the facility will be much like any other well designed and operated facility. During the construction period there will be a disturbance and most likely a loss of individuals of various species of flora and fauna as well as increased emissions into the air and water. Conscientious efforts will be exercised in order to mitigate these environmental disturbances so that the construction activity will impose minimal long range effects on the environment.

Similarly, during the term of operation of the plant, the best available control technology will be utilized to protect the environment from the effects of discharges from the facility.

Detailed accounts of the proposed abatement efforts during construction and operation of the facility are presented in the Power Plant Site Certification Chapters 4 and 5, respectively.

Of primary significance, however, is the fact that without this facility, much larger scale negative environmental effects would be realized. A comparison of effects with and without the resource recovery facility is also detailed in the PPSC report.

EXHIBIT A

BASIS OF DESIGN
 PINELLAS COUNTY RESOURCE RECOVERY FACILITY
 MARCH 1978

I. EXISTING CONDITION

a. Solid Waste Quantities Disposed in 1977

<u>Landfill</u>	<u>1977 Quantities Tons/Year</u>	<u>% Total</u>	<u>Source of Data</u>
Toytown	334,840	58.7	City of St. Petersburg Weighed Data
Wells Bros.	146,761	25.7	Pinellas County Wells Bros., Weighed Data
Largo	48,000	8.4	City of Largo Estimated
Tarpon Springs	11,000	1.9	City of Tarpon Springs Estimated
Windish	30,000	5.3	Cities of Dunedin, Safety Harbor, Pinellas County, Wells Bros., Estimated
TOTAL	570,601	100.0	

b. Population Projections

Population projections were obtained from the Pinellas County Planning Department. Figure 1 depicts the 1975 and 1977 projections to the year 2000. The 1977 projections are lower than the previous projections and are based on the Pinellas County Comprehensive Land Use Plan adopted by Pinellas County in October 1977.

c. Per Capita Generation Rate

In 1977 approximately 570,600 tons of solid waste were disposed in Pinellas County by an estimated population of 770,000 people, which equals to an average per capita generation rate of 4.06 lb/cap/day (570,600 TPY x 2000 lbs/ton ÷ 770,000 capita ÷ 365 days/year = 4.06 lb/cap/day).

d. Seasonal Variation

Scale data was obtained from the Toytown and Wells Bros. sanitary landfills. The data reported daily, weekly and monthly quantities during 1977. These two landfills received 84.4 percent of the 1977 tonnage disposed in Pinellas County. Figure 2 depicts the 1977 monthly variation in waste quantities. Two maximum peaks occurred in 1977. In March 11.1 percent of the total waste was disposed while in August 9.2 percent was disposed. Further inspection indicates that during the month of January the minimum tonnage was received. During January 7.0 percent of the total annual solid waste was discarded.

Analysis of records from prior years indicated a similar seasonal variation. Therefore, the consultant proposes to use the 1977 seasonal variation as a typical condition to estimate the tonnage by month for the following years: 1980, 1990 and 2000.

II. SOLID WASTE PROJECTIONS

Listed below are the projected quantities for three project years:

<u>Year</u>	<u>Quantity (Tons)</u>
1980	592,690
1990	676,455
2000	776,400

The estimated quantities are based on the 1977 population projections for the three project years and a 4 lbs/capita/day waste generation rate.

PINELLAS COUNTY POPULATION PROJECTIONS




FIGURE A

EXHIBIT B
DERIVATION OF EFFICIENCY ESTIMATION

REVISED SEPTEMBER 19, 1978

CALCULATIONS FOR
EPA PSD PERMIT APPLICATION
(SUBSTITUTED FOR APPENDICES D AND E
OF JULY 12, 1978 SUBMITTAL)

FOR
PINELLAS COUNTY RESOURCE RECOVERY FACILITY

UOP 9/19/78

EMISSION CALCULATIONS

No Electrostatic Precipitator Control

Maximum Hourly Fuel Consumption

Annual Fuel Consumption	730,000 T/Year
Boiler Emission (Uncorrected)	1.654 gr/scf
Boiler Gas Flow	279,549 scfm
Excess Air at Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.654 \times \frac{190}{150} \times \frac{1}{.87} = 2.41 \text{ gr/dscf @ 50\% excess air}$$

Particulate Emission Rate:

$$279,549 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times 2.41 \frac{\text{gr}}{\text{dscf}}$$

$$= 3966 \text{ lb/hr}$$

EMISSION CALCULATIONS

No Electrostatic Precipitator Control

Average Hourly Fuel Consumption

Annual Fuel Consumption	530,000 T/Year
Boiler Emission (Uncorrected)	1.447 gr/scf
Boiler Flue Gas Flow	202,960 scfm
Excess Air at Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%

Boiler Emission Corrected to dscf @ 50% Excess Air

$$1.447 \times \frac{190}{150} \times \frac{1}{.87} = 2.11 \text{ gr/dscf @ 50\% excess air}$$

Particulate Emission Rate:

$$202,960 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times 2.11 \frac{\text{gr}}{\text{dscf}}$$

= 2521 lb/hr

EMISSION CALCULATIONS

Three Field Electrostatic Precipitator

Maximum Hourly Fuel Consumption

Annual Fuel Consumption	730,000 T/Year
Boiler Emission (Uncorrected)	1.654 gr/scf
Boiler Gas Flow	279,549 scfm
Excess Air at Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%
ESP Outlet Dust Loading (Guaranteed)	.08 gr/dscf @ 50 excess air

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.654 \times \frac{190}{150} \times \frac{1}{.87} = 2.41 \text{ gr/dscf @ 50\% Excess Air}$$

ESP Efficiency:

$$\% \text{ Eff.} = \frac{2.41 - 0.08}{2.41} = 96.7\%$$

Particulate Emission Rate:

$$279,549 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times 0.08 \frac{\text{gr}}{\text{dscf}}$$

= 132 lb/hr

EMISSION CALCULATIONS

Three Field Electrostatic Precipitator

Average Hourly Fuel Consumption

Annual Fuel Consumption	530,000 T/Year
Boiler Emission (Uncorrected)	1.447 gr/scf
Boiler Gas Flow	202,960 scfm
Excess Air @ Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%
ESP Outlet Dust Loading	.05 gr/dscf @ 50% excess air

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.447 \times \frac{190}{150} \times \frac{1}{.87} = 2.11 \text{ gr/dscf @ 50\% Excess Air}$$

ESP Efficiency:

$$\% \text{ EFF} = \frac{2.11 - .05}{2.11} = 97.6$$

Particulate Emission Rate:

$$202,960 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times 0.05 \frac{\text{gr}}{\text{dscf}}$$

= 60 lb/hr

EMISSION CALCULATIONS

Four Field Electrostatic Precipitator

Maximum Hourly Fuel Consumption

Annual Fuel Consumption	730,000 T/Year
Average Hourly Fuel Consumption	83 T/Hour
Boiler Emission (Uncorrected)	1.654 gr/scf
Boiler Gas Flow	279,549 scfm
Excess Air @ Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%
ESP Outlet Dust Loading (Guaranteed)	.04 gr/dscf @ 50% excess air

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.654 \times \frac{190}{150} \times \frac{1}{.87} = 2.41 \text{ gr/dscf @ 50\% excess air}$$

ESP Efficiency:

$$\% \text{ EFF} = \frac{2.41 - 0.04}{2.41} = 98.3\%$$

Particulate Emission Rate:

$$279,549 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times .04 \frac{\text{gr}}{\text{dscf}} = 66 \text{ lb/hr}$$

EMISSION CALCULATIONSFour Field Electrostatic PrecipitatorAverage Hourly Fuel Consumption

Annual Fuel Consumption	530,000 T/Year
Average Hourly Fuel Consumption	60 T/Hour
Boiler Emission (Uncorrected)	1.447 gr/scf
Boiler Gas Flow	202,960 scfm
Excess Air @ Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%
ESP Outlet Dust Loading	.025 gr/dscf @ 50% excess air

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.447 \times \frac{190}{150} \times \frac{1}{.87} = 2.11 \text{ gr/dscf @ 50\% Excess Air}$$

ESP Efficiency:

$$\% \text{ Eff.} = \frac{2.11 - .025}{2.11} = 98.8 \%$$

Particulate Emission Rate:

$$202,960 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times .025 \frac{\text{gr}}{\text{dscf}}$$

$$= 30 \text{ lb/hr}$$




FIGURE C




FIGURE D

PLOT PLAN




FIGURE E

APPENDIX D

LANDFILL PERMIT INFORMATION

GENERAL

The following information is presented in order to clarify and further elaborate on the landfilling process which will be used as an adjunct activity to the Resource Recovery Plant. This landfill will be used primarily for the disposal of inert residue from the plant. Other short term uses of the landfill will be for the disposal of construction debris (during construction of the plant) and in the event of an emergency shut down, raw refuse will be disposed of until the plant is again operational.

The information presented herein is provided on the standard DER Resource Recovery and Management Facility format with Exhibits A through C included with this Appendix for additional clarification.

STATE OF FLORIDA
DEPARTMENT OF POLLUTION CONTROL

CONSTRUCT (X)
APPLICATION TO A SOLID WASTE
OPERATE ()

RESOURCE RECOVERY AND MANAGEMENT FACILITY

G. Jordan, Director of Public Works
and Utilities

Applicant:
(owner or authorized agent)

Street Address:

County Courthouse
315 Haven Street
Clearwater, Florida 33516

Mailing Address:

(If different from above)

(City)

(County)

Location of Site:

Township 30, Range 16, Section 14

Lat. 27° 52' 18" N Long. 82° 40' 48" W

(Township, Range, Section, & Lat., Long.)

28th Street N. & 110th Avenue

(Name of Access Road and Crossroad)

Towns and Areas to be Served:

All Portions of

Pinellas County

Population to be Served: approx. 775,000 Area of Site: 240 AC Acres

Date Site Ready to Receive Refuse:

General Requirements

A permit for each Resource Recovery and Management Facility is required. Separate applications for each permit, four copies each, should be submitted to the Regional Office of the Department of Pollution Control. Complete appropriate sections of the application for the type of facility proposed: sanitary landfill, incinerator, volume reduction plant, etc.

Each application shall be accompanied by an application fee of \$20.00 payable by check drawn in favor of "State of Florida, Department of Pollution Control".

Applicant has the responsibility to provide copies of the application to appropriate city, county and/or regional pollution control agencies, established pursuant to Section 403.182 Florida Statutes. Applicant shall also clear the application through appropriate local planning agencies. Comments from any of these agencies shall be forwarded with the application to the Department.

Information contained in the application shall conform to requirements of Chapter 17-7 F.A.C. All entries should be typed or printed in ink. If additional space is needed, separate, properly identified sheets of paper may be attached.

All documents submitted to support the application should be on 8.5" x 11" paper.


Processing of the application will begin when the foregoing requirements have been met.

Permit Number _____ Issue Date _____
Review Date _____ Expiration Date _____

STATEMENTS BY APPLICANT AND ENGINEER

A. Applicant

The undersigned owner, or authorized representative*, of Pinellas County is aware that statements made in this form and attached exhibits are an application for a Sanitary Landfill Permit from the Florida Department of Pollution Control and certifies that the information in this application is true, correct and complete to the best of his knowledge and belief. Further, the undersigned agrees to comply with the provisions of Chapter 403 Florida Statutes and all rules and regulations of the Department. It is understood that the Permit is not transferable, and, if granted a permit, the Department will be notified prior to the sale or legal transfer of the permitted establishment.



Signature of owner or agent

Director of Public Works & Utilities

Name and Title

Date: Oct. 23, 1978

*Attach letter of authorization

B. Professional Engineer Registered in Florida

This is to certify that the engineering features of this resource recovery and management facility have been designed/examined by me and found to conform to engineering principles applicable to such facilities. In my professional judgement, this facility, when properly maintained and operated, will comply with all applicable statutes of the State of Florida and rules of the Department. It is agreed that the undersigned will provide the applicant with a set of instructions for proper maintenance and operation of the facility.

Signature R. Lee Torrens Mailing Address: P. O. Box 12744
Pensacola, Fla. 32575

Name: R. Lee Torrens Telephone No.: 904/432-2481
(please type)

Florida Registration Number 21274 Date: 10/22/78
(please affix seal)

Sanitary landfill including milled refuse disposal sites requirements
Required Attachments
(Submit in the order listed)

1. Maps
 - A. A location map drawn to a scale of one inch equals one half mile showing the contours and elevation of the area surrounding the site.
 - B. A topographic map of the site drawn to a scale not to exceed one inch equals two hundred feet showing existing and final grades.
2. Drawings which shall include:
 - A. Property lines
 - B. Land use including existing habitations; other structures; public roads and highways; shallow and deep wells; trees; etc.
 - C. Area and depth of the proposed fill
 - D. All borrow areas
 - E. Location and elevation of surface and highest ground waters
 - F. A wind rose to show prevailing winds
 - G. Special provisions for surface and subsurface drainage and erosion control
 - H. Leachate treatment and control provisions
 - I. Necessary provisions for gas control
 - J. Method of operation and completion
 - K. Cross sections showing typical lifts not to exceed ten feet compacted depth of refuse
 - L. The necessary grade for proper drainage of each lift and the final grade of the completed operation
 - M. Locations of stockpiled cover material
 - N. Access routes, approach roads and on-site roads
 - O. Fencing, direction and information signs.
 - P. Weighing facilities, locker room; toilet and shower facilities; equipment shelter, and wash-out facilities
 - Q. Locations of existing and proposed utilities
 - R. Fire Control and potable water supply locations
3. Hydrogeological Report which shall include:
 - A. Thickness and character of the overburden (soil)
 - B. Character of bedrock
 - C. Depth of the water table and potentiometric surfaces
 - D. Depth to the shallow ground water aquifer and artesian aquifer
 - E. Local and regional ground water flow systems
 - F. Chemical quality of surface and ground water. (See Page 24 - A Handbook for Sanitary Landfills in Florida for list of substances to be tested for.)
 - G. Frequency and extent of flooding of the area.
 - H. Nature and volume of the waste materials to be buried

4. Soils Survey which shall include

- A. Depth to seasonal high watertable
- B. Soil Series
- C. Soil Drainage Class
- D. Flooding
- E. Permeability
- F. Slope
- G. Soil Texture (dominant to depth of 60")
- H. Depth to bedrock
- I. Stoniness Class
- J. Rockiness Class

5. Equipment -- Discuss

- A. Present - types, sizes, numbers
- B. Proposed - types, sizes, numbers

6. Discuss projected amount of waste to be handled including basis for projection.

7. Operating procedures - explain methods of

- A. Controlling the length and width of the working face
- B. Disposing of large items, special industrial, and hazardous wastes
- C. Confining papers to the site
- D. Waste handling in the wake of a natural disaster
- E. Emergency provisions for insect and rodent control
- F. Providing adequate site supervision
- G. Controlling unauthorized fires
- H. Maintaining an all weather access road
- I. Posting operating hours, fee schedule, waste restrictions, the name, address and phone number of the operating agent
- J. Locating signs to direct traffic

8. Land Disposal Data Form

NOTE: Additional information may be required as determined by the Department.

DESCRIPTION OF SITE

The landfill site (approximately 40 acres) will be used as an auxiliary to the proposed resource recovery plant. The specific landfill site is located as shown on Figure LP1 (following page) and is part of the 240 acre site included as the resource recovery site. The legal description of the entire 240 acres is as follows:

Lots 41 through 56, 73 through 86 and 105 through 120, inclusive Bridgewater Acres Subdivision and as recorded in Plat Book 6, page 64, Public Records of Pinellas County, Florida, and Lots 1 through 28, Block A, and Lots 1 through 28, Block B, Beladona Heights Subdivision as recorded in Plat Book 10, page 63, public records of Pinellas County, Florida.

The northernmost 80 acres was included in Phase I of the Bridgewater Acres sanitary landfill permit (application made March 1, 1977). The remaining 160 acres was described as Phase II in that Phase I application. This landfill site will predominantly be used to dispose of residues from the Resource Recovery Facility; however, during emergency conditions of a system failure, raw refuse will be disposed of in this site. In addition, debris generated during the construction of the Resource Recovery Facility will also be disposed of at this site.

RESOURCE RECOVERY FACILITY




FIGURE LP-1

COMMENTS ON REQUIRED ATTACHMENTS

1. Maps - Drawings from other portions of the PPSC text provide the same required information. Figure LP-1 is included herein for added clarification.
2. Drawings - Drawings provided as attachments hereto augment the material presented in the PPSC text.
 - A. Property lines - PPSC text.
 - B. Land Use, etc. - PPSC text.
 - C. Area and depth of proposed fill - The effective fill area as shown on Figure LP-1 is approximately 40 acres. The final equivalent depth of material to be landfilled in this fill is approximately 20 to 30 feet, to be constructed using 10 to 12 foot cell lifts.
 - D. Borrow areas - Borrow material, when needed, will be obtained either on site or from the adjacent county owned property. Material from excavation of the perimeter canals will be used for construction of a levee screen. This is shown on Figure LP-1. Potential areas for borrow in the contiguous county land are shown on Figure LP-1.
 - E. Location and elevation of surface and ground waters - Refer to PPSC text in addition to U.S. Geological Survey Hydrogeological Report (Exhibit A).
 - F. Wind rose indicating prevailing winds - Refer to PPSC text.
 - G. Special provision for drainage and erosion control - The drainage system proposed for the entire resource recovery site consists of the following items shown on Figure LP-2:
 - (1) Interceptor Canals - These canals will be served by intermediate drainage swales which direct drainage from the areas to be drained. The interceptor canals will flow to the stormwater holding lagoon.
 - (2) Stormwater Holding Lagoon - This lagoon will serve as a main holding area for drainage. If water levels become too high due to major storms water from this lagoon will be pumped to the stormwater/leachate treatment system.

(3) Stormwater/Leachate Treatment System - This system consists of an aeration basin, two contiguous ponds containing water hyacinth, a chlorine contact basin and a high head pump station. Additional design parameter information is contained in the PPSC text. Effluent from this system will be pumped to the spray irrigation area, shown on LP-1, or it will be used at the Resource Recovery Facility as cooling water make-up (reference PPSC text). Final top and side slopes of completed fill areas will be graded in such a manner that proper drainage will be provided by directing flow away from active landfill areas. All slopes of covers, canals, and completed fill areas will be seeded to retard erosion.

- H. Leachate treatment/control provisions - Drainage of completed fills will be employed to minimize leachate formation by allowing water to run off the fill rather than being allowed to percolate through the filled material. Leachate which does form by percolation through an active fill through seepage will be accumulated at the low point of the active cell. This accumulation will be pumped, via portable pumps, directly to the aeration pond. At no time will residue or raw refuse be deposited in standing water.

As described in "G" above, all leachate and stormwater will be treated and contained on site by spray irrigation. Drainage of treated wastewaters from the spray irrigation field into the perimeter canals will be discharged only during emergency conditions from an emergency overflow structure located at the extreme southeast corner of the site (see LP-1).

Existing monitoring wells (refer to PPSC text), plus any additionally required, will be used to monitor the effectiveness of the system. The need for special treatment will depend on the final analysis of the system's effectiveness during full operations. If required, they will be implemented appropriately.

- I. Gas control provisions - This site will primarily be used for plant residues containing less than 0.2% putrescible matter. Odors and gas production of any consequence are not expected. Since putrescible matter will be landfilled during emergencies, this condition will be monitored, and provisions evaluated at that time. Objectionable odors, if any, originating from this site will be effectively controlled during all phases of operation as circumstances dictate.

- J. Method of operation and completion - The incremental landfill area is approximately 40 acres. The acreage will be used sequentially from north to south through this 40 acre parcel. Primarily residues from the Resource Recovery Facility will be disposed of in this area. There will, however, be a need to dispose of raw refuse during periods of emergencies if a plant outage occurs. It is anticipated that such outages would be quite rare. At all times, normal residue will be segregated from the emergency landfill refuse. Putrescible wastes will receive daily cover while residues will only receive cover when necessary or at cell completion.


One standby putrescible cell will be available at all times. A typical cross-section of a finalized standby putrescible cell is shown on Figure LP-2. Following is an explanation of the sequence of operation of a putrescible cell when it is being utilized.

Site preparation prior to unloading and compacting of refuse, consists of excavating with dragline a portion of the north half of each strip, beginning at the end nearest to the on-site haul road. The nominal size of each portion (mini-cell) is 75 by 80-100 feet, one dimension being half the width of a full cell. Spoil is temporarily deposited at the outer edge of the excavation for later use as cover. Once this portion has been dug, the dragline begins excavating the other half of the cell width, depositing spoil beyond the outer edge of that portion.

Meanwhile, the first portion is prepared to receive refuse. Once this mini-cell has been filled and compacted to the desired elevation, the spoil deposited nearby is spread over the completed portion, as cover.

When required, the dragline is moved back (in direction away from on-site road) to begin excavation of the third portion located behind the initial mini-cell. Soon thereafter, the second portion is prepared to receive refuse from collection trucks. This procedure is repeated until the entire strip has been excavated, landfilled with refuse, compacted and covered.

This entire sequence is repeated if and when additional raw refuse fill is required.



TYPICAL 250' BUFFER ON WEST AND SOUTH BOUNDARIES OF RESOURCE RECOVERY SITE. MUCH OF LANDFILL AREA ABUTS STORM WATER HOLDING POND.

NOTE: CONTOUR ADJUSTED BASE ELEVATION AND SUBSEQUENT LIFT CONTOURS TO PROMOTE SURFACE AND SUB-SURFACE DRAINAGE AWAY FROM RAW REFUSE - FOR DIVERSION TO TREATMENT SYSTEM.


NO SCALE

FIGURE LP-2
TYPICAL CROSS SECTION
RAW REFUSE CELL WITH PERIMETER
CANAL AND BERM

Shown on Figure LP-3 is a typical lift configuration for use in residue disposal. The sequence for excavation is basically the same as for the raw refuse cell described above, however, there will only be minimum compaction exercised. In addition, this material will receive cover only as circumstances dictate plus final cover.

This sequence of operation will continue until all of the designated area has been completely filled.

- K. Sections of typical lifts - These are shown for both putrescible and residue cells on Figures LP-3 and LP-4, respectively.
- L. Necessary grade for proper drainage - Figures LP-2 and LP-3 illustrate the requirements for contouring the adjusted base elevation and subsequent lift elevations, as well as final grade of completed operation to promote surface and sub-surface (leachate) drainage away from completed cells and on-site haul roads. A final top slope of not less than one percent will be provided to promote proper drainage.
- M. Locations of stockpiled cover material - The cover material is normally stockpiled alongside the mini-cells, from excavation of the next cell area in the operation sequence (refer to Item J). Significant portions of fill material (consisting of: loose to medium dense fine sands, becoming clayey with depth; very loose to loose thinly stratified clayey-sands; and very loose calcareous, silty sands with shell fragments) will be excavated on-site with development of the disposal strips, as well as drainage swales/canals.
- N. Access roads, approach roads, and on-site roads - Shown on LP-1 and in the PPSC text. Illegal entrance to the landfill site will be prevented through the presence of canals and fencing.
- O. Fencing, direction and information signs - Only under emergency conditions will refuse collection and transfer vehicles be allowed access to the landfill area. Primarily dump trucks hauling residue within the site will be using this area. At no times will the general public have access to the landfill area. A public dumping area is provided at the entrance to the Resource Recovery Plant site (reference PPSC text). A variety of directional signs are provided at the entrance to the plant site and during emergency outages of the facility, the bypassed refuse vehicles will be directed by the scale operator at the Resource Recovery Plant to the landfill area. Fencing will be provided where necessary.



NOTE: CONTOUR ADJUSTED BASE ELEVATION AND SUBSEQUENT LIFT CONTOURS TO PROMOTE SURFACE AND SUBSURFACE DRAINAGE AWAY FROM FILLED RESIDUE FOR DIVERSION TO TREATMENT SYSTEM.

NO SCALE

FIGURE LP-3
TYPICAL CROSS SECTION
RESIDUE CELL WITH PERIMETER
CANAL AND BERM

- P. Weighing facilities and other additional facilities - All weighing and adjunct facilities will be located at the plant site (reference PPSC text).
- Q. Locations of existing and proposed utilities - No utilities are contemplated at this time for the landfill area. A three phase 12 KV service is located along 28th Street to serve the treatment system. Additional electrical as well as water and sewerage utilities requirements for the plant itself are outlined in the PPSC text.
- R. Fire control and portable water supply locations - Fire control at the landfill will be handled with portable pumps utilizing perimeter canals and the holding pond as sources of water.

In the case of fire occurring in the active putrescible cell area, the area Volunteer Fire Department will be called. Fires are to be extinguished with water and cover dirt as necessary.

- 3. Sections A through G have been addressed by the U.S. Geological Survey (Tampa, Florida office). This report is included as Exhibit A of this document. A more thorough discussion of this information is contained in the PPSC text.

- H. Nature and volume of wastes to be buried - As discussed previously, the primary function of this landfill is to dispose of non-marketable residues from the Resource Recovery Plant.

In addition, this landfill will be used in emergency situations to landfill raw refuse.

It is impossible to estimate the volume of bypassed materials which will be landfilled until the plant is operational, however, it is estimated that this will be rare due to the economic penalties and/or incentives for the contractor to keep the plant operational.

As specified in the text of the PPSC, the annual volume of residue estimated in 1982 is 11,130 tons per year. This residue material has a density of approximately 30 lbs/ft³. This is approximately 27,481 c.y. per year. The full refuse flow volume delivered at the plant will be in the range of 1450 to 1700 tons per day initially.

Hazardous materials, such as poisons, herbicides, pesticides, flammable liquids, and other hazardous wastes will not be disposed of at this landfill. Certain approved chemicals will be disposed of subject to prior arrangements with the Pinellas County Public Works Department.

Sewage sludges and septic tank pumpings will not be accepted at the site.

4. This section has been discussed in the text of the PPSC report. Correspondence from the U.S. Geological Survey and the Soil Conservation Service (Exhibits A and B of this document) summarize this data in the format required in the Sanitary Landfill Application.
5. Equipment discussion - At present the county landfill activities are handled by a contract with Wells Brothers, Inc. who operate the Phase I Bridgewater Areas Landfill. The following is a list of equipment presently used in this operation.

<u>Description</u>	<u>Size</u>	<u>Quantity</u>
Steel-wheeled compactor with trash blade	N/A	1
Crawler dozer	D7 (Caterpillar)	1
Crawler dozer	D6 (Caterpillar)	1
Dragline with 6 cubic yard bucket	88B (Bucyrus-Erie)	1
Dragline with 1 cubic yard bucket	22B (Bucyrus-Erie)	1
Rubber tired loader	950 (Caterpillar)	1
Dump Truck	15 cubic yard	2
Pick-up Truck	1/2 ton	1
Miscellaneous Equipment pumps, generator, etc.	N/A	3

During the changeover of operation from the conventional landfill to the resource recovery operation, it is most likely the same equipment and staffing requirements will prevail as for the Phase I operation.

Once the resource recovery operation is begun, the equipment and staffing requirements will be minimal due to the nature of the residues being landfilled. Since the landfill activities will be adjunct to the resource recovery operation, some of the County personnel assigned to the plant will be utilized periodically at the landfill. Below is an estimate of the complement of personnel that will be assigned to the landfill operation:

Landfill Superintendent & Equipment Operator	1
Residue Truck Operators	1
Equipment Mechanic	<u>1</u>
	3

This staffing is considered to be the minimum required, however, if increased equipment and staffing are required, adjustments will be made.

In the advent of an emergency shutdown of the plant necessitating the landfilling of raw refuse, additional equipment will be procured on an interim basis (leased, rentals, or County equipment). Since the plant has storage capabilities (i.e. refuse pit) and two operating boiler units, there will be sufficient lead time available to make the necessary preparations for the landfilling of raw refuse.

6. Refuse quantities - The life of a sanitary landfill is a function of the rate at which material is landfilled. Anticipated quantities of solid waste are discussed in the PPSC report text. The materials which are intended to be landfilled are estimated to be 2.1 percent by weight of the incoming wastes with a density of approximately 30 lbs/ft³. Assuming multiple cell construction and an uncompacted depth of this material of 20 feet, the annual land requirement will be 0.85 to 1 acre per year. It is anticipated non-combustible demolition material and debris will bypass the plant and increase land consumption. However, the volumes involved must await operational experience.
7. Operating procedures - The operation of the landfill will be directed by the County staff at the Resource Recovery Plant. All wastes directed to the landfill will be weighed at the facilities located at the plant. The quantity of residue to be landfilled is very important to the calculation of the payment due the plant operators (UOP), therefore, good record keeping and inventories are incumbent upon the County. Least of all this includes a complete inventory of the materials directed to the landfill.

As mentioned previously, only those vehicles directed to the landfill by the scale operators located at the plant will be allowed access to the landfill.

During residue disposal, the landfill superintendent will direct the residue trucks to the dump area to be used. Since there will be County personnel hauling the residue on a routine basis, traffic and vehicle management on the site are not anticipated problems.

In the event of an emergency landfill condition, the operating procedures would be essentially the same as for the Phase I Bridgeway Acres Landfill.

No scavenging of any kind will be permitted anywhere on the solid waste site.

- A. Controlling the length and width of working face - During the disposal of residue, the landfill superintendent will direct the residue trucks to the dump area as required by existing conditions at that time. This residue material will be covered only when a maximum lift depth of 12 feet is reached or when extraneous conditions dictate (e.g. high rainfall, wind conditions, etc.).

On the rare occasions that raw refuse must be landfilled the basic trench and combined area method will be used. At the end of each working day, it is to be covered completely with a minimum six inch continuous layer of soil. The compacted waste and soil cover constitute a cell. A series of adjoining cells make up a lift.

Cell dimensions are determined by the volume occupied by the compacted refuse which in turn depends on the in-place density. Obtaining maximum in-place density is the major objective of the County landfill operation. To accomplish this, refuse is to be spread in layers of not more than two feet on the working face and the compacting vehicle is required to run up and down the slope compacting the refuse and eliminating voids.

The working face is to be no wider than required for dumping operations without causing a serious backlog of trucks waiting to dump. The slope of the face is to be as steep as the compaction vehicle can efficiently handle. The depth of the cell for each lift will only significantly vary on the side slopes of the exterior waste strips.

The typical height of each lift will average three to four yards. To conserve cover material, the cells are to be constructed with minimum surface area or approximately square. This cell construction will be accomplished by development of mini-cells initially emplaced in each minimum 150' wide disposal strip excavated to accommodate the required face dimension for each of two mini-cells, having typical individual widths of 75' nominal. Allowing a five-yard width for safety and truck dumping, this dimension will provide six to seven dumping positions per mini-cell width.

- B. Disposing of large items, special industrial, and hazardous wastes - Pinellas County is not really faced with the problems of any special industrial or hazardous wastes as the County consists primarily of tourist-oriented communities and does not support any type of heavy manufacturing.

The proposed landfill operation will not accept hazardous materials such as indicated in Item 3-H.

Any bulky items received at the plant which will be diverted to the landfill will be heavy demolition debris and concrete.

- C. Confining papers to the site - The only paper which will be landfilled will be during emergency operations. During these time temporary fences will be used (if required) to prevent blowing litter.
 - D. Waste handling in the wake of a natural disaster - These wastes will be handled at the plant, as much as possible. In the event that these wastes exceed the capabilities of the plant, special cells will be constructed for these materials as required.
 - E. Emergency provision for insect and rodent control - Since the residue is essentially non-putrescible in nature insect and rodent infestation is not anticipated. Nevertheless the County Mosquito Control Unit will cycle the proposed landfill site on a regular basis. Effective measures for rodent control will also be employed at the landfill site as required.
 - F. Providing adequate site supervisions - Site supervision will be provided by a contractor or the Public Works Department. A supervisor is to be on duty at all times that the site is being used.
 - G. Controlling unauthorized fires - All operating personnel will have been instructed in the proper control of unauthorized fires.
 - H. Maintaining all-weather access roads - All weather haul roads are to be maintained as required from the plant to the landfill.
 - I. Posting operating hours, fee schedules, waste restrictions, the name, address, and phone number of operating agent - All of the above is to be posted at the entrance gate to the Resource Recovery Plant since the landfill is adjunct to this facility.
 - J. Locating signs to direct traffic - Refer to Section 2 "O".
8. Land Disposal Data Form - The DER Land Disposal Data Form is provided as Exhibit C.

EXHIBIT A

Items 3A-G

U. S. GEOLOGICAL SURVEY
HYDROGEOLOGICAL REPORT



United States Department of the Interior

GEOLOGICAL SURVEY

Water Resources Division
4710 Eisenhower Boulevard, Suite B-5
Tampa, Florida 33614

February 4, 1977

(FL-152)

Mr. D. Acenbrack
Director of Solid Waste Management
315 Haven Street
Clearwater, Florida 33516

Dear Mr. Acenbrack:

This letter is in response to your request dated January 20, 1977 for information on the hydrogeology of the Pinellas County landfill vicinity. The data requested is enclosed and we hope it will satisfy most of Sections 3 and 4 of Chapter 17-7, F.A.C., Resource Recovery and Management, Part I: Solid Waste Facilities. The information is listed below in the order of appearance on the permit application. The data presented is part of a report entitled, "Hydrogeology of a landfill operation, Pinellas County, Florida" that is now being prepared.

Section 3. Hydrogeological Report

A. Thickness and character of the overburden (soil): Soil samples from 8 test holes indicate the presence of 2 hydrologic units that comprise the overburden: (1) a sand layer comprised of fine to very fine sand and shell, light gray to dark brown, which grades down to very fine sands with traces of clay to (2) marl and clay. The clay, soft, sandy gray-green becomes, with depth, stiff, cherty, with phosphate pebbles and limestone fragments. The thickness of the sand unit ranges from 13 to 23 feet, and the thickness of the marl/clay unit is about 32 to 42 feet.

B. Character of bedrock: The hard chert and limestone which forms the upper part of the Miocene-aged Tampa formation was never penetrated. The bed rock, based on drilling logs, appears to begin from 33 to 55 feet below land surface.

C. Depth of the Water-table and potentiometric surfaces: The depth to the water-table surface is about 1 to 5 feet for the wet and dry season, respectively. The potentiometric surface of the artesian aquifer is about 5 feet above mean sea level, figure 1.

D. Depth to the shallow ground-water surface and artesian aquifer: The shallow ground-water aquifer is the sand unit mentioned in 3A. This aquifer extends from essentially land surface to depths ranging from 13 to 23 feet as determined by test drilling. A marl and clay unit separates the shallow ground-water aquifer from the artesian aquifer. The artesian aquifer has not been reached by drilling in the immediate area of the landfill. From material encountered in shallow test holes, the top of the artesian aquifer probably is 33 to 55 feet below land surface.

E. Local and Regional Ground-water flow system: The local ground-water flow system is presented in figures 2 and 3. These figures are preliminary configurations and are subject to revision. Since the general direction of ground-water flow follows the topography of the land, it can be assumed that the overall ground-water flow is to the east and northeast. A local configuration of potentiometric ground-water flow system has not been developed, however the regional system has been developed and is presented in figure 1.

F. Chemical quality of surface and ground water: Water samples from surface water and ground-water sites are being collected periodically for analysis of the following parameters; biochemical oxygen demand, chemical oxygen demand, coliforms, nitrogen, phosphorus, sodium, potassium, magnesium, calcium, chlorides, pH, specific conductance, toxic heavy metals, pesticides and herbicides. The results of analysis for all the sites sampled are presented in Tables 1-6. The locations of the sampling sites are presented in figure 4.

G. Frequency and extent of flooding of the area: The Pinellas County landfill site lies at the boundary of a flood-prone area (figure 5). Flood prone areas shown on this map have a 1 in 100 chance on the average of being inundated during any year. Figure 5 was taken from "Map of flood-prone areas" prepared by the U. S. Department of Interior, Geological Survey, in cooperation with the U. S. Department of Housing and Urban Development, Federal Insurance Administration, 1973.

H. Nature and volume of the waste materials to be buried: This topic is not part of the Survey's geohydrological investigations.

Section 4. Soil Survey

A. Depth to seasonal high water table: The depth to the water-table surface is about 1 to 5 feet for the wet and dry season, respectively.

D. Flooding: The Pinellas County landfill site lies at the boundary of a flood-prone area (figure 5). Flood prone areas shown on this map have a 1 in 100 chance on the average of being inundated during any years.




Figure 2. Water-table contours in Pinellas County, Landfill October 1975




Figure 3. Water-table contours in Pinellas County Landfill
May 1975

EXHIBIT B

Item 4 - A
B
D
E
G

SOIL CONSERVATION SERVICE
SOILS SURVEY

UNITED STATES DEPARTMENT OF AGRICULTURE
SOIL CONSERVATION SERVICE

SUBJECT: Feasibility of Sanitary Landfill

DATE: 2/16/77

TO: Henningson, Durham, & Richardson, Inc.

SOILS: Elred series- these are nearly level, poorly drained soils on broad low ridges in the flatswoods. The water table is at a depth of 10 - 30 inches for 2 to 6 months in most years and within a depth of 10 inches for 1 to 2 months during wet seasons.

Texture	Permeability
0 - 30" Fine sand	6.3 - 20.0 in/hr
30 - 35" Fine sandy loam	0.63 - 2.0 "
35 - 62" Sand, Shell	6.3 - 20.0 "

Flood hazard* once in 5 to 20 years for 7 to 30 days

SOILS: Felda series 20% - this is a nearly level poorly drained soil that occupies slightly elevated areas bordering sloughs and ponds. The water table is at a depth of about 10 inches.

Texture	Permeability
0 - 30 Fine sand	6.3 - 20.0 in/hr
30 - 41 Fine sandy loam, loamy fine sand	0.63 - 2.0 "
41 - 60 Shell, sand	6.3 - 20.0 in/hr

Flood hazard - Once in 5 to 20 years for 7 to 30 days



LAND DISPOSAL SITE DATA FORM
(Fill in and check blocks as appropriate.)

DELETE
ADD
CHANGE
INACTIVE

CONTROL NO. _____

1. COUNTY Pinellas		2. SITE Bridgeway Acres		3. DATE Oct. 20, 1978	
4. STREET ADDRESS 34th Street N. & 110th Avenue					
5. LOCATION UTM X 280,352.45		Lat. 27°52'18"N		TOWNSHIP 30 RANGE 16 SECTION 14	
Y 1,286,607.29		Long. 82°40'48"W			
6. RESPONSIBLE OPERATING AUTHORITY P/C Dept. of Public Works					
7. OWNERSHIP Pinellas County			8. ADDRESS 315 Haven St., Clearwater, Fla.		
9. PHONE NO. 813/448-2251			10. POPULATION SERVED approx. 775,000		
11. NO. OF ACRES 40		12. METHOD OF OPERATION (a) TRENCH <input checked="" type="checkbox"/> (c) WETLAND <input type="checkbox"/> (e) DUMP <input type="checkbox"/> (b) AREA <input checked="" type="checkbox"/> (d) HIGH-RISE <input type="checkbox"/> (f) OTHER <input type="checkbox"/>			
13. TOPOGRAPHY (a) QUARRY <input type="checkbox"/> (c) STRIPMINE <input type="checkbox"/> (e) GULLY <input type="checkbox"/> (g) MARSH <input type="checkbox"/> 14. YES <input checked="" type="checkbox"/> (b) BORROW PIT <input type="checkbox"/> (d) HILLSIDE <input type="checkbox"/> (f) LEVEL AREA <input checked="" type="checkbox"/> SCALES NO <input type="checkbox"/>					
15. SURROUNDING LAND-USE (a) RESIDENTIAL <input type="checkbox"/> (c) AGRICULTURAL <input type="checkbox"/> (e) VACANT <input checked="" type="checkbox"/> (b) COMMERCIAL <input type="checkbox"/> (d) INDUSTRIAL <input checked="" type="checkbox"/>					
16. ZONING (a) RESIDENTIAL <input type="checkbox"/> (c) AGRICULTURAL <input type="checkbox"/> (e) VACANT <input type="checkbox"/> (b) COMMERCIAL <input type="checkbox"/> (d) INDUSTRIAL <input checked="" type="checkbox"/>		17. YEAR BEGUN 1979			
18. PLANNED FINAL USE (a) PARK <input checked="" type="checkbox"/> (c) BUILDING CONSTRUCTION <input type="checkbox"/> (e) NONE <input type="checkbox"/> (b) PARKING LOT <input type="checkbox"/> (d) AIRPORT <input type="checkbox"/> (f) OTHER <input type="checkbox"/>					
19. TYPES OF WASTE RECEIVED (a) RESIDENTIAL <input checked="" type="checkbox"/> (e) SEPTIC TANK PUMPINGS <input type="checkbox"/> (i) HAZARDOUS, CLINI- <input type="checkbox"/> 20. YES <input type="checkbox"/> (b) COMMERCIAL <input checked="" type="checkbox"/> (f) SEWAGE SLUDGE <input type="checkbox"/> CAL, HOSPITAL BURNING NO <input checked="" type="checkbox"/> (c) INDUSTRIAL <input checked="" type="checkbox"/> (g) INCINERATOR RESIDUE <input checked="" type="checkbox"/> (j) WATER TREATMENT, <input type="checkbox"/> (d) AGRICULTURAL <input type="checkbox"/> (h) DEAD ANIMALS <input type="checkbox"/> SLUDGE					
21. DAYS OPEN FOR DISPOSAL S M T W T F S		22. FREQUENCY OF COVER NONE <input checked="" type="checkbox"/> S M T W T F S			
23. DEPTH OF WATER TABLE 1-5' for wet & dry seasons		24. SOIL PERMEABILITY 6-20"/hr. for top 30 in. of soil			
SWPMD data: 19 wells in contiguous 8 sections		(a) NONE <input type="checkbox"/> (c) OCCASIONAL <input type="checkbox"/>			
NO. OF WELLS WITHIN ONE MILE 3 w/ 34'+ case; 16 deep		FLOODING (b) RARE <input checked="" type="checkbox"/> (d) FREQUENT <input type="checkbox"/>			
27. NO. OF ROADWAYS ADJACENT TO SITE (existing & unpaved) 28th St. N. & 110th Ave.		28. SLOPE OF SITE 0-1%			
29. NO. OF RESIDENCES OR BUSINESSES WITHIN 1000 FEET 30		30. SOIL SERIES Eldred, Felda			
31. SOIL TEXTURE (a) SAND <input type="checkbox"/> (c) LOAMY-SAND <input type="checkbox"/> (e) SANDY CLAY LOAM <input type="checkbox"/> 32. YES <input type="checkbox"/> * (b) SANDY-LOAM <input checked="" type="checkbox"/> (d) SANDY CLAY <input type="checkbox"/> (f) CLAY <input type="checkbox"/> FENCED NO <input checked="" type="checkbox"/>					
33. MONITORING WELLS YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		34. POTENTIAL WATER POLLUTION (a) IMMEDIATE <input type="checkbox"/> (c) LOW <input checked="" type="checkbox"/> (b) HIGH <input type="checkbox"/>			
35. DUMPING IN WATER YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		36. PERIMETER DITCH YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		37. LINER YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	
38. LINER TYPE (a) PLASTIC <input type="checkbox"/> (c) BENTONITE <input type="checkbox"/> (e) OTHER <input type="checkbox"/> 39. YES <input type="checkbox"/> (b) ASPHALT <input type="checkbox"/> (d) CLAY <input type="checkbox"/> (f) NONE <input checked="" type="checkbox"/> WELL POINT SYSTEM NO <input checked="" type="checkbox"/>					
40. OXIDATION POHD YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		41. POND AREA 5 acres		42. DEPTH OF SOILS TO BEDROCK 33 to 55'	
43. EVIDENCE OF LEACHING YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		44. FINAL LEACHATE TREATMENT NEEDED YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>			
45. FINAL TREATMENT (a) CHLORINATION <input checked="" type="checkbox"/> (c) OZONATION <input type="checkbox"/> (e) OTHER <input checked="" type="checkbox"/> hyacinth 46. NO <input checked="" type="checkbox"/> (b) AERATION <input checked="" type="checkbox"/> (d) ADVANCED <input type="checkbox"/> (f) NONE <input type="checkbox"/> RODENT PROBLEM YES <input type="checkbox"/>					
47. DISCHARGE (a) CANAL <input type="checkbox"/> (c) STREAM <input type="checkbox"/> (e) OTHER <input checked="" type="checkbox"/> on-site spray 48. NO <input type="checkbox"/> (b) DITCH <input type="checkbox"/> (d) LAKE <input type="checkbox"/> (f) MARSH <input type="checkbox"/> irrigation** RODENT CONTROL YES <input checked="" type="checkbox"/>					
49. CELL DEPTH OF REFUSE 3-4 yards		50. INSECT PROBLEM YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		51. INSECT CONTROL YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	
52. BLOWING PAPER CONTROL YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		53. FULL TIME ATTENDANT YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>			
54. ALL WEATHER ACCESS ROAD YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		55. GAS CONTROL YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>			
56. SPREADING OF REFUSE IN 2 FT. LAYERS YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>					
57. ONE (1) FT. INTERMEDIATE COVER APPLIED WITHIN ONE (1) WEEK CELL COMPLETION YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>					
59. TWO (2) FT. FINAL COVER APPLIED WITHIN ONE (1) YEAR CELL COMPLETION YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>					
60. EQUIPMENT AVAILABLE DAILY (a) CRAWLER TRACTOR <input checked="" type="checkbox"/> (c) HYDRAULIC BACK HOE <input type="checkbox"/> (e) PAN SCRAPER <input type="checkbox"/> (g) BRUSH HOG <input type="checkbox"/> (b) RUBBER TYPED TRACTOR <input type="checkbox"/> (d) LANDFILL COMPACTOR <input checked="" type="checkbox"/> (f) DRAGLINE <input checked="" type="checkbox"/> (h) TRASH PUMPS <input checked="" type="checkbox"/>					
61. PROPOSED COST OF OPERATION \$/CU. YD. included in Resource Recovery Plant fee					
NAME OF PERSON COMPLETING FORM D.F. Acenbrack P/C Director Solid Waste Mgt.					
62. REVIEW DATE _____		63. PERMIT NO. _____		64. ISSUE DATE _____	
				65. EXPIRATION DATE _____	

4-74 ** Discharge only in emergency. -5- D-24

APPENDIX E

LETTER OF RESPONSE FROM
STATE OF FLORIDA, DIVISION
OF ARCHIVES, HISTORY AND
RECORDS MANAGEMENT



SECRETARY OF STATE

JESSE J. McCrARY, JR.

STATE OF FLORIDA

Department of State

THE CAPITOL
TALLAHASSEE 32304

October 16, 1978

L. ROSS MORRELL, ACTING DIRECTOR
DIVISION OF ARCHIVES, HISTORY, AND
RECORDS MANAGEMENT

(904) 488-1480

IN REPLY REFER TO:

Mr. Louis D. Tesar
Historic Sites Specialist
(904) 487-2333

Mr. James C. Andrews
Environmental Biologist
Henningson, Durham and Richardson
528 West Garden Street
Post Office Box 12744
Pensacola, Florida 32575

Re: Cultural Resource Assessment
Solid Waste Resource Recovery Facility
240 Acres in South 3/4 of West 1/2 of S14,
T30S-R16E, and Proposed Transmission Line
Pinellas County, Florida

Dear Mr. Andrews:

In accordance with the procedures contained in 36 C.F.R., Part 800 ("Procedures for the Protection of Historic and Cultural Properties"), we have reviewed the above referenced project for possible impact to archaeological and historical sites or properties listed, or eligible for listing, in the National Register of Historic Places. The authorities for these procedures are the National Historic Preservation Act of 1966 (Public Law 89-665) as amended by P.L. 91-243, P.L. 93-54, P.L. 94-422, and P.L. 94-458, and Presidential Executive Order 11593 ("Protection and Enhancement of the Cultural Environment").

A review of the Florida Master Site File indicates that no archaeological or historical sites are recorded for the project area. Furthermore, because of the location of the project, it is considered highly unlikely that any significant unrecorded sites exist in the vicinity. Therefore, it is the opinion of this office that the proposed project will not adversely impact any sites listed, or eligible for listing, in the National Register of Historic Places, or otherwise of national, state, or local significance.

Mr. James C. Andrews
October 16, 1978
Page Two

Your interest and cooperation in protecting Florida's
irreplaceable historic resources are appreciated.


Sincerely,



L. Ross Morrell,
Deputy State Historic
Preservation Officer

LRM:Teh

Pinellas County, Florida
Resource Recovery Program



Application For
EPA PSD
AIR QUALITY PERMIT

ITEMS INCLUDED

- I. Environmental Protection Agency
Air Pollutant Emissions Report
(Parts I through VI)

Appendices:

- A - General Project Footnotes
 - B - Seasonal Waste Distribution, Pinellas County -
1977
 - C - U.S. Bureau of Mines Test Results - % Sulfur
in Refuse
 - D - Calculations
- II. Air Quality Modelling and Analysis Report for EPA PSD
Permit Application
- III. Best Available Control Technology (BACT) Report and
Summary

I

ENVIRONMENTAL PROTECTION AGENCY
AIR POLLUTANT EMISSIONS REPORT
(PARTS I THROUGH VI WITH APPENDICES A THROUGH D)

Date Report Submitted: July 12, 1978

ENVIRONMENTAL PROTECTION AGENCY
AIR POLLUTANT EMISSIONS REPORT
SECTION I - GENERAL INFORMATION

FORM APPROVED
OMB NUMBER 158-R75

For Official Use Only:
Date Sent: _____
Date Returned: _____
UTM Grid Coordinates: _____
SIC No.: _____
Source ID: _____

Plant, institution, or establishment name: Pinellas County Resource Recovery Facility

Plant, institution, or establishment address: Pinellas County, Florida
(Street or Box Number) (City) (State) (Zip)

Person to contact regarding this report: D. F. Acenbrack Title: Director, Solid Waste Telephone: 813/448-2251

Mailing address: 315 Haven Street Clearwater Florida 33516
(Street or Box Number) (City) (State) (Zip)

Approximate number of employees at plant, institution, or establishment location: Less than 100 100 or more.

Elevation of plant, institution, or establishment in relationship to mean sea level: 8 feet above mean sea level, - feet below mean sea level

Information is representative of calendar year: 1978

Land area at plant location: + 18 acres. Enclose a sketch of layout if there is more than one building.

Plant location: (give nearest cross streets, describe by landmarks or enclose a map, engineering drawing, or sketch) Plant site is located approximately 350 ft. west of 28th Street on 110th Avenue in east section of existing Pinellas County landfill (see map in Appendix A)

Air pollutants of the type indicated in the instructions for the completion of this report, i.e., _____ are not emitted at this plant, institution or establishment. Therefore, no other Sections of the report need be completed.

(Signed) _____ (Title)

Please return all sections of this report to: D. F. Acenbrack

Note: All numbers in parentheses (e.g., (16)) denote that additional information or clarification is included in the tabulation of additional notes which accompanies this application.

Date Report Submitted: July 12, 1978

**ENVIRONMENTAL PROTECTION AGENCY
AIR POLLUTANT EMISSIONS REPORT**

FORM **1** REVISED
OMB NUMBER 158-R76

SECTION II - FUEL COMBUSTION FOR GENERATION OF HEAT, STEAM, AND POWER

Plant, institution, or establishment name: Pinellas County Resource Recovery Facility

Normal operating schedule for fuel use: 24 Hours per day 7 Days per week 52 Weeks per year 8760 Hours per year.

Dates of annually occurring shutdowns of operations: Unit No. 1-21 days June, 10 days Jan. Additional operating information enclosed . See (1)
Unit No. 2-21 days Jan., 10 days June, Unit No. 3 -21 days Feb., 10 days July

Source ^{a,e} Code	Number of Combustion Sources ^{b,e} (Boilers)	Size of Unit (Input) ^{c,e} 10 ⁶ BTU/hr.	Type of Unit ^{d,e}	Installation Date ^e	Percent Excess Air Used In Combustion (Design) ^e	Power Output Megawatts ^{e,f}
Unit No. 1 (2)	1	438	Wet bottom - traveling grate	Dec. 1982 (est.)	90%	(2) 47 (total)
Unit No. 2 (2)	1	438	Wet bottom - traveling grate	Dec. 1982 (est.)	90%	

- a. List a separate code number to represent each source (e.g., II-a, II-b, II-c, etc.), then enter the same code number and the required data on the continuation of this Section on Page 3, and in Sections V and VI.
- b. Multiple sources may be grouped if units are similar in size and type, burn the same fuel, or are vented to the same stack.
- c. Nameplate data are sufficient (give rated or maximum capacity, whichever is greater).
- d. Hand-fired, underfeed, overfeed, traveling-grate or spreader stoker; cyclone furnace; pulverized, wet or dry bottom with or without fly ash reinjection; rotary or gun type oil burner; etc.
- e. List separately future equipment and expected date of installation.
- f. Power generation only.

NOTE: Please read reverse side of
this page. Use additional sheets
if necessary. Retain last copy.

Date Report Submitted: July 12, 1978

ENVIRONMENTAL PROTECTION AGENCY
AIR POLLUTANT EMISSIONS REPORT

FORM APPROVED
OMB NUMBER 168-R76**SECTION II - FUEL COMBUSTION FOR GENERATION OF HEAT, STEAM, AND POWER (continued)**Plant, institution, or establishment name: Pinellas County Resource Recovery Facility

Source Code ^a	Type of Fuel ^b	Annual Consumption ^c					Hourly Consumption ^d		Percent Used for Space Heat	Heat Content BTU/Quan. ^e	Percent Sulfur ^f	Percent Ash (Solid Fuel Only) ^{e,f}	Delivered Cost of Fuel \$/Quantity	Future Use ^g
		Quantity ^d	Percent Distribution by Season				Maximum	Average						
			Spring March/ May	Summer June/ Aug.	Fall Sept./ Nov.	Winter Dec./ Febr.								
Unit No. 1	Solid Waste	264,997 ton/yr.	28.4	24.2	24.2	(3) 23.2	41.4 T/hr	30 T/hr	Negligible	5000 BTU/lb.	(4) 0.002	18.5% (5)	N.A.	(6) N.A.
Unit No. 2	Solid Waste	264,997 ton/yr.	28.4	24.2	24.2	(3) 23.2	41.4 T/hr	30 T/hr	Negligible	5000 BTU/lb.	(4) 0.002	18.5% (5)	N.A.	(6) N.A.

- List code numbers corresponding to each source referred to on page 2, (e.g., II-a, II-b, II-c, etc.), then enter required data on this page, and for the same code number sources in Sections V and VI.
- Coke, bituminous coal, anthracite coal, lignite; No. 1, 2, 4, 5 and 6 fuel oil; natural gas; LPG; refinery or coke oven gas; residual coke; wood; bark; sludge; etc. (Note: Indicate if two or more fuels are burned in the same boiler and provide all data pertinent to each fuel type.)
- Fuel data are to be reported on an "as burned" basis.
- Solid fuel, tons; liquid fuel, gallons; gaseous fuel, 1000 cubic feet.
- If unknown, please give name and address of fuel supplier.
- Sulfur and ash content for each fuel should be a weighted average.
- Estimated percent increase or decrease in fuel usage (by fuel type) per year for the five years after the calendar year for which this report is completed. If increase is due to new equipment, please list this equipment separately on page 2 and the expected fuel use on this page.

NOTE: Please read reverse side of this page. Use additional sheets if necessary. Retain copy.

Date Report Submitted: _____

ENVIRONMENTAL PROTECTION AGENCY
AIR POLLUTANT EMISSIONS REPORT

FORM APPROVED
OMB NUMBER 168-R75

SECTION III - COMBUSTIBLE SOLID AND LIQUID WASTES DISPOSAL

Plant, institution, or establishment name: Not Applicable

Combustible solid and liquid wastes disposed of on site, off site, both on and off site. If off site, location of disposal site and/or name of hauler: _____
_____. (If disposal of solid and liquid wastes is partly or wholly on site, complete remainder of this page and Sections IV, V and VI; otherwise, skip to Section IV.)

Normal on-site combustion operating schedule: _____ Hours per day _____ Days per week _____ Weeks per year _____ Hours per year.

Seasonal and/or peak operation period: (Specify) _____

Dates of annually occurring shutdowns of operations: _____ Additional operating information enclosed .

Source Code ^a	Waste Material			Method of Disposal ^d	Installation Date	Hourly Burning Rate, lbs.		Auxiliary Fuel Used ^e	Percent Excess Air Used in Combustion (Design)	Future Disposal ^f
	Type ^b	Amount Per Year ^c	Percent Combustible			Average	Maximum			

- List a separate code number to represent each source (e.g., III-a, III-b, III-c, etc.), then enter required data on this page and for the same code number sources in Section V and VI.
- Rubbish, garbage, mixed garbage and rubbish, waste paper, wood chips or sawdust, etc.
- Tons, pounds, or gallons/year.
- Open burning dump; incinerator, single chamber; etc. (See instructions for examples and use appropriate identification numbers; other non-listed methods, specify.)
- Indicate whether auxiliary fuel is used in incinerators and pit burning, and the amount.
- Estimated increase or decrease in combustible solid and liquid wastes disposal rate for the five years after the calendar year for which this report is completed. If increase is due to new equipment, please list this equipment separately.

NOTE: Please read reverse side of this page. Use additional sheets if necessary. Retain last copy.

Date Report Submitted: _____

**ENVIRONMENTAL PROTECTION AGENCY
AIR POLLUTANT EMISSIONS REPORT**

FORM APPROVED
OMB NUMBER 168-R75

SECTION IV - PROCESS/OPERATIONS EMISSIONS

Plant, institution, or establishment name: _____ Not Applicable

Normal operating schedule: _____ Hours per day _____ Days per week _____ Weeks per year _____ Hours per year.

Seasonal and/or peak operation period: _____

Dates of annually occurring shutdowns of operations: _____ Additional operating information enclosed .

Source Code ^a	Processes or Operations Releasing Pollutants to the Atmosphere ^{b,c,d}	Date Installation Went on Line	Raw Materials Used for Processes or Operations				Products of Processes or Operations				Intermittent Operation Only: Average Hours/week ^h	Future Increase or Decrease in Process Rate
			Type	Quantity			Type	Annual Average ^f	Quantity			
				Annual Average ^f	Hourly Process Rate, lbs.				Hourly Process Rate, lbs.			
					Design	Maximum			Design	Maximum		

- a. List a separate code number to represent each source (e.g., IV-a, IV-b, IV-c, etc.) then enter required data on this page and for the same code number sources in Sections V and VI.
- b. Multiple sources may be grouped if similar in size and type.
- c. Sulfuric acid-contact; aluminum smelting-crucible furnace; cement manufacturing-dry process; etc. (See instruction for examples and use appropriate identification numbers; other non-listed processes and operations, specify.)
- d. The pollutants to be covered in this report are listed in the accompanying instructions.
- e. Sulfur burned; pig, foundry returns, or scrap aluminum melted; limestone, cement rock, clay, iron ore used; etc.
- f. Pounds, tons, gallons, barrels, etc.
- g. Sulfuric acid produced; aluminum ingots produced; cement produced; etc.
- h. For intermittent processes, indicate average number of hours per week of operation so that estimates of yearly emissions may be obtained.
- j. Estimated percent increase or decrease in process rate on a total plant basis for the five years after the calendar year for which this report is completed. If increase is due to new equipment, please list this equipment separately.

NOTE: Please read reverse side of this page. Use additional sheets if necessary. Retain last

Date Report Submitted: July 12, 1978

**ENVIRONMENTAL PROTECTION AGENCY
AIR POLLUTANT EMISSIONS REPORT
SECTION V - AIR CLEANING EQUIPMENT**

FORM APPROVED
OMB NUMBER 158-R

Plant, institution, or establishment name: Pinellas County Resource Recovery Facility

Source Code ^a	Type of Air Cleaning Equipment ^{b,c}	Installation Date ^c	Pollutant Removed ^{c,d}	Efficiency ^e		Inlet Gas Temperature, °F	Inlet Gas Flow Rate, ^f CFM	Exit Gas Pressure, PSI
				Design Percent	Operating Percent			
Unit No. 1	010- (8)	Dec. 1982 (est.)	TSP	96.7%	98.1%	490°F	(10) 174,273 ACFM	0.036
Unit No. 2	010 - (8)	Dec. 1982 (est.)	TSP	96.7%	98.1%	490°F	(10) 174,273 ACFM	0.036

- a. List code numbers corresponding to each emissions source reported in Sections II, III, and IV.
- b. Wet scrubber, electrostatic precipitator, fabric filter, etc. (See instructions for examples and use appropriate identification numbers; other non-listed type, specify.)
- c. Please list future equipment separately.
- d. The pollutants to be covered in this survey are specified in the accompanying instructions.
- e. Give efficiency in terms of pollutant removed.
- f. At actual flow conditions.

NOTE: Please read reverse side of this page. Use additional sheets if necessary. Retain last copy.

Date Report Submitted: July 12, 1978
 Revised September 19, 1978

ENVIRONMENTAL PROTECTION AGENCY
 AIR POLLUTANT EMISSIONS REPORT

FORM APPROVED
 OMB NUMBER 168-R78

SECTION VI - STACK AND POLLUTANT EMISSIONS DATA

Pinellas County Resource Recovery Facility

Plant, institution, or establishment name: _____

STACK DATA							ESTIMATE OF POLLUTANT EMISSIONS:			
Source Code ^a	Height Above Grade ft.	Inside Diameter at Top, ft.	Exit Gas Velocity, ^b ft./sec.	Exit Gas Temperature, ^b °F	Exit Gas Flow Rate, CFM ^c		Pollutants	Quantity		
					Average	Maximum		Tons Per Year	Lbs. Per Hour	
									Average	Maximum
units 1 & 2	161	9'-0"	90.9	480-485	202,960	279,549	TSP (11)	300	60	132
	(See Notes (2) and (8))				SCFM	SCFM	SO ₂ (11)	784	179	247
							NO _x (11)	784	195	269

- a. List code numbers corresponding to each emissions source reported in Sections II, III, and IV.
- b. Values should be representative of average flow conditions for hours of operation.
- c. At actual flow conditions.
- d. The pollutants to be covered in this survey are specified in the accompanying instructions.
- e. Give stack test data if available (indicate stack sampling method used), otherwise, specify basis used. If unknown, please do not complete these columns.

NOTE: Please read reverse side of this page. Use additional sheets if necessary. Retain in file.

APPENDIX A

Reference Notes to EPA Air Pollutant Emissions Report - Pinellas County Resource Recovery Facility

- (1) Each boiler will be down twice per year for routine maintenance. These units will be taken down during periods when solid waste flows are low and the operating unit is capable of meeting the disposal requirements. Scheduled annual down times for Unit 1 are 21 days at the end of June and first of July and 10 days in January. Down times for Unit 2 are 21 days at the end of January and first of February and 10 days in June. On-line availability of the units, based on historical operating experience of other Martin installations in Europe, is over 90%. The unit operations will be a solid function of the refuse flow to the plant. Accompanying data (Appendix B) shows typical solid waste generation variations during 1977.
- (2) The facility will consist of 2 - 1050 ton per day traveling grate boilers designed by the Joseph Martin Company of Munich, Germany. Each unit will be equipped with an electrostatic precipitator and will use a common stack. Steam generated from both units will be used to drive a single 47 MW turbine generator.
- (3) Seasonal percentages were calculated on the basis of waste data collected on refuse quantities and distribution during 1977 (see Appendix B).
- (4) This sulfur content is based upon test data gathered on refuse collected in Pinellas County. These tests were performed by the U. S. Bureau of Mines in Washington, D. C. in January, 1976. The test results are included in this submittal as Appendix C.
- (5) The ash percentage as exited through the ash quench system is estimated at 18.5%. This quenched ash is then diverted to a secondary materials recovery facility where aluminum, ferrous metals, heavy non-ferrous metals, and an aggregate are recovered. The ultimate ash is estimated to be 1.5% (by weight) after this recovery process and this material will be landfilled.


- (6) It is estimated that the average quantities to be processed by the facility would be 530,000 tons per year beginning in 1982. There is a certain amount of excess capacity which would be increasingly used if the solid waste volumes in Pinellas County increase in the future. This increased processing would take place only to the limit of the facility's maximum capability of approximately 766,000 tons per year (during the early 1990's). During the first five years, only a slight increase is expected (less than 2% per year).
- (7) Due to the nature of the project, Sections III and IV (pages 4 and 5) were not applicable.
- (8) Each boiler (2) is equipped with throw-out hoppers under the boiler as well as the economizer. In addition, each boiler has its own electrostatic precipitator (ESP) and both ESP's are connected to a common stack. On the inlet gas side of each ESP there is a perforated screen which insures proper air flow through the ESP as well as acting as a screen to prevent larger particles from entering the electric fields.
- (9) Calculations of the operating efficiencies of the ESP's are included as Appendix D. Also included in this Appendix are results of a particle size distribution analysis performed on a system in design to the facility contemplated here (i.e., Chicago Northwest incinerator combustion train - also substantially designed by the Josef Martin Co. of Germany).
- (10) These values are typical of average inlet flow conditions for each ESP. Flow rate at maximum or design peak levels of operation is 239,948 ACFM. Airflow from both ESP units enter a common stack for which information was included in Section VI.

- (11) Calculations of estimated pollutant discharges are provided in Appendix E. The data used for the basis of the calculations was gathered during actual operation of facilities of similar design (i.e., Josef Martin-type systems) at Harrisburg, Pennsylvania, and Chicago (Chicago Northwest Incinerator).

General Notes

Appendix A of this submittal contains a site map showing approximate location of the stack along with the appropriate location coordinates. Also included in Appendix A is a process flow diagram.

SEASONAL VARIATION



APPENDIX B

APPENDIX C

BUREAU OF MINES ANALYSIS

ST. PETERSBURG COMBUSTIBLES (JAN., 1976)

	<u>BTU/lb</u>	<u>H₂O, %</u>	<u>Ash, %</u>	<u>S, %</u>	<u>Cl, %</u>
Cyclone No. 1 screened and reshredded thru 2 inch.....	7,010	16.8	7.4	0.1	0.4
Cyclone No. 2 screened and reshredded thru 2 inch.....	6,240	19.8	9.7	0.1	0.2
Cyclone No. 3 (minus 2 inch)..	7,200	14.6	6.6	0.2	0.4
Three-state aspirator heavy nonconductors...	4,970	41.9	3.6	0.2	0.3
Jig overflow (putrescibles and yard wastes.	3,480	50.0 ¹	11.5	0.1	0.2
Fine combusti- bles ²	4,860	26.4	20.3	0.1	0.3
Composite, total combustibles....	5,830	25.2	10.3	0.2	0.3
Composite Total.. combustibles (without yard waste)	6,040	24.9	8.3	0.2	0.3

S = Sulfur

Cl = Chloride

APPENDIX D

REVISED SEPTEMBER 19, 1978

CALCULATIONS FOR
EPA PSD PERMIT APPLICATION
(SUBSTITUTED FOR APPENDICES D AND E
OF JULY 12, 1978 SUBMITTAL)

FOR
PINELLAS COUNTY RESOURCE RECOVERY FACILITY

UOP 9/19/78

EMISSION CALCULATIONS

No Electrostatic Precipitator Control

Maximum Hourly Fuel Consumption

Annual Fuel Consumption	730,000 T/Year
Boiler Emission (Uncorrected)	1.654 gr/scf
Boiler Gas Flow	279,549 scfm
Excess Air at Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.654 \times \frac{190}{150} \times \frac{1}{.87} = 2.41 \text{ gr/dscf @ 50\% excess air}$$

Particulate Emission Rate:

$$279,549 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times 2.41 \frac{\text{gr}}{\text{dscf}}$$

= 3966 lb/hr

EMISSION CALCULATIONS

No Electrostatic Precipitator Control

Average Hourly Fuel Consumption

Annual Fuel Consumption	530,000 T/Year
Boiler Emission (Uncorrected)	1.447 gr/scf
Boiler Flue Gas Flow	202,960 scfm
Excess Air at Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%

Boiler Emission Corrected to dscf @ 50% Excess Air

$$1.447 \times \frac{190}{150} \times \frac{1}{.87} = 2.11 \text{ gr/dscf @ 50\% excess air}$$

Particulate Emission Rate:

$$202,960 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times 2.11 \frac{\text{gr}}{\text{dscf}}$$

= 2521 lb/hr

EMISSION CALCULATIONS

Three Field Electrostatic Precipitator

Maximum Hourly Fuel Consumption

Annual Fuel Consumption	730,000 T/Year
Boiler Emission (Uncorrected)	1.654 gr/scf
Boiler Gas Flow	279,549 scfm
Excess Air at Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%
ESP Outlet Dust Loading (Guaranteed)	.08 gr/dscf @ 50% excess air

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.654 \times \frac{190}{150} \times \frac{1}{.87} = 2.41 \text{ gr/dscf @ 50\% Excess Air}$$

ESP Efficiency:

$$\% \text{ Eff.} = \frac{2.41 - 0.08}{2.41} = 96.7\%$$

Particulate Emission Rate:

$$279,549 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times 0.08 \frac{\text{gr}}{\text{dscf}}$$

= 132 lb/hr

EMISSION CALCULATIONS

Three Field Electrostatic Precipitator

Average Hourly Fuel Consumption

Annual Fuel Consumption	530,000 T/Year
Boiler Emission (Uncorrected)	1.447 gr/scf
Boiler Gas Flow	202,960 scfm
Excess Air @ Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%
ESP Outlet Dust Loading	.05 gr/dscf @ 50% excess a:

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.447 \times \frac{190}{150} \times \frac{1}{.87} = 2.11 \text{ gr/dscf @ 50\% Excess Air}$$

ESP Efficiency:

$$\% \text{ EFF} = \frac{2.11 - .05}{2.11} = 97.6$$

Particulate Emission Rate:

$$202,960 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times 0.05 \frac{\text{gr}}{\text{dscf}}$$

= 60 lb/hr

EMISSION CALCULATIONS

Four Field Electrostatic Precipitator

Maximum Hourly Fuel Consumption

Annual Fuel Consumption	730,000 T/Year
Average Hourly Fuel Consumption	83 T/Hour
Boiler Emission (Uncorrected)	1.654 gr/scf
Boiler Gas Flow	279,549 scfm
Excess Air @ Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%
ESP Outlet Dust Loading (Guaranteed)	.04 gr/dscf @ 50% excess air

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.654 \times \frac{190}{150} \times \frac{1}{.87} = 2.41 \text{ gr/dscf @ 50\% excess air}$$

ESP Efficiency:

$$\% \text{ EFF} = \frac{2.41 - 0.04}{2.41} = 98.3\%$$

Particulate Emission Rate:

$$279,549 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times .04 \frac{\text{gr}}{\text{dscf}} = 66 \text{ lb/hr}$$

EMISSION CALCULATIONS

Four Field Electrostatic Precipitator

Average Hourly Fuel Consumption

Annual Fuel Consumption	530,000 T/Year
Average Hourly Fuel Consumption	60 T/Hour
Boiler Emission (Uncorrected)	1.447 gr/scf
Boiler Gas Flow	202,960 scfm
Excess Air @ Boiler Outlet	90%
% Moisture by Volume in Flue Gas	13%
ESP Outlet Dust Loading	.025 gr/dscf @ 50% excess air

Boiler Emission Corrected to dscf @ 50% Excess Air:

$$1.447 \times \frac{190}{150} \times \frac{1}{.87} = 2.11 \text{ gr/dscf @ 50\% Excess Air}$$

ESP Efficiency:

$$\% \text{ Eff.} = \frac{2.11 - .025}{2.11} = 98.8 \%$$

Particulate Emission Rate:

$$202,960 \frac{\text{scf}}{\text{min}} \times .87 \frac{\text{dscf}}{\text{scf}} \times 60 \frac{\text{min}}{\text{hr}} \times \frac{1 \text{ lb}}{7000 \text{ gr}} \times \frac{150}{190} \times .025 \frac{\text{gr}}{\text{dscf}}$$

= 30 lb/hr

II

AIR QUALITY MODELLING AND ANALYSIS
REPORT FOR EPA PSD PERMIT APPLICATION

REVISED SEPTEMBER 19, 1978

AIR QUALITY MODELLING AND ANALYSIS REPORT

FOR

EPA PSD PERMIT APPLICATION

FOR

PINELLAS COUNTY RESOURCE RECOVERY FACILITY

HDR 9/19/78

AIR QUALITY ANALYSIS

PURPOSE - It is the intent of this air quality analysis to identify the nature and characteristics of air emissions generated by the proposed solid waste resource recovery facility and their impacts on ambient total suspended particulate (TSP) and sulfur dioxide (SO₂) concentrations. The calculated consumption of Prevention of Significant Deterioration (PSD) increment by this facility and those pertinent major air pollution sources permitted since January 6, 1975, will also be estimated.

METHODOLOGY - The air quality models proposed by EPA¹ were utilized to calculate existing ambient air pollutant concentrations and the impact on these levels imparted by the proposed facility. Basically, the following dispersion models were applied:

- Climatological Dispersion Model (CDM) - A multiple source model, more apropos to urban areas (as opposed to AQDM); annual arithmetic mean concentrations of TSP and SO₂ are determined based on an inventory of areawide source emissions and local meteorologic conditions. The relative contribution of each source (point and area) at a given receptor site is also determined.

¹EPA UNAMAP-III Series.

- CRSTER - A single source, short term model which identifies first and second maximum 3 hour, 24 hour and annual pollutant emissions for a saturated array of receptors.
- Point Maximum (PTMAX) - A single source model which calculates maximum downwind pollutant concentrations based on a given set of emission and meteorologic parameters.

The CDM model was utilized to determine the nature and sources of ambient TSP and SO₂ concentrations at selected receptor sites surrounding and including the facility. Those receptors chosen for the Pinellas Resource Recovery CDM modeling coincide with intermittent air quality monitors² maintained by Pinellas County.

CRSTER was employed to estimate 3 hour, 24 hour and annual TSP and SO₂ concentrations from the facility. Once the maximum concentration areas or 'hot spots' were determined, additional CRSTER runs of those major sources permitted since January 6, 1975, were completed. For these latter CRSTER runs receptor rings were situated at those 'hot spots' resulting from the proposed facility's emissions. From the model runs the PSD increment consumption by the proposed facility and those other facilities added since the baseline year was rendered. CRSTER models were run using one year's meteorologic data and several plant operating options; specifically:

² Samples every six days, 365 days per year

- TSP, maximum emission rates, controlled (with three field electrostatic precipitators) - PSD 24 hour TSP increment consumption was determined from this run.
- TSP, average emission rates, controlled - PSD annual TSP increment consumption.
- SO₂, maximum emission rates³ - PSD 3 hour and 24 hour SO₂ increment consumption were determined from this run.
- SO₂, average emission rates - PSD annual SO₂ increment consumption were determined from this run.

PTMAX models were run for each of the facility emission characteristics stated above; with this the estimated distances to maximum concentration areas and, consequently, the location of CRSTER model receptor ring distances for each case were determined.

Meteorologic data for the modeling efforts span the 1970-1974 period for the Tampa Airfield station. Due to the proposed location of the facility on a peninsula, the Tampa data were judiciously contrasted and compared to MacDill AFB⁴ meteorologic data to evaluate the impact of such phenomenon as the land-sea breeze effect. The 1974 weather data were input to the CRSTER model.

³ No SO₂ emission controls are proposed

⁴ Also located on a peninsula in Tampa Bay

The emissions of the proposed solid waste resource recovery facility will in no way impact air quality in a Class I maintenance area; the most proximal such area is the Chassahowitzka National Wildlife Refuge situated over fifty miles to the north of the study area.

Based on discussions with federal, state, county and private concerns, and on the analysis and evaluation of existing study area air quality data, background values of 40.0 and 0.0 ug/m³ for TSP and SO₂, respectively, were input to the CDM model.

RESULTS

◦ CDM - While the CDM calculations are quite general with respect to determinations of increment consumption, they do identify the relative contributions of TSP and SO₂ to a given receptor site from each inventoried area and point source. Table 1 summarizes the calculated long-term contribution of TSP and SO₂ for point, area and background sources at those receptors shown in Figure 1. From these data, it is quite apparent that the vast majority of ambient SO₂ concentration and a significant portion of TSP level at all receptors can be attributed to certain point source emitters. Breakdowns of major point sources which most substantially impact the Koger and Airport Receptors⁵ are featured in Tables 2 and 3, respectively.

⁵Closest receptors to site, flanking north and east boundaries.

TABLE 1

RELATIVE CONTRIBUTION OF TSP AND SO₂
TO SELECTED CDM MODEL RECEPTORS

RECEPTOR	UTM Coord.		Point Sources ug/m ³	Area Sources ug/m ³	Background ug/m ³	Total
	X	Y				
Oakhurst TSP SO ₂	323.14	3080.59	0.8 13.4	0.0 0.0	40.0 0.0	40.8 13.5
Largo TSP SO ₂	323.55	3088.85	0.8 9.9	0.1 0.0	40.0 0.0	41.0 9.9
Koger TSP SO ₂	339.85	3082.74	1.4 16.2	0.1 0.0	40.0 0.0	41.5 16.3
Airport TSP SO ₂	333.50	3087.73	1.1 12.4	0.3 0.0	40.0 0.0	41.4 12.5
Woodlawn TSP SO ₂	336.49	3074.28	0.7 12.9	0.0 0.0	40.0 0.0	40.7 13.0
Clearwater TSP SO ₂	329.23	3095.00	1.4 10.1	0.1 0.0	40.0 0.0	41.5 10.2
Site TSP SO ₂	335.26	3084.39	1.1 12.8	0.1 0.1	40.0 0.0	41.2 12.9

TABLE 2

TSP AND SO ₂ CONTRIBUTIONS OF MAJOR SOURCES AT THE KOGER RECEPTOR			
	Source	Contribution ug/m ³	Percent of Total Calculated Pollutant Concentration*
◦ TSP	-Florida Power Corp., Bartow Pipeline Heater	0.49	1.56
	-Florida Power Corp., Higgins Unit #2	0.20	0.63
◦ SO ₂	-Florida Power Corp., Bartow Unit #1	1.76	10.8
	-Florida Power Corp., Bartow Pipeline Heater	1.74	10.7
	-Florida Power Corp., Bartow Unit #3	1.42	8.7
	-Tampa Electric Co.,** Big Bend Unit #1	1.37	8.4
	-Tampa Electric Co.,** Big Bend Unit #2	1.37	8.4
	-Florida Power Corp., Bartow Plant	1.34	8.2
	-Tampa Electric Co.,** Gannon Unit #6	0.87	5.3

* Including all area, point and background sources.

**Distant sources; indiscriminant acceptance of respective contributions for these stacks may compromise model limitations.

TABLE 3

TSP AND SO₂ CONTRIBUTIONS OF
MAJOR SOURCES AT THE AIRPORT RECEPTOR

	Source	Contribution ug/m ³	Percent of Total Calculated Pollutant Concentration*
o TSP	-Florida Power Corp., Higgins Unit #2	0.20	0.63
o SO ₂	-Tampa Electric Co.,** Big Bend Unit #2	1.22	9.79
	-Tampa Electric Co.,** Big Bend Unit #1	1.22	9.77
	-Tampa Electric Co.,** Gannon Unit #6	1.21	9.74
	-Florida Power Corp., Bartow Unit #1	0.68	5.46
	-Florida Power Corp., Bartow Unit #3	0.67	5.38
	-Tampa Electric Co.,** Big Bend Unit #3	0.64	5.12

* Including all area, point and background sources.

**Distant sources; indiscriminant acceptance of respective contributions for these stacks may compromise model limitations.

Generally, it can be stated that most of the SO₂ load at the proposed facility site can be traced to the Florida Power Bartow Plant and the Tampa Electric Big Bend Plant. This latter facility, situated on the eastern shore of Tampa Bay, emits the largest inventoried volume of SO₂ in the region; however, the large distance between the Big Bend Plant and the CDM receptors (upwards of 35.0 KM) should dissuade a prudent analyst from making dubious assumptions. Another large SO₂ source, the Florida Power Anclote Plant, emits that pollutant at a rate of 1631.9 grams per second; however, the northwesterly orientation and considerable distance from the power plant to the proposed facility, coupled with actual meteorologic conditions limit the impact of the Anclote emissions on the study area. Point sources contributing the most to TSP concentrations at the evaluated receptors are the Florida Power Higgens Unit #2, and the Florida Power Bartow Pipeline Heater.

◦ PTMAX - The PTMAX model was run utilizing those input variables shown on page 3; for each facility pollutant and emission rate the locations of areas of maximum concentrations were determined. For all model runs maximum concentration areas were generally located in the following distance ranges (kilometers): 0.80-0.90, 1.4-1.7, 2.5-3.5, 4.0-6.5, and 16.0-19.0. It should be noted that the validity of the 16.0-19.0 kilometer range is highly questionable as it is

doubtful that the input atmospheric stabilities persist at those distances; consequently, while those distances will be input to CRSTER as the outer receptor ring, the resulting calculations will be viewed with appropriate discretion.

o CRSTER - The facility operating options and stack data input to the CRSTER model are shown in Table 4; these data are extracted from the EPA air emission source construction and operation permit. The maximum pollutant concentrations and affected receptor locations for each CRSTER run is featured in Table 5. With respect to these modeling results, the following conclusions relative to the emission dispersal characteristics of the proposed facility are offered:

- Maximum SO₂ and TSP concentrations occurred primarily from 1.0 to 6.5 kilometers out from the stack site; maximum concentrations at more distant receptors were infrequent (less than 11 days per 365 days, average; no receptor at such a distance recorded a maximum in the top 50 readings for any model run).
- Maximum concentrations were recorded primarily during unstable meteorologic conditions; that is, the highest concentrations for SO₂ and TSP were noted during the noon to evening period during the summer and fall months. This phenomenon is no doubt attributable to

TABLE 4

EMISSION CHARACTERISTICS OF VARIOUS CRSTER MODEL RUNS	
	Emission Rate GM/Sec.
Maximum TSP, Controlled	<u>16.506</u>
Average TSP, Controlled	7.50
Maximum TSP, Uncontrolled	<u>499.71</u>
Maximum SO ₂	31.120
Average SO ₂	22.55
Stack Data	
Height (Meters)	49.07
Diameter (Meters)	2.74
Maximum Gas Exit Velocity (Meters/Sec.)	38.16
Average Gas Exit Velocity (Meters/Sec.)	27.72
Exit Gas Temperature (Degrees K)	521.89

TABLE 5

SYNOPSIS OF CRSTER MODEL RUNS				
	Max (UG/M ³)	Distance (KM)	Direction (°)	Allowable PSD Incr. UG/M ³
TSP, Max. Controlled 24 hour	<u>1.69</u>	<u>2.0</u>	<u>90</u>	<u>37</u>
TSP, Avg. Controlled Annual	0.09	3.0	90	19
TSP, Max. Uncontrolled 24 hour	<u>51.03</u>	<u>2.0</u>	<u>90</u>	--
Annual	<u>4.32</u>	<u>3.8</u>	<u>90</u>	--
SO ₂ , Max. 3 hour	12.82	1.9	270	512
24 hour	3.21	3.0	90	91
SO ₂ , Avg. Annual	0.29	2.0	90	20


the high exit temperature of the facility emissions and their ability to penetrate such stable situations as a temperature inversion layer. The mixing of exit gases in a more unstable atmosphere is characterized by both upward and downward plume dispersal, hence the recording of maximum concentrations during these periods.

- The maximum values recorded for the resultant concentration from facility emissions are quite small and, by themselves, do not violate the allowable PSD increment for any situation with each pollutant.

Figures 2 through 6 illustrate the isopleths of maximum concentration for each pollutant and averaging time; specifically, with receptor ring distances designated, these are:

- Figure 2 - TSP, Annual Maximum Mean Concentrations; Ring Distances at 0.85, 1.60, 3.00 and 5.00 KM.
- Figure 3 - TSP, 24 Hour Maximum Concentrations; Ring Distances at 1.5, 2.0, 3.58 and 6.20 KM.
- Figure 4 - SO₂, 3 Hour Maximum Concentrations; Ring Distances at 0.90, 1.85, 3.00 and 5.00 KM.
- Figure 5 - SO₂, 24 Hour Maximum Concentrations; Ring Distances at 0.90, 1.85, 3.00 and 5.00 KM.
- Figure 6 - SO₂, Annual Maximum Mean Concentrations; Ring Distances at 0.85, 1.60, 2.00 and 5.00 KM.

CALCULATED MAXIMUM ANNUAL MEAN TSP
CONCENTRATION ($\mu\text{g}/\text{m}^3$), TO 5.0 KILOMETERS







 0.04 - 0.09 $\mu\text{g}/\text{m}^3$

FIGURE 3
CALCULATED MAXIMUM 24-HOUR TSP CONCENTRATION ($\mu\text{g}/\text{m}^3$)



 1.1 - 1.7 $\mu\text{g}/\text{m}^3$

CALCULATED MAXIMUM 3-HOUR SO₂ CONCENTRATION
(ug/m³) TO 5.0 KILOMETERS






 9.0 - 12.0 ug/m³


FIGURE 5

CALCULATED MAXIMUM 24 HOUR SO₂ CONCENTRATIONS,
ug/m³ TO 5.0 KILOMETERS



CALCULATED MAXIMUM ANNUAL MEAN SO₂ CONCENTRATION
(ug/m³), to 5.0 KILOMETERS



 0.16 - 0.29 ug/m³

As previously cited, the readings recorded at distant receptors (greater than 15.0 KM) are viewed with some caution due to meteorologic factors; in addition, few maximum readings were calculated at these receptors. Consequently, the isopleths shown in Figures 2 through 6 are exclusive of the outer receptor ring.

◦ Other Major Sources Permitted Since January 6, 1975 -

The area and point source emissions inventory, utilized for the CDM model, was submitted to the Florida Department of Environmental Regulation (Tampa), the Pinellas County Department of Environmental Management and the Hillsborough County Environmental Protection Commission so that their guidance concerning the selection of post-baseline permitted facilities would be received. Based on such input, the following sources have been designated as being permitted since January 6, 1975:

- Florida Power, Anclote - SO₂ and TSP
- Florida Power and Light, 2 Units at Willow Point - SO₂ and TSP
- Nord Southern Dolomite - SO₂ only
- Gardiniers, 1 Unit - SO₂ only
- Chloride Metals, 1 Unit - SO₂ only
- Tampa Electric, Big Bend - SO₂ and TSP

For each of these facilities and respective major emissions a CRSTER model was run with receptor ring distances coinciding with the 'hot spots' from each pollutant generated by

the proposed facility. Maximum readings recorded within these 'hot spots' from both the post-baseline source and the proposed facility will be utilized to estimate increment consumption. As meteorologic data for plume dispersal is randomly generated by the CRSTER model, the values obtained should not be taken as real-case situations; rather, they represent a worst case condition at a particular receptor and point in time. Furthermore, it should be clearly understood that the accuracy of the CRSTER model at distances greater than 15.0 KM becomes highly suspect as the probability for identical meteorologic conditions over such distances (as the model assumes) is very unlikely.

Table 6 features the pertinent data input to CRSTER for each 'new' major source.

- PSD Increment Consumption - Again, increment consumption by both the proposed resource recovery facility and those major sources permitted since January 6, 1975, were determined by inputting maximum, allowable emission rates for each source into the CRSTER model.

For the proposed facility the magnitude of increment consumption is featured in Table 5: those CRSTER results for the other major sources are shown in Table 7.

TABLE 6

MAJOR AIR EMISSION SOURCES PERMITTED SINCE
JANUARY 6, 1975, AND RELEVANT CRSTER INPUT DATA

Source	Emissions		Stack Data			
	SO ₂ (GM/Sec)	TSP (GM/Sec)	Height (M)	Diameter (M)	Flow (M/Sec)	Temp. (°C)
◦ Florida Power Corp., Anclote (Pasco County)	1631.9	58.08	152.1	3.66	49.95	143.3
◦ Florida Power & Light, Willow Point (Manatee Co.)	438.69	39.98	152.0	6.97	26.7	151.7
◦ Florida Power & Light, Willow Point (Manatee Co.)	666.2	37.71	152.0	8.05	20.7	151.7
◦ Nord Southern Dolomite (Manatee Co.)	3.22	0.22	16.76	1.22	12.9	76.7
◦ Gardiniers (Hillsborough County)	13.86	0.0	45.4	2.74	11.6	70.6
◦ Chloride Metals (Hillsborough County)	7.19	0.06	20.9	0.61	12.1	80.6
◦ Tampa Electric Co., Big Bend (Hillsborough County)	1153.0	10.32	149.4	4.57	33.0	137.0

TABLE 7

MAXIMUM CALCULATED CONCENTRATION ($\mu\text{g}/\text{m}^3$)
 FOR EACH 'NEW' SOURCE MAJOR EMISSION
 WHICH COINCIDES WITH PROPOSED FACILITY 'HOT SPOTS'

Major Source Permitted Since 1/6/75	SO ₂ 3 Hour	SO ₂ 24 Hour	SO ₂ Annual	TSP 24 Hour	TSP Annual
Anclote	36.7	10.4	0.63	0.40	0.023
FPL Willow (Both Units)	17.4	3.80	0.39	0.37	0.030
Nord	1.77	0.22	0.01	NA*	NA*
Teco Big Bend	47.23	13.48	1.02	0.12	0.009
Gardiniers	5.84	1.59	0.10	NA*	NA*
Chloride	5.81	1.63	0.09	NA*	NA*

* Not a major (greater than 100 tons per year) emission.

To simply sum the increment consumption by each source to determine the remaining increment would be unsound. Since, as stated before, the post-baseline source modeling values obtained are construed as being worst case situations, they are, therefore, overestimates. However, it is quite obvious that even when utilizing these very high readings, the construction and operation of the proposed facility will not violate the allowable PSD increment at any averaging time for either pollutant. Specifically:

	<u>SO₂</u> <u>3 Hour</u>	<u>SO₂</u> <u>24 Hour</u>	<u>SO₂</u> <u>Annual</u>	<u>TSP</u> <u>24 Hour</u>	<u>TSP</u> <u>Annual</u>
Proposed Facility Increment	12.82	3.21	0.29	<u>1.69</u>	0.09
Other Source Increment	<u>114.75</u>	<u>31.12</u>	<u>2.25</u>	<u>0.77</u>	<u>0.053</u>
Total	127.57	34.33	2.54	<u>2.46</u>	0.14
Allowable	512	91	20	37	19

III

BEST AVAILABLE CONTROL TECHNOLOGY (BACT)

REPORT AND SUMMARY

PARTICULATE REMOVAL DEVICES FOR PINELLAS COUNTY

Particulate matter can be removed from stack effluent (flue gas stream) by using electrostatic precipitators, bag houses or wet scrubbers. To our knowledge, only electrostatic precipitators and scrubbers have been successfully utilized on incinerators. Electrostatic precipitators, commonly called esp's, were selected for this project due to their superior performances on incinerators and power plants in the United States and particularly on incinerators throughout Europe where particulate emission regulations are often more stringent than those existing in the United States.

Several advantages and disadvantages of the three removal methods are presented below.

ELECTROSTATIC PRECIPITATORS

1. Proven efficiencies as high as 99.9%
2. High reliability due to no moving parts within the flue gas stream. Some moving parts are present in certain designs.
3. Capable of handling high flue gas temperatures (in excess of 1000°F) and large fluctuations in flue gas volumes and temperatures.
4. Low pressure drop through units.
5. Fully automatic controls for consistent electrical operation.

6. Low operating cost.
7. Long term unattended operation.
8. Not particle size limited
9. Can be dry or wet installations

BAG HOUSES

1. Efficiencies of 99.9% can usually be obtained, but have not been proven on incinerators.
2. High power requirements.
3. Low reliability due to wear and tearing of fabric filters.
4. Higher pressure drops through units, thereby requiring more power to operate.
5. Temperature limited.
6. Capital costs usually higher than esp's.
7. Operating costs higher than esp's.
8. Require large structures.
9. Require special materials for specific gas compositions.
10. Subject to fines.
11. Very sensitive to humidity in Flue Gas

WET SCRUBBERS

1. Were developed to remove gaseous compounds, not particulate matter. They do remove particulates, but require excessive power inputs for high efficiencies than obtained with the former methods.
2. Large quantities of water used in the scrubbing process add considerable moisture to the flue gas, which causes the formation of heavy water vapor plumes.
3. Operating costs high due to power required.
4. Not as reliable as esp's and bag houses.
5. Water disposal problem.
6. Sludge disposal problem.

Submittal to EPA Regional Office

Subject: Pinellas County

Solid Waste Resource Recovery Facility

Reference: Proposed & Alternative Best Available
Control Technology (BACT)

Electrostatic Precipitator

In accordance with a request received from the U. S. Environmental Protection Agency UOP Inc. submits herewith an analysis of the Best Available Control Technology (BACT) regarding the Electrostatic Precipitators for the above referenced project.

The analysis was made in accordance with the guidelines of June 14th as prepared by the Office of Air and Waste Management of the U. S. E. P. A. and is limited to the performance of the proposed and alternative electrostatic precipitators for this project.

The plant performance is based on the capacity rating indicated below.

Table 1

Theoretical annual throughput	$\frac{\text{tons}}{\text{year}}$	730,000
Daily throughput (365 days)	$\frac{\text{tons}}{\text{day}}$	2,000
Hourly throughput rating	$\frac{\text{tons}}{\text{hour}}$	83.33
Number of boiler-incinerator units		2
Unit capacity	$\frac{\text{tons}}{\text{hour}}$	41.66
" "	$\frac{\text{tons}}{\text{day}}$	1000

The ESP proposal is designed for an exit dust loading of 0.08 gr./DSCF to meet the existing federal standard for incinerators.

The alternative ESP as described in this report is designed for an exit dust loading of 0.04 gr./dscf.

The precipitator performance is outlined on the enclosed electrostatic precipitator analysis chart prepared to conform to the BACT guide lines.

In the following, the difference for Energy, Environmental and Economical Impacts is analyzed and where necessary further clarified.

- I Energy Impact for further clarification see table 1.
- A₁) Energy required for ESP due to installation of the 4th field the electric power requirement increases proportionally from 388 KWH to 474 KWH.
- A₂) Energy required for I. D. fan due to the installation of the 4th field the draft loss resistance is increased from 0.50" to 0.67" W. C. and consequently increases the power required to operate the induced draft fan.
- B) Impact on scarce fuels: - none
- C) Impact on locally available coal: - none
- D) Energy production impact
- Unavailable energy: - indicates the increase in power required to operate the 4 field ESP as well as the additional fan power required to overcome the increase in draft loss.

This power required must be directly deducted from the energy generated at the turbo-generator.

system reliability: - reflects the operational availability of the ESP and may be slightly better for the 4 field EPS than with the 3 field due to the better availability with 4 fields than 3.

Such outages fall of course within the scheduled outages of the boiler and stoker and may therefore be disregarded.

II Environmental Impact

A.) Air pollution impact

The particulate loading discharge with the gas stream into the atmosphere at maximum hourly fuel consumption is reduced from 131.0 to 66.0 = 65.0 lb/hr (730,000 T/YR) and results in a lower rate of air contamination for the 4 field ESP.

B.) Water pollution impact - none

water is not used in the ESP or in the fly-ash removal system

C.) Solid Waste disposal impact

The fly-ash is returned to the residue discharge duct from the incinerator for disposal together with the incinerator residue.

D.) Irreversible & Irretrievable

Commitment of Resources

With the 3 field ESP the dust loading into the atmosphere is increased by the values indicated.

E.) Other environmental impacts

Noise level none

Radiant Heat Loss: The ESP casing is heavily insulated to prevent cooling and condensing effect by prevailing winds and rain. The radiant heat loss is therefore minimal.

III Economic impact

A.) Direct economic impact on plant

1.) Direct costs

The costs for the 4 field ESP over those for the 3 field ESP are considerably higher due to the furnishing of the 4th field equipment with casing, electrical equipment as well as its erection. Also the fan static pressure has to be increased. Additional land area is required as well as an added section for fly-ash conveyance. The greater casing surface and equipment will need additional maintenance and the operation of the 4th field requires additional operation supervision for rappers. The difference in maintenance costs for the increased I. D. fan size may be minimal but should not be overlooked.

Capital availability

A breakdown of the individual costs is shown and indicates the additional capital requirements for the installation and operational costs of a 4th ESP field.

ELECTROSTATIC PRECIPITATORPROPOSED AND ALTERNATE BEST AVAILABLE CONTROL TECHNOLOGY (BACT)

ITEM	IMPACT ANALYSIS	Proposed	Alternate
I	Energy Impact	3 Field Precipitator	4 Field Precipitator
A	<u>Direct Energy Impact</u>		
	Source of Energy for ESP	In Plant Generation	In Plant Generation
	Source of Energy for I.D.Fan	In Plant Generation	In Plant Generation
	Plant Capacity T/Hr	83.3	83.3
	T/Yr	730,000	730,000
	Particulate Emissions-Design GR/DSCF	0.08	0.04
	Energy required for ESP KWH	388.0	474.0
	Energy Required for I.D.Fan KWH	231.17	237.88
	Draft Loss Through ESP IN. W.C.	0.50	0.67
	Fly-Ash Entering ESP Lb/H	3966	3966
	Leaving ESP to Stack Lb/H	131	66
	Recovered Lb/H	3835	3900
B.	Impact On Scarce Fuel Oil	None	None
C.	Impact on Locally Available Coal	None	None
D.	<u>Energy Production Impact</u>		
	Unavailable Energy KWH		92.71
	System Reliability		
	% Normal Availability	95.0	95.0
	% Scheduled Outage	4.0	4.0
	% Emergency Outage	1.0	1.0

ELECTROSTATIC PRECIPITATORPROPOSED AND ALTERNATE BEST AVAILABLE CONTROL TECHNOLOGY (BACT)

ITEM	IMPACT ANALYSIS	Proposed	Alternate
		3 Field Precipitator	4 Field Precipitator
II	<u>Environmental Impact</u>		
	Plant Capacity T/Hr	83.33	83.33
	T/Yr	730,000	730,000
	Particulate Emission GR/DSCF	0.08	0.04
A.	<u>Air Pollution Impact</u>		
	Stack Emissions		
	Particulate Lb/Hr	131	66
	Dry Gas Tons/Hr	582	582
	Moisture Tons/Hr	53	53
	Total Gas-Net Tons/Hr	635	635
B.	<u>Water Pollution Impact</u>		
C.	<u>Solid Waste Disposal Impact</u>		
	Fly Ash Entering Stack Gas Ton/Hr	0.0655	0.033
	Fly Ash Recovered Ton/Hr	1.9175	1.950
	Total Fly-Ash Ton/Hr	1.9830	1.983
D.	<u>Irreversible & Irretrievable</u>		
	Commitment of Resources		
	Increase in Air Pollutants Lb/Hr.	65	-
E	<u>Other Environmental Impacts</u>		
	Noise Level	None	None
	Radiant Heat Loss	Minimal	Minimal

ELECTROSTATIC PRECIPITATOR

PROPOSED AND ALTERNATIVE BEST AVAILABLE CONTROL TECHNOLOGY (BACT)

Item	Impact Analysis	Proposed	Alternative
	Air Quality	3 Field Precipitator	4 Field Precipitator
	Plan Capacity T/Hr	83.33	83.33
	T/Yr	730,000	730,000
	Particulate Emission GR/DSCF	0.08	0.04
III	Economic Impact		
A	Direct Economic Impact on Plant		
	1.) Direct Cost		
	<u>Added Capital Costs</u>		
	(UOP Budgetary Estimate)		\$ 712,000.-
	Sales tax, Insurance, Permits & Fees		\$ 43,000.-
	Financing Costs (23.4%) (HDR estimate not guaranteed by UOP)		<u>\$ 177,000.-</u> \$ 932,000.-
	Debt Service per Year 9.08% (HDR estimate not guaranteed by UOP)		\$ 84,600.-
	Debt Service per Ton (Based on 530,000 tons per year)		\$0.16
	<u>Added Operating & Maintenance Costs</u>		
	per Year (UOP Budgetary Estimate)		\$ 11,000.-
	O & M Costs per Ton (Based on 530,000 Tons per year)		\$0.02

UOP

	<p>County's Decreased Revenue Per Year</p> <p>First Year at 21.9 Mills Per KWH</p> <p>Decreased Revenue per Ton (Based on 530,000 Tons per year)</p>		<p>\$ 12,000</p> <p>\$0.02</p>
--	--	--	--------------------------------

B	Local Economic Impact	none	none
---	-----------------------	------	------

EXHIBIT 1

◦ Fourth Field Electrostatic Precipitator

By utilizing the single source CRSTER model, the environmental effectiveness of a fourth ESP field for the proposed facility's TSP emissions can be estimated.

Calculations reveal that given identical stack data as designated for the facility with a three field precipitator (see Table A), the emission rate for particulate matter will be 7.182 grams per second; this represents a 30% reduction in TSP emissions over the identical facility, but with a three field ESP.

Table A compares the results of CRSTER model runs for the proposed facility for both a three field and four field electrostatic precipitator.

TABLE A

	3 Field ESP	4 Field ESP
<u>Stack Data</u>		
◦ Height (m)	49.07	49.07
◦ Diameter (m)	2.74	2.74
◦ Exit Velocity (m/sec)	38.16	38.16
◦ Gas Temperature (°K)	521.89	521.89
◦ Volumetric Flow Rate	225.53	225.53
<u>Emissions Data</u>		
◦ Rate (g/sec)	10.332	7.182
◦ Maximum Calculated Annual Concentration	0.092	0.064
◦ Maximum Calculated 24 Hr. Concentration	0.974	0.677

While the reduction in ambient maximum concentrations with the fourth field is nearly 30%, the magnitude of all pollutant levels involved is quite insignificant. With respect to the allowable PSD increment, the proposed facility will consume a minimal amount of increment. Specifically:

Pollutant	Allowable Increment (ug/m ³)	3 Field ESP Increment Consumption (ug/m ³)	4 Field ESP Increment (ug/m ³)	Other* Source Increment (ug/m ³)
TSP Annual	19	0.09	0.06	0.53
TSP 24 Hour	37	0.97	0.68	0.77

* Based on individual CRSTER runs on those major sources permitted since January 6, 1975; other source increment is maximum reading recorded at maximum concentration receptor for the resource recovery facility.

BEST AVAILABLE CONTROL TECHNOLOGY (BACT)

SELECTION RATIONALE

Pinellas County is committed to a solid waste, resource recovery program because of both practical and philosophical reasons. Practically speaking, this densely populated area with low elevations and high ground water has little space left for landfilling activities. As landfilling costs rise to meet State Department of Environmental Regulation (DER) requirements, the system proposed by UOP becomes more cost competitive. Being an urban area with a progressive philosophy, the goal to eliminate the various forms of pollution emanating from landfills while reclaiming the energy and material to be extracted from a modern solid waste system, is high on our list.

Part of the BACT analysis, was to keep these concerns in mind while attempting to insure that the economic viability of the project was not weakened.

Reviewing the energy impact showed that the 4 field ESP does use somewhat more electrical energy during operation but the amount is not significant when compared to the overall size of the project. Environmentally, the system provides a huge improvement over landfilling regardless of whether a 3 or 4 field ESP is installed. The only drawback is some slight pollution from stack emission. Even this impediment is a substantial improvement over standard power plant stack emissions as a result of using garbage as a fuel.

On an ESP loading basis, checking TSP only, there is an admitted 30% reduction in emissions from a 4 field ESP configuration. This appears to be a substantial reduction; however, both the 3 and 4 field configurations were-

analyzed using the single source CRSTER model to predict air quality impacts (see Exhibit 1). In reviewing the predicted impacts, it can be seen that there is a consistent 30% reduction in the incremental consumption for both the annual and the 24 hour intervals, when using the 4 field rather than 3 field unit. On the other hand, it should be noted that the levels of impact as predicted by the CRSTER model for the 3 field ESP (see "Air Quality Analysis") were not very significant. From an actual monitoring standpoint, the difference between the two sizes may be difficult to detect with the sampling equipment used to measure the selected pollutants.


The major impact on the project, definitely centers on economics. The difference in total costs between the 3 and 4 unit configurations is \$932,000. This is a substantial amount of money, especially when considered within the parameters of what small difference in effect the extra field would have on air emission control.

Briefly stated, the 3 field precipitator was chosen as Best Available Control Technology (BACT) by Pinellas County for its Resource Recovery System because:

- a. Experience at the Chicago Northwest Incinerator, a facility similar to the one proposed here, has operated effectively since 1971 in compliance with the emission standards promulgated by EPA.
- b. The substantial additional cost of a fourth field does not appear justified in comparison to the relatively small improvement to emission control to be anticipated from such an installation.

Pinellas County Resource Recovery Project

Application For Power Plant Site Certification




July 1983

HDR

Henningson, Durham & Richardson

RECEIVED
AUG 03 1983 54143
PINELLAS COUNTY
SOLID WASTE SYSTEM




BOARD OF COUNTY COMMISSIONERS

COMMISSIONERS

BARBARA SHEEN TODD, CHAIRMAN
JOHN CHESNUT, JR., VICE-CHAIRMAN
GABRIEL CAZARES
CHARLES E. RAINEY
BRUCE TYNDALL

DEPARTMENT OF SOLID WASTE MANAGEMENT
2800 110TH AVENUE NORTH
ST. PETERSBURG, FLORIDA 33702
PHONE (813) 825-1565

P.O. Box 21623
St. Petersburg, FL 33742-1623



June 28, 1983

State of Florida
Department of Environmental Regulation
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, FL 32301

ATTN: Mr. Hamilton Owen

Re: Application for Power Plant Siting Certification (PPSC), Phase II

Gentlemen:

The document enclosed herewith is Pinellas County's Phase II application for an electrical power plant siting certification, submitted in accordance with Florida Department of Environmental Regulation Chapter 17-17 Rules.

Hopefully, the information contained herein provides all that is necessary to permit a through evaluation of our application. If, however, you find that additional data is required, please contact me at your earliest convenience.

Activities covering our application to the Public Service Commission for a Certificate of Need are underway at this time.

Also enclosed is our check for \$25,000.00 to cover the application fee.

Sincerely,

D. F. Acenbrack, Director
Solid Waste Management

ACE:lhl
Encl

PINELLAS COUNTY RESOURCE RECOVERY FACILITY

APPLICATION FOR POWER PLANT SITING

Table of Contents

Pertinent Applicant Information

- 1.0 - Purpose of the proposed facility
- 2.0 - The site
- 3.0 - The plant
- 4.0 - Environmental effects of site preparation
- 5.0 - Environmental effects of plant operation
- 6.0 - Environmental measurements and monitoring programs
- 7.0 - Economic and social effects
- 8.0 - Alternative energy sources
- 9.0 - Alternative plant design

APPENDICES

- A. Air quality analysis
 - A-1. Visibility analysis
 - A-2. Mass burn emission factors

PERTINENT APPLICANT INFORMATION

Company or Applicant's
Official Name: Pinellas County

Address: 315 Court Street
Clearwater, Florida 33516

Address of Official Headquarters: Same

Business Entity: County Government

Name and Title of Business Head: Barbara Sheen-Todd, Chairman of
Board of County Commissioners

Name, Title and Address of Official
Representative Responsible for
Obtaining Certification: Gene Jordan, Director
Public Works and Utilities
315 Court Street
Clearwater, Florida 33516

Site Location: Pinellas County

Nearest Incorporated City: Pinellas Park

Latitude & Longitude: 27°52' N, 82°40' W

UTMs Northerly: 3084.1

UTMs Easterly: 335.2

Name Plate Generating Capacity
Existing: 50.1 MW

Proposed: Additional 29 MW

Remarks: Pinellas County does not operate,
maintain, or construct facilities for
the purpose of electric generation.
Neither does Pinellas County
distribute electrical energy generated
at facilities operated by others. The
sole purpose of the proposed addition
is to dispose of solid waste and
recovery energy and materials. The
proposed addition will afford Pinellas
County a more flexible method of
solid waste disposal which will
substitute for the present landfilling
operations.

CHAPTER I
PURPOSE OF THE FACILITY

1.0 The Resource Recovery Facility (RRF) was planned and constructed as the ultimate solution to solid waste disposal in Pinellas County, Florida. Since the submittal of the site application for the original two boiler plant in 1978, refuse generation rates have risen faster than was anticipated. To meet the added demand on the processing capacity of the plant an additional boiler is needed.

The capacity afforded by the third boiler will minimize the landfilling of Class I solid waste in the future; this is the stated policy of the Board of County Commissioners, Pinellas County, Florida. Based on current estimates, all Class I material can be incinerated by a three boiler plant through 1996.

CHAPTER 2 THE SITE

2.1 Changes in Site Location and Layout

This proposal involves no substantial changes in land use. Figure 2-1 shows the existing facility and the proposed additional equipment. The battery limits of the plant will not be enlarged. The electrical generation capacity will be increased by 29 megawatts (MW).

2.2 Changes in Regional Demography, Land and Water Use

Pinellas County continues to be one of the most densely populated of all Florida Counties. Since the original PPSC application in 1978 the four cities adjacent to the site (St. Petersburg, Largo, Pinellas Park and Kenneth City) have all increased their boundaries by annexation. Those increases that are within a five-mile radius of the Facility are indicated in Figure 2-2. The resident populations (1970 and 1980 census) for the above cities and for the rest of the County are listed in Table 2-1. Figure 2-3 shows solid waste generation projected through 2001.

The present and projected land use within the five-mile radius is essentially the same as it was previously. The one notable change is the area within about two miles which is becoming more industrialized, and this change is reflected in the latest land use and zoning plans prepared by the County and the various municipalities. Figures 2-4 and 2-5 show the changes in the zoning between the original application and the present.

The proposed changes at the RRF will increase non-potable water consumption by 50%. Existing water mains from the St. Petersburg and Largo reclaimed water sources are capable of conveying the added flow.




FIGURE 2-1

FENCE
 TRACK
 HIGH
 FIVE
 AIR TO
 SELF
 WALL

PINELLAS COUNTY
 SOLID WASTE OPERATION PLAN


Table 2-1

Pinellas County, Florida

1970 and 1980 Census Counts


	<u>Resident Populations</u>		Percent Change
	1970	1980	
Belleair	2,962	3,673	24.0
Belleair Beach	952	1,643	72.6
Belleair Bluffs	1,910	2,522	32.0
Belleair Shores	124	80	(35.5)
Clearwater	52,074	85,528	64.2
Dunedin	17,639	30,203	71.2
Gulfport	9,976	11,180	12.1
Indian Rocks Beach	2,666	3,717	39.4
Indian Shores	791	981	24.4
Kenneth City	3,862	4,344	12.5
Largo	24,230	58,977	143.4
Madeira Beach	4,177	4,520	8.2
North Redington Beach	768	1,156	50.5
Oldsmar	1,538	2,608	69.6
Pinellas Park	22,287	32,811	47.2
Redington Beach	1,583	1,708	7.9
Redington Shores	1,733	2,142	23.6
Safety Harbor	3,103	6,461	108.2
St. Petersburg	216,159	238,647	10.4
St. Petersburg Beach	8,024	9,354	16.6
Seminole	2,121	4,586	116.2
South Pasadena	2,465	4,188	69.9
Tarpon Springs	7,118	13,251	86.2
Treasure Island	<u>6,120</u>	<u>6,316</u>	<u>3.2</u>
Total Incorporated	394,382	530,599	34.5
Total Unincorporated	<u>127,947</u>	<u>197,932</u>	<u>54.7</u>
Total County	<u>522,329</u>	<u>728,531</u>	<u>39.5</u>


Source: U.S. Department of Commerce, Bureau of the Census, 1980 Census of Population and Housing - Florida, Advanced Reports (PHC80-V-11).



ANNEXATION CHANGES

FIGURE 2 - 3
SOLID WASTE PROJECTIONS






LEGEND

A- AGRICULTURAL C-COMMERCIAL M-MANUFACTURING, INDUSTRIAL
 RL- LOW DENSITY RESIDENTIAL RM-MEDIUM DENSITY RESIDENTIAL
 P- PUBLIC

ORIGINAL ZONING IN THE STUDY AREA.



LEGEND

A- AGRICULTURAL C-COMMERCIAL M-MANUFACTURING, INDUSTRIAL
 RL- LOW DENSITY RESIDENTIAL RM-MEDIUM DENSITY RESIDENTIAL
 P- PUBLIC

CHANGES OF ZONING IN STUDY AREA

2.3-2.7 No changes from original application

2.8 Ambient Air

See Section 3.7

2.9 Other Environmental Features

No additional factors to be added.

CHAPTER 3 THE PLANT

3.0 The Plant

The expansion features a third Martin combustion unit capable of handling 1050 tpd of solid waste at 5000 Btu/#. Two additional cells will be added to the cooling tower system and a 29 MW (gross) turbine-generator will be installed adjacent to the existing one. A new 161 ft. stack will be constructed just north of the one present. There will be minimal changes to other parts of the facility as needed by the third unit.

3.1 Changes in External Appearance

Figure 2.1 shows a plot plan with the changes as planned for the facility. The visible changes include the second stack, an additional turbine-generator, the expanded cooling tower, and the boiler house. The figure also shows the construction that has taken place since the original application was submitted.

3.2 Fuel

The facility will be capable of handling up to 22,050 tons of solid waste per week, an increase of 7,350 tons. The third unit will allow for higher available capacity during times of maintenance or other unit shutdown. Solid waste projections are shown on Figure 2-3.

Based on operations at the existing RRF, the average composition of incoming solid waste to the plant is 85% Class I (garbage), 5% Class III material which is processible (P), 5% Class III material which is not processible (NP), and 5% construction debris (not requiring DER permit). Six categories of boiler discharges are generated at the average rates listed below:

1. Ferrous metals	88 tpd
2. Aluminum	6 tpd
3. Heavy non-ferrous.	3 tpd
4. +10" Iron	18 tpd
5. Aggregate	460 tpd
6. 2-10" non-magnetic	15 tpd

3.3 Plant Water Use Changes

Figure 3-1 presents the revised design water use rates for normal and peak load operation of the facility with the addition of the third unit.


3.4 Heat Dissipation System Changes

Flow will increase from 33,400 gpm to 50,100 gpm, and the heat rejection load will increase from 450,000,000 BTU/hr to 675,000,000 BTU/hr. Table 3-1 shows the typical analysis of the cooling tower supply waters. A preliminary water quality review of the makeup water potential of stormwater indicates it to be lower in dissolved solids, but high in suspended solids.

3.4.1 - No changes from the original application.

3.4.2 Source of Cooling Water

Cooling tower make-up water is now obtained from the City of St. Petersburg Northeast Advanced Wastewater Treatment Plant (AWT). A second source from the City of Largo AWT will be available in the near future. Another source contemplated is the storm water runoff from the resource recovery site. Quantities available from (1) and (2) are sufficient to supply the requirements individually. The Largo supply will ultimately be the primary source and the St. Petersburg system used as back-up. Use of stormwater runoff in the towers would be intermittent and based



SUMMARY WATER FLOW DIAGRAM
(BASED ON USING LARGO WATER)

Table 3-1
 Chemical Characteristics of Facility
 Cooling Water Influent

<u>Chemical Constituent</u>	<u>Potable Supply Pinellas County</u>	<u>Non-Potable Supply 1 Largo STP</u>	<u>Non-Potable Supply 2 St. Pete. NE STP</u>
pH	7.7	7.6	6.9
Total hardness as ppm CaCO ₃	124	248	412
Calcium hardness as ppm CaCO ₃	108	232	282
Total Alkalinity as ppm CaCO ₃	90	270	240
P-Alkalinity as ppm CaCO ₃	-	0	0
OH-Alkalinity as ppm CaCO ₃	0	0	0
Total dissolved solids, ppm	20	670	1394
Suspended solids, ppm	10	9	30
Conductivity, micromhos/cm	268	938	2390
Calcium, ppm Ca	43	80	97
Magnesium, ppm Mg	4	6	43
Ferric iron, ppm Fe	.05	.11	.298
Bicarbonate, ppm HCO ₃	110	324	293
Carbonate, ppm CO ₃	0	0	0
Sulfate, ppm SO ₄	0	40	100
Chloride, ppm Cl	26	95	522
Silica, ppm SiO ₂	16	19	20
Aluminum, ppm SiO ₂	.1	.1	.1
Zinc, ppm Zn	.05	.016	.06
Orthophosphate, ppm PO ₄	0	3.3	5

on the need to reduce water levels in on-site detention facilities.

3.4.3 System Design

The quantities of water withdrawn from sources of supply are shown in Figure 3-1. The average potable withdrawal is 149 gpm (maximum = 158 gpm and minimum = 96 gpm). The average non-potable withdrawal is 1590 gpm (maximum = 1817 gpm and minimum = 623 gpm).

The consumptive usage rate for the system is shown in Figure 3-1. The consumptive use of water by the facility is through cooling tower losses in the form of evaporation and drift. The average evaporative loss will be 1255 gpm (minimum = 474 gpm and maximum = 1383 gpm), and the average drift loss will be 56 gpm (minimum = 21 gpm and maximum = 62 gpm).

The location of the cooling towers was shown on the facility layout (Figure 2-1). The cooling tower system will consist of a six (6) cell group of Class 600 Marley cross flow towers or approved substitutes. The average blow down rate for the towers is 279 gpm (minimum = 105 gpm and maximum = 306 gpm). The cooling tower blow down will accumulate along with the boiler demineralization back flush water average flow 45 gpm, minimum = 23 gpm, maximum = 53 gpm), and the boiler blow down water (average flow 32 gpm, minimum = 11 gpm, maximum = 33 gpm) for a total process blow down average flow of 356 gpm (minimum = 134 gpm, maximum = 390 gpm). The water that is used to quench the residue discharged from the boiler grates will be drawn from the process blow down cumulative flow, leaving an average process discharge rate of 311 gpm. Minimum and maximum process flows are 116 gpm and 343 gpm, respectively. Sanitary flow, discharged at a rate of 50 gpm, will be added to the process flow for an average total discharge of 361 gpm (minimum = 158 gpm, maximum = 394 gpm).

The cooling water increases in temperature from 86°F to 110°F in the process of condensing the exhaust steam from the turbine. The water is then cooled by evaporation in the cooling tower. The flow rate through the cooling tower is 56,250 gpm, and the evaporation rate from the tower will average 1255 gpm or approximately 2.2% of the circulation rate. No intake structure is anticipated at this time, since the cooling water will be drawn from a pressurized main which carries non-potable water. The potable water supply will also be drawn from a pressurized main. This plant effluent, with a maximum temperature of 92° F, will be pumped to the Pinellas Park lift station; from there it will be diluted in the Pinellas County sewage collection and treatment system.

3.4.4 - No change from the original application.

3.4.5 Blowdown and Trash Disposal

Blowdown will be from the boilers, the cooling towers and the demineralizers as described in Section 3.4.3 above. This cumulative flow, less the 45 gpm which goes to quench the residue, is discharged after neutralization and stabilization to the sanitary sewage collection system. The physical-chemical characteristics of the blowdown mixture are shown in Table 3-2.

3.4.6-3.6 No changes from original application.

3.7 Air Emissions

With the addition of the third unit, the facility will then consist of three combustion units and two stacks. Units 1 and 2 will be vented through a single stack, and Unit 3 will have a separate stack. A full discussion of the air pollution aspects is contained in Appendix A under separate cover.

3.8 No changes from the original application.

Table 3-2

Characteristics of Blowdown Mixture (Using Largo Supply)

Parameter	Boiler Blowdown			Cooling Tower Blowdown			Demineralizer			R.O. Reject		
	Q(gpm)	mg/l	#/Day	Q(gpm)	mg/l	#/Day	Q(gpm)	mg/l	#/Day	Q(gpm)	mg/l	#/Day
Ca	32	0	0	279	400	1340	5	36	2	40	236	113
Mg	32	0	0	279	30	101	5	5	1	40	17	8
Na	32	350	135	279	445	1491	5	3398	204	40	248	119
HCO ₃	32	100	38	279	475	1592	5	144	9	40	266	128
CO ₃	32	0	0	279	0	0	5	0	0	40	0	0
SO ₄	32	0	0	279	1445	4842	5	6277	377	40	118	57
Cl	32	100	38	279	475	1592	5	144	9	40	266	128
PO ₄	32	40	15	279	17	57	5	5	1	40	9	4
TDS	32	800	308	279	3017	10109	5	10194	612	40	1337	642
TSS	32	100	38	279	75	251	5	0	0	40	50	24
pH	32	10.5	-	279	7.5	-	5	8.5	-	40	6.5	-

3.9 Associated Facilities

All items designated as "to be constructed" for the original project have been constructed.

3.10 On-Site Drainage

Site stormwater is conveyed to a 20 acre stormwater detention basin located south of the plant. Water in the pond is pumped to existing aeration-oxidation ponds for treatment and subsequent land spraying on perimeter berms. An alternative stormwater management project being investigated is the use of stormwater as a makeup water source for the cooling towers. The volume of water supplied in this manner would be small in comparison with total makeup water requirements. Water levels in site storage facilities could be effectively regulated by this technique, assuming the stormwater is amenable to any required pretreatment.

CHAPTER 4
ENVIRONMENTAL EFFECTS OF CONSTRUCTION

4.1 Site Preparation and Plant Construction

No changes from original application except those changes concerning air quality. The air quality discussion is contained in Appendix A of this document.

4.2-4.4 No changes from original application.

CHAPTER 5
ENVIRONMENTAL EFFECTS OF PLANT OPERATION

5.0 All of the fundamental plant processes remain the same. Changes in water flows are described in Section 3.4. It is proposed that the stormwater-leachate treatment concept described in the original application be modified. This is due to the findings of a forthcoming USGS report which documents the treatment efficiency of the existing aeration-oxidation pond. At present the oxidation ponds are vegetated by cattails; the aeration basin is lined and is supplied with a 20 HP floating mechanical aerator. The data indicate that substantial water quality improvement is attained after aeration alone and that polishing by hyacinths may not be warranted. A copy of this report will be forwarded to the Department as soon as it is available.

The effect of added air emissions is detailed in Appendix A. All other discussions are as presented in the original application.

5.1-5.3 No changes from original application.

5.4 Effects of Air Emission

Discussed in Appendix A.

5.5-5.7 No changes from original application.

CHAPTER 6

ENVIRONMENTAL MEASUREMENTS & MONITORING PROGRAMS

6.0 As required by the Conditions of Certification of the original Power Plant Site Certification an environmental monitoring plan was prepared and submitted to the Department. The proposal was found to be acceptable and major components of the plan have been implemented. Addition of the third boiler does not cause any changes in the original monitoring plan; therefore the document is inserted here to fulfill the requirements of this chapter. Since the plan was originally submitted for Department review, more detailed information on well construction and leachate plume detection methods have been added.

EXECUTIVE SUMMARY

PROGRAM OBJECTIVES

This monitoring program is designed to fulfill the requirements of the Conditions of Certification (COC) of the Power Plant Site Certification (PPSC) and to ensure that the operation of the plant does not cause harm to the surrounding environment and human population.

PROGRAM SUMMARY

The monitoring program is shown schematically in Figure 6.1 and described in Tables 6.1 and 6.2; program implementation is presented in Figure 6.2. The monitoring program consists of startup and continuous regimens, some of which are stipulated in the COC; others, which are labeled additional tests, are performed as insurance that the facility is operating in an environmentally sound manner. A specific sampling and analysis team is assigned to each task in as shown in Table 6.1. On May 24, 1983, Pinellas County contracted with the firm of Environmental Science and Engineering, Inc. (ESE) of Gainesville, Florida, to perform analytical tasks associated with the residue and water quality sampling. The County has also signed a contract with the Florida State Epidemiology Laboratory to conduct virus monitoring of the cooling towers. Noise sampling, initiated prior to plant construction, is being conducted by the Pinellas County Department of Environmental Management (DEM). The one year's background data prior to plant startup was collected by




FIGURE 6-1
PROGRAM SCHEME

TABLE 6.1
PROGRAM SUMMARY

Program Component	Type/Regimen	Project Assignments
Boiler Residue	Required/Startup	ESE
Initial Pond Water & Sediment Tests	Required/Startup	ESE
Quarterly Groundwater, Pond Sediment Tests	Required/Continuous	ESE
Solid Waste Report	Required/Continuous	Pinellas County
Blowdown Sump Wastewater	Additional/Continuous	Refuse Tech, Inc. & ESE
Noise	Additional/Continuous	Pinellas County
Virus	Additional/Continuous	Florida HRS


TABLE 6.2

SUMMARY OF MINIMUM MONITORING REQUIREMENTS

Requirement	Frequency of Analysis	Purpose
Analyze water quality of pond water, sediments	Once, prior to pumping leachate and/or storm-water through system	To establish background concentrations in the pond system.
Collect groundwater data	Continuous for one year prior to plant startup	To establish background concentrations under sprayfield.
Analyze pond water & sediments	Quarterly, commencing within 3 months after commencement of pumping into system	To establish treatment effectiveness, heavy metal uptake and correlation with groundwater data.
Monitor groundwater quality	Quarterly	To determine impact of sprayfield and treatment pond system operation on underlying groundwater.
Solid waste report	Monthly, submit to District DER quarterly	To document fill quantity and applied treatment.
Analyze boiler residue	Completed on June 6, 1983	To determine if the boiler residue is a hazardous material.

IMPLEMENTATION SCHEDULE

FIGURE 6-2



the U. S. Geological Survey (USGS) under contract with Pinellas County.
A statistical analysis of the data from selected wells was submitted to
the DER (Tallahassee) on March 8, 1983.


DESCRIPTION OF THE MONITORING PROGRAM

BACKGROUND DATA


In accordance with paragraphs 3a and 3b of Section D of the COC, at least one year prior to plant startup groundwater quality data shall be collected from a minimum of four wells: one upgradient hydrologically from the southern boundary of the Bridgeway Acres II landfill, one located in the immediate vicinity of the aeration/oxidation pond, and two located down slope from the landfill/sprayfield area. Locations of the wells constructed by the USGS under contract with Pinellas County are shown in Figure 6.3. Not shown in this Figure are wells LF-18, LF-15, and LF-30 and surface water station SW-2. LF-18 and SW-2 are located in the U.S. Homes area (they are both now destroyed), well 30 is at the northwest corner of the stormwater holding pond (Lake Acenbrack), and LF-15 is just north of U.S. Homes in a perimeter ditch bordering County property. The required parameters listed in the COC for routine monitoring are as follows:

Conductivity	Arsenic	Barium
Nitrates	Selenium	Silver
Iron	Cadmium	Chlorides
COD	Chromium	pH
Nickel	Copper	Lead
Aluminum	Mercury	Zinc
Total Coliform Bacteria		

FIGURE 6-3
MONITORING WELLS IN THE VICINITY
 OF THE AERATION/OXIDATION POND




GROUNDWATER FLOW



EXPLANATION

- Surficial aquifer well cluster and number/letter
- Surface water quality site and number/letter
- Stage measurement station and number/letter

100 FEET



WELL LOCATIONS

Well clusters will be sited in locations best suited to monitor the ground water quality and identify any possible sources of contamination. The use of the cluster construction will provide vertical definition of any contaminant plumes. All well locations appear in Figure 6.4.


A limited EM survey of the site will be conducted using a Geonics EM-31 non-contact terrain conductivity meter. The purpose of this survey will be to determine the existence and extent of any subsurface contaminant plume. Parallel transects, 25 ft. apart, will be run at the site (see Figure 1 for transect locations). EM reading will be taken and recorded at 25-ft intervals along each transect. On-site analysis of the data will be performed and, if a plume is suspected, a grid pattern with readings of 25-ft. spacing will be used to determine its extent.

WELL CONSTRUCTION

Each well cluster will contain two wells and will be installed so as to monitor the entire permeable zone and the underlying Floridan aquifer. All wells will be drilled using a water-rotary rig and will be constructed using 2-inch, schedule 40, flush-fitting, threaded PVC casing and screen. No glue or solvents will be used during construction. Undisturbed samples will be taken from the permeable zone and from the confining layer at four of the cluster locations (C-5, C-6, C-7, and C-9).

FIGURE 6-4

WELL LOCATIONS AND EM SURVEY LINES



The first well in the cluster will penetrate to the top of an underlying confining layer which is located at an average depth of 29 ft. below the site. The well will be screened throughout the more permeable sand stratum. The second well will penetrate to the first zone of high transmissivity encountered in the limestone of the Floridan aquifer which underlies the site at an average depth of 54 ft.

Well screen and casing will be installed in the completed hole and will extend approximately 2 ft. above the land surface. The annulus around the screen will be packed with sand to a point approximately 2 ft. above the top of the screen. A 2-ft. bentonite seal (1 ft. in the shallow wells) will be placed above the sand pack to prevent vertical migration of water in the borehole. The hole will then be grouted to the surface and a 4-in protective steel casing installed. All wells will be developed by pumping until the water runs clear.

Hydraulic testing (commonly called slug testing) will be performed on all newly installed monitor wells and selected existing wells to determine hydraulic conductivity of the surficial aquifer. The slug tests will be performed using a small-diameter pressure transducer which is lowered into the well; the pressure that corresponds to the water level is recorded with an Envirolab 2-channel pressure recorder. After the well has been allowed to stabilize, a mechanical slug is placed into the well to quickly raise the water level in the well. The slug will remain in place while the water levels are recorded at 1-second intervals until the well has reached equilibrium. At that point the slug is removed and the water levels are recorded until equilibrium is reached again. Data obtained

during the slug tests will be used to develop plots from which hydraulic conductivity can be determined.

BOILER RESIDUE ANALYSIS

This test is to establish whether the boiler residue is a hazardous material in accordance with the Resource Conservation and Recovery Act (RCRA). It will yield data to assess the ignitability, corrosivity, reactivity, and toxicity of the residue. Test procedures are documented in the Federal Register, Vol. 43, No. 243 (12/18/78) and Vol. 45, No. 98 (5/19/80 amended 7/7/81). On June 6, 1983, individual composite samples were taken from three boiler residue streams: total combined residue as it flows off the conveyor, aggregate, and 2 - 10" non-magnetic (Figure 6.5). The results of the tests show that the residue is not hazardous. A declaration of this has been submitted to the DER.

STARTUP AND CONTINUOUS SAMPLING OF POND WATER, SEDIMENTS AND GROUNDWATER.

ESE will collect separate water and sediment samples at the RRF. Each well will be evacuated for a minimum of 3 well volumes. Conductivity, temperature, and pH will be measured on-site using portable S-C-T meters and pH meters which have been calibrated at the beginning of each trip. Well sampling will be accomplished using a bailer constructed of PVC materials. The samples will be collected in a manner which will minimize aeration and prevent oxidation of reduced compounds. All containers will be filled to the top and tightly stoppered. All samples




FIGURE 6-5
FATE OF RAW WASTE

will be chilled, preserved as appropriate, and transported to the Gainesville laboratory for analysis; all equipment will be rinsed between collections to avoid any possible cross-contamination.

Samples will be drawn using a peristaltic pump and a vacuum bottle. The vacuum bottle for these samplings will be the actual sample bottles. A separate Teflon tube and stopper will be provided for each sampling station. The pump will create a vacuum in the sample container which will in turn draw the sample out of the well.

The samples will be preserved upon arrival at the laboratory as follows:

Metals fraction: HNO_3 to pH 2

COD fraction: H_2SO_4 to pH 2

Samples will be filtered and analyzed for total parameters (Table 6-3).


Samples of the pond surface and pond bottom waters will be composited from three locations in each of the three ponds shown in Figure 6.6. Sample volumes shall be sufficient to perform analyses of specified parameters (see Table 6.3). Individual samples of pond sediments shall be taken from the top four inches of the sediment layer at the locations specified in Figure 6.6.

SOLID WASTE REPORT

Monthly solid waste reports are prepared and submitted to the Southwest

FIGURE 6-6

SAMPLING LOCATIONS FOR POND WATER & SEDIMENTS



(NOT TO SCALE)

TABLE 6.3
PARAMETERS FOR ANALYSIS

SURFACE WATER SAMPLES			
Parameter	STORET #	Parameter	STORET #
Conductivity	00095	Nitrates	00620
Iron	01045	COD	00340
Total Coliform	31506	Aluminum	01105
Barium	01007	Arsenic	01002
Chromium	01034	Lead	01051
Mercury	71900	Selenium	01147
Silver	01077	Chlorides	00940
pH	00400	Copper	01042
Zinc	01092	Nickel	01067
Cadmium	01027		
SEDIMENT SAMPLES			
Barium	01008	Iron	01170
Nickel	01068	Aluminum	01108
Arsenic	01003	Cadmium	01028
Chromium	01029	Lead	01052
Mercury	71921	Selenium	01148
Silver	01078	Copper	01043
Zinc	01093		

District DER office on a quarterly basis. This function is performed by the Solid Waste Management Division of Pinellas County. The following items are to be included in this report:

- A. Amount and type (i.e., putrescible, special wastes, boiler residue, rejects, etc.) of materials landfilled.
- B. The treatment provided (i.e., daily cover - if required, etc.).

BLOWDOWN SUMP ANALYSES

In accordance with Tables I and II of Appendix I of the Construction Agreement and Appendix D of the Management Agreement for the existing facility, maximum water quality values for system blowdown have been established. Accordingly, routine sampling and analysis for those parameters are performed. Supplementary sampling and analysis will be conducted by ESE.

NOISE MONITORING

Routine noise monitoring is now conducted by the Pinellas County Department of Environmental Management. Sampling sites are located in the more sensitive areas surrounding the facility, namely the residential areas southwest of the plant. Sampling frequencies are arbitrary and based on normal plant operating conditions. Maximum facility-associated noise can be anticipated when truck traffic is at a peak and during plant blowdowns.

VIRUS MONITORING

Virus monitoring is conducted for two reasons: (1) to ensure that viruses are not being discharged to the environment through the cooling towers and, (2) to allow adjustments to the chlorine dioxide dose in the cooling tower makeup water. The County has contracted with the State of Florida Epidemiology Research Center (DHRS) to collect and analyze samples for viruses. Specific sampling frequencies are determined by that agency, though monthly regimens are specified. Samples are taken prior to entry of water into the cooling tower and after it passes through the tower's recirculation sump.

CHAPTER 7
ECONOMIC AND SOCIAL EFFECTS
OF PLANT CONSTRUCTION AND OPERATIONS

7.1 Benefits

The capacity afforded by the third boiler will minimize the landfilling of Class I solid waste; this is the stated policy of the Board of County Commissioners, Pinellas County, Florida. Based on current waste generation estimates, all Class I material can be incinerated by the three boiler plants through the year 1996. Specific benefits derived from this operation are as follows:

1. Drastically reduced land requirement for disposal of solid waste with a resultant savings in real estate costs.
2. Landfilling of the boiler residue, in contrast with garbage, will not contaminate ground water.
3. As boiler residue does not attract gulls and disease vectors, public health and aviation safety will be enhanced.
4. The increase in electrical generation capacity will reduce foreign oil import requirements by 4,521,957 barrels over a ten year period which translates conservatively into a savings of \$135,658,707.
5. The additional 29 MW of electricity will satisfy the energy requirements for over 8500 Pinellas County homes.

7.2 Costs

The additional boiler, stack, turbine generator, cooling tower units, and associated hardware will be financed by a supplemental revenue bond issue. The 1983 construction cost for the expansion

I. BEST AVAILABLE CONTROL TECHNOLOGY

A. INTRODUCTION

Best Available Control Technology (BACT) is defined in the 40 CFR 52.21 as follows:

"An emission limitation based on the maximum degree of reduction of each pollutant emitted which the Department, taking into account, energy, environmental and economic impacts and other costs, determines on a case by case basis, is achievable through application of production processes and available methods, systems, and techniques, for control of each such pollutant".

Table I-1 lists the air emissions for which an evaluation for BACT was conducted and control alternatives (both commercially available and in the research stage) which were considered for the control of each of the pollutants. The air pollutants and the emission levels for which BACT must be determined are shown in Table I-2.

TABLE I-1
BACT POLLUTANTS AND CONTROL ALTERNATIVES

<u>Air Emission Parameter</u>	<u>Control Alternatives</u>
Particulate	Electrostatic Precipitator (ESP) Wet or Dry Scrubber Fabric Filter Electrostatic Baghouse
Sulfur Dioxide	Wet Scrubber Dry Scrubber Low Sulfur Fuel
Nitrogen Oxide	Ammonia Injection Wet Scrubber Catalytic Reduction Design and Operating Procedures
Carbon Monoxide	Design and Operating Procedures
Lead & Beryllium & Particulate Mercury	Electrostatic Precipitator (ESP) Wet or Dry Scrubber Fabric Filter
Hydrogen Fluoride & Gaseous Mercury	Wet & Dry Scrubber

TABLE I-2
BACT POLLUTANTS AND ANNUAL EMISSIONS

Air Emission Parameter	Tons/Year
Particulate	109
Sulfur Dioxide	577
Nitrogen Oxide	577
Carbon Monoxide	288
Lead	58
Beryllium	0.0019
Mercury (particulate & gaseous)	2.1
Hydrogen Fluoride	28

This BACT evaluation of the above described control alternatives considered their technical feasibility, energy usage and certain environmental factors. The proposed unit is projected to be on-line approximately 80-85% of the time. Air pollution control equipment must be reliable to minimize contribution to unit downtime. A projection of the equipment's reliability can be developed only after it has received commercial application; therefore, commercial application of the equipment was reviewed in formulating BACT. Installation of air pollution control equipment increases the facility cost, but results in benefits to the surrounding area and population. At some point, the cost of air pollution control equipment is not outweighed by the resulting benefits. To this end, the capital, operational and energy costs, were compared to the benefits. Air pollution control equipment will lessen the facility's air emissions, however, increasing the waste requiring land disposal resulting from the additional equipment operation is not advantageous.

**B. TOTAL SUSPENDED PARTICULATE (TSP),
LEAD, BERYLLIUM AND PARTICULATE MERCURY**

In this section, BACT for control of total suspended particulate (TSP) emissions is proposed. The control device which is BACT for TSP will also concurrently control lead, beryllium and the particulate form of mercury, and is thus also proposed as BACT for these pollutants.

An electrostatic precipitator with an outlet particulate loading of 0.03 gr/dscf, corrected to 12% CO₂, is proposed as BACT for this project. Other control alternatives reviewed include ESP's with emission rates of 0.05 and 0.015 gr/dscf at 12% CO₂, two different Fabric Filters, and a Dry Acid Gas Scrubber.

1. Electrostatic Precipitators

Electrostatic precipitators function by imparting a negative charge to particulates in the flue gas stream. The particles are then attracted to positively charged plates, where they are collected. Characteristics of electrostatic precipitators include the following:

- Generally capable of particulate removal efficiencies greater than 98% with efficiencies as high as 99.8%.
- Can handle high temperature gases of over 600°F in special applications.
- Low pressure drop through units resulting in lower energy usage by fans.
- Performance is sensitive to actual vs. design flue gas flow rates (actual gas flow must be less than design) and particle resistivity.
- Consideration must be given to prevent corrosion caused by acid gas condensation. Acid mist condensation begins about 250°F.
- Recognized as the most reliable and efficient technology on resource recovery systems.

Table I-3 shows estimated costs for electrostatic precipitators investigated for this project.

2. Fabric Filters/Electrostatic Baghouses

Baghouses remove particulate by filtering the flue gas stream through a fabric. Actually, most of the effectiveness is attributed to filtering through a mat of particulate which has built-up on the surface of the fabric. Characteristics of baghouses are as follows:

- Particulate removal efficiencies as high as 99.8% have been demonstrated on coal fired units.
- Variations in flue gas flow rate and particulate composition do not generally effect performance.
- Pressure drop through units is significant resulting in relatively high energy usage by fans.
- Available filter materials limit operating temperatures to less than 500°F.
- Sparks in flue gas can cause pinhole leaks and even fires within the filter.

TABLE I-3
 COSTS OF ELECTROSTATIC PRECIPITATORS
 1050 TPD Unit

Emission Limit gr/dscf @ 12% CO ₂	0.05	0.03	0.015
Removal Efficiency, Percent	98.0	98.7	99.4
Construction Cost	\$1,707,700	\$2,003,400	\$2,592,300
Annual Cost:			
Net Debt Service	\$ 299,500	\$ 351,400	\$ 454,700
Operating and Maintenance Costs	<u>\$ 179,300</u>	<u>\$ 222,400</u>	<u>\$ 298,100</u>
Total	\$ 478,800	\$ 573,800	\$ 752,800
Unit Cost:			
Per Ton MSW (300,000)	\$ 1.60	\$ 1.91	\$ 2.51
Per Ton Particulate Removed	\$ 45	\$ 53	\$ 69
Incremental Costs:			
Additional Tons Removed	base	100	45
Additional Annual Cost	base	\$ 95,000	\$ 179,000
Per Ton Removed		\$ 863	\$ 3,980
Per Ton MSW (300,000)		\$ 0.31	\$.60

- Consideration must be given to prevention of corrosion caused by acid gas condensation.
- Experience on resource recovery facilities is very limited.

Table I-4 shows estimated costs for the baghouse systems investigated for this project. The TSP emission rate would be guaranteed less than 0.01 gr/dscf corrected to 12% CO₂.

3. Dry Scrubbers

Dry scrubbers are devices which are designed to remove SO₂ and acid gases from the flue gas stream, in addition to particulates. Aqueous solutions of lime are sprayed into the gas stream, which react with the SO₂ and acid gases. Heat from the reaction, and from the flue gas, dry the resultant products, which are then collected in a baghouse. Characteristics of dry scrubbers are the same as those for baghouses, except as follows:

- SO₂, acid gases and other flue gas constituents, that may condense with lower exit gas temperatures are controlled.
- Acid gas corrosion may be less of a problem.
- Approximately twice as much residue is produced.
- Experience on resource recovery facilities is even more limited.

Table I-5 shows estimated costs for a dry scrubber and baghouse system, guaranteed for a TSP emission limit of 0.01 gr/dscf, corrected to 12% CO₂, and guaranteed to remove 70% of the SO₂ and 70% of the HCL in the flue gas stream.

C. SULFUR DIOXIDE (SO₂) AND ACID GASES

Use of a low sulfur fuel is currently considered by many as BACT for control of sulfur dioxide emissions. Municipal solid waste (MSW) is inherently a low sulfur fuel with a sulfur content of approximately 0.15 ± 0.1%.

A control alternative which was examined for this report is the use of a dry scrubber system for SO₂ control, which simultaneously controls emissions of acid gases. Use of a dry scrubber has been examined for particulate control in the particulate BACT analysis. Wet scrubbing for SO₂ control was not investigated due to the presence of a vapor plume. Even though the gas has been cleaned the steam plume is considered unacceptable and eliminates this option.

TABLE I-4
 COSTS OF FABRIC FILTER SYSTEMS
 1050 TPD Unit

	Pulse Jet Fabric Filter	Reverse Air Fabric Filter
Emission Limit, * gr/dscf @ 12% CO ₂	0.01	0.01
Removal Efficiency, Percent	99.6+	99.6+
Construction Cost	\$1,381,000	\$1,620,000
Annual Cost:		
Debt Service	\$ 151,200	\$ 177,700
Operating and Maintenance Costs	<u>\$ 359,000</u>	<u>\$ 421,200</u>
Total	\$ 510,500	\$ 598,900
Unit Cost:		
Per Ton MSW (120,000 tpy)	\$ 1.70	\$ 2.00
Per Ton Particulate Removed	\$ 47	\$ 55
Incremental Annual Cost	base	\$ 88,400
Incremental Cost Per Ton MSW	base	\$ 0.30

* Due to nature of fabric filters the collection efficiency and emission limit cannot be specified. The listed values indicate minimum acceptable performance.

TABLE I-5
 DRY SCRUBBER/FABRIC FILTER SYSTEM
 1050 TPD Unit

	Dry Scrubber Plus Fabric Filter
Emission Limit, gr/dscf @12% CO ₂	0.015
Removal Efficiency, Percent	99 +
Construction Cost	\$5,000,000
Annual Cost:	
Debt Service	\$ 823,500
Operating and Maintenance Costs	<u>\$1,425,000</u>
Total	\$2,248,500
Unit Cost:	
Per Ton MSW (300,000 tpy)	\$ 7.50
Per Ton Particulate Removed	\$ 206

Table I-6 shows general effects of SO₂ control alternatives.

TABLE I-6
EFFECTS OF SO₂ CONTROL ALTERNATIVES

Area of Effect	Low Sulfur Fuel	Dry Scrubber
Energy Consumption	No effect	Increased facility energy consumption
Environmental	Reduced emissions of SO ₂ compared to other fossil fuels	Reduced emissions of SO ₂ , HF and gaseous mercury; increased amounts of residues requiring land disposal
Economic	No direct facility related costs	Increased facility capital and operating costs

1. Low Sulfur Fuel

The emission rate of sulfur dioxide is dependent on the amount of sulfur in the fuel. Municipal solid waste is estimated to have a sulfur content of less than 0.2%. Generally, coal-fired facilities have switched from high (5-7%) to low (1-2%) sulfur coal to comply with laws and regulations. The proposed unit will utilize municipal solid waste which is much lower in sulfur content.

2. Dry Scrubbers

Dry scrubbers operate by injecting droplets of alkali reagent into the flue gas. The resulting reactions remove the sulfur dioxide as sulfites and sulfates in particulate form. The heat generated during the reaction plus flue gas heat evaporates the water carrying the alkali reagent. A particulate removal device is located downstream to remove the sulfate and sulfite particulates. The first commercial scale dry scrubber has just gone on-line at the coal-fired Northern States Power Company's Riverside Power Plant in Minneapolis, Minnesota. The system's costs and effects were based upon projections provided by system vendors.

Table I-7 shows estimated costs of a dry scrubber to control particulates, SO₂ and acid gases.

TABLE I-7
DRY SCRUBBER COSTS

Total Annual Cost (Debt Service + O&M)	\$2,248,500 (1)
Annual Cost attributable to particulate control	\$ 573,800/year (2)
Annual Cost attributable to SO ₂ + acid gas control	\$1,674,700/year (3)
Incremental Cost per ton of SO ₂ + acid gas controlled	\$ 1,600/ton (4)


- Notes:
1. From Table I-5
 2. Proportioned such that cost for particulate removal is equal to cost for electrostatic precipitator.
 3. Total cost less that attributable to particulate.
 4. Based on guaranteed removal efficiencies, i.e. 70% removal of SO₂ and 90% removal of HCL.
-

D. NITROGEN OXIDE

The technologies for nitrogen oxide (NO_x) control include ammonia injection, wet scrubbers, and catalytic reduction. However, none have been utilized on a commercial scale at either resource recovery facilities or coal-fired power plants in the United States.

Research relative to ammonia injection has revealed the following utilization limiting factors:

- When the flue gas temperature is between 1600°F and 1650°F, the reaction:



readily takes place, controlling NO emissions. Above 1800°F, the NH₃ is oxidized to NO. Below 1600°F, the reaction does not take place. A supplemental heating source may be required to maintain the appropriate temperature envelope.

- Ammonia can react with sulfur trioxide in the flue gas to form ammonium sulfate or ammonium bisulfate. Ammonium bisulfate can condense after emission to the atmosphere and act as a corrosive agent.
- Cyanide formation at the ammonia injection zone has occurred in the presence of hydrocarbons.

- Ammonium Chloride formation has been documented and forms a pervasive visible plume.

Research on nitrogen oxide control with catalytic reduction processes has identified the following problems:

- Formation of ammonium bisulfate with resulting corrosivity
- Blinding of the catalyst
- Catalyst corrosion
- Formation of unexpected compounds


The wet scrubber has been demonstrated only on a glass manufacturing furnace. The information is insufficient to judge its applicability to a municipal solid waste fired resource recovery facility.

Nitrogen oxides (NO_x) result from the reaction of atmospheric nitrogen and oxygen in the combustion zone and the partial combustion of nitrogenous compounds in the fuel. Important factors affecting NO_x production are flame and furnace temperature, residence time of combustion gases at flame temperature, rate of gas cooling, and amount of excess air.

Given the state of the art of NO_x control technologies, refuse feeding, and the importance of temperature zone parameters in NO_x generation, the BACT recommendation for the proposed resource recovery facilities is the use of proper boiler design and operating procedures.

E. CARBON MONOXIDE

Carbon Monoxide is a product of incomplete combustion. The generalized reaction is shown below:



When incomplete combustion takes place energy is lost, carbon monoxide and another hydrocarbon are formed. The new hydrocarbon is a pyrolysis product and may combust further. BACT is the use of state-of-the-art boiler controls to insure sufficient underfire and overfire air so that the emissions of products of incomplete combustion are minimized.

The underfire air has three purposes: 1) to ignite the refuse, 2) cool the grates, and 3) supply air to all parts of the fuel bed. The overfire air causes turbulence in the fire ball to assist in complete burnout.

There are four steps in the combustion of refuse or any damp fuel:

- 1) drying
- 2) volitization
- 3) pyrolyzing
- 4) direct combustion

The step that contributes to carbon monoxide production is the pyrolysis step. Pyrolysing is the breaking down of larger organic compound in to smaller organic compounds by the application of heat. This differs little from cracking of crude oils into various fractions.

In a mass burn system, this cracking takes place in the presence of some air but still in a reducing atmosphere. Incomplete combustion can take place producing carbon monoxide. In a properly designed system, the products of pyrolysis are consumed in the fire ball section of the incinerator.

The fireball's intensity is controlled by high velocity overfire air. As long as sufficient overfire air is supplied to insure approximately 100% excess air, carbon monoxide production will be minimized.

There are no controls for carbon monoxide production other than state-of-the-art boiler design and control is BACT for CO control. The boiler will be designed to operate at peak efficiency which will minimize products of incomplete combustion.

II. AIR QUALITY ANALYSIS

A. INTRODUCTION

Available data indicate that emission levels as listed in Table II-1 are attainable by mass burn resource recovery facilities. These emission levels at a throughput of 1,050 TPD will be used in the modeling required for the PSD permit. This data was developed by comparing 14 mass burn facilities throughout the USA and Europe. The analysis is attached.

TABLE II-1
EXPECTED EMISSIONS

Pollutant	lb of Pollutant per ton of MSW.	lb of Pollutant per hour
Particulate	0.6	26.3
Sulfur Dioxide	3.0	131
Nitrogen Dioxide	4.3	188
Carbon Monoxide	0.8	35
Hydrocarbons	0.2	8.7
Lead	0.1	4.4
Mercury	0.003	0.13
Beryllium	1.0×10^{-5}	4.4×10^{-4}
Fluorides	0.1	4.4
Chlorides	5.3	232

Table II-1 is expanded in Table II-2 to indicate the equivalent emission factors used in the various parts of the Air Quality Analysis. The Resource Recovery Facility (RRF) is a PSD significant source for all criteria and several non-criteria pollutants. Table II-3 lists the stack parameters used in the analysis of this unit.

TABLE II-2
3rd UNIT
RRF EMISSIONS AND STACK PARAMETERS

Pollutant	lb per ton MSW	Equivalent Factors		
		lb/hr	TPY	gm/s
Particulate	0.6	25	110	3.15
Sulfur Dioxide	3.0	131	574	16.5
Nitrogen Dioxide	4.3	188	823	23.7
Carbon Monoxide	0.8	35	153	4.4
Hydrocarbons	0.2	8.7	38	1.1
Lead	0.07	4.4	19	0.55
Mercury	.003	0.13	.6	0.016
Beryllium	7.7×10^{-5}	4.1×10^{-4}	1.9×10^{-2}	5.5×10^{-5}
Fluorides	0.1	4.4	19	0.55
Chlorides	5.3	232	1016	29

TABLE II-3
STACK PARAMETERS

Parameters	Unit 3	
	Metric	English
Volumetric Flow	118.0 m ³ /s	251,000 acfm
Stack Diameter	2.37 m	7.8 ft
Stack Height	49.1 m	161 ft
Exit Velocity	26.8 m/s	88 ft/s
Exit Temperature	505 °K	450 °F

The Good Engineering Practice stack height for this facility is 290 ft. The planned stack height is 161 ft to be consistent with the existing construction. The shortness is due to the Clearwater - St. Petersburg Airport being 11,000 ft from the facility. Negotiations with the Federal Aviation Authority indicate that a stack higher than 178 ft will interfere with the approach surface to the airport.

A stack this short could significantly affect the air quality impacts caused by the facility. These impacts were investigated and are explained in Section II-0.

B. MODELING

To model the air quality impact due to the planned facility expansion, the following protocol was used:

1. Unit 3 will be identical to Units 1 and 2, actual design data for those units have been used for Unit 3. These data were developed in the design process and vary from that in the original application.
2. Results from previous CRSTER modeling of the facility using meteorological data from Tampa International Airport for the years 1970-74 were used to identify the worst years for pollutant concentrations from the facility. Data from the year 1970 were used for further short-term concentration estimates, while data from the year 1971 were used for annual estimates.
3. The ISCST model from UNAMAP4 was used to calculate the impacts of the emissions from 1) the project (Unit 3), 2) from all three Resource Recovery Facility (RRF) units, 3) from all of the PSD sources, and 4) from the RRF and other major interacting sources of SO₂ and TSP in the area.
4. PSD sources modeled include the three units of the Pinellas County RRF, the McKay Bay RRF, and the TECO Big Bend Plant.
5. The major interacting sources modeled include the aforementioned PSD sources, as well as the Florida Power facilities at Anclote, Higgins, and Bartow, TECO's Hooker Point and Gannon Plants, and the Golden Triangle Asphalt Plant.
6. Initial modeling was performed using a polar coordinate system for locating receptors every 22.5° at distances of 500, 1,000, 1,500, 2,000, 2,500, 3,000, 3,500, 4,000, 4,500, 5,000, 6,000, 7,000, 8,000, 9,000 meters.
7. Hotspot analysis was performed using a 15 by 15 Cartesian receptor grid which extended from the maximum polar receptor to the receptors on either adjacent radial line.
8. Hotspot analysis was performed for the project (Unit 3) for all pollutants. Hotspot analyses were also performed for the cumulative impacts of the PSD sources and the cumulative impacts of the interacting sources for 3-hour and 24-hour SO₂ concentrations.

9. Because of the short stack used for the project, a downwash problem could occur. Therefore, the downwash option in the ISCST model was used for the Pinellas County RRF. Any effect of downwash will appear in the model calculations.
10. The results of the modeling of the interacting sources was added to the County's monitored background concentrations for comparison to Florida and federal standards. The source of the data is the County's 1981 Air Quality Annual Report.

C. CURRENT AMBIENT AIR QUALITY

Measured maximum ambient air quality concentrations for 1981 in the vicinity of the Pinellas County Resource Recovery Project are contained in Table II-4. The National Ambient Air Quality Standards (NAAQS) and Florida AAQS are included in the table for comparison. With the exception of ozone (O₃), all pollutant concentrations are considerably lower than the Florida and National standards.

There are two nonattainment areas in the region. A nonattainment area for SO₂ exists at Tarpon Springs, approximately 20 miles to the north-northwest of the project location. In addition, an area defined as a 12-kilometer circle around the intersection of the roads U.S. 41 and Florida 60 in Tampa has been designated nonattainment for TSP. The closest point of this nonattainment area to the project is 9 miles to the east-northeast.

D. IMPACT ANALYSIS

The impact analysis for the proposed project (Unit 3) as well as for all three units of the Pinellas County RRF was based on the sulfur dioxide emission rate. The impact of the facility on other pollutant concentrations was calculated by multiplying the SO₂ concentration by scaling factors which represent the other pollutants emission rates divided by the SO₂ emission rate. All pollutants were assumed to behave conservatively (i.e., no pollutant removal mechanisms). Summaries of the impacts on air quality of Unit 2 only and of all three units are contained in Tables II-5 and II-6, respectively.

Table II-7 contains a summary of the cumulative impacts of the proposed project and other major sources of SO₂ and TSP (as listed in Section II.B.). The peak modeled concentration is added to the ambient air quality data from Table II-4 to give a predicted worst-case cumulative concentration. None of these predicted concentrations exceed Florida or National Ambient Air Quality Standards as listed in Table II-4.

Table II-8 contains the cumulative impacts of the project and other PSD sources. These peak modeled concentrations are compared to the PSD Class II increment in the table. None of the Class II increments are exceeded. Table II-9 shows the predicted peak impact of the project on the SO₂ nonattainment area at Tarpon Springs and the TSP nonattainment area in Tampa. These impacts are practically negligible.

TABLE II-4
PINELLAS COUNTY 1981 AMBIENT AIR QUALITY MONITORING DATA
IN VICINITY OF PINELLAS COUNTY RESOURCE RECOVERY PROJECT

Pollutant	Site	Averaging Time	Maximum Concentration	2nd Max. Concentration	Ambient Air Quality Standards	
					National	Florida
CO	Honeywell	1-hour	19.5 ppm	a	35 ppm	35 ppm
		8-hour	7.4 ppm	a	9 ppm	9 ppm
NO ₂	Derby Lane	Annual	22.9 ug/m ³	-	100 ug/m ³	100 ug/m ³
O ₃	Azalea Park	1-hour	125 ppb	105 ppb	120 ppb	120 ppb
SO ₂	Derby Lane	3-hour	476 ug/m ³	380 ug/m ³	1,300 ug/m ³	1,300 ug/m ³ b
		24-hour	104 ug/m ³	97 ug/m ³	365 ug/m ³	260 ug/m ³
		Annual	8.8 ug/m ³	-	80 ug/m ³	60 ug/m ³
TSP	Derby Lane	24-hour	89 ug/m ³	a	260 ug/m ³	150 ug/m ³
		Annual c	44.6 ug/m ³	-	75 ug/m ³	60 ug/m ³
Pb	Azalea Park	Quarterly	0.5 ug/m ³	-	1.5 ug/m ³	1.5 ug/m ³

T7020/5-24-83

^a2nd maximum concentration not reported

^bSecondary standard

^cGeometric mean

Source: Air Quality 1981, Pinellas County Annual Report, Pinellas County Dept. of Environmental Management, 1982.

TABLE II-5
IMPACT OF THE PROPOSED PROJECT

Pollutant	Averaging Time	Peak Modeled Concentration (ug/m ³)	Location ^a
SO ₂	3-hour	28.70	(110 M, -40 m)
	24-hour	8.70	(-310 m, -110 m)
	Annual	0.36	(2,000 m, 90°)
TSP	24-hour	1.70	(500 m, 247.5°)
	Annual	0.07	(2,000 m, 90°)
NO ₂	Annual	0.52	(2,000 m, 90°)
Lead	24-hour	0.29	(500 m, 247.5°)
Mercury	24-hour	0.009	(500 m, 247.5°)
Beryllium	24-hour	2.9 x 10 ⁻⁵	(500 m, 247.5°)
Fluoride	24-hour	0.29	(500 m, 247.5°)

T7018/5-24-83

^aThe locations of peak concentration are expressed with respect to the location of the project (0,0). The 3-hour and 24-hour SO₂ maximum locations are based on a Cartesian coordinate system while the others are based on a polar coordinate system.

TABLE II-6
IMPACT OF THE ALL 3 UNITS OF RESOURCE RECOVERY PROJECT

Pollutant	Averaging Time	Peak Modeled Concentration (ug/m ³)	Location ^a
SO ₂	3-hour	86.10	(110 M, -40 m)
	24-hour	26.20	(-310 m, -110 m)
	Annual	1.07	(2,000 m, 90°)
TSP	24-hour	5.00	(500 m, 247.5°)
	Annual	0.20	(2,000 m, 90°)
NO ₂	Annual	1.53	(2,000 m, 90°)
Lead	24-hour	0.26	(500 m, 247.5°)
Mercury	24-hour	0.088	(500 m, 247.5°)
Beryllium	24-hour	8.8 x 10 ⁻⁵	(500 m, 247.5°)
Fluoride	24-hour	0.88	(500 m, 247.5°)

T7019/5-24-83

^aThe locations of peak concentration are expressed with respect to the location of the project (0,0). The 3-hour and 24-hour SO₂ maximum locations are based on a Cartesian coordinate system while the others are based on a polar coordinate system.

TABLE II-7
 CUMULATIVE IMPACTS OF THE PROJECT
 AND OTHER MAJOR SOURCES OF SO₂ AND TSP

Pollutant	Averaging Time	Background Concentration (ug/m ³)	Peak Modeled Concentration (ug/m ³)	Cumulative Concentration (ug/m ³)	Location ^a
SO ₂	3-hour	476	443	919	(10,420 m, 1,340 m)
	24-hour	104	86	190	(10,420 m, -1,750 m)
	Annual	8.8	9.6	18.4	(2,000 m, 270°)
TSP	24-hour	89	3	92	(8,000 m, 112.5°)
	Annual	44.6	0.4	45.0	(2,000 m, 90°)

T7017/5-24-83

^aThe locations of peak concentration are expressed with respect to the location of the project (0,0). The 3-hour and 24-hour SO₂ maximum locations are based on a Cartesian coordinate system while the others are based on a polar coordinate system.

TABLE II-8
 CUMULATIVE IMPACTS OF THE PROJECT
 AND OTHER PSD SOURCES

Pollutant	Averaging Time	Peak Modeled Concentration (ug/m ³)	PSD Class II Increment (ug/m ³)	Location ^a
SO ₂	3-hour	443	512	(10,240 m, 1,340 m)
	24-hour	51	91	(-5,400 m, -6,840 m)
	Annual	3	20	(9,000 m, 157.5°)
TSP	24-hour	2.4	37	(500 m, 247.5°)
	Annual	0.24	19	(2,000 m, 90°)

T7016/5-24-83

^aThe locations of peak concentration are expressed with respect to the location of the project (0,0). The 3-hour and 24-hour SO₂ maximum locations are based on a Cartesian coordinate system while the others are based on a polar coordinate system.

TABLE II-9
 IMPACT OF THE PROJECT ON SO₂ AND TSP
 NONATTAINMENT AREAS IN THE VICINITY OF THE PROJECT

Location of Nonattainment Areas	Nonattainment Pollutant	Averaging Time	Modeled Impact of Project
Tarpon Springs	SO ₂	3-hour	1.66 ug/m ³
		24-hour	0.35 ug/m ³
		Annual	0.012 ug/m ³
Tampa	TSP	24-hour	0.09 ug/m ³
		Annual	0.006 ug/m ³

T7015/5-24-83

E. MONITORING

The PSD regulations require air monitoring to determine the existing air quality. Sources may be exempted from monitoring if the modeled impacts are below certain de minimis values. The de minimis values and the modeled impacts are shown in Table II-10.

Based on the data in Table II-10, the lead value is very close to the De Minimis impact. In order to remain very conservative in the analysis, monitoring data will be supplied for lead.

The lead monitoring data will be supplied from the Sheriff's and Azalea Park monitoring stations. These stations are beyond the facility's highest impact area but are located to record the highest lead levels expected within the county. This technique will distinguish the facility's highest impact added to the county's highest monitored level.

The ambient lead levels have fallen significantly in the past three years. The quarterly maximum has fallen from a high of 1.0 ug/m³ in 1979 to 0.3 ug/m³ in 1981. Table II-11 shows the highest quarterly average for the past three years.

TABLE II-11
AMBIENT LEAD CONCENTRATIONS
LEAD QUARTERLY MAXIMUMS
(ug/m³)

Station	1979	1980	1981
Azalea Park	0.9	0.6	0.5
Sheriff's	1.0	0.5	0.3

It can be seen that the unit's highest 24-hour average level concentration (0.09 ug/m³) added to the county's highest recorded quarterly average level in the past three years (1.0 ug/m³) is still significantly below the NAAQS of 1.5 ug/m³. Therefore, the facility will not violate the NAAQS for lead.

F. CONTINUED COMPLIANCE

To demonstrate compliance with the final permits stack testing will be performed as required. The tests performed will be as requested by the DER and will be performed according to the procedures found in 40 C.F.R. Part 60 Appendix A.

III. ADDITIONAL IMPACT ANALYSIS

A. PURPOSE

The basic purpose of the additional impacts analysis is to determine the effects of applicable criteria and noncriteria pollutant emissions on visibility, soils and vegetation. This assessment will be helpful in providing the Federal land manager with information regarding the potential impacts on Class I areas (Scenic areas, designated by Congress, to be protected from manmade air pollution, 33 U.S.C. 1288). In addition, this chapter of the air permit will help to inform the general public of potential impacts related air quality.

Three components of the additional impact analysis are: (1) a growth analysis, (2) a visibility impairment analysis, and (3) a soils and vegetation impact analysis. The final section of this chapter will summarize the results of these analyses.

B. GROWTH ANALYSIS

The Pinellas County Department of Planning estimates that the Pinellas County population will increase from the 1980 Census figure of 728,531 to 796,000 persons in 1985. This increase of approximately 68,000 people represents a 9% increase in five years or 1.8% per year. Future projections by the Department indicate an estimated population of 1,003,000 in the year 2000 which is a 38% increase over 20 years or an average of 1.6%/year.

The construction force is expected to range between 200 to 300 persons throughout the construction phase of the third unit. This represents less than 0.06% of the total population. It is expected that all of the construction work force except certain supervisory personnel will be from the local area. If there is any relocation of workers, housing is available in the vicinity of the proposed project. A sample of the types and numbers of construction workers is shown in Table III-1.

The operation of the proposed facility will require approximately 6 additional persons. A sample of the types and numbers of operations personnel is shown in Table III-2. It is expected that these personnel will also be from the local area.

The implementation of the proposed facility will cause a positive economic impact on Pinellas County because most, if not all, of the construction and operations work forces will be from the local community. Since there will not be a major influx of workers into the area, there will a minimal impact on the environmental quality of the community due to growth in the area's work force or secondary construction caused by the facility.

TABLE III-1
ESTIMATED CONSTRUCTION WORK FORCE
1050-TPD UNIT

Types	Work Force
Boilermakers	50
Carpenters	30
Electricians	15
Ironworkers	40
Laborers	50
Masons	15
Millwrights	25
Painters	5
Pipefitters	<u>20</u>
Total	250

TABLE III-2
ESTIMATED ADDITIONAL OPERATIONAL STAFF
1050 TPD UNIT

Types	Work Force
Supervisory	0
Clerical	1
Operators per shift	3
Maintenance	2
Security	0
Janitorial	<u>0</u>
Total	6

C. VISIBILITY ANALYSIS

The Clean Air Act Amendments of 1977 require evaluation of new and existing emission sources to determine potential impacts on visibility in Class 1 areas. These source evaluations are to be used as part of a regulatory program to prevent future and remedy existing impairment of visibility in Class 1 areas that results from man-made air pollution. The visibility analysis discussed below is taken from EPA's "Workbook for Estimating Visibility Impairment", November, 1980, which provides a general guidance for determining the potential impacts of an emissions source on visibility in a Class 1 area.

There are two separate types of visibility impairment: atmospheric discoloration and visual range reduction (increased haze); see Figure 1. EPA has defined "visibility impairment" to mean any humanly perceptible change in visibility (visual range, contrast, coloration) from that which would have existed under natural conditions. An important part of a visibility analysis is to determine the frequency of occurrence and magnitude of visual impact in, or within view of, a Class 1 area.

A schematic of EPA's recommended visibility screening analysis procedure is shown in Figure 2. A Level 1 analysis has been performed and is included in Appendix B. The input data included in the analysis estimated NO₂, SO₂ and the particulate emissions for the proposed resource recovery facility. Regional visual range and distance to the nearest Class 1 areas were used. The nearest Class I area is the Chassahowitzka National Wildlife refuge, located on the west coast of Florida, 75 miles north of the site. A plume contrast rating load was established with reference to the sky, the terrain and the primary and secondary aerosols. EPA has established a rating factor for the plume contrasts which provides guidance for determination of further analysis. If the calculated plume contrast is less than 0.1, no further analyses of potential visibility impacts are necessary. The absolute values of each plume contrast for the proposed facility were calculated to be less than 0.001, which is less than the EPA rating factor. Therefore, further analyses of potential visibility impacts are unnecessary, as it is considered highly unlikely that the proposed facility would cause adverse visibility impairment in Class 1 areas.

D. SOILS AND VEGETATION ANALYSIS

The electrostatic precipitators and the stack height of the proposed Facility will be designed so that neither Florida Ambient Air Quality Standards (FAAQS) nor the PSD increments will be violated. The facility will not violate the secondary FAAQS's, established to protect vegetation, materials, visibility, etc. The secondary standards for CO, NO_x, O₃ and HC are equivalent to their respective primary standards, as can be seen in Table III-3. The secondary standards for TSP and SO₂ are more stringent than their respective primary standards.




Figure 10. Two types of plume visibility impairment considered in the level-1 visibility screening analysis.




Figure 11. Geometry of plume, observer, and line of sight used in level-1 visibility screening analysis.




Figure 1. Schematic of visibility screening analysis procedure. The numerical meaning of the terms "significant" and "adverse" differ on a case-by-case basis and will be defined after an in-depth policy analysis of each case.

TABLE III-3
FLORIDA AMBIENT AIR QUALITY STANDARDS

Pollutant	Averaging Time ¹	Primary Standards	Secondary Standards
Particulate matter	Annual geometric mean	75 ug/m ³	60 ug/m ³
	24-hour	260 ug/m ³	150 ug/m ³
Sulfur oxides	Annual arithmetic mean	80 ug/m ³ (0.03 ppm)	---
	24-hour	365 ug/m ³ (0.14 ppm)	---
	3-hour	---	130 ug/m ³ (0.5 ppm)
Carbon monoxide	8-hour	10 mg/m ³ (9 ppm)	same
	1-hour	40 mg/m ³ (35 ppm)	same
Nitrogen dioxide	Annual arithmetic mean	100 ug/m ³ (0.05 ppm)	same
Ozone	1-hour	240 ug/m ³ (0.12 ppm)	same
Lead	Calendar quarter	1.5 ug/m ³	same

¹. The 1-, 3-, 8-, or 24-hour standards are not to be exceeded more than once per year.

1. Soils

The air pollutants from a major stationary source could alter soil characteristics, which may affect vegetation in the area. Vegetation can also be affected directly by acid rain, the result of SO₂ and NO_x emissions. There are pollutant levels at which soils and vegetation are not affected. In fact, the soil is a natural sink for many pollutants such as CO. Soils in the temperate zone have been estimated to remove and assimilate, on the average, 8.44 mg of CO/hr/m² from the atmosphere (Inman and Ingersoll, 1971). Particulate matter that drops out of the atmosphere and into the soil is generally recycled as nutrients or fixed in a form that is unavailable to vegetation (Bonn, 1972, Rasmussen, et al., 1975).

Pollutants such as fluoride, mercury and beryllium are absorbed by soil and generally fixed by the organic and clay fractions of the soil.

Therefore, the pollutants would be in a form unavailable to plants. The tolerance of soils and plants is dependent on the soil type and plant species.

The most serious impact on soil would be caused by acid rain, which could increase the soil acidity and increase nutrient leaching rates. It appears unlikely that increasing annual ambient levels by 0.8 ug/m^3 of SO_2 and 0.8 ug/m^3 of NO_2 that the proposed facility would measurably alter long-term precipitation pH levels. In fact, no accurate estimation of the change in the pH of rainfall caused by the proposed facility is feasible within current state-of-the-art technology.

2. Vegetation

Native vegetation in the study is associated with specific soil classifications. In areas of urban or agricultural usage, non-native species have invaded or are cultivated. Table III-4 features a compilation of soil and vegetation communities found in the area.

In residential areas plantings of various ornamental species are common; also prevalent, especially in less dense residential subdivisions are backyard gardens. In vacant lots where the native vegetation has been removed, thick coppices of Brazilian pepper are found. Fringing the shores of Tampa Bay are stands of Black Mangrove.

Table III-5 is a compilation of landscape, agricultural and other non-native species observed in the study area. This listing presents only those specimens which commonly occur.

Backyard gardens range from several square feet to an acre in size. The local climate allows for year round planting although tender plants are generally sown in spring only. Vegetables grown include corn, beans (bush, pole, lima, and pinto), peas (English and southern), greens (collards, mustard, lettuce, cabbage, celery), tomatoes, okra, carrots, turnips, broccoli, cauliflower, eggplant, and peppers. The most common fruit are strawberries; garden specimens of citrus and avocado are not uncommon.

The land within the study area to the south and east characterized by urban usage and resultant landscape plantings. Immediately surrounding the facility site on disturbed open land are dense coppices of Brazilian pepper. The tidal shoreline is fringed by black and red mangroves although the former species is more common. Severe freeze damage to the mangroves and many other tender exotics (e.g. Australian pine, cajuput) resulted from an unusually cold period during January, 1981. A few small citrus groves were identified in the far north portion of the study area.

TABLE III-4
SOIL AND VEGETATION COMMUNITIES

Soil Classification	Associated Major Community Species
Well drained deep sands	turkey oak, bluejack oak, slash pine, dogwood, hickory
Poorly drained sands over organic hardpans	pine flatwoods (slash pine, palmetto, wire grass)
Poorly drained sands over calcareous substrate	sabal palm, saw palmetto and wire grass
Well drained sands with phosphatic materials	live and laurel oaks, hickory, and pines
Tidal lands	white, black and red mangrove and black needlerush
Freshwater swamps	pond and bald cypress and sweet bay
Poorly drained acid sands	pine flatwoods (slash pine, palmetto, and wire grass)
Poorly drained neutral to alkaline soils	slash pine, water oaks, and sweet bay
Poorly drained dark colored sands	pine flatwoods (slash pine, palmetto, and wire grass)
Urban lands	landscape plantings and backyard gardens; commercial/industrial open land is covered by Brazilian pepper
Agricultural lands	pasture land of bahia grass; some citrus groves (oranges, grapefruit)

TABLE III-5 (Continued)

Common Name	Genus	Species	Location
<u>Palms</u>			
Cabbage palm	Sabal	palmetto	native; prairies and landscape plantings (state fee)
Areca palm	Chrysalidocarpus	lutescens	landscape plantings
Canary Island data palm	Phoenix	canariensis	landscape plantings
Coconut palm	Cocos	nucifera	landscape plantings
Manila palm	Veitchia	merrillii	landscape plantings
Queen palm	Arecastrum	romanzofianum	landscape plantings
<u>Native Trees</u>			
Slash Pine	Pinus	elliottii	pine flatwoods, swamps, & left on developed land
Longleaf Pine	Pinus	palustris	on drier sites and in landscapes
Live Oak	Quercus	virginiani	better, dry soils and landscapes
Water Oak	Quercus	nigra	poorly trained sites
Red Cedar	Juniperus	silicicola	soils underlain by calcareous material and landscapes
Sweet Gum	Liquidambar	styraciflua	poorly drained sands and loams
Sweet Bay	Magnolia	virginiana	poorly drained acid sands
Turkey Oak	Quercus	laevis	excessively drained sands
Bluejack Oak	Quercus	incana	exceesively drained sands
Bald cypress	Taxodium	distichum	riverine swamps
Pond cypress	Taxodium	ascendens	cypress domes and depressed lands among pine flatwoods along ditches and streams
Black mangrove	Avicennia	nitida	tidal swamps
Red mangrove	Rhizophora	mangle	tidal swamps seaward of black mangrove
Hickory	Carya	sp	mesic forests

TABLE III-5 (Continued)

Common Name	Genus	Species	Location
<u>Native Shrubs</u>			
Saw palmetto	Serenoa	sp	pine flatwoods and deep sands
Yaupon holly	Ilex	vomitorea	deep sands and landscapes
Gallberry	Ilex	coriacea	pine flatwoods
Wax myrtle	Myrica	cerifera	pine flatwoods
<u>Exotic Species</u>			
Australian Pine	Casuarina	spp	along roads and property lines
Citrus	Citrus	spp	oranges, grapefruits, lines, lemons, and tangerines in backyards or small groves
Jerusalem thorn	Parkinsonia	aculeata	disturbed open land and landscapes
Norfolk Island pine	Araucaria	excelsa	landscape plantings
Cajeput	Melaleuca	leucadendra	disturbed open land
Rubber tree	Ficus	sp.	landscape plantings
Banana	Musa	spp	landscape plantings
Bamboo	Bambusa	sp.	landscape plantings
Sago palm	Cycas	revoluta	landscape plantings
Pampas grass	Cortaderia	sellonae	landscape plantings
Copper leaf	Acalypha	wilkesiana	landscape plantings
Croton	Cordia	variegatum	landscape plantings
Hibiscus	Hibiscus	spp.	landscape plantings
Oleander	Nerium	oleander	landscape plantings
Surinam cherry	Eugenia	uniflora	landscape plantings
Brazilian pepper			grows in dense thickets on disturbed open land.

E. SENSITIVE ZONES

The area immediately surrounding the facility consists of open disturbed lands (created by recent construction) with some warehouse and other light manufacturing structures. The water body just east of this fill area is Tampa Bay, an emergent, or man-impacted ecosystem; it is the focal point of many area conservation groups primarily in conjunction with nesting and/or migratory bird populations. The mangrove ecosystem fringing tidal shores are important natural assets from both a fisheries and storm protection standpoints.

Tree species, such as black and red oak, white pine, gray and white birch, American elm and red maple, have been reported to be relatively sensitive to ambient SO₂ levels (Jones, et al., 1974, Davis and Wilhour, 1976). Concentrations of SO₂ between 786 and 1,572 ug/m³ for three hours have developed visible injury symptoms (Jones, et al., 1974). White pines exposed to ambient SO₂ levels of more than 0.25 ppm are often stunted (Linzon, 1966). Maximum annual SO₂ concentrations are predicted to be less than 35 ug/m³, which is considered to be below the threshold at which injury to even sensitive woody vegetation may occur (NAS, 1978).

Long-term exposure to 470 ug/m³ NO₂ throughout the months of the growing season has been found to reduce growth, weight and yield in tomato plants (Spiering, 1971). However, the predicted peak annual ambient NO₂ concentration of 0.8 ug/m³ will be well below the minimum concentration reported to cause injury to vegetation after long-term exposures.

Only small increases of ambient TSP levels, 1.44 ug/m³ and 0.16 ug/m³ for the 24-hour and annual averages will be caused by the proposed facility. These small increases will not be sufficient to coat foliage or block light and gas exchange (Lodge, et al., 1981).

Vegetation is extremely resistant to CO. In fact, plants exposed to 115 mg/m³ CO for up to three weeks did not produce any visible injury (Zimmerman, et al., 1933). Predicted maximum CO levels in the vicinity of the proposed facility is 14 ug/m³, per 8-hour interval.

Ambient lead levels are predicted to be less than 0.24 ug/m³ for a calendar quarter. The proposed facility will contribute approximately 17% of the ambient standard. However, there have been no known reports of injury to vegetation from lead concentrations near highways where lead concentrations are expected to be high (NRC, 1979).

Plants can be particularly sensitive to fluoride emissions, especially as hydrofluoric acid. However, most of the fluoride emissions from the proposed plant will be in the form of an aerosol (suspended fine particulates), which is less damaging to vegetation. Fluorides can cause spotting or partial destruction of leaf surfaces and reduced plant growth.

Total ambient fluoride levels of 0.8 to 4.0 ug/m³ for several days have been shown to adversely affect the most fluoride-sensitive plants, such as corn, cherry pine and gladiolus (Treshow, 1969). However, when gladiolus plants were exposed to average fluoride aerosol averaging levels of 1.9 ug/m³ for four weeks, no damage to leaf areas was experienced (Pack, et al., 1960).

The proposed facility may have peak 24-hour averaging fluoride levels of 0.24 ug/m³ in the immediate vicinity of the plant.

F. SUMMARY

There will be a positive economic impact on Pinellas County due to the implementation of the proposed facility, while environmental impacts will be slight. Workers for the construction and operation of the facility will be from the local work force; therefore, no growth impacts would be experienced due to an influx of workers from outside the county.

The Class 1 areas closest to the proposed facility are about at a 75 kilometers from the facility. A level 1 visibility analysis indicated that it is extremely unlikely that visibility would be affected in these areas.

The soils in Pinellas County have sufficient high clay content to resist acid precipitation, and should be good at absorbing pollutants such as particulate matter, fluoride, mercury and beryllium. Any increase in SO₂ or NO₂ due to the proposed facility should not significantly alter the pH of rainfall. In fact, any pH change experienced would not be measurable. Increased ambient levels of criteria and non-criteria pollutants due to the facility emissions are not likely to have a significant effect on vegetation in the area.

REFERENCES

- Bonn, H. L., "Soil Absorption of Air Pollutants," Journal of Environmental Quality 1(4):372-276 (1972).
- Davis, D. D. and R. G. Wilbour, "Susceptibility of Woody Plants to Sulfur Dioxide and Photochemical Oxidants," EPA-600/3-76102 (Corvallis, Oregon: EPA, Environmental Research Lab, 1976).
- Feder, W. A., "Cumulative Effects of Chronic Exposure of Plants to Low Levels of Air Pollutants," Air Pollution Damage to Vegetation. (Washington, D. C.: American Chemical Society, 1973).
- Frink, C. R., G. K. Voight and M. K. Musser, United States Department of Agriculture, "Potential Effects of Acid Precipitation of Soils in the Humid Temperate Zone," Forest Service Technical Report NE-23:685-710 (1976).
- Inman, R. E. and R. B. Ingersoll, "Uptake of Carbon Monoxide by Soil Fungi," Journ. APCA 21:646-647 (1971).
- Jones, H. C., D. Weber, and D. Basillie, "Acceptable Limits for Air Pollution Dosages and Vegetation Effects: Sulfur Dioxide." 67th Annual Meeting of the Air Pollution Control Association, Denver, Colorado (1974).
- Linzon, S. N., "Uptake of Cadmium, Lead, and Zinc from Soil and Air," Soil Sci. 111:129 (1958), p. 21.
- Lodge, J. P., Jr., A. P. Waggoner, D. T. Klodt and C. N. Crain, "Non-health Effects of Airborne Particulate Matter," Atmos. Env. 15(4):431-482, (1981).
- National Academy of Sciences, Committee on Sulfur Oxides, "Sulfur Oxides," (Washington, D. C., 1978).
- National Research Council, Subcommittee on Airborne Particles, Airborne Particles, (Baltimore: University Park Press, 1979), p. 212.
- Pack, M. R., A. C. Hill, M. D. Thomas and L. G. Transtrum. "Determination of Gaseous and Particulate Inorganic Fluorides in the Atmosphere," pp. 27-44. American Society for Testing Materials Special Technical Publication No. 281. Symposium on Air Pollution Control, San Francisco, California, October 16, 1959 (Philadelphia: American Society for Testing Materials, 1960).
- Rasmussen, K. H., M. Taheri and P. L. Kabel, "Global Emissions and Natural Processes for Removal of Gaseous Pollutants," Water, Air and Soil Pollution 4:33-64 (1975).

Tamm, C. O., G. Wiklander, and B. Popovic. "Effects of Applications of Sulfuric Acid to Poor Pine Forests," in Proc. First Int. Symp. on Acid Precipitation and Forest Ecosystem, ed. L. S. Dochinger and T. A. Jeliga. (Upper Darby, PA: USPA Forest Service Gen. Tech. Rep. NE-23, 1976) pp. 1011-1024.

Taylor, O. C., C. R. Thompson, D. T. Tingey, and R. A. Reinert, "Oxides of Nitrogen," in Recognition of Air Pollution Injury to Vegetation, ed. J. S. Jacobson and A. C. Hills. (Pittsburgh, PA: APCA, 1975).

Treshow, M., Pennsylvania State University, Center for Air Environment Studies, "Symptomatology of Fluoride Injury on Vegetation," in Handbook of Effects Assessment: Vegetation Damage, ed. N. L. Lacasse and W. J. Moroz. (University Park, PA, 1969), pp. VII-1 to VII-41.

AIR PERMIT APPLICATION FORMS



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION
APPLICATION TO OPERATE/CONSTRUCT
AIR POLLUTION SOURCES

SOURCE TYPE: Incinerator New¹ Existing¹
 APPLICATION TYPE: Construction Operation Modification
 COMPANY NAME: Pinellas County COUNTY: Pinellas
 Identify the specific emission point source(s) addressed in this application (i.e. Lime Kiln No. 4 with Venturi Scrubber; Peeking Unit No. 2, Gas Fired) Incinerator
 SOURCE LOCATION: Street 28th SE & 110th Avenue City County
 UTM: East _____ North _____
 Latitude 27 ° 52 ' - "N Longitude 82 ° 40 ' - "W
 APPLICANT NAME AND TITLE: Pinellas County, Dept. of Public Works & Utilities
 APPLICANT ADDRESS: 310 Court Street, Clearwater, Florida 33516

SECTION I: STATEMENTS BY APPLICANT AND ENGINEER

A. APPLICANT

I am the undersigned owner or authorized representative* of Pinellas County
 I certify that the statements made in this application for a Construction Permit
 permit are true, correct and complete to the best of my knowledge and belief. Further, I agree to maintain and operate the pollution control source and pollution control facilities in such a manner as to comply with the provision of Chapter 403, Florida Statutes, and all the rules and regulations of the department and revisions thereof. I also understand that a permit, if granted by the department, will be non-transferable and I will promptly notify the department upon sale or legal transfer of the permitted establishment.

*Attach letter of authorization

Signed: D. F. Acenbrack
D. F. Acenbrack, Director
 Name and Title (Please Type)
 Date: 6/10/83 Telephone No. 813-825-156

B. PROFESSIONAL ENGINEER REGISTERED IN FLORIDA (where required by Chapter 471, F.S.)

This is to certify that the engineering features of this pollution control project have been designed/examined by me and found to be in conformity with modern engineering principles applicable to the treatment and disposal of pollutants characterized in the permit application. There is reasonable assurance, in my professional judgment, that the pollution control facilities, when properly maintained and operated, will discharge an effluent that complies with all applicable statutes of the State of Florida and the rules and regulations of the department. It is also agreed that the undersigned will furnish, if authorized by the owner, the applicant a set of instructions for the proper maintenance and operation of the pollution control facilities and, if applicable, pollution sources.

Signed: Robert Van Deman
Robert Van Deman
 Name (Please Type)

(Affix Seal)

(SEALED)

Henningson, Durham & Richardson, Inc.
 Company Name (Please Type)
P.O. Box 5576, Clearwater, Florida 33516
 Mailing Address (Please Type)
 Date: 6/10/83 Telephone No. 813-577-945

Florida Registration No. 25963

¹See Section 17-2.02(15) and (22), Florida Administrative Code, (F.A.C.)

SECTION II: GENERAL PROJECT INFORMATION

A. Describe the nature and extent of the project. Refer to pollution control equipment, and expected improvements in source performance as a result of installation. State whether the project will result in full compliance. Attach additional sheet if necessary.

Addition of third combustion to existing facility. Advantages
will be greater availability of energy production. Electrostatic
precipitators will be used to control particulate.

B. Schedule of project covered in this application (Construction Permit Application Only)

Start of Construction August 1983 Completion of Construction August 1986

C. Costs of pollution control system(s): (Note: Show breakdown of estimated costs only for individual components/units of the project serving pollution control purposes. Information on actual costs shall be furnished with the application for operation permit.)

D. Indicate any previous DER permits, orders and notices associated with the emission point, including permit issuance and expiration dates.

DER Powerplant Site Certification PA 78-11

E. Is this application associated with or part of a Development of Regional Impact (DRI) pursuant to Chapter 380, Florida Statutes, and Chapter 22F-2, Florida Administrative Code? Yes No

F. Normal equipment operating time: hrs/day 24 ; days/wk 7 ; wks/yr 52 ; if power plant, hrs/yr 8760 ;
 if seasonal, describe: _____

G. If this is a new source or major modification, answer the following questions. (Yes or No)

- | | |
|---|------------|
| 1. Is this source in a non-attainment area for a particular pollutant? | <u>Yes</u> |
| a. If yes, has "offset" been applied? | <u>No</u> |
| b. If yes, has "Lowest Achievable Emission Rate" been applied? | <u>No</u> |
| c. If yes, list non-attainment pollutants. | |
| <u>Ozone</u> | |
| 2. Does best available control technology (BACT) apply to this source? If yes, see Section VI. | <u>Yes</u> |
| 3. Does the State "Prevention of Significant Deterioration" (PSD) requirements apply to this source? If yes, see Sections VI and VII. | <u>Yes</u> |
| 4. Do "Standards of Performance for New Stationary Sources" (NSPS) apply to this source? | <u>Yes</u> |
| 5. Do "National Emission Standards for Hazardous Air Pollutants" (NESHAP) apply to this source? | <u>Yes</u> |

Attach all supportive information related to any answer of "Yes". Attach any justification for any answer of "No" that might be considered questionable.

SECTION III: AIR POLLUTION SOURCES & CONTROL DEVICES (Other than Incinerators)

A. Raw Materials and Chemicals Used in your Process, if applicable:

Description	Contaminants		Utilization Rate - lbs/hr	Relate to Flow Diagram
	Type	% Wt		

B. Process Rate, if applicable: (See Section V, Item 1)

1. Total Process Input Rate (lbs/hr): _____

2. Product Weight (lbs/hr): _____

C. Airborne Contaminants Emitted:

Name of Contaminant	Emission ¹		Allowed Emission ² Rate per Ch. 17-2, F.A.C.	Allowable ³ Emission lbs/hr	Potential Emission ⁴		Relate to Flow Diagram
	Maximum lbs/hr	Actual T/yr			lbs/hr	T/yr	

D. Control Devices: (See Section V, Item 4)

Name and Type (Model & Serial No.)	Contaminant	Efficiency	Range of Particles ⁵ Size Collected (in microns)	Basis for Efficiency (Sec. V, It ⁵)

¹See Section V, Item 2.

²Reference applicable emission standards and units (e.g., Section 17-2.05(6) Table II, E. (1), F.A.C. - 0.1 pounds per million 8TU heat input)

³Calculated from operating rate and applicable standard

⁴Emission, if source operated without control (See Section V, Item 3)

⁵If Applicable

E. Fuels

Type (Be Specific)	Consumption*		Maximum Heat Input (MMBTU/hr)
	avg/hr	max./hr	

*Units Natural Gas, MMCF/hr; Fuel Oils, barrels/hr; Coal, lbs/hr

Fuel Analysis:

Percent Sulfur: _____ Percent Ash: _____
 Density: _____ lbs/gal Typical Percent Nitrogen: _____
 Heat Capacity: _____ BTU/lb _____ BTU/gal
 Other Fuel Contaminants (which may cause air pollution): _____

F. If applicable, indicate the percent of fuel used for space heating. Annual Average _____ Maximum _____

G. Indicate liquid or solid wastes generated and method of disposal.

H. Emission Stack Geometry and Flow Characteristics (Provide data for each stack):

Stack Height: _____ ft. Stack Diameter: _____ ft.
 Gas Flow Rate: _____ ACFM Gas Exit Temperature: _____ °F.
 Water Vapor Content: _____ % Velocity: _____ FPS

SECTION IV: INCINERATOR INFORMATION

Type of Waste	Type O (Plastics)	Type I (Rubbish)	Type II (Refuse)	Type III (Garbage)	Type IV (Pathological)	Type V (Liq & Gas By-prod.)	Type VI (Solid By-prod.)
Lbs/hr Incinerated approx.	8%	24%	40%	10%	0	0	18%
	7000	21000	35000	8750			15750

Description of Waste Municipal Solid Waste

Total Weight Incinerated (lbs/hr) 87500 @ 5,000Btu/lb Design Capacity (lbs/hr) 87500

Approximate Number of Hours of Operation per day 24 days/week 7

Manufacturer UOP

Date Constructed _____ Model No. _____

	Volume (ft) ³	Heat Release (BTU/hr)	Fuel		Temperature (°F)
			Type	BTU/hr	
Primary Chamber	Na	4.11x10 ⁸ Btu/hr	Solid Waste	4.11x10 ⁸ Btu/hr	1600-1800°F
Secondary Chamber					

Stack Height: 161 ft. Stack Diameter 7.78bf Stack Temp. 450°F
 Gas Flow Rate: 251,000 ACFM DSCFM* Velocity 88 FPS

*If 50 or more tons per day design capacity, submit the emissions rate in grains per standard cubic foot dry gas corrected to 50% excess air.

Type of pollution control device: Cyclone Wet Scrubber Afterburner Other (specify) ESP

Brief description of operating characteristics of control devices: _____

Electrostatic collection of particulate matter

Ultimate disposal of any effluent other than that emitted from the stack (scrubber water, ash, etc.):

solids to landfill

liquids to sewer

SECTION V: SUPPLEMENTAL REQUIREMENTS

Please provide the following supplements where required for this application.

1. Total process input rate and product weight – show derivation.
2. To a construction application, attach basis of emission estimate (e.g., design calculations, design drawings, pertinent manufacturer's test data, etc.) and attach proposed methods (e.g., FR Part 60 Methods 1, 2, 3, 4, 5) to show proof of compliance with applicable standards. To an operation application, attach test results or methods used to show proof of compliance. Information provided when applying for an operation permit from a construction permit shall be indicative of the time at which the test was made.
3. Attach basis of potential discharge (e.g., emission factor, that is, AP42 test).
4. With construction permit application, include design details for all air pollution control systems (e.g., for baghouse include cloth to air ratio; for scrubber include cross-section sketch, etc.).
5. With construction permit application, attach derivation of control device(s) efficiency. Include test or design data. Items 2, 3, and 5 should be consistent: actual emissions = potential (1-efficiency).
6. An 8½" x 11" flow diagram which will, without revealing trade secrets, identify the individual operations and/or processes. Indicate where raw materials enter, where solid and liquid waste exit, where gaseous emissions and/or airborne particles are evolved and where finished products are obtained.
7. An 8½" x 11" plot plan showing the location of the establishment, and points of airborne emissions, in relation to the surrounding area, residences and other permanent structures and roadways (Example: Copy of relevant portion of USGS topographic map).
8. An 8½" x 11" plot plan of facility showing the location of manufacturing processes and outlets for airborne emissions. Relate all flows to the flow diagram.

9. An application fee of \$20, unless exempted by Section 17-4.05(3), F.A.C. The check should be made payable to the Department of Environmental Regulation.
10. With an application for operation permit, attach a Certificate of Completion of Construction indicating that the source was constructed as shown in the construction permit.

SECTION VI: BEST AVAILABLE CONTROL TECHNOLOGY

- A. Are standards of performance for new stationary sources pursuant to 40 C.F.R. Part 60 applicable to the source?
 Yes No

Contaminant	Rate or Concentration
Particulate	0.08 gr / dscf @ 12% CO ₂

- B. Has EPA declared the best available control technology for this class of sources (If yes, attach copy) Yes No

Contaminant	Rate or Concentration

- C. What emission levels do you propose as best available control technology?

Contaminant	Rate or Concentration
Particulate	0.03 gr / dscf at 12% CO ₂

- D. Describe the existing control and treatment technology (if any).

- | | |
|---------------------------|----------------------|
| 1. Control Device/System: | NONE |
| 2. Operating Principles: | |
| 3. Efficiency: * | 4. Capital Costs: |
| 5. Useful Life: | 6. Operating Costs: |
| 7. Energy: | 8. Maintenance Cost: |
| 9. Emissions: | |

Contaminant	Rate or Concentration

*Explain method of determining D 3 above.

10. Stack Parameters

- a. Height: ft.
- b. Diameter:
- c. Flow Rate: ACFM
- d. Temperature:
- e. Velocity: FPS

E. Describe the control and treatment technology available (As many types as applicable, use additional pages if necessary).

1.

- a. Control Device: SEE BACT SECTION
- b. Operating Principles:
- c. Efficiency*:
- d. Capital Cost:
- e. Useful Life:
- f. Operating Cost:
- g. Energy*:
- h. Maintenance Cost:
- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

2.

- a. Control Device:
- b. Operating Principles:
- c. Efficiency*:
- d. Capital Cost:
- e. Useful Life:
- f. Operating Cost:
- g. Energy**:
- h. Maintenance Costs:
- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

*Explain method of determining efficiency.

**Energy to be reported in units of electrical power – KWH design rate.

3.

- a. Control Device:
- b. Operating Principles:
- c. Efficiency*:
- d. Capital Cost:
- e. Life:
- f. Operating Cost:
- g. Energy:
- h. Maintenance Cost:

*Explain method of determining efficiency above.

- i. Availability of construction materials and process chemicals:
 - j. Applicability to manufacturing processes:
 - k. Ability to construct with control device, install in available space and operate within proposed levels:
- 4.
- a. Control Device
 - b. Operating Principles:
 - c. Efficiency*:
 - d. Capital Cost:
 - e. Life:
 - f. Operating Cost:
 - g. Energy:
 - h. Maintenance Cost:
 - i. Availability of construction materials and process chemicals:
 - j. Applicability to manufacturing processes:
 - k. Ability to construct with control device, install in available space, and operate within proposed levels:

F. Describe the control technology selected:

SEE BACT SECTION

- 1. Control Device:
- 2. Efficiency*:
- 3. Capital Cost:
- 4. Life:
- 5. Operating Cost:
- 6. Energy:
- 7. Maintenance Cost:
- 8. Manufacturer:
- 9. Other locations where employed on similar processes:

a.

- (1) Company:
- (2) Mailing Address:
- (3) City:
- (4) State:
- (5) Environmental Manager:
- (6) Telephone No.:

* Explain method of determining efficiency above.

(7) Emissions*:

Contaminant	Rate or Concentration

(8) Process Rate*:

b.

- (1) Company:
- (2) Mailing Address:
- (3) City:
- (4) State:

* Applicant must provide this information when available. Should this information not be available, applicant must state the reason(s) why.

(5) Environmental Manager:

(6) Telephone No.:

(7) Emissions*:

Contaminant	Rate or Concentration
_____	_____
_____	_____
_____	_____

(8) Process Rate*:

10. Reason for selection and description of systems:

*Applicant must provide this information when available. Should this information not be available, applicant must state the reason(s) why.

SECTION VII – PREVENTION OF SIGNIFICANT DETERIORATION

A. Company Monitored Data

1. _____ no sites None TSP _____ () SO² _____ Wind spd/dir _____

Period of monitoring _____ / _____ / _____ to _____ / _____ / _____
month day year month day year

Other data recorded Pinellas County Dept. of Environmental Management

Attach all data or statistical summaries to this application.

2. Instrumentation, Field and Laboratory

a) Was instrumentation EPA referenced or its equivalent? Yes _____ No

b) Was instrumentation calibrated in accordance with Department procedures? Yes _____ No _____ Unknown

B. Meteorological Data Used for Air Quality Modeling

1. 5 Year(s) of data from 1 / 1 / 70 to 12 / 31 / 74
month day year month day year

2. Surface data obtained from (location) Tampa

3. Upper air (mixing height) data obtained from (location) Tampa

4. Stability wind rose (STAR) data obtained from (location) _____

C. Computer Models Used

1. CRSTER Modified? If yes, attach description.

2. P.TP/U Modified? If yes, attach description.

3. PTDIS Modified? If yes, attach description.

4. _____ Modified? If yes, attach description.

Attach copies of all final model runs showing input data, receptor locations, and principle output tables.

D. Applicants Maximum Allowable Emission Data

Pollutant	Emission Rate
TSP	_____ grams/sec
SO ²	_____ grams/sec

E. Emission Data Used in Modeling

Attach list of emission sources. Emission data required is source name, description on point source (on NEDS point number), UTM coordinates, stack data, allowable emissions, and normal operating time.

F. Attach all other information supportive to the PSD review.

*Specify bubbler (B) or continuous (C).

G. Discuss the social and economic impact of the selected technology versus other applicable technologies (i.e., jobs, payroll, production, taxes, energy, etc.). Include assessment of the environmental impact of the sources.

The project will create jobs and decrease need for landfill space.

H. Attach scientific, engineering, and technical material, reports, publications, journals, and other competent relevant information describing the theory and application of the requested best available control technology.

APPENDIX A-1
VISIBILITY ANALYSIS

Level I Visibility Analysis

Ref. EPA 450/4-8-031 Nov 80
 "Workbook for Estimating
 Visibility Impairment."

Q = Pine Hls Co. RRF Units 1, 2 + 3

Q_{part} = 1.81 metric tons/day particulate

Q_{NO_2} = 4.31 metric tons/day NO_2

Q_{SO_2} = 4.31 metric tons/day SO_2

x = 75 km to Chassahowitzka Nat Wildlife Area

σ_z = 90m vertical dispersion coefficient

Plume Dispersion Parameter

$$P = \frac{2.0 \times 10^5}{\sigma_z x} = \frac{2 \times 10^8}{90 \cdot 75} = 2.96 \times 10^4$$

T_{part} = Optical thickness

$$T_{part} = 10 \times 10^{-7} Q_{part} = (10 \times 10^{-7})(2.96 \times 10^4) \left(\frac{1.81}{4.31} \right)$$

$$T_{part} = \cancel{1.25 \times 10^{-2}} 5.86 \times 10^{-2}$$

$$T_{NO_2} = 1.7 \times 10^{-7} P Q_{NO_2} = 1.7 \times 10^{-7} (2.96 \times 10^4)(4.31)$$

$$T_{NO_2} = 2.17 \times 10^{-2}$$

r_{v0} = 25 km regional background visual range
 (Figure 13).

$T_{aerosol}$ - Primary & Secondary Aerosol

$$T_{ar} = 1.06 \times 10^{-5} r_{w0} (Q_{part} + 1.31 Q_{sc})$$

$$T_{ar} = (1.06 \times 10^{-5}) (25) (1.81 + 1.31(4.31))$$

$$T_{ar} = 1.98 \times 10^{-3}$$

C_1 = Plume Contrast / Sky

$$C_1 = \frac{T_{nc2}}{T_{part} + T_{nc2}} \left[1 - \exp(-T_{part} - T_{nc2}) \right] \left[\exp(-0.78 \frac{x}{r_{w0}}) \right]$$

$$C_1 = \frac{-2.17 \times 10^{-2}}{5.36 \times 10^{-2} + 2.17 \times 10^{-2}} \left[1 - \exp(-5.36 \times 10^{-2} + 2.17 \times 10^{-2}) \right] \left[\exp(-0.78 \frac{25}{25}) \right]$$

$$C_1 = -2.01 \times 10^{-3}$$

C_2 = Plume Contrast / Terrain

$$C_2 = \left[1 - \left(\frac{1}{C_1 + 1} \right) \exp(-[T_{part} + T_{nc2}]) \right] \left[\exp(-1.56 \frac{x}{r_{w0}}) \right]$$

$$C_2 = \left[1 - \left(\frac{1}{-2.01 \times 10^{-3} + 1} \right) \exp(-5.36 \times 10^{-2} + 2.17 \times 10^{-2}) \right] \left[\exp(-1.56 \frac{25}{25}) \right]$$

$$C_2 = -1.74 \times 10^{-5}$$

C_3 = Change in Sky/Terrain Contrast / Aerosol

$$C_3 = 0.368 [1 - \exp(-T_{ar})]$$

$$C_3 = 0.368 [1 - \exp(-1.98 \times 10^{-3})]$$

$$C_3 = 7.28 \times 10^{-4}$$

Notes:

Since the absolute values of C_1 , C_2 , & C_3 are all less than 0.01 it is unlikely that the RRF will cause ~~a~~ visibility impairment in the Class I area.

APPENDIX A-2
MASS BURN EMISSION FACTORS

DEVELOPMENT OF EMISSION FACTORS FOR MASS BURN RESOURCE RECOVERY FACILITIES

FEBRUARY 1983

Emission factors for mass burn resource recovery facilities were developed from a survey of available emission data in the literature and in proposals made by prospective contractors in response to RFPs for the construction of mass burn resource recovery facilities. Available data are limited and frequently the literature references the same data base more than once. An effort was made only to use data from mass burn waterwall incinerators. However, for some pollutants, data from refractory lined incinerators and RDF plants were included because of limited data available from mass burn facilities.

The emission levels presented by contractors in their proposals are considered representative of average to maximum emission levels expected because contractors are concerned that these levels will be used as emission limits in the permit. Where a specific contractor has submitted different emission values for different proposals, only the highest value was used. The inconsistencies between proposals can be attributed to a changing attitude towards the margin of safety used in deriving these numbers. It is unrealistic to specify absolute maximum emission limits because of the heterogeneous composition of municipal solid waste.

The actual emissions from a new mass burn resource recovery facility may be lower than the emission values presented in this paper. In the first place, a new facility would provide current air pollution control technology whereas the technology used for the tested facilities may represent an earlier level of technology which is less efficient. Also, the composition of the solid waste which will be processed may be different from the waste

from which the data were obtained. The solid waste burned will have a higher Btu content and significantly fewer glass and plastic bottles and metal cans if returnable container legislation has been enacted. The impact of this legislation may be to reduce emissions for certain pollutants such as lead, tin, and chlorides due to a reduction in the amount of cans and plastic bottles in the waste stream.

The emission factors presented herein (Tables 1 and 2) are averages of the various source data available. To avoid using the same test data twice, references that appeared to be duplicates of a previous source were eliminated. When an average emission value from three different facilities was presented in one reference, a weighted average of the three was assigned to this value. Thus, each facility tested and each proposal were given the same weight.

Emissions have been grouped into four major classifications. The first classification consists of total suspended particulates and is discussed separately. The next group consists of the major pollutants and includes SO₂, NO_x, CO, hydrocarbons, chlorides (represented as hydrogen chloride), and fluorides (represented as hydrogen fluoride). The last two groups consist of trace metals and certain organics.

1. Particulates

Uncontrolled particulate emission data is available from the Braintree, Nashville, Chicago Northwest, and Harrisburg facilities (1). The average uncontrolled particulate loading from these four plants is 26.6 lb/ton of solid waste fired. Based on seven proposals (2, 3, 4, 5, 6, 7, and 8) in which contractors estimated expected uncontrolled

particulate levels, an average of 37.6 lb/ton was calculated. Contractors used these values to calculate the required efficiency of their electrostatic precipitators to meet a specific particulate emission requirement. The uncontrolled particulate emission values proposed by the contractors range from 18 to 103 pounds per ton of solid waste fired because there is a difference in the uncontrolled particulate loading based on the configuration of the proposed system and the amount of excess air used. In addition, these values vary because of the margin of safety the contractors allow themselves for meeting a guaranteed particulate loading. To be conservative without using the highest controlled values proposed by contractors, a maximum uncontrolled emission value of 60 lb/ton of solid waste was used for calculating the required particulate removal efficiency to be used in the air pollution control technology analysis. This equates to an uncontrolled particulate loading of 3 gr/dscf.

2. Major Pollutants

The emission of SO₂, chlorides, and fluorides through the stack is largely dependent on the respective amount of sulfur, chlorine, and fluorine present in the fuel. Based on SO₂ emissions from Braintree, Nashville, Chicago Northwest, and Harrisburg waterwall incinerators (1, 9) and SO₂ data given in six proposals (3, 6, 8, 11, 13, and 14), a weighted average of 3 lb SO₂/ton of solid waste was obtained. For chlorides, a weighted average of 5.3 lb/ton of solid waste was obtained using actual data from the four incinerators and data from four proposals (10, 11, 13, and 14). There was no data available on fluoride emissions from mass burn waterwall incinerators in the

literature. However, the average for the four same proposals was 0.1 lb/ton of solid waste and equaled the values from the two sources found in the literature for other than waterwall incinerators.

Emissions of hydrocarbons, CO, and NO_x are dependent on the composition of the waste and on operating and design conditions at the facility. Based on data from Nashville (1) and Harrisburg (9) waterwall incinerators and six proposals (3, 6, 11, 12, 13, and 14), an emission factor of 0.8 lb of CO per ton of solid waste was derived. Data from Braintree was eliminated from the analysis because there are indications that the facility was operating under severe draft imbalance conditions at the time the tests were taken (15). The Braintree data were also eliminated when calculating the emission factor for hydrocarbons for the same reason. Based on four proposals (6, 11, 13, and 14), an emission factor of 0.2 lb of hydrocarbons per ton of solid waste was derived. Including the Braintree data would bring the weighted average up to 0.3 lb/ton. The NO_x emission factor of 4.3 lb/ton solid waste was derived from Braintree, Nashville, Chicago Northwest, and Harrisburg data (1), and emission values presented by six contractors in their proposals (3, 6, 11, 12, 13, and 14). Table 1 summarizes the derived emission factors for the major pollutants.

3. Trace Metals

Published data on trace metal emissions from incinerators in the United States and Europe were reviewed. Authors were contacted to discuss the data presented and to obtain additional data for making the proper corrections to report the data in pounds of pollutant per ton of solid

TABLE 1. EXPECTED EMISSION FACTORS OF MAJOR POLLUTANTS FROM RESOURCE RECOVERY FACILITIES

Pollutant	Pounds/Ton Solid Waste
Particulates	0.6
Hydrocarbons	0.2
Carbon Monoxide	0.8
Nitrogen Oxides	4.3
Sulfur Dioxide	3
Chlorides	5.3
Fluorides	0.1

waste fired. An effort was made to use data from mass burn waterwall incinerators only; but due to the limited available data, data from refractory lined incinerators and one RDF plant were used. The data from the RDF plant were very complete and were found to be of the same order of magnitude as the other data.

Six references (16, 17, 18, 19, 20, and 21) were found to be sufficiently complete, including additional data obtained from authors, to calculate the level of trace metals in the particulate fraction of the controlled flue gas. Table 2 summarizes these results. Each facility in the United States was given equal weight in the analysis, but all the seven facilities in Germany together were given the weight of one facility. This was done so the analysis would be more representative of data from facilities in the United States. The trace metals reported were those considered to be of concern which are listed in the USEPA report entitled "Environmental Assessment of Waste to Energy Processes" (1977). The trace metal emission factors were calculated based on a controlled particulate level of 0.6 pounds per ton (at 99% ESP efficiency) of solid waste fired. Portions of mercury, antimony, cadmium, lead, and tin emissions have been found to be present in the gaseous phase. Very little data are available quantifying the portion of these elements in the gaseous phase. Based on conversations with authors in the field, percentages were estimated as follows: mercury, 85%; antimony, 30%; cadmium, less than 10%; and lead and tin, less than 5% each. These percentages have been used to estimate the emission levels of these elements in the gaseous state. The last column in Table 2 represents a total of the various forms of the expected emissions of each pollutant.

TABLE 2. ESTIMATED TRACE METAL EMISSION FACTORS

Trace Metal	Measured Concentration in Controlled Particulates (ppm)	Estimated Uncontrolled Emissions (pounds per ton solid waste)		
		Particulate* Portion	Gaseous** Portion	Total
Antimony	1,388	8.3×10^{-4}	3.6×10^{-4}	1.2×10^{-3}
Arsenic	160.7	9.6×10^{-5}	-	9.6×10^{-5}
Barium	876	5.3×10^{-4}	-	5.3×10^{-4}
Beryllium	2.1	1.3×10^{-6}	-	1.3×10^{-6}
Cadmium	1,305	7.8×10^{-4}	0.9×10^{-4}	8.7×10^{-4}
Chromium	439.3	2.6×10^{-4}	-	2.6×10^{-4}
Cobalt	14.1	8.5×10^{-6}	-	8.5×10^{-6}
Copper	1,529	9.2×10^{-4}	-	9.2×10^{-4}
Manganese	778	4.7×10^{-4}	-	4.7×10^{-4}
Mercury	632	3.8×10^{-4}	2.2×10^{-3}	2.6×10^{-3}
Lead	47,100	2.8×10^{-2}	0.1×10^{-2}	2.9×10^{-2}
Lithium	100	6.0×10^{-5}	-	6.0×10^{-5}
Nickel	260.4	1.6×10^{-4}	-	1.6×10^{-4}
Silver	276.2	1.7×10^{-4}	-	1.7×10^{-4}
Tin	7,158	4.3×10^{-3}	0.2×10^{-3}	4.5×10^{-3}
Tungsten	14	8.4×10^{-6}	-	8.4×10^{-6}
Vanadium	52.6	3.2×10^{-5}	-	3.2×10^{-5}
Zinc	82,200	4.9×10^{-2}	-	4.9×10^{-2}
Zirconium	24.5	1.5×10^{-5}	-	1.5×10^{-5}

Note: * Based on a particulate loading of 0.6 lb/ton of solid waste fired.

** Percentages assumed to be in the gaseous state: mercury, 85%; antimony, 30%; cadmium, less than 10%; and lead and tin, less than 5% each.

4. Organic Compounds

Emission factors for certain organic compounds which have been identified as being of concern from a potential adverse health effect viewpoint, have been calculated based on test results on fly ash and stack particulates from unspecified European plants burning solid waste (22). Table 3 lists emission rates for these compounds based on a controlled particulate emission of 0.6 pounds per ton of solid waste. These compounds are absorbed on particulates and the potential emissions of these compounds is therefore dependent on the degree of particulate removal. Actual emissions of these compounds from a new mass burn resource recovery facility are expected to be minimal.

Research conducted by EPA indicates that at temperature of 1830F and higher in the combustion chamber, organic compounds are almost completely destroyed (more than 99%) if this temperature is maintained for at least two seconds (23, 24).

TABLE 3. ESTIMATED TRACE ORGANIC EMISSION FACTORS

Organic Compound	Emission Rate (10 ⁻⁶ lb/ton)
Total Polynuclear Aromatic Hydrocarbons (PAH)	240
Pyrene	6
Perylene	0.8
Ideno (1,2,3cd) pyrene	0.8
Fluoranthene	5
Coronene	0.8
Benzo(a)pyrene/benzo(e)pyrene	0.8
Benzo(ghi)perylene	2
Benzo(b)fluoranthene	1.5
Benzo(a)anthracene	3
Chlorinated Dibenzodioxins	
2, 3, 7, 8 - TCDD	0.02
TCDD	0.2
P5CDD	0.5
HCDD	0.8
H7CDD	0.8
OCDD	0.2
Chlorinated Dibenzofurans	
TCDF	0.3
P5CDF	0.6
HCDF	1.0
H7CDF	0.7
OCDF	0.08

Notes: * Based on a particulate loading of 0.6 lb/ton of solid waste.

Source: Arthur D. Little, Inc., March 1981

References

1. Simons, G. March 17, 1980. Air Pollution Aspects of Resource Recovery Facilities. California Air Resources Board. (Braintree, Nashville, Chicago Northwest, and Harrisburg data)
2. Clark-Kenith, Incorporated. October 15, 1982. Proposal for Dutchess County Resource Recovery Project.
3. Katy-Seghers Incinco Systems, Inc. Proposal for the Northeast Maryland Waste Disposal Authority - Southwest Resource Recovery Facility.
4. _____ . October 12, 1982. Proposal for Dutchess County Solid Waste Management Project.
5. Pennsylvania Engineering Corporation. October 15, 1982. Proposal for Dutchess County Resource Recovery Project.
6. UOP Inc. April 2, 1980. Proposal to Westchester County Industrial Development Agency for Westchester County Resource Recovery Plant.
7. Wheelabrator-Frye Inc. October 15, 1982. Proposal for Dutchess County Resource Recovery Project.
8. _____ . Proposal for Northeast Maryland Waste Disposal Authority-Southwest Resource Recovery Facility.
9. Gaughan, W. June 1978. Draft Environmental Impact Statement on Northeastern Massachusetts Resource Recovery Project. Prepared for Commonwealth of Massachusetts. Metrex Division of Mitre Corp. (Harrisburg data)
10. UOP Inc. June 1, 1981. Proposal for Onondaga County Resource Recovery Facility.
11. Browning-Ferris Industries. June 1981. Proposal for Onondaga County Resource Recovery Facility.
12. Wheelabrator-Frye, Inc. Proposal for Onondaga County Resource Recovery Project.
13. Waste Management, Inc. October 12, 1981. Proposal for McKay Bay Refuse to Energy Project.
14. International Incinerators, Inc. October 12, 1981. Proposal for the City of Tampa - McKay Bay Refuse to Energy Project Facility 1.
15. Rigo, H.G., Raschko, J., and Worster, S. Consolidated Data Base for Waste to Energy Plant Emissions. CSI Resource Systems, Inc. 1982 National Waste Processing Conference, May 2-5, 1982, pp 305-319.

16. Dumarey, R., Heindryckx, R., and Dams, R. February 1981. Determination of Mercury Emissions from a Municipal Incinerator. Environmental Science & Technology 15: 206-209.
17. Golembiewski, M., et al. April 1979. Environmental Assessment of a Waste to Energy Program: Braintree Municipal Incinerator. Midwest Research incorporated, Project No. 4290-L(14).
18. Greenberg, R., Gordon, G., and Zoller, W., November 1978. Composition of Particles Emitted from the Nicosia Municipal Incinerator. Environmental Science & Technology 12: 1329-1332.
19. Jacko, R.B. and Neuendorf, D.W. Trace Metal Particulate Emission Test Results from a Number of Industrial and Municipal Point Sources. Journal of Air-Pollution Control Association 27: 989.
20. Kirsch, H. November. Composition of Dust in the Waste Gases of Incineration Plants. Conversion of Refuse to Energy: First International Conference and Technical Exhibition, November 3-5, 1975. Montreaux, Switzerland.
21. Reid, R.S. and Heber, D.H. June 1977. Analysis of Fuel, Ash, and Flue Gas Characteristics; Ash and Leachate Analysis: East Hamilton Solid Waste Reduction Unit. Prepared for Humboldt County, California.
22. Arthur D. Little, Inc. March 1981. Municipal Incinerator Emission Estimates. Prepared for O'Brien & Gere Engineers, Inc. Cambridge, Massachusetts.
23. U.S. Environmental Protection Agency. 1977. Laboratory Evaluation of High Temperature Destruction of Polychlorinated Biphenyls and Related Compounds.
24. U.S. Environmental Protection Agency. 1976. Laboratory Evaluation at High Temperature Destruction of Kepone and Related Pesticides.

State of Florida Department of Environmental Regulation
 Pinellas County
 Resource Recovery Facility
 Case No. PA 78-11 and PA 83-18
 CONDITIONS OF CERTIFICATION (2/29/84)

Table of Contents

I.	Change in Discharge	1.
II.	Non-Compliance Notification	1
III.	Facilities Operation	2
IV.	Adverse Impact	2
V.	Right of Entry	2
VI.	Revocation or Suspension	3
VII.	Civil and Criminal Liability	3
VIII.	Property Rights	3
IX.	Severability	3
X.	Definitions	4
XI.	Review of Site Certification	4
XII.	Modification of Conditions	4
XIII.	Construction	5
	A. Control Measures	
	1. Stormwater Runoff	5
	2. Burning	5
	3. Sanitary Wastes	5
	4. Solid Wastes	6
	5. Noise	6
	6. Dust	6
	7. Transmission Lines	6
	B. Environmental Control Program	6
	C. Reporting	7
XIV.	Operation	7
	A. Air	
	1. Emission Limitations	7
	2. Electrostatic Precipitators	9
	3. Air Monitoring Program	10
	4. Reporting	10
	B. Fuel	11
	C. Cooling Tower	
	1. Makeup Water Constituency	11
	2. Chlorination	11
	3. Special Studies	12
	D. Water Discharges	
	1. Surface Water	12
	2. Groundwaters	13
	3. Groundwater Monitoring Program	14
	E. Solid/Hazardous Waste	15
	F. Operational Safeguards	17
	G. Transmission Lines	18
	H. Noise	18
XV.	Status of Existing Permits	18

State of Florida
Pinellas County
Resource Recovery Facility
Case No. PA 78-11 and PA 83-18
CONDITIONS OF CERTIFICATION

I. CHANGE IN DISCHARGE

All discharges or emissions authorized herein shall be consistent with the terms and conditions of this certification. The discharge of any pollutant not identified in the application, or more frequent than, or at a level in excess of that authorized herein, shall constitute a violation of the certification. Any anticipated facility expansions, production increases, or process modifications which may result in new, different, or increased discharges or pollutants, change in fuel, or expansion in steam generating capacity must be reported by submission of a new or supplemental application pursuant to Chapter 403, Florida Statutes.

II. NON-COMPLIANCE NOTIFICATION

If, for any reason, the permittee does not comply with or will be unable to comply with any limitation specified in this certification, the permittee shall notify the Southwest Florida District Manager of the Department by telephone during the working day that said noncompliance occurs and shall confirm this in writing within seventy-two (72) hours of becoming aware of such conditions, and shall supply the following information:

- A. A description of the discharge and cause of noncompliance; and
- B. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate and prevent recurrence of the noncomplying event.

III. FACILITIES OPERATION

The permittee shall at all times maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee to achieve compliance with the terms and conditions of this certification. Such systems are not to be bypassed without prior Department approval.

IV. ADVERSE IMPACT

The permittee shall take all reasonable steps to minimize any adverse impact resulting from noncompliance with any limitation specified in this certification, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

V. RIGHT OF ENTRY

The permittee shall allow the Secretary of the Florida Department of Environmental Regulation and/or authorized representatives, upon the presentation of credentials:

- A. To enter upon the permittee's premises where an effluent source is located or in which records are required to be kept under the terms and conditions of this permit, and
- B. To have access to and copy any records required to be kept under the conditions of this certification, and
- C. To inspect and test any monitoring equipment or monitoring method required in this certification and to sample any discharge or pollutants, and
- D. To assess any damage to the environment or violation of ambient standards.

VI. REVOCAION OR SUSPENSION

This certification may be suspended or revoked pursuant to Section 403.512, Florida Statutes, or for violations of any of its conditions.

VII. CIVIL AND CRIMINAL LIABILITY

This certification does not relieve the permittee from civil or criminal penalties for noncompliance with any conditions of this certification, applicable rules or regulations of the Department or Chapter 403, Florida Statutes, or regulations thereunder.

Subject to Section 403.511, Florida Statutes, this certification shall not preclude the institution of any legal action or relieve the permittee from any responsibilities, or penalties established pursuant to any other applicable State Statutes, or regulations.

VIII. PROPERTY RIGHTS

The issuance of this certification does not convey any property rights in either real or personal property, nor any exclusive privileges, nor does it authorize any injury to public or private property or any invasion of personal rights nor any infringement of Federal, State or local laws or regulations.

IX. SEVERABILITY

The provisions of this certification are severable, and if any provision of this certification or the application of any provision of this certification to any circumstances, is held invalid, the application of such provision to other circumstances and the remainder of the certification shall not be affected

thereby.

X. DEFINITIONS

The meaning of terms used herein shall be governed by the definitions contained in Chapter 403, Florida Statutes and any regulations adopted pursuant thereto. In the event of any dispute over the meaning of a term in these general or special conditions which is not defined in such statutes or regulations, such dispute shall be resolved by reference to the most relevant definitions contained in any other state or federal statute or regulation or, in the alternative by the use of the commonly accepted meaning as determined by the Department.

XI. REVIEW OF SITE CERTIFICATION

The certification shall be final unless revised, revoked or suspended pursuant to law. At least every five years from the date of issuance of certification the Department shall review all monitoring data that has been submitted to it during the preceding five-year period for the purpose of determining the extent of the permittee's compliance with the conditions of this certification and the environmental impact of this facility. The Department shall submit the results of its review and recommendations to the permittee. Such review will be repeated at least every five years thereafter.

XII. MODIFICATION OF CONDITIONS

Pursuant to Subsection 403.516(1), F.S., the Board hereby delegates the authority to the Secretary to modify any condition of this certification dealing with sampling, monitoring, reporting, specification of control equipment, related time schedules, emission limitations subject to notice and opportunity for hearing, or any special studies conducted, as necessary to attain the objectives of Chapter 403, Florida Statutes.

All other modifications shall be made in accordance with Section 403.516, Florida Statutes

XIII. CONSTRUCTION

The facility shall be constructed, as a minimum, pursuant to the design standards presented in the application.

A. Control Measures

1. Stormwater Runoff

To control runoff during construction which may reach and thereby pollute Waters of the State, necessary measures shall be utilized to settle, filter, treat or absorb silt-containing or pollutant-laden stormwater to insure against spillage or discharge of excavated material that may cause turbidity in excess of 50 Jackson Turbidity Units above background in Waters of the State. Control measures may consist of sediment traps, barriers, berms, and vegetation plantings. Exposed or disturbed soil shall be protected and stabilized as soon as possible to minimize silt and sediment laden runoff. The pH shall be kept within the range of 6.0 to 8.5.

2. Burning

Open burning in connection with land clearing shall be in accordance with Chapter 17-5, FAC, and County Ordinance 76-18. No additional permits shall be required, but prior to each act of burning, the Division of Forestry shall be contacted to determine if satisfactory conditions exist for burning. Open burning shall not occur if the Division of Forestry has issued a ban on burning due to fire hazard conditions.

3. Sanitary Wastes

Disposal of sanitary wastes from construction toilet facilities shall be in accordance with applicable regulations of the appropriate local health agency.

4. Solid Wastes

Solid wastes resulting from construction shall be disposed of in accordance with the applicable regulations of Chapter 17, FAC.

5. Noise

Construction noise shall not exceed local noise ordinance specifications, nor those noise standards imposed by zoning.

6. Dust

The County shall employ proper dust-control techniques to minimize fugitive dust emissions.

7. Transmission Lines

The directly associated transmission lines from the Resource Recovery Facility electric generators to the existing Florida Power Corporation Gandy substation shall be cleared, maintained and prepared without the use of herbicides.

B. Environmental Control Program

An environmental control program shall be established under the supervision of a qualified person to assure that all construction activities conform to good environmental practices and the applicable conditions of certification.

If unexpected or harmful effects or evidence of irreversible environmental damage are detected during construction, the permittee shall notify the DER Southwest Florida District Office, 7601 Highway 301 North, Tampa, Florida, 33610, by telephone during the working day that the effect or damage occurs and shall confirm this in writing within seventy-two (72) hours of becoming aware of such conditions, and shall provide in writing an analysis of the problem and a plan to eliminate or significantly reduce the harmful effects of damage.

C. Reporting

1. Starting three (3) months after certification, a quarterly construction status report shall be submitted to the Southwest Florida District Office of the Department of Environmental Regulation. The report shall be a short narrative describing the progress of construction.

2. Upon completion of construction the DER Southwest Florida District Office will be notified in order that a pre-operational inspection can be performed.

XIV. OPERATION

A. Air

The operation of the Resource Recovery Facility shall be in accordance with all applicable provisions of Chapter 17-2, 17-5, and 17-7, Florida Administrative Code. In addition to the foregoing, the permittee shall comply with the following specific conditions of certification:

1. Emission Limitations upon Operation of Unit 3

a. Stack emissions from each unit shall not exceed the following:

- (1) Particulate matter: in grains per standard cubic foot dry gas corrected to 12% CO₂
Units 1 and 2 - 0.08
Unit 3 - 0.03
- (2) SO₂: 83 lbs/hr of Sulfur Dioxide
- (3) Nitrogen Oxides: 132 lbs/hr
- (4) Carbon Monoxide: 66 lbs/hr
- (5) Lead: .1.3 lbs/hr
- (6) Mercury: 3200 grams/day when more than 2205 lbs/day of municipal sludge is fired. Compliance shall be determined in accordance with 40 CFR 61, Method 101, Appendix B.
- (7) Odor: there shall be no objectionable odor.
- (8) Visible emissions: opacity shall be no greater than 10% except that visible emissions with no more than 20% opacity may be allowed for up to three minutes in any one hour except during start up or upsets when the provisions of 17-2.250, FAC shall apply. Opacity compliance shall be demonstrated in accordance with Florida Administrative Code Rule 17-2, 700(6)(2)9;, DER Method 9.

b. The height of the boiler exhaust stacks shall not be less than 161 feet above grade.

c. The incinerator boilers shall not be loaded in excess of their rated capacity of 87,500 pounds per hour each.

d. The incinerator boilers shall have a metal name plate affixed in a conspicuous place on the shell showing manufacturer, model number, type waste, rated capacity and certification number.

e. Compliance with the limitations for particulates, sulfur oxides, nitrogen oxides, carbon monoxide and lead shall be determined in accordance with Florida Administrative Code Rule 17-2.700, DER Methods 1,2, 3, 5, 6, and 40 CFR 60, Appendix A, Method 7. The stack test shall be performed at $\pm 10\%$ of the maximum steam rate of 250,000 pounds per hour.

2. Electrostatic Precipitators

For Unit 3 the electrostatic precipitator shall be designed and constructed to achieve a maximum emission rate of 0.03 grains per dscf. In the event that the ESP fails to perform as specified, or if other parameters of the facility's operation are subsequently modified, additional control will be necessitated.

For Units 1 and 2 the three-field electrostatic precipitator shall be designed and constructed to allow the installation of a fourth field in the event that the three-field ESP fails to perform as specified, or if other parameters of the facility's operation are subsequently modified, necessitating additional control.

3. Air Monitoring Program

a. The permittee shall install and operate continuously stack monitoring devices for oxygen and opacity. The monitoring devices shall meet the applicable requirements of Chapter 17-2, 710, FAC, and 40 CFR 60.45, and 40 CFR 60.13, including certification of each device.

b. The permittee shall provide sampling ports into the stack and shall provide access to the sampling ports in accordance with Section 17-2.700(4), FAC.

c. The permittee shall have a sampling test of the stack emissions performed by a commercial testing firm within 90 days of the start of operation of the boilers and annually from the date of testing thereafter.

d. The permittee shall operate two continuous SO₂ monitors and one continuous wind direction and velocity monitor in the immediate vicinity of the site. The monitors shall be specifically located as designated by the DER and shall conform to 40 CFR 53. Monitoring shall begin upon commencement of operation.

4. Reporting

a. Two copies of the results of the stack tests shall be submitted within forty-five days of testing to the DER Southwest Florida District Office.

b. Stack monitoring shall be reported to the DER Southwest District Office on a quarterly basis in accordance with Section 17-2.710, FAC, and 40 CFR, Part 60, Subsection 60.7.

c. SO₂ monitoring shall be reported to the DER Southwest Florida District Office on a monthly basis.

B. Fuel

The Resource Recovery Facility shall utilize refuse such as garbage and trash (as defined in Chapter 17-7, FAC) as its fuel. Use of alternate fuels would necessitate modification of these Conditions of Certification.

C. Cooling Tower

1. Makeup Water Constituency

The Resource Recovery Facility shall utilize only treated sewage effluent or stormwater runoff from the stormwater holding pond as cooling tower makeup water. The effluent shall have received prior to use in the tower, as a minimum, secondary treatment, as well as treatment described in Condition XIV.C.2. below. Use of waters other than treated sewage effluent or site stormwater, i.e., higher quality potable waters or lower quality less-than-secondarily treated sewage effluent, will require a modification of conditions agreed to by the Southwest Florida Water Management District and the Department and must be approved by the Governor and Cabinet.

2. Chlorination

Chlorine levels in the cooling tower makeup water shall continuously be monitored, prior to insertion in the cooling towers. Sewage effluent from the Northeast St. Petersburg Wastewater Treatment Plant used as makeup shall be treated if necessary to maintain a 1.0 mg/liter total chlorine residual after fifteen minutes contact time. Makeup water from the Largo Wastewater Treatment Plant shall be treated to maintain a 1.0 mg/liter free chlorine residual after fifteen minutes contact time. Chlorination should occur at an effluent turbidity of 5 Nephelometric Turbidity Units or less.

3. Special Studies

Upon satisfactory demonstration to the Department that the number of viruses entering the towers in the effluent makeup from the upgraded Largo Plant can be reduced to an undetectable level with the use of a lesser amount of chlorination, the above requirement may be altered to 1.0 mg/liter total chlorine residual after a 15 minute contact time or alternate levels as approved by the department. This demonstration may occur through performance of special studies approved by the Department. Alteration of the chlorination requirements must still insure adequate treatment for the control of bacterial growth in the cooling towers.

D. Water Discharges

1. Surface Water

a. Any discharges from the site stormwater/leachate treatment system via the emergency overflow structure which result from an event LESS than a ten-year, 24-hour storm (as defined by the U.S. Weather Bureau Technical Paper No. 40, or the DOT drainage manual, or similar documents) shall meet State Water Quality Standards, Chapter 17-3, FAC.

b. Sampling of water quality in the aeration pond, the cattail ponds, and an analysis of the tissues of the cattails utilized as part of the leachate/stormwater treatment system shall be conducted prior to pumping of leachate or stormwater through this system to verify background levels and concentrations of any metals, especially heavy metals, already present in the ponds or the vegetation. Within three months after commencement of stormwater/leachate pumping through this system, and quarterly thereafter, the pond waters and cattail tissues, as well as root detritus or other sediments on the bottom of the ponds shall again be sampled to determine the degree and effectiveness of heavy metal uptake treatment in this system, and for correlation with

groundwater monitoring data. If analyses indicate that toxic levels of materials are present in the cattail tissues, root detritus, or other pond precipitates, then these materials shall be incinerated or otherwise removed from contact with the natural environment and groundwaters. Results of analyses conducted shall be sent to the Department for review of system effectiveness.

c. Leachate, stormwater, or other site wastewaters which are to be spray irrigated shall be treated to conform to any rules promulgated by the State for the land application of wastewaters in areas not commonly accessible to the public.

d. Cooling tower blowdown shall not be discharged to surface waters.

e. Upon satisfactory demonstration to the Department that surface water quality will not be deteriorated, a special pilot operation, in the field, to determine the environmental effect of land application of process blowdown water from the Resource Recovery Facility may be allowed. This demonstration will require submittal of background and system design data, and provisions for monitoring as approved by the Department.

2. Groundwaters

a. All discharges to groundwaters, such as landfill leachate, shall be collected and treated as necessary, or otherwise be of high enough quality, to be able to meet the Water Quality Standards of Chapter 17-3.101, FAC, (Class G-II Groundwaters) at the boundary of the site.

b. If the groundwater monitoring system in the vicinity of the aeration/cattail ponds indicates that groundwater quality beyond the boundary of the site has been deteriorated by substances leaching from these ponds, then these ponds shall be lined or other Departmentally approved methods employed to reduce

further leaching sufficient to insure attainment of groundwater quality standards at the boundary of the site.

3. Groundwater Monitoring Program

a. Sampling of the shallow aquifer groundwater quality shall be conducted in at least four wells in the site vicinity. One of these wells shall be up hydrologic slope from the landfill area to provide current background data; one shall be located in the immediate vicinity of the aeration/cattail ponds; and two shall be located down hydrologic slope from the landfill/spray irrigation areas. Specific location of these wells may be proposed by the applicant, but must be approved by the Department.

b. Operational background monitoring shall commence at least one year prior to operation of the resource recovery facility. Construction of monitoring wells and the collection of samples shall be in accordance with EPA recommended methods as contained in Procedures Manual for Ground Water Monitoring at Solid Waste Disposal Facilities (EPA/530/SW-611). The wells shall be deep enough to insure that groundwater samples can be obtained with the groundwater table elevation at its estimated lowest point and shall be protected from damage or destruction. Samples shall be analyzed in accordance with the methods described in Chapter 17-4, FAC. Analyses shall be performed by laboratories which are approved by the Department of Health and Rehabilitative Services to conduct analyses pursuant to Section 403.863, F.S., the State Public Water Supply Laboratory Certification Program.

c. The wells shall be monitored on a quarterly basis for the following parameters:

Conductivity	Arsenic	Selenium
Nitrates	Barium	Silver
Iron	Cadmium	Chlorides

COD	Chromium	pH
Nickel	Lead	Copper
Aluminum	Mercury	Zinc
Total Coliform Bacteria		

d. Reports shall be submitted in duplicate within 30 days of receipt of analysis results to the Department for distribution to the appropriate review personnel.

e. The monitoring program may be reviewed annually by the Department, and a determination made as to the necessity and extent of continuation of the program. Aspects of the program relation to sampling, monitoring, reporting, and related time schedules may be modified in accordance with the provisions of condition number XII.

E. Solid/Hazardous Waste

1. Operation of the associated landfill shall be done in accordance with all applicable portions of Chapter 17-7, FAC, including prohibitions, procedures for closing of the landfill, and final cover requirements, or, as provided in this condition (XIV.E.) in its entirety.

2. Putrescible wastes shall receive daily cover. No cover shall be required for the landfilling of only ash or construction/demolition debris. Daily cover shall consist of a six inch layer of compacted earth or other material approved by the DER placed at the end of each working day.

3. Rodent and insect control shall be provided as necessary to protect the health and safety of site employees and the public. Pesticides used to control rodents, flies, and other vectors shall be as specified by the Florida Department of Agriculture and Consumer Services.

4. A monthly report shall be prepared detailing the amount and type (putrescible, special wastes, boiler residue, etc.) of materials landfilled at the site, and the treatment provided (see condition XIV.E.2. above). These reports shall be furnished to the DER Southwest District Office quarterly, commencing 120 days after the Resource Recovery Facility becomes operational and is producing residues.

5. Unless approved by the Department with subsequent modification of conditions, this facility shall not accept materials currently defined as "Hazardous Wastes", i.e., pesticides, volatile or radioactive material, etc.

6. No putrescible wastes shall be placed below the maximum groundwater level unless permanent leachate controls are installed. Methodology for permanent leachate controls shall be submitted to the Department for review. Such methodology shall not be implemented until approved by the Department. In the absence of permanent leachate controls, demolition debris and other non-putrescible items (other than boiler residue) shall be utilized to separate the putrescible waste from the groundwater. Boiler residue may be placed below the maximum groundwater level without permanent leachate controls provided that the permittee demonstrates that the residue will not contribute to a violation of water quality criteria at the boundary of a zone of discharge extending to the site boundary. Fly ash which has been segregated or separated from bottom ash shall not be placed below the maximum groundwater level without permanent leachate controls.

7. Separate cells and lifts shall be maintained for landfilling putrescible wastes.

8. All cells will be constructed to promote leachate drainage to a low end of the cell; all leachate formed at the low end of an active cell shall be pumped to the aeration pond for treatment.

9. A chemical analysis of the boiler residue shall be conducted within 30 days after commencement of operation, testing at the minimum for levels of Cadmium, Chromium, Zinc and Lead to determine the nature and potential toxicity or hazardousness of the materials created in the combustion process.

10. Results from the residue analysis shall immediately be sent to the Department and will be used to determine whether or not these materials constitute a "Hazardous Waste" as defined by Chapter 17-30, FAC; results of these analyses may also be used for correlation with groundwater monitoring information and in any subsequent modification of conditions.

11. If residue material are determined to be a "Hazardous Waste", then measures shall be taken to treat or dispose of the residues pursuant to rules promulgated by either Federal or State authorities.

12. If the nature of materials received at the facility becomes altered, either due to modification of conditions, i.e., the facility is allowed to incinerate already known hazardous wastes such as pesticides, or if groundwater monitoring reveals unusual groundwater conditions which may be attributable to the landfilling of this residue, then a subsequent analysis may be required at that time.

13. There shall be no discharge to the environment of polychlorinated biphenyl compounds.

F. Operational Safeguards

The overall design and layout of the facilities shall be such as to minimize hazards to humans and the environment. Security control measures shall be utilized to prevent exposure of the public to hazardous conditions. The Federal Occupational

Safety and Health Standards will be complied with during construction and operation. The safety standards specified under Section 440.56, Florida Statutes, by the Industrial Safety Section of the Florida Department of Commerce will be complied with during operation.

G. Transmission Lines

The directly associated transmission lines from the Resource Recovery Facility electric generators to the Florida Power Corporation Gandy Substation shall be kept cleared without the use of herbicides.

H. Noise

Operational noises shall not exceed local noise ordinance limitations nor those noise standards imposed by zoning.

IV. STATUS OF EXISTING PERMITS

No permit may be issued for sanitary waste landfilling other than this Certification, for the area known as Bridgeway Acres II.



STATE OF FLORIDA

Department of Administration

Division of Administrative Hearings

Oakland Building, 2009 Apalachee Parkway

TALLAHASSEE

32301

Bob Graham
Governor

Nevin G. Smith
Secretary of Administration

March 9, 1984

Victoria Tschinkel, Secretary
Department of Environmental
Regulation
2600 Blair Stone Road
Tallahassee, Florida 32301

Re: Case No. 83-2355
In Re: Pinellas County Resource Project:
Application for Power Plant Site
Certification.

Dear Ms. Tschinkel:

Enclosed are copies of my Stipulation to Recommended
Order and Recommended Order Regarding Site Certification entered
in the above-styled case.

Please furnish the Division of Administrative Hearings
a copy of the Final Order entered in this case.

Sincerely,

WILLIAM E. WILLIAMS
Hearing Officer

/mc

Enclosures

- xc: Honorable Bob Graham
- Cabinet Members
- Van B. Cook, Esq.
- Julia D. Cobb, Esq.
- C. Laurence Keeseey, Esq.
- Mr. Tom Herndon
- Hamilton S. Oven, Jr., P.E.
- Bonnie Davis, Esq.
- Karen A. Lloyd, Esq.

RECEIVED

MAR 12 1984

COUNTY ATTORNEY

STATE OF FLORIDA
DIVISION OF ADMINISTRATIVE HEARINGS


IN RE:]

Pinellas County Resource]
Project: Application for]
Power Plant Site]
Certification.]


DOAH CASE NO.: 83-2355]

STIPULATION TO RECOMMENDED ORDER


The Undersigned counsel to the parties to this proceeding hereby stipulate to the entry of the attached Recommended Order regarding site certification.



VAN S. COOK
Chief Assistant County Attorney
315 Court Street
Clearwater, Florida 33516
For the Applicant, Pinellas
County



JULIA D. COBB
2600 Blair Stone Road
Tallahassee, Florida 32301
Assistant General Counsel for
Department of Environmental
Regulation



C. LAURENCE KEESNEY
2571 Executive Center Circle
East
Tallahassee, Florida 32301
For the Department of Community
Affairs

STATE OF FLORIDA
DIVISION OF ADMINISTRATIVE HEARINGS

IN RE: Pinellas County Resource)
Project: Application for Power)
Plant Site Certification)

Case No. 83-2355

RECOMMENDED ORDER
REGARDING SITE CERTIFICATION

Pursuant to notice, the Division of Administrative Hearings, by its duly designated Hearing Officer, William E. Williams, held a public hearing in this cause on February 29, 1984, in Clearwater, Florida.

APPEARANCES

For the Applicant:

Van B. Cook
Chief Assistant County Attorney
315 Court Street
Clearwater, Florida 33516

For the Department
of Environmental
Regulation:

Julie Cobb
Assistant General Counsel
2600 Blair Stone Road
Tallahassee, Florida 32301

For the Department
of Community Affairs:

C. Laurence Keesey, Esq.
2571 Executive Center Circle East
Tallahassee, Florida 32301

For Southwest Florida
Water Management
District:

None

For Public Service
Commission

None

On or about September 6, 1983, the Applicant, Pinellas County, filed an amended application for power plant site certification to expand its existing resource recovery facility with the Department of Environmental Regulation. The Division of Administrative Hearings received a request from the Department of Environmental Regulation for the appointment of a Hearing Officer to conduct the hearings required by Chapter 403, Part II, Florida Statutes. On September 19, 1983, the Division of Administrative Hearings received a statement from the Department of Environmental Regulation declaring the application to be complete as of September 6, 1983.

On January 19, 1984, the Applicant filed a Motion to Expedite the certification hearing required by Chapter 403, Part II, Florida Statutes. On January 25, 1984, the undersigned entered an Order scheduling a certification hearing for February 29, 1984 and requiring a pre-hearing stipulation, and issued a Notice of Hearing. A pre-hearing stipulation was filed on or about February 24, 1984.

A certification hearing as required by Section 403.508(3), Florida Statutes, was held pursuant to proper notice in Clearwater, Florida. The notice published in the Florida Administrative Weekly was four days less than the required 30 day notice. Upon motion of the Applicant, and no other party entering an objection, this defect was waived. The purpose of that hearing was to receive testimony and evidence concerning whether the location and operation of the proposed facility would produce adverse effects on human health, environment, the ecology of the land and its wildlife, and the ecology of State waters and their aquatic life;

would assure the citizens of Florida that operational safeguards are technically sufficient for their welfare and protection; and would effect a reasonable balance between the need for the facility and the environmental impact resulting from construction and operation of the facility; as well as providing abundant, low-cost electrical energy. The hearing included an examination of the following:

The necessity for expanded electrical generation;
The expected environmental impact from construction
and operation of the resource recovery facility;
Operational safeguards of the facility;
The availability of abundant, low-cost electrical
energy;
Other public interests and issues relevant to certification
of the proposed site.

In addition, evidence relating to best available control
technology and the prevention of significant deterioration of
ambient air quality was presented.

The following parties entered appearances at or participated
in this proceeding:

1. The Applicant, Pinellas County.
2. Florida Department of Environmental Regulation.
3. Florida Department of Community Affairs.

Having considered all testimony and evidence properly
admitted, having heard arguments of Counsel, and being otherwise
fully apprised herein, the following Findings of Fact,
Conclusions of Law, and Recommended Order are entered:

FINDINGS OF FACT

1. A revised Application for power plant site
certification was filed by Pinellas County on September 6, 1983.
The Applicant proposes to expand its resource recovery facility,
within the existing certified site, at which municipal solid
wastes are burned to produce steam-generated electrical energy by
the addition of a third boiler, additional turbine-generator,
expanded cooling tower, a second stack, and related structures.
The residue from the burning of these wastes is processed for
recovery of metals and other valuable materials. The facility
includes a large landfill which is used for disposal of those
portions of the residue not amenable to recovery. Existing
transmission facilities connecting the facility to Florida Power
Corporation's Gandy Substation will continue to be utilized.

2. The resource recovery facility buildings are located on approximately 20 acres within Pinellas County's existing certified site. Areas of the plant site not previously disturbed by landfilling or construction activities are occupied largely either by pine flatwoods or wet weather ponds.

3. The existing resource recovery facility, certified in July 1979, consists of a 50 megawatt steam-electric generating turbine, two 1050 tons-per-day solid waste fired boilers; truck weighing scales; a refuse collection and storage pit, refuse stoking equipment; magnetic and ferrofluid separators; conveyors; a four cell mechanical draft cooling tower utilizing treated sewage effluent; effluent intake and outfall piping and connections; a 161 foot flue gas stack; electro-static precipitators; stormwater retention and treatment ponds; stormwater spray irrigation fields; a sanitary landfill; and control ditching. A 230 kilovolt transmission line and associated structures runs East, South, and then East of the site for approximately 1 and 1/4 miles. The proposed expansion of electrical generation capacity is approximately 29 MW for a total capacity not exceeding 79.9 MW.

4. The primary purpose for the facility is to dispose of the county's refuse and trash. There is a clear need for recovery facilities such as that proposed by the Applicant.

The Florida Public Service Commission has found that the proposed facility expansion will increase electrical system reliability and integrity and will maintain the supply of adequate electricity at a reasonable cost while reducing dependence on fossil fuel. The Department of Environmental Regulation has found that construction of the resource recovery facility permitted the closing of current landfills and reduced the need for future landfill areas and in fact serves a recognized need.

5. Impacts from site modification are minimal in that all new additions are adjacent to existing structures on previously cleared land. No rare or endangered species have been observed on the site.

6. Since 1978, refuse generation rates in Pinellas County have risen faster than was anticipated. To meet the added demand on the processing capacity of the plant, expansion of the facility is proposed. The reduction of landfill areas is environmentally desirable and area residents, concerned about the presence of landfills near their home, should find the proposed site modification and visual barriers more attractive than landfills.

7. Extensive measures have been incorporated into the proposal and the conditions of certification so as to minimize the environmental impacts from construction and operation.

8. Due to the isolated nature of the proposed site there is very little opportunity for public access during construction and operation. In addition, traffic into the site will be limited and controlled by fencing. The applicant has proposed adequate measures to comply with both State and Federal health and safety requirements.

9. The resource recovery facility is expected to produce the following average volumes of water during normal daily operations:

1. Cooling tower blowdown 279gpm.
2. Boiler blowdown 32gpm.
3. Cooling tower evaporation and drift 1311gpm.
4. Boiler demineralization backflush water 45 gpm.
5. Sanitary wastes 50gpm.

The plant effluents will be discharged to Pinellas County's South Cross Bayou Sewage Treatment Plant. Any surface water impacts would largely arise from stormwater runoff. Perimeter ditches, a central holding pond, and associated treatment facilities are used to collect, contain, and treat runoff originating on the site. This collection and treatment system is of sufficient size to prevent any stormwater discharge from the site except during periods of extremely heavy rainfall.

Groundwater in the vicinity is Class G-II (as defined by Section 17-3.401, Florida Administrative Code). Movement of the shallow aquifer groundwater in the area is generally

Northeasterly at a rate of 1 to 10 feet per year. The area of the site is underlain by a clay/marl zone which would tend to slow the vertical migration of leachates. There has previously been an impact on the shallow aquifer groundwater quality in the vicinity of the site due to adjacent landfilling operations and saltwater intrusions. Leaching of the decomposition materials from putrescible wastes has already altered the natural state and quality of the shallow aquifer. Since landfill materials from the resource recovery facility should primarily be boiler residue and non-putrescible wastes it is likely that any groundwater impacts from these new landfill materials will be much less than from previously landfilled putrescible materials.

10. Leachates and drainage are minimized by allowing water to run off the fill rather than being allowed to percolate through the filled material. Leachate which does form by percolation through an active fill is accumulated at the low point of the active cell. This accumulation is pumped directly to the aeration pond and is contained on site. At no time will raw refuse be deposited in standing water.

Wastewater leaves the aeration lagoon and enters two water treatment ponds which have been designed to remove nutrients and heavy metals from the runoff waters. Upon leaving the ponds, wastewater is chlorinated for bacteria and virus control and pumped to the land on the Southern portion of the site.

11. Construction activities are expected to produce air pollutants from vehicular and heavy equipment exhaust emissions and fugitive dust. During operation, expected stack emissions will include particulate, sulfur dioxide, fluorides, lead, carbon monoxide, hydrocarbons, mercury, beryllium, chlorides, and oxides of nitrogen. Odor is not expected to be a problem and control measures have been included in the proposal. An electro-static precipitator has been included for the control of particulate matter. There are no sulfur dioxide emission limitations for incinerators; however, if a sufficient volume of refuse is incinerated, prevention of significant deterioration criteria may

be applicable. The Department has conducted a Best Available Control Technology analysis for the resource recovery facility and has proposed emission limitation rates for the facility.

12. During operation, refuse will be sorted for large items or non-combustibles, the remaining refuse will be incinerated. Following combustion, the residue will pass through a resource recovery system designed to extract ferrous and non-ferrous metals. The residue, approximately 2.1 percent by weight of the original raw waste, will be landfilled on site. In the event of a facility shutdown, storage facilities at the processing plant will be sufficient for storage of three to four days of incoming waste. If the plant should remain out of operation beyond three to four days, incoming raw wastes would be landfilled at the site. The facility does not intend to accept hazardous wastes.

13. During and at the conclusion of the site certification hearing, the public was given the opportunity to comment upon the application for site certification. No one not a party provided any verbal or written testimony, reports, or other evidence.

14. The Department of Environmental Regulation and the Applicant have agreed that no land use hearing was required because the proposed expansion is within the previously certified site.

15. The Applicant has accepted the proposed conditions of certification (Exhibit 1) and has agreed to comply therewith if certification is granted subject to a reservation of its right to exercise the Modification of Conditions procedure referenced in Exhibit 1 and a further reservation of its rights to object, if deemed necessary, to the application of any revised emission limitation rates contained in Exhibit 1 to its existing facilities. No objection to said reservations was entered by any party to this hearing.

16. The Florida Department of Environmental Regulation, the Public Service Commission, the Division of State Planning and Southwest Florida Water Management District, have all recommended certification of the proposed resource recovery facility subject to conditions. The stipulated conditions are attached hereto as Exhibit 1.

CONCLUSIONS OF LAW

1. This proceeding was held pursuant to the Florida Electrical Power Plant Siting Act, Chapter 403, Part II, Florida Statutes, and Chapter 17-17, Florida Administrative Code, to consider the subject application for site certification.

2. Notice in accordance with Chapter 403 and Chapter 120, Florida Statutes, and Chapter 17-17, Florida Administrative Code, has been given to all persons and parties entitled thereto, as well as to the general public. The defect in the required time period for publication of the notice in the Florida Administrative Weekly is deemed inconsequential and not prejudicial and is therefore waived.

3. The purpose of the site certification hearing was to receive testimony and evidence concerning whether the location and operation of the proposed facility will produce minimal adverse effects on human health, the environment, the ecology of the land and its wildlife, the ecology of State waters and their aquatic life, and to fully balance the increasing demand for electrical power plant location and operation with the broad interest of the public as provided in Chapter 403, Florida Statutes.

4. The record of this hearing consists of all pleadings and papers filed herein, including the site certification application, as amended, the transcripts of all hearings, all orders entered by the Hearing Officer, as well as all evidence and exhibits properly admitted.

5. Section 403.507(1)(a), Florida Statutes, provides that the Department of Community Affairs shall present a report as to the compatibility of the proposed electrical power plant with the State comprehensive plan. The Department of Community Affairs has made a report on the resource recovery facility and its report and recommendation have been submitted and introduced into evidence. The Department recommends certification subject to the conditions in Exhibit 1.

6. Section 403.507(1)(b), Florida Statutes, requires that the Florida Public Service Commission prepare a report and recommendation as to the present and future needs for electrical generating capacity in the area to be served by the proposed facility. Such a report and recommendation have been submitted and introduced into evidence. The Public Service Commission states that there will be some benefits derived from the generating capacity addition of the resource recovery facility and resulting reduction in oil consumption. The recommendation of the Public Service Commission is that the Pinellas County Waste Resource Recovery Facility be certified subject to the conditions in Exhibit 1.

7. Section 403.507(1)(c), Florida Statutes, requires the Water Management District in whose jurisdiction the resource recovery facility will be located to prepare a report as to matters within its jurisdiction. On September 22, 1983, the Southwest Florida Water Management District stated it did not object to the proposed expansion and encouraged the continued use of reclaimed water for such industrial non-potable needs.

8. Section 403.507(2), Florida Statutes, requires that the Department of Environmental Regulation conduct or contract for studies of the proposed electrical power plant including but not limited to:

- a. Cooling system requirements
- b. Construction and operational safeguards
- c. Proximity to transportation systems
- d. Soil and foundation conditions
- e. Impact on suitable present and projected water supplies for this and other competing uses
- f. Impact on surrounding land uses
- g. Accessibility to transmission corridors
- h. Environmental impacts.

Such a report and recommendations have been submitted and introduced into evidence. The Department of Environmental Regulation recommends certification of the proposed facility subject to the conditions of certification which are attached as Exhibit 1.

9. The Applicant has accepted the proposed conditions of certification (Exhibit 1) and has agreed to comply therewith if certification is granted subject to a reservation of its right to exercise the Modification of Conditions procedure referenced in Exhibit 1 and a further reservation of its rights to object, if deemed necessary, to the application of any revised emission limitation rates contained in Exhibit 1 to its existing facilities. No objection to said reservations was entered by any party to this hearing.

10. The location and operation of the proposed facility, as described by the evidence in the record, if made subject to the conditions of certification attached, are expected to produce minimal adverse effects on human health, the environment, the ecology of the land and its wildlife, and the ecology of state waters and their aquatic life. Section 403.502, Florida Statutes.

11. The operational safeguards for the proposed facility are technically sufficient for the welfare and protection of the citizens of Florida. Section 403.502(1), Florida Statutes.

12. The certification of the proposed facility is consistent with the provision of abundant low-cost electrical energy. Section 403.502(3), Florida Statutes.

13. The proposed air pollution control equipment should prevent the operation of the facility from causing significant deterioration of ambient air quality in the vicinity.

14. Construction and operation of the facility satisfy the prevention of significant deterioration criteria and the application of the Best Available Control Technology standards.

15. No land use hearing was required in this case because the proposed expansion is within the previously certified site and responsible zoning or planning authorities are precluded from changing land use plans or zoning ordinances so as to affect the site by Section 403.508(2), Florida Statutes.


16. The parties to this certification hearing have stipulated to this Recommended Order.

RECOMMENDED ORDER

Having reviewed the record of this proceeding, and based upon the Findings of Fact and Conclusions of Law set forth herein, it is hereby recommended that certification, pursuant to Chapter 403, Part II, Florida Statutes, be granted to Pinellas County for the construction and operation of its resource recovery facility expansion and associated facilities, as proposed in the amended application and described in the record of this proceeding. It is further recommended that this certification be made subject to the conditions of certification attached hereto as Exhibit 1.

However, pursuant to the stipulation of the parties to this certification hearing, to the extent of any conflict between previously imposed Conditions of Certification and the proposed Conditions of Certification contained in Exhibit 1 herein pertaining to air quality, the revised Conditions of Exhibit 1 shall not apply to the existing facilities until the proposed expansion which is the subject of this proceeding is operational, at which time the Conditions of Certification (Exhibit 1 herein) shall apply and the previous Conditions of Certification shall be deemed rescinded.

DONE AND ORDERED this 5th day of MARCH 1984 in Tallahassee, Florida.



WILLIAM E. WILLIAMS
Hearing Officer
Division of Administrative Hearings
The Oakland Building
2009 Apalachee Parkway
Tallahassee, Florida 32301

FILED with the Division of Administrative Hearings this 5th day of March, 1984.

State of Florida



Commissioners:

JOSEPH P. CRESSE
BERALD L. (JERRY) GUNTER, Chairman
JUSAN WAGNER LEISNER
JOHN R. MARKS, III
KATIE NICHOLS

Executive Director
DAVID L. SWAFFORD
(904) 488-7181

Public Service Commission

November 7, 1983

RECEIVED

NOV 14 1983

Mr. Hamilton S. Oven, Jr., P.E.
Administrator, Power Plant Siting
Department of Environmental Regulation
Twin Towers Office Building
2600 Blairstone Road
Tallahassee, Florida 32301

6076
PINELLAS COUNTY
SOLID WASTE DEPT.

Dear Mr. Oven:

The attached orders constitute the Commission's final reports, as required by Section 403.507(1)(b) of the Power Plant Siting Act, on the applications of Pinellas and Hillsborough Counties for power plant certification.

As the orders indicate, the matter was handled in the form of a Proposed Agency Action. No person requested a hearing within the required time; therefore, the Commission's finding that a need exists for the proposed plants has become final.

Sincerely yours,

A handwritten signature in dark ink, appearing to read "D. Swafford", written over a faint, larger signature.

DAVID L. SWAFFORD
Executive Director

DLS/cd

CC: Commissioners
Electric & Gas Department
Legal Department
Department of Community Affairs
Hillsborough County
Pinellas County

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Petition by Pinellas County) DCKET 830417-EU
for determination of need for a solid) ORDER NO. 12611
waste-fired cogeneration power plant.) ISSUED: 10-14-83

The following Commissioners participated in the disposition of this matter:

GERALD L. GUNTER, Chairman
JOSEPH P. CRESSE
JOHN R. MARKS, III
KATIE NICHOLS
SUSAN LEISNER

NOTICE OF PROPOSED AGENCY ACTION

ORDER

BY THE COMMISSION:

Under the Florida Electrical Power Plant Siting Act, Section 403.501, Florida Statutes, the Commission is charged with the responsibility of determining whether construction of a proposed electrical generation facility is necessary to meet the present or expected need for electricity in all or part of Florida. Under the Act, the Department of Environmental Regulation must determine whether the proposed plant will comply with all relevant environmental standards and whether the proposed site for the plant is suitable for that use. Weighing all of these determinations, the Governor and Cabinet, sitting as the Power Plant Siting Board, ultimately determine whether approval will be granted for construction of the proposed plant.

Certification under the Act must be obtained for the construction of any generating facility greater than 50 MW, or for the expansion of any existing electrical power plant. Pinellas County currently owns an existing solid waste-fired power plant containing a single 50.9-megawatt (gross) turbine generator and two incinerator/boilers located near Pinellas Park in Pinellas County, Florida, and has an existing Power Plant Site Certification for the facility. Pinellas County proposes to construct and operate an additional incinerator/boiler, and a single 29-megawatt (gross) turbine generator facility at the same site. The proposed incinerator/boiler will be similar to the two incinerator/boilers currently owned by the County and will have the capacity to burn up to 1,050 tons per day of 5000 BTU per pound solid waste. This is a small power production facility within the meaning of PURPA and Rules 25-17.80 through 25-17.87, Florida Administrative Code.

The steam generated by the proposed incinerator/boiler plant will be used to drive a single 29-megawatt (gross) turbine generator which will produce electricity that will be sold to Florida Power Corporation. The projected in-service date for the unit is July 1986, with construction scheduled to begin in the summer of 1984. The existing facility presently is selling an average of 38-40 MW a year to Florida Power Corporation. With increasing fuel supply and capacity expansion, the facility will ultimately have about 60 MW available for sale to Florida Power Corporation in mid-1990's. By a petition filed on August 29, 1983, Pinellas County seeks an affirmative determination of need for the 29 MW generating plant.

While the Power Plant Siting Act requires the Commission to determine whether a need exists for the proposed generating facility, the purpose of the Commission's need determination is

DOCUMENT NO.

to protect electric utility ratepayers from unnecessary expenditures. The statute lists four criteria the Commission must consider in determining need:

- 1) the need for electrical system reliability and integrity;
- 2) the need for adequate electricity at a reasonable cost;
- 3) whether the proposed plant is the most cost effective alternative available; and
- 4) conservation measures taken or reasonably available that might mitigate the need for new plant (Sec. 403.519, F.S.)

Congress and the Florida Legislature have determined that cogeneration and small power production should be encouraged on the premise that they constitute alternate sources of power that either displace production of fossil fuel electricity or use fossil fuels more efficiently. Moreover, the proliferation of cogeneration and small power production facilities may obviate the need for construction of additional generating facilities by electric utilities. Therefore, in the present context, we find that the County's proposed small power production facility will increase electrical system reliability and integrity and will maintain the supply of adequate electricity at a reasonable cost while reducing our dependence on fossil fuel. When viewed as an alternative to construction of additional generating facilities by electric utilities, and considering the permissible level of payments to small power producers outlined in Rules 25-17.80 through 25-17.87, Fla. Admin. Code, the proposed facility is the most cost effective alternative available. Finally, construction of the plant is a conservation measure which we have encouraged precisely because it may mitigate the need for additional construction by electric utilities. Therefore, the relief sought in this petition, an affirmative determination of need, will be and the same is hereby granted. It is, therefore,

ORDERED by the Florida Public Service Commission that this Order constitute the final report required by Section 403.507(1)(b), Florida Statutes, the report concluding that a need exists, within the meaning of Section 403, Florida Statutes, for the construction of the 29 MW generating facility proposed by Pinellas County, Florida. It is further

ORDERED that a copy of this Order be furnished to the Department of Environmental Regulation, as required by Section 403.507(1)(b), Florida Statutes. It is further


ORDERED that any person adversely affected by the action proposed herein may file a petition for a formal proceeding, as provided in Rule 25-22.29, within 21 days of the date of this order, November 4, 1983, in the form provided by Rule 25-22.36(7)(a) and (f). It is further

ORDERED that in the absence of such a petition, this Order shall become effective and final as provided by Rule 25-22.29(6), as stated in a subsequent order.

By Order of the Florida Public Service Commission, this
14th day of OCTOBER 1983.

(S E A L)

BED


STEVE TRIBBLE
COMMISSION CLERK

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Petition of Pinellas County for) DOCKET NO. 830417-EU
determination of need for a solid waste-) ORDER NO. 12677
fired cogeneration power plant.) ISSUED: 11-14-83

CONSUMMATING ORDER

BY THE COMMISSION:

By Order No. 12611, this Commission proposed to take certain action, subject to a Petition for Formal Proceeding as provided in Rule 25-22.29, Florida Administrative Code. No response has been filed to the order and it has become effective. It is, therefore,


ORDERED by the Florida Public Service Commission that this Order constitute the final report required by Section 403.507(1)(b), Florida Statutes, the report concluding that a need exists, within the meaning of Section 403, Florida Statutes, for the construction of the 29 MW generating facility proposed by Pinellas County, Florida. It is further

ORDERED that a copy of this Order be furnished to the Department of Environmental Regulation, as required by Section 403.507(1)(b), Florida Statutes. It is further

ORDERED that Order No. 12611 be and the same is hereby determined to be effective and final on November 4, 1983, as provided in Rule 25-22.29(6), Florida Administrative Code. It is further

ORDERED that this docket be closed.

By ORDER of the Florida Public Service Commission, this day 14th of November, 1983.


Steve Tribble
COMMISSION CLERK


(S E A L)

BED

RECEIVED

NOV 17 1983

6104
PINELLAS COUNTY



BOARD OF COUNTY COMMISSIONERS

PINELLAS COUNTY, FLORIDA

315 COURT STREET

CLEARWATER, FLORIDA 33516

COMMISSIONERS

BARBARA SHEEN TODD, CHAIRMAN
JOHN CHESNUT, JR., VICE-CHAIRMAN
GABRIEL CAZARES
CHARLES E. RAINEY
BRUCE TYNDALL

August 23, 1983

Re: Wastewater Discharge, Resource Recovery Plant

TO WHOM IT MAY CONCERN:

This is to confirm that the Pinellas County Wastewater Treatment Plant which receives the wastewater discharged by the Solid Waste, Resource Recovery Plant has ample capacity to handle the maximum design volume of wastewater expected to be discharged by the refuse processing plant and has experienced no problems with processing the liquid effluent as concerns its chemical make-up.

Existing wastewater treatment facilities are of sufficient size and capacity to conclude that ample processing equipment will be available to support the solid waste plant throughout the 20-year term of the permit being applied for in accordance with the Florida Power Plant Siting Certification process.

Todd L. Tanberg, Director
Pinellas County Sewer System