



**The Air  
Compliance  
Group, LLC**

5075 Hollins Road  
Roanoke, VA 24019  
Phone: (540) 265-1987  
Fax: (540) 265-0082

**Air Emissions Test Report  
For Compliance Testing  
Conducted on Units 1, 2,  
and 3 at Pinellas County  
Resource Recovery Facility  
in St. Petersburg, Florida**

**Facility ID No. 1030117**

***Prepared for***  
**GCS Energy Recovery of Pinellas, Inc.**  
**St. Petersburg, Florida**

**Test Dates: April 9-13, 2013**

**Report Date: May 23, 2013**

ACG Contract Number: V13030



The Air Compliance Group, LLC

# TEST REPORT CERTIFICATION

*Air Emissions Test Report for Compliance Testing  
Conducted on Units 1, 2, & 3 at Pinellas County Resource Recovery Facility*

*Prepared by: The Air Compliance Group, LLC of Roanoke, Virginia for  
Prepared for: GCS Energy Recovery of Pinellas, Inc. of St. Petersburg, Florida*

*Test Dates: April 9-13, 2013  
Report Date: May 23, 2013  
Contract Number V13030*

We certify that, to the best of our knowledge, this source test report has been checked for completeness, and that the results presented herein are accurate, error-free, legible, and representative of the actual emissions measured during testing.

Signature . . . . . Date .5/23/2013. . . . .

**Kenley Houtz, QSTI (electronic signature)**  
Project Manager  
The Air Compliance Group, LLC

Signature . . . . . Date .5/23/2013. . . . .

**David Vecellio, QSTI (electronic signature)**  
Project Manager - Reporting  
The Air Compliance Group, LLC

Signature . . . . . Date .5/23/2013. . . . .

**Arthur B. Nunn, III, QEP (electronic signature)**  
President  
The Air Compliance Group, LLC

I have supplied facility data in Appendix N of this test report, and I certify that I believe the information provided to be true, accurate, and complete. For results of the facility's QA/QC program, refer to the Pinellas County Resource Recovery Facility.

Signature . . . . . Date . . . . .

**Rebecca Bigari**  
Environmental Manager  
Representative of Pinellas County Resource Recovery Facility

# TABLE OF CONTENTS

	<i>Page</i>
<b>1.0 Introduction</b> .....	1
1.1 Background .....	1
1.2 Objective.....	1
1.3 Test Program.....	2
<b>2.0 Summary of Results</b> .....	3
2.1 Presentation .....	3
2.2 Particulate Emissions .....	3
2.3 PM <sub>2.5</sub> Emissions.....	3
2.4 Visible and Fugitive Emissions .....	3
2.5 Hydrogen Chloride (HCl) Emissions .....	5
2.6 Metals Emissions and Mercury Reduction Efficiency.....	5
2.7 Audit Samples .....	5
2.8 Facility Operation.....	5
<b>3.0 Test Program Changes and Problems</b> .....	6
<b>4.0 Facility Description</b> .....	6
<b>5.0 Sampling and Analytical Procedures</b> .....	7
5.1 Sampling Procedures .....	8
5.1.1 Sampling Point Determination - EPA Method 1.....	8
5.1.2 Volumetric Measurements - EPA Method 2 .....	8
5.1.3 Molecular Weight Determination - EPA Method 3.....	8
5.1.4 Flue Gas Moisture Content - EPA Method 4 .....	9
5.1.5 Metals Sampling - EPA Method 29.....	9
5.1.5.1 Sampling Train Description .....	9
5.1.5.2 Sampling Train Operation.....	10
5.1.5.3 Sample Recovery and Clean-up.....	10
5.1.5.4 Blanks.....	11
5.1.6 Particulate and HCl Sampling - EPA Methods 5 and 26A ..	11
5.1.6.1 Sampling Train Description .....	12
5.1.6.2 Sampling Train Operation.....	12
5.1.6.3 Sample Recovery and Clean-up.....	12
5.1.6.4 Blanks.....	13
5.1.7 Visible Emissions Evaluation - EPA Method 9 .....	13
5.1.7.1 Observer Position .....	13
5.1.7.2 Opacity Observations .....	13
5.1.8 Fugitive Emission Evaluations - EPA Method 22 .....	13
5.1.8.1 Observer Position .....	14
5.1.8.2 Fugitive Emissions Observations.....	14

## TABLE OF CONTENTS (CONTINUED)

		<i>Page</i>
5.1.9	PM <sub>2.5</sub> Sampling - EPA Methods 201A and 202 .....	14
	5.1.9.1 Sampling Train Description .....	14
	5.1.9.2 Pre-Test Preparation .....	15
	5.1.9.3 Sampling Train Operation.....	15
	5.1.9.4 Sample Recovery and Clean-up.....	16
	5.1.9.5 Blanks.....	17
5.2	Analytical Procedures .....	17
	5.2.1 Molecular Weight Determination - EPA Method 3A.....	17
	5.2.2 Moisture Content - EPA Method 4.....	18
	5.2.3 Particulate Analysis - EPA Method 5.....	18
	5.2.4 Hydrogen Chloride Analysis- EPA Method 26A .....	18
	5.2.5 Metals Analyses - EPA 29.....	18
	5.2.6 PM <sub>2.5</sub> Analysis – EPA Methods 201A and 202 .....	19
5.3	Data Analysis .....	20
5.4	Equipment Calibration .....	20
<b>6.0</b>	<b>Quality Assurance</b> .....	20
	6.1 Equipment Inspection and Maintenance.....	20
	6.2 Equipment Calibration .....	21
	6.3 Sampling Quality Control Procedures.....	21
	6.4 Analytical Quality Control Procedures .....	23

## LIST OF TABLES

Table 1 - Overall Summary of Test Program Results*.....	4
---	---

\*Note – See Appendix A.1 for detailed summary tables

## LIST OF FIGURES\*

\*See Appendix A.2 for detailed list of figures

# LIST OF APPENDICES

## **Appendix A - Detailed Summary Tables, Figures, and Test Log**

Appendix A.1 - Detailed Summary Tables

Appendix A.2 - Figures

Appendix A.3 - Test Log

Appendix A.4 - Contact Information

## **Appendix B - EPA Methods 29 Data and Results**

Appendix B.1 - EPA Method 29 Data and Results: Unit 1 FF Outlet

Appendix B.2 - EPA Method 29 Data and Results: Unit 1 SDA Inlet

Appendix B.3 - EPA Method 29 Data and Results: Unit 2 FF Outlet

Appendix B.4 - EPA Method 29 Data and Results: Unit 2 SDA Inlet

Appendix B.5 - EPA Method 29 Data and Results: Unit 3 FF Outlet

Appendix B.6 - EPA Method 29 Data and Results: Unit 3 SDA Inlet

## **Appendix C - EPA Methods 5 and 26A Data and Results**

Appendix C.1 - EPA Method 5/26A Data and Results: Unit 1 FF Outlet

Appendix C.2 - EPA Method 5/26A Data and Results: Unit 2 FF Outlet

Appendix C.3 - EPA Method 5/26A Data and Results: Unit 3 FF Outlet

## **Appendix D - EPA Methods 201A and 202 Data and Results**

Appendix D.1 - EPA Method 201A/202 Data and Results: Unit 1 FF Outlet

Appendix D.2 - EPA Method 201A/202 Data and Results: Unit 2 FF Outlet

Appendix D.3 - EPA Method 201A/202 Data and Results: Unit 3 FF Outlet

## **Appendix E - EPA Method 9 Data and Results**

## **Appendix F - Equations and Sample Calculations**

## **Appendix G - EPA Method 1 Cyclonic Flow Checks**

## **Appendix H - EPA Method 29 Raw Field Data**

Appendix H.1 - EPA Method 29 Raw Field Data: Unit 1 FF Outlet

Appendix H.2 - EPA Method 29 Raw Field Data: Unit 1 SDA Inlet

Appendix H.3 - EPA Method 29 Raw Field Data: Unit 2 FF Outlet

Appendix H.4 - EPA Method 29 Raw Field Data: Unit 2 SDA Inlet

Appendix H.5 - EPA Method 29 Raw Field Data: Unit 3 FF Outlet

Appendix H.6 - EPA Method 29 Raw Field Data: Unit 3 SDA Inlet

## **Appendix I - EPA Methods 5 and 26A Raw Field Data**

Appendix I.1 - EPA Method 5/26A Raw Field Data: Unit 1 FF Outlet

Appendix I.2 - EPA Method 5/26A Raw Field Data: Unit 2 FF Outlet

Appendix I.3 - EPA Method 5/26A Raw Field Data: Unit 3 FF Outlet

## **Appendix J - EPA Methods 201A and 202 Raw Field Data**

Appendix J.1 - EPA Method 201A/202 Raw Field Data: Unit 1 FF Outlet

Appendix J.2 - EPA Method 201A/202 Raw Field Data: Unit 3 FF Outlet

Appendix J.3 - EPA Method 201A/202 Raw Field Data: Unit 3 FF Outlet

## **Appendix K - EPA Method 9 and 22 Raw Field Data**

Appendix K.1 - EPA Method 9 Raw Field Data: Unit 1 Stack

Appendix K.2 - EPA Method 9 Raw Field Data: Unit 2 Stack

Appendix K.3 - EPA Method 9 Raw Field Data: Unit 3 Stack

Appendix K.4 - EPA Method 9 Raw Field Data: Silos and Vents

Appendix K.5 - EPA Method 22 Raw Field Data: Ash Handling System

## **Appendix L - Analytical Data**

Appendix L.1 - EPA Method 3A Analytical Data

Appendix L.2 - EPA Method 5 Gravimetric Analytical Data

Appendix L.3 – EPA Method 201A Gravimetric Analytical Data

Appendix L.4 – EPA Method 202 Laboratory Analytical Data

Appendix L.5 - EPA Method 26A Laboratory Analytical Data\*

Appendix L.6 - EPA Method 29 Laboratory Analytical Data\*

\*(see attached CD for full lab report)

## **Appendix M - Field Equipment Calibration Data**

Appendix M.1 - Pitot Tube, Barometer and Nozzle Calibration Data

Appendix M.2 - Meter Console and Thermocouple Calibration Data

Appendix M.3 - Gas Analyzer Calibration and Related Data

Appendix M.4 - Visible Emissions Evaluator Certification

## **Appendix N - Facility Operating Data**

Appendix N.1 - Facility Operating Data: Unit 1

Appendix N.2 - Facility Operating Data: Unit 2

Appendix N.3 - Facility Operating Data: Unit 3

## 1.0 Introduction

### 1.1 Background

An air emissions test program was conducted for GCS Energy Recovery of Pinellas, Inc. (GCS) at the Pinellas County Resource Recovery Facility (PCRRF) in St. Petersburg, Florida. The plant is owned by Pinellas County and operated by GCS. The plant consists of three municipal waste combustor units, designated Unit 1, Unit 2, and Unit 3. The test program was conducted April 9–13, 2013 by The Air Compliance Group, LLC (ACG) of Roanoke, Virginia. The following personnel participated in the test program:

Name	Affiliation	Test Program Position
Rebecca Bigari	GCS	Overall Program Manager
Kenley Houtz	ACG	Project Manager
Tony Underwood	ACG	Field Technician
Mike Henry	ACG	Field Technician
James Stultz	ACG	Field Technician
Cooper Franks	ACG	Field Technician
Ian Wilmer	ACG	Field Technician
Michael Wilson	ACG	Field Technician

### 1.2 Objective

Testing was conducted on Units 1, 2, and 3 (Emission Unit ID Nos. -001, -002, and -003, respectively), as well as the Residue Storage and Processing Building (Emission Unit ID No. -005), the Activated Carbon Storage Silo (Emission Unit ID No. -006), the Lime Storage Silo for SDA (Emission Unit ID No. -007), the Ash Conditioning Building (Emission Unit ID No. -008), and the Ash Handling System at the facility, as required by Title V Permit No. 1030117-008-AV and Construction Permit No 1030117-009-AC. In accordance with the permit, testing was conducted for the following pollutants on Units 1, 2, and 3 while the units were being operated at or near the maximum permitted operating rate:

Particulate Matter (PM)	PM $\leq$ 2.5 microns (PM <sub>2.5</sub> )
Visible Emissions (VE) (also conducted at vents)	Cadmium (Cd)
Fugitive Emissions (only conducted at the Ash Handling System)	Lead (Pb)
Hydrogen Chloride (HCl)	Mercury (Hg)

### 1.3 Test Program

The majority of the sampling program was conducted at the Spray Dryer Absorber (SDA) inlet and the Fabric Filter (FF) outlet of each unit. Additionally, visible (at the vents) and fugitive (at the ash handling system) emissions were visually determined at the applicable test locations.

Three valid measurements were made at the Units 1, 2, and 3 FF outlets for: PM, PM<sub>2.5</sub> (filterable and condensable PM<sub>2.5</sub>), VE, HCl and metals (Cd, Pb, and Hg). For the purpose of determining reduction efficiency, concurrent testing was also conducted at the Units 1, 2, and 3 SDA inlets for Hg. Three valid fugitive emission measurements were conducted at the Ash Handling System, and one valid VE test was also conducted at each of the silos and vents.

Each pollutant measurement (excluding visible emissions) included determination of the given pollutant emissions as well as average gas temperature, moisture content, molecular weight, and volumetric flow rate. Unit steam flow and conditions were also recorded during the testing period. The testing was conducted in accordance with the procedures of Appendix A of the *Code of Federal Regulations*, Title 40, Part 60 (40 CFR 60), or other methods accepted by the EPA and the Florida Department of Environmental Protection (FDEP). Appendix A.3 contains a test log that provides the exact date and time for each test.



## **2.0 Summary of Results**

### **2.1 Presentation**

Table 1 summarizes the average emissions for each pollutant tested versus the established permit limits. Detailed test results can be found in Tables 2 through 15, which are located in Appendix A.1. Appendices B through E contain detailed data and results for each test.

### **2.2 Particulate Emissions**

During the test program, particulate emissions from Unit 1 Method 5/26A averaged 0.004 grains per dry standard cubic foot corrected 7% O<sub>2</sub> (gr/dscf @ 7% O<sub>2</sub>) and 8.9 milligrams per dry standard cubic meter corrected to 7% O<sub>2</sub> (mg/dscm @ 7% O<sub>2</sub>). Particulate emissions from Unit 2 averaged 0.004 gr/dscf @ 7% O<sub>2</sub> and 9.3 mg/dscm @ 7% O<sub>2</sub>. Particulate emissions from Unit 3 averaged 0.003 gr/dscf @ 7% O<sub>2</sub> and 8.0 mg/dscm @ 7% O<sub>2</sub>. The Title V permit limit for PM for each unit is 0.012 gr/dscf @ 7% O<sub>2</sub> and 25 mg/dscm @ 7% O<sub>2</sub>, and the MACT limit is 25 mg/dscm @ 7% O<sub>2</sub>. Tables 8 through 10 and Appendix C contain more detailed results.

### **2.3 PM<sub>2.5</sub> Emissions**

During the test program, PM<sub>2.5</sub> emissions from Units 1, 2 and 3 Method 201A/202 averaged 25, 42 and 27 mg/dscm @ 7% O<sub>2</sub>, respectively. The BACT limit is 30 mg/dscm @ 7% O<sub>2</sub>. Tables 11 through 13 and Appendix D contain more detailed results. Please see Section 3.0 for discussion concerning the Unit 2 results.

### **2.4 Visible and Fugitive Emissions**

Opacity of visible emissions (maximum six-minute average value measured by EPA Method 9, concurrently with particulate testing) was 0.00 percent for each of Units 1, 2, and 3. The permitted limit for each unit is 10 percent opacity (six-minute average).

No VEs were observed (all were uniformly zero percent opacity) at the Ash Conditioning Building (ACB), the Residue Storage and Processing Building (RSPB), the Activated Carbon Storage Silo (CS), and the Lime Storage Silo for SDA (LS).

**Table 1 – Overall Summary of Test Program Results**

**Pinellas County Resource Recovery Facility (April 2013)**

Pollutant		Reporting Units	Title V Emission Limits	MACT Emission Limits	Average Emissions		
					Unit 1	Unit 2	Unit 3
Particulate Matter		gr/dscf @7% O <sub>2</sub>	0.012	N/A	0.004	0.004	0.003
		mg/dscm @7% O <sub>2</sub>	25		8.9	9.3	8.0
PM2.5		mg/dscm @7% O <sub>2</sub>	30 (BACT Standard)		25	42*	27
Cadmium		mg/dscm @7% O <sub>2</sub>	0.035 (3.5E-02)		2.57E-03	1.61E-03	9.23E-04
Lead		mg/dscm @7% O <sub>2</sub>	0.400 (4.00E-01)		1.68E-02	1.85E-02	9.65E-03
Mercury	Outlet concentration	mg/dscm @7% O <sub>2</sub>	0.050 (5.0E-02)		4.20E-03	2.45E-03	6.59E-03
	Removal efficiency	Reduction Efficiency % (based on mass flow - lb/hr)	OR				
			85		91	96	86
Hydrogen Chloride	Outlet concentration	ppmdv @7% O <sub>2</sub>	20		10	9	18
Visible Emissions		% Opacity (6-minute Average)	10		0.00	0.00	0.00
			5	All tested sources were 0.00%.			
Fugitive Emissions		% of Observation Period	5	Fugitive emissions were observed for 0.00% of the observation period duration on the Ash Handling System.			
Avg. carbon mass feed				lb/hr	15 <sup>(1)</sup>	15 <sup>(1)</sup>	15 <sup>(1)</sup>

\* The Unit 2 Run 1 inorganic condensable result is an outlier that is significantly greater than all other test runs. The analytical laboratory noted that the sample contained significantly more white, flaky residue than the other samples. If Run 1 is excluded, then average is 22 mg/dscm @ 7% O<sub>2</sub>, which is more than 20% below the emission limit.

<sup>(1)</sup> Average value during three valid EPA Method 29 metals test runs.

Fugitive visible emissions measured by EPA Method 22 at the ash handling system were observed for 0 seconds (0.00%) of the three 60-minute tests. Table 14 and Appendix E contain more detailed results for the visible and fugitive emissions tests. Please note that Appendix E only contains data reduction for test locations in which emissions were observed, and the raw field data for all locations is in Appendix K.

## **2.5 Hydrogen Chloride (HCl) Emissions**

HCl emissions from Units 1, 2, and 3 averaged 10, 9, and 18 ppm<sub>dv</sub> @ 7% O<sub>2</sub>, respectively. The Title V permit limit, as well as the MACT standard, for each unit is 20 ppm<sub>dv</sub> @ 7% O<sub>2</sub>. Tables 8 through 10 and Appendix C contain more detailed results.

## **2.6 Metals Emissions and Reduction Efficiency**

Cadmium emissions from Units 1, 2, and 3 averaged  $2.57 \times 10^{-3}$ ,  $1.61 \times 10^{-3}$ , and  $9.23 \times 10^{-4}$  mg/dscm @ 7% O<sub>2</sub>, respectively. Lead emissions from Units 1, 2, and 3 averaged  $1.68 \times 10^{-2}$ ,  $1.85 \times 10^{-2}$ , and  $9.65 \times 10^{-3}$  mg/dscm @ 7% O<sub>2</sub>, respectively. Mercury emissions from Units 1, 2, and 3 averaged  $4.20 \times 10^{-3}$ ,  $2.45 \times 10^{-3}$ , and  $6.59 \times 10^{-3}$  mg/dscm @ 7% O<sub>2</sub>, respectively. Mercury reduction efficiency for Units 1, 2, and 3 averaged 91%, 96%, and 86%, respectively. The Title V permit and MACT limits (in mg/dscm @ 7% O<sub>2</sub>) for each unit are: 0.035 ( $3.5 \times 10^{-2}$  for cadmium); 0.400 ( $4.00 \times 10^{-1}$  for lead); and 0.050 ( $5.0 \times 10^{-2}$  mercury) or 85% mercury reduction. Tables 2 through 7 and Appendix B contain more detailed results.

## **2.7 Audit Samples**

No audit samples were analyzed for the test program, as none were provided.

## **2.8 Facility Operation**

Appendix N contains the facility operating data (steam flow in Klb/hr) recorded during the test program. Testing of emissions was conducted at or near the maximum permitted operating rate. Only MSW was burned during the testing.

### 3.0 Test Program Changes and Problems

Except as noted below, all testing was conducted in accordance with the test protocol submitted to the FDEP, issued by ACG and dated March 7, 2013, and no significant problems were experienced by the test team or the contracted analytical laboratories during the execution of the test program. The following should be noted:

- EPA Method 23 dioxins/furans testing was not conducted on Unit 2 because the unit malfunctioned and was brought off-line before testing could be completed. The dioxins/furans testing and results will be addressed in a separate report.
- The visible emissions tests were not conducted at the Hydrated Lime Storage Silo for Lime Softening (Emission Unit ID No. -004, which is also known as the Hydrated Lime Storage Silo or Hydrated Lime Silo Vent), due to coordination issues. Once testing occurs at that location, results will be addressed in a separate report.
- The analytical laboratory result for the Unit 2 PM<sub>2.5</sub> Run 1 inorganic fraction is an outlier that was significantly greater than those of the other runs. The high result caused the average total PM<sub>2.5</sub> results for Unit 2 to be above the BACT limit, as the total PM<sub>2.5</sub> average result of Runs 2 and 3 was greater than 20% below the limit. As noted in the narrative of the lab's report contained in Appendix L.4, the Unit 2 Run 1 inorganic sample contained significantly more white, flaky residue than the other runs. It is not known whether the Unit 2 Run 1 high result can be attributed to an unknown process upset or an unknown form of contamination but that result appears to be suspect.

### 4.0 Facility Description

PCRRF consists of three 1,100 tons per day (nominal per MWC unit) municipal waste fired combustors. Each combustor consists of a Riley Stoker water wall boiler with a reciprocating grate stoker system. Each combustor is equipped with a spray dryer absorber (SDA), a fabric filter (FF), a Selective Non-Catalytic Reduction (SNCR) NOx control system, and a powdered activated carbon injection system (PACIS) supplied by Wheelabrator Air Pollution Control, Inc. Combustion gases exit the boiler economizer and pass through the SDA and FF, then to an induced draft fan prior to entering separate flues in a common stack.

Figure 1 presents a general flow arrangement of the process. Figure 2 depicts a cross-section of the SDA Inlet test locations. Figure 3 depicts a cross-section of the FF Outlet

test locations. The test locations meet EPA Methods 1 and 2 minimum criteria for upstream (2.0) and downstream (0.5) dimensions. All figures are in Appendix A.2.

## **5.0 Sampling and Analytical Procedures**

All sampling and analytical procedures followed those recommended by the U.S. Environmental Protection Agency (EPA), Title 40, Part 60, Appendix A of the *Code of Federal Regulations* (40 CFR 60), or other methods generally accepted by the EPA and the Florida Department of Environmental Protection. The following specific methods were used:

- EPA Method 1 for determining sampling and traverse points;
- EPA Method 2 for determining flue gas velocity and volumetric flow rate;
- EPA Method 3 (sampling procedure) and 3A (analytical procedure) for determining flue gas composition and molecular weight;
- EPA Method 4 for determining flue gas moisture content;
- EPA Method 5 (in conjunction with EPA Methods 26A at the outlet locations) for determining total particulate emissions;
- EPA Method 9 for determining visible emissions;
- EPA Method 201A (in conjunction with EPA Method 202 at the outlet locations) for determining particulate emissions <2.5 microns;
- EPA Method 202 (in conjunction with EPA Method 201A at the outlet locations) for determining condensable particulate emissions;
- EPA Method 22 for determining fugitive emissions;
- EPA Method 26A (in conjunction with EPA Method 5 at the outlet locations) for determining HCl emissions; and
- EPA Method 29 for determining metals emissions (cadmium, lead and mercury).

## **5.1 Sampling Procedures**

### **5.1.1 Sampling Point Determination - EPA Method 1**

At each FF Outlet, thirty sampling and traverse points (five for each of six ports – see Figure 3) were used for all isokinetic pollutant sampling and gas flow rate measurements.

At each SDA Inlet (see Figure 2), twenty-four sampling and traverse points were used for all isokinetic pollutant sampling and gas flow rate measurements.

### **5.1.2 Volumetric Measurements - EPA Method 2**

EPA Reference Method 2 was used to determine the velocity and volumetric flow rates of the stack gases. Stainless steel type-S pitot tubes were used to measure the gas velocity heads. The pitot tubes were assigned a baseline coefficient of 0.84 as allowed by Method 2. Calibrated type-K thermocouples were used to determine gas temperatures.

Velocity and temperature measurements were made at each of the traverse points, as shown in Figures 2 and 3. These measurements were performed in conjunction with the pollutant sampling described below.

### **5.1.3 Molecular Weight Determination - EPA Method 3**

Gas compositional measurements ( $O_2$  and  $CO_2$ ) for determining the average molecular weight of the stack gases, and for correction of pollutant emissions to 7%  $O_2$ , were conducted in accordance with EPA Reference Method 3. Multipoint, integrated sampling was used to obtain a constant-rate sample of flue gas concurrent with the pollutant testing. Sampling was of the same duration as the pollutant testing.

A stainless steel probe affixed to the pollutant sampling probe was used for this purpose, and a peristaltic pump was used to fill a Tedlar bag. Moisture was removed from the sample gas by an air-cooled condenser located prior to the pump. Figure 4 shows a schematic of the Method 3 sampling train.

#### **5.1.4 Flue Gas Moisture Content - EPA Method 4**

The flue gas moisture was measured in conjunction with the pollutant tests according to the sampling and analytical procedures outlined in EPA Method 4. The flue gas moisture for each test was determined by gravimetric or volumetric analysis of the water collected in the impingers of the pollutant sampling trains. All impingers were contained in an ice bath throughout the testing to ensure complete condensation of the moisture in the flue gas stream. Any moisture not condensed in the impinger condensers was captured in the silica gel contained in the final impinger.

#### **5.1.5 Metals Sampling - EPA Method 29**

Sampling at the FF Outlet for cadmium, lead and mercury, and at the SDA Inlet for mercury only, was performed in accordance with EPA Method 29.

##### **5.1.5.1 Sampling Train Description**

The Method 29 testing was conducted using the metals sampling train illustrated in Figure 5. A heated stainless steel probe with a glass liner was used to withdraw the gas sample. The probe was equipped with an appropriately sized glass nozzle for isokinetic gas withdrawal.

From the nozzle and probe, sample gas was drawn through a Pallflex ultra-pure 2500 QUAT-UP quartz filter supported on a Teflon frit in a heated glass filter holder. The filter was maintained at a temperature sufficiently high to prevent the condensation of water ( $250 \pm 25^{\circ}\text{F}$ ). Sample gas subsequently passed through an impinger train consisting of seven glass impingers immersed in an ice bath. The first impinger was initially empty. The second and third impingers each initially contained 100 ml of 5% nitric acid/10% hydrogen peroxide solution. The fourth impinger initially was empty. The fifth and sixth impingers each initially contained 100 ml of 4% potassium permanganate/10% sulfuric acid solution. The seventh impinger initially contained approximately 250 grams of silica gel. The moisture collected in the sampling train was quantified to determine the stack gas moisture content in accordance with Method 4.

### 5.1.5.2 Sampling Train Operation

Sampling was done in accordance with EPA Method 29 procedures and specifications, including leak checking, isokinetic sampling rate and stack traversing. Sampling at each SDA Inlet and FF Outlet was conducted concurrently for the purpose of determining the mercury reduction percentage. Sampling was conducted for 5 minutes at each of the 24 traverse points at each SDA Inlet, resulting in a 120-minute test per run, excluding the time required to change. Sampling was conducted for 4 minutes at each of the 30 traverse points at each FF Outlet, resulting in a 120-minute test per run, excluding the time required to change ports. A minimum sample volume of 60 dscf (1.7 m<sup>3</sup>) was drawn, as measured by the dry gas meter.

### 5.1.5.3 Sample Recovery and Clean-Up

Recovery of the sampling probe was accomplished using a Teflon-fiber probe brush. The probe was cleaned in the mobile laboratory, while the remainder of the sample train was transported to a clean-up site for recovery. Sample recovery then proceeded as follows:

- 1) **Front-half acid rinse:** The probe, front half of filter holder, and all connecting lines between the probe and filter holder were rinsed and brushed three times with 100 mls of 0.1N nitric acid. A Teflon-fiber probe brush was used to brush the probe between rinses. Rinses were collected in pre-cleaned polyethylene (PE) bottles fitted with a Teflon-lined screw caps.
- 2) **Filter catch:** The filter was removed from the housing with Teflon tweezers and placed into a pre-cleaned glass petri dish. The dish was sealed externally with Teflon tape.
- 3) **Back-half and impingers 1-3 recovery:** Condensate from the first three impingers was transferred to a graduated cylinder and the volumes were recorded. The back half of the filter holder, all connecting lines from the filter to the first impinger, and the first three impingers were rinsed with 100 mls of 0.1N



nitric acid. The rinses were collected into the same container (PE bottle fitted with a Teflon-lined cap) as the condensate.

- 4) **Fourth impinger catch and rinses:** The amount of condensate in the fourth impinger was measured and recorded. The impinger was then rinsed with 100 mls of 0.1N nitric acid and recovered in a pre-cleaned PE bottle fitted with a Teflon-lined screw cap. The rinses were collected into the same container as the condensate.
- 5) **Impinger five and six catch and rinses:** The sample liquid in the fifth and sixth impingers was transferred to a graduated cylinder and the volumes were recorded. The impingers were then rinsed three times with an acidified potassium permanganate solution, followed by a water rinse, then a rinse with 8 Normal HCl to remove any residue in the impingers. All solutions were transferred to glass bottles for storage. The permanganate and HCl rinses were recovered into separate containers to prevent chlorine generation.
- 6) **Silica gel:** The silica gel was transferred from the seventh impinger to its original container, sealed, and weighed.

#### **5.1.5.4 Blanks**

A field blank was performed for the test program for the metals tests. The field blank consisted of a sample train setup at the test location and leak checked as the sample train. The field blank train was then recovered following the same sample recovery procedures as the sample trains.

#### **5.1.6 Particulate and HCl Sampling - EPA Methods 5 and 26A**

Compliance sampling for particulate matter and hydrogen chloride at each FF Outlet followed EPA Method 26A procedures, except for substituting de-ionized water impingers for the NaOH impingers, since chlorine sampling was not required. As noted in the pre-test protocol, this modification was approved by the FDEP for previous test programs utilizing a modified EPA Method 26 sampling train. Additionally, the outlet

testing met 40 CFR 60, Subpart Eb, EPA Method 5 temperature requirements of heating the probe and filter to no greater than 320°F.

#### **5.1.6.1 Sampling Train Description**

Figure 6 shows the major components of Method 26A sampling train. A stainless steel probe sheath containing a heated glass liner was used to withdraw the gas sample. The probe was equipped with an appropriately sized nozzle for isokinetic gas withdrawal. From the nozzle and probe, sample gas was pulled through a heated filter for capture of particulate matter. The filter temperature was maintained at 300-320°F to prevent water condensation. Sample gas subsequently passed into an impinger train consisting of six glass impingers immersed in an ice bath. The first impinger initially contained 50 mls of 0.1N H<sub>2</sub>SO<sub>4</sub>, the second and third impingers each initially contained 100 mls of 0.1N H<sub>2</sub>SO<sub>4</sub>, the fourth and fifth impingers each initially contained DI water, and the last impinger initially contained approximately 250 grams of silica gel.

#### **5.1.6.2 Sampling Train Operation**

Except for the modifications previously noted, sampling was conducted in accordance with EPA Method 5/26A procedures and specifications, including leak checking. Sampling was conducted for 4 minutes at each of the 30 traverse points at each FF Outlet, resulting in a 120-minute test per run, excluding the time required to change ports. A minimum sample volume of 60 dscf (1.7 m<sup>3</sup>) was obtained for each run.

#### **5.1.6.3 Sample Recovery and Clean-Up**

Front half recovery (including the filters and probe rinses) of the sampling trains was performed in accordance with EPA Method 5 procedures and specifications. Recovery of the probe was accomplished using a Nylon bristle or Teflon-fiber probe brush. The nozzle, probe and front-half filter housing were rinsed with acetone at least three times each and brushed between rinses. The filter was recovered into a Petri dish. The impinger contents were first quantified volumetrically to determine the stack gas moisture content in accordance with EPA Method 4. The catches were collected into a high density polyethylene bottle, which was fitted with a Teflon-lined cap. The first three

impingers were rinsed with deionized distilled water, and the rinses were combined with the impinger catches from the first three impingers. The fourth and fifth impinger contents were quantified and discarded, as necessary. The silica gel from the last impinger was transferred back to its original container.

#### **5.1.6.4 Blanks**

One set of reagent blanks was collected during the test program for the Method 5/26A tests. The blanks consisted of all reagents required in the setup and recovery of the Method 5/26A sampling train.

#### **5.1.7 Visible Emissions Evaluation - EPA Method 9**

Opacity of visible emissions from each applicable test location was evaluated in accordance with EPA Method 9 by a certified observer. Certification(s) can be found in Appendix M.4 of this report. During each opacity test, 10 sets of 24 readings (readings taken every 15 seconds) were made, yielding a 60-minute test.

##### **5.1.7.1 Observer Position**

The observer was positioned such that he had a clear view of the emissions with the sun oriented in the 140° sector to his back. In addition, the observer made observations from a position at which his line of vision was approximately perpendicular to the plume direction.

##### **5.1.7.2 Opacity Observations**

Opacity observations were made at the point of greatest opacity in the portion of the plume where condensed water vapor was not present. A clearly visible background which gave the highest degree of contrast was used when the readings were made. Opacity was read at 15-second intervals, and readings were recorded to the nearest 5 percent opacity.

#### **5.1.8 Fugitive Emission Evaluations - EPA Method 22**

A fugitive emissions evaluation was performed on the facility's ash handling system for three 1-hour periods.

#### **5.1.8.1 Observer Position**

The observer surveyed the area for potential sources of emissions and selected an observation point that enabled a clear view. The observer ensured that the sun was not in his field of vision.

#### **5.1.8.2 Fugitive Emissions Observations**

The observer recorded the clock time for the start and end of observations. In accordance with Method 22, the potential emissions points were watched continuously during each test, which consisted of 20-minute observation periods separated by short rest breaks. The clock time was recorded at the beginning and end of each rest break. If any emission was observed, the observer started a stopwatch, then stopped it (without resetting to zero) when the emissions ceased. At the end of the observation period, the elapsed time recorded on the stopwatch was recorded as the total emission time.

Fugitive emission results are reported as emission frequency (percentage of time that emissions are visible during the observation period), and emission time (accumulated amount of time that emissions are visible during the observation period).

#### **5.1.9 PM<sub>2.5</sub> Sampling - EPA Methods 201A and 202**

Filterable and condensable particulate emissions less than or equal to 2.5 micrometers in diameter (PM<sub>2.5</sub>) were measured in accordance with EPA Method 201A (for filterable PM<sub>2.5</sub>), coupled with a back-half analysis in accordance with EPA Method 202 (for condensable PM<sub>2.5</sub>).

##### **5.1.9.1 Sampling Train Description**

Figure 7 shows the major components of the Method 201A/202 sampling train. The train consisted of one cyclone (PM<sub>2.5</sub> cyclone) followed by an out-of-stack heated glass fiber filter, maintained at 248°F ± 25°F. The probe was equipped with an appropriately sized stainless steel nozzle for isokinetic gas withdrawal. After the PM<sub>2.5</sub> cyclone, the sample gas passed through a glass-lined heated probe, a heated glass fiber filter, a water-

cooled glass condenser, capable of cooling the stack gas to below 85°F, and a series of glass impingers. The first two impingers were initially clean and empty. Impinger 1 was a condensate dropout impinger without a bubbler tube and Impinger 2 was a modified Greenburg Smith impinger. The sample gas then passed through the condensable particulate matter (CPM) Teflon filter, maintained at  $> 65^{\circ}\text{F}$  and  $\leq 85^{\circ}\text{F}$ , and subsequently passed through moisture traps. The moisture traps consisted of a modified Greenburg Smith impinger (Impinger 3) containing 100 ml of water followed by an impinger (Impinger 4) containing approximately 250 grams of silica gel. The moisture trap impingers were maintained in an ice bath to keep the gas temperature below 68° F at the exit of the impinger train.

#### **5.1.9.2 Pre-Test Preparation**

Before sampling, a velocity traverse of the stack was performed. This traverse, along with a gas analysis of the stack gas, was used to determine the nozzle diameter(s) needed to maintain a flow rate through the cyclone to achieve a cyclone separation size of  $>2.5\mu\text{m}$  and  $<2.5\mu\text{m}$ . A nozzle was selected by comparing the velocity heads from the velocity traverse with the minimum and maximum differential pitot pressures ( $\Delta p_{\text{min}}$  and  $\Delta p_{\text{max}}$ ) calculated for each nozzle, as required by the method. The nozzle was chosen to bracket all the  $\Delta p$ 's from the velocity traverse. If one nozzle did not meet this criterion, then the nozzle was changed during the sampling run so that the velocity head at that sampling point was within the  $\Delta p_{\text{min}}$  and  $\Delta p_{\text{max}}$  for that nozzle. The details of the calculations are given in Method 201A.

Two additional pretest calculations were also be performed: the orifice pressure head needed to maintain the necessary cyclone flow rate, and the dwell time for the first traverse point. These calculations are also detailed in Method 201A.

#### **5.1.9.3 Sampling Train Operation**

Throughout the sampling run, flow through the cyclone, as indicated by the orifice pressure head, was maintained at the pretest calculated value. If the stack gas

temperature varied by more than 50°F from the pretest average temperature, the orifice pressure head was determined using the pretest average  $\pm 50^\circ\text{F}$ .

Sampling time (or dwell time) at the first sampling point was determined by the pretest calculations. At each subsequent sampling point, dwell time was calculated as a function of the velocity head. The dwell time calculations are provided in Method 201A and in Appendix F.

Appropriate traverse points for each stack were sampled, and a test duration of 60 minutes was targeted, excluding the time required to change ports. The test duration varied as determined by velocity fluctuations in the flue gas stream. Nozzles were changed as necessary. Filters were also changed as necessary.

#### **5.1.9.4 Sample Train Recovery**

For the Method 201A sample recovery, the hot filter was recovered into a clean petri dish, which was sealed externally with Teflon tape. The  $\text{PM}_{2.5}$  filterable fraction was recovered by acetone rinsing and brushing all the surfaces from the  $\text{PM}_{2.5}$  cyclone exit to the front half of the heated filter holder. The rinses were placed into a labeled glass bottle. The filters and rinses were transported to the ACG laboratory for gravimetric analyses as described by EPA Method 5.

For EPA Method 202 recovery, moisture gain in the impingers was quantified volumetrically for the first three impingers and gravimetrically for the silica gel impinger, then a post-test purge was performed with ultra-pure nitrogen. The purge was performed whether or not water was collected in the first impinger. The moisture collected in the first impinger was measured and transferred to the second impinger, then the purge was conducted through the condenser, second impinger, and the CPM filter. The purge of the condenser and train was performed for 60 minutes at a rate of 14 liters per minute. Sample recovery for Method 202 proceeded as follows:

1. **Aqueous Liquid Impinger:** The liquid from the dropout and impinger prior to the CPM filter (i.e., the first two impingers) was measured in a graduated cylinder and transferred to clean glass or plastic sample bottle. The condenser, Impingers 1 and 2, connecting glassware, and the front half of the CPM filter housing were rinsed twice with water. The rinses were collected into the same bottle.
2. **CPM Organic Rinses:** After the water rinse, the condenser, Impingers 1 and 2, connecting glassware, and the front half of the CPM filter housing were rinsed with acetone, followed by two rinses of hexane. The organic rinses were collected together into the same container, which was separate from the aqueous rinses.
3. **CPM Filter:** The filter was removed from the CPM filter housing and placed into a petri dish, which was then sealed with Teflon tape.
4. **Cold Impinger Water:** The volume of the contents of the cold water impinger was transferred to a graduated cylinder, measured, and recorded.
5. **Silica Gel:** The silica gel was transferred back to its original container, weighed, and recorded.

#### 5.1.9.5 Blanks

One set of reagent blanks was collected during the test program for the Method 201A/202 tests. The blanks consisted of all reagents required in the setup and recovery of the Method 201A/202 sampling train. Also, a field train recovery blank was collected for the Method 202 portion of the tests by assembling and recovering a sampling train in the same manner that it was used for testing but without exposure to the sample gas.

## 5.2 Analytical Procedures

### 5.2.1 Molecular Weight Determination - EPA Method 3A

Flue gas compositional analysis for molecular weight determination, and for correction of pollutant emissions to 7% O<sub>2</sub>, was conducted using instrumental analyzers set up and operated in accordance with EPA Method 3A. The EPA Method 3 samples were injected directly into the instruments, which were calibrated with EPA Protocol G1 calibration gas standards. Calibration data are contained in Appendix M.3. Results of the O<sub>2</sub> and CO<sub>2</sub> analyses are in Appendix L.1.

### **5.2.2 Moisture Content - EPA Method 4**

Moisture contents were determined gravimetrically/volumetrically in accordance with Method 4 by measuring either the volume or mass gain of each impinger in the pollutant sampling trains.

### **5.2.3 Particulate Analysis - EPA Method 5**

Particulate matter was determined in accordance with EPA Method 5 procedures. The filter was analyzed gravimetrically to a constant weight. The front-half acetone rinse was evaporated and analyzed gravimetrically to a constant weight. The total particulate catch equaled the sum of the front-half acetone rinse and the filter. Gravimetric laboratory data are contained in Appendix L.2.

### **5.2.4 Hydrogen Chloride Analysis - EPA Method 26A**

The contents and rinses of the first three impingers of the HCl sampling trains were analyzed by ion chromatography for total chloride in accordance with EPA Method 26A procedures. The analytical laboratory data for the modified EPA Method 26A samples are found in Appendix L.5.

### **5.2.5 Metals Analyses - EPA Method 29**

The filter, front-half rinses, and contents of impingers 1 through 3 of the metals sampling train were analyzed for cadmium, lead and mercury. The contents and rinses of impinger 4 were collected separately and analyzed for mercury. Impingers 5 and 6 contents and rinses were also analyzed for mercury. The analytical laboratory data for the EPA Method 29 samples are found in Appendix L.6.

The sampling train components (including the digested filter, probe washes, and impinger contents and rinses) were prepared for analysis in accordance with the procedures of EPA Method 29. After preparation, samples were analyzed by inductively coupled plasma - mass spectrometry (ICP-MS) for cadmium and lead. A cold vapor atomic absorption spectrometer (CVAAS) was used to analyze the samples for mercury.



### **5.2.6 PM<sub>2.5</sub> Analysis – EPA Methods 201A and 202**

Analyses of the filters and cyclone acetone rinses from the EPA Method 201A sampling trains were performed gravimetrically in accordance with EPA Method 201A procedures. The filters were analyzed gravimetrically to a constant weight. The acetone rinses were evaporated and analyzed gravimetrically to a constant weight. The total filterable PM<sub>2.5</sub> catch for each run equaled the sum of the mass gains of the PM<sub>2.5</sub> acetone rinse and the filter. The gravimetric laboratory data for the EPA Method 201A samples are contained in Appendix L.3.

Condensable particulate matter was determined in accordance with EPA Method 202 procedures. The water soluble CPM was extracted from the CPM filter and the aqueous extract combined with the contents of the aqueous sample container. The organic soluble CPM was extracted from the CPM filter and the organic extract was combined with the contents of the organic sample container. The aqueous impinger contents were placed in a separatory funnel and extracted three times with hexane. This organic extract was combined with the sampling train's organic rinse. The organic phase extracts and rinses were evaporated to dryness. Following evaporation, the organic fraction was desiccated for 24 hours, and then weighed at 6-hour intervals to a constant weight.

The contents of the inorganic fraction were also dried at room temperature. Following evaporation, the inorganic fraction was desiccated for 24 hours and then weighed at 6-hour intervals to a constant weight. If the residue could not be weighed to a constant weight, then it was re-dissolved in deionized, distilled ultra-filtered water and titrated with NH<sub>4</sub>OH to subtract out NH<sub>4</sub><sup>+</sup> retained in the sample. Following titration, the volume of the aqueous phase was reduced and then allowed to dry at room temperature and pressure. Following evaporation, the inorganic fraction was desiccated for 24 hours, and then weighed at 6-hour intervals to a constant weight. The back-half condensable particulate catch equals the organic residue plus the inorganic residue. The gravimetric laboratory data for the EPA Method 202 samples are contained in Appendix L.4.

### **5.3 Data Analyses**

All equations related to the sampling, including gas flow rates, temperatures, percent isokinetics, moisture contents, and pollutant emissions, are shown in Appendix F. This appendix also includes sample calculations using actual data from the test program.

### **5.4 Equipment Calibration**

All field equipment was calibrated in accordance with the requirements of the applicable EPA Methods. Recommendations within the *Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III* (EPA/600/R-94/038c, September 1994) were also considered. Appendix M contains records for all the calibrations.

## **6.0 Quality Assurance**

Specific quality control (QC) procedures were followed to ensure the continuous production of useful and valid data throughout the course of this test program. The QC checks and procedures described in this section represent an integral part of the overall sampling and analytical scheme. A discussion of both the sampling and analytical QC checks used during this program is presented below.

### **6.1 Equipment Inspection and Maintenance**

Each critical item of field test equipment is assigned a unique identification number. An effective preventive maintenance program is necessary to ensure data quality. Each item of equipment returning from the field is inspected before it is returned to storage. During the course of these inspections, items are cleaned, repaired, reconditioned and recalibrated where necessary.

Each item of equipment transported to the field is inspected again before being packed to detect equipment problems that may originate during periods of storage. This minimizes lost time on the job site due to equipment failure. Occasional equipment failure in the field is unavoidable despite the most rigorous inspection and maintenance procedures. For this reason, ACG routinely transports to the job site spare equipment for all critical sampling train components.

## 6.2 Equipment Calibration

New items for which calibration is required are calibrated before initial field use.

Equipment whose calibration status may change with use or time is inspected in the field before testing begins and again upon return from each field use. When an item of equipment is found to be out of calibration, it is repaired and recalibrated, or retired from service. All equipment is periodically recalibrated in full, regardless of the outcome of these regular inspections.

Calibrations are conducted in a manner, and at a frequency, which meets or exceeds U.S. EPA specifications. ACG generally follows the calibration procedures outlined in the EPA methods, and those recommended within the *Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III* (EPA/600/R-94/038c, September 1994). When these methods are inapplicable, ACG uses methods such as those prescribed by the American Society for Testing and Materials (ASTM).

Data obtained during calibrations are recorded on standardized forms, which are double checked for completeness and accuracy. Data reduction and subsequent calculations are performed using ACG's own computer facilities. Calculations are checked at least twice for accuracy. Copies of calibrations are included in the test or project reports.

Emissions sampling equipment requiring calibration includes pitot tubes, nozzles, gas analyzers, barometers, dry gas meters and thermocouples.

## 6.3 Sampling Quality Control Procedures

The following **pretest** QC checks are conducted:

- All sampling equipment is thoroughly checked to ensure clean and operable components.
- Equipment is inspected for possible damage from shipment.
- The oil manometer used to measure pressure across the type-S pitot tube is leveled and zeroed.

- The number and location of the sampling traverse points are checked before taking measurements.
- The temperature measurement system is visually checked for damage and operability by measuring the ambient temperature before each traverse.

In addition to the general QC procedures listed above, QC procedures specific to each sampling method are also incorporated into the sampling scheme. The following QC procedures are emphasized:

### **Before start of tests**

- Keep all cleaned glassware and sample train components sealed until train assembly.
- Assemble the sampling trains in an environment free from uncontrolled dust.
- Visually inspect each sampling train for proper assembly.
- Perform pretest calculations to determine the proper sampling nozzle size.

### **During testing each day**

- Readings of temperature and differential pressure are taken at each traverse point.
- All sampling data and calculations are recorded on preformatted data sheets.
- All calibration data forms are reviewed for completeness and accuracy.
- Any unusual occurrences are noted during each run on the appropriate data form.
- Project supervisor reviews sampling data sheets daily during testing.
- Properly maintain the roll and pitch axis of the type-S pitot tube and the sampling nozzle.
- Leak-check the train before and after each run, or if a filter change takes place.
- Conduct additional leak checks if the sampling time  $\geq 2$  hours.
- Maintain the probe, filter and impingers at the proper temperature.

- Maintain ice in the ice bath at all times.
- Make proper readings of the dry gas meter, delta P and delta H, temperature, and pump vacuum during sampling at each traverse point.
- Maintain isokinetic sampling within  $\pm 10\%$  of 100%, as applicable.

**After testing each day**

- Visually inspect the sampling nozzle.
- Visually inspect the type-S pitot tube.
- Leak-check each leg of the type-S pitot tube.
- Leak-check the entire sampling train.

**6.4 Analytical Quality Control Procedures**

All analyses for this program were performed using accepted laboratory procedures in accordance with the specified analytical protocols. Adherence to prescribed QC procedures ensured data of consistent and measurable quality. Analytical QC focused upon the use of control standards to provide a measure of analytical precision and accuracy. Also, specific acceptance criteria were defined for various analytical operations including calibrations, control standard analyses, drift checks, blanks, etc. If any QC criteria were not met, then an explanation, and the impact that this may have had on the results, was provided.

## **Appendix A**

### **Detailed Summary Tables, Figures, and Test Log**

**Appendix A.1**  
**Detailed Summary Tables**

TABLE 2

SUMMARY OF CADMIUM, LEAD AND MERCURY EMISSIONS / MERCURY REDUCTION EFFICIENCY  
PINELLAS COUNTY RRF

UNIT 1 FF OUTLET

RUN I.D.	U1O-M29-R1	U1O-M29-R2	U1O-M29-R3	AVERAGE
DATE	04/09/13	04/09/13	04/09/13	
TIME STARTED	9:05	13:24	16:22	
TIME ENDED	11:28	15:36	18:33	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	81.384	81.677	81.819	81.627
Corrected Volume (dscf)	76.456	75.437	75.872	75.922
Total Test Time (min)	120	120	120	120
Isokinetics (%)	102.9	99.2	100.3	100.8
<b>GAS PARAMETERS</b>				
Gas Temperature (°F)	316	317	317	317
Oxygen (%)	9.98	10.06	10.33	10.12
Carbon Dioxide (%)	9.37	9.35	9.11	9.28
Moisture (%)	21.32	21.38	22.58	21.76
<b>GAS FLOW RATE</b>				
Velocity (ft/sec)	46.27	47.37	47.83	47.16
Actual Volume (acfm)	267181	273588	276223	272331
Standard Volume (dscfm)	139513	142753	141945	141403
Standard Volume @ 7% O2 (dscfm)	109603	111327	107939	109623
<b>STEAM PRODUCTION RATE (Klb/hr)</b>				
	233	235	236	235
<b>CARBON RATE (lb/hr)</b>				
	15	15	15	15
<b>CADMIUM EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	2.65E-03	1.66E-03	3.40E-03	2.57E-03
Mass Rate (lb/hr)	1.09E-03	6.93E-04	1.37E-03	1.05E-03
<b>LEAD EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	1.48E-02	1.29E-02	2.27E-02	1.68E-02
Mass Rate (lb/hr)	6.08E-03	5.37E-03	9.17E-03	6.88E-03
<b>MERCURY EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	3.61E-03	4.26E-03	4.72E-03	4.20E-03
Mass Rate (lb/hr)	1.48E-03	1.78E-03	1.91E-03	1.72E-03
<b>MERCURY REDUCTION EFFICIENCY</b>				
Inlet Mass Rate (lb/hr)	2.07E-02	1.96E-02	1.78E-02	1.94E-02
Outlet Mass Rate (lb/hr)	1.48E-03	1.78E-03	1.91E-03	1.72E-03
Reduction Efficiency	92.9	90.9	89.3	91.0

Pollutant	Title V Permit Limit	MACT Limit
Cadmium	0.035 mg/dscm @ 7% O2	0.035 mg/dscm @ 7% O2
Lead	0.400 mg/dscm @ 7% O2	0.400 mg/dscm @ 7% O2
Mercury	0.050 mg/dscm @ 7% O2 or 85% Reduction	0.050 mg/dscm @ 7% O2 or 85% Reduction



TABLE 3

SUMMARY OF CADMIUM, LEAD AND MERCURY EMISSIONS / MERCURY REDUCTION EFFICIENCY  
PINELLAS COUNTY RRF

UNIT 2 FF OUTLET

RUN I.D.	U2O-M29-R1	U2O-M29-R2	U2O-M29-R3	AVERAGE
DATE	04/10/13	04/10/13	04/10/13	
TIME STARTED	8:45	12:09	15:25	
TIME ENDED	11:15	14:28	17:35	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	81.193	82.192	82.726	82.037
Corrected Volume (dscf)	77.137	76.432	75.218	76.262
Total Test Time (min)	120	120	120	120
Isokinetics (%)	99.7	98.1	94.9	97.6
<b>GAS PARAMETERS</b>				
Gas Temperature (°F)	294	296	297	295
Oxygen (%)	10.60	11.16	11.72	11.16
Carbon Dioxide (%)	8.60	8.19	7.70	8.16
Moisture (%)	18.44	18.94	17.19	18.19
<b>GAS FLOW RATE</b>				
Velocity (ft/sec)	45.10	45.87	45.75	45.57
Actual Volume (acfm)	260454	264895	264216	263188
Standard Volume (dscfm)	145261	146184	148751	146732
Standard Volume @ 7% O2 (dscfm)	107639	102434	98240	102771
<b>STEAM PRODUCTION RATE (Klb/hr)</b>				
	234	234	234	234
<b>CARBON RATE (lb/hr)</b>				
	15	15	15	15
<b>CADMIUM EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	8.71E-04	3.55E-03	4.18E-04	1.61E-03
Mass Rate (lb/hr)	3.51E-04	1.36E-03	1.54E-04	6.23E-04
<b>LEAD EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	1.14E-02	3.41E-02	1.01E-02	1.85E-02
Mass Rate (lb/hr)	4.60E-03	1.31E-02	3.71E-03	7.14E-03
<b>MERCURY EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	1.30E-03	3.65E-03	2.39E-03	2.45E-03
Mass Rate (lb/hr)	5.25E-04	1.40E-03	8.79E-04	9.34E-04
<b>MERCURY REDUCTION EFFICIENCY</b>				
Inlet Mass Rate (lb/hr)	1.61E-02	2.71E-02	3.52E-02	2.61E-02
Outlet Mass Rate (lb/hr)	5.25E-04	1.40E-03	8.79E-04	9.34E-04
Reduction Efficiency	96.7	94.8	97.5	96.4

<u>Pollutant</u>	<u>Title V Permit Limit</u>	<u>MACT Limit</u>
Cadmium	0.035 mg/dscm @ 7% O2	0.035 mg/dscm @ 7% O2
Lead	0.400 mg/dscm @ 7% O2	0.400 mg/dscm @ 7% O2
Mercury	0.050 mg/dscm @ 7% O2 or 85% Reduction	0.050 mg/dscm @ 7% O2 or 85% Reduction

TABLE 4

SUMMARY OF CADMIUM, LEAD AND MERCURY EMISSIONS / MERCURY REDUCTION EFFICIENCY  
PINELLAS COUNTY RRF

UNIT 3 FF OUTLET

RUN I.D.	U3O-M29-R1	U3O-M29-R2	U3O-M29-R3	AVERAGE
DATE	04/11/13	04/11/13	04/11/13	
TIME STARTED	8:37	11:45	14:36	
TIME ENDED	10:56	13:54	17:04	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	78.811	79.315	77.034	78.387
Corrected Volume (dscf)	74.099	73.441	70.040	72.527
Total Test Time (min)	120	120	120	120
Isokinetics (%)	104.8	104.4	99.2	102.8
<b>GAS PARAMETERS</b>				
Gas Temperature (°F)	308	305	306	306
Oxygen (%)	8.54	8.52	8.17	8.41
Carbon Dioxide (%)	10.45	10.51	10.65	10.54
Moisture (%)	23.05	24.18	23.81	23.68
<b>GAS FLOW RATE</b>				
Velocity (ft/sec)	44.75	44.98	45.01	44.91
Actual Volume (acfm)	258433	259755	259953	259380
Standard Volume (dscfm)	132648	132061	132522	132410
Standard Volume @ 7% O2 (dscfm)	117952	117619	121367	118979
<b>STEAM PRODUCTION RATE (Klb/hr)</b>				
	235	233	236	235
<b>CARBON RATE (lb/hr)</b>				
	15	15	15	15
<b>CADMIUM EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	9.92E-04	9.50E-04	8.26E-04	9.23E-04
Mass Rate (lb/hr)	4.38E-04	4.19E-04	3.75E-04	4.11E-04
<b>LEAD EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	1.01E-02	1.27E-02	6.10E-03	9.65E-03
Mass Rate (lb/hr)	4.47E-03	5.61E-03	2.77E-03	4.28E-03
<b>MERCURY EMISSIONS</b>				
Concentration (mg/dscm @ 7% O2)	6.40E-03	7.18E-03	6.19E-03	6.59E-03
Mass Rate (lb/hr)	2.83E-03	3.17E-03	2.82E-03	2.94E-03
<b>MERCURY REDUCTION EFFICIENCY</b>				
Inlet Mass Rate (lb/hr)	4.91E-02	2.25E-02	1.32E-02	2.83E-02
Outlet Mass Rate (lb/hr)	2.83E-03	3.17E-03	2.82E-03	2.94E-03
Reduction Efficiency	94.2	85.9	78.7	86.3

Pollutant	Title V Permit Limit	MACT Limit
Cadmium	0.035 mg/dscm @ 7% O2	0.035 mg/dscm @ 7% O2
Lead	0.400 mg/dscm @ 7% O2	0.400 mg/dscm @ 7% O2
Mercury	0.050 mg/dscm @ 7% O2 or 85% Reduction	0.050 mg/dscm @ 7% O2 or 85% Reduction

TABLE 5

SUMMARY OF MERCURY LOADINGS  
PINELLAS COUNTY RESOURCE RECOVERY FACILITY

UNIT 1 SDA INLET

RUN I.D.	U11-M29-R1	U11-M29-R2	U11-M29-R3	AVERAGE
DATE	04/09/13	04/09/13	04/09/13	
TIME STARTED	9:05	13:24	16:22	
TIME ENDED	11:26	15:34	18:31	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	80.291	81.696	80.460	80.816
Corrected Volume (dscf)	78.065	78.318	76.865	77.749
Total Test Time (min)	120	120	120	120
Isokinetics (%)	97.2	96.1	96.1	96.5
<b>GAS PARAMETERS</b>				
Gas Temperature (°F)	590	597	599	596
Oxygen (%)	8.10	8.54	8.29	8.31
Carbon Dioxide (%)	10.90	10.55	10.97	10.81
Moisture (%)	17.19	17.24	17.89	17.44
<b>GAS FLOW RATE</b>				
Velocity (ft/sec)	62.71	64.07	63.50	63.43
Actual Volume (acfm)	295490	301940	299253	298894
Standard Volume (dscfm)	122996	124764	122464	123408
Standard Volume @ 7% O2 (dscfm)	113263	110941	111099	111768
<b>STEAM PRODUCTION RATE (lb/hr)</b>	233	235	236	235
<b>MERCURY EMISSIONS</b>				
Conc. (mg/dscm @ 7% O2)	0.049	0.047	0.043	0.046
Mass Rate (lb/hr)	2.07E-02	1.96E-02	1.78E-02	1.94E-02

Pollutant	Limit
Mercury	Not Applicable to Inlet Location

TABLE 6

SUMMARY OF MERCURY LOADINGS  
PINELLAS COUNTY RESOURCE RECOVERY FACILITY

UNIT 2 SDA INLET

RUN I.D.	U2I-M29-R1	U2I-M29-R2	U2I-M29-R3	AVERAGE
DATE	04/10/13	04/10/13	04/10/13	
TIME STARTED	8:45	12:09	15:25	
TIME ENDED	11:13	14:26	17:33	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	79.161	77.852	80.191	79.068
Corrected Volume (dscf)	77.343	74.446	75.144	75.644
Total Test Time (min)	120	120	120	120
Isokinetics (%)	97.6	95.8	95.3	96.3
<b>GAS PARAMETERS</b>				
Gas Temperature (°F)	516	520	520	519
Oxygen (%)	8.56	9.01	9.84	9.14
Carbon Dioxide (%)	10.31	9.94	9.25	9.83
Moisture (%)	16.75	17.18	14.61	16.18
<b>GAS FLOW RATE</b>				
Velocity (ft/sec)	57.21	56.60	55.77	56.53
Actual Volume (acfm)	269606	266728	262800	266378
Standard Volume (dscfm)	121366	118954	120717	120346
Standard Volume @ 7% O2 (dscfm)	107745	101753	96053	101850
<b>STEAM PRODUCTION RATE (lb/hr)</b>				
	234	234	234	234
<b>MERCURY EMISSIONS</b>				
Conc. (mg/dscm @ 7% O2)	0.040	0.071	0.098	0.070
Mass Rate (lb/hr)	1.61E-02	2.71E-02	3.52E-02	2.61E-02

Pollutant	Limit
Mercury	Not Applicable to Inlet Location

TABLE 7

SUMMARY OF MERCURY LOADINGS  
PINELLAS COUNTY RESOURCE RECOVERY FACILITY

UNIT 3 SDA INLET

RUN I.D.	U3I-M29-R1	U3I-M29-R2	U3I-M29-R3	AVERAGE
DATE	04/11/13	04/11/13	04/11/13	
TIME STARTED	8:37	11:45	14:36	
TIME ENDED	10:54	13:52	17:02	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	75.549	75.719	77.573	76.280
Corrected Volume (dscf)	72.968	72.200	73.067	72.745
Total Test Time (min)	120	120	120	120
Isokinetics (%)	99.2	99.9	100.0	99.7
<b>GAS PARAMETERS</b>				
Gas Temperature (°F)	610	610	610	610
Oxygen (%)	6.79	6.98	7.11	6.96
Carbon Dioxide (%)	12.05	11.72	11.49	11.75
Moisture (%)	18.83	19.90	18.79	19.18
<b>GAS FLOW RATE</b>				
Velocity (ft/sec)	60.03	59.66	59.55	59.75
Actual Volume (acfm)	282881	281147	280616	281548
Standard Volume (dscfm)	112650	110707	111944	111767
Standard Volume @ 7% O2 (dscfm)	114352	110866	111058	112092
<b>STEAM PRODUCTION RATE (lb/hr)</b>				
	235	233	236	235
<b>MERCURY EMISSIONS</b>				
Conc. (mg/dscm @ 7% O2)	0.115	0.054	0.032	0.067
Mass Rate (lb/hr)	4.91E-02	2.25E-02	1.32E-02	2.83E-02

Pollutant	Limit
Mercury	Not Applicable to Inlet Location

TABLE 8

**SUMMARY OF PARTICULATE AND HCl EMISSIONS  
PINELLAS COUNTY RESOURCE RECOVERY FACILITY**

**UNIT 1 FF OUTLET**

RUN I.D.	U1O-M26A-R1	U1O-M26A-R2	U1O-M26A-R3	AVERAGE
DATE	04/09/13	04/09/13	04/09/13	
TIME STARTED	9:05	13:24	16:22	
TIME ENDED	11:28	15:36	18:33	

**SAMPLING PARAMETERS**

Metered Volume (dcf)	77.124	78.945	79.906	78.658
Corrected Volume (dscf)	77.672	79.278	80.330	79.093
Total Test Time (min)	120	120	120	120
Isokinetics (%)	106.3	104.3	105.4	105.3

**GAS PARAMETERS**

Gas Temperature (°F)	315	315	317	316
Oxygen (%)	9.56	10.22	10.24	10.01
Carbon Dioxide (%)	9.62	9.10	9.01	9.24
Moisture (%)	21.11	20.70	21.14	20.98

**GAS FLOW RATE**

Velocity (ft/sec)	45.20	46.80	47.25	46.42
Actual Volume (acfm)	261018	270271	272882	268057
Standard Volume (dscfm)	137153	142655	142979	140929
Standard Volume @ 7% O <sub>2</sub> (dscfm)	111893	109608	109652	110384

**STEAM PRODUCTION RATE (Klb/hr)**

	233	235	236	235
--	-----	-----	-----	-----

**PARTICULATE EMISSIONS**

Concentration (gr/dscf @ 7 % O <sub>2</sub> )	0.003	0.005	0.004	0.004
Concentration (mg/dscm @ 7% O <sub>2</sub> )	7.579	10.552	8.541	8.891
Mass Rate (lb/hr)	3.18	4.33	3.51	3.67

**HCl OUTLET EMISSIONS**

Concentration (ppmdv)	6.09	8.08	9.80	7.99
Concentration (ppmdv @ 7% O <sub>2</sub> )	7.46	10.52	12.78	10.25
Mass Rate (lb/hr)	4.74	6.55	7.96	6.42

<b>Pollutant</b>	<b>Title V Permit Limit</b>	<b>MACT Limit</b>
Particulate Matter	25 mg/dscm @ 7% O <sub>2</sub> and 0.012 gr/dscf @ 7% O <sub>2</sub>	25 mg/dscm @ 7% O <sub>2</sub>
Hydrogen Chloride	20 ppmdv @ 7% O <sub>2</sub>	

TABLE 9

**SUMMARY OF PARTICULATE AND HCl EMISSIONS  
PINELLAS COUNTY RESOURCE RECOVERY FACILITY**

**UNIT 2 FF OUTLET**

RUN I.D.	U2O-M26A-R1	U2O-M26A-R2	U2O-M26A-R3	AVERAGE
DATE	04/10/13	04/10/13	04/10/13	
TIME STARTED	8:45	12:09	15:25	
TIME ENDED	11:15	14:28	17:35	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	77.049	80.575	79.840	79.155
Corrected Volume (dscf)	78.551	80.408	77.948	78.969
Total Test Time (min)	120	120	120	120
Isokinetics (%)	99.0	101.1	97.3	99.1
<b>GAS PARAMETERS</b>				
Gas Temperature (°F)	295	297	296	296
Oxygen (%)	10.74	10.93	11.63	11.10
Carbon Dioxide (%)	8.52	8.42	7.72	8.22
Moisture (%)	17.04	18.10	16.69	17.28
<b>GAS FLOW RATE</b>				
Velocity (ft/sec)	45.61	46.38	45.87	45.95
Actual Volume (acfm)	263408	267842	264906	265385
Standard Volume (dscfm)	148964	149272	150357	149531
Standard Volume @ 7% O <sub>2</sub> (dscfm)	108883	107068	100274	105408
<b>STEAM PRODUCTION RATE (Klb/hr)</b>	234	234	234	234
<b>PARTICULATE EMISSIONS</b>				
Concentration (gr/dscf @ 7 % O <sub>2</sub> )	0.004	0.004	0.005	0.004
Concentration (mg/dscm @ 7% O <sub>2</sub> )	8.857	8.634	10.530	9.340
Mass Rate (lb/hr)	3.61	3.46	3.95	3.68
<b>HCl OUTLET EMISSIONS</b>				
Concentration (ppmdv)	7.15	5.77	6.81	6.58
Concentration (ppmdv @ 7% O <sub>2</sub> )	9.78	8.04	10.22	9.35
Mass Rate (lb/hr)	6.05	4.89	5.82	5.58

<b>Pollutant</b>	<b>Title V Permit Limit</b>	<b>MACT Limit</b>
Particulate Matter	25 mg/dscm @ 7% O <sub>2</sub> and 0.012 gr/dscf @ 7% O <sub>2</sub>	25 mg/dscm @ 7% O <sub>2</sub>
Hydrogen Chloride	20 ppmv @ 7% O <sub>2</sub>	

TABLE 10

SUMMARY OF PARTICULATE AND HCl EMISSIONS  
PINELLAS COUNTY RESOURCE RECOVERY FACILITY

UNIT 3 FF OUTLET

RUN I.D.	U3O-M26A-R1	U3O-M26A-R2	U3O-M26A-R3	AVERAGE
DATE	04/11/13	04/11/13	04/11/13	
TIME STARTED	8:37	11:45	14:36	
TIME ENDED	10:56	13:54	17:04	

**SAMPLING PARAMETERS**

Metered Volume (dcf)	76.592	78.278	74.593	76.488
Corrected Volume (dscf)	77.227	77.678	72.820	75.908
Total Test Time (min)	120	120	120	120
Isokinetics (%)	107.0	107.8	101.0	105.2

**GAS PARAMETERS**

Gas Temperature (°F)	306	302	305	304
Oxygen (%)	8.33	7.83	8.00	8.05
Carbon Dioxide (%)	10.67	11.15	10.86	10.89
Moisture (%)	22.46	23.67	23.35	23.16

**GAS FLOW RATE**

Velocity (ft/sec)	45.17	45.55	45.57	45.43
Actual Volume (acfm)	260836	263026	263191	262351
Standard Volume (dscfm)	135446	135284	135380	135370
Standard Volume @ 7% O <sub>2</sub> (dscfm)	122486	127206	125640	125111

**STEAM PRODUCTION RATE (Klb/hr)**

	235	233	236	235
--	-----	-----	-----	-----

**PARTICULATE EMISSIONS**

Concentration (gr/dscf @ 7% O <sub>2</sub> )	0.004	0.003	0.003	0.003
Concentration (mg/dscm @ 7% O <sub>2</sub> )	8.445	7.543	7.995	7.994
Mass Rate (lb/hr)	3.87	3.59	3.76	3.74

**HCl OUTLET EMISSIONS**

Concentration (ppmdv)	19.28	16.62	15.23	17.04
Concentration (ppmdv @ 7% O <sub>2</sub> )	21.32	17.67	16.41	18.47
Mass Rate (lb/hr)	14.82	12.76	11.71	13.10

<u>Pollutant</u>	<u>Title V Permit Limit</u>	<u>MACT Limit</u>
Particulate Matter	25 mg/dscm @ 7% O <sub>2</sub> and 0.012 gr/dscf @ 7% O <sub>2</sub>	25 mg/dscm @ 7% O <sub>2</sub>
Hydrogen Chloride	20 ppmdv @ 7% O <sub>2</sub>	



**TABLE 11**  
**SUMMARY OF PM2.5 EMISSIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 1 OUTLET**

RUN I.D.	U1O-M201A/202-R1	U1O-M201A/202-R2	U1O-M201A/202-R3	AVERAGE
DATE	04/10/13	04/10/13	04/10/13	
TIME STARTED	10:08	12:11	15:03	
TIME ENDED	11:08	13:12	16:03	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	19.606	20.112	19.711	19.810
Corrected Volume (dscf)	18.964	19.363	18.898	19.075
Corrected Volume (dscm)	0.537	0.548	0.535	0.540
Total Test Time (min)	59.5	61.1	60.1	60.2
% Isokinetics	116.2	118.1	115.5	116.6
<b>GAS PARAMETERS</b>				
Gas Temperature (deg F)	325	324	311	320
Oxygen (%)	9.47	8.84	9.30	9.20
Carbon Dioxide (%)	9.67	10.17	9.88	9.91
Moisture (%)	18.67	19.15	18.55	18.79
<b>GAS FLOWRATE</b>				
Velocity (ft/sec)	49.08	48.26	47.81	48.38
Actual Volume (acfm)	283412	278728	276113	279417
Standard Volume (dscfm)	151039	147796	149919	149585
Standard Volume @ 7% O2 (dscfm)	124200	128232	125112	125848
<b>STEAM PRODUCTION RATE - kpph</b>	236.0	233.0	234.0	234.3
<b>FILTERABLE PM2.5 EMISSIONS</b>				
Concentration (mg/dscm)	1.30	1.64	1.87	1.60
Concentration (mg/dscm @ 7%O2)	1.59	1.89	2.24	1.91
Mass Rate (lb/hr)	0.74	0.91	1.05	0.90
<b>CONDENSABLE PM2.5 EMISSIONS</b>				
Concentration (gr/dscf)	0.0075	0.0068	0.0114	0.0085
Concentration (gr/dscf @ 7%O2)	0.0091	0.0078	0.0136	0.0102
Concentration (mg/dscm)	17.13	15.50	25.97	19.54
Concentration (mg/dscm @ 7%O2)	20.83	17.87	31.12	23.28
Mass Rate (lb/hr)	9.69	8.58	14.59	10.95
<b>TOTAL PM2.5 EMISSIONS</b>				
Concentration (gr/dscf)	0.0081	0.0075	0.0122	0.0092
Concentration (gr/dscf @ 7%O2)	0.0098	0.0086	0.0146	0.0110
Concentration (mg/dscm)	18.44	17.14	27.84	21.14
Concentration (mg/dscm @ 7%O2)	22.42	19.76	33.36	25.18
Mass Rate (lb/hr)	10.43	9.49	15.64	11.85

<u>Pollutant</u>	<u>BACT Standard</u>
Particulate Matter	30 mg/dscm @ 7% O2

**TABLE 12**  
**SUMMARY OF PM2.5 EMISSIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 2 OUTLET**

RUN I.D.	U2O-M201A/202-R1	U2O-M201A/202-R2	U2O-M201A/202-R3	AVERAGE
DATE	04/11/13	04/11/13	04/11/13	
TIME STARTED	7:32	10:14	12:08	
TIME ENDED	8:38	11:14	13:08	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	22.397	20.157	20.184	20.913
Corrected Volume (dscf)	21.895	19.469	19.308	20.224
Corrected Volume (dscm)	0.620	0.551	0.547	0.573
Total Test Time (min)	66.3	60.6	60.3	62.4
% Isokinetics	109.0	119.4	120.2	116.2
<b>GAS PARAMETERS</b>				
Gas Temperature (deg F)	302	302	304	303
Oxygen (%)	9.98	9.51	9.81	9.77
Carbon Dioxide (%)	9.16	9.59	9.44	9.40
Moisture (%)	16.21	16.57	18.05	16.94
<b>GAS FLOWRATE</b>				
Velocity (ft/sec)	44.93	45.59	46.09	45.54
Actual Volume (acfm)	259499	263289	266193	262994
Standard Volume (dscfm)	146594	148208	146697	147166
Standard Volume @ 7% O2 (dscfm)	115166	121445	117041	117884
<b>STEAM PRODUCTION RATE (Klb/hr)</b>	231	233	232	232
<b>PM2.5 EMISSIONS</b>				
Concentration (gr/dscf)	0.0003	0.0003	0.0004	0.0003
Concentration (gr/dscf @ 7%O2)	0.0004	0.0004	0.0005	0.0004
Concentration (mg/dscm)	0.65	0.73	0.91	0.76
Concentration (mg/dscm @ 7%O2)	0.82	0.89	1.15	0.95
Mass Rate (lb/hr)	0.35	0.40	0.50	0.42
<b>CONDENSABLE PM2.5 EMISSIONS</b>				
Concentration (gr/dscf)	0.0276 *	0.0063	0.0088	0.0143
Concentration (gr/dscf @ 7%O2)	0.0352 *	0.0077	0.0110	0.0180
Concentration (mg/dscm)	63.23 *	14.51	20.12	32.62
Concentration (mg/dscm @ 7%O2)	80.48 *	17.71	25.22	41.14
Mass Rate (lb/hr)	34.72 *	8.06	11.05	17.94
<b>TOTAL PM2.5 EMISSIONS</b>				
Concentration (gr/dscf)	0.0279 *	0.0067	0.0092	0.0146
Concentration (gr/dscf @ 7%O2)	0.0355 *	0.0081	0.0115	0.0184
Concentration (mg/dscm)	63.87 *	15.24	21.03	33.38
Concentration (mg/dscm @ 7%O2)	81.30 *	18.59	26.36	42.09
Mass Rate (lb/hr)	35.07 *	8.46	11.56	18.36
<hr/>				
<b>Pollutant</b>	<b>BACT Standard</b>			
Particulate Matter	30 mg/dscm @ 7% O2			

\* The Unit 2 Run 1 inorganic condensable result is an outlier that is significantly greater than all other test runs. The analytical laboratory noted that the sample contained significantly more white, flaky residue than the other samples. If Run 1 is excluded, then average is 22 mg/dscm @ 7% O2, which is more than 20% below the emission limit.

TABLE 13

**SUMMARY OF PM2.5 EMISSIONS  
PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 OUTLET**

RUN I.D.	U3O-M201A/202-R1	U3O-M201A/202-R2	U3O-M201A/202-R3	AVERAGE
DATE	04/09/13	04/09/13	04/09/13	
TIME STARTED	11:56	14:08	16:38	
TIME ENDED	12:58	15:08	17:38	
<b>SAMPLING PARAMETERS</b>				
Metered Volume (dcf)	18.528	18.466	19.243	18.746
Corrected Volume (dscf)	17.918	17.581	18.298	17.933
Corrected Volume (dscm)	0.507	0.498	0.518	0.508
Total Test Time (min)	57.5	59.6	59.7	58.9
% Isokinetics	110.7	103.9	110.9	108.5
<b>GAS PARAMETERS</b>				
Gas Temperature (deg F)	310	309	308	309
Oxygen (%)	9.57	8.85	9.71	9.38
Carbon Dioxide (%)	9.84	10.33	9.57	9.91
Moisture (%)	20.43	19.56	21.49	20.49
<b>GAS FLOWRATE</b>				
Velocity (ft/sec)	50.50	50.30	50.14	50.31
Actual Volume (acfm)	291622	290484	289542	290549
Standard Volume (dscfm)	154991	156389	152213	154531
Standard Volume @ 7% O2 (dscfm)	126334	135575	122537	128149
<b>STEAM PRODUCTION RATE (Klb/hr)</b>	232	240	233	235
<b>PM2.5 EMISSIONS</b>				
Concentration (gr/dscf)	0.0028	0.0010	0.0005	0.0014
Concentration (gr/dscf @ 7%O2)	0.0034	0.0012	0.0006	0.0017
Concentration (mg/dscm)	6.35	2.34	1.17	3.29
Concentration (mg/dscm @ 7%O2)	7.79	2.70	1.45	3.98
Mass Rate (lb/hr)	3.69	1.37	0.67	1.91
<b>CONDENSABLE PM2.5 EMISSIONS</b>				
Concentration (gr/dscf)	0.0071	0.0101	0.0081	0.0084
Concentration (gr/dscf @ 7%O2)	0.0088	0.0116	0.0101	0.0102
Concentration (mg/dscm)	16.36	23.10	18.53	19.33
Concentration (mg/dscm @ 7%O2)	20.07	26.65	23.01	23.24
Mass Rate (lb/hr)	9.50	13.53	10.56	11.20
<b>TOTAL PM2.5 EMISSIONS</b>				
Concentration (gr/dscf)	0.0099	0.0111	0.0086	0.0099
Concentration (gr/dscf @ 7%O2)	0.0122	0.0128	0.0107	0.0119
Concentration (mg/dscm)	22.71	25.44	19.70	22.62
Concentration (mg/dscm @ 7%O2)	27.86	29.35	24.47	27.23
Mass Rate (lb/hr)	13.18	14.90	11.23	13.11
<hr/>				
<b>Pollutant</b>	<b>BACT Standard</b>			
Particulate Matter	30 mg/dscm @ 7% O2			

TABLE 14

SUMMARY OF VISIBLE AND FUGITIVE EMISSIONS  
PINELLAS COUNTY RESOURCE RECOVERY FACILITY

MWC STACKS, SILOS AND VENTS, AND ASH HANDLING SYSTEM

LOCATION	MWC UNIT 1 STACK			Average
	U1O-M9-R1	U1O-M9-R2	U1O-M9-R3	
RUN I.D.				
DATE	04/12/13	04/12/13	04/12/13	
TIME STARTED	10:13	11:13	12:13	
TIME ENDED	11:13	12:13	13:13	

STEAM PRODUCTION RATE (Klb/hr)	228	233	229	230
--------------------------------	-----	-----	-----	-----

All values are percent opacity

Maximum 6-Minute Value	0.00	0.00	0.00	0.00
Average for 60 Minutes	0.00	0.00	0.00	0.00

POLLUTANT	LIMIT
Visible Emissions	10% opacity (6-min. avg.)

LOCATION	MWC UNIT 2 STACK			Average
	U2O-M9-R1	U2O-M9-R2	U2O-M9-R3	
RUN I.D.				
DATE	04/10/13	04/12/13	04/12/13	
TIME STARTED	8:51	13:20	14:30	
TIME ENDED	9:51	14:20	15:30	

STEAM PRODUCTION RATE (Klb/hr)	236	233	227	232
--------------------------------	-----	-----	-----	-----

All values are percent opacity

Maximum 6-Minute Value	0.00	0.00	0.00	0.00
Average for 60 Minutes	0.00	0.00	0.00	0.00

POLLUTANT	LIMIT
Visible Emissions	10% opacity (6-min. avg.)

LOCATION	MWC UNIT 3 STACK			Average
	U3O-M9-R1	U3O-M9-R2	U3O-M9-R3	
RUN I.D.				
DATE	04/12/13	04/12/13	04/12/13	
TIME STARTED	10:13	11:13	12:13	
TIME ENDED	11:13	12:13	13:13	

STEAM PRODUCTION RATE (Klb/hr)	234	242	237	238
--------------------------------	-----	-----	-----	-----

All values are percent opacity

Maximum 6-Minute Value	0.00	0.00	0.00	0.00
Average for 60 Minutes	0.00	0.00	0.00	0.00

POLLUTANT	LIMIT
Visible Emissions	10% opacity (6-min. avg.)

LOCATION	ASH COND. BLDG.	RESIDUE S & P BLDG.	CARBON SILO	LIME STORAGE SILO
	M9-ACBO-R1	M9-RSPB-R1	CS-M9-R1	M9-Pebbel Lime Silo-R1
RUN I.D.				
DATE	04/13/13	04/12/13	04/12/13	04/09/13
TIME STARTED	12:15	16:47	8:51	10:22
TIME ENDED	13:15	17:47	9:51	11:22

All values are percent opacity

Maximum 6-Minute Value	0.00	0.00	0.00	0.00
Average for 60 Minutes	0.00	0.00	0.00	0.00

POLLUTANT	LIMIT
Visible Emissions	5% opacity (6-min. avg.)

LOCATION	ASH HANDLING SYSTEM		
	East Face	West Face	Northeast Face
RUN I.D.	AHS-M22-R1	AHS-M22-R2	AHS-M22-R3
DATE	04/12/13	04/12/13	04/12/13
TIME STARTED	8:58	10:22	11:45
TIME ENDED	10:13	11:37	13:00

Observation Period Duration (min:sec)	60:00	60:00	60:00
---------------------------------------	-------	-------	-------

Accumulated Fugitive Emissions Time (min:sec)	00:00	00:00	00:00
---	-------	-------	-------

Fugitive Emissions (% of Observation Period Duration)	0.00	0.00	0.00
---	------	------	------

POLLUTANT	LIMIT
Fugitive Emissions	5% of observation period duration

TABLE 15

SUMMARY OF RUN-BY-RUN ISOKINETIC TEST AIR FLOW RESULTS AT UNITS 1-3 FF OUTLETS  
PINELLAS COUNTY RRF

Unit No.	Run No.	Run Date	Run Time	Steam Flow (Klbs/hr)	Flue Gas Temp. (°F)	SDA Outlet Temp	Activated Carbon	Air Flow (ACFM)	O2 (%dv)	Air Flow (DSCFM)	Air Flow (DSCFM @ 7% O2)
1	U1O-M26A-R1	4/9/2013	09:05-11:28	233	315	Not Applicable	Not Applicable	261018	9.56	137153	111,893
	U1O-M26A-R2	4/9/2013	13:24-15:36	235	315	Not Applicable	Not Applicable	270271	10.22	142655	109,608
	U1O-M26A-R3	4/9/2013	16:22-18:33	236	317	Not Applicable	Not Applicable	272882	10.24	142979	109,652
	U1O-M29-R1	4/9/2013	09:05-11:28	233	316	Not Applicable	15	267181	9.98	139513	109,603
	U1O-M29-R2	4/9/2013	13:24-15:36	235	317	Not Applicable	15	273588	10.06	142753	111327
	U1O-M29-R3	4/9/2013	16:22-18:33	236	317	Not Applicable	15	276223	10.33	141945	107939
	U1O-M201A/202-R1	4/10/2013	10:08-11:08	236	325	Not Applicable	Not Applicable	283412	9.47	151039	124,200
	U1O-M201A/202-R2	4/10/2013	12:11-13:12	233	324	Not Applicable	Not Applicable	278728	8.84	147796	128,232
	U1O-M201A/202-R3	4/10/2013	15:03-16:03	234	311	Not Applicable	Not Applicable	276113	9.30	149919	125,112
Average =>				235	317	Not Applicable	15	273,268	9.78	143,972	115,285
2	U2O-M26A-R1	4/10/2013	08:45-11:15	234	295	Not Applicable	Not Applicable	263408	10.74	148964	108,883
	U2O-M26A-R2	4/10/2013	12:09-14:28	234	297	Not Applicable	Not Applicable	267842	10.93	149272	107,068
	U2O-M26A-R3	4/10/2013	15:25-17:35	234	296	Not Applicable	Not Applicable	264906	11.63	150357	100,274
	U2O-M29-R1	4/10/2013	08:45-11:15	234	294	Not Applicable	15	260454	10.60	145261	107,639
	U2O-M29-R2	4/10/2013	12:09-14:28	234	296	Not Applicable	15	264895	11.16	146184	102,434
	U2O-M29-R3	4/10/2013	15:25-17:35	234	297	Not Applicable	15	264216	11.72	148751	98,240
	U2O-M201A/202-R1	4/11/2013	07:32-08:38	231	302	Not Applicable	Not Applicable	259499	9.98	146594	115,166
	U2O-M201A/202-R2	4/11/2013	10:14-11:14	233	302	Not Applicable	Not Applicable	263289	9.51	148208	121,445
	U2O-M201A/202-R3	4/11/2013	12:08-13:08	232	304	Not Applicable	Not Applicable	266193	9.81	146697	117,041
Average =>				233	298	Not Applicable	15	263,856	10.68	147,810	108,688
3	U3O-M26A-R1	4/11/2013	08:37-10:56	235	306	Not Applicable	Not Applicable	260836	8.33	135446	122,486
	U3O-M26A-R2	4/11/2013	11:45-13:54	233	302	Not Applicable	Not Applicable	263026	7.83	135284	127,206
	U3O-M26A-R3	4/11/2013	14:36-17:04	236	305	Not Applicable	Not Applicable	263191	8.00	135380	125,640
	U3O-M29-R1	4/11/2013	08:37-10:56	235	308	Not Applicable	15	258433	8.54	132648	117,952
	U3O-M29-R2	4/11/2013	11:45-13:54	233	305	Not Applicable	15	259755	8.52	132061	117,619
	U3O-M29-R3	4/11/2013	14:36-17:04	236	306	Not Applicable	15	259953	8.17	132522	121,367
	U3O-M201A/202-R1	4/9/2013	11:56-12:53	232	310	Not Applicable	Not Applicable	291622	9.57	154991	126,334
	U3O-M201A/202-R2	4/9/2013	14:08-15:08	240	309	Not Applicable	Not Applicable	290484	8.85	156389	135,575
	U3O-M201A/202-R3	4/9/2013	16:38-17:38	233	308	Not Applicable	Not Applicable	289542	9.71	152213	122,537
Average =>				235	306	Not Applicable	15	270,760	8.61	140,770	124,080
<b>Facility Average =&gt;</b>				<b>234</b>	<b>307</b>	Not Applicable	<b>15</b>	<b>269,295</b>	<b>9.69</b>	<b>144,184</b>	<b>116,017</b>

**Table 16 – Summary of Pollutant Mass Rates  
Pinellas County Resource Recovery Facility (April 2013)**

Pollutant		Reporting Units	Title V Emission Limits	MACT Emission Limits	Average Emissions		
					Unit 1	Unit 2	Unit 3
Particulate Matter		lb/hr	N/A		3.67	3.68	3.74
PM2.5					11.85	18.36*	13.01
Cadmium					1.05E-03	6.23E-04	4.11E-04
Lead					6.88E-03	7.14E-03	4.28E-03
Mercury	<i>Inlet concentration</i>				1.94E-02	2.61E-02	2.83E-02
	<i>Outlet concentration</i>				1.72E-03	9.34E-04	2.94E-03
Hydrogen Chloride	<i>Outlet concentration</i>				6.42	5.58	13.11

\* The Unit 2 Run 1 inorganic condensable result is an outlier that is significantly greater than all other test runs. The analytical laboratory noted that the sample contained significantly more white, flaky residue than the other samples. If Run 1 is excluded, then average is 22 mg/dscm @ 7% O<sub>2</sub>, which is more than 20% below the emission limit.


## **Appendix A.2**

### **Figures**


## **LIST OF FIGURES**

- Figure 1 - Process General Flow Arrangement
- Figure 2 - SDA Inlet Sampling Location
- Figure 3 - FF Outlet Sampling Location
- Figure 4 - EPA Method 3 Sampling Train
- Figure 5 - EPA Method 29 Sampling Train
- Figure 6 - EPA Method 5/26A Sampling Train
- Figure 7 - EPA Method 201A/202 Sampling Train






**Figure 1 - Simplified Process General Flow Arrangement  
(Units 1, 2, & 3 are identical)**




INSIDE DIAMETER	120.0 in.	10.0 ft.
DISTANCE UPSTREAM FROM DISTURBANCE	168 in.	1.4 dia.
DISTANCE DOWNSTREAM FROM DISTURBANCE	288 in.	2.4 dia.


**Figure 2 - SDA Inlet Sampling Location  
(Units 1, 2, and 3 are Identical)**




**Figure 3 - FF Outlet Sampling Location  
(Units 1, 2, & 3 are Identical)**




**Figure 4 - EPA Method 3 Sampling Train**



**Figure 5 - EPA Method 29 Sampling Train**



**Figure 6 - EPA Method 5/26A Sampling Train**



**Figure 7 - EPA Method 201A/202 Sampling Train**

## **Appendix A.3**

### **Test Log**



**TEST LOG**  
**UNIT 1**  
**Pinellas County Resource Recovery Facility**  
**St. Petersburg, Florida**

Test Location	Run I.D.	Test Parameter	Test Date	Start Time	End Time
Unit 1 FF Outlet	U1O-M9-R1	Opacity EPA Method 9	4/12/13	10:13	11:13
	U1O-M9-R2			11:13	12:13
	U1O-M9-R3			12:13	13:13
	U1O-M201A/202-R1	PM <2.5 and Condensable Particulate EPA Method 201A/202	4/10/13	10:08	11:08
	U1O-M201A/202-R2			12:11	13:12
	U1O-M201A/202-R3			15:03	16:03
	U1O-M26A-R1*	Particulate and Hydrogen Chloride EPA Method 5/26A	4/9/13	09:05	11:28*
	U1O-M26A-R2			13:24	15:36
	U1O-M26A-R3			16:22	18:33
	U1O-M29-R1*	Cadmium, Lead, and Mercury EPA Method 29		09:05	11:28*
	U1O-M29-R2			13:24	15:36
	U1O-M29-R3			16:22	18:33
Unit 1 SDA Inlet	U1I-M29-R1*	Mercury EPA Method 29		09:05	11:26*
	U1I-M29-R2			13:24	15:34
	U1I-M29-R3			16:22	18:31

\* Delay 09:30-09:39 during the run because of a power loss.

**TEST LOG**  
**UNIT 2**  
**Pinellas County Resource Recovery Facility**  
**St. Petersburg, Florida**

Test Location	Run I.D.	Test Parameter	Test Date	Start Time	End Time
Unit 2 FF Outlet	U2O-M9-R1	Opacity EPA Method 9	4/10/13	08:51	09:51
	U2O-M9-R2		4/12/13	13:20	14:20
	U2O-M9-R3			14:30	15:30
	U2O-M201A/202-R1	PM <2.5 and Condensable Particulate EPA Method 201A/202	4/11/13	07:32	08:38
	U2O-M201A/202-R2			10:14	11:14
	U2O-M201A/202-R3			12:08	13:08
	U2O-M26A-R1*	Particulate and Hydrogen Chloride EPA Method 5/26A	4/10/13	08:45	11:15*
	U2O-M26A-R2			12:09	14:28
	U2O-M26A-R3			15:25	17:35
	U2O-M29-R1*	Cadmium, Lead, and Mercury EPA Method 29		08:45	11:15*
	U2O-M29-R2			12:09	14:28
	U2O-M29-R3			15:25	17:35
Unit 2 SDA Inlet	U2I-M29-R1*	Mercury EPA Method 29		08:45	11:13*
	U2I-M29-R2			12:09	14:26
	U2I-M29-R3			15:25	17:33

- \* Delay 08:57-08:59 during the run because of a power loss.
- \* Delay 09:32-09:40 during the run because of a power loss.
- \* Delay 10:35-10:44 during the run because of a power loss.

**TEST LOG**  
**UNIT 3**  
**Pinellas County Resource Recovery Facility**  
**St. Petersburg, Florida**

Test Location	Run I.D.	Test Parameter	Test Date	Start Time	End Time
Unit 3 FF Outlet	U3O-M9-R1	Opacity EPA Method 9	4/12/13	10:13	11:13
	U3O-M9-R2			11:13	12:13
	U3O-M9-R3			12:13	13:13
	U3O-M201A/202-R1	PM <2.5 and Condensable Particulate EPA Method 201A/202	4/9/13	11:56	12:53
	U3O-M201A/202-R2			14:08	15:08
	U3O-M201A/202-R3			16:38	17:38
	U3O-M26A-R1	Particulate and Hydrogen Chloride EPA Method 5/26A	4/11/13	08:37	10:56
	U3O-M26A-R2			11:45	13:54
	U3O-M26A-R3*			14:36	17:04*
	U3O-M29-R1	Cadmium, Lead, and Mercury EPA Method 29		08:37	10:56
	U3O-M29-R2			11:45	13:54
	U3O-M29-R3*			14:36	17:04*
Unit 3 SDA Inlet	U3I-M29-R1	Mercury EPA Method 29		08:37	10 :54
	U3I-M29-R2			11 :45	13 :52
	U3I-M29-R3*			14:36	17:02*

\* Delay 15:06-15:23 during the run because of a power loss.

**TEST LOG**  
**Additional Visible and Fugitive Emissions Test Locations**  
**Pinellas County Resource Recovery Facility**  
**St. Petersburg, Florida**

Location	Parameter	Method	Run ID	Date	Start Time	End Time
Ash Conditioning Building (Ash Handling Vent)	Visible Emissions	EPA Method 9	M9-ACBO-R1	4/13/13	12:15	13:15
Residue Storage and Processing Building (Rod Mill Vent)			M9-RSPB-R1	4/12/13	16:47	17:47
Activated Carbon Storage Silo			CS-M9-R1		08:51	09:51
Lime Storage Silo for SDA (Pebble Bin Vent)			M9-Pebble Lime Silo-R1	4/9/13	10:22	11:22
Ash Handling System	Fugitive Emissions	EPA Method 22	(EF)AHS-M22-R1	4/12/13	08:58	10:13
			(WF)AHS-M22-R2		10:22	11:37
			(NE)AHS-M22-R3		11:45	13:00

**Appendix A.4**  
**Contact Information**

## Contact Information

<p><b>Facility</b>  Pinellas County Resource Recovery Facility (PCRRF)  Operator: GCS Energy Recovery of Pinellas, Inc.  3001 110<sup>th</sup> Avenue North  St. Petersburg, Florida 33716</p>	<p><i>Plant Contact</i>  Ms. Rebecca Bigari  Environmental Manager  Phone: (727) 572-9163  Email: <a href="mailto:rbigari@gcspinelas.com">mailto:rbigari@gcspinelas.com</a></p>
<p><b>Testing Firm</b>  The Air Compliance Group, LLC  5075 Hollins Road  Roanoke, Virginia 24019</p>	<p><i>Testing Firm Contact</i>  Mr. Tony Underwood  Vice President - Operations  Phone: (540) 265-1987 Ext. 240  Email: <a href="mailto:tony.underwood@aircompgroup.com">tony.underwood@aircompgroup.com</a></p>
<p><b>Analytical Lab Names, Addresses and Contacts</b></p>	
<p><b><i>EPA Methods 5 and 201A Analyses</i></b>  The Air Compliance Group, LLC – see Testing Firm above</p>	<p>See Testing Firm Contact above</p>
<p><b><i>EPA Methods 26A, 29 and 202 Analyses</i></b>  Element One, Inc.  5022-C Wrightsville Ave.  Wilmington, North Carolina 28403</p>	<p><i>Element One Contact</i>  Ken Smith  Phone: (910) 793-0128  Email: <a href="mailto:e1lab@e1lab.com">e1lab@e1lab.com</a></p>

**Appendix B**  
**EPA Method 29 Data and Results**

## **Appendix B.1**

### **EPA Method 29 Data and Results: Unit 1 FF Outlet**



**Run Number**

**U10-M29-R1**

Date	04/09/13
Start Time	9:05
End Time	11:28
Stack Length	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	30.02 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	228.0	228.0
Impinger 2	100.0	247.0	147.0
Impinger 3	100.0	146.0	46.0
Impinger 4	0.0	6.0	6.0
Impinger 5	100.0	101.0	1.0
Impinger 6	100.0	92.0	-8.0
Impinger 7			0.0
<b>Total</b>	400.0	820.0	420.0
Silica gel (g)	250.0	270.0	20.0

**METHOD 1-4 RESULTS**

Metered Volume	81.384 dcf
Volume @ Std.Cond.	76.456 dscf
% Water	21.32 %
% Isokinetics	102.9 %
Velocity	46.27 ft/sec
Actual Flow	267181 acfm
Std. Flow	177308 scfm
Dry Std. Flow	139513 dscfm

**METHOD 3 DATA**

%O2	9.98	Md	29.90
%CO2	9.37	Ms	27.36
%CO	0.0	Ps	29.18
%N2	80.7	Fo	1.165
O2+CO2	19.4	%EA	88

POINT	Stack	Static	Delta P	Delta H	Meter	Meter	
	Temp.	Pressure				Temp. (Deg. F)	Inlet
	(DegF)	(in.WC)	(in.WC)	(in.WC)	(dcf)		
1	312	-11.50	0.42	1.60	199.714	75	75
2	314	-12.00	0.43	1.60	240.988	76	75
3	316	-11.00	0.44	1.60		76	75
4	316	-11.50	0.43	1.60	241.997	77	75
5	318	-11.50	0.46	1.70	282.107	80	76
6	316	-11.00	0.44	1.60		81	77
7	316		0.43	1.60		82	77
8	314		0.41	1.50		81	77
9	314		0.42	1.60		81	77
10	315		0.43	1.60		83	77
11	315		0.38	1.80		84	78
12	317		0.48	1.80		84	78
13	315		0.45	1.70		86	79
14	315		0.43	1.60		87	79
15	316		0.42	1.60		88	80
16	315		0.40	1.50		86	83
17	315		0.39	1.50		87	84
18	315		0.41	1.50		88	84
19	315		0.42	1.60		88	84
20	315		0.42	1.60		90	85
21	316		0.44	1.60		90	85
22	316		0.45	1.70		90	85
23	318		0.44	1.60		91	85
24	317		0.42	1.60		92	86
25	316		0.43	1.70		91	86
26	317		0.44	1.70		93	87
27	315		0.45	1.70		93	87
28	320		0.43	1.60		94	87
29	320		0.41	1.50		95	88
30	320		0.40	1.50		95	88
<b>AVG.</b>	316	-11.42	0.43	1.61	81.384	84	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 1 FF OUTLET**

**SAMPLING DATA**

Run Number           **U10-M29-R1**  
 Date                    04/09/13  
 Corr. Sample Volume   76.456 dscf  
 Corr. Flowrate         139513 dscfm  
 O2 Content             9.98 %  
 CO2 Content            9.37 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Sample Fraction 1	Blank Fraction 1	Sample Fraction 2	Blank Fraction 2	Sample Total	CONCENTRATION				MASS RATE
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@ 7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	0.10	0.00	6.03	0.00	6.13	2.83	3.63	3.61	3.61E-03	1.48E-03
Cadmium	Cd	4.51	0.00			4.51	2.08	2.67	2.65	2.65E-03	1.09E-03
Lead	Pb	26.00	0.83			25.17	11.63	14.89	14.80	1.48E-02	6.08E-03

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U1O-M29-R2**

Date	04/09/13
Start Time	13:24
End Time	15:36
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	30.04 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	248.0	248.0
Impinger 2	100.0	233.0	133.0
Impinger 3	100.0	122.0	22.0
Impinger 4	0.0	5.0	5.0
Impinger 5	100.0	104.0	4.0
Impinger 6	100.0	103.0	3.0
Impinger 7			0.0
<b>Total</b>	400.0	815.0	415.0
Silica gel (g)	250.0	270.7	20.7

**METHOD 1-4 RESULTS**

Metered Volume	81.677 dcf
Volume @ Std.Cond.	75.437 dscf
% Water	21.38 %
% Isokinetics	99.2 %
Velocity	47.37 ft/sec
Actual Flow	273588 acfm
Std. Flow	181565 scfm
Dry Std. Flow	142753 dscfm

**METHOD 3 DATA**

%O2	10.06	Md	29.90
%CO2	9.35	Ms	27.35
%CO	0.0	Ps	29.22
%N2	80.6	Fo	1.159
O2+CO2	19.4	%EA	90

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	306	-11.0	0.43	1.50	289.826	89	89
2	312	-11.0	0.44	1.50	330.015	90	89
3	317	-11.5	0.46	1.60		90	89
4	316	-11.0	0.47	1.60	331.010	91	90
5	315	-11.5	0.42	1.50	372.498	92	90
6	313	-11.0	0.42	1.50		94	91
7	313		0.45	1.60		95	91
8	318		0.43	1.50		95	91
9	328		0.43	1.60		96	93
10	330		0.46	1.60		97	92
11	320		0.45	1.60		98	93
12	321		0.40	1.40		98	93
13	320		0.43	1.50		98	93
14	321		0.42	1.50		99	94
15	321		0.43	1.50		100	94
16	316		0.43	1.50		95	94
17	318		0.45	1.60		97	94
18	320		0.46	1.60		98	94
19	317		0.44	1.50		97	94
20	316		0.43	1.50		96	94
21	313		0.48	1.70		93	91
22	315		0.48	1.70		93	91
23	315		0.45	1.60		94	90
24	316		0.46	1.60		94	90
25	312		0.48	1.70		96	90
26	314		0.48	1.70		96	90
27	316		0.50	1.80		96	90
28	316		0.47	1.70		97	90
29	317		0.45	1.60		97	90
30	317		0.44	1.50		97	90
<b>AVG.</b>	317	-11.17	0.45	1.58	81.677	93	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 1 FF OUTLET**

**SAMPLING DATA**

Run Number           **U1O-M29-R2**  
 Date                    04/09/13  
 Corr. Sample Volume   75.437 dscf  
 Corr. Flowrate        142753 dscfm  
 O2 Content             10.06 %  
 CO2 Content            9.35 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Sample Fraction 1	Blank Fraction 1	Sample Fraction 2	Blank Fraction 2	Sample Total	CONCENTRATION				MASS RATE (lb/hr)
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@ 7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	0.15	0.00	6.95	0.00	7.10	3.32	4.26	4.26	4.26E-03	1.78E-03
Cadmium	Cd	2.77	0.00			2.77	1.30	1.66	1.66	1.66E-03	6.93E-04
Lead	Pb	22.30	0.83			21.47	10.05	12.90	12.89	1.29E-02	5.37E-03

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U1O-M29-R3**

Date	04/09/13
Start Time	16:22
End Time	18:33
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	30.04 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	308.0	308.0
Impinger 2	100.0	230.0	130.0
Impinger 3	100.0	112.0	12.0
Impinger 4	0.0	4.0	4.0
Impinger 5	100.0	90.0	-10.0
Impinger 6	100.0	104.0	4.0
Impinger 7			0.0
<b>Total</b>	400.0	848.0	448.0
Silica gel (g)	250.0	272.0	22.0

**METHOD 1-4 RESULTS**

Metered Volume	81.819 dcf
Volume @ Std.Cond.	75.872 dscf
% Water	22.58 %
% Isokinetics	100.3 %
Velocity	47.83 ft/sec
Actual Flow	276223 acfm
Std. Flow	183337 scfm
Dry Std. Flow	141945 dscfm

**METHOD 3 DATA**

%O2	10.33	Md	29.87
%CO2	9.11	Ms	27.19
%CO	0.0	Ps	29.22
%N2	80.6	Fo	1.160
O2+CO2	19.4	%EA	94

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	314	-11.00	0.40	1.40	374.091	86	86
2	316	-11.50	0.40	1.40	414.596	87	86
3	316	-11.00	0.44	1.50		88	87
4	316	-11.00	0.45	1.60	414.732	89	87
5	315	-11.50	0.46	1.60	456.046	89	87
6	315	-11.00	0.43	1.50		91	88
7	315		0.44	1.50		92	88
8	317		0.46	1.60		93	88
9	317		0.47	1.60		94	89
10	317		0.46	1.60		94	89
11	318		0.46	1.60		95	91
12	319		0.48	1.70		95	92
13	318		0.48	1.70		95	91
14	319		0.47	1.60		96	90
15	319		0.45	1.60		96	90
16	315		0.45	1.60		92	89
17	315		0.48	1.70		93	89
18	316		0.45	1.60		93	89
19	317		0.44	1.50		93	89
20	317		0.46	1.60		94	89
21	314		0.44	1.50		95	90
22	315		0.45	1.60		97	90
23	317		0.43	1.50		97	90
24	317		0.44	1.50		97	90
25	320		0.46	1.60		97	91
26	320		0.50	1.80		96	92
27	317		0.51	1.80		93	91
28	319		0.47	1.70		92	90
29	318		0.45	1.60		92	90
30	318		0.44	1.50		92	89
<b>AVG.</b>	317	-11.17	0.45	1.59	81.819	91	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 1 FF OUTLET**

**SAMPLING DATA**

Run Number           **U10-M29-R3**  
 Date                    04/09/13  
 Corr. Sample Volume   75.872 dscf  
 Corr. Flowrate        141945 dscfm  
 O2 Content             10.33 %  
 CO2 Content            9.11 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Sample Fraction 1	Blank Fraction 1	Sample Fraction 2	Blank Fraction 2	Sample Total	CONCENTRATION				MASS RATE (lb/hr)
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	0.42	0.00	7.30	0.00	7.72	3.59	4.73	4.72	4.72E-03	1.91E-03
Cadmium	Cd	5.55	0.00			5.55	2.58	3.40	3.40	3.40E-03	1.37E-03
Lead	Pb	37.90	0.83			37.07	17.26	22.73	22.69	2.27E-02	9.17E-03

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

## **Appendix B.2**

### **EPA Method 29 Data and Results: Unit 1 SDA Inlet**

**Run Number**

**U11-M29-R1**

Date	04/09/13
Start Time	9:05
End Time	11:26
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	30.02 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	133.0	133.0
Impinger 2	100.0	250.0	150.0
Impinger 3	100.0	137.0	37.0
Impinger 4	0.0	2.0	2.0
Impinger 5	100.0	100.0	0.0
Impinger 6	100.0	94.0	-6.0
Impinger 7			0.0
<b>Total</b>	400.0	716.0	316.0
Silica gel (g)	250.0	278.3	28.3

**METHOD 1-4 RESULTS**

Metered Volume	80.291 dcf
Volume @ Std.Cond.	78.065 dscf
% Water	17.19 %
% Isokinetics	97.2 %
Velocity	62.71 ft/sec
Actual Flow	295490 acfm
Std. Flow	148534 scfm
Dry Std. Flow	122996 dscfm

**METHOD 3 DATA**

%O2	8.10	Md	30.07
%CO2	10.90	Ms	27.99
%CO	0.0	Ps	29.92
%N2	81.0	Fo	1.174
O2+CO2	19.0	%EA	61

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	587	-1.50	0.54	1.40	472.068	73	73
2	586	-1.30	0.62	1.60	513.015	74	73
3	587		0.66	1.70		75	73
4	587		0.65	1.70	513.244	76	73
5	586		0.68	1.80	552.588	76	73
6	588		0.66	1.70		77	73
7	587		0.64	1.70		77	74
8	587		0.65	1.70		77	74
9	590		0.63	1.60		79	75
10	591		0.63	1.60		78	75
11	592		0.59	1.50		78	75
12	592		0.62	1.60		78	75
13	592		0.50	1.30		76	76
14	593		0.54	1.40		77	76
15	593		0.60	1.60		78	76
16	593		0.60	1.60		78	76
17	592		0.62	1.60		77	76
18	592		0.61	1.60		77	75
19	593		0.62	1.60		78	75
20	593		0.63	1.60		77	75
21	592		0.61	1.60		78	76
22	592		0.60	1.60		78	76
23	592		0.57	1.50		78	77
24	590		0.54	1.40		78	77
<b>AVG.</b>	590	-1.40	0.61	1.58	80.291	76	



**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 SDA INLET**

**SAMPLING DATA**

Run Number                    **U11-M29-R1**  
 Date                            04/09/13  
 Corr. Sample Volume        78.065 dscf  
 Corr. Sample Volume        2.211 dscm  
 Corr. Flowrate                122996 dscfm  
 O2 Content                    8.10 %  
 CO2 Content                  10.90 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Front Half Sample	Front Half Blank	Back Half Sample	Back Half Blank	Sample Total	CONCENTRATION				MASS RATE lb/hr
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	25.10	0.0000	74.281	0.00	99.38	44.96	49.49	48.82	0.049	2.07E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U11-M29-R2**

Date	04/09/13
Start Time	13:24
End Time	15:34
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	30.02 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	154.0	154.0
Impinger 2	100.0	218.0	118.0
Impinger 3	100.0	140.0	40.0
Impinger 4	0.0	2.0	2.0
Impinger 5	100.0	104.0	4.0
Impinger 6	100.0	100.0	0.0
Impinger 7			0.0
<b>Total</b>	400.0	718.0	318.0
Silica gel (g)	250.0	278.6	28.6

**METHOD 1-4 RESULTS**

Metered Volume	81.696 dcf
Volume @ Std.Cond.	78.318 dscf
% Water	17.24 %
% Isokinetics	96.1 %
Velocity	64.07 ft/sec
Actual Flow	301940 acfm
Std. Flow	150757 scfm
Dry Std. Flow	124764 dscfm

**METHOD 3 DATA**

%O2	8.54	Md	30.03
%CO2	10.55	Ms	27.96
%CO	0.0	Ps	29.91
%N2	80.9	Fo	1.172
O2+CO2	19.1	%EA	67

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	597	-1.60	0.62	1.60	553.523	81	82
2	598	-1.40	0.64	1.70	594.857	85	82
3	599		0.66	1.70		85	82
4	599		0.65	1.70	595.066	85	82
5	598		0.67	1.70	635.428	86	83
6	599		0.67	1.70		86	83
7	599		0.66	1.70		86	83
8	600		0.64	1.70		86	83
9	600		0.65	1.70		86	84
10	599		0.63	1.60		86	84
11	598		0.60	1.60		86	84
12	598		0.58	1.50		86	84
13	597		0.56	1.50		83	83
14	598		0.61	1.60		85	83
15	598		0.63	1.60		84	83
16	599		0.65	1.70		84	83
17	595		0.65	1.70		83	83
18	593		0.64	1.70		82	82
19	594		0.63	1.60		83	82
20	594		0.65	1.70		83	82
21	595		0.62	1.60		84	82
22	594		0.62	1.60		84	82
23	595		0.60	1.60		84	83
24	595		0.59	1.50		84	83
<b>AVG.</b>	597	-1.50	0.63	1.64	81.696	84	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 SDA INLET**

**SAMPLING DATA**

Run Number                    **U11-M29-R2**  
 Date                            04/09/13  
 Corr. Sample Volume        78.318 dscf  
 Corr. Sample Volume        2.218 dscm  
 Corr. Flowrate                124764 dscfm  
 O2 Content                    8.54 %  
 CO2 Content                  10.55 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Front Half Sample	Front Half Blank	Back Half Sample	Back Half Blank	Sample Total	CONCENTRATION				MASS RATE lb/hr
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	24.00	0.0000	68.87	0.00	92.87	41.88	47.63	47.09	0.047	1.96E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U11-M29-R3**

Date	04/09/13
Start Time	16:22
End Time	18:31
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	30.04 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	145.0	145.0
Impinger 2	100.0	235.0	135.0
Impinger 3	100.0	130.0	30.0
Impinger 4	0.0	11.0	11.0
Impinger 5	100.0	115.0	15.0
Impinger 6	100.0	95.0	-5.0
Impinger 7			0.0
<b>Total</b>	400.0	731.0	331.0
Silica gel (g)	250.0	274.7	24.7

**METHOD 1-4 RESULTS**

Metered Volume	80.460 dcf
Volume @ Std.Cond.	76.865 dscf
% Water	17.89 %
% Isokinetics	96.1 %
Velocity	63.50 ft/sec
Actual Flow	299253 acfm
Std. Flow	149143 scfm
Dry Std. Flow	122464 dscfm

**METHOD 3 DATA**

%O2	8.29	Md	30.09
%CO2	10.97	Ms	27.92
%CO	0.0	Ps	29.92
%N2	80.7	Fo	1.149
O2+CO2	19.3	%EA	64

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	594	-1.60	0.55	1.40	636.623	85	85
2	595	-1.70	0.59	1.50	677.298	84	83
3	598		0.62	1.60		85	83
4	598		0.63	1.60	678.967	86	83
5	599		0.63	1.60	718.752	86	86
6	598		0.65	1.70		86	84
7	599		0.64	1.70		86	84
8	599		0.64	1.70		87	83
9	599		0.65	1.70		87	83
10	600		0.63	1.60		87	84
11	600		0.63	1.60		87	84
12	600		0.61	1.60		87	84
13	601		0.60	1.60		85	84
14	601		0.63	1.60		88	85
15	600		0.62	1.60		88	85
16	600		0.65	1.70		88	85
17	600		0.64	1.70		88	85
18	601		0.63	1.60		88	86
19	601		0.63	1.60		88	86
20	601		0.62	1.60		87	86
21	601		0.60	1.60		87	86
22	600		0.61	1.60		88	86
23	600		0.58	1.50		89	87
24	600		0.53	1.40		89	87
<b>AVG.</b>	599	-1.65	0.62	1.60	80.460	86	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 SDA INLET**

**SAMPLING DATA**

Run Number                    **U11-M29-R3**  
 Date                            04/09/13  
 Corr. Sample Volume        76.865 dscf  
 Corr. Sample Volume        2.177 dscm  
 Corr. Flowrate               122464 dscfm  
 O2 Content                    8.29 %  
 CO2 Content                  10.97 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT	LABORATORY DATA					METALS EMISSIONS				
	Front Half Sample (µg)	Front Half Blank (µg)	Back Half Sample (µg)	Back Half Blank (µg)	Sample Total (µg)	CONCENTRATION				MASS RATE lb/hr
	ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)						
Mercury Hg	21.05	0.0000	63.329	0.00	84.38	38.77	42.41	42.73	0.043	1.78E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

## **Appendix B.3**

### **EPA Method 29 Data and Results: Unit 2 FF Outlet**

**Run Number**

**U2O-M29-R1**

Date	04/10/13
Start Time	8:45
End Time	11:15
Stack Length	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	29.99 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	176.0	176.0
Impinger 2	100.0	228.0	128.0
Impinger 3	100.0	137.0	37.0
Impinger 4	0.0	8.0	8.0
Impinger 5	100.0	97.0	-3.0
Impinger 6	100.0	107.0	7.0
Impinger 7			0.0
<b>Total</b>	400.0	753.0	353.0
Silica gel (g)	250.0	267.6	17.6

**METHOD 1-4 RESULTS**

Metered Volume	81.193 dcf
Volume @ Std.Cond.	77.137 dscf
% Water	18.44 %
% Isokinetics	99.7 %
Velocity	45.10 ft/sec
Actual Flow	260454 acfm
Std. Flow	178113 scfm
Dry Std. Flow	145261 dscfm

**METHOD 3 DATA**

%O2	10.60	Md	29.80
%CO2	8.60	Ms	27.62
%CO	0.0	Ps	29.20
%N2	80.8	Fo	1.198
O2+CO2	19.2	%EA	99

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	282	-11.00	0.48	1.80	470.436	70	70
2	297	-10.50	0.48	1.80	511.836	72	71
3	298	-11.00	0.45	1.70		73	71
4	291	-10.50	0.40	1.50	511.997	75	71
5	302	-11.00	0.33	1.30	551.790	75	71
6	292	-10.50	0.47	1.80		77	72
7	292		0.49	1.90		78	73
8	293		0.46	1.70		78	74
9	298		0.42	1.60		79	74
10	303		0.34	1.30		80	75
11	292		0.45	1.70		81	75
12	297		0.47	1.80		78	75
13	288		0.44	1.70		80	75
14	291		0.43	1.60		80	75
15	293		0.35	1.30		80	75
16	288		0.48	1.80		78	76
17	280		0.47	1.80		79	76
18	305		0.43	1.60		79	76
19	299		0.40	1.50		80	76
20	289		0.33	1.30		81	76
21	291		0.47	1.80		81	77
22	292		0.45	1.70		82	77
23	290		0.45	1.70		82	77
24	291		0.40	1.50		80	78
25	300		0.35	1.30		80	78
26	291		0.40	1.50		81	78
27	291		0.43	1.60		82	78
28	292		0.43	1.60		83	78
29	297		0.41	1.50		83	78
30	300		0.35	1.30		84	79
<b>AVG.</b>	294	-10.75	0.42	1.60	81.193	77	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 2 FF OUTLET**

**SAMPLING DATA**

Run Number           **U2O-M29-R1**  
 Date                    04/10/13  
 Corr. Sample Volume   77.137 dscf  
 Corr. Flowrate         145261 dscfm  
 O2 Content             10.60 %  
 CO2 Content            8.60 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Sample Fraction 1	Blank Fraction 1	Sample Fraction 2	Blank Fraction 2	Sample Total	CONCENTRATION				MASS RATE
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	0.16	0.00	1.95	0.00	2.11	0.97	1.35	1.30	1.30E-03	5.25E-04
Cadmium	Cd	1.41	0.00			1.41	0.65	0.90	0.87	8.71E-04	3.51E-04
Lead	Pb	19.30	0.83			18.47	8.46	11.80	11.41	1.14E-02	4.60E-03

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank



**Run Number**

**U2O-M29-R2**

Date	04/10/13
Start Time	12:09
End Time	14:28
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	29.95 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	213.0	213.0
Impinger 2	100.0	235.0	135.0
Impinger 3	100.0	120.0	20.0
Impinger 4	0.0	0.0	0.0
Impinger 5	100.0	98.0	-2.0
Impinger 6	100.0	95.0	-5.0
Impinger 7			0.0
<b>Total</b>	400.0	761.0	361.0
Silica gel (g)	250.0	268.4	18.4

**METHOD 1-4 RESULTS**

Metered Volume	82.192 dcf
Volume @ Std.Cond.	76.432 dscf
% Water	18.94 %
% Isokinetics	98.1 %
Velocity	45.87 ft/sec
Actual Flow	264895 acfm
Std. Flow	180343 scfm
Dry Std. Flow	146184 dscfm

**METHOD 3 DATA**

%O2	11.16	Md	29.76
%CO2	8.19	Ms	27.53
%CO	0.0	Ps	29.16
%N2	80.7	Fo	1.189
O2+CO2	19.4	%EA	110

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	294	-11.0	0.48	1.80	556.062	84	81
2	294	-10.5	0.48	1.80	596.820	85	81
3	298	-10.5	0.45	1.70		84	82
4	297	-11.0	0.41	1.60	596.967	85	82
5	295	-11.0	0.35	1.30	638.401	86	82
6	295	-10.5	0.45	1.70		87	83
7	295		0.46	1.70		88	83
8	297		0.44	1.70		88	83
9	294		0.40	1.50		88	84
10	292		0.36	1.40		89	84
11	292		0.47	1.80		89	84
12	296		0.48	1.80		90	85
13	302		0.45	1.70		90	85
14	294		0.41	1.60		90	85
15	292		0.37	1.40		91	85
16	293		0.49	1.90		88	87
17	293		0.47	1.80		89	87
18	300		0.44	1.70		90	87
19	304		0.41	1.60		90	87
20	292		0.35	1.30		90	88
21	292		0.51	1.90		91	88
22	294		0.50	1.90		91	88
23	304		0.48	1.80		92	89
24	305		0.43	1.60		93	90
25	293		0.40	1.50		95	91
26	304		0.47	1.80		94	91
27	299		0.45	1.70		94	91
28	291		0.45	1.70		94	92
29	292		0.40	1.50		95	92
30	292		0.33	1.30		95	92
<b>AVG.</b>	296	-10.75	0.43	1.65	82.192	88	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 2 FF OUTLET**

**SAMPLING DATA**

Run Number           **U20-M29-R2**  
 Date                    04/10/13  
 Corr. Sample Volume   76.432 dscf  
 Corr. Flowrate        146184 dscfm  
 O2 Content             11.16 %  
 CO2 Content            8.19 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT	LABORATORY DATA					METALS EMISSIONS				
	Sample Fraction 1 (µg)	Blank Fraction 1 (µg)	Sample Fraction 2 (µg)	Blank Fraction 2 (µg)	Sample Total (µg)	CONCENTRATION				MASS RATE (lb/hr)
	ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@ 7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)						
Mercury Hg	0.98	0.00	4.55	0.00	5.53	2.55	3.74	3.65	3.65E-03	1.40E-03
Cadmium Cd	5.39	0.00			5.39	2.49	3.65	3.55	3.55E-03	1.36E-03
Lead Pb	52.60	0.83			51.77	23.92	35.05	34.14	3.41E-02	1.31E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U2O-M29-R3**

Date	04/10/13
Start Time	15:25
End Time	17:35
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	29.95 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	133.0	133.0
Impinger 2	100.0	241.0	141.0
Impinger 3	100.0	134.0	34.0
Impinger 4	0.0	7.0	7.0
Impinger 5	100.0	101.0	1.0
Impinger 6	100.0	95.0	-5.0
Impinger 7			0.0
<b>Total</b>	400.0	711.0	311.0
Silica gel (g)	250.0	270.6	20.6

**METHOD 1-4 RESULTS**

Metered Volume	82.726 dcf
Volume @ Std.Cond.	75.218 dscf
% Water	17.19 %
% Isokinetics	94.9 %
Velocity	45.75 ft/sec
Actual Flow	264216 acfm
Std. Flow	179622 scfm
Dry Std. Flow	148751 dscfm

**METHOD 3 DATA**

%O2	11.72	Md	29.70
%CO2	7.70	Ms	27.69
%CO	0.0	Ps	29.15
%N2	80.6	Fo	1.192
O2+CO2	19.4	%EA	123

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	298	-10.50	0.40	1.50	643.160	94	94
2	301	-11.00	0.48	1.80	685.316	96	93
3	294	-10.50	0.50	1.90		97	95
4	294	-11.00	0.46	1.70	685.620	96	97
5	293	-11.00	0.40	1.50	726.190	97	98
6	294	-11.00	0.48	1.80		99	100
7	295		0.47	1.80		99	100
8	292		0.44	1.60		101	101
9	298		0.44	1.60		101	102
10	298		0.38	1.40		102	102
11	292		0.50	1.90		102	102
12	295		0.46	1.70		103	104
13	304		0.48	1.80		103	104
14	306		0.44	1.60		103	104
15	300		0.38	1.40		101	102
16	292		0.45	1.70		102	103
17	292		0.46	1.70		102	103
18	294		0.43	1.60		102	103
19	294		0.41	1.50		102	103
20	308		0.35	1.30		101	102
21	306		0.40	1.50		101	102
22	292		0.44	1.60		102	101
23	292		0.44	1.60		102	102
24	303		0.38	1.40		101	99
25	295		0.35	1.30		101	99
26	290		0.47	1.80		101	101
27	291		0.48	1.80		101	101
28	300		0.45	1.70		102	98
29	300		0.40	1.50		102	98
30	300		0.40	1.50		102	98
<b>AVG.</b>	297	-10.83	0.43	1.62	82.726	100	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 2 FF OUTLET**

**SAMPLING DATA**

Run Number           **U2O-M29-R3**  
 Date                    04/10/13  
 Corr. Sample Volume   75.218 dscf  
 Corr. Flowrate        148751 dscfm  
 O2 Content             11.72 %  
 CO2 Content            7.70 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				MASS RATE (lb/hr)
		Sample Fraction 1 (µg)	Blank Fraction 1 (µg)	Sample Fraction 2 (µg)	Blank Fraction 2 (µg)	Sample Total (µg)	CONCENTRATION				
		ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)						
Mercury	Hg	< 0.10	0.00	3.36	0.00	3.36	1.58	2.46	2.39	2.39E-03	8.79E-04
Cadmium	Cd	0.59	0.00			0.59	0.28	0.43	0.42	4.18E-04	1.54E-04
Lead	Pb	15.00	0.83			14.17	6.65	10.37	10.08	1.01E-02	3.71E-03

**Notes**

"<" denotes that one or more fractions were below the detection limit. Detection limits were used in cases of non-detect results.

Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

## **Appendix B.4**

### **EPA Method 29 Data and Results: Unit 2 SDA Inlet**

**Run Number**

**U2I-M29-R1**

Date	04/10/13
Start Time	8:45
End Time	11:13
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	29.99 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	94.0	94.0
Impinger 2	100.0	237.0	137.0
Impinger 3	100.0	157.0	57.0
Impinger 4	0.0	12.0	12.0
Impinger 5	100.0	106.0	6.0
Impinger 6	100.0	101.0	1.0
Impinger 7			0.0
<b>Total</b>	400.0	707.0	307.0
Silica gel (g)	250.0	273.5	23.5

**METHOD 1-4 RESULTS**

Metered Volume	79.161 dcf
Volume @ Std.Cond.	77.343 dscf
% Water	16.75 %
% Isokinetics	97.6 %
Velocity	57.21 ft/sec
Actual Flow	269606 acfm
Std. Flow	145780 scfm
Dry Std. Flow	121366 dscfm

**METHOD 3 DATA**

%O2	8.56	Md	29.99
%CO2	10.31	Ms	27.98
%CO	0.0	Ps	29.91
%N2	81.1	Fo	1.197
O2+CO2	18.9	%EA	67

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	518	-1.10	0.46	1.30	727.148	69	68
2	519	-1.00	0.50	1.40	766.703	72	70
3	519		0.52	1.50		73	70
4	520		0.54	1.50	766.913	73	71
5	518		0.54	1.50	806.519	73	70
6	517		0.55	1.50		74	71
7	517		0.58	1.60		73	71
8	516		0.59	1.70		73	70
9	516		0.58	1.60		73	71
10	515		0.60	1.70		74	71
11	515		0.59	1.70		74	71
12	516		0.59	1.70		75	72
13	516		0.43	1.20		73	72
14	515		0.46	1.30		74	73
15	515		0.49	1.40		74	72
16	515		0.50	1.40		74	73
17	516		0.51	1.40		74	72
18	515		0.54	1.50		75	72
19	515		0.57	1.60		75	73
20	515		0.58	1.60		74	73
21	516		0.58	1.60		75	74
22	516		0.60	1.70		75	74
23	515		0.59	1.70		75	74
24	515		0.60	1.70		75	74
<b>AVG.</b>	516	-1.05	0.55	1.53	79.161	73	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 SDA INLET**

**SAMPLING DATA**

Run Number                    **U2I-M29-R1**  
 Date                            04/10/13  
 Corr. Sample Volume        77.343 dscf  
 Corr. Sample Volume        2.190 dscm  
 Corr. Flowrate                121366 dscfm  
 O2 Content                    8.56 %  
 CO2 Content                  10.31 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Front Half Sample	Front Half Blank	Back Half Sample	Back Half Blank	Sample Total	CONCENTRATION				MASS RATE lb/hr
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	45.75	0.0000	31.979	0.00	77.73	35.49	41.31	39.98	0.040	1.61E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U2I-M29-R2**

Date	04/10/13
Start Time	12:09
End Time	14:26
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	29.98 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	116.0	116.0
Impinger 2	100.0	240.0	140.0
Impinger 3	100.0	129.0	29.0
Impinger 4	0.0	10.0	10.0
Impinger 5	100.0	100.0	0.0
Impinger 6	100.0	105.0	5.0
Impinger 7			0.0
<b>Total</b>	400.0	700.0	300.0
Silica gel (g)	250.0	278.0	28.0

**METHOD 1-4 RESULTS**

Metered Volume	77.852 dcf
Volume @ Std.Cond.	74.446 dscf
% Water	17.18 %
% Isokinetics	95.8 %
Velocity	56.60 ft/sec
Actual Flow	266728 acfm
Std. Flow	143627 scfm
Dry Std. Flow	118954 dscfm

**METHOD 3 DATA**

%O2	9.01	Md	29.95
%CO2	9.94	Ms	27.90
%CO	0.0	Ps	29.90
%N2	81.1	Fo	1.196
O2+CO2	19.0	%EA	73

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	515	-0.98	0.44	1.20	807.109	77	77
2	515	-1.10	0.47	1.30	846.015	78	78
3	516		0.49	1.40		80	78
4	516		0.52	1.50	846.307	82	79
5	515		0.53	1.50	885.253	83	81
6	515		0.55	1.50		85	82
7	516		0.55	1.50		89	84
8	519		0.58	1.60		89	84
9	523		0.56	1.60		88	84
10	522		0.57	1.60		88	83
11	522		0.55	1.50		89	83
12	523		0.56	1.60		88	83
13	523		0.46	1.30		83	83
14	522		0.47	1.30		86	83
15	522		0.49	1.40		87	84
16	523		0.51	1.40		88	83
17	522		0.53	1.50		87	83
18	522		0.53	1.50		87	84
19	523		0.55	1.50		87	84
20	522		0.56	1.60		87	85
21	522		0.55	1.50		86	84
22	521		0.57	1.60		86	84
23	521		0.56	1.60		86	85
24	520		0.56	1.60		86	85
<b>AVG.</b>	520	-1.04	0.53	1.48	77.852	84	



**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 SDA INLET**

**SAMPLING DATA**

Run Number                    **U2I-M29-R2**  
 Date                            04/10/13  
 Corr. Sample Volume        74.446 dscf  
 Corr. Sample Volume        2.108 dscm  
 Corr. Flowrate                118954 dscfm  
 O2 Content                    9.01 %  
 CO2 Content                  9.94 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Front Half Sample	Front Half Blank	Back Half Sample	Back Half Blank	Sample Total	CONCENTRATION				MASS RATE
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	36.40	0.0000	91.87	0.00	128.27	60.85	73.46	71.13	0.071	2.71E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U2I-M29-R3**

Date	04/10/13
Start Time	15:25
End Time	17:33
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	29.95 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	71.0	71.0
Impinger 2	100.0	232.0	132.0
Impinger 3	100.0	137.0	37.0
Impinger 4	0.0	13.0	13.0
Impinger 5	100.0	100.0	0.0
Impinger 6	100.0	97.0	-3.0
Impinger 7			0.0
<b>Total</b>	400.0	650.0	250.0
Silica gel (g)	250.0	273.2	23.2

**METHOD 1-4 RESULTS**

Metered Volume	80.191 dcf
Volume @ Std.Cond.	75.144 dscf
% Water	14.61 %
% Isokinetics	95.3 %
Velocity	55.77 ft/sec
Actual Flow	262800 acfm
Std. Flow	141379 scfm
Dry Std. Flow	120717 dscfm

**METHOD 3 DATA**

%O2	9.84	Md	29.87
%CO2	9.25	Ms	28.14
%CO	0.0	Ps	29.87
%N2	80.9	Fo	1.196
O2+CO2	19.1	%EA	85

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	521	-1.10	0.43	1.20	886.015	85	86
2	522	-1.00	0.45	1.30	926.124	86	87
3	522		0.46	1.30		88	86
4	521		0.49	1.40	926.355	90	88
5	523		0.51	1.50	966.437	90	88
6	520		0.51	1.50		92	88
7	519		0.54	1.60		94	89
8	518		0.57	1.70		94	90
9	519		0.56	1.70		95	91
10	520		0.58	1.70		95	92
11	520		0.58	1.70		95	91
12	520		0.57	1.70		93	91
13	520		0.40	1.20		88	88
14	521		0.44	1.30		95	90
15	520		0.46	1.40		98	92
16	519		0.49	1.50		101	95
17	519		0.52	1.60		102	96
18	520		0.52	1.60		103	97
19	519		0.55	1.70		104	99
20	518		0.55	1.70		106	100
21	518		0.57	1.70		106	101
22	519		0.58	1.70		105	102
23	520		0.56	1.70		105	103
24	520		0.56	1.70		104	103
<b>AVG.</b>	520	-1.05	0.52	1.55	80.191	95	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 SDA INLET**

**SAMPLING DATA**

Run Number                    **U2I-M29-R3**  
 Date                            04/10/13  
 Corr. Sample Volume        75.144 dscf  
 Corr. Sample Volume        2.128 dscm  
 Corr. Flowrate                120717 dscfm  
 O2 Content                    9.84 %  
 CO2 Content                  9.25 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT	LABORATORY DATA					METALS EMISSIONS				
	Front Half Sample (µg)	Front Half Blank (µg)	Back Half Sample (µg)	Back Half Blank (µg)	Sample Total (µg)	CONCENTRATION				MASS RATE lb/hr
	ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)						
Mercury Hg	55.25	0.0000	110.275	0.00	165.53	77.79	100.92	97.76	0.098	3.52E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

## **Appendix B.5**

### **EPA Method 29 Data and Results: Unit 3 FF Outlet**

**Run Number**

**U3O-M29-R1**

Date	04/11/13
Start Time	8:37
End Time	10:56
Stack Length	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	29.84 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	160.0	160.0
Impinger 2	100.0	335.0	235.0
Impinger 3	100.0	153.0	53.0
Impinger 4	0.0	5.0	5.0
Impinger 5	100.0	100.0	0.0
Impinger 6	100.0	98.0	-2.0
Impinger 7			0.0
<b>Total</b>	400.0	851.0	451.0
Silica gel (g)	250.0	270.4	20.4

**METHOD 1-4 RESULTS**

Metered Volume	78.811 dcf
Volume @ Std.Cond.	74.099 dscf
% Water	23.05 %
% Isokinetics	104.8 %
Velocity	44.75 ft/sec
Actual Flow	258433 acfm
Std. Flow	172372 scfm
Dry Std. Flow	132648 dscfm

**METHOD 3 DATA**

%O2	8.54	Md	30.01
%CO2	10.45	Ms	27.24
%CO	0.0	Ps	29.03
%N2	81.0	Fo	1.183
O2+CO2	19.0	%EA	66

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	311	-11.00	0.45	1.70	739.165	75	74
2	310	-11.00	0.45	1.70	779.116	76	74
3	312	-11.00	0.43	1.60		76	74
4	312	-11.00	0.40	1.50	779.360	77	74
5	312	-11.00	0.34	1.30	818.220	78	74
6	320	-11.00	0.44	1.70		79	75
7	320		0.45	1.70		80	75
8	305		0.41	1.60		80	76
9	304		0.39	1.50		81	76
10	306		0.35	1.30		82	77
11	307		0.43	1.60		82	77
12	307		0.42	1.60		83	77
13	308		0.40	1.50		82	78
14	308		0.38	1.50		83	78
15	307		0.35	1.30		83	78
16	306		0.43	1.60		79	78
17	306		0.42	1.60		80	79
18	307		0.41	1.50		81	79
19	307		0.40	1.50		82	79
20	308		0.34	1.30		82	79
21	306		0.42	1.60		83	80
22	306		0.41	1.60		84	80
23	306		0.41	1.60		84	80
24	306		0.39	1.50		85	80
25	307		0.33	1.30		86	81
26	303		0.42	1.60		85	81
27	306		0.43	1.60		86	81
28	307		0.40	1.50		86	82
29	307		0.38	1.50		86	83
30	306		0.34	1.30		87	83
<b>AVG.</b>	308	-11.00	0.40	1.52	78.811	80	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 3 FF OUTLET**

**SAMPLING DATA**

Run Number           **U30-M29-R1**  
 Date                    04/11/13  
 Corr. Sample Volume   74.099 dscf  
 Corr. Flowrate        132648 dscfm  
 O2 Content             8.54 %  
 CO2 Content            10.45 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Sample Fraction 1	Blank Fraction 1	Sample Fraction 2	Blank Fraction 2	Sample Total	CONCENTRATION				MASS RATE (lb/hr)
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@ 7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	< 0.10	0.00	11.95	0.00	11.95	5.70	6.54	6.40	6.40E-03	2.83E-03
Cadmium	Cd	1.85	0.00			1.85	0.88	1.01	0.99	9.92E-04	4.38E-04
Lead	Pb	19.70	0.83			18.87	8.99	10.33	10.12	1.01E-02	4.47E-03

**Notes**

"<" denotes that one or more fractions were below the detection limit. Detection limits were used in cases of non-detect results.

Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U30-M29-R2**

Date	04/11/13
Start Time	11:45
End Time	13:54
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	29.87 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	273.0	273.0
Impinger 2	100.0	260.0	160.0
Impinger 3	100.0	136.0	36.0
Impinger 4	0.0	4.0	4.0
Impinger 5	100.0	100.0	0.0
Impinger 6	100.0	101.0	1.0
Impinger 7			0.0
<b>Total</b>	400.0	874.0	474.0
Silica gel (g)	250.0	273.6	23.6

**METHOD 1-4 RESULTS**

Metered Volume	79.315 dcf
Volume @ Std.Cond.	73.441 dscf
% Water	24.18 %
% Isokinetics	104.4 %
Velocity	44.98 ft/sec
Actual Flow	259755 acfm
Std. Flow	174181 scfm
Dry Std. Flow	132061 dscfm

**METHOD 3 DATA**

%O2	8.52	Md	30.02
%CO2	10.51	Ms	27.12
%CO	0.0	Ps	29.06
%N2	81.0	Fo	1.178
O2+CO2	19.0	%EA	66

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	292	-11.0	0.44	1.70	821.630	84	83
2	298	-11.0	0.45	1.70	861.484	84	83
3	305	-11.0	0.43	1.60		85	83
4	305	-11.0	0.41	1.60	861.650	86	83
5	307	-11.0	0.38	1.40	901.111	86	83
6	301	-11.0	0.43	1.60		87	83
7	306		0.43	1.60		88	84
8	306		0.40	1.50		88	84
9	307		0.38	1.40		89	84
10	307		0.34	1.30		89	85
11	306		0.45	1.70		90	85
12	306		0.44	1.70		91	85
13	306		0.41	1.60		91	85
14	306		0.41	1.60		92	85
15	306		0.34	1.30		91	86
16	304		0.43	1.60		89	87
17	304		0.44	1.60		89	87
18	306		0.41	1.60		91	88
19	306		0.34	1.50		91	88
20	306		0.35	1.30		92	89
21	307		0.43	1.60		92	89
22	307		0.43	1.60		93	90
23	307		0.41	1.60		93	90
24	307		0.39	1.50		94	90
25	306		0.37	1.40		95	91
26	304		0.40	1.50		95	91
27	304		0.44	1.60		96	91
28	304		0.44	1.60		96	91
29	304		0.39	1.40		97	92
30	304		0.34	1.30		97	92
<b>AVG.</b>	305	-11.00	0.41	1.53	79.315	89	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 3 FF OUTLET**

**SAMPLING DATA**

Run Number           **U30-M29-R2**  
 Date                    04/11/13  
 Corr. Sample Volume   73.441 dscf  
 Corr. Flowrate         132061 dscfm  
 O2 Content             8.52 %  
 CO2 Content            10.51 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Sample Fraction 1	Blank Fraction 1	Sample Fraction 2	Blank Fraction 2	Sample Total	CONCENTRATION				MASS RATE (lb/hr)
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@ 7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	< 0.10	0.00	13.31	0.00	13.31	6.40	7.31	7.18	7.18E-03	3.17E-03
Cadmium	Cd	1.76	0.00			1.76	0.85	0.97	0.95	9.50E-04	4.19E-04
Lead	Pb	24.40	0.83			23.57	11.34	12.94	12.73	1.27E-02	5.61E-03

**Notes**

"<" denotes that one or more fractions were below the detection limit. Detection limits were used in cases of non-detect results.

Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank



**Run Number**

**U30-M29-R3**

Date	04/11/13
Start Time	14:36
End Time	17:04
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9604
Meter Box dH@	2.0614
Barometric	29.85 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	196.0	196.0
Impinger 2	100.0	294.0	194.0
Impinger 3	100.0	144.0	44.0
Impinger 4	0.0	8.0	8.0
Impinger 5	100.0	106.0	6.0
Impinger 6	100.0	100.0	0.0
Impinger 7			0.0
<b>Total</b>	400.0	848.0	448.0
Silica gel (g)	250.0	266.9	16.9

**METHOD 1-4 RESULTS**

Metered Volume	77.034 dcf
Volume @ Std.Cond.	70.040 dscf
% Water	23.81 %
% Isokinetics	99.2 %
Velocity	45.01 ft/sec
Actual Flow	259953 acfm
Std. Flow	173929 scfm
Dry Std. Flow	132522 dscfm

**METHOD 3 DATA**

%O2	8.17	Md	30.03
%CO2	10.65	Ms	27.17
%CO	0.0	Ps	29.04
%N2	81.2	Fo	1.195
O2+CO2	18.8	%EA	62

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	305	-11.00	0.43	1.60	901.177	92	91
2	305	-11.00	0.44	1.60	939.704	92	91
3	305	-11.00	0.41	1.50		92	91
4	308	-11.00	0.40	1.40	939.884	93	91
5	307	-11.00	0.35	1.30	978.391	94	91
6	306	-11.00	0.42	1.50		95	92
7	306		0.43	1.50		96	92
8	307		0.40	1.40		96	93
9	307		0.40	1.40		97	93
10	304		0.35	1.30		99	98
11	304		0.44	1.60		99	98
12	308		0.45	1.60		100	98
13	306		0.44	1.60		102	99
14	306		0.40	1.40		104	99
15	306		0.34	1.20		104	99
16	306		0.40	1.40		103	102
17	307		0.45	1.60		103	102
18	307		0.44	1.60		104	103
19	306		0.41	1.40		105	103
20	306		0.36	1.30		105	103
21	306		0.43	1.50		104	103
22	306		0.43	1.50		103	102
23	306		0.40	1.40		102	101
24	306		0.39	1.40		101	100
25	305		0.36	1.30		101	99
26	306		0.42	1.50		100	99
27	305		0.43	1.50		99	99
28	305		0.40	1.40		99	98
29	306		0.38	1.30		98	97
30	306		0.36	1.30		98	97
<b>AVG.</b>	306	-11.00	0.41	1.44	77.034	98	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RRF  
UNIT 3 FF OUTLET**

**SAMPLING DATA**

Run Number           **U3O-M29-R3**  
 Date                    04/11/13  
 Corr. Sample Volume   70.040 dscf  
 Corr. Flowrate         132522 dscfm  
 O2 Content             8.17 %  
 CO2 Content            10.65 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				MASS RATE (lb/hr)
		Sample Fraction 1 (µg)	Blank Fraction 1 (µg)	Sample Fraction 2 (µg)	Blank Fraction 2 (µg)	Sample Total (µg)	CONCENTRATION				
		ACTUAL (µg/dscm)	@ 12% CO2 (µg/dscm)	@7% O2 (µg/dscm)	@ 7% O2 (mg/dscm)						
Mercury	Hg	< 0.10	0.00	11.25	0.00	11.25	5.67	6.39	6.19	6.19E-03	2.82E-03
Cadmium	Cd	1.50	0.00			1.50	0.76	0.85	0.83	8.26E-04	3.75E-04
Lead	Pb	11.90	0.83			11.07	5.58	6.29	6.10	6.10E-03	2.77E-03

**Notes**

"<" denotes that one or more fractions were below the detection limit. Detection limits were used in cases of non-detect results.

Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

## **Appendix B.6**

### **EPA Method 29 Data and Results: Unit 3 SDA Inlet**

**Run Number**

**U3I-M29-R1**

Date	04/11/13
Start Time	8:37
End Time	10:54
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	29.84 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	119.0	119.0
Impinger 2	100.0	264.0	164.0
Impinger 3	100.0	141.0	41.0
Impinger 4	0.0	12.0	12.0
Impinger 5	100.0	100.0	0.0
Impinger 6	100.0	106.0	6.0
Impinger 7			0.0
<b>Total</b>	400.0	742.0	342.0
Silica gel (g)	250.0	267.7	17.7

**METHOD 1-4 RESULTS**

Metered Volume	75.549 dcf
Volume @ Std.Cond.	72.968 dscf
% Water	18.83 %
% Isokinetics	99.2 %
Velocity	60.03 ft/sec
Actual Flow	282881 acfm
Std. Flow	138790 scfm
Dry Std. Flow	112650 dscfm

**METHOD 3 DATA**

%O2	6.79	Md	30.20
%CO2	12.05	Ms	27.90
%CO	0.0	Ps	29.74
%N2	81.2	Fo	1.171
O2+CO2	18.8	%EA	46

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	606	-1.40	0.44	1.10	976.029	73	73
2	608	-1.40	0.48	1.20	1013.419	74	73
3	609		0.52	1.40		76	73
4	610		0.51	1.30	1013.604	77	73
5	610		0.53	1.40	1051.763	78	73
6	609		0.53	1.40		77	74
7	609		0.54	1.40		78	74
8	610		0.57	1.50		78	74
9	610		0.58	1.50		78	74
10	610		0.58	1.50		78	75
11	609		0.57	1.50		78	75
12	609		0.59	1.50		78	75
13	609		0.46	1.20		75	75
14	610		0.49	1.30		77	75
15	610		0.53	1.40		78	75
16	611		0.52	1.40		78	75
17	611		0.54	1.40		78	76
18	610		0.57	1.50		78	76
19	610		0.57	1.50		77	76
20	611		0.58	1.50		78	76
21	610		0.57	1.50		78	76
22	610		0.59	1.50		78	77
23	609		0.59	1.50		78	77
24	610		0.58	1.50		78	77
<b>AVG.</b>	610	-1.40	0.54	1.41	75.549	76	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 SDA INLET**

**SAMPLING DATA**

Run Number                   **U3I-M29-R1**  
 Date                            04/11/13  
 Corr. Sample Volume        72.968 dscf  
 Corr. Sample Volume        2.066 dscm  
 Corr. Flowrate               112650 dscfm  
 O2 Content                    6.79 %  
 CO2 Content                  12.05 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Front Half Sample	Front Half Blank	Back Half Sample	Back Half Blank	Sample Total	CONCENTRATION				MASS RATE lb/hr
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	54.65	0.0000	186.012	0.00	240.66	116.47	115.99	114.74	0.115	4.91E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U3I-M29-R2**

Date	04/11/13
Start Time	11:45
End Time	13:52
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	29.87 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	88.0	88.0
Impinger 2	100.0	275.0	175.0
Impinger 3	100.0	168.0	68.0
Impinger 4	0.0	16.0	16.0
Impinger 5	100.0	106.0	6.0
Impinger 6	100.0	106.0	6.0
Impinger 7			0.0
<b>Total</b>	400.0	759.0	359.0
Silica gel (g)	250.0	272.0	22.0

**METHOD 1-4 RESULTS**

Metered Volume	75.719 dcf
Volume @ Std.Cond.	72.200 dscf
% Water	19.90 %
% Isokinetics	99.9 %
Velocity	59.66 ft/sec
Actual Flow	281147 acfm
Std. Flow	138208 scfm
Dry Std. Flow	110707 dscfm

**METHOD 3 DATA**

%O2	6.98	Md	30.15
%CO2	11.72	Ms	27.74
%CO	0.0	Ps	29.80
%N2	81.3	Fo	1.188
O2+CO2	18.7	%EA	48

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	610	-1.00	0.41	1.10	52.247	80	79
2	609	-0.98	0.45	1.20	89.952	81	79
3	610		0.49	1.30		82	79
4	609		0.51	1.30	90.229	83	79
5	610		0.52	1.40	128.243	83	80
6	611		0.54	1.40		84	80
7	612		0.54	1.40		84	80
8	611		0.56	1.50		85	81
9	610		0.58	1.60		85	81
10	610		0.58	1.60		85	82
11	610		0.59	1.60		85	82
12	609		0.58	1.60		85	82
13	610		0.43	1.20		82	82
14	610		0.47	1.30		85	83
15	609		0.50	1.40		86	84
16	609		0.52	1.40		88	84
17	608		0.55	1.50		88	84
18	608		0.56	1.50		88	84
19	609		0.57	1.50		88	85
20	609		0.58	1.60		87	85
21	610		0.58	1.60		86	85
22	610		0.57	1.50		86	84
23	610		0.57	1.50		86	84
24	609		0.58	1.60		87	84
<b>AVG.</b>	610	-0.99	0.53	1.44	75.719	84	

**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 SDA INLET**

**SAMPLING DATA**

Run Number                    **U3I-M29-R2**  
 Date                            04/11/13  
 Corr. Sample Volume        72.200 dscf  
 Corr. Sample Volume        2.044 dscm  
 Corr. Flowrate                110707 dscfm  
 O2 Content                    6.98 %  
 CO2 Content                  11.72 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Front Half Sample (µg)	Front Half Blank (µg)	Back Half Sample (µg)	Back Half Blank (µg)	Sample Total (µg)	CONCENTRATION				MASS RATE lb/hr
							ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	61.80	0.0000	49.14	0.00	110.94	54.26	55.56	54.18	0.054	2.25E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

**Run Number**

**U3I-M29-R3**

Date	04/11/13
Start Time	14:36
End Time	17:02
Stack Diameter	120 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	0.9798
Meter Box dH@	1.8708
Barometric	29.85 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	138.0	138.0
Impinger 2	100.0	248.0	148.0
Impinger 3	100.0	135.0	35.0
Impinger 4	0.0	9.0	9.0
Impinger 5	100.0	109.0	9.0
Impinger 6	100.0	101.0	1.0
Impinger 7			0.0
<b>Total</b>	400.0	740.0	340.0
Silica gel (g)	250.0	269.2	19.2

**METHOD 1-4 RESULTS**

Metered Volume	77.573 dcf
Volume @ Std.Cond.	73.067 dscf
% Water	18.79 %
% Isokinetics	100.0 %
Velocity	59.55 ft/sec
Actual Flow	280616 acfm
Std. Flow	137850 scfm
Dry Std. Flow	111944 dscfm

**METHOD 3 DATA**

%O2	7.11	Md	30.12
%CO2	11.49	Ms	27.84
%CO	0.0	Ps	29.77
%N2	81.4	Fo	1.200
O2+CO2	18.6	%EA	49

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	609	-1.00	0.42	1.10	129.249	87	86
2	610	-1.10	0.46	1.20	167.915	89	87
3	610		0.49	1.30		90	87
4	610		0.52	1.40	168.242	92	87
5	609		0.53	1.40	207.149	93	88
6	610		0.53	1.40		93	88
7	609		0.55	1.50		93	89
8	609		0.56	1.50		93	91
9	610		0.59	1.60		94	90
10	610		0.58	1.60		94	91
11	610		0.58	1.60		92	90
12	610		0.59	1.60		91	89
13	609		0.44	1.20		87	87
14	609		0.47	1.30		90	87
15	609		0.49	1.30		92	88
16	610		0.51	1.40		93	89
17	610		0.53	1.40		93	91
18	609		0.53	1.40		93	91
19	609		0.56	1.50		92	91
20	609		0.57	1.50		91	90
21	610		0.58	1.60		90	89
22	610		0.58	1.60		89	88
23	609		0.57	1.50		87	88
24	610		0.59	1.60		87	88
<b>AVG.</b>	610	-1.05	0.53	1.44	77.573	90	



**EPA Method 29: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 SDA INLET**

**SAMPLING DATA**

Run Number                    **U3I-M29-R3**  
 Date                            04/11/13  
 Corr. Sample Volume        73.067 dscf  
 Corr. Sample Volume        2.069 dscm  
 Corr. Flowrate                111944 dscfm  
 O2 Content                    7.11 %  
 CO2 Content                  11.49 %

**TRACE METALS ANALYTICAL DATA AND RESULTS**

COMPONENT		LABORATORY DATA					METALS EMISSIONS				
		Front Half Sample	Front Half Blank	Back Half Sample	Back Half Blank	Sample Total	CONCENTRATION				MASS RATE lb/hr
		(µg)	(µg)	(µg)	(µg)	(µg)	ACTUAL (ug/dscm)	@ 12% CO2 (ug/dscm)	@7% O2 (ug/dscm)	@ 7% O2 (mg/dscm)	
Mercury	Hg	8.15	0.0000	57.162	0.00	65.31	31.56	32.96	31.82	0.032	1.32E-02

**Notes**

-----  
 Front Half = Probe Wash and Filter  
 Back Half = Impinger Catch  
 Blank = Field Blank

## **Appendix C**

### **EPA Methods 5 and 26A Data and Results**

## **Appendix C.1**

### **EPA Method 5/26A Data and Results: Unit 1 FF Outlet**

**Run Number U10-M26A-R1**

Date	04/09/13
Start Time	9:05
End Time	11:28
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	30.02 in.Hg
Cp	0.84
Test Duration	120 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	302.0	252.0
Impinger 2	100.0	250.0	150.0
Impinger 3	100.0	118.0	18.0
Impinger 4	100.0	97.0	-3.0
Impinger 5	100.0	102.0	2.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	<b>450.0</b>	<b>869.0</b>	<b>419.0</b>
Silica gel (g)	250.0	272.5	22.5

METHOD 1-4 RESULTS	
Metered Volume	77.124 dcf
Volume @ Std.Cond.	77.672 dscf
% Water	21.11 %
% Isokinetics	106.3 %
Velocity	45.20 ft/sec
Actual Flow	261018 acfm
Std. Flow	173851 scfm
Dry Std. Flow	137153 dscfm

METHOD 3 DATA			
%O2	9.56	Md	29.92
%CO2	9.62	Ms	27.41
%CO	0.0	Ps	29.24
%N2	80.8	Fo	1.179
O2+CO2	19.2	%EA	81

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	313	-10.0	0.33	1.10	176.584	74	77
2	314	-11.0	0.33	1.10	214.945	75	77
3	313	-10.0	0.45	1.50		76	77
4	313	-10.0	0.45	1.50	215.157	76	77
5	315	-11.0	0.40	1.30	253.920	76	77
6	312	-12.0	0.35	1.20		78	77
7	314		0.37	1.20		81	80
8	312		0.42	1.40		81	80
9	313		0.42	1.40		82	81
10	312		0.40	1.30		84	82
11	315		0.40	1.30		83	83
12	314		0.42	1.40		84	83
13	314		0.45	1.50		84	82
14	313		0.43	1.40		84	82
15	312		0.42	1.40		85	82
16	313		0.43	1.40		82	83
17	315		0.44	1.50		82	84
18	316		0.44	1.50		82	81
19	315		0.42	1.40		79	79
20	315		0.42	1.40		79	78
21	316		0.41	1.40		77	76
22	315		0.42	1.40		77	76
23	315		0.42	1.40		78	77
24	317		0.43	1.40		77	76
25	315		0.40	1.50		77	76
26	312		0.40	1.30		77	75
27	317		0.40	1.30		79	76
28	318		0.42	1.40		80	76
29	320		0.42	1.40		78	75
30	320		0.40	1.30		80	76
<b>AVG.</b>	<b>315</b>	<b>-10.67</b>	<b>0.41</b>	<b>1.37</b>	<b>77.124</b>	<b>79</b>	

## EPA Method 26A: Gravimetric Data and Results

---

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 1 FF OUTLET

---

#### SAMPLING DATA

Run Number	<b>U10-M26A-R1</b>
Corr. Sample Volume	77.672 dscf
Corr. Sample Volume	2.199 dscm
Corr. Flowrate	137153 dscfm
O2 Content	9.6 %
CO2 Content	9.6 %

---

#### ANALYTICAL DATA

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	801	65.2035	65.2145	0.01100	100.0
Corr. for Blank				0.01100	
Filter	800	0.3703	0.3729	0.00260	
<b>TOTAL</b>				0.01360	

---

#### Acetone Blank

Actual Residue	0.00000 grams
Applicable Blank Corr.	0.00000 grams
Max Allowable Residue	0.00078 grams
Blank used	0.00000 grams
Volume	150.0 ml

---

#### PARTICULATE LOADING

Actual Grain Loading	0.00270 gr/dscf
Corrected to 7% O2	0.00331 gr/dscf @ 7% O2
Actual Loading	6.18338 mg/dscm
Corrected to 7% O2	7.57927 mg/dscm @ 7% O2
Corrected to 12% CO2	7.71315 mg/dscm @ 12% CO2
Corrected to 50% Excess Air	7.46865 mg/dscm @ 50% EA
Mass Rate	3.1766 lb/hr

---

## EPA Method 26A: Analytical Data and Results

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 1 FF OUTLET

#### SAMPLING DATA

Run Number	<b>U10-M26A-R1</b>
Date	04/09/13
Corr. Sample Volume	77.672 dscf
Corr. Flowrate	137153 dscfm
O2 Content	9.6 %
CO2 Content	9.6 %

#### LABORATORY DATA

	IMPINGERS 1 - 3	H <sub>2</sub> SO <sub>4</sub> BLANK
Sample ID	802	838
<i>CHLORIDE LABORATORY DATA</i> HCl in Sample (mg)	20.30	< 0.115

#### POLLUTANT EMISSIONS

Pollutant	Concentration (ppmdv)	Concentration (ppmdv @7% O2)	Mass Rate (lb/hr)
HCl	6.09	7.46	4.74

#### Notes

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.

**Run Number**

**U10-M26A-R2**

Date	04/09/13
Start Time	13:24
End Time	15:36
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	30.04 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	290.0	240.0
Impinger 2	100.0	246.0	146.0
Impinger 3	100.0	128.0	28.0
Impinger 4	100.0	102.0	2.0
Impinger 5	100.0	100.0	0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	<b>450.0</b>	<b>866.0</b>	<b>416.0</b>
Silica gel (g)	250.0	273.5	23.5

**METHOD 1-4 RESULTS**

Metered Volume	78.945 dcf
Volume @ Std.Cond.	79.278 dscf
% Water	20.70 %
% Isokinetics	104.3 %
Velocity	46.80 ft/sec
Actual Flow	270271 acfm
Std. Flow	179884 scfm
Dry Std. Flow	142655 dscfm

**METHOD 3 DATA**

%O2	10.22	Md	29.86
%CO2	9.10	Ms	27.41
%CO	0.0	Ps	29.24
%N2	80.7	Fo	1.174
O2+CO2	19.3	%EA	92

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	315	-10.0	0.43	1.30	254.215	79	81
2	315	-12.0	0.43	1.30	293.353	80	81
3	315	-10.0	0.42	1.30		80	80
4	315	-11.0	0.42	1.30	293.480	81	80
5	313	-11.0	0.44	1.40	333.287	81	80
6	312	-11.0	0.44	1.40		82	80
7	314		0.46	1.40		82	80
8	313		0.45	1.40		82	80
9	316		0.46	1.40		82	80
10	330		0.45	1.40		83	81
11	320		0.43	1.30		83	82
12	320		0.43	1.30		83	82
13	318		0.43	1.30		83	83
14	318		0.42	1.30		83	82
15	320		0.42	1.30		82	81
16	315		0.45	1.40		82	81
17	314		0.46	1.40		82	81
18	315		0.46	1.40		82	81
19	313		0.45	1.40		82	81
20	313		0.45	1.40		82	81
21	313		0.40	1.30		81	80
22	314		0.40	1.30		81	80
23	313		0.41	1.30		81	79
24	314		0.43	1.30		81	79
25	315		0.43	1.30		83	80
26	312		0.47	1.50		81	80
27	313		0.49	1.50		81	80
28	313		0.49	1.50		81	79
29	316		0.43	1.30		81	79
30	314		0.43	1.30		81	80
<b>AVG.</b>	<b>315</b>	<b>-10.83</b>	<b>0.44</b>	<b>1.36</b>	<b>78.945</b>	<b>81</b>	

---

---

**EPA Method 26A: Gravimetric Data and Results**

---

---

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 FF OUTLET**

---

**SAMPLING DATA**

Run Number	<b>U10-M26A-R2</b>
Corr. Sample Volume	79.278 dscf
Corr. Sample Volume	2.245 dscm
Corr. Flowrate	142655 dscfm
O2 Content	10.2 %
CO2 Content	9.1 %

---

**ANALYTICAL DATA**

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	805	65.9841	66.0004	0.01630	105.0
Corr. for Blank				0.01630	
Filter	804	0.3702	0.3721	0.00190	
<b>TOTAL</b>				0.01820	

---

**Acetone Blank**

Actual Residue	0.00000 grams
Applicable Blank Corr.	0.00000 grams
Max Allowable Residue	0.00082 grams
Blank used	0.00000 grams
Volume	150.0 ml

---

**PARTICULATE LOADING**

Actual Grain Loading	0.00354 gr/dscf
Corrected to 7% O2	0.00461 gr/dscf @ 7% O2
Actual Loading	8.10725 mg/dscm
Corrected to 7% O2	10.55157 mg/dscm @ 7% O2
Corrected to 12% CO2	10.69088 mg/dscm @ 12% CO2
Corrected to 50% Excess Air	9.79241 mg/dscm @ 50% EA
Mass Rate	4.3320 lb/hr

---

---



## EPA Method 26A: Analytical Data and Results

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 1 FF OUTLET

#### SAMPLING DATA

Run Number	<b>U10-M26A-R2</b>
Date	04/09/13
Corr. Sample Volume	79.278 dscf
Corr. Flowrate	142655 dscfm
O2 Content	10.2 %
CO2 Content	9.1 %

#### LABORATORY DATA

	IMPINGERS 1 - 3	H <sub>2</sub> SO <sub>4</sub> BLANK
Sample ID	806	838
<i>CHLORIDE LABORATORY DATA</i> HCl in Sample (mg)	27.50	< 0.115

#### POLLUTANT EMISSIONS

Pollutant	Concentration (ppmdv)	Concentration (ppmdv @7% O2)	Mass Rate (lb/hr)
HCl	8.08	10.52	6.55

#### Notes

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.

**Run Number**

**U1O-M26A-R3**

Date	04/09/13
Start Time	16:22
End Time	18:33
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	30.04 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	328.0	278.0
Impinger 2	100.0	246.0	146.0
Impinger 3	100.0	116.0	16.0
Impinger 4	100.0	100.0	0.0
Impinger 5	100.0	100.0	0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	<b>450.0</b>	<b>890.0</b>	<b>440.0</b>
Silica gel (g)	250.0	267.4	17.4

**METHOD 1-4 RESULTS**

Metered Volume	79.906 dcf
Volume @ Std.Cond.	80.330 dscf
% Water	21.14 %
% Isokinetics	105.4 %
Velocity	47.25 ft/sec
Actual Flow	272882 acfm
Std. Flow	181302 scfm
Dry Std. Flow	142979 dscfm

**METHOD 3 DATA**

%O2	10.24	Md	29.85
%CO2	9.01	Ms	27.35
%CO	0.0	Ps	29.24
%N2	80.8	Fo	1.183
O2+CO2	19.3	%EA	92

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	314	-11.0	0.40	1.20	334.140	80	78
2	314	-10.0	0.45	1.40	374.000	81	79
3	314	-10.0	0.45	1.40		80	79
4	316	-12.0	0.44	1.30	374.348	81	80
5	318	-11.0	0.49	1.50	414.394	81	80
6	315	-11.0	0.40	1.20		82	80
7	318		0.43	1.30		82	80
8	318		0.43	1.30		82	80
9	319		0.47	1.40		81	79
10	317		0.45	1.40		81	79
11	317		0.42	1.30		81	78
12	318		0.46	1.40		81	79
13	317		0.46	1.40		81	79
14	317		0.45	1.40		82	78
15	318		0.46	1.40		82	79
16	315		0.43	1.30		80	78
17	316		0.43	1.30		80	79
18	315		0.46	1.40		80	79
19	315		0.47	1.40		80	79
20	317		0.45	1.40		81	79
21	316		0.43	1.30		82	79
22	315		0.43	1.30		82	80
23	319		0.45	1.40		82	80
24	319		0.45	1.40		83	80
25	318		0.46	1.40		83	80
26	317		0.46	1.40		83	81
27	317		0.46	1.40		83	81
28	316		0.45	1.40		83	81
29	318		0.47	1.40		82	80
30	319		0.42	1.30		82	80
<b>AVG.</b>	<b>317</b>	<b>-10.83</b>	<b>0.45</b>	<b>1.36</b>	<b>79.906</b>	<b>80</b>	

**EPA Method 26A: Gravimetric Data and Results**

---

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 FF OUTLET**

---

**SAMPLING DATA**

Run Number	<b>U10-M26A-R3</b>
Corr. Sample Volume	80.330 dscf
Corr. Sample Volume	2.275 dscm
Corr. Flowrate	142979 dscfm
O2 Content	10.2 %
CO2 Content	9.0 %

---

**ANALYTICAL DATA**

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	809	66.0690	66.0807	0.01170	105.0
Corr. for Blank				0.01170	
Filter	808	0.3663	0.3695	0.00320	
<b>TOTAL</b>				0.01490	

---

**Acetone Blank**

Actual Residue	0.00000 grams
Applicable Blank Corr.	0.00000 grams
Max Allowable Residue	0.00082 grams
Blank used	0.00000 grams
Volume	150.0 ml

---

**PARTICULATE LOADING**

Actual Grain Loading	0.00286 gr/dscf
Corrected to 7% O2	0.00373 gr/dscf @ 7% O2
Actual Loading	6.55030 mg/dscm
Corrected to 7% O2	8.54120 mg/dscm @ 7% O2
Corrected to 12% CO2	8.72405 mg/dscm @ 12% CO2
Corrected to 50% Excess Air	7.91184 mg/dscm @ 50% EA
Mass Rate	3.5080 lb/hr

---

**EPA Method 26A: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 FF OUTLET**

**SAMPLING DATA**

Run Number	<b>U10-M26A-R3</b>
Date	04/09/13
Corr. Sample Volume	80.330 dscf
Corr. Flowrate	142979 dscfm
O2 Content	10.2 %
CO2 Content	9.0 %

**LABORATORY DATA**

	<b>IMPINGERS 1 - 3</b>	<b>H<sub>2</sub>SO<sub>4</sub> BLANK</b>
Sample ID	810	838
<i>CHLORIDE LABORATORY DATA</i> HCl in Sample (mg)	33.80	< 0.115

**POLLUTANT EMISSIONS**

<b>Pollutant</b>	<b>Concentration (ppmdv)</b>	<b>Concentration (ppmdv @7% O2)</b>	<b>Mass Rate (lb/hr)</b>
HCl	9.80	12.78	7.96

**Notes**

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.

## **Appendix C.2**

### **EPA Method 5/26A Data and Results: Unit 2 FF Outlet**

**Run Number U2O-M26A-R1**

Date	04/10/13
Start Time	8:45
End Time	11:15
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	29.99 in.Hg
Cp	0.84
Test Duration	120 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	255.0	205.0
Impinger 2	100.0	205.0	105.0
Impinger 3	100.0	113.0	13.0
Impinger 4	100.0	100.0	0.0
Impinger 5	100.0	100.0	0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	450.0	773.0	323.0
Silica gel (g)	250.0	269.8	19.8

METHOD 1-4 RESULTS	
Metered Volume	77.049 dcf
Volume @ Std.Cond.	78.551 dscf
% Water	17.04 %
% Isokinetics	99.0 %
Velocity	45.61 ft/sec
Actual Flow	263408 acfm
Std. Flow	179567 scfm
Dry Std. Flow	148964 dscfm

METHOD 3 DATA			
%O2	10.74	Md	29.79
%CO2	8.52	Ms	27.78
%CO	0.0	Ps	29.16
%N2	80.7	Fo	1.192
O2+CO2	19.3	%EA	102

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	295	-11.0	0.35	1.10	451.437	67	64
2	298	-12.0	0.40	1.30	489.540	69	65
3	298	-11.0	0.40	1.30		69	65
4	295	-11.0	0.40	1.30	489.742	69	65
5	295	-12.0	0.42	1.30	528.688	71	66
6	298	-11.0	0.43	1.30		71	66
7	293		0.49	1.50		72	68
8	293		0.48	1.50		73	67
9	299		0.48	1.50		73	67
10	297		0.47	1.50		74	68
11	295		0.45	1.40		73	69
12	295		0.45	1.40		73	70
13	298		0.45	1.40		73	71
14	295		0.49	1.50		73	69
15	293		0.49	1.50		74	70
16	295		0.48	1.50		73	70
17	295		0.49	1.50		74	71
18	295		0.47	1.50		74	71
19	296		0.47	1.50		74	71
20	299		0.44	1.40		75	71
21	290		0.47	1.50		76	70
22	291		0.47	1.50		75	72
23	293		0.46	1.40		76	71
24	294		0.47	1.50		78	73
25	295		0.34	1.10		78	73
26	294		0.36	1.10		80	74
27	290		0.32	1.00		80	75
28	293		0.42	1.30		80	74
29	295		0.42	1.30		81	74
30	291		0.31	1.00		81	74
<b>AVG.</b>	295	-11.33	0.43	1.36	77.049	72	

---

---

**EPA Method 26A: Gravimetric Data and Results**

---

---

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 FF OUTLET**

---

**SAMPLING DATA**

Run Number	<b>U2O-M26A-R1</b>
Corr. Sample Volume	78.551 dscf
Corr. Sample Volume	2.224 dscm
Corr. Flowrate	148964 dscfm
O2 Content	10.7 %
CO2 Content	8.5 %

---

**ANALYTICAL DATA**

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	813	66.3244	66.3375	0.01310	100.0
Corr. for Blank				0.01310	
Filter	812	0.3813	0.3826	0.00130	
<b>TOTAL</b>				0.01440	

---

**Acetone Blank**

Actual Residue	0.00000 grams
Applicable Blank Corr.	0.00000 grams
Max Allowable Residue	0.00078 grams
Blank used	0.00000 grams
Volume	150.0 ml

---

**PARTICULATE LOADING**

Actual Grain Loading	0.00283 gr/dscf
Corrected to 7% O2	0.00387 gr/dscf @ 7% O2
Actual Loading	6.47388 mg/dscm
Corrected to 7% O2	8.85698 mg/dscm @ 7% O2
Corrected to 12% CO2	9.11814 mg/dscm @ 12% CO2
Corrected to 50% Excess Air	8.69903 mg/dscm @ 50% EA
Mass Rate	3.6123 lb/hr

---

---

**EPA Method 26A: Analytical Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 FF OUTLET**

**SAMPLING DATA**

Run Number	<b>U2O-M26A-R1</b>
Date	04/10/13
Corr. Sample Volume	78.551 dscf
Corr. Flowrate	148964 dscfm
O2 Content	10.7 %
CO2 Content	8.5 %

**LABORATORY DATA**

	<b>IMPINGERS 1 - 3</b>	<b>H<sub>2</sub>SO<sub>4</sub> BLANK</b>
Sample ID	814	838
<i>CHLORIDE LABORATORY DATA</i>		
HCl in Sample (mg)	24.1	< 0.115

**POLLUTANT EMISSIONS**

<b>Pollutant</b>	<b>Concentration (ppmdv)</b>	<b>Concentration (ppmdv @7% O2)</b>	<b>Mass Rate (lb/hr)</b>
HCl	7.15	9.78	6.05

**Notes**

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.



**Run Number U2O-M26A-R2**

Date	04/10/13
Start Time	12:09
End Time	14:28
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	29.98 in.Hg
Cp	0.84
Test Duration	120 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	272.0	222.0
Impinger 2	100.0	214.0	114.0
Impinger 3	100.0	114.0	14.0
Impinger 4	100.0	100.0	0.0
Impinger 5	100.0	100.0	0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	<b>450.0</b>	<b>800.0</b>	<b>350.0</b>
Silica gel (g)	250.0	277.5	27.5

METHOD 1-4 RESULTS	
Metered Volume	80.575 dcf
Volume @ Std.Cond.	80.408 dscf
% Water	18.10 %
% Isokinetics	101.1 %
Velocity	46.38 ft/sec
Actual Flow	267842 acfm
Std. Flow	182263 scfm
Dry Std. Flow	149272 dscfm

METHOD 3 DATA			
%O2	10.93	Md	29.78
%CO2	8.42	Ms	27.65
%CO	0.0	Ps	29.20
%N2	80.7	Fo	1.184
O2+CO2	19.4	%EA	105

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	297	-11.0	0.33	1.00	530.465	80	76
2	298	-10.0	0.45	1.40	570.850	80	79
3	298	-11.0	0.45	1.40		80	79
4	299	-11.0	0.49	1.50	570.960	80	78
5	298	-10.0	0.49	1.50	611.150	80	78
6	295	-11.0	0.48	1.50		81	78
7	296		0.49	1.50		82	79
8	299		0.49	1.50		83	79
9	297		0.47	1.50		83	79
10	294		0.35	1.10		83	79
11	292		0.49	1.50		84	80
12	296		0.49	1.50		85	78
13	295		0.47	1.50		85	79
14	293		0.46	1.40		85	79
15	297		0.35	1.10		86	78
16	296		0.49	1.50		86	81
17	298		0.49	1.50		86	82
18	297		0.48	1.50		86	82
19	298		0.47	1.50		87	81
20	298		0.33	1.00		86	82
21	299		0.50	1.60		87	82
22	301		0.48	1.50		88	82
23	300		0.49	1.50		89	83
24	298		0.42	1.30		89	84
25	297		0.37	1.20		90	84
26	298		0.49	1.50		92	86
27	298		0.48	1.50		93	86
28	299		0.41	1.30		93	86
29	297		0.41	1.30		93	85
30	296		0.34	1.10		93	85
<b>AVG.</b>	<b>297</b>	<b>-10.67</b>	<b>0.45</b>	<b>1.39</b>	<b>80.575</b>	<b>83</b>	

**EPA Method 26A: Gravimetric Data and Results**

---

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 FF OUTLET**

---

**SAMPLING DATA**

Run Number **U2O-M26A-R2**  
Corr. Sample Volume 80.408 dscf  
Corr. Sample Volume 2.277 dscm  
Corr. Flowrate 149272 dscfm  
O2 Content 10.9 %  
CO2 Content 8.4 %

---

**ANALYTICAL DATA**

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	817	65.3171	65.3230	0.00590	100.0
Corr. for Blank				0.00590	
Filter	816	0.4354	0.4436	0.00820	
<b>TOTAL</b>				0.01410	

---

**Acetone Blank**

Actual Residue 0.00000 grams  
Applicable Blank Corr. 0.00000 grams  
Max Allowable Residue 0.00078 grams  
Blank used 0.00000 grams  
Volume 150.0 ml

---

**PARTICULATE LOADING**

Actual Grain Loading 0.00271 gr/dscf  
Corrected to 7% O2 0.00377 gr/dscf @ 7% O2  
Actual Loading 6.19257 mg/dscm  
Corrected to 7% O2 8.63358 mg/dscm @ 7% O2  
Corrected to 12% CO2 8.82552 mg/dscm @ 12% CO2  
Corrected to 50% Excess Air 8.32104 mg/dscm @ 50% EA  
  
Mass Rate 3.4624 lb/hr

---

## EPA Method 26A: Analytical Data and Results

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 2 FF OUTLET

#### SAMPLING DATA

Run Number	<b>U2O-M26A-R2</b>
Date	04/10/13
Corr. Sample Volume	80.408 dscf
Corr. Flowrate	149272 dscfm
O2 Content	10.9 %
CO2 Content	8.4 %

#### LABORATORY DATA

	IMPINGERS 1 - 3	H <sub>2</sub> SO <sub>4</sub> BLANK
Sample ID	818	838
<i>CHLORIDE LABORATORY DATA</i> HCl in Sample (mg)	19.9	< 0.115

#### POLLUTANT EMISSIONS

Pollutant	Concentration (ppmdv)	Concentration (ppmdv @7% O2)	Mass Rate (lb/hr)
HCl	5.77	8.04	4.89

#### Notes

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.

**Run Number U2O-M26A-R3**

Date	04/10/13
Start Time	15:25
End Time	17:35
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	29.95 in.Hg
Cp	0.84
Test Duration	120 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	183.0	133.0
Impinger 2	100.0	234.0	134.0
Impinger 3	100.0	128.0	28.0
Impinger 4	100.0	108.0	8.0
Impinger 5	100.0	104.0	4.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	<b>450.0</b>	<b>757.0</b>	<b>307.0</b>
Silica gel (g)	250.0	274.6	24.6

METHOD 1-4 RESULTS	
Metered Volume	79.840 dcf
Volume @ Std.Cond.	77.948 dscf
% Water	16.69 %
% Isokinetics	97.3 %
Velocity	45.87 ft/sec
Actual Flow	264906 acfm
Std. Flow	180468 scfm
Dry Std. Flow	150357 dscfm

METHOD 3 DATA			
%O2	11.63	Md	29.70
%CO2	7.72	Ms	27.75
%CO	0.0	Ps	29.17
%N2	80.7	Fo	1.201
O2+CO2	19.4	%EA	120

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	293	-10.0	0.49	1.50	611.600	94	90
2	298	-12.0	0.48	1.50	651.425	94	90
3	297	-11.0	0.42	1.30		96	91
4	295	-11.0	0.42	1.30	651.550	96	91
5	296	-10.0	0.32	1.00	691.565	96	91
6	293	-10.0	0.47	1.50		98	92
7	293		0.47	1.50		99	92
8	295		0.48	1.50		100	92
9	296		0.40	1.20		100	93
10	294		0.36	1.10		100	93
11	298		0.49	1.50		102	95
12	296		0.49	1.50		100	94
13	297		0.48	1.50		100	95
14	299		0.44	1.40		96	92
15	297		0.37	1.20		96	92
16	293		0.47	1.50		94	89
17	293		0.46	1.40		94	90
18	295		0.45	1.40		95	89
19	292		0.45	1.40		95	88
20	292		0.38	1.20		95	88
21	300		0.49	1.50		96	90
22	300		0.49	1.50		98	91
23	298		0.47	1.50		100	92
24	295		0.43	1.30		101	93
25	295		0.37	1.20		101	94
26	295		0.45	1.40		99	95
27	298		0.45	1.40		99	95
28	294		0.42	1.30		98	94
29	295		0.40	1.20		99	94
30	293		0.39	1.20		99	96
<b>AVG.</b>	<b>296</b>	<b>-10.67</b>	<b>0.44</b>	<b>1.36</b>	<b>79.840</b>	<b>95</b>	

## EPA Method 26A: Gravimetric Data and Results

---

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 2 FF OUTLET

---

#### SAMPLING DATA

Run Number **U2O-M26A-R3**  
Corr. Sample Volume 77.948 dscf  
Corr. Sample Volume 2.207 dscm  
Corr. Flowrate 150357 dscfm  
O2 Content 11.6 %  
CO2 Content 7.7 %

---

#### ANALYTICAL DATA

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	821	68.9617	68.9760	0.01430	140.0
Corr. for Blank				0.01430	
Filter	820	0.3649	0.3661	0.00120	
<b>TOTAL</b>				0.01550	

---

#### Acetone Blank

Actual Residue 0.00000 grams  
Applicable Blank Corr. 0.00000 grams  
Max Allowable Residue 0.00110 grams  
Blank used 0.00000 grams  
Volume 150.0 ml

---

#### PARTICULATE LOADING

Actual Grain Loading 0.00307 gr/dscf  
Corrected to 7% O2 0.00460 gr/dscf @ 7% O2  
Actual Loading 7.02233 mg/dscm  
Corrected to 7% O2 10.52970 mg/dscm @ 7% O2  
Corrected to 12% CO2 10.91554 mg/dscm @ 12% CO2  
Corrected to 50% Excess Air 9.43599 mg/dscm @ 50% EA  
  
Mass Rate 3.9549 lb/hr

---

## EPA Method 26A: Analytical Data and Results

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 2 FF OUTLET

#### SAMPLING DATA

Run Number	<b>U2O-M26A-R3</b>
Date	04/10/13
Corr. Sample Volume	77.948 dscf
Corr. Flowrate	150357 dscfm
O2 Content	11.6 %
CO2 Content	7.7 %

#### LABORATORY DATA

	IMPINGERS 1 - 3	H <sub>2</sub> SO <sub>4</sub> BLANK
Sample ID	822	838
<i>CHLORIDE LABORATORY DATA</i> HCl in Sample (mg)	22.8	< 0.115

#### POLLUTANT EMISSIONS

Pollutant	Concentration (ppmdv)	Concentration (ppmdv @7% O2)	Mass Rate (lb/hr)
HCl	6.81	10.22	5.82

#### Notes

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.

## **Appendix C.3**

### **EPA Method 5/26A Data and Results: Unit 3 FF Outlet**

**Run Number U3O-M26A-R1**

Date	04/11/13
Start Time	8:37
End Time	10:56
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	29.84 in.Hg
Cp	0.84
Test Duration	120 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	305.0	255.0
Impinger 2	100.0	263.0	163.0
Impinger 3	100.0	121.0	21.0
Impinger 4	100.0	100.0	0.0
Impinger 5	100.0	104.0	4.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	450.0	893.0	443.0
Silica gel (g)	250.0	282.2	32.2

METHOD 1-4 RESULTS	
Metered Volume	76.592 dcf
Volume @ Std.Cond.	77.227 dscf
% Water	22.46 %
% Isokinetics	107.0 %
Velocity	45.17 ft/sec
Actual Flow	260836 acfm
Std. Flow	174680 scfm
Dry Std. Flow	135446 dscfm

METHOD 3 DATA			
%O2	8.33	Md	30.04
%CO2	10.67	Ms	27.34
%CO	0.0	Ps	29.07
%N2	81.0	Fo	1.178
O2+CO2	19.0	%EA	64

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	303	-11.0	0.45	1.40	725.336	74	70
2	305	-10.0	0.40	1.20	763.808	71	69
3	310	-10.0	0.42	1.30		72	70
4	311	-11.0	0.43	1.30	765.030	72	70
5	308	-11.0	0.34	1.10	803.150	72	69
6	318	-10.0	0.46	1.40		73	70
7	313		0.41	1.30		75	71
8	315		0.41	1.30		75	71
9	305		0.41	1.30		75	71
10	302		0.35	1.10		76	71
11	304		0.44	1.40		76	73
12	305		0.44	1.40		76	73
13	305		0.43	1.30		77	72
14	306		0.40	1.20		78	73
15	304		0.33	1.00		78	74
16	305		0.45	1.40		77	74
17	303		0.45	1.40		77	75
18	304		0.44	1.40		78	75
19	305		0.41	1.30		79	76
20	306		0.36	1.10		78	75
21	305		0.43	1.30		79	75
22	306		0.43	1.30		79	75
23	305		0.42	1.30		80	76
24	303		0.41	1.30		79	76
25	303		0.32	1.00		79	76
26	301		0.45	1.40		80	76
27	303		0.45	1.40		80	76
28	306		0.42	1.30		81	77
29	306		0.43	1.30		81	77
30	304		0.35	1.10		80	77
<b>AVG.</b>	306	-10.50	0.41	1.28	76.592	75	



## EPA Method 26A: Gravimetric Data and Results

---

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 3 FF OUTLET

---

#### SAMPLING DATA

Run Number **U30-M26A-R1**  
Corr. Sample Volume 77.227 dscf  
Corr. Sample Volume 2.187 dscm  
Corr. Flowrate 135446 dscfm  
O2 Content 8.3 %  
CO2 Content 10.7 %

---

#### ANALYTICAL DATA

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	825	67.1311	67.1468	0.01570	190.0
Corr. for Blank				0.01570	
Filter	824	0.3696	0.3706	0.00100	
<b>TOTAL</b>				0.01670	

---

#### Acetone Blank

Actual Residue 0.00000 grams  
Applicable Blank Corr. 0.00000 grams  
Max Allowable Residue 0.00149 grams  
Blank used 0.00000 grams  
Volume 150.0 ml

---

#### PARTICULATE LOADING

Actual Grain Loading 0.00334 gr/dscf  
Corrected to 7% O2 0.00369 gr/dscf @ 7% O2  
Actual Loading 7.63663 mg/dscm  
Corrected to 7% O2 8.44464 mg/dscm @ 7% O2  
Corrected to 12% CO2 8.58852 mg/dscm @ 12% CO2  
Corrected to 50% Excess Air 8.33980 mg/dscm @ 50% EA  
  
Mass Rate 3.8744 lb/hr

---

---

## EPA Method 26A: Analytical Data and Results

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 3 FF OUTLET

#### SAMPLING DATA

Run Number	<b>U3O-M26A-R1</b>
Date	04/11/13
Corr. Sample Volume	77.227 dscf
Corr. Flowrate	135446 dscfm
O2 Content	8.3 %
CO2 Content	10.7 %

#### LABORATORY DATA

	IMPINGERS 1 - 3	H <sub>2</sub> SO <sub>4</sub> BLANK
Sample ID	826	838
<i>CHLORIDE LABORATORY DATA</i>		
HCl in Sample (mg)	63.9	< 0.115

#### POLLUTANT EMISSIONS

Pollutant	Concentration (ppmdv)	Concentration (ppmdv @7% O2)	Mass Rate (lb/hr)
HCl	19.28	21.32	14.82

#### Notes

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.

**Run Number U3O-M26A-R2**

Date	04/11/13
Start Time	11:45
End Time	13:54
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	29.87 in.Hg
Cp	0.84
Test Duration	120 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	336.0	286.0
Impinger 2	100.0	243.0	143.0
Impinger 3	100.0	152.0	52.0
Impinger 4	100.0	106.0	6.0
Impinger 5	100.0	102.0	2.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	450.0	939.0	489.0
Silica gel (g)	250.0	272.6	22.6

METHOD 1-4 RESULTS	
Metered Volume	78.278 dcf
Volume @ Std.Cond.	77.678 dscf
% Water	23.67 %
% Isokinetics	107.8 %
Velocity	45.55 ft/sec
Actual Flow	263026 acfm
Std. Flow	177227 scfm
Dry Std. Flow	135284 dscfm

METHOD 3 DATA			
%O2	7.83	Md	30.10
%CO2	11.15	Ms	27.23
%CO	0.0	Ps	29.09
%N2	81.0	Fo	1.172
O2+CO2	19.0	%EA	58

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	303	-11.0	0.46	1.40	803.450	81	80
2	303	-11.0	0.46	1.40	842.425	81	80
3	300	-10.0	0.44	1.40		81	80
4	301	-11.0	0.40	1.20	842.627	81	81
5	302	-10.0	0.36	1.10	881.930	82	81
6	301	-11.0	0.43	1.30		82	80
7	303		0.43	1.30		83	80
8	301		0.43	1.30		83	80
9	302		0.41	1.30		84	80
10	301		0.37	1.20		84	81
11	301		0.45	1.40		84	81
12	302		0.44	1.40		85	81
13	302		0.44	1.40		85	82
14	302		0.38	1.20		85	82
15	302		0.38	1.20		85	82
16	301		0.46	1.40		86	83
17	301		0.46	1.40		86	83
18	302		0.44	1.40		86	82
19	301		0.37	1.20		86	83
20	300		0.37	1.20		87	83
21	302		0.44	1.40		88	84
22	302		0.44	1.40		88	84
23	301		0.43	1.30		88	85
24	302		0.40	1.20		89	84
25	301		0.35	1.10		88	84
26	305		0.45	1.40		94	89
27	305		0.45	1.40		94	87
28	303		0.43	1.30		91	88
29	301		0.43	1.30		91	87
30	300		0.37	1.20		90	86
<b>AVG.</b>	302	-10.67	0.42	1.30	78.278	84	

---

---

**EPA Method 26A: Gravimetric Data and Results**

---

---

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 FF OUTLET**

---

**SAMPLING DATA**

Run Number	<b>U30-M26A-R2</b>
Corr. Sample Volume	77.678 dscf
Corr. Sample Volume	2.200 dscm
Corr. Flowrate	135284 dscfm
O2 Content	7.8 %
CO2 Content	11.2 %

---

**ANALYTICAL DATA**

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	829	65.8345	65.8490	0.01450	100.0
Corr. for Blank				0.01450	
Filter	828	0.4452	0.4463	0.00110	
<b>TOTAL</b>				0.01560	

---

**Acetone Blank**

Actual Residue	0.00000 grams
Applicable Blank Corr.	0.00000 grams
Max Allowable Residue	0.00078 grams
Blank used	0.00000 grams
Volume	150.0 ml

---

**PARTICULATE LOADING**

Actual Grain Loading	0.00310 gr/dscf
Corrected to 7% O2	0.00330 gr/dscf @ 7% O2
Actual Loading	7.09217 mg/dscm
Corrected to 7% O2	7.54255 mg/dscm @ 7% O2
Corrected to 12% CO2	7.63283 mg/dscm @ 12% CO2
Corrected to 50% Excess Air	7.74521 mg/dscm @ 50% EA
Mass Rate	3.5938 lb/hr

---

---

## EPA Method 26A: Analytical Data and Results

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 3 FF OUTLET

#### SAMPLING DATA

Run Number	<b>U3O-M26A-R2</b>
Date	04/11/13
Corr. Sample Volume	77.678 dscf
Corr. Flowrate	135284 dscfm
O2 Content	7.8 %
CO2 Content	11.2 %

#### LABORATORY DATA

	IMPINGERS 1 - 3	H <sub>2</sub> SO <sub>4</sub> BLANK
Sample ID	830	838
<i>CHLORIDE LABORATORY DATA</i>		
HCl in Sample (mg)	55.4	< 0.115

#### POLLUTANT EMISSIONS

Pollutant	Concentration (ppmdv)	Concentration (ppmdv @7% O2)	Mass Rate (lb/hr)
HCl	16.62	17.67	12.76

#### Notes

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.

**Run Number U3O-M26A-R3**

Date	04/11/13
Start Time	14:36
End Time	17:04
Stack Depth	105 inches
Stack Width	132 inches
Nozzle I.D.	0.280 inches
Meter Box Gamma	1.0215
Meter Box dH@	1.6942
Barometric	29.85 in.Hg
Cp	0.84
Test Duration	120 minutes

**METHOD 4 DATA**

	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	50.0	264.0	214.0
Impinger 2	100.0	292.0	192.0
Impinger 3	100.0	137.0	37.0
Impinger 4	100.0	104.0	4.0
Impinger 5	100.0	102.0	2.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	450.0	899.0	449.0
Silica gel (g)	250.0	272.3	22.3

**METHOD 1-4 RESULTS**

Metered Volume	74.593 dcf
Volume @ Std.Cond.	72.820 dscf
% Water	23.35 %
% Isokinetics	101.0 %
Velocity	45.57 ft/sec
Actual Flow	263191 acfm
Std. Flow	176626 scfm
Dry Std. Flow	135380 dscfm

**METHOD 3 DATA**

%O2	8.00	Md	30.06
%CO2	10.86	Ms	27.24
%CO	0.0	Ps	29.08
%N2	81.1	Fo	1.188
O2+CO2	18.9	%EA	60

POINT	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Meter Temp. (Deg. F)	
						Inlet	Outlet
1	300	-11.0	0.45	1.40	882.264	91	89
2	304	-10.0	0.45	1.40	919.457	91	89
3	302	-11.0	0.44	1.20		92	90
4	305	-10.0	0.41	1.20	919.757	94	88
5	305	-10.0	0.37	1.00	957.157	95	89
6	308	-11.0	0.44	1.20		94	89
7	307		0.43	1.20		94	88
8	308		0.42	1.20		96	90
9	307		0.38	1.10		96	90
10	305		0.36	1.00		96	90
11	305		0.45	1.30		98	90
12	305		0.45	1.30		99	91
13	306		0.44	1.20		95	95
14	308		0.44	1.20		96	95
15	307		0.35	1.00		96	94
16	306		0.46	1.30		95	92
17	303		0.44	1.20		94	91
18	303		0.43	1.20		95	91
19	301		0.40	1.10		95	92
20	301		0.39	1.10		95	92
21	304		0.43	1.20		95	92
22	305		0.43	1.20		95	93
23	305		0.41	1.20		95	93
24	304		0.41	1.20		95	93
25	303		0.37	1.00		96	93
26	304		0.45	1.30		94	90
27	305		0.45	1.30		93	90
28	305		0.46	1.30		94	89
29	305		0.40	1.10		93	90
30	303		0.33	0.92		93	90
<b>AVG.</b>	305	-10.50	0.42	1.18	74.593	93	

**EPA Method 26A: Gravimetric Data and Results**

---

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 FF OUTLET**

---

**SAMPLING DATA**

Run Number **U30-M26A-R3**  
Corr. Sample Volume 72.820 dscf  
Corr. Sample Volume 2.062 dscm  
Corr. Flowrate 135380 dscfm  
O2 Content 8.0 %  
CO2 Content 10.9 %

---

**ANALYTICAL DATA**

<i>Component</i>	Sample I.D.	Weights (grams)			Volume (mL)
		Tare	Final	Net	
Probe Wash	833	66.3811	66.3955	0.01440	100.0
Corr. for Blank				0.01440	
Filter	832	0.4594	0.4603	0.00090	
<b>TOTAL</b>				0.01530	

---

**Acetone Blank**

Actual Residue 0.00000 grams  
Applicable Blank Corr. 0.00000 grams  
Max Allowable Residue 0.00078 grams  
Blank used 0.00000 grams  
Volume 150.0 ml

---

**PARTICULATE LOADING**

Actual Grain Loading 0.00324 gr/dscf  
Corrected to 7% O2 0.00349 gr/dscf @ 7% O2  
Actual Loading 7.41984 mg/dscm  
Corrected to 7% O2 7.99502 mg/dscm @ 7% O2  
Corrected to 12% CO2 8.19872 mg/dscm @ 12% CO2  
Corrected to 50% Excess Air 8.10305 mg/dscm @ 50% EA  
  
Mass Rate 3.7625 lb/hr

---

## EPA Method 26A: Analytical Data and Results

### PINELLAS COUNTY RESOURCE RECOVERY FACILITY UNIT 3 FF OUTLET

#### SAMPLING DATA

Run Number	<b>U3O-M26A-R3</b>
Date	04/11/13
Corr. Sample Volume	72.820 dscf
Corr. Flowrate	135380 dscfm
O2 Content	8.0 %
CO2 Content	10.9 %

#### LABORATORY DATA

	IMPINGERS 1 - 3	H <sub>2</sub> SO <sub>4</sub> BLANK
Sample ID	834	838
<i>CHLORIDE LABORATORY DATA</i>		
HCl in Sample (mg)	47.6	< 0.115

#### POLLUTANT EMISSIONS

Pollutant	Concentration (ppmdv)	Concentration (ppmdv @7% O2)	Mass Rate (lb/hr)
HCl	15.23	16.41	11.71

#### Notes

"<" denotes not detected, detection limit given. Non-detect blanks were treated as zero.



## **Appendix D**

### **EPA Methods 201A and 202 Data and Results**

## **Appendix D.1**

### **EPA Method 201A/202 Data and Results: Unit 1 FF Outlet**

**RUN NUMBER PRE-U10-M201A-R1**

Date 04/09/13  
 Meter Box dH@ 1.7473  
 Barometric 30.02 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 30

**METHOD 3 AND 4 DATA**

%O2 10.0  
 %CO2 10.00  
 % Water 20.00 %

**METHOD 3 DATA**

	Md	30.00
	Ms	27.60
	Ps	29.20
%CO 0.0	Fo	1.090
%N2 80.0	%EA	90
O2+CO2 20.0		

**METHOD 2 RESULTS**

Velocity 47.64 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED	
					Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	314	-11.00	0.44	0.44	88	88
2	316	-11.00	0.44	0.44		
3	316	-11.00	0.44	0.44		
4	316	-11.50	0.45	0.45		
5	315	-11.00	0.46	0.46		
6	315	-11.50	0.43	0.43		
7	315		0.44	0.44		
8	317		0.46	0.46		
9	317		0.47	0.47		
10	317		0.46	0.46		
11	318		0.46	0.46		
12	319		0.48	0.48		
13	318		0.48	0.48		
14	319		0.47	0.47		
15	319		0.45	0.45		
16	315		0.45	0.45		
17	315		0.48	0.48		
18	316		0.45	0.45		
19	317		0.44	0.44		
20	317		0.46	0.46		
21	314		0.44	0.44		
22	315		0.45	0.45		
23	317		0.43	0.43		
24	317		0.44	0.44		
25	320		0.46	0.46		
26	320		0.50	0.50		
27	317		0.51	0.51		
28	319		0.47	0.47		
29	318		0.45	0.45		
30	318		0.44	0.44		
<b>AVG.</b>	317	-11.17	0.46	0.46	88	

**EPA METHOD 201A**  
 PRELIMINARY TRAVERSE  
**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U1O-M201A-R2

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft <sup>3</sup> /min)	ORIFICE HEAD (in. H <sub>2</sub> O)
325	0.588	0.31
275	0.541	0.30
375	0.634	0.32

Nre	=	2354
-----	---	------

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.44  
 Max. dP from Traverse: 0.54  
 Average dP from Traverse: 0.48

**dPmin and dPmax Calculations at Stack Temperature of 325**

Stack Gas Viscosity (micropoise) 221.064  
 Stack Gas Viscosity (micropoise) @ -50 °F 209.504  
 Stack Gas Viscosity (micropoise) @ +50 °F 232.409

<b>D (calc. nozzle dia.)</b>	=	<b>0.191</b>
------------------------------	---	--------------

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H <sub>2</sub> O)	dPmax (in. H <sub>2</sub> O)
1	0.114		138.179	0.280	0.775	107.074	1.218	1.218	168.276	2.279	5.629
2	0.129		107.913	0.268	0.763	82.364	1.226	1.226	132.265	1.349	3.478
3	0.148		81.984	0.248	0.743	60.953	1.238	1.238	101.532	0.739	2.049
4	0.158		71.935	0.235	0.730	52.539	1.247	1.247	89.667	0.549	1.598
5	0.179	OK	56.046	0.202	0.695	38.965	1.267	1.267	70.997	0.302	1.002
6	0.191	OK	49.225	0.179	0.669	32.949	1.280	1.280	63.028	0.216	0.790
7	0.201	OK	44.449	0.158	0.644	28.609	1.293	1.293	57.471	0.163	0.657
8	0.230		33.947	0.084	0.536	18.190	1.336	1.336	45.341	0.066	0.409
9	0.253		28.055	0.010	0.347	9.749	1.376	1.376	38.610	0.019	0.296
10	0.274		23.919	-0.070	0.500	11.960	1.418	1.418	33.926	0.028	0.229
11	0.296		20.496	-0.168	0.500	10.248	1.468	1.468	30.081	0.021	0.180

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **1.98** minutes

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: 0.48

**Run Number U10-M201A/202-R1**

Date	04/10/13
Start Time	10:08
End Time	11:08
Stack Length	132 inches
Stack Width	105 inches
Nozzle I.D.	0.179 inches
Meter Box Gamma	0.991
Meter Box dH@	1.7473
Barometric	29.98 in.Hg
Cp	0.84
Test Duration	59.50 minutes

METHOD 4 DATA			
Impinger Volume (mL)			
	Initial	Final	Net
Impinger 1	0.0	80.0	80.0
Impinger 2	0.0	0.0	0.0
Impinger 3	100.0	102.0	2.0
Impinger 4			0.0
Impinger 5			0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	100.0	182.0	82.0
Silica gel (g)	250.0	260.5	10.5

METHOD 1-4 RESULTS	
Metered Volume	19.606 dcf
Volume @ Std.Cond.	18.964 dscf
% Water	18.67 %
% Isokinetics	116.2 %
Velocity	49.08 ft/sec
Actual Flow	283412 acfm
Std. Flow	185723 scfm
Dry Std. Flow	151039 dscfm

METHOD 3 DATA			
%O2	9.47	Md	29.93
%CO2	9.67	Ms	27.70
%CO	0.0	Ps	29.15
%N2	80.9	Fo	1.182
O2+CO2	19.1	%EA	80

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	2.0	320	-11.0	0.47	0.32	594.831	86.0	82	81
2	2.0	329	-10.0	0.48	0.32	595.3	125.1	83	81
3	1.9	324	-12.0	0.46	0.32	596.0	133.9	84	81
4	1.9	328	-11.0	0.45	0.32	596.7	116.3	84	81
5	2.0	329	-12.0	0.48	0.32	597.3	124.9	84	81
6	2.0	319	-12.0	0.49	0.32	598.0	122.8	84	82
7	2.0	324		0.47	0.32	598.7	125.7	84	82
8	2.0	327		0.49	0.32	599.4	105.8	84	82
9	1.9	325		0.48	0.32	600.0	112.3	84	82
10	1.9	325		0.45	0.32	600.6	116.0	84	82
11	2.0	321		0.48	0.32	601.2	124.2	84	82
12	1.9	327		0.44	0.32	601.9	137.1	84	82
13	1.9	325		0.46	0.32	602.6	114.8	84	82
14	2.0	324		0.48	0.32	603.2	124.4	84	82
15	1.9	323		0.45	0.32	603.9	115.9	84	82
16	2.0	325		0.48	0.32	604.5	124.5	84	82
17	2.1	327		0.54	0.32	605.2	112.0	84	81
18	2.0	326		0.50	0.32	605.9	122.3	83	81
19	2.0	325		0.48	0.32	606.6	124.7	83	81
20	2.0	324		0.47	0.32	607.3	108.0	83	81
21	2.1	326		0.54	0.32	607.9	112.1	83	81
22	2.1	326		0.52	0.32	608.6	114.2	83	81
23	2.0	328		0.48	0.32	609.3	124.9	84	81
24	2.0	325		0.51	0.32	610.0	103.6	84	81
25	2.0	323		0.50	0.32	610.6	121.9	84	81
26	2.0	328		0.49	0.32	611.3	123.7	83	81
27	2.0	326		0.48	0.32	612.0	107.0	83	81
28	2.0	325		0.47	0.32	612.6	108.0	83	81
29	1.9	324		0.45	0.32	613.2	116.2	83	81
30	2.0	319		0.48	0.32	613.8	113.1	83	81
						614.437			
AVG.		325	-11.33	0.48	0.32	19.606	117.4	82	

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 1 OUTLET**  
**U1O-M201A/202-R1**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	316.87 degrees F
Ts	=	776.87 degrees R
%O2, dry	=	10.00 %
%O2, wet	=	8.00 %
Bws	=	0.20
Pbar	=	30.02 in. Hg
Pstatic	=	-11.17 in. H2O
Ps	=	29.20 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	27.60 lb/lb-mole
Tm	=	88.00 degrees F
Tm	=	548.00 degrees R
Md	=	30.00 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	47.64 ft/sec
μ	=	219.471
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.86
D50T (for Nre< 3162)	=	10.43
Qs (=QI for Nre< 3162)	=	0.581
Nre	=	2371
D50LL (for Nre >= 3162)	=	10.56
D50T (for Nre >= 3162)	=	10.78
Qs (=QI for Nre >= 3162)	=	0.554
Sampling Rate ΔH	=	0.32 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.31 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.33 in. H2O
D (calc. nozzle dia.)	=	0.193 in.
D (actual selected)	=	0.179 in.
Vn	=	55.36 ft/sec
ΔPmin allowed	=	0.298 in. H2O
ΔPmax allowed	=	0.990 in. H2O
Dwell Time at Point 1 (T1) is:	=	1.96 min.
<b>Actual Run Data</b>		
Ts	=	324.90 degrees F
Ts	=	784.90 degrees R
%O2, dry	=	9.47 %
%O2, wet	=	7.70 %
Vwc	=	3.860
Vsg	=	0.495
Bws	=	0.1867
Pbar	=	29.98 in. Hg
Pstatic	=	-11.33 in. H2O
Ps	=	29.15 in. Hg
Mw (same as Ms)	=	27.70 lb/lb-mole
Tm	=	82.47 degrees F
Tm	=	542.5 degrees R
Md	=	29.93 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.32 in. H2O
Meter Volume	=	19.606 dcf
Meter Volume at Std. Cond.	=	18.964 dscf
Avg. Square Root of Delta P	=	0.6931
Velocity	=	49.08 ft/sec
Area of Nozzle	=	0.0001748 in <sup>2</sup>
Test Duration	=	59.5 min.
Isokinetics (rounded to nearest whole #)	=	116%
No. of Points < 71% or > 129% Iso.	=	2
ΔPmin allowed	=	0.315 in. H2O
ΔPmax allowed	=	1.040 in. H2O
Actual ΔPmin from run	=	0.44 in. H2O
Actual ΔPmax from run	=	0.54 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	222.232
Qs	=	0.598 acfm
D50 (for PM-10 cyclone I)	=	10.32
Nre (actual test conditions)	=	2392
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.45
Cr	=	1.25
D50-1	=	2.28
Z	=	0.93
Recalculated Cr	=	1.27
Recalculated D50 (for cyclone IV)	=	2.27
Recalculated D50-1	=	2.27
Recalculated Z	=	1.00

**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 OUTLET**

Run Number **U1O-M201A/202-R1**  
 Stack Gas Viscosity (micropoise) 219.471  
 Cyclone Flow Rate (dscf/min) 0.319  
 Cyclone Flow Rate (acfm) 0.598  
 D50 10.320

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 222.232  
 Cyclone Flow Rate (acfm) 0.598  
 Vmstd - dscf 18.964  
 Sample Time - min 59.5  
 Ts 324.900  
 % O2 9.470  
 % Water 18.675  
 Vwc 3.860  
 Vsg 0.495  
 Ps 29.147  
 Mw 27.699  
 Cp 0.84  
 Nozzle Size(s) Used For Test: 0.179  
 Minimum dP During Test: 0.44  
 Maximum dP During Test: 0.54

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax Step 1	Conditional Rmax Step 2	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	140.634	0.280	0.775	109.020	1.218	1.218	171.235	2.371	5.850	OK	OK OK OK
2	0.129	109.830	0.268	0.764	83.878	1.225	1.225	134.581	1.404	3.613		
3	0.148	83.440	0.249	0.744	62.097	1.238	1.238	103.297	0.769	2.129		
4	0.158	73.213	0.236	0.731	53.539	1.246	1.246	91.220	0.572	1.660		
5	0.179	57.042	0.203	0.697	39.738	1.266	1.266	72.213	0.315	1.040		
6	0.191	50.099	0.181	0.671	33.626	1.279	1.279	64.100	0.226	0.820		
7	0.201	45.238	0.160	0.646	29.220	1.292	1.292	58.443	0.170	0.681		
8	0.230	34.550	0.087	0.541	18.674	1.334	1.334	46.093	0.070	0.424		
9	0.253	28.553	0.014	0.364	10.394	1.374	1.374	39.240	0.022	0.307		
10	0.274	24.344	-0.065	0.500	12.172	1.416	1.416	34.471	0.030	0.237		
11	0.296	20.860	-0.162	0.500	10.430	1.465	1.465	30.556	0.022	0.186		

**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 OUTLET**

**SAMPLING DATA**

Run number	<b>U10-M201A/202-R1</b>
Corrected sample volume	18.964 dscf
	0.537 dscm
Corrected flow rate	151039 dscfm
O2 Content	9.47 %
CO2 Content	9.67 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
FILTERABLE PM2.5		
Probe Wash	0.00080	0.00000
Filter	0.00070	0.00070
CONDENSIBLE PM2.5		
Inorganic CPM	0.00360	0.00179
Organic CPM	0.00760	0.00741
TOTAL CPM	0.01120	0.00920
TOTAL PM	0.01270	0.00990

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	67.0124	67.0132	0.00080	170
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00163	
Max. Allowable Blank			0.00133	
Blank Value Used for Correction			0.00133	
Filter	0.3468	0.3475	0.00070	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.00360	260	29.71%
Organic CPM in Sample	0.00760	232	70.29%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00440	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0006	0.0015	0.0060	0.0075	0.0081
Corrected to 7% O2 (gr/dscf)	0.0007	0.0018	0.0073	0.0091	0.0098
Corrected to 12% CO2 (gr/dscf)	0.0007	0.0018	0.0075	0.0093	0.0100
Actual Grain Loading (mg/dscm)	1.30	3.34	13.79	17.13	18.44
Corrected to 7% O2 (mg/dscm)	1.59	4.06	16.77	20.83	22.42
Corrected to 12% CO2 (mg/dscm)	1.62	4.14	17.12	21.26	22.88
Mass Rate (lb/hr)	0.74	1.89	7.80	9.69	10.43

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).



**RUN NUMBER PRE-U10-M201A-R2**

Date 04/10/13  
 Start Time 10:08  
 End Time 11:08  
 Meter Box dH@ 1.7473  
 Barometric 29.98 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 24

**METHOD 3 AND 4 DATA**

%O2 9.47  
 %CO2 9.67  
 % Water 20.00 %

**METHOD 3 DATA**

%CO 0.0 Md 29.93  
 %N2 80.9 Ms 27.54  
 O2+CO2 19.1 Ps 29.21  
 %EA 80 Fo 1.182

**METHOD 2 RESULTS**

Velocity 49.16 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	320	-11.00	0.47	0.47	82	81
2	329	-10.00	0.48	0.48	83	81
3	324		0.46	0.46	84	81
4	328		0.45	0.45	84	81
5	329		0.48	0.48	84	81
6	319		0.49	0.49	84	82
7	324		0.47	0.47	84	82
8	327		0.49	0.49	84	82
9	325		0.48	0.48	84	82
10	325		0.45	0.45	84	82
11	321		0.48	0.48	84	82
12	327		0.44	0.44	84	82
13	325		0.46	0.46	84	82
14	324		0.48	0.48	84	82
15	323		0.45	0.45	84	82
16	325		0.48	0.48	84	82
17	327		0.54	0.54	84	81
18	326		0.50	0.50	83	81
19	325		0.48	0.48	83	81
20	324		0.47	0.47	83	81
21	326		0.54	0.54	83	81
22	326		0.52	0.52	83	81
23	328		0.48	0.48	84	81
24	325		0.51	0.51	84	81
25	323		0.50	0.50	84	81
26	328		0.49	0.49	83	81
27	326		0.48	0.48	83	81
28	325		0.47	0.47	83	81
29	324		0.45	0.45	83	81
30	319		0.48	0.48	83	81
AVG.	325	-10.50	0.48	0.48	82	

**EPA METHOD 201A**  
 PRELIMINARY TRAVERSE  
**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U1O-M201A-R2

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft <sup>3</sup> /min)	ORIFICE HEAD (in. H <sub>2</sub> O)
325	0.588	0.31
275	0.541	0.30
375	0.634	0.32

Nre	=	2354
-----	---	------

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.44  
 Max. dP from Traverse: 0.54  
 Average dP from Traverse: 0.48

**dPmin and dPmax Calculations at Stack Temperature of 325**

Stack Gas Viscosity (micropoise) 221.064  
 Stack Gas Viscosity (micropoise) @ -50 °F 209.504  
 Stack Gas Viscosity (micropoise) @ +50 °F 232.409

D (calc. nozzle dia.)	=	0.191
-----------------------	---	-------

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H <sub>2</sub> O)	dPmax (in. H <sub>2</sub> O)
1	0.114		138.179	0.280	0.775	107.074	1.218	1.218	168.276	2.279	5.629
2	0.129		107.913	0.268	0.763	82.364	1.226	1.226	132.265	1.349	3.478
3	0.148		81.984	0.248	0.743	60.953	1.238	1.238	101.532	0.739	2.049
4	0.158		71.935	0.235	0.730	52.539	1.247	1.247	89.667	0.549	1.598
5	0.179	OK	56.046	0.202	0.695	38.965	1.267	1.267	70.997	0.302	1.002
6	0.191	OK	49.225	0.179	0.669	32.949	1.280	1.280	63.028	0.216	0.790
7	0.201	OK	44.449	0.158	0.644	28.609	1.293	1.293	57.471	0.163	0.657
8	0.230		33.947	0.084	0.536	18.190	1.336	1.336	45.341	0.066	0.409
9	0.253		28.055	0.010	0.347	9.749	1.376	1.376	38.610	0.019	0.296
10	0.274		23.919	-0.070	0.500	11.960	1.418	1.418	33.926	0.028	0.229
11	0.296		20.496	-0.168	0.500	10.248	1.468	1.468	30.081	0.021	0.180

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **1.98** minutes

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: 0.48

**Run Number U10-M201A/202-R2**

Date	04/10/13
Start Time	12:11
End Time	13:12
Stack Length	132 inches
Stack Width	105 inches
Nozzle I.D.	0.179 inches
Meter Box Gamma	0.9910
Meter Box dH@	1.7473
Barometric	29.98 in.Hg
Cp	0.84
Test Duration	61.10 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	93.0	93.0
Impinger 2	0.0	0.0	0.0
Impinger 3	100.0	98.0	-2.0
Impinger 4			0.0
Impinger 5			0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	100.0	191.0	91.0
Silica gel (g)	250.0	256.4	6.4

METHOD 1-4 RESULTS	
Metered Volume	20.112 dcf
Volume @ Std.Cond.	19.363 dscf
% Water	19.15 %
% Isokinetics	118.1 %
Velocity	48.26 ft/sec
Actual Flow	278728 acfm
Std. Flow	182794 scfm
Dry Std. Flow	147796 dscfm

METHOD 3 DATA			
%O2	8.84	Md	29.98
%CO2	10.17	Ms	27.69
%CO	0.0	Ps	29.13
%N2	81.0	Fo	1.186
O2+CO2	19.0	%EA	70

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	2.1	314	-12.00	0.47	0.31	615.268	110.9	82	82
2	2.1	318	-11.00	0.49	0.31	615.9	117.7	82	82
3	2.1	322	-11.00	0.48	0.31	616.6	119.3	82	82
4	2.0	324	-12.00	0.46	0.31	617.3	128.0	83	82
5	2.0	327	-11.00	0.45	0.31	618.0	111.1	83	82
6	2.1	325	-12.00	0.48	0.31	618.6	119.4	83	82
7	2.0	323		0.47	0.31	619.3	126.5	83	82
8	2.1	325		0.49	0.31	620.0	118.1	83	82
9	1.9	323		0.46	0.31	620.7	115.4	83	82
10	2.0	320		0.46	0.31	621.3	127.6	83	82
11	2.1	327		0.49	0.31	622.0	118.0	85	83
12	2.2	326		0.52	0.31	622.7	109.2	85	83
13	2.1	325		0.48	0.31	623.4	118.8	86	84
14	2.0	325		0.43	0.31	624.1	131.8	86	84
15	1.9	327		0.41	0.31	624.8	121.7	88	84
16	2.1	325		0.49	0.31	625.4	100.6	88	84
17	2.2	327		0.53	0.31	626.0	107.9	88	84
18	2.2	326		0.54	0.31	626.7	122.2	87	84
19	2.0	323		0.47	0.31	627.5	107.6	87	86
20	2.0	320		0.44	0.31	628.1	129.5	87	86
21	2.0	324		0.45	0.31	628.8	128.4	87	86
22	1.9	325		0.42	0.31	629.5	120.0	87	86
23	1.9	327		0.42	0.31	630.1	120.2	87	86
24	2.0	326		0.46	0.31	630.7	108.9	88	86
25	2.1	328		0.49	0.31	631.3	117.4	88	86
26	2.1	325		0.48	0.31	632.0	118.4	88	86
27	2.0	327		0.44	0.31	632.7	129.9	89	86
28	1.9	323		0.42	0.31	633.4	119.6	89	86
29	2.0	322		0.43	0.31	634.0	130.8	89	87
30	2.0	320		0.44	0.31	634.7	125.5	89	87
							635.380		
AVG.		324	-11.50	0.47	0.31	20.112	119.4	85	

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 1 OUTLET**  
**U1O-M201A/202-R2**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	324.90 degrees F
Ts	=	784.90 degrees R
%O2, dry	=	9.47 %
%O2, wet	=	7.58 %
Bws	=	0.20
Pbar	=	29.98 in. Hg
Pstatic	=	-10.50 in. H2O
Ps	=	29.21 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	27.54 lb/lb-mole
Tm	=	82.47 degrees F
Tm	=	542.47 degrees R
Md	=	29.93 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	49.16 ft/sec
μ	=	221.064
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.84
D50T (for Nre< 3162)	=	10.42
Qs (=QI for Nre< 3162)	=	0.588
Nre	=	2354
D50LL (for Nre >= 3162)	=	10.56
D50T (for Nre >= 3162)	=	10.78
Qs (=QI for Nre >= 3162)	=	0.560
Sampling Rate ΔH	=	0.31 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.30 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.32 in. H2O
D (calc. nozzle dia.)	=	0.191 in.
D (actual selected)	=	0.179 in.
Vn	=	56.04 ft/sec
ΔPmin allowed	=	0.302 in. H2O
ΔPmax allowed	=	1.002 in. H2O
Dwell Time at Point 1 (T1) is:	=	2.47 min.
<b>Actual Run Data</b>		
Ts	=	323.97 degrees F
Ts	=	783.97 degrees R
%O2, dry	=	8.84 %
%O2, wet	=	7.15 %
Vwc	=	4.283
Vsg	=	0.302
Bws	=	0.1915
Pbar	=	29.98 in. Hg
Pstatic	=	-11.50 in. H2O
Ps	=	29.13 in. Hg
Mw (same as Ms)	=	27.69 lb/lb-mole
Tm	=	84.98 degrees F
Tm	=	545.0 degrees R
Md	=	29.98 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.31 in. H2O
Meter Volume	=	20.112 dcf
Meter Volume at Std. Cond.	=	19.363 dscf
Avg. Square Root of Delta P	=	0.6818
Velocity	=	48.26 ft/sec
Area of Nozzle	=	0.0001748 ft <sup>2</sup>
Test Duration	=	61.1 min.
Isokinetics (rounded to nearest whole #)	=	118%
No. of Points < 71% or > 129% Iso.	=	4
Actual ΔPmin from run	=	0.41 in. H2O
Actual ΔPmax from run	=	0.54 in. H2O
Actual ΔPmin from run	=	0.41 in. H2O
Actual ΔPmax from run	=	0.54 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	221.302
Qs	=	0.598 acfm
D50 (for PM-10 cyclone I)	=	10.29
Nre (actual test conditions)	=	2401
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.44
Cr	=	1.25
D50-1	=	2.27
Z	=	0.93
Recalculated Cr	=	1.27
Recalculated D50 (for cyclone IV)	=	2.26
Recalculated D50-1	=	2.26
Recalculated Z	=	1.00

**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 OUTLET**

Run Number **U1O-M201A/202-R2**

Stack Gas Viscosity (micropoise) 221.064  
 Cyclone Flow Rate (dscf/min) 0.317  
 Cyclone Flow Rate (acfm) 0.598  
 D50 10.294

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 221.302  
 Cyclone Flow Rate (acfm) 0.598

Vmstd - dscf 19.363  
 Sample Time - min 61.1  
 Ts 323.967  
 % O2 8.840  
 % Water 19.146  
 Vwc 4.283  
 Vsg 0.302  
 Ps 29.134  
 Mw 27.687  
 Cp 0.84

Nozzle Size(s) Used For Test: 0.179  
 Minimum dP During Test: 0.41  
 Maximum dP During Test: 0.54

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Step 1	Conditional Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	140.540	0.280	0.775	108.960	1.218	1.218	171.112	2.369	5.843	OK	OK
2	0.129	109.756	0.268	0.764	83.836	1.225	1.225	134.481	1.403	3.609		
3	0.148	83.384	0.249	0.744	62.072	1.238	1.238	103.217	0.769	2.126		
4	0.158	73.163	0.236	0.732	53.522	1.246	1.246	91.147	0.572	1.658		
5	0.179	57.004	0.204	0.697	39.735	1.266	1.266	72.152	0.315	1.039		
6	0.191	50.066	0.181	0.672	33.630	1.279	1.279	64.044	0.226	0.819		
7	0.201	45.208	0.161	0.647	29.230	1.292	1.292	58.390	0.171	0.680		
8	0.230	34.527	0.088	0.542	18.707	1.334	1.334	46.047	0.070	0.423		
9	0.253	28.534	0.015	0.368	10.509	1.374	1.374	39.197	0.022	0.307		
10	0.274	24.328	-0.064	0.500	12.164	1.415	1.415	34.432	0.030	0.237		
11	0.296	20.846	-0.161	0.500	10.423	1.464	1.464	30.518	0.022	0.186		

**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 OUTLET**

**SAMPLING DATA**

Run number	<b>U10-M201A/202-R2</b>
Corrected sample volume	19.363 dscf
	0.548 dscm
Corrected flow rate	147796 dscfm
O2 Content	8.84 %
CO2 Content	10.17 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
<b>FILTERABLE PM2.5</b>		
Probe Wash	0.00100	0.00000
Filter	0.00090	0.00090
<b>CONDENSIBLE PM2.5</b>		
Inorganic CPM	0.00480	0.00299
Organic CPM	0.00570	0.00551
TOTAL CPM	0.01050	0.00850
<b>TOTAL PM</b>	<b>0.01240</b>	<b>0.00940</b>

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	66.3309	66.3319	0.00100	140
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00134	
Max. Allowable Blank			0.00110	
Blank Value Used for Correction			0.00110	
Filter	0.3603	0.3612	0.00090	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.00480	270	45.71%
Organic CPM in Sample	0.00570	270	54.29%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00470	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0007	0.0024	0.0044	0.0068	0.0075
Corrected to 7% O2 (gr/dscf)	0.0008	0.0027	0.0051	0.0078	0.0086
Corrected to 12% CO2 (gr/dscf)	0.0008	0.0028	0.0052	0.0080	0.0088
Actual Grain Loading (mg/dscf)	1.64	5.46	10.04	15.50	17.14
Corrected to 7% O2 (mg/dscf)	1.89	6.29	11.57	17.87	19.76
Corrected to 12% CO2 (mg/dscf)	1.94	6.44	11.85	18.29	20.23
Mass Rate (lb/hr)	0.91	3.02	5.56	8.58	9.49

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).

**RUN NUMBER PRE-U10-M201A-R3**

Date 04/10/13  
 Start Time 12:11  
 End Time 13:12  
 Meter Box dH@ 1.7473  
 Barometric 29.98 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 30

**METHOD 3 AND 4 DATA**

%O2 8.84  
 %CO2 10.17  
 % Water 20.00 %

**METHOD 3 DATA**

%CO 0.0 Md 29.98  
 %N2 81.0 Ms 27.58  
 O2+CO2 19.0 Ps 29.13  
 %EA 70 Fo 1.186

**METHOD 2 RESULTS**

Velocity 48.35 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	314	-12.00	0.47	0.47	82	82
2	318	-11.00	0.49	0.49	82	82
3	322		0.48	0.48	82	82
4	324		0.46	0.46	83	82
5	327		0.45	0.45	83	82
6	325		0.48	0.48	83	82
7	323		0.47	0.47	83	82
8	325		0.49	0.49	83	82
9	323		0.46	0.46	83	82
10	320		0.46	0.46	83	82
11	327		0.49	0.49	85	83
12	326		0.52	0.52	85	83
13	325		0.48	0.48	86	84
14	325		0.43	0.43	86	84
15	327		0.41	0.41	88	84
16	325		0.49	0.49	88	84
17	327		0.53	0.53	88	84
18	326		0.54	0.54	87	84
19	323		0.47	0.47	87	86
20	320		0.44	0.44	87	86
21	324		0.45	0.45	87	86
22	325		0.42	0.42	87	86
23	327		0.42	0.42	87	86
24	326		0.46	0.46	88	86
25	328		0.49	0.49	88	86
26	325		0.48	0.48	88	86
27	327		0.44	0.44	89	86
28	323		0.42	0.42	89	86
29	322		0.43	0.43	89	87
30	320		0.44	0.44	89	87
AVG.	324	-11.50	0.47	0.47	85	

**EPA METHOD 201A**  
 PRELIMINARY TRAVERSE  
**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U10-M201A-R3

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft <sup>3</sup> /min)	ORIFICE HEAD (in. H <sub>2</sub> O)		
324	0.586	0.31	Nre	= 2354
274	0.540	0.30		
374	0.633	0.32		

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.41  
 Max. dP from Traverse: 0.54  
 Average dP from Traverse: 0.47

**dPmin and dPmax Calculations at Stack Temperature of 324**

Stack Gas Viscosity (micropoise) 220.552  
 Stack Gas Viscosity (micropoise) @ -50 °F 208.988  
 Stack Gas Viscosity (micropoise) @ +50 °F 231.901

**D (calc. nozzle dia.) = 0.192**

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H <sub>2</sub> O)	dPmax (in. H <sub>2</sub> O)
1	0.114		137.847	0.280	0.775	106.816	1.218	1.218	167.872	2.269	5.603
2	0.129		107.654	0.268	0.763	82.165	1.226	1.226	131.948	1.342	3.462
3	0.148		81.787	0.248	0.743	60.806	1.238	1.238	101.288	0.735	2.040
4	0.158		71.762	0.235	0.730	52.412	1.247	1.247	89.452	0.546	1.591
5	0.179	OK	55.912	0.202	0.695	38.870	1.267	1.267	70.826	0.300	0.997
6	0.191	OK	49.107	0.179	0.669	32.869	1.280	1.280	62.876	0.215	0.786
7	0.201	OK	44.342	0.158	0.644	28.539	1.293	1.293	57.333	0.162	0.654
8	0.230		33.865	0.084	0.536	18.145	1.336	1.336	45.232	0.065	0.407
9	0.253		27.988	0.010	0.347	9.722	1.376	1.376	38.517	0.019	0.295
10	0.274		23.862	-0.070	0.500	11.931	1.418	1.418	33.845	0.028	0.228
11	0.296		20.447	-0.168	0.500	10.223	1.468	1.468	30.009	0.021	0.179

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **2.01** minutes

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: 0.47



**Run Number U10-M201A/202-R3**

Date	04/10/13
Start Time	15:03
End Time	16:03
Stack Length	132 inches
Stack Width	105 inches
Nozzle I.D.	0.179 inches
Meter Box Gamma	0.9910
Meter Box dH@	1.7473
Barometric	29.96 in.Hg
Cp	0.84
Test Duration	60.10 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	92.0	92.0
Impinger 2	0.0	0.0	0.0
Impinger 3	100.0	85.0	-15.0
Impinger 4			0.0
Impinger 5			0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	<b>100.0</b>	<b>177.0</b>	<b>77.0</b>
Silica gel (g)	250.0	264.4	14.4

METHOD 1-4 RESULTS	
Metered Volume	19.711 dcf
Volume @ Std.Cond.	18.898 dscf
% Water	18.55 %
% Isokinetics	115.5 %
Velocity	47.81 ft/sec
Actual Flow	276113 acfm
Std. Flow	184057 scfm
Dry Std. Flow	149919 dscfm

METHOD 3 DATA			
%O2	9.30	Md	29.95
%CO2	9.88	Ms	27.74
%CO	0.0	Ps	29.14
%N2	80.8	Fo	1.174
O2+CO2	19.2	%EA	77

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	2.0	317	-12.0	0.47	0.31	636.637	117.0	87	86
2	2.0	310	-12.0	0.45	0.31	637.3	108.3	87	86
3	1.9	312	-10.0	0.43	0.31	637.9	117.1	85	85
4	2.0	313	-11.0	0.46	0.31	638.5	125.4	86	85
5	2.0	310	-11.0	0.45	0.31	639.2	108.5	86	85
6	2.1	316	-11.0	0.49	0.31	639.8	116.0	86	85
7	2.1	309		0.50	0.31	640.5	114.3	86	85
8	2.0	310		0.47	0.31	641.2	106.2	86	85
9	2.1	312		0.49	0.31	641.8	115.5	87	86
10	2.1	314		0.50	0.31	642.5	114.5	87	86
11	2.1	308		0.51	0.31	643.2	112.9	87	86
12	2.1	311		0.53	0.31	643.9	95.1	87	86
13	2.0	313		0.46	0.31	644.5	107.3	87	86
14	1.9	310		0.42	0.31	645.1	137.5	88	86
15	1.9	313		0.40	0.31	645.8	141.2	88	86
16	1.9	312		0.43	0.31	646.5	136.1	88	86
17	2.0	314		0.47	0.31	647.2	106.2	88	86
18	2.0	310		0.48	0.31	647.8	122.2	88	86
19	2.0	312		0.45	0.31	648.5	108.3	88	86
20	1.9	307		0.44	0.31	649.1	134.1	88	86
21	2.0	313		0.46	0.31	649.8	107.2	88	86
22	2.0	315		0.47	0.31	650.4	123.9	88	86
23	1.9	309		0.44	0.31	651.1	114.9	89	87
24	2.0	310		0.45	0.31	651.7	126.0	89	87
25	2.0	308		0.45	0.31	652.4	107.9	89	87
26	2.1	312		0.52	0.31	653.0	111.8	89	87
27	2.2	310		0.54	0.31	653.7	104.5	90	87
28	1.9	310		0.43	0.31	654.4	116.2	90	87
29	2.0	314		0.46	0.31	655.0	124.8	90	87
30	1.9	308		0.43	0.31	655.7	125.3	90	87
						656.348			
AVG.		311	-11.17	0.47	0.31	19.711	116.9	87	

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 1 OUTLET**  
**U1O-M201A/202-R3**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	323.97 degrees F
Ts	=	783.97 degrees R
%O2, dry	=	8.84 %
%O2, wet	=	7.07 %
Bws	=	0.20
Pbar	=	29.98 in. Hg
Pstatic	=	-11.50 in. H2O
Ps	=	29.13 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	27.58 lb/lb-mole
Tm	=	84.98 degrees F
Tm	=	544.98 degrees R
Md	=	29.98 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	48.35 ft/sec
μ	=	220.552
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.84
D50T (for Nre< 3162)	=	10.42
Qs (=QI for Nre< 3162)	=	0.586
Nre	=	2354
D50LL (for Nre >= 3162)	=	10.55
D50T (for Nre >= 3162)	=	10.78
Qs (=QI for Nre >= 3162)	=	0.559
Sampling Rate ΔH	=	0.31 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.30 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.32 in. H2O
D (calc. nozzle dia.)	=	0.192 in.
D (actual selected)	=	0.179 in.
Vn	=	55.91 ft/sec
ΔPmin allowed	=	0.300 in. H2O
ΔPmax allowed	=	0.997 in. H2O
Dwell Time at Point 1 (T1) is:	=	2.01 min.
<b>Actual Run Data</b>		
Ts	=	311.40 degrees F
Ts	=	771.40 degrees R
%O2, dry	=	9.30 %
%O2, wet	=	7.58 %
Vwc	=	3.624
Vsg	=	0.679
Bws	=	0.1855
Pbar	=	29.96 in. Hg
Pstatic	=	-11.17 in. H2O
Ps	=	29.14 in. Hg
Mw (same as Ms)	=	27.74 lb/lb-mole
Tm	=	86.90 degrees F
Tm	=	546.9 degrees R
Md	=	29.95 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.31 in. H2O
Meter Volume	=	19.711 dcf
Meter Volume at Std. Cond.	=	18.898 dscf
Avg. Square Root of Delta P	=	0.6815
Velocity	=	47.81 ft/sec
Area of Nozzle	=	0.0001748 in <sup>2</sup>
Test Duration	=	60.1 min.
Isokinetics (rounded to nearest whole #)	=	116%
No. of Points < 71% or > 129% Iso.	=	4
Actual ΔPmin from run	=	0.40 in. H2O
Actual ΔPmax from run	=	0.54 in. H2O
Actual ΔPmin from run	=	0.40 in. H2O
Actual ΔPmax from run	=	0.54 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	219.167
Qs	=	0.579 acfm
D50 (for PM-10 cyclone I)	=	10.41
Nre (actual test conditions)	=	2392
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.47
Cr	=	1.24
D50-1	=	2.31
Z	=	0.94
Recalculated Cr	=	1.26
Recalculated D50 (for cyclone IV)	=	2.30
Recalculated D50-1	=	2.30
Recalculated Z	=	1.00

**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 OUTLET**

Run Number **U1O-M201A/202-R3**

Stack Gas Viscosity (micropoise) 220.552  
 Cyclone Flow Rate (dscf/min) 0.314  
 Cyclone Flow Rate (acfm) 0.579  
 D50 10.415

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 219.167  
 Cyclone Flow Rate (acfm) 0.579

Vmstd - dscf 18.898  
 Sample Time - min 60.1  
 Ts 311.400  
 % O2 9.300  
 % Water 18.548  
 Vwc 3.624  
 Vsg 0.679  
 Ps 29.139  
 Mw 27.736  
 Cp 0.84

Nozzle Size(s) Used For Test: 0.179  
 Minimum dP During Test: 0.40  
 Maximum dP During Test: 0.54

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Step 1	Conditional Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	136.182	0.280	0.775	105.505	1.218	1.218	165.858	2.262	5.590	OK	OK OK OK
2	0.129	106.353	0.268	0.763	81.149	1.226	1.226	130.369	1.338	3.454		
3	0.148	80.799	0.247	0.743	60.043	1.239	1.239	100.082	0.733	2.035		
4	0.158	70.895	0.234	0.730	51.748	1.247	1.247	88.390	0.544	1.588		
5	0.179	55.236	0.201	0.695	38.363	1.267	1.267	69.991	0.299	0.996		
6	0.191	48.513	0.179	0.668	32.429	1.281	1.281	62.139	0.214	0.785		
7	0.201	43.806	0.157	0.643	28.146	1.293	1.293	56.663	0.161	0.652		
8	0.230	33.456	0.083	0.534	17.850	1.336	1.336	44.711	0.065	0.406		
9	0.253	27.650	0.009	0.338	9.356	1.377	1.377	38.078	0.018	0.295		
10	0.274	23.574	-0.072	0.500	11.787	1.420	1.420	33.463	0.028	0.228		
11	0.296	20.200	-0.171	0.500	10.100	1.469	1.469	29.674	0.021	0.179		

**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 1 OUTLET**

**SAMPLING DATA**

Run number	<b>U10-M201A/202-R3</b>
Corrected sample volume	18.898 dscf
	0.535 dscm
Corrected flow rate	149919 dscfm
O2 Content	9.30 %
CO2 Content	9.88 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
FILTERABLE PM2.5		
Probe Wash	0.00090	0.00000
Filter	0.00100	0.00100
CONDENSIBLE PM2.5		
Inorganic CPM	0.00790	0.00609
Organic CPM	0.00800	0.00781
TOTAL CPM	0.01590	0.01390
TOTAL PM	0.01780	0.01490

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	65.3940	65.3949	0.00090	210
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00202	
Max. Allowable Blank			0.00165	
Blank Value Used for Correction			0.00165	
Filter	0.3482	0.3492	0.00100	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.00790	250	44.38%
Organic CPM in Sample	0.00800	202	55.62%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00420	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0008	0.0050	0.0064	0.0114	0.0122
Corrected to 7% O2 (gr/dscf)	0.0010	0.0060	0.0076	0.0136	0.0146
Corrected to 12% CO2 (gr/dscf)	0.0010	0.0060	0.0077	0.0138	0.0148
Actual Grain Loading (mg/dscf)	1.87	11.39	14.59	25.97	27.84
Corrected to 7% O2 (mg/dscf)	2.24	13.64	17.48	31.12	33.36
Corrected to 12% CO2 (mg/dscf)	2.27	13.83	17.72	31.55	33.82
Mass Rate (lb/hr)	1.05	6.39	8.19	14.59	15.64

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).

## **Appendix D.2**

### **EPA Method 201A/202 Data and Results: Unit 2 FF Outlet**

**RUN NUMBER PRE-U2O-M201A-R1**

Date 04/10/13  
 Meter Box dH@ 1.7473  
 Barometric 29.95 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 30

**METHOD 3 AND 4 DATA**

%O2 11.0  
 %CO2 8.00  
 % Water 18.00 %

**METHOD 3 DATA**

		Md	29.72
		Ms	27.61
%CO	0.0	Ps	29.17
%N2	81.0	Fo	1.238
O2+CO2	19.0	%EA	106

**METHOD 2 RESULTS**

Velocity 45.99 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	293	-10.00	0.49	0.49	85	85
2	298	-12.00	0.48	0.48		
3	297	-11.00	0.42	0.42		
4	295	-11.00	0.42	0.42		
5	296	-10.00	0.32	0.32		
6	293	-10.00	0.47	0.47		
7	293		0.47	0.47		
8	295		0.48	0.48		
9	296		0.40	0.40		
10	294		0.36	0.36		
11	298		0.49	0.49		
12	296		0.49	0.49		
13	297		0.48	0.48		
14	299		0.44	0.44		
15	297		0.37	0.37		
16	293		0.47	0.47		
17	293		0.46	0.46		
18	295		0.45	0.45		
19	292		0.45	0.45		
20	292		0.38	0.38		
21	300		0.49	0.49		
22	300		0.49	0.49		
23	298		0.47	0.47		
24	295		0.43	0.43		
25	295		0.37	0.37		
26	295		0.45	0.45		
27	298		0.45	0.45		
28	294		0.42	0.42		
29	295		0.40	0.40		
30	293		0.39	0.39		
AVG.	296	-10.67	0.44	0.44	85	

**EPA METHOD 201A**

PRELIMINARY TRAVERSE

**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U2O-M201A-R1

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft3/min)	ORIFICE HEAD (in. H2O)
296	0.567	0.33
246	0.521	0.32
346	0.614	0.34

Nre	=	2409
-----	---	------

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.32  
 Max. dP from Traverse: 0.49  
 Average dP from Traverse: 0.44

**dPmin and dPmax Calculations at Stack Temperature of 296**

Stack Gas Viscosity (micropoise) 216.812  
 Stack Gas Viscosity (micropoise) @ -50 °F 205.152  
 Stack Gas Viscosity (micropoise) @ +50 °F 228.260

**D (calc. nozzle dia.) = 0.194**

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)
1	0.114		133.359	0.280	0.774	103.283	1.218	1.218	162.444	2.205	5.456
2	0.129		104.148	0.267	0.763	79.426	1.226	1.226	127.694	1.304	3.371
3	0.148		79.124	0.247	0.743	58.750	1.239	1.239	98.038	0.714	1.987
4	0.158		69.425	0.234	0.729	50.622	1.247	1.247	86.590	0.530	1.550
5	0.179	OK	54.091	0.200	0.693	37.503	1.268	1.268	68.576	0.291	0.972
6	0.191	OK	47.508	0.177	0.667	31.683	1.282	1.282	60.888	0.208	0.766
7	0.201	OK	42.898	0.156	0.641	27.480	1.294	1.294	55.527	0.156	0.637
8	0.230		32.762	0.081	0.530	17.349	1.338	1.338	43.826	0.062	0.397
9	0.253		27.076	0.006	0.320	8.669	1.379	1.379	37.333	0.016	0.288
10	0.274		23.085	-0.076	0.500	11.543	1.421	1.421	32.815	0.028	0.223
11	0.296		19.781	-0.176	0.500	9.890	1.471	1.471	29.106	0.020	0.175

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **2.12 minutes**

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: 0.44

**Run Number U2O-M201A/202-R1**

Date	04/11/13
Start Time	7:32
End Time	8:38
Stack Length	132 inches
Stack Width	105 inches
Nozzle I.D.	0.191 inches
Meter Box Gamma	0.991
Meter Box dH@	1.7473
Barometric	29.84 in.Hg
Cp	0.84
Test Duration	66.30 minutes

METHOD 4 DATA			
Impinger Volume (mL)			
	Initial	Final	Net
Impinger 1	0.0	90.0	90.0
Impinger 2	0.0	0.0	0.0
Impinger 3	100.0	93.0	-7.0
Impinger 4			0.0
Impinger 5			0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	100.0	183.0	83.0
Silica gel (g)	250.0	257.0	7.0

METHOD 1-4 RESULTS	
Metered Volume	22.397 dcf
Volume @ Std.Cond.	21.895 dscf
% Water	16.21 %
% Isokinetics	109.0 %
Velocity	44.93 ft/sec
Actual Flow	259499 acfm
Std. Flow	174962 scfm
Dry Std. Flow	146594 dscfm

METHOD 3 DATA			
%O2	9.98	Md	29.86
%CO2	9.16	Ms	27.94
%CO	0.0	Ps	29.12
%N2	80.9	Fo	1.192
O2+CO2	19.1	%EA	88

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	2.1	304	-10.0	0.38	0.33	667.676	101.0	72	72
2	2.2	304	-9.0	0.40	0.33	668.3	121.7	72	72
3	2.2	305	-10.0	0.43	0.33	669.1	88.0	73	72
4	2.2	305	-10.0	0.42	0.33	669.7	89.0	73	72
5	2.3	301	-10.0	0.44	0.33	670.3	96.7	74	72
6	2.2	302	-10.0	0.43	0.33	671.0	102.3	74	72
7	2.2	303		0.40	0.33	671.7	106.2	74	72
8	2.1	302		0.37	0.33	672.4	132.1	74	72
9	2.1	301		0.39	0.33	673.2	144.7	74	72
10	2.1	302		0.38	0.33	674.1	114.1	74	72
11	2.4	301		0.47	0.33	674.8	102.5	74	72
12	2.3	302		0.45	0.33	675.6	95.7	74	72
13	2.2	301		0.43	0.33	676.3	116.9	74	72
14	2.2	302		0.43	0.33	677.1	102.3	74	72
15	2.2	301		0.40	0.33	677.8	121.0	75	73
16	2.3	302		0.46	0.33	678.6	94.5	75	73
17	2.3	300		0.44	0.33	679.3	110.3	75	73
18	2.2	300		0.43	0.33	680.1	116.3	77	74
19	2.2	302		0.41	0.33	680.9	119.2	77	74
20	2.2	304		0.39	0.33	681.7	107.1	77	74
21	2.1	303		0.45	0.33	682.4	119.3	77	74
22	2.3	301		0.42	0.33	683.2	112.6	77	74
23	2.2	302		0.42	0.33	684.0	117.8	77	74
24	2.2	303		0.40	0.33	684.8	120.8	77	74
25	2.3	301		0.44	0.33	685.6	96.2	77	75
26	2.2	303		0.42	0.33	686.3	117.8	77	75
27	2.2	301		0.43	0.33	687.1	116.1	78	75
28	2.2	302		0.40	0.33	687.9	105.4	78	75
29	2.2	301		0.42	0.33	688.6	102.8	78	75
30	2.2	302		0.40	0.33	689.3	116.4	78	75
						690.073			
AVG.		302	-9.83	0.42	0.33	22.397	110.2	74	



**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 2 OUTLET**  
**U2O-M201A/202-R1**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	295.50 degrees F
Ts	=	755.50 degrees R
%O2, dry	=	11.00 %
%O2, wet	=	9.02 %
Bws	=	0.18
Pbar	=	29.95 in. Hg
Pstatic	=	-10.67 in. H2O
Ps	=	29.17 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	27.61 lb/lb-mole
Tm	=	85.00 degrees F
Tm	=	545.00 degrees R
Md	=	29.72 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	45.99 ft/sec
μ	=	216.812
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.91
D50T (for Nre< 3162)	=	10.45
Qs (=QI for Nre< 3162)	=	0.567
Nre	=	2409
D50LL (for Nre >= 3162)	=	10.56
D50T (for Nre >= 3162)	=	10.78
Qs (=QI for Nre >= 3162)	=	0.543
Sampling Rate ΔH	=	0.33 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.32 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.34 in. H2O
D (calc. nozzle dia.)	=	0.194 in.
D (actual selected)	=	0.191 in.
Vn	=	47.50 ft/sec
ΔPmin allowed	=	0.208 in. H2O
ΔPmax allowed	=	0.766 in. H2O
Dwell Time at Point 1 (T1) is:	=	2.12 min.
<b>Actual Run Data</b>		
Ts	=	302.10 degrees F
Ts	=	762.10 degrees R
%O2, dry	=	9.98 %
%O2, wet	=	8.36 %
Vwc	=	3.907
Vsg	=	0.330
Bws	=	0.1621
Pbar	=	29.84 in. Hg
Pstatic	=	-9.83 in. H2O
Ps	=	29.12 in. Hg
Mw (same as Ms)	=	27.94 lb/lb-mole
Tm	=	74.25 degrees F
Tm	=	534.3 degrees R
Md	=	29.86 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.33 in. H2O
Meter Volume	=	22.397 dcf
Meter Volume at Std. Cond.	=	21.895 dscf
Avg. Square Root of Delta P	=	0.6465
Velocity	=	44.93 ft/sec
Area of Nozzle	=	0.0001990 ft <sup>2</sup>
Test Duration	=	66.3 min.
Isokinetics (rounded to nearest whole #)	=	109%
No. of Points < 71% or > 129% Iso.	=	2
ΔPmin allowed	=	0.223 in. H2O
ΔPmax allowed	=	0.814 in. H2O
Actual ΔPmin from run	=	0.37 in. H2O
Actual ΔPmax from run	=	0.47 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	219.432
Qs	=	0.585 acfm
D50 (for PM-10 cyclone I)	=	10.31
Nre (actual test conditions)	=	2457
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.42
Cr	=	1.24
D50-1	=	2.26
Z	=	0.94
Recalculated Cr	=	1.26
Recalculated D50 (for cyclone IV)	=	2.25
Recalculated D50-1	=	2.25
Recalculated Z	=	1.00

**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 OUTLET**

Run Number **U2O-M201A/202-R1**  
 Stack Gas Viscosity (micropoise) 216.812  
 Cyclone Flow Rate (dscf/min) 0.330  
 Cyclone Flow Rate (acfm) 0.585  
 D50 10.314

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 219.432  
 Cyclone Flow Rate (acfm) 0.585  
 Vmstd - dscf 21.895  
 Sample Time - min 66.3  
 Ts 302.100  
 % O2 9.980  
 % Water 16.213  
 Vwc 3.907  
 Vsg 0.330  
 Ps 29.117  
 Mw 27.941  
 Cp 0.84  
 Nozzle Size(s) Used For Test: 0.191  
 Minimum dP During Test: 0.37  
 Maximum dP During Test: 0.47

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax Step 1	Conditional Rmax Step 2	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	137.465	0.280	0.775	106.528	1.218	1.218	167.401	2.350	5.802	OK	OK OK OK
2	0.129	107.355	0.268	0.763	81.947	1.226	1.226	131.576	1.390	3.585		
3	0.148	81.560	0.248	0.744	60.649	1.238	1.238	101.000	0.762	2.112		
4	0.158	71.563	0.235	0.731	52.279	1.246	1.246	89.197	0.566	1.647		
5	0.179	55.757	0.202	0.695	38.778	1.267	1.267	70.622	0.311	1.033		
6	0.191	48.971	0.180	0.670	32.795	1.280	1.280	62.694	0.223	0.814		
7	0.201	44.219	0.159	0.644	28.479	1.293	1.293	57.165	0.168	0.677		
8	0.230	33.771	0.085	0.537	18.125	1.335	1.335	45.097	0.068	0.421		
9	0.253	27.910	0.011	0.351	9.787	1.376	1.376	38.400	0.020	0.305		
10	0.274	23.796	-0.069	0.500	11.898	1.418	1.418	33.741	0.029	0.236		
11	0.296	20.390	-0.167	0.500	10.195	1.467	1.467	29.915	0.022	0.185		

**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 OUTLET**

**SAMPLING DATA**

Run number	<b>U20-M201A/202-R1</b>
Corrected sample volume	21.895 dscf
	0.620 dscm
Corrected flow rate	146594 dscfm
O2 Content	9.98 %
CO2 Content	9.16 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
FILTERABLE PM2.5		
Probe Wash	0.00130	0.00000
Filter	0.00040	0.00040
CONDENSIBLE PM2.5		
Inorganic CPM	0.03240	0.03059
Organic CPM	0.00880	0.00861
TOTAL CPM	0.04120	0.03920
TOTAL PM	0.04290	0.03960

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	64.3671	64.3684	0.00130	230
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00221	
Max. Allowable Blank			0.00180	
Blank Value Used for Correction			0.00180	
Filter	0.3469	0.3473	0.00040	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.03240	250	79.04%
Organic CPM in Sample	0.00880	256	20.96%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00430	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0003	0.0216	0.0061	0.0276	0.0279
Corrected to 7% O2 (gr/dscf)	0.0004	0.0274	0.0077	0.0352	0.0355
Corrected to 12% CO2 (gr/dscf)	0.0004	0.0282	0.0079	0.0362	0.0366
Actual Grain Loading (mg/dscm)	0.65	49.34	13.88	63.23	63.87
Corrected to 7% O2 (mg/dscm)	0.82	62.81	17.67	80.48	81.30
Corrected to 12% CO2 (mg/dscm)	0.85	64.64	18.19	82.83	83.67
Mass Rate (lb/hr)	0.35	27.09	7.62	34.72	35.07

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).

**RUN NUMBER PRE-U2O-M201A-R2**

Date 04/11/13  
 Start Time 7:32  
 End Time 8:38  
 Meter Box dH@ 1.7473  
 Barometric 29.84 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 30

**METHOD 3 AND 4 DATA**

%O2 9.98  
 %CO2 9.16  
 % Water 20.00 %

**METHOD 3 DATA**

%CO 0.0 Md 29.86  
 %N2 80.9 Ms 27.49  
 O2+CO2 19.1 Ps 29.14  
 %EA 88 Fo 1.192

**METHOD 2 RESULTS**

Velocity 45.28 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	304	-10.00	0.38	0.38	72	72
2	304	-9.00	0.40	0.40	72	72
3	305		0.43	0.43	73	72
4	305		0.42	0.42	73	72
5	301		0.44	0.44	74	72
6	302		0.43	0.43	74	72
7	303		0.40	0.40	74	72
8	302		0.37	0.37	74	72
9	301		0.39	0.39	74	72
10	302		0.38	0.38	74	72
11	301		0.47	0.47	74	72
12	302		0.45	0.45	74	72
13	301		0.43	0.43	74	72
14	302		0.43	0.43	74	72
15	301		0.40	0.40	75	73
16	302		0.46	0.46	75	73
17	300		0.44	0.44	75	73
18	300		0.43	0.43	77	74
19	302		0.41	0.41	77	74
20	304		0.39	0.39	77	74
21	303		0.45	0.45	77	74
22	301		0.42	0.42	77	74
23	302		0.42	0.42	77	74
24	303		0.40	0.40	77	74
25	301		0.44	0.44	77	75
26	303		0.42	0.42	77	75
27	301		0.43	0.43	78	75
28	302		0.40	0.40	78	75
29	301		0.42	0.42	78	75
30	302		0.40	0.40	78	75
AVG.	302	-9.50	0.42	0.42	74	

**EPA METHOD 201A**  
 PRELIMINARY TRAVERSE  
**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U2O-M201A-R2

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft3/min)	ORIFICE HEAD (in. H2O)
302	0.568	0.31
252	0.522	0.30
352	0.615	0.32

Nre	=	2390
-----	---	------

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.37  
 Max. dP from Traverse: 0.47  
 Average dP from Traverse: 0.42

**dPmin and dPmax Calculations at Stack Temperature of 302**

Stack Gas Viscosity (micropoise) 216.060  
 Stack Gas Viscosity (micropoise) @ -50 °F 204.405  
 Stack Gas Viscosity (micropoise) @ +50 °F 227.503

**D (calc. nozzle dia.) = 0.196**

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)
1	0.114	OK OK OK	133.676	0.280	0.775	103.549	1.218	1.218	162.816	2.186	5.405
2	0.129		104.396	0.267	0.763	79.639	1.226	1.226	127.982	1.293	3.340
3	0.148		79.312	0.247	0.743	58.918	1.239	1.239	98.253	0.708	1.968
4	0.158		69.590	0.234	0.730	50.773	1.247	1.247	86.777	0.526	1.535
5	0.179		54.220	0.201	0.694	37.629	1.267	1.267	68.719	0.289	0.963
6	0.191		47.621	0.178	0.668	31.801	1.281	1.281	61.011	0.206	0.759
7	0.201		43.000	0.157	0.642	27.593	1.294	1.294	55.636	0.155	0.631
8	0.230		32.840	0.082	0.532	17.466	1.337	1.337	43.906	0.062	0.393
9	0.253		27.141	0.007	0.331	8.988	1.378	1.378	37.396	0.016	0.285
10	0.274		23.140	-0.074	0.500	11.570	1.420	1.420	32.867	0.027	0.220
11	0.296		19.828	-0.173	0.500	9.914	1.470	1.470	29.148	0.020	0.173

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **1.91** minutes

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: 0.42

**Run Number U2O-M201A/202-R2**

Date	04/11/13
Start Time	10:14
End Time	11:14
Stack Length	132 inches
Stack Width	105 inches
Nozzle I.D.	0.179 inches
Meter Box Gamma	0.9910
Meter Box dH@	1.7473
Barometric	29.86 in.Hg
Cp	0.84
Test Duration	60.60 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	81.0	81.0
Impinger 2	0.0	0.0	0.0
Impinger 3	100.0	88.0	-12.0
Impinger 4			0.0
Impinger 5			0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	100.0	169.0	69.0
Silica gel (g)	250.0	263.1	13.1

METHOD 1-4 RESULTS	
Metered Volume	20.157 dcf
Volume @ Std.Cond.	19.469 dscf
% Water	16.57 %
% Isokinetics	119.4 %
Velocity	45.59 ft/sec
Actual Flow	263289 acfm
Std. Flow	177634 scfm
Dry Std. Flow	148208 dscfm

METHOD 3 DATA			
%O2	9.51	Md	29.91
%CO2	9.59	Ms	27.94
%CO	0.0	Ps	29.12
%N2	80.9	Fo	1.188
O2+CO2	19.1	%EA	80

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	1.9	300	-9.00	0.38	0.31	692.737	135.4	77	77
2	2.1	302	-10.00	0.47	0.31	693.4	99.5	79	78
3	2.2	303	-10.00	0.49	0.31	694.0	124.0	79	79
4	2.0	303	-11.00	0.44	0.31	694.8	144.1	79	78
5	2.0	302	-10.00	0.41	0.31	695.6	111.9	79	78
6	2.0	301	-10.00	0.43	0.31	696.2	109.0	80	79
7	2.0	301		0.43	0.31	696.8	109.0	80	79
8	2.0	302		0.44	0.31	697.4	125.9	80	78
9	2.1	301		0.46	0.31	698.1	117.0	81	79
10	2.0	302		0.42	0.31	698.8	110.2	81	79
11	2.1	300		0.45	0.31	699.4	118.2	81	79
12	2.0	302		0.42	0.31	700.1	128.5	82	79
13	2.0	303		0.42	0.31	700.8	110.2	82	79
14	2.1	301		0.46	0.31	701.4	116.9	82	79
15	1.9	301		0.40	0.31	702.1	138.3	83	80
16	2.1	304		0.47	0.31	702.8	115.6	83	80
17	2.1	301		0.45	0.31	703.5	117.9	83	80
18	2.1	303		0.48	0.31	704.2	114.2	83	81
19	2.0	304		0.42	0.31	704.9	128.3	83	81
20	2.0	302		0.41	0.31	705.6	129.7	83	81
21	1.9	305		0.40	0.31	706.3	138.5	83	81
22	1.9	303		0.38	0.31	707.0	121.5	84	81
23	2.0	303		0.41	0.31	707.6	111.1	84	81
24	2.0	301		0.43	0.31	708.2	126.4	84	81
25	2.1	300		0.45	0.31	708.9	117.5	84	82
26	2.0	299		0.42	0.31	709.6	127.7	84	82
27	2.0	302		0.43	0.31	710.3	108.4	84	82
28	2.1	302		0.45	0.31	710.9	117.5	85	83
29	2.0	301		0.41	0.31	711.6	129.1	85	83
30	1.9	300		0.40	0.31	712.3	116.7	85	83
						712.894			
<b>AVG.</b>		302	-10.00	0.43	0.31	20.157	120.6	81	

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 2 OUTLET**  
**U2O-M201A/202-R2**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	302.10 degrees F
Ts	=	762.10 degrees R
%O2, dry	=	9.98 %
%O2, wet	=	7.98 %
Bws	=	0.20
Pbar	=	29.84 in. Hg
Pstatic	=	-9.50 in. H2O
Ps	=	29.14 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	27.49 lb/lb-mole
Tm	=	74.25 degrees F
Tm	=	534.25 degrees R
Md	=	29.86 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	45.28 ft/sec
μ	=	216.060
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.88
D50T (for Nre< 3162)	=	10.44
Qs (=QI for Nre< 3162)	=	0.568
Nre	=	2390
D50LL (for Nre >= 3162)	=	10.56
D50T (for Nre >= 3162)	=	10.78
Qs (=QI for Nre >= 3162)	=	0.543
Sampling Rate ΔH	=	0.31 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.30 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.32 in. H2O
D (calc. nozzle dia.)	=	0.196 in.
D (actual selected)	=	0.179 in.
Vn	=	54.22 ft/sec
ΔPmin allowed	=	0.289 in. H2O
ΔPmax allowed	=	0.963 in. H2O
Dwell Time at Point 1 (T1) is:	=	1.91 min.
<b>Actual Run Data</b>		
Ts	=	301.80 degrees F
Ts	=	761.80 degrees R
%O2, dry	=	9.51 %
%O2, wet	=	7.93 %
Vwc	=	3.248
Vsg	=	0.618
Bws	=	0.1657
Pbar	=	29.86 in. Hg
Pstatic	=	-10.00 in. H2O
Ps	=	29.12 in. Hg
Mw (same as Ms)	=	27.94 lb/lb-mole
Tm	=	81.07 degrees F
Tm	=	541.1 degrees R
Md	=	29.91 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.31 in. H2O
Meter Volume	=	20.157 dcf
Meter Volume at Std. Cond.	=	19.469 dscf
Avg. Square Root of Delta P	=	0.6562
Velocity	=	45.59 ft/sec
Area of Nozzle	=	0.0001748 ft <sup>2</sup>
Test Duration	=	60.6 min.
Isokinetics (rounded to nearest whole #)	=	119%
No. of Points < 71% or > 129% Iso.	=	5
Actual ΔPmin from run	=	0.38 in. H2O
Actual ΔPmax from run	=	0.49 in. H2O
Actual ΔPmin from run	=	0.38 in. H2O
Actual ΔPmax from run	=	0.49 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	218.818
Qs	=	0.571 acfm
D50 (for PM-10 cyclone I)	=	10.47
Nre (actual test conditions)	=	2407
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.48
Cr	=	1.24
D50-1	=	2.33
Z	=	0.94
Recalculated Cr	=	1.25
Recalculated D50 (for cyclone IV)	=	2.31
Recalculated D50-1	=	2.31
Recalculated Z	=	1.00

**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 OUTLET**

Run Number **U2O-M201A/202-R2**

Stack Gas Viscosity (micropoise) 216.060  
 Cyclone Flow Rate (dscf/min) 0.321  
 Cyclone Flow Rate (acfm) 0.571  
 D50 10.469

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 218.818  
 Cyclone Flow Rate (acfm) 0.571

Vmstd - dscf 19.469  
 Sample Time - min 60.6  
 Ts 301.800  
 % O2 9.510  
 % Water 16.566  
 Vwc 3.248  
 Vsg 0.618  
 Ps 29.125  
 Mw 27.941  
 Cp 0.84

Nozzle Size(s) Used For Test: 0.179  
 Minimum dP During Test: 0.38  
 Maximum dP During Test: 0.49

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Step 1	Conditional Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	134.207	0.280	0.774	103.930	1.218	1.218	163.484	2.238	5.538	OK	OK
2	0.129	104.811	0.267	0.763	79.920	1.226	1.226	128.514	1.323	3.422		
3	0.148	79.627	0.247	0.742	59.110	1.239	1.239	98.670	0.724	2.017		
4	0.158	69.867	0.234	0.729	50.928	1.247	1.247	87.150	0.537	1.574		
5	0.179	54.435	0.200	0.693	37.722	1.268	1.268	69.022	0.295	0.987		
6	0.191	47.810	0.177	0.666	31.863	1.282	1.282	61.286	0.210	0.778		
7	0.201	43.171	0.156	0.640	27.631	1.295	1.295	55.891	0.158	0.647		
8	0.230	32.971	0.080	0.528	17.421	1.338	1.338	44.117	0.063	0.403		
9	0.253	27.249	0.005	0.314	8.559	1.379	1.379	37.583	0.015	0.293		
10	0.274	23.232	-0.077	0.500	11.616	1.422	1.422	33.037	0.028	0.226		
11	0.296	19.907	-0.177	0.500	9.953	1.472	1.472	29.305	0.021	0.178		



**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 OUTLET**

**SAMPLING DATA**

Run number	<b>U20-M201A/202-R2</b>
Corrected sample volume	19.469 dscf
	0.551 dscm
Corrected flow rate	148208 dscfm
O2 Content	9.51 %
CO2 Content	9.59 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
FILTERABLE PM2.5		
Probe Wash	0.00050	0.00000
Filter	0.00040	0.00040
CONDENSIBLE PM2.5		
Inorganic CPM	0.00360	0.00179
Organic CPM	0.00640	0.00621
TOTAL CPM	0.01000	0.00800
TOTAL PM	0.01090	0.00840

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	69.0587	69.0592	0.00050	260
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00250	
Max. Allowable Blank			0.00204	
Blank Value Used for Correction			0.00204	
Filter	0.3559	0.3563	0.00040	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.00360	240	32.56%
Organic CPM in Sample	0.00640	206	67.44%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00410	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0003	0.0014	0.0049	0.0063	0.0067
Corrected to 7% O2 (gr/dscf)	0.0004	0.0017	0.0060	0.0077	0.0081
Corrected to 12% CO2 (gr/dscf)	0.0004	0.0018	0.0062	0.0079	0.0083
Actual Grain Loading (mg/dscf)	0.73	3.25	11.26	14.51	15.24
Corrected to 7% O2 (mg/dscf)	0.89	3.97	13.74	17.71	18.59
Corrected to 12% CO2 (mg/dscf)	0.91	4.07	14.09	18.16	19.07
Mass Rate (lb/hr)	0.40	1.81	6.25	8.06	8.46

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).

**RUN NUMBER PRE-U20-M201A-R3**

Date 04/11/13  
 Start Time 10:14  
 End Time 11:14  
 Meter Box dH@ 1.7473  
 Barometric 29.86 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 30

**METHOD 3 AND 4 DATA**

%O2 9.51  
 %CO2 9.59  
 % Water 20.00 %

**METHOD 3 DATA**

%CO 0.0 Md 29.91  
 %N2 80.9 Ms 27.53  
 O2+CO2 19.1 Ps 29.16  
 %EA Fo 1.188  
 %EA 80

**METHOD 2 RESULTS**

Velocity 45.90 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	300	-9.00	0.38	0.38	77	77
2	302	-10.00	0.47	0.47	79	78
3	303		0.49	0.49	79	79
4	303		0.44	0.44	79	78
5	302		0.41	0.41	79	78
6	301		0.43	0.43	80	79
7	301		0.43	0.43	80	79
8	302		0.44	0.44	80	78
9	301		0.46	0.46	81	79
10	302		0.42	0.42	81	79
11	300		0.45	0.45	81	79
12	302		0.42	0.42	82	79
13	303		0.42	0.42	82	79
14	301		0.46	0.46	82	79
15	301		0.40	0.40	83	80
16	304		0.47	0.47	83	80
17	301		0.45	0.45	83	80
18	303		0.48	0.48	83	81
19	304		0.42	0.42	83	81
20	302		0.41	0.41	83	81
21	305		0.40	0.40	83	81
22	303		0.38	0.38	84	81
23	303		0.41	0.41	84	81
24	301		0.43	0.43	84	81
25	300		0.45	0.45	84	82
26	299		0.42	0.42	84	82
27	302		0.43	0.43	84	82
28	302		0.45	0.45	85	83
29	301		0.41	0.41	85	83
30	300		0.40	0.40	85	83
AVG.	302	-9.50	0.43	0.43	81	

**EPA METHOD 201A**  
 PRELIMINARY TRAVERSE  
**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U20-M201A-R3

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft <sup>3</sup> /min)	ORIFICE HEAD (in. H <sub>2</sub> O)		
302	0.567	0.31	Nre	= 2393
252	0.521	0.30		
352	0.614	0.32		

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.38  
 Max. dP from Traverse: 0.49  
 Average dP from Traverse: 0.43

**dPmin and dPmax Calculations at Stack Temperature of 302**

Stack Gas Viscosity (micropoise) 215.768  
 Stack Gas Viscosity (micropoise) @ -50 °F 204.112  
 Stack Gas Viscosity (micropoise) @ +50 °F 227.213

**D (calc. nozzle dia.) = 0.194**

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H <sub>2</sub> O)	dPmax (in. H <sub>2</sub> O)
1	0.114		133.358	0.280	0.775	103.299	1.218	1.218	162.432	2.181	5.393
2	0.129		104.148	0.267	0.763	79.445	1.226	1.226	127.680	1.290	3.332
3	0.148		79.123	0.247	0.743	58.773	1.239	1.239	98.023	0.706	1.964
4	0.158		69.425	0.234	0.730	50.647	1.247	1.247	86.574	0.524	1.532
5	0.179	OK	54.091	0.201	0.694	37.533	1.267	1.267	68.559	0.288	0.961
6	0.191	OK	47.507	0.178	0.668	31.718	1.281	1.281	60.870	0.206	0.757
7	0.201	OK	42.898	0.157	0.642	27.519	1.294	1.294	55.508	0.155	0.630
8	0.230		32.762	0.082	0.531	17.411	1.337	1.337	43.806	0.062	0.392
9	0.253		27.076	0.007	0.329	8.917	1.378	1.378	37.311	0.016	0.285
10	0.274		23.085	-0.074	0.500	11.542	1.421	1.421	32.793	0.027	0.220
11	0.296		19.781	-0.174	0.500	9.890	1.470	1.470	29.083	0.020	0.173

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **1.88** minutes

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: 0.43

**Run Number U2O-M201A/202-R3**

Date	04/11/13
Start Time	12:08
End Time	13:08
Stack Length	132 inches
Stack Width	105 inches
Nozzle I.D.	0.179 inches
Meter Box Gamma	0.9910
Meter Box dH@	1.7473
Barometric	29.87 in.Hg
Cp	0.84
Test Duration	60.30 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	77.0	77.0
Impinger 2	0.0	1.0	1.0
Impinger 3	100.0	96.0	-4.0
Impinger 4			0.0
Impinger 5			0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	<b>100.0</b>	<b>174.0</b>	<b>74.0</b>
Silica gel (g)	250.0	266.3	16.3

METHOD 1-4 RESULTS	
Metered Volume	20.184 dcf
Volume @ Std.Cond.	19.308 dscf
% Water	18.05 %
% Isokinetics	120.2 %
Velocity	46.09 ft/sec
Actual Flow	266193 acfm
Std. Flow	179000 scfm
Dry Std. Flow	146697 dscfm

METHOD 3 DATA			
%O2	9.81	Md	29.90
%CO2	9.44	Ms	27.75
%CO	0.0	Ps	29.12
%N2	80.8	Fo	1.175
O2+CO2	19.3	%EA	85

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	1.9	302	-10.0	0.38	0.31	718.174	108.7	86	84
2	1.9	303	-11.0	0.40	0.31	718.7	139.5	87	84
3	2.0	302	-11.0	0.42	0.31	719.4	110.8	87	84
4	2.0	304	-9.0	0.44	0.31	720.0	126.6	86	84
5	2.0	302	-10.0	0.43	0.31	720.7	127.8	86	84
6	2.1	302	-10.0	0.44	0.31	721.4	120.4	86	84
7	2.0	309		0.42	0.31	722.1	130.0	86	84
8	2.1	310		0.47	0.31	722.8	117.1	86	84
9	1.9	307		0.41	0.31	723.5	118.4	87	84
10	2.0	303		0.43	0.31	724.1	127.7	87	85
11	2.0	304		0.45	0.31	724.8	107.1	87	85
12	2.1	303		0.46	0.31	725.4	117.6	87	85
13	2.0	304		0.43	0.31	726.1	127.8	87	85
14	2.0	304		0.42	0.31	726.8	129.2	88	85
15	1.9	303		0.40	0.31	727.5	139.2	88	85
16	2.2	305		0.51	0.31	728.2	106.6	88	85
17	2.1	303		0.48	0.31	728.9	115.0	88	85
18	2.0	306		0.45	0.31	729.6	125.0	88	85
19	2.0	303		0.44	0.31	730.3	125.9	89	86
20	2.1	300		0.46	0.31	731.0	117.0	89	86
21	2.1	302		0.47	0.31	731.7	115.9	89	86
22	2.2	305		0.52	0.31	732.4	105.5	88	86
23	2.0	307		0.45	0.31	733.1	107.1	88	86
24	2.0	308		0.44	0.31	733.7	126.4	88	86
25	1.9	305		0.40	0.31	734.4	119.4	88	86
26	1.9	303		0.38	0.31	735.0	122.3	88	86
27	2.0	305		0.43	0.31	735.6	127.3	90	87
28	1.9	307		0.40	0.31	736.3	139.1	90	87
29	2.0	304		0.42	0.31	737.0	110.3	90	87
30	2.0	303		0.44	0.31	737.6	136.1	90	87
						738.358			
AVG.		304	-10.17	0.44	0.31	20.184	121.6	86	

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 2 OUTLET**  
**U2O-M201A/202-R3**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	301.80 degrees F
Ts	=	761.80 degrees R
%O2, dry	=	9.51 %
%O2, wet	=	7.61 %
Bws	=	0.20
Pbar	=	29.86 in. Hg
Pstatic	=	-9.50 in. H2O
Ps	=	29.16 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	27.53 lb/lb-mole
Tm	=	81.07 degrees F
Tm	=	541.07 degrees R
Md	=	29.91 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	45.90 ft/sec
μ	=	215.768
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.88
D50T (for Nre< 3162)	=	10.44
Qs (=QI for Nre< 3162)	=	0.567
Nre	=	2393
D50LL (for Nre >= 3162)	=	10.56
D50T (for Nre >= 3162)	=	10.78
Qs (=QI for Nre >= 3162)	=	0.542
Sampling Rate ΔH	=	0.31 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.30 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.32 in. H2O
D (calc. nozzle dia.)	=	0.194 in.
D (actual selected)	=	0.179 in.
Vn	=	54.09 ft/sec
ΔPmin allowed	=	0.288 in. H2O
ΔPmax allowed	=	0.961 in. H2O
Dwell Time at Point 1 (T1) is:	=	1.88 min.
<b>Actual Run Data</b>		
Ts	=	304.27 degrees F
Ts	=	764.27 degrees R
%O2, dry	=	9.81 %
%O2, wet	=	8.04 %
Vwc	=	3.483
Vsg	=	0.769
Bws	=	0.1805
Pbar	=	29.87 in. Hg
Pstatic	=	-10.17 in. H2O
Ps	=	29.12 in. Hg
Mw (same as Ms)	=	27.75 lb/lb-mole
Tm	=	86.48 degrees F
Tm	=	546.5 degrees R
Md	=	29.90 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.31 in. H2O
Meter Volume	=	20.184 dcf
Meter Volume at Std. Cond.	=	19.308 dscf
Avg. Square Root of Delta P	=	0.6601
Velocity	=	46.09 ft/sec
Area of Nozzle	=	0.0001748 in <sup>2</sup>
Test Duration	=	60.3 min.
Isokinetics (rounded to nearest whole #)	=	120%
No. of Points < 71% or > 129% Iso.	=	5
Actual ΔPmin from run	=	0.38 in. H2O
Actual ΔPmax from run	=	0.52 in. H2O
Actual ΔPmin from run	=	0.38 in. H2O
Actual ΔPmax from run	=	0.52 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	218.217
Qs	=	0.581 acfm
D50 (for PM-10 cyclone I)	=	10.34
Nre (actual test conditions)	=	2433
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.43
Cr	=	1.24
D50-1	=	2.28
Z	=	0.94
Recalculated Cr	=	1.26
Recalculated D50 (for cyclone IV)	=	2.26
Recalculated D50-1	=	2.26
Recalculated Z	=	1.00

**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 OUTLET**

Run Number **U2O-M201A/202-R3**

Stack Gas Viscosity (micropoise) 215.768  
 Cyclone Flow Rate (dscf/min) 0.320  
 Cyclone Flow Rate (acfm) 0.581  
 D50 10.338

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 218.217  
 Cyclone Flow Rate (acfm) 0.581

Vmstd - dscf 19.308  
 Sample Time - min 60.3  
 Ts 304.267  
 % O2 9.810  
 % Water 18.046  
 Vwc 3.483  
 Vsg 0.769  
 Ps 29.122  
 Mw 27.755  
 Cp 0.84

Nozzle Size(s) Used For Test: 0.179  
 Minimum dP During Test: 0.38  
 Maximum dP During Test: 0.52

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Step 1	Conditional Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	136.630	0.280	0.775	105.879	1.218	1.218	166.385	2.300	5.679	OK	OK OK OK
2	0.129	106.703	0.268	0.763	81.447	1.226	1.226	130.778	1.361	3.508		
3	0.148	81.065	0.248	0.744	60.278	1.238	1.238	100.388	0.745	2.067		
4	0.158	71.128	0.235	0.730	51.958	1.246	1.246	88.657	0.554	1.612		
5	0.179	55.418	0.202	0.695	38.539	1.267	1.267	70.195	0.305	1.011		
6	0.191	48.673	0.180	0.670	32.592	1.280	1.280	62.315	0.218	0.797		
7	0.201	43.950	0.159	0.644	28.302	1.293	1.293	56.820	0.164	0.662		
8	0.230	33.566	0.085	0.536	18.008	1.335	1.335	44.826	0.067	0.412		
9	0.253	27.741	0.011	0.350	9.707	1.376	1.376	38.169	0.019	0.299		
10	0.274	23.651	-0.069	0.500	11.826	1.418	1.418	33.538	0.029	0.231		
11	0.296	20.266	-0.167	0.500	10.133	1.467	1.467	29.736	0.021	0.181		

**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 2 OUTLET**

**SAMPLING DATA**

Run number	<b>U20-M201A/202-R3</b>
Corrected sample volume	19.308 dscf
	0.547 dscm
Corrected flow rate	146697 dscfm
O2 Content	9.81 %
CO2 Content	9.44 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
FILTERABLE PM2.5		
Probe Wash	0.00070	0.00000
Filter	0.00050	0.00050
CONDENSIBLE PM2.5		
Inorganic CPM	0.00430	0.00249
Organic CPM	0.00870	0.00851
TOTAL CPM	0.01300	0.01100
TOTAL PM	0.01420	0.01150

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	63.9044	63.9051	0.00070	120
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00115	
Max. Allowable Blank			0.00094	
Blank Value Used for Correction			0.00094	
Filter	0.3586	0.3591	0.00050	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.00430	250	29.73%
Organic CPM in Sample	0.00870	214	70.27%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00420	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0004	0.0020	0.0068	0.0088	0.0092
Corrected to 7% O2 (gr/dscf)	0.0005	0.0025	0.0085	0.0110	0.0115
Corrected to 12% CO2 (gr/dscf)	0.0005	0.0025	0.0086	0.0112	0.0117
Actual Grain Loading (mg/dscf)	0.91	4.56	15.56	20.12	21.03
Corrected to 7% O2 (mg/dscf)	1.15	5.72	19.50	25.22	26.36
Corrected to 12% CO2 (mg/dscf)	1.16	5.80	19.78	25.57	26.74
Mass Rate (lb/hr)	0.50	2.51	8.55	11.05	11.56

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).

## **Appendix D.3**

### **EPA Method 201A/202 Data and Results: Unit 3 FF Outlet**



**RUN NUMBER PRE-U3O-M201A-R1**

Date 04/09/13  
 Meter Box dH@ 1.7473  
 Barometric 30.02 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 30

**METHOD 3 AND 4 DATA**

%O2 10.0  
 %CO2 10.00  
 % Water 16.00 %

**METHOD 3 DATA**

%CO	0.0	Md	30.00
%N2	80.0	Ms	28.08
O2+CO2	20.0	Ps	29.10
		Fo	1.090
		%EA	90

**METHOD 2 RESULTS**

Velocity 50.32 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	305	-13.00	0.52	0.52	85	85
2	308	-11.00	0.51	0.51		
3	304	-14.00	0.56	0.56		
4	305	-12.00	0.55	0.55		
5	303	-12.00	0.52	0.52		
6	304	-13.00	0.50	0.50		
7	303		0.51	0.51		
8	304		0.54	0.54		
9	305		0.53	0.53		
10	303		0.54	0.54		
11	306		0.54	0.54		
12	305		0.52	0.52		
13	304		0.51	0.51		
14	303		0.56	0.56		
15	305		0.52	0.52		
16	300		0.55	0.55		
17	304		0.56	0.56		
18	300		0.53	0.53		
19	300		0.52	0.52		
20	301		0.52	0.52		
21	297		0.55	0.55		
22	303		0.53	0.53		
23	300		0.56	0.56		
24	300		0.46	0.46		
25	296		0.55	0.55		
26	299		0.43	0.43		
27	302		0.54	0.54		
28	303		0.56	0.56		
29	300		0.49	0.49		
30	300		0.52	0.52		
<b>AVG.</b>	302	-12.50	0.53	0.53	85	

**EPA METHOD 201A**

PRELIMINARY TRAVERSE

**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U3O-M201A-R1

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft3/min)	ORIFICE HEAD (in. H2O)	
302	0.573	<b>0.35</b>	Nre = 2416
252	0.527	0.34	
352	0.620	0.36	

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.43  
 Max. dP from Traverse: 0.56  
 Average dP from Traverse: 0.53

**dPmin and dPmax Calculations at Stack Temperature of 302**

Stack Gas Viscosity (micropoise) 219.701  
 Stack Gas Viscosity (micropoise) @ -50 °F 208.092  
 Stack Gas Viscosity (micropoise) @ +50 °F 231.095

**D (calc. nozzle dia.) = 0.187**

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)
1	0.114		134.787	0.280	0.774	104.380	1.218	1.218	164.190	2.265	5.604
2	0.129		105.264	0.267	0.763	80.266	1.226	1.226	129.068	1.339	3.463
3	0.148		79.971	0.247	0.742	59.366	1.239	1.239	99.095	0.733	2.041
4	0.158		70.169	0.234	0.729	51.150	1.247	1.247	87.526	0.544	1.593
5	0.179	OK	54.670	0.200	0.693	37.887	1.268	1.268	69.320	0.298	0.999
6	0.191	OK	48.017	0.177	0.666	32.003	1.282	1.282	61.549	0.213	0.788
7	0.201	OK	43.358	0.156	0.640	27.753	1.295	1.295	56.131	0.160	0.655
8	0.230		33.113	0.080	0.528	17.500	1.338	1.338	44.306	0.064	0.408
9	0.253		27.366	0.005	0.315	8.613	1.379	1.379	37.744	0.015	0.296
10	0.274		23.332	-0.077	0.500	11.666	1.422	1.422	33.179	0.028	0.229
11	0.296		19.993	-0.177	0.500	9.996	1.472	1.472	29.430	0.021	0.180

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **1.99 minutes**

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: **0.53**

**Run Number U30-M201A/202-R1**

Date	04/09/13	<b>METHOD 4 DATA</b>			
Start Time	11:56	<b>Impinger Volume (mL)</b>			
End Time	12:58	<u>Initial</u>	<u>Final</u>	<u>Net</u>	
Stack Length	132 inches	Impinger 1	0.0	86.0	86.0
Stack Width	105 inches	Impinger 2	0.0	10.0	10.0
Nozzle I.D.	0.179 inches	Impinger 3	100.0	89.0	-11.0
Meter Box Gamma	0.991	Impinger 4			0.0
Meter Box dH@	1.7473	Impinger 5			0.0
Barometric	30.04 in.Hg	Impinger 6			0.0
Cp	0.84	Impinger 7			0.0
Test Duration	57.50 minutes	<b>Total</b>	100.0	185.0	85.0
		Silica gel (g)	250.0	262.7	12.7

<b>METHOD 1-4 RESULTS</b>	
Metered Volume	18.528 dcf
Volume @ Std.Cond.	17.918 dscf
% Water	20.43 %
% Isokinetics	110.7 %
Velocity	50.50 ft/sec
Actual Flow	291622 acfm
Std. Flow	194778 scfm
Dry Std. Flow	154991 dscfm

<b>METHOD 3 DATA</b>			
%O2	9.57	Md	29.96
%CO2	9.84	Ms	27.51
%CO	0.0	Ps	29.13
%N2	80.6	Fo	1.151
O2+CO2	19.4	%EA	82

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	2.0	303	-12.0	0.55	0.35	517.799	102.0	75	75
2	2.0	304	-13.0	0.53	0.35	518.4	120.5	78	78
3	1.9	309	-12.0	0.52	0.35	519.1	109.4	82	81
4	1.9	310	-11.0	0.50	0.35	519.7	111.5	83	81
5	1.9	310	-12.0	0.51	0.35	520.3	110.4	83	81
6	2.0	308	-14.0	0.56	0.35	520.9	100.0	83	81
7	1.9	302		0.51	0.35	521.5	127.9	84	82
8	1.9	310		0.52	0.35	522.2	127.3	84	82
9	1.9	316		0.54	0.35	522.9	125.4	84	82
10	2.0	320		0.53	0.35	523.6	103.3	85	82
11	1.9	312		0.50	0.35	524.2	111.3	85	82
12	1.9	310		0.52	0.35	524.8	109.0	85	82
13	2.0	315		0.55	0.35	525.4	101.0	85	83
14	1.9	308		0.49	0.35	526.0	112.0	86	83
15	2.0	307		0.57	0.35	526.6	98.6	86	83
16	1.9	310		0.50	0.35	527.2	111.0	86	83
17	1.8	313		0.47	0.35	527.8	121.1	86	83
18	1.9	308		0.52	0.35	528.4	108.6	87	83
19	1.8	307		0.46	0.35	529.0	121.8	87	83
20	1.9	306		0.50	0.35	529.6	110.6	87	83
21	1.9	310		0.48	0.35	530.2	132.0	87	83
22	2.0	312		0.54	0.35	530.9	101.5	87	83
23	1.9	314		0.52	0.35	531.5	109.0	87	83
24	2.0	314		0.57	0.35	532.1	98.9	87	83
25	1.9	310		0.53	0.35	532.7	107.6	87	84
26	1.9	308		0.50	0.35	533.3	110.6	87	84
27	1.9	313		0.50	0.35	533.9	111.0	87	84
28	1.9	310		0.52	0.35	534.5	108.6	87	84
29	1.9	307		0.48	0.35	535.1	112.8	87	84
30	1.8	306		0.47	0.35	535.7	125.6	88	84
						536.327			
<b>AVG.</b>		310	-12.33	0.52	0.35	18.528	112.0	84	

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 3 OUTLET**  
**U3O-M201A/202-R1**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	302.40 degrees F
Ts	=	762.40 degrees R
%O2, dry	=	10.00 %
%O2, wet	=	8.40 %
Bws	=	0.16
Pbar	=	30.02 in. Hg
Pstatic	=	-12.50 in. H2O
Ps	=	29.10 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	28.08 lb/lb-mole
Tm	=	85.00 degrees F
Tm	=	545.00 degrees R
Md	=	30.00 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	50.32 ft/sec
μ	=	219.701
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.92
D50T (for Nre< 3162)	=	10.46
Qs (=QI for Nre< 3162)	=	0.573
Nre	=	2416
D50LL (for Nre >= 3162)	=	10.57
D50T (for Nre >= 3162)	=	10.79
Qs (=QI for Nre >= 3162)	=	0.549
Sampling Rate ΔH	=	0.35 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.34 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.36 in. H2O
D (calc. nozzle dia.)	=	0.187 in.
D (actual selected)	=	0.179 in.
Vn	=	54.67 ft/sec
ΔPmin allowed	=	0.298 in. H2O
ΔPmax allowed	=	0.999 in. H2O
Dwell Time at Point 1 (T1) is:	=	1.99 min.
<b>Actual Run Data</b>		
Ts	=	309.73 degrees F
Ts	=	769.73 degrees R
%O2, dry	=	9.57 %
%O2, wet	=	7.62 %
Vwc	=	4.001
Vsg	=	0.599
Bws	=	0.2043
Pbar	=	30.04 in. Hg
Pstatic	=	-12.33 in. H2O
Ps	=	29.13 in. Hg
Mw (same as Ms)	=	27.51 lb/lb-mole
Tm	=	83.68 degrees F
Tm	=	543.7 degrees R
Md	=	29.96 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.35 in. H2O
Meter Volume	=	18.528 dcf
Meter Volume at Std. Cond.	=	17.918 dscf
Avg. Square Root of Delta P	=	0.7176
Velocity	=	50.50 ft/sec
Area of Nozzle	=	0.0001748 in <sup>2</sup>
Test Duration	=	57.5 min.
Isokinetics (rounded to nearest whole #)	=	111%
No. of Points < 71% or > 129% Iso.	=	1
ΔPmin allowed	=	0.307 in. H2O
ΔPmax allowed	=	1.012 in. H2O
Actual ΔPmin from run	=	0.46 in. H2O
Actual ΔPmax from run	=	0.57 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	217.249
Qs	=	0.586 acfm
D50 (for PM-10 cyclone I)	=	10.27
Nre (actual test conditions)	=	2428
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.42
Cr	=	1.25
D50-1	=	2.26
Z	=	0.94
Recalculated Cr	=	1.26
Recalculated D50 (for cyclone IV)	=	2.25
Recalculated D50-1	=	2.25
Recalculated Z	=	1.00

**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 OUTLET**

Run Number **U3O-M201A/202-R1**

Stack Gas Viscosity (micropoise) 219.701  
 Cyclone Flow Rate (dscf/min) 0.312  
 Cyclone Flow Rate (acfm) 0.586  
 D50 10.273

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 217.249  
 Cyclone Flow Rate (acfm) 0.586

Vmstd - dscf 17.918  
 Sample Time - min 57.5  
 Ts 309.733  
 % O2 9.570  
 % Water 20.427  
 Vwc 4.001  
 Vsg 0.599  
 Ps 29.133  
 Mw 27.515  
 Cp 0.84

Nozzle Size(s) Used For Test: 0.179  
 Minimum dP During Test: 0.46  
 Maximum dP During Test: 0.57

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax Step 1	Conditional Rmax Step 2	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	137.876	0.280	0.775	106.893	1.218	1.218	167.871	2.308	5.692	OK	OK OK OK
2	0.129	107.676	0.268	0.764	82.245	1.225	1.225	131.934	1.366	3.516		
3	0.148	81.804	0.249	0.744	60.893	1.238	1.238	101.263	0.749	2.071		
4	0.158	71.777	0.236	0.731	52.504	1.246	1.246	89.422	0.557	1.615		
5	0.179	55.923	0.204	0.697	38.978	1.266	1.266	70.787	0.307	1.012		
6	0.191	49.117	0.181	0.672	32.988	1.279	1.279	62.833	0.220	0.797		
7	0.201	44.351	0.161	0.646	28.671	1.292	1.292	57.286	0.166	0.663		
8	0.230	33.872	0.088	0.542	18.345	1.334	1.334	45.178	0.068	0.412		
9	0.253	27.994	0.015	0.368	10.288	1.374	1.374	38.457	0.021	0.299		
10	0.274	23.867	-0.064	0.500	11.934	1.415	1.415	33.782	0.029	0.231		
11	0.296	20.451	-0.161	0.500	10.226	1.464	1.464	29.943	0.021	0.181		

**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 OUTLET**

**SAMPLING DATA**

Run number	<b>U30-M201A/202-R1</b>
Corrected sample volume	17.918 dscf
	0.507 dscm
Corrected flow rate	154991 dscfm
O2 Content	9.57 %
CO2 Content	9.84 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
FILTERABLE PM2.5		
Probe Wash	0.00400	0.00282
Filter	0.00040	0.00040
CONDENSIBLE PM2.5		
Inorganic CPM	0.00500	0.00319
Organic CPM	0.00530	0.00511
TOTAL CPM	0.01030	0.00830
TOTAL PM	0.01470	0.01152

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	65.3892	65.3932	0.00400	150
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00144	
Max. Allowable Blank			0.00118	
Blank Value Used for Correction			0.00118	
Filter	0.3598	0.3602	0.00040	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.00500	240	54.60%
Organic CPM in Sample	0.00530	306	45.40%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00420	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0028	0.0028	0.0044	0.0071	0.0099
Corrected to 7% O2 (gr/dscf)	0.0034	0.0034	0.0054	0.0088	0.122
Corrected to 12% CO2 (gr/dscf)	0.0034	0.0034	0.0054	0.0087	0.0121
Actual Grain Loading (mg/dscm)	6.35	6.29	10.06	16.36	22.71
Corrected to 7% O2 (mg/dscm)	7.79	7.72	12.35	20.07	27.86
Corrected to 12% CO2 (mg/dscm)	7.75	7.68	12.27	19.95	27.70
Mass Rate (lb/hr)	3.69	3.65	5.84	9.50	13.18

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).

**RUN NUMBER PRE-U30-M201A-R2**

Date 04/09/13  
 Start Time 11:56  
 End Time 12:58  
 Meter Box dH@ 1.7473  
 Barometric 30.04 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 24

**METHOD 3 AND 4 DATA**

%O2 9.57  
 %CO2 9.84  
 % Water 20.00 %

**METHOD 3 DATA**

%CO 0.0 Md 29.96  
 %N2 80.6 Ms 27.57  
 O2+CO2 19.4 Ps 29.12  
 %EA 82 Fo 1.151

**METHOD 2 RESULTS**

Velocity 50.46 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	303	-12.00	0.55	0.55	75	75
2	304	-13.00	0.53	0.53	78	78
3	309		0.52	0.52	82	81
4	310		0.50	0.50	83	81
5	310		0.51	0.51	83	81
6	308		0.56	0.56	83	81
7	302		0.51	0.51	84	82
8	310		0.52	0.52	84	82
9	316		0.54	0.54	84	82
10	320		0.53	0.53	85	82
11	312		0.50	0.50	85	82
12	310		0.52	0.52	85	82
13	315		0.55	0.55	85	83
14	308		0.49	0.49	86	83
15	307		0.57	0.57	86	83
16	310		0.50	0.50	86	83
17	313		0.47	0.47	86	83
18	308		0.52	0.52	87	83
19	307		0.46	0.46	87	83
20	306		0.50	0.50	87	83
21	310		0.48	0.48	87	83
22	312		0.54	0.54	87	83
23	314		0.52	0.52	87	83
24	314		0.57	0.57	87	83
25	310		0.53	0.53	87	84
26	308		0.50	0.50	87	84
27	313		0.50	0.50	87	84
28	310		0.52	0.52	87	84
29	307		0.48	0.48	87	84
30	306		0.47	0.47	88	84
AVG.	310	-12.50	0.52	0.52	84	

**EPA METHOD 201A**  
 PRELIMINARY TRAVERSE  
**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U3O-M201A-R2

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft3/min)	ORIFICE HEAD (in. H2O)
310	0.574	0.31
260	0.528	0.30
360	0.621	0.32

Nre	=	2378
-----	---	------

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.46  
 Max. dP from Traverse: 0.57  
 Average dP from Traverse: 0.52

**dPmin and dPmax Calculations at Stack Temperature of 310**

Stack Gas Viscosity (micropoise) 217.627  
 Stack Gas Viscosity (micropoise) @ -50 °F 206.004  
 Stack Gas Viscosity (micropoise) @ +50 °F 229.037

**D (calc. nozzle dia.) = 0.187**

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)
1	0.114		135.078	0.280	0.775	104.646	1.218	1.218	164.516	2.215	5.475
2	0.129		105.491	0.268	0.763	80.487	1.226	1.226	129.315	1.310	3.383
3	0.148		80.144	0.247	0.743	59.551	1.239	1.239	99.274	0.717	1.994
4	0.158		70.320	0.234	0.730	51.322	1.247	1.247	87.677	0.533	1.555
5	0.179	OK	54.788	0.201	0.694	38.045	1.267	1.267	69.428	0.293	0.975
6	0.191	OK	48.120	0.179	0.668	32.158	1.281	1.281	61.639	0.209	0.769
7	0.201	OK	43.451	0.157	0.642	27.909	1.294	1.294	56.208	0.158	0.639
8	0.230		33.185	0.083	0.533	17.691	1.337	1.337	44.353	0.063	0.398
9	0.253		27.425	0.008	0.337	9.232	1.377	1.377	37.774	0.017	0.289
10	0.274		23.383	-0.073	0.500	11.691	1.420	1.420	33.197	0.028	0.223
11	0.296		20.036	-0.172	0.500	10.018	1.469	1.469	29.439	0.020	0.175

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **2.07** minutes

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: 0.52



**Run Number U30-M201A/202-R2**

Date	04/09/13
Start Time	14:08
End Time	15:08
Stack Length	132 inches
Stack Width	105 inches
Nozzle I.D.	0.179 inches
Meter Box Gamma	0.9910
Meter Box dH@	1.7473
Barometric	30.04 in.Hg
Cp	0.84
Test Duration	59.60 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	72.0	72.0
Impinger 2	0.0	10.0	10.0
Impinger 3	100.0	94.0	-6.0
Impinger 4			0.0
Impinger 5			0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	100.0	176.0	76.0
Silica gel (g)	250.0	264.8	14.8

METHOD 1-4 RESULTS	
Metered Volume	18.466 dcf
Volume @ Std.Cond.	17.581 dscf
% Water	19.56 %
% Isokinetics	103.9 %
Velocity	50.30 ft/sec
Actual Flow	290484 acfm
Std. Flow	194417 scfm
Dry Std. Flow	156389 dscfm

METHOD 3 DATA			
%O2	8.85	Md	30.01
%CO2	10.33	Ms	27.66
%CO	0.0	Ps	29.16
%N2	80.8	Fo	1.167
O2+CO2	19.2	%EA	71

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	2.1	298	-13.00	0.55	0.31	544.278	83.1	92	88
2	2.0	298	-11.00	0.52	0.31	544.8	100.5	93	89
3	2.0	301	-12.00	0.56	0.31	545.4	96.8	93	92
4	2.0	303	-11.00	0.51	0.31	546.0	101.5	93	92
5	1.9	309	-12.00	0.47	0.31	546.6	111.8	94	91
6	2.0	313	-13.00	0.54	0.31	547.2	99.4	93	91
7	1.9	309		0.51	0.31	547.8	107.3	94	91
8	2.0	310		0.55	0.31	548.4	98.2	94	91
9	2.0	309		0.53	0.31	549.0	100.0	94	91
10	2.0	307		0.50	0.31	549.6	119.8	94	92
11	1.9	309		0.49	0.31	550.3	109.4	94	92
12	2.1	312		0.57	0.31	550.9	91.9	94	92
13	2.0	313		0.50	0.31	551.5	103.2	94	91
14	1.9	309		0.48	0.31	552.1	110.6	94	91
15	1.9	311		0.48	0.31	552.7	110.6	94	92
16	1.9	314		0.46	0.31	553.3	113.3	94	91
17	2.0	317		0.52	0.31	553.9	101.5	94	91
18	2.0	314		0.53	0.31	554.5	117.0	94	91
19	2.0	309		0.50	0.31	555.2	120.2	93	91
20	2.0	309		0.52	0.31	555.9	101.0	93	91
21	2.0	311		0.54	0.31	556.5	99.3	93	91
22	2.0	310		0.52	0.31	557.1	117.9	93	91
23	1.9	308		0.49	0.31	557.8	109.5	93	91
24	2.0	309		0.51	0.31	558.4	102.0	93	91
25	2.0	305		0.50	0.31	559.0	120.0	93	90
26	2.1	309		0.56	0.31	559.7	92.8	93	90
27	2.0	314		0.51	0.31	560.3	102.3	93	91
28	2.0	311		0.52	0.31	560.9	101.2	93	91
29	2.0	306		0.50	0.31	561.5	102.8	94	90
30	2.0	307		0.51	0.31	562.1	109.3	94	91
						562.744			
<b>AVG.</b>		309	-12.00	0.52	0.31	18.466	105.1	92	

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 3 OUTLET**  
**U3O-M201A/202-R2**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	309.73 degrees F
Ts	=	769.73 degrees R
%O2, dry	=	9.57 %
%O2, wet	=	7.66 %
Bws	=	0.20
Pbar	=	30.04 in. Hg
Pstatic	=	-12.50 in. H2O
Ps	=	29.12 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	27.57 lb/lb-mole
Tm	=	83.68 degrees F
Tm	=	543.68 degrees R
Md	=	29.96 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	50.46 ft/sec
μ	=	217.627
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.87
D50T (for Nre< 3162)	=	10.43
Qs (=QI for Nre< 3162)	=	0.574
Nre	=	2378
D50LL (for Nre >= 3162)	=	10.56
D50T (for Nre >= 3162)	=	10.78
Qs (=QI for Nre >= 3162)	=	0.549
Sampling Rate ΔH	=	0.31 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.30 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.32 in. H2O
D (calc. nozzle dia.)	=	0.187 in.
D (actual selected)	=	0.179 in.
Vn	=	54.78 ft/sec
ΔPmin allowed	=	0.293 in. H2O
ΔPmax allowed	=	0.975 in. H2O
Dwell Time at Point 1 (T1) is:	=	2.58 min.
<b>Actual Run Data</b>		
Ts	=	308.80 degrees F
Ts	=	768.80 degrees R
%O2, dry	=	8.85 %
%O2, wet	=	7.12 %
Vwc	=	3.577
Vsg	=	0.698
Bws	=	0.1956
Pbar	=	30.04 in. Hg
Pstatic	=	-12.00 in. H2O
Ps	=	29.16 in. Hg
Mw (same as Ms)	=	27.66 lb/lb-mole
Tm	=	92.20 degrees F
Tm	=	552.2 degrees R
Md	=	30.01 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.31 in. H2O
Meter Volume	=	18.466 dcf
Meter Volume at Std. Cond.	=	17.581 dscf
Avg. Square Root of Delta P	=	0.7174
Velocity	=	50.30 ft/sec
Area of Nozzle	=	0.0001748 ft <sup>2</sup>
Test Duration	=	59.6 min.
Isokinetics (rounded to nearest whole #)	=	104%
No. of Points < 71% or > 129% Iso.	=	0
Actual ΔPmin from run	=	0.46 in. H2O
Actual ΔPmax from run	=	0.57 in. H2O
Actual ΔPmin from run	=	0.46 in. H2O
Actual ΔPmax from run	=	0.57 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	217.460
Qs	=	0.548 acfm
D50 (for PM-10 cyclone I)	=	10.77
Nre (actual test conditions)	=	2284
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.61
Cr	=	1.23
D50-1	=	2.46
Z	=	0.94
Recalculated Cr	=	1.24
Recalculated D50 (for cyclone IV)	=	2.45
Recalculated D50-1	=	2.45
Recalculated Z	=	1.00

**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 OUTLET**

Run Number **U3O-M201A/202-R2**

Stack Gas Viscosity (micropoise) 217.722  
 Cyclone Flow Rate (dscf/min) 0.295  
 Cyclone Flow Rate (acfm) 0.548  
 D50 10.769

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 217.460  
 Cyclone Flow Rate (acfm) 0.548

Vmstd - dscf 17.581  
 Sample Time - min 59.6  
 Ts 308.800  
 % O2 8.850  
 % Water 19.560  
 Vwc 3.577  
 Vsg 0.698  
 Ps 29.158  
 Mw 27.658  
 Cp 0.84

Nozzle Size(s) Used For Test: 0.179  
 Minimum dP During Test: 0.46  
 Maximum dP During Test: 0.57

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Step 1	Conditional Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	128.845	0.279	0.773	99.659	1.219	1.219	157.033	2.021	5.017	OK	OK OK OK
2	0.129	100.623	0.266	0.761	76.589	1.227	1.227	123.469	1.193	3.102		
3	0.148	76.446	0.245	0.740	56.584	1.240	1.240	94.830	0.651	1.830		
4	0.158	67.075	0.231	0.726	48.713	1.249	1.249	83.776	0.483	1.428		
5	0.179	52.260	0.196	0.689	35.994	1.270	1.270	66.384	0.264	0.897		
6	0.191	45.900	0.172	0.661	30.339	1.285	1.285	58.962	0.187	0.707		
7	0.201	41.446	0.150	0.633	26.244	1.298	1.298	53.788	0.140	0.589		
8	0.230	31.653	0.072	0.514	16.266	1.343	1.343	42.495	0.054	0.367		
9	0.253	26.160	-0.006	0.500	13.080	1.385	1.385	36.230	0.035	0.267		
10	0.274	22.304	-0.091	0.500	11.152	1.429	1.429	31.871	0.025	0.207		
11	0.296	19.111	-0.194	0.500	9.556	1.480	1.480	28.292	0.019	0.163		

**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 OUTLET**

**SAMPLING DATA**

Run number	<b>U30-M201A/202-R2</b>
Corrected sample volume	17.581 dscf
	0.498 dscm
Corrected flow rate	156389 dscfm
O2 Content	8.85 %
CO2 Content	10.33 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
FILTERABLE PM2.5		
Probe Wash	0.00160	0.00027
Filter	0.00090	0.00090
CONDENSIBLE PM2.5		
Inorganic CPM	0.00690	0.00509
Organic CPM	0.00660	0.00641
TOTAL CPM	0.01350	0.01150
TOTAL PM	0.01600	0.01267

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	67.5381	67.5397	0.00160	170
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00163	
Max. Allowable Blank			0.00133	
Blank Value Used for Correction			0.00133	
Filter	0.3581	0.3590	0.00090	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.00690	250	47.46%
Organic CPM in Sample	0.00660	216	52.54%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00420	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0010	0.0045	0.0056	0.0101	0.0111
Corrected to 7% O2 (gr/dscf)	0.0012	0.0052	0.0065	0.0116	0.0128
Corrected to 12% CO2 (gr/dscf)	0.0012	0.0052	0.0065	0.0117	0.0129
Actual Grain Loading (mg/dscf)	2.34	10.23	12.87	23.10	25.44
Corrected to 7% O2 (mg/dscf)	2.70	11.80	14.84	26.65	29.35
Corrected to 12% CO2 (mg/dscf)	2.72	11.89	14.95	26.83	29.56
Mass Rate (lb/hr)	1.37	5.99	7.54	13.53	14.90

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).

**RUN NUMBER PRE-U30-M201A-R3**

Date 04/09/13  
 Start Time 14:08  
 End Time 15:08  
 Meter Box dH@ 1.7473  
 Barometric 30.04 in.Hg  
 Cp' (for Prelim.) 0.84  
 Cp (for actual run) 0.84  
 Test Duration 60 minutes

PM-2.5 fraction to be included (Y or N)? Y  
 PM-10 fraction to be included? (Y or N)? N

No. of Sample Points 30

**METHOD 3 AND 4 DATA**

%O2 8.85  
 %CO2 10.33  
 % Water 20.00 %

**METHOD 3 DATA**

%CO 0.0 Md 30.01  
 %N2 80.8 Ms 27.61  
 O2+CO2 19.2 Ps 29.16  
 %EA 71 Fo 1.167

**METHOD 2 RESULTS**

Velocity 50.35 ft/sec

Point	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Pitot Coefficient Adjusted Delta P (in.WC)	ESTIMATED Meter Temp	
					Inlet (DegF)	Outlet (DegF)
1	298	-13.00	0.55	0.55	92	88
2	298	-11.00	0.52	0.52	93	89
3	301		0.56	0.56	93	92
4	303		0.51	0.51	93	92
5	309		0.47	0.47	94	91
6	313		0.54	0.54	93	91
7	309		0.51	0.51	94	91
8	310		0.55	0.55	94	91
9	309		0.53	0.53	94	91
10	307		0.50	0.50	94	92
11	309		0.49	0.49	94	92
12	312		0.57	0.57	94	92
13	313		0.50	0.50	94	91
14	309		0.48	0.48	94	91
15	311		0.48	0.48	94	92
16	314		0.46	0.46	94	91
17	317		0.52	0.52	94	91
18	314		0.53	0.53	94	91
19	309		0.50	0.50	93	91
20	309		0.52	0.52	93	91
21	311		0.54	0.54	93	91
22	310		0.52	0.52	93	91
23	308		0.49	0.49	93	91
24	309		0.51	0.51	93	91
25	305		0.50	0.50	93	90
26	309		0.56	0.56	93	90
27	314		0.51	0.51	93	91
28	311		0.52	0.52	93	91
29	306		0.50	0.50	94	90
30	307		0.51	0.51	94	91
AVG.	309	-12.00	0.52	0.52	92	

**EPA METHOD 201A**  
 PRELIMINARY TRAVERSE  
**ORIFICE HEAD, NOZZLE, AND DWELL TIME CALCULATIONS**

RUN I.D. PRE-U30-M201A-R3

**ORIFICE HEAD DETERMINATION (dH)**

TEMP. (°F)	CYCLONE FLOW (ft <sup>3</sup> /min)	ORIFICE HEAD (in. H <sub>2</sub> O)		
309	0.572	0.31	Nre	= 2384
259	0.526	0.30		
359	0.619	0.32		

**NOZZLE SIZE DETERMINATION**

Min. dP from Traverse: 0.46  
 Max. dP from Traverse: 0.57  
 Average dP from Traverse: 0.52

**dPmin and dPmax Calculations at Stack Temperature of 309**

Stack Gas Viscosity (micropoise) 217.071  
 Stack Gas Viscosity (micropoise) @ -50 °F 205.444  
 Stack Gas Viscosity (micropoise) @ +50 °F 228.486

**D (calc. nozzle dia.) = 0.186**

Nozzle No.	Dn (in.)	OPTIONAL NOZZLES	vn (ft/s)	Conditional Rmin Step 1	Conditional Rmin Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H <sub>2</sub> O)	dPmax (in. H <sub>2</sub> O)
1	0.114		134.520	0.280	0.775	104.209	1.218	1.218	163.841	2.205	5.451
2	0.129		105.055	0.268	0.763	80.148	1.226	1.226	128.786	1.304	3.368
3	0.148		79.813	0.247	0.743	59.298	1.239	1.239	98.869	0.714	1.985
4	0.158		70.030	0.234	0.730	51.102	1.247	1.247	87.320	0.530	1.548
5	0.179	OK	54.562	0.201	0.694	37.878	1.267	1.267	69.147	0.291	0.971
6	0.191	OK	47.922	0.178	0.668	32.014	1.281	1.281	61.390	0.208	0.765
7	0.201	OK	43.272	0.157	0.642	27.781	1.294	1.294	55.982	0.157	0.636
8	0.230		33.048	0.082	0.532	17.598	1.337	1.337	44.176	0.063	0.396
9	0.253		27.312	0.008	0.334	9.121	1.378	1.378	37.625	0.017	0.287
10	0.274		23.286	-0.073	0.500	11.643	1.420	1.420	33.067	0.028	0.222
11	0.296		19.953	-0.172	0.500	9.977	1.470	1.470	29.324	0.020	0.175

**DWELL TIME DETERMINATION**

Dwell Time at Point 1 (T1) is: **2.07** minutes

**TRAVERSE POINT DETERMINATION**

DATA FROM PRELIMINARY TRAVERSE:  
 Average dP from Traverse: 0.52

**Run Number U30-M201A/202-R3**

Date	04/09/13
Start Time	16:38
End Time	17:38
Stack Length	132 inches
Stack Width	105 inches
Nozzle I.D.	0.179 inches
Meter Box Gamma	0.9910
Meter Box dH@	1.7473
Barometric	30.02 in.Hg
Cp	0.84
Test Duration	59.70 minutes

METHOD 4 DATA			
	Impinger Volume (mL)		
	Initial	Final	Net
Impinger 1	0.0	100.0	100.0
Impinger 2	0.0	0.0	0.0
Impinger 3	100.0	90.0	-10.0
Impinger 4			0.0
Impinger 5			0.0
Impinger 6			0.0
Impinger 7			0.0
<b>Total</b>	100.0	190.0	90.0
Silica gel (g)	250.0	266.4	16.4

METHOD 1-4 RESULTS	
Metered Volume	19.243 dcf
Volume @ Std.Cond.	18.298 dscf
% Water	21.49 %
% Isokinetics	110.9 %
Velocity	50.14 ft/sec
Actual Flow	289542 acfm
Std. Flow	193886 scfm
Dry Std. Flow	152213 dscfm

METHOD 3 DATA			
%O2	9.71	Md	29.92
%CO2	9.57	Ms	27.36
%CO	0.0	Ps	29.15
%N2	80.7	Fo	1.169
O2+CO2	19.3	%EA	84

POINT	Dwell Time (Min.)	Stack Temp. (DegF)	Static Pressure (in.WC)	Delta P (in.WC)	Delta H (in.WC)	Meter Volume (dcf)	Iso (%)	Meter Temp. (Deg. F)	
								Inlet	Outlet
1	2.1	301	-12.0	0.55	0.31	565.211	110.2	93	93
2	2.0	302	-11.0	0.53	0.31	565.9	84.0	97	94
3	2.0	300	-11.0	0.50	0.31	566.4	103.9	96	93
4	2.0	300	-13.0	0.50	0.31	567.0	121.2	96	93
5	1.9	305	-12.0	0.48	0.31	567.7	111.8	97	93
6	2.1	303	-12.0	0.57	0.31	568.3	108.4	95	93
7	2.0	304		0.53	0.31	569.0	101.3	94	93
8	2.0	309		0.51	0.31	569.6	103.6	94	93
9	2.0	311		0.50	0.31	570.2	122.3	94	93
10	1.9	314		0.46	0.31	570.9	115.2	94	93
11	1.8	307		0.43	0.31	571.5	125.3	94	92
12	2.0	313		0.50	0.31	572.1	105.0	94	92
13	2.0	317		0.49	0.31	572.7	124.1	94	92
14	1.9	315		0.44	0.31	573.4	118.1	93	92
15	2.0	313		0.49	0.31	574.0	123.9	93	92
16	2.1	306		0.57	0.31	574.7	93.3	94	91
17	2.0	311		0.53	0.31	575.3	119.0	94	91
18	2.0	310		0.53	0.31	576.0	101.9	94	91
19	2.0	308		0.50	0.31	576.6	122.2	94	91
20	2.0	309		0.51	0.31	577.3	103.8	94	91
21	2.1	302		0.54	0.31	577.9	111.9	92	90
22	2.1	309		0.58	0.31	578.6	93.0	92	90
23	2.0	312		0.53	0.31	579.2	119.4	92	90
24	2.0	310		0.50	0.31	579.9	122.7	92	90
25	1.9	308		0.46	0.31	580.6	115.3	92	90
26	2.0	307		0.53	0.31	581.2	119.0	92	90
27	2.0	310		0.50	0.31	581.9	122.7	92	90
28	1.9	309		0.48	0.31	582.6	112.9	92	90
29	1.9	313		0.46	0.31	583.2	115.8	92	89
30	2.0	308		0.50	0.31	583.8	114.6	92	89
						584.454			
AVG.		308	-11.83	0.51	0.31	19.243	112.2	93	

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 3 OUTLET**  
**U3O-M201A/202-R3**

C1	=	-150.3162 micropoise
C2	=	18.0614 micropoise/K <sup>0.5</sup>
	=	13.4622 micropoise/R <sup>0.5</sup>
C3	=	1.19183E+06 micropoise/K <sup>2</sup>
	=	3.86153E+06 micropoise/R <sup>2</sup>
C4	=	0.591123 micropoise
C5	=	91.9723 micropoise
C6	=	4.91705E-05 micropoise/K <sup>2</sup>
	=	1.51761E-05 micropoise/R <sup>2</sup>
<b>Preliminary Data</b>		
Ts	=	308.80 degrees F
Ts	=	768.80 degrees R
%O2, dry	=	8.85 %
%O2, wet	=	7.08 %
Bws	=	0.20
Pbar	=	30.04 in. Hg
Pstatic	=	-12.00 in. H2O
Ps	=	29.16 in. Hg
Dp (for 2.25 micrometer cut size)	=	2.25 micrometers
Mw (same as Ms)	=	27.61 lb/lb-mole
Tm	=	92.20 degrees F
Tm	=	552.20 degrees R
Md	=	30.01 lb/lb-mole
ΔH@	=	1.7473
Cp' (for Prelim.)	=	0.84
Vs	=	50.35 ft/sec
μ	=	217.071
C (for 2.25 micrometer cut size)	=	1.10
D50LL (for Nre< 3162)	=	9.87
D50T (for Nre< 3162)	=	10.44
Qs (=QI for Nre< 3162)	=	0.572
Nre	=	2384
D50LL (for Nre >= 3162)	=	10.56
D50T (for Nre >= 3162)	=	10.78
Qs (=QI for Nre >= 3162)	=	0.547
Sampling Rate ΔH	=	0.31 in. H2O
Sampling Rate ΔH @ Ts - 50 deg. F	=	0.30 in. H2O
Sampling Rate ΔH @ Ts + 50 deg. F	=	0.32 in. H2O
D (calc. nozzle dia.)	=	0.186 in.
D (actual selected)	=	0.179 in.
Vn	=	54.56 ft/sec
ΔPmin allowed	=	0.291 in. H2O
ΔPmax allowed	=	0.971 in. H2O
Dwell Time at Point 1 (T1) is:	=	2.07 min.
<b>Actual Run Data</b>		
Ts	=	308.20 degrees F
Ts	=	768.20 degrees R
%O2, dry	=	9.71 %
%O2, wet	=	7.62 %
Vwc	=	4.236
Vsg	=	0.773
Bws	=	0.2149
Pbar	=	30.02 in. Hg
Pstatic	=	-11.83 in. H2O
Ps	=	29.15 in. Hg
Mw (same as Ms)	=	27.36 lb/lb-mole
Tm	=	92.53 degrees F
Tm	=	552.5 degrees R
Md	=	29.92 lb/lb-mole
Cp (for actual run)	=	0.84
Meter Calibration Factor (Gamma)	=	0.9910
Meter Box Delta H During Test	=	0.31 in. H2O
Meter Volume	=	19.243 dcf
Meter Volume at Std. Cond.	=	18.298 dscf
Avg. Square Root of Delta P	=	0.7114
Velocity	=	50.14 ft/sec
Area of Nozzle	=	0.0001748 in <sup>2</sup>
Test Duration	=	59.7 min.
Isokinetics (rounded to nearest whole #)	=	111%
No. of Points < 71% or > 129% Iso.	=	0
Actual ΔPmin from run	=	0.43 in. H2O
Actual ΔPmax from run	=	0.58 in. H2O
Actual ΔPmin from run	=	0.43 in. H2O
Actual ΔPmax from run	=	0.58 in. H2O
No. of ΔPs outside of allowed range	=	0
Recalculated μ	=	216.014
Qs	=	0.583 acfm
D50 (for PM-10 cyclone I)	=	10.28
Nre (actual test conditions)	=	2421
C (where Dp = 2.5)	=	1.09
D50 (for PM-2.5 cyclone IV)	=	2.43
Cr	=	1.25
D50-1	=	2.27
Z	=	0.94
Recalculated Cr	=	1.26
Recalculated D50 (for cyclone IV)	=	2.25
Recalculated D50-1	=	2.25
Recalculated Z	=	1.00



**EPA Method 201A: Performance Criteria Calculations**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 OUTLET**

Run Number **U3O-M201A/202-R3**

Stack Gas Viscosity (micropoise) 217.071  
 Cyclone Flow Rate (dscf/min) 0.306  
 Cyclone Flow Rate (acfm) 0.585  
 D50 10.243

***dPmin and dPmax Calculations and Performance:***

Stack Gas Viscosity (micropoise) 215.734  
 Cyclone Flow Rate (acfm) 0.585

Vmstd - dscf 18.298  
 Sample Time - min 59.7  
 Ts 308.200  
 % O2 9.710  
 % Water 21.810  
 Vwc 4.236  
 Vsg 0.868  
 Ps 29.150  
 Mw 27.320  
 Cp 0.84

Nozzle Size(s) Used For Test: 0.179  
 Minimum dP During Test: 0.43  
 Maximum dP During Test: 0.58

Nozzle No.	Dn (in.)	vn (ft/s)	Conditional Step 1	Conditional Step 2	vmin (ft/s)	Conditional Rmax	Conditional Rmax	vmax (ft/s)	dPmin (in. H2O)	dPmax (in. H2O)	Acceptance Criteria	Nozzle Selection for Next Run
1	0.114	137.652	0.281	0.775	106.737	1.217	1.217	167.585	2.291	5.647	OK	OK OK OK
2	0.129	107.501	0.269	0.764	82.133	1.225	1.225	131.705	1.356	3.488		
3	0.148	81.671	0.249	0.745	60.819	1.238	1.238	101.082	0.744	2.054		
4	0.158	71.660	0.236	0.732	52.447	1.246	1.246	89.259	0.553	1.602		
5	0.179	55.832	0.204	0.698	38.949	1.265	1.265	70.653	0.305	1.004		
6	0.191	49.037	0.182	0.672	32.973	1.279	1.279	62.711	0.219	0.791		
7	0.201	44.279	0.161	0.647	28.667	1.291	1.291	57.172	0.165	0.657		
8	0.230	33.817	0.089	0.544	18.382	1.333	1.333	45.082	0.068	0.409		
9	0.253	27.948	0.016	0.374	10.447	1.373	1.373	38.371	0.022	0.296		
10	0.274	23.828	-0.062	0.500	11.914	1.414	1.414	33.703	0.029	0.228		
11	0.296	20.418	-0.158	0.500	10.209	1.463	1.463	29.869	0.021	0.179		

**EPA Method 202: Gravimetric Data and Results**

**PINELLAS COUNTY RESOURCE RECOVERY FACILITY  
UNIT 3 OUTLET**

**SAMPLING DATA**

Run number	<b>U30-M201A/202-R3</b>
Corrected sample volume	18.298 dscf
	0.518 dscm
Corrected flow rate	152213 dscfm
O2 Content	9.71 %
CO2 Content	9.57 %

**SUMMARY**

COMPONENT	NET (grams)	CORRECTED FOR BLANK (grams)
FILTERABLE PM2.5		
Probe Wash	0.00130	0.00001
Filter	0.00060	0.00060
CONDENSIBLE PM2.5		
Inorganic CPM	0.00480	0.00299
Organic CPM	0.00680	0.00661
TOTAL CPM	0.01160	0.00960
TOTAL PM	0.01350	0.01021

**ANALYTICAL DATA**

METHOD 201A COMPONENTS	TARE (grams)	FINAL (grams)	NET (grams)	VOLUME (ml)
PM2.5 Acetone Probe Wash	66.6928	66.6941	0.00130	165
Acetone Blank Residue	67.9233	67.9245	0.00120	125
Applicable Acetone Blank			0.00158	
Max. Allowable Blank			0.00129	
Blank Value Used for Correction			0.00129	
Filter	0.3591	0.3597	0.00060	

METHOD 202 COMPONENTS	NET (grams)	Volume (mL)	CPM RATIO (%)
Inorganic CPM in Sample	0.00480	230	37.80%
Organic CPM in Sample	0.00680	198	62.20%
Inorganic CPM in Field Blank	0.00280	180	90.32%
Organic CPM in Field Blank	0.00040	240	9.68%
Total CPM in Field Blank	0.00390	*	
Max. Allowable Field Blank	0.00200		
Inorganic CPM Field Blank Value Used for Correction	0.00181	**	
Organic CPM Field Blank Value Used for Correction	0.00019	**	
Total CPM Field Blank Value Used for Correction	0.00200		

**PM2.5 EMISSIONS**

	FILTERABLE (FPM)	Inorganic (CPM)	Organic (CPM)	Total (CPM)	TOTAL (FPM+CPM)
Actual Grain Loading (gr/dscf)	0.0005	0.0025	0.0056	0.0081	0.0086
Corrected to 7% O2 (gr/dscf)	0.0006	0.0031	0.0069	0.0101	0.0107
Corrected to 12% CO2 (gr/dscf)	0.0006	0.0032	0.0070	0.0102	0.0108
Actual Grain Loading (mg/dscf)	1.17	5.78	12.75	18.53	19.70
Corrected to 7% O2 (mg/dscf)	1.45	7.18	15.84	23.01	24.47
Corrected to 12% CO2 (mg/dscf)	1.47	7.24	15.99	23.23	24.70
Mass Rate (lb/hr)	0.67	3.29	7.27	10.56	11.23

**Notes**

\* The field blank value was corrected for the volume difference between the sample and the blank.  
Field blank corrected value = actual value x sample volume over blank volume.

\*\* If the Total CPM in Field Blank value is > 2 mg, then the inorganic and organic blank fractions were calculated by:  
2 mg x CPM Ratio % of Uncorrected CPM in Field Blank (Inorganic or Organic, as applicable).

**Appendix E**  
**EPA Method 9 Data and Results**

Note:

Visible emissions were uniformly zero percent opacity for all applicable test locations; therefore, this appendix contains no data and results for testing of those locations. Please refer to Appendix K for all of the raw field data sheets from the visible emissions evaluations.

**Appendix F**  
**Equations and Sample Calculations**

## EPA METHODS 2-4 CALCULATIONS

### 1. Metered Gas Sample Volume at Standard Conditions

$$V_{m(std)} = V_m \times \gamma \times \frac{528}{29.92} \times \left[ \frac{P_B + \frac{\Delta H}{13.6}}{T_m + 460} \right]$$

### 2. Gas Volume of Water Vapor Collected in Impinger Liquid

$$V_{WC(std)} = (v_f - v_i) \times 0.04707$$

### 3. Gas Volume of Water Vapor Collected in Silica Gel

$$V_{wsg(std)} = (w_f - w_i) \times 0.04715$$

### 4. Moisture Volume Fraction in Flue Gas

$$B_{ws} = \frac{V_{wc(std)} + V_{wsg(std)}}{V_{wc(std)} + V_{wsg(std)} + V_{m(std)}}$$

### 5. Moisture Volume Percentage in Flue Gas

$$\% H_2O = B_{ws} \times 100$$

### 6. Absolute Pressure of Flue Gas

$$P_s = P_B + \frac{P_{static}}{13.6}$$

### 7. Nitrogen Content of Flue Gas

$$\% N_2 = 100 - (\% CO_2 + \% O_2 + \% CO)$$

### 8. Dry Molecular Weight of Flue Gas

$$M_d = 0.44 \times \% CO_2 + 0.32 \times \% O_2 + 0.28 \times (\% N_2 + \% CO)$$

### 9. Wet Molecular Weight of Flue Gas

$$M_s = M_d \times (1 - B_{ws}) + 18 \times B_{ws}$$

## EPA METHODS 2-4 CALCULATIONS - continued

10. Fuel Factor Based on Flue Gas Composition

$$F_o = \frac{20.9 - \%O_2}{\%CO_2}$$

11. Excess Air of Flue Gas

$$\%EA = \frac{\%O_2 - 0.5\%CO}{0.264\%N_2 - (\%O_2 - 0.5\%CO)} \times 100$$

12. Average Gas Velocity, ft/sec

$$v_s = 85.49 \times C_p \times (\Delta P^{1/2})_{avg} \times \frac{(T_s + 460)^{1/2}}{(P_s \times M_s)^{1/2}}$$

13. Area of Round Duct or Stack

$$A_s = \frac{\pi \times D^2}{4 \times 144} \quad (\text{round ducts})$$

14. Area of Rectangular Duct

$$A_s = \frac{L \times W}{144} \quad (\text{rectangular ducts})$$

15. Actual Volumetric Flow Rate of Flue Gas

$$Q_a = v_s \times A_s \times 60$$

16. Flow Rate of Flue Gas at Standard Temperature and Pressure

$$Q_s = Q_a \times \left[ \frac{P_s \times 528}{(T_s + 460) \times 29.92} \right]$$

17. Dry Flow Rate of Flue Gas at Std. Temperature and Pressure

$$Q_{sd} = Q_s \times (1 - B_{ws})$$

## NOMENCLATURE FOR EPA METHODS 2-4

$A_s$	=	Stack area, ft <sup>2</sup>
$B_{ws}$	=	Moisture volume fraction
$C_p$	=	Pitot tube coefficient (S-type≈0.84, Std.≈0.99)
$D_s$	=	Stack diameter, inches
$\Delta H$	=	Average meter orifice pressure, in.W.C.
$\Delta P$	=	Pitot tube differential pressure, in.W.C.
$F_o$	=	Combustion factor
$\gamma$	=	Meter calibration factor, gamma
$L$	=	Length of rectangular stack or duct, inches
$M_D$	=	Dry molecular weight, lb/lb-mole
$M_s$	=	Wet molecular weight, lb/lb-mole
$P_B$	=	Barometric pressure, in.Hg
$P_s$	=	Absolute stack pressure, in.Hg
$P_{static}$	=	Average static pressure, in.W.C.
$Q_a$	=	Actual gas flow rate, acfm
$Q_s$	=	Standard gas flow rate, scfm
$Q_{sd}$	=	Dry standard gas flow rate, dscfm
$T_m$	=	Average meter temperature, °F
$T_s$	=	Average stack temperature, °F
$V_f$	=	Final impinger volume, ml
$V_i$	=	Initial impinger volume, ml
$V_m$	=	Uncorrected metered gas volume, dcf
$V_{m(std)}$	=	Corrected gas volume, dscf
$V_s$	=	Average gas velocity, ft/sec
$V_{wc(std)}$	=	Gas volume of water caught in impingers, scf
$V_{wsg(std)}$	=	Gas volume of water caught in silica gel, scf
$W$	=	Width of rectangular stack or duct, inches
$W_f$	=	Final silica gel mass, grams
$W_i$	=	Initial silica gel mass, grams
%O <sub>2</sub>	=	Dry volumetric concentration of O <sub>2</sub> , %dv
%CO <sub>2</sub>	=	Dry volumetric concentration of CO <sub>2</sub> , %dv
%CO	=	Dry volumetric concentration of CO, %dv
%N <sub>2</sub>	=	Dry volumetric concentration of N <sub>2</sub> , %dv
%EA	=	Percent excess air



## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Methods 2-4: Actual Calculations for Unit 1, Run 1 Run ID: U1O-M29-R1

1. Metered gas sample volume at standard conditions

$$\begin{aligned} Vm(\text{std}) &= 81.384 \cdot .9604 \cdot (528/29.92) \cdot (30.02 + (1.61/13.6)) / (84 + 460) \\ &= 76.416 \quad \text{dscf} \end{aligned}$$

2. Gas volume of water vapor collected in impinger liquid

$$\begin{aligned} Vwc(\text{std}) &= (820 - 400.0) \cdot 0.04707 \\ &= 19.769 \quad \text{scf} \end{aligned}$$

3. Gas volume of water vapor collected in silica gel

$$\begin{aligned} Vwsg(\text{std}) &= (270 - 250.0) \cdot 0.04715 \\ &= 0.943 \quad \text{scf} \end{aligned}$$

4. Moisture volume fraction in flue gas

$$\begin{aligned} Bws &= (19.769 + 0.943) / (19.769 + 0.943 + 76.416) \\ &= 0.2132 \end{aligned}$$

5. Moisture volume percentage in flue gas

$$\begin{aligned} \%H_2O &= 0.2132 \times 100 \\ &= 21.32 \% \end{aligned}$$

6. Absolute pressure of flue gas

$$\begin{aligned} Ps &= 30.02 + (-11.42/13.6) \\ &= 29.18 \quad \text{in. Hg} \end{aligned}$$

7. Nitrogen content of flue gas

$$\begin{aligned} \%N_2 &= 100 - (9.98 + 9.37 + 0.0) \\ &= 80.65 \% \end{aligned}$$

8. Dry molecular weight of flue gas

$$\begin{aligned} Md &= (0.44 \cdot 9.37) + (0.32 \cdot 9.98) + (0.28 \cdot (80.65 + 0.0)) \\ &= 29.90 \quad \text{lb/lb-mole} \end{aligned}$$

9. Wet molecular weight of flue gas

$$\begin{aligned} M_s &= 29.90*(1-0.2132)+(18*0.2132) \\ &= 27.36 \quad \text{lb/lb-mole} \end{aligned}$$

10. Fuel factor based on flue gas composition

$$\begin{aligned} F_o &= (20.9-9.98)/9.37 \\ &= 1.165 \end{aligned}$$

11. Excess air of flue gas

$$\begin{aligned} \%EA &= (9.98-(0.5*0.0))/((0.264*80.65)-(9.98-(0.5*0.0)))*100 \\ &= 88.23 \% \end{aligned}$$

12. Average gas velocity

$$\begin{aligned} V_s &= 85.49*0.84*0.6535*(((316+460)^{0.5})/(29.18*27.36)^{0.5}) \\ &= 46.27 \text{ ft/sec} \end{aligned}$$

13. Area of rectangular stack

$$\begin{aligned} A_s &= (105*132)/144 \\ &= 96.25 \text{ square feet} \end{aligned}$$

14. Area of round duct or stack - not applicable

15. Actual volumetric flow rate of flue gas

$$\begin{aligned} Q_a &= 46.27*96.25*60 \\ &= 267209 \text{ acfm} \end{aligned}$$

16. Flow rate of flue gas at standard temperature and pressure

$$\begin{aligned} Q_s &= 267209*((29.18*528)/((316+460)*29.92)) \\ &= 177316 \text{ scfm} \end{aligned}$$

17. Dry flow rate of flue gas at standard temperature and pressure

$$\begin{aligned} Q_{sd} &= 177316*(1-0.2132) \\ &= 139512 \text{ dscfm} \end{aligned}$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Methods 2-4: Actual Calculations for Unit 2, Run 1 Run ID: U2O-M29-R1

1. Metered gas sample volume at standard conditions

$$\begin{aligned} Vm(\text{std}) &= 81.193 * 0.9604 * (528/29.92) * (29.99 + (1.6/13.6)) / (77 + 460) \\ &= 77.152 \quad \text{dscf} \end{aligned}$$

2. Gas volume of water vapor collected in impinger liquid

$$\begin{aligned} Vwc(\text{std}) &= (753.0 - 400.0) * 0.04707 \\ &= 16.616 \quad \text{scf} \end{aligned}$$

3. Gas volume of water vapor collected in silica gel

$$\begin{aligned} Vwsg(\text{std}) &= (267.6 - 250.0) * 0.04715 \\ &= 0.830 \quad \text{scf} \end{aligned}$$

4. Moisture volume fraction in flue gas

$$\begin{aligned} Bws &= (16.616 + 0.830) / (16.616 + 0.830 + 77.152) \\ &= 0.1844 \end{aligned}$$

5. Moisture volume percentage in flue gas

$$\begin{aligned} \%H_2O &= 0.1844 * 100 \\ &= 18.44 \% \end{aligned}$$

6. Absolute pressure of flue gas

$$\begin{aligned} Ps &= 29.99 + (-10.75/13.6) \\ &= 29.20 \quad \text{in. Hg} \end{aligned}$$

7. Nitrogen content of flue gas

$$\begin{aligned} \%N_2 &= 100 - (8.6 + 10.6 + 0.0) \\ &= 80.80 \% \end{aligned}$$

8. Dry molecular weight of flue gas

$$\begin{aligned} Md &= (0.44 * 8.6) + (0.32 * 10.6) + (0.28 * (80.8 + 0.0)) \\ &= 29.80 \quad \text{lb/lb-mole} \end{aligned}$$

9. Wet molecular weight of flue gas

$$\begin{aligned} M_s &= 29.80*(1-0.1844)+(18*0.1844) \\ &= 27.62 \quad \text{lb/lb-mole} \end{aligned}$$

10. Fuel factor based on flue gas composition

$$\begin{aligned} F_o &= (20.9-10.6)/8.6 \\ &= 1.198 \end{aligned}$$

11. Excess air of flue gas

$$\begin{aligned} \%EA &= (10.6-(0.5*0.0))/((0.264*80.8)-(10.6-(0.5*0.0)))*100 \\ &= 99 \% \end{aligned}$$

12. Average gas velocity

$$\begin{aligned} V_s &= 85.49*0.84*0.6498*(((294+460)^{0.5})/(29.20*27.62)^{0.5}) \\ &= 45.12 \text{ ft/sec} \end{aligned}$$

13. Area of rectangular stack

$$\begin{aligned} A_s &= (105*132)/144 \\ &= 96.25 \text{ square feet} \end{aligned}$$

14. Area of round duct or stack - not applicable

15. Actual volumetric flow rate of flue gas

$$\begin{aligned} Q_a &= 45.12*96.25*60 \\ &= 260568 \text{ acfm} \end{aligned}$$

16. Flow rate of flue gas at standard temperature and pressure

$$\begin{aligned} Q_s &= 260568*((29.20*528)/((294+460)*29.92)) \\ &= 178076 \text{ scfm} \end{aligned}$$

17. Dry flow rate of flue gas at standard temperature and pressure

$$\begin{aligned} Q_{sd} &= 178076*(1-0.1844) \\ &= 145239 \text{ dscfm} \end{aligned}$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Methods 2-4: Actual Calculations for Unit 3, Run 1 Run ID: U3O-M29-R1

1. Metered gas sample volume at standard conditions

$$\begin{aligned} Vm(\text{std}) &= 78.811 * 0.9604 * (528/29.92) * (29.84 + (1.52/13.6)) / (80 + 460) \\ &= 74.087 \quad \text{dscf} \end{aligned}$$

2. Gas volume of water vapor collected in impinger liquid

$$\begin{aligned} Vwc(\text{std}) &= (851 - 400.0) * 0.04707 \\ &= 21.229 \quad \text{scf} \end{aligned}$$

3. Gas volume of water vapor collected in silica gel

$$\begin{aligned} Vwsg(\text{std}) &= (270.4 - 250.0) * 0.04715 \\ &= 0.962 \quad \text{scf} \end{aligned}$$

4. Moisture volume fraction in flue gas

$$\begin{aligned} Bws &= (21.229 + 0.962) / (21.229 + 0.962 + 74.087) \\ &= 0.2305 \end{aligned}$$

5. Moisture volume percentage in flue gas

$$\begin{aligned} \%H_2O &= 0.2305 * 100 \\ &= 23.05 \% \end{aligned}$$

6. Absolute pressure of flue gas

$$\begin{aligned} Ps &= 29.84 + (-11/13.6) \\ &= 29.03 \quad \text{in. Hg} \end{aligned}$$

7. Nitrogen content of flue gas

$$\begin{aligned} \%N_2 &= 100 - (10.45 + 8.54 + 0.0) \\ &= 81.01 \% \end{aligned}$$

8. Dry molecular weight of flue gas

$$\begin{aligned} Md &= (0.44 * 10.45) + (0.32 * 8.54) + (0.28 * (81.01 + 0.0)) \\ &= 30.01 \quad \text{lb/lb-mole} \end{aligned}$$

9. Wet molecular weight of flue gas

$$\begin{aligned} M_s &= 30.01*(1-0.2305)+(18*0.2305) \\ &= 27.24 \text{ lb/lb-mole} \end{aligned}$$

10. Fuel factor based on flue gas composition

$$\begin{aligned} F_o &= (20.9-8.54)/10.45 \\ &= 1.183 \end{aligned}$$

11. Excess air of flue gas

$$\begin{aligned} \%EA &= (8.54-(0.5*0.0))/((0.264*81.01)-(8.54-(0.5*0.0)))*100 \\ &= 66 \% \end{aligned}$$

12. Average gas velocity

$$\begin{aligned} V_s &= 85.49*0.84*0.6324*(((308+460)^{0.5})/(29.03*27.24)^{0.5}) \\ &= 44.75 \text{ ft/sec} \end{aligned}$$

13. Area of rectangular stack

$$\begin{aligned} A_s &= (105*132)/144 \\ &= 96.25 \text{ square feet} \end{aligned}$$

14. Area of round duct or stack - not applicable

15. Actual volumetric flow rate of flue gas

$$\begin{aligned} Q_a &= 44.75*96.25*60 \\ &= 258431 \text{ acfm} \end{aligned}$$

16. Flow rate of flue gas at standard temperature and pressure

$$\begin{aligned} Q_s &= 258431*((29.03*528)/((308+460)*29.92)) \\ &= 172386 \text{ scfm} \end{aligned}$$

17. Dry flow rate of flue gas at standard temperature and pressure

$$\begin{aligned} Q_{sd} &= 172386*(1-0.2305) \\ &= 132651 \text{ dscfm} \end{aligned}$$

## EPA METHOD 5 GRAVIMETRIC CALCULATIONS

1. **PM Collected in Probe Wash -  $M_{pw}$**

$$M_{pw} = (W_{pw})_{final} - (W_{pw})_{tare}$$

2. **Applicable Acetone Blank Correction -  $B_{apw}$**

$$B_{apw} = [(W_{ab})_{final} - (W_{ab})_{tare}] \times \frac{V_{pw}}{V_{ab}}$$

3. **Maximum Allowable Acetone Blank -  $B_{amax}$**

$$B_{amax} = 0.7845 \times 0.00001 \times V_{pw}$$

4. **Actual Probe Wash Blank Correction -  $B_{pw}$**

$$B_{pw} = \text{MINIMUM} [B_{apw}, B_{amax}]$$

5. **PM Collected on Filter -  $M_f$**

$$M_f = (W_f)_{final} - (W_f)_{tare}$$

6. **Total PM Collected for Method 5 Calculations -  $M_5$**

$$M_5 = M_{pw} + M_f - B_{pw}$$

### NOMENCLATURE

$B_{amax}$	=	Maximum allowable acetone blank correction, based on weight of acetone in probe wash, grams
$B_{apw}$	=	Acetone blank correction based on residue of blank, grams
$B_{pw}$	=	Acetone blank correction actually used, grams
$M_5$	=	Total mass of particulate in train corrected for acetone blank, grams
$M_f$	=	Mass gain of filter, grams
$M_{pw}$	=	Probe wash residue, grams
$V_{ab}$	=	Liquid volume of acetone blank, ml
$V_{pw}$	=	Liquid volume of probe wash, ml
$(W_{ab})_{final}$	=	Final weight of beaker containing acetone blank residue, grams
$(W_{ab})_{tare}$	=	Tare weight of beaker containing acetone blank residue, grams
$(W_f)_{final}$	=	Final weight of filter, grams
$(W_f)_{tare}$	=	Tare weight of filter, grams
$(W_{pw})_{final}$	=	Final weight of beaker containing probe wash residue, grams
$(W_{pw})_{tare}$	=	Tare weight of beaker containing probe wash residue, grams

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 5: Actual Calculations for Unit 1, Run 1 Run ID: U1O-M26A-R1

1. PM collected in probe wash

$$\begin{aligned} \text{Mpw} &= 65.2145 - 65.2035 \\ &= 0.01100 \text{ grams} \end{aligned}$$

2. Applicable acetone blank correction

$$\begin{aligned} \text{Bapw} &= (66.9915 - 66.9920) * (100/150) \\ &= -0.00033 \text{ grams} \quad (\text{Negative result treated as Zero}) \end{aligned}$$

3. Maximum allowable acetone blank

$$\begin{aligned} \text{Bamax} &= 0.7845 * 0.00001 * 100 \\ &= 0.00078 \text{ grams} \end{aligned}$$

4. Actual probe wash blank correction

$$\begin{aligned} \text{Bpw} &= \text{minimum} (0.00000, 0.00078) \\ &= 0.00000 \text{ grams} \end{aligned}$$

5. PM collected on filter

$$\begin{aligned} \text{Mf} &= .3729 - .3703 \\ &= 0.00260 \text{ grams} \end{aligned}$$

6. Total PM collected for method 5 calculations

$$\begin{aligned} \text{M5} &= 0.01100 + 0.00260 - 0.00000 \\ &= 0.01360 \text{ grams} \end{aligned}$$



## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 5: Actual Calculations for Unit 2, Run 1 Run ID: U2O-M26A-R1

1. PM collected in probe wash

$$\begin{aligned} \text{Mpw} &= 66.3375 - 66.3244 \\ &= 0.01310 \text{ grams} \end{aligned}$$

2. Applicable acetone blank correction

$$\begin{aligned} \text{Bapw} &= (66.9915 - 66.9920) * (100/150) \\ &= -0.00033 \text{ grams} \quad (\text{Negative result treated as Zero}) \end{aligned}$$

3. Maximum allowable acetone blank

$$\begin{aligned} \text{Bamax} &= 0.7845 * 0.00001 * 100 \\ &= 0.00078 \text{ grams} \end{aligned}$$

4. Actual probe wash blank correction

$$\begin{aligned} \text{Bpw} &= \text{minimum} (0.00000, 0.00078) \\ &= 0.00000 \text{ grams} \end{aligned}$$

5. PM collected on filter

$$\begin{aligned} \text{Mf} &= 0.3826 - 0.3813 \\ &= 0.00130 \text{ grams} \end{aligned}$$

6. Total PM collected for method 5 calculations

$$\begin{aligned} \text{M5} &= 0.01310 + 0.00130 - 0.00000 \\ &= 0.01440 \text{ grams} \end{aligned}$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 5: Actual Calculations for Unit 3, Run 1 Run ID: U3O-M26A-R1

1. PM collected in probe wash

$$\begin{aligned} \text{Mpw} &= 67.1468 - 67.1311 \\ &= 0.01570 \text{ grams} \end{aligned}$$

2. Applicable acetone blank correction

$$\begin{aligned} \text{Bapw} &= (66.9915 - 66.9920) * (100/150) \\ &= -0.00033 \text{ grams} \quad (\text{Negative result treated as Zero}) \end{aligned}$$

3. Maximum allowable acetone blank

$$\begin{aligned} \text{Bamax} &= 0.7845 * 0.00001 * 190 \\ &= 0.00149 \text{ grams} \end{aligned}$$

4. Actual probe wash blank correction

$$\begin{aligned} \text{Bpw} &= \text{minimum} (0.00000, 0.00078) \\ &= 0.00000 \text{ grams} \end{aligned}$$

5. PM collected on filter

$$\begin{aligned} \text{Mf} &= 0.3706 - 0.3696 \\ &= 0.00100 \text{ grams} \end{aligned}$$

6. Total PM collected for method 5 calculations

$$\begin{aligned} \text{M5} &= 0.01570 + 0.00100 + 0.00000 \\ &= 0.01670 \text{ grams} \end{aligned}$$

## PARTICULATE EMISSIONS CALCULATIONS

1. **Particulate Concentration -  $C_{sd}$**

$$C_{sd} = \frac{\Sigma(M_i)}{V_{m(std)}} \times \frac{7000}{453.593}$$

2. **Particulate Concentration Corrected to 7%  $O_2$  -  $C_{sd@7\%O_2}$**

$$C_{sd@7\%} = C_{sd} \times \frac{20.9 - 7.0}{20.9 - \%O_2}$$

3. **Particulate Concentration Corrected to 12%  $CO_2$  -  $C_{sd@12\%CO_2}$**

$$C_{sd@12\%} = C_{sd} \times \frac{12}{\%CO_2}$$

4. **Particulate Concentration Corrected to 50% Excess Air -  $C_{sd@50\%EA}$**

$$C_{sd@50\%EA} = C_{sd} \times \frac{100 + \%EA}{150}$$

5. **Particulate Mass Rate -  $M_p$**

$$M_p = \frac{\Sigma(M_i)}{V_{m(std)}} \times Q_{sd} \times \frac{60}{453.593}$$

6. **Isokinetic Variation - %ISO**

$$\%ISO = \frac{0.09450 \times (T_s + 460) \times V_{m(std)}}{P_s \times v_s \times A_n \times time \times (1 - B_{ws})}$$

## PARTICULATE EMISSIONS CALCULATIONS (continued)

### NOMENCLATURE

$A_n$	=	Nozzle area, ft <sup>2</sup>
$B_{ws}$	=	Moisture volume fraction
$C_{sd}$	=	Particulate concentration, grains/dscf
$D_n$	=	Nozzle diameter, inches
$\Sigma M_i$	=	Summation of PM collected in sample train, grams
$M_p$	=	Mass rate of particulate emissions, lb/hr
$P_s$	=	Absolute stack pressure, in.Hg
$Q_{sd}$	=	Dry standard gas flow rate, dscfm
time	=	Net sampling time, minutes
$T_s$	=	Average stack temperature, °F
$V_{m(std)}$	=	Corrected gas volume, dscf
$v_s$	=	Average gas velocity, ft/sec
%O <sub>2</sub>	=	Dry volumetric concentration of O <sub>2</sub> , %dv
%CO <sub>2</sub>	=	Dry volumetric concentration of CO <sub>2</sub> , %dv
%EA	=	Percent excess air
%Iso	=	Percent isokinetics

## PARTICULATE EMISSIONS CALCULATIONS (METRIC)

1. Total sample weight -  $W_i$  (milligrams)\*

$$W_i = M_5 \times 1000$$

2. Particulate Concentration -  $C_{mi}$  (milligrams/dscm)

$$C_{mi} = \frac{W_i \times 35.3145}{V_{mstd}}$$

3. Particulate Concentration corrected to 7%  $O_2$  -  $C_{mi7}$

$$C_{mi7} = C_{mi} \times \frac{13.9}{20.9 - \%O_2}$$

4. Particulate Concentration corrected to 12%  $CO_2$  -  $C_{mi12}$

$$C_{mi12} = C_{mi} \times \frac{12}{\%CO_2}$$

5. Particulate Concentration Corrected to 50% Excess Air -  $C_{mi@50\%EA}$

$$C_{mi@50\%EA} = C_{mi} \times \frac{100 + \%EA}{150}$$

6. Particulate Mass Rate -  $M_p$

$$G_i = \frac{M_5 \times Q_{sd} \times 60}{V_{mstd} \times 453.593}$$

7. Isokinetic Variation - %ISO

$$\%ISO = \frac{0.09450 \times (T_s + 460) \times V_{m(std)}}{P_s \times v_s \times A_n \times time \times (1 - B_{ws})}$$

## NOMENCLATURE

$A_n$	=	Nozzle Area (ft <sup>2</sup> )
$B_{ws}$	=	Moisture volume fraction
$C_{mi}$	=	Particulate concentration (mg/dscm)
$M_5$	=	Total mass of particulate matter (grams)
$M_P$	=	Mass Rate of particulate emissions (lb/hr)
$P_s$	=	Absolute Stack Pressure (in. Hg)
$Q_{sd}$	=	stack gas flow rate (dscfm)
time	=	Net sampling time (minutes)
$T_s$	=	Average Stack Temperature (°F)
$V_{mstd}$	=	the volume of gas sampled at STP (dscf)
$V_s$	=	Average Gas Velocity (ft/sec)
$W_i$	=	total sample weight (milligrams)
%O <sub>2</sub>	=	oxygen content in stack gas, dry %
%CO <sub>2</sub>	=	carbon dioxide content in stack gas, dry %
%EA	=	Percent excess air
% ISO	=	Percent Isokinetics
60	=	min/hr
1000	=	milligrams per gram
35.3145	=	cubic feet per cubic meter
453.593	=	grams/lb

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 5: Actual Calculations for Unit 1, Run 1 Run ID: U1O-M26A-R1

1. Particulate concentration

$$\begin{aligned} \text{Csd} &= (0.01360/77.672)*7000/453.593 \\ &= 0.00270 \text{ gr/dscf} \\ &= (0.01360/77.672)*35.3145*1000 \\ &= 6.18340 \text{ mg/dscm} \end{aligned}$$

2. Particulate concentration corrected to 7% O2

$$\begin{aligned} \text{Csd@7\%O}_2 &= 0.00270*((20.9-7.0)/(20.9-9.6)) \\ &= 0.00332 \text{ gr/dscf @ 7\%O}_2 \\ &= 6.18340*((20.9-7.0)/(20.9-9.6)) \\ &= 7.60613 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

3. Particulate concentration corrected to corrected to 12% CO2

$$\begin{aligned} \text{Csd@12\%CO}_2 &= 6.18340*(12/9.6) \\ &= 7.72925 \text{ mg/dscm @ 12\%CO}_2 \end{aligned}$$

4. Particulate concentration corrected to 50% excess air

$$\begin{aligned} \text{Csd@50\%EA} &= 6.18340*((100+81)/150) \\ &= 7.46130 \text{ mg/dscm @ 50\%EA} \end{aligned}$$

5. Particulate mass rate

$$\begin{aligned} \text{Mp} &= (0.01360/77.672)*137153*(60/453.593) \\ &= 3.1766 \text{ lb/hr} \end{aligned}$$

6. Isokinetic variation

$$\begin{aligned} \% \text{ISO} &= (0.0945*(315+460)*77.672)/(29.24*45.20*0.000428*120*(1-0.2111)) \\ &= 106.2 \% \end{aligned}$$

$$\text{nozzle area} = 0.000428 \text{ ft}^2$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 5: Actual Calculations for Unit 2, Run 1 Run ID: U2O-M26A-R1

1. Particulate concentration

$$\begin{aligned} \text{Csd} &= (0.01440/78.551)*7000/453.593 \\ &= 0.00283 \text{ gr/dscf} \\ &= (0.01440/78.551)*35.3145*1000 \\ &= 6.47387 \text{ mg/dscm} \end{aligned}$$

2. Particulate concentration corrected to 7% O<sub>2</sub>

$$\begin{aligned} \text{Csd@7\%O}_2 &= 0.00283*((20.9-7.0)/(20.9-10.7)) \\ &= 0.00386 \text{ gr/dscf @ 7\%O}_2 \\ &= 6.47387*((20.9-7.0)/(20.9-10.7)) \\ &= 8.82223 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

3. Particulate concentration corrected to corrected to 12% CO<sub>2</sub>

$$\begin{aligned} \text{Csd@12\%CO}_2 &= 6.47387*(12/8.5) \\ &= 9.13958 \text{ mg/dscm @ 12\%CO}_2 \end{aligned}$$

4. Particulate concentration corrected to 50% excess air

$$\begin{aligned} \text{Csd@50\%EA} &= 6.47387*((100+102)/150) \\ &= 8.71814 \text{ mg/dscm @ 50\%EA} \end{aligned}$$

5. Particulate mass rate

$$\begin{aligned} \text{Mp} &= (0.01440/78.551)*148964*(60/453.593) \\ &= 3.6122 \text{ lb/hr} \end{aligned}$$

6. Isokinetic variation

$$\begin{aligned} \% \text{ISO} &= (0.0945*(295+460)*78.551)/(29.16*45.61*0.000427606*120*(1-0.1704)) \\ &= 99.0 \% \end{aligned}$$

$$\text{nozzle area} = 0.000427606 \text{ ft}^2$$



## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 5: Actual Calculations for Unit 3, Run 1 Run ID: U3O-M26A-R1

1. Particulate concentration

$$\begin{aligned} \text{Csd} &= (0.01670/77.227)*7000/453.593 \\ &= 0.00334 \text{ gr/dscf} \\ &= (0.0167/77.227)*35.3145*1000 \\ &= 7.63661 \text{ mg/dscm} \end{aligned}$$

2. Particulate concentration corrected to 7% O<sub>2</sub>

$$\begin{aligned} \text{Csd@7\%O}_2 &= 0.00334*((20.9-7.0)/(20.9-8.3)) \\ &= 0.00368 \text{ gr/dscf @ 7\%O}_2 \\ &= 7.63661*((20.9-7.0)/(20.9-8.3)) \\ &= 8.42451 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

3. Particulate concentration corrected to corrected to 12% CO<sub>2</sub>

$$\begin{aligned} \text{Csd@12\%CO}_2 &= 7.63661*(12/10.7) \\ &= 8.56442 \text{ mg/dscm @ 12\%CO}_2 \end{aligned}$$

4. Particulate concentration corrected to 50% excess air

$$\begin{aligned} \text{Csd@50\%EA} &= 7.63661*((100+64)/150) \\ &= 8.34936 \text{ mg/dscm @ 50\%EA} \end{aligned}$$

5. Particulate mass rate

$$\begin{aligned} \text{Mp} &= (0.0167/77.227)*135446*(60/453.593) \\ &= 3.8743 \text{ lb/hr} \end{aligned}$$

6. Isokinetic variation

$$\begin{aligned} \% \text{ISO} &= (0.0945*(306+460)*77.227)/(29.07*45.17*0.000427606*120*(1-0.2246)) \\ &= 107.0 \% \end{aligned}$$

$$\text{nozzle area} = 0.000427606 \text{ ft}^2$$

## EPA METHOD 26A CALCULATIONS

1. MASS OF HCl IN SAMPLE - mg

$$M_H = (C_H - C_B) \times V_o \times \left( \frac{1 \text{ liter}}{1000 \text{ mliter}} \right)$$

2. CONCENTRATION OF HCl - ppm<sub>dv</sub>

$$C_{H(D)} = \frac{M_H}{V_{m(std)}} \times \left( \frac{1 \text{ gram}}{1000 \text{ mg}} \right) \times \left( \frac{\text{g-mole}}{MW_H \text{ grams}} \right) \times \left( \frac{0.84948 \text{ ft}^3}{\text{g-mole}} \right) \times 10^6$$

3. CONCENTRATION AT 7% O<sub>2</sub> - ppm<sub>dv</sub>

$$C_{7H} = C_{H(D)} \times \frac{20.9 - 7.0}{20.9 - \%O_2}$$

4. HOURLY EMISSIONS RATE - lb/hr

$$E_H = \frac{C_{H(D)} \times Q_{sd} \times 60 \times MW_H}{10^6 \times 0.84948 \times 453.593}$$

### NOMENCLATURE FOR EPA METHOD 26A

$C_B$	=	concentration of HCl in blank - mg/L
$C_H$	=	concentration of HCl in sample - mg/L
$C_{H(D)}$	=	Dry basis HCl concentration - ppm <sub>dv</sub>
$C_{7H}$	=	Concentration of gas HCl corrected to 7% O <sub>2</sub>
$E_H$	=	Mass emissions rate of HCl - lb/hr
$M_H$	=	Mass of HCl in sample - mg
$MW_H$	=	Molecular weight of HCl
	=	36.461
$Q_{sd}$	=	Average flue gas flow rate - dscfm
$V_{m(std)}$	=	Sample gas volume - dscf
$V_o$	=	Volume of sample solution - mL
$\%O_2$	=	Actual gas concentration of O <sub>2</sub> , % dry volume
60	=	Minutes per hour
0.84948	=	Molar volume of ideal gas - ft <sup>3</sup> /mole
453.593	=	Grams per pound
$10^6$	=	Parts per million

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 26A: Actual Calculations for Unit 1, Run 1 Run ID: U1O-M26A-R1

1. Mass of HCl in sample

$$M_H = 20.30 \text{ mg} \quad (\text{ND Blank} = 0)$$

Note: Non-detect blank treated as zero.

2. Concentration of HCl

$$\begin{aligned} C_{H(D)} &= (20.30/77.672)*(1/1000)*(0.84948/36.461)*10^6 \\ &= 6.09 \text{ ppmdv} \end{aligned}$$

3. Concentration at 7% O<sub>2</sub>

$$\begin{aligned} C_{7H} &= 6.09*((20.9-7.0)/(20.9-9.56)) \\ &= 7.46 \text{ ppmdv @ 7\% O}_2 \end{aligned}$$

4. Hourly emissions rate

$$\begin{aligned} C_{HCl} &= (6.09*137153*60*36.461/10^6/0.84948/453.593) \\ &= 4.74 \text{ lb/hr} \end{aligned}$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 26A: Actual Calculations for Unit 2, Run 1 Run ID: U2O-M26A-R1

1. Mass of HCl in sample

$$M_H = 24.10 \text{ mg} \quad (\text{ND Blank} = 0)$$

Note: Non-detect blank treated as zero.

2. Concentration of HCl

$$\begin{aligned} C_{H(D)} &= (24.1/78.551) * (1/1000) * (0.84948/36.461) * 10^6 \\ &= 7.15 \text{ ppmdv} \end{aligned}$$

3. Concentration at 7% O<sub>2</sub>

$$\begin{aligned} C_{7H} &= 7.15 * ((20.9-7)/(20.9-10.74)) \\ &= 9.78 \text{ ppmdv @ 7\% O}_2 \end{aligned}$$

4. Hourly emissions rate

$$\begin{aligned} C_{HCl} &= (7.15 * 148964 * 60 * 36.461 / 10^6 / 0.84948 / 453.593) \\ &= 6.05 \text{ lb/hr} \end{aligned}$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 26A: Actual Calculations for Unit 3, Run 1 Run ID: U3O-M26A-R1

1. Mass of HCl in sample

$$M_H = 63.90 \text{ mg} \quad (\text{ND Blank} = 0)$$

Note: Non-detect blank treated as zero.

2. Concentration of HCl

$$\begin{aligned} C_{H(D)} &= (63.90/77.227) * (1/1000) * (0.84948/36.461) * 10^6 \\ &= 19.28 \text{ ppmdv} \end{aligned}$$

3. Concentration at 7% O<sub>2</sub>

$$\begin{aligned} C_{7H} &= 19.28 * ((20.9 - 7.0) / (20.9 - 8.33)) \\ &= 21.32 \text{ ppmdv @ 7\% O}_2 \end{aligned}$$

4. Hourly emissions rate

$$\begin{aligned} C_{HCl} &= (19.28 * 135492 * 60 * 36.461 / 10^6 / 0.84948 / 453.593) \\ &= 14.83 \text{ lb/hr} \end{aligned}$$

## EPA METHOD 29 METALS CALCULATIONS

### 1. Total sample weight - $W_i$ (micrograms)\*

For Mercury:

$$W_i = [m_{front} - mb_{front}] + [m_{back} - mb_{back}]$$

For All Metals Except Mercury:

$$W_i = [m_{front} + m_{back}] - [mb_{front} + mb_{back}]$$

### 2. Gas Concentration - $C_{m_i}$ (micrograms/dscm)

$$C_{m_i} = \frac{W_i \times 35.3145}{V_{mstd}}$$

### 3. Concentration corrected to 7% $O_2$ , $C_{i7}$

$$C_{i7} = C_i \times \frac{13.9}{20.9 - \%O_2}$$

### 4. Concentration corrected to 12% $CO_2$ , $C_{i12}$

$$C_{i12} = C_i \times \frac{12}{\%CO_2}$$

### 5. The mass flow rate of substance (I), $G_i$ (lb/hr),

$$G_i = \frac{W_i \times Q_{sd} \times 60}{V_{mstd} \times 10^6 \times 453.593}$$

## NOMENCLATURE

$i$	=	metal of interest (e.g., Hg)
$m_{front}$	=	total sample weight collected in front half of sample train (micrograms)
$m_{back}$	=	total sample weight collected in back half of sample train (micrograms)
$mb_{front}$	=	front half blank correction (micrograms)
$mb_{back}$	=	back half blank correction (micrograms)
$Q_{sd}$	=	stack gas flow rate (dscfm)
$V_{mstd}$	=	the volume of gas sampled at STP (dscf)
$W_i$	=	total sample weight of $i$ (micrograms)
$\%O_2$	=	oxygen content in stack gas, dry %
$\%CO_2$	=	carbon dioxide content in stack gas, dry %
60	=	min/hr
$10^6$	=	micrograms per gram
35.3145	=	cubic feet per cubic meter
453.593	=	grams/lb

## **EPA METHOD 29 METALS CALCULATIONS (continued)**

### **\*BLANK CORRECTION RULES**

#### **For All Metals Except Mercury (combined front half and back half fractions)**

If the measured blank value is in the range of 0.0 to 1.0  $\mu\text{g}$ , then use that value to correct the total sample value. If the blank value exceeds 1.0  $\mu\text{g}$ , then the greater of the two following values may be used: (1) 1.0  $\mu\text{g}$ , or (2) 5 percent of the total sample.

#### **For Mercury (separate front half and back half fractions)**

If the sum of the front and back half blank values is in the range of 0.0 to 0.6  $\mu\text{g}$ , then use this value. If it exceeds 0.6  $\mu\text{g}$ , then use the greater of (a) 0.6  $\mu\text{g}$  or (b) the lesser of the sum of the front and back half blank values or 5 percent of the emission sample value (all mercury fractions added together).

### **METALS CALCULATION RULES**

#### **For All Fractions above MDL (Minimum Detection Limit)**

Emissions are calculated using arithmetic sum of all fractions. Results are reported as detected or actual emissions (no "<" prefix designation).

#### **For One (Or More) Fractions above MDL and One (Or More) Fractions below MDL**

Emissions are calculated based only on the data above the MDL. Data below the MDL are treated as zero. Results are reported as detected or actual emissions (no "<" prefix designation).

#### **For All Fractions below MDL**

Emissions are calculated based on arithmetic sum of all fractions. Results are reported as being less than the MDL (preceded with "<" designation).

**In cases where the blank corrected sample total is less than the MDL, the MDL is applied.**

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 29: Actual Calculations for Unit 1, Run 1 Run ID: U1O-M29-R1

1. Total sample weight (Pb)

$$\begin{aligned}W_i &= (26.0-0.83) \\ &= 25.17 \quad \mu\text{g}\end{aligned}$$

2. Gas concentration (Pb)

$$\begin{aligned}C_{mi} &= (25.17*35.3145)/76.456 \\ &= 11.63 \quad \mu\text{g/dscm}\end{aligned}$$

- 3 Concentration (Pb) corrected to 7% O<sub>2</sub>

$$\begin{aligned}C_{i7} &= 11.63*(13.9/(20.9-9.98)) \\ &= 14.80 \quad \mu\text{g/dscm @ 7\% O}_2\end{aligned}$$

- 4 Concentration (Pb) corrected to 12% CO<sub>2</sub>

$$\begin{aligned}C_{i12} &= 11.63*(12/9.37) \\ &= 14.89 \quad \mu\text{g/dscm @ 12\% CO}_2\end{aligned}$$

- 5 The mass flow rate of substance (Pb)

$$\begin{aligned}G_i &= (25.17*139513*60)/76.456/10^6/453.593 \\ &= 6.08\text{E-}03 \quad \text{lb/hr}\end{aligned}$$



## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 29: Actual Calculations for Unit 2, Run 1 Run ID: U2O-M29-R1

1. Total sample weight (Pb)

$$\begin{aligned}W_i &= (19.30-0.83) \\ &= 18.47 \quad \mu\text{g}\end{aligned}$$

2. Gas concentration (Pb)

$$\begin{aligned}C_{mi} &= (18.47*35.3145)/77.137 \\ &= 8.46 \quad \mu\text{g/dscm}\end{aligned}$$

3. Concentration (Pb) corrected to 7% O<sub>2</sub>

$$\begin{aligned}C_{i7} &= 8.46*(13.9/(20.9-10.60)) \\ &= 11.42 \quad \mu\text{g/dscm @ 7\% O}_2\end{aligned}$$

4. Concentration (Pb) corrected to 12% CO<sub>2</sub>

$$\begin{aligned}C_{i12} &= 8.46*(12/8.60) \\ &= 11.80 \quad \mu\text{g/dscm @ 12\% CO}_2\end{aligned}$$

5. The mass flow rate of substance (Pb)

$$\begin{aligned}G_i &= (18.47*145261*60)/77.137/10^6/453.593 \\ &= 4.60\text{E-}03 \quad \text{lb/hr}\end{aligned}$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

### EPA Method 29: Actual Calculations for Unit 3, Run 1 Run ID: U3O-M29-R1

1. Total sample weight (Pb)

$$\begin{aligned}W_i &= (19.7-0.83) \\ &= 18.87 \quad \mu\text{g}\end{aligned}$$

2. Gas concentration (Pb)

$$\begin{aligned}C_{mi} &= (18.87*35.3145)/74.099 \\ &= 8.99 \quad \mu\text{g/dscm}\end{aligned}$$

3. Concentration (Pb) corrected to 7% O<sub>2</sub>

$$\begin{aligned}C_{i7} &= 8.99*(13.9/(20.9-8.54)) \\ &= 10.11 \quad \mu\text{g/dscm @ 7\% O}_2\end{aligned}$$

4. Concentration (Pb) corrected to 12% CO<sub>2</sub>

$$\begin{aligned}C_{i12} &= 8.99*(12/10.45) \\ &= 10.32 \quad \mu\text{g/dscm @ 12\% CO}_2\end{aligned}$$

5. The mass flow rate of substance (Pb)

$$\begin{aligned}G_i &= (18.87*132648*60)/74.099/10^6/453.593 \\ &= 4.47\text{E-}03 \quad \text{lb/hr}\end{aligned}$$

## REDUCTION EFFICIENCY CALCULATION

### 1. Reduction efficiency

$$Eff = \frac{M_i - M_o}{M_i} \times 100$$

or

$$Eff = \frac{C_i - C_o}{C_i} \times 100$$

#### Nomenclature

Eff	=	Reduction efficiency, percent
C <sub>i</sub>	=	Pollutant concentration, corrected to 7% oxygen (ppmdv @ 7% O <sub>2</sub> ), at inlet to control device
C <sub>o</sub>	=	Pollutant concentration, corrected to 7% oxygen (ppmdv @ 7% O <sub>2</sub> ), at outlet to control device
M <sub>i</sub>	=	Pollutant mass emissions rate (lb/hr) at inlet to control device
M <sub>o</sub>	=	Pollutant mass emissions rate (lb/hr) at outlet to control device
100	=	Correction for percentage calculation

## Sample Calculations for Pinellas County RRF April 2013 Testing

**Reduction Efficiency: Actual Calculations for Unit 1, Run 1**  
**Run IDs: U1O-M29-R1 / U1IN-M29-R1**

1. Reduction Efficiency (Hg lb/hr)

$$\begin{aligned} \text{Eff} &= (2.07\text{E-}02 - 1.48\text{E-}03) / 2.07\text{E-}02 * 100 \\ &= 92.9 \quad \% \end{aligned}$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

**Reduction Efficiency: Actual Calculations for Unit 2, Run 1**  
**Run IDs: U2O-M29-R1 / U2IN-M29-R1**

1. Reduction Efficiency (Hg lb/hr)

$$\begin{aligned} \text{Eff} &= (1.61\text{E-}02 - 5.25\text{E-}04) / 1.61\text{E-}02 * 100 \\ &= 96.7 \quad \% \end{aligned}$$

## Sample Calculations for Pinellas County RRF April 2013 Testing

Reduction Efficiency: Actual Calculations for Unit 3, Run 1  
Run IDs: U3O-M29-R1 / U3IN-M29-R1

1. Reduction Efficiency (Hg lb/hr)

$$\begin{aligned} \text{Eff} &= (4.91\text{E-}02 - 2.83\text{E-}03) / 4.91\text{E-}02 * 100 \\ &= 94.2 \quad \% \end{aligned}$$

# EPA METHOD 201A EQUATIONS

## Molecular Weight of Dry Gas

$$\text{eq 1} \quad M_d = 0.44 \cdot \text{CO}_2 + 0.32 \cdot \text{O}_2 + 0.28 \cdot (100 - \text{O}_2 - \text{CO}_2)$$

## Molecular Weight of Wet Gas

$$\text{eq 2} \quad M_w = M_d \cdot (1 - B_{ws}) + 18 \cdot B_{ws}$$

## Gas Stream Viscosity

$$\text{eq 3} \quad \mu = C_1 + C_2 \cdot (T_s)^{0.5} + C_3 \cdot (T_s)^{-2} + C_4 \cdot (\text{O}_2\text{wet}) - C_5 \cdot B_{ws} + C_6 \cdot B_{ws} \cdot T_s^2$$

## Cunningham Correction Factor

$$\text{eq 4} \quad C = 1 + 0.0057193 \cdot \left( \frac{\mu}{(P_s \cdot D_p)} \right) \cdot (T_s / M_w)^{0.5}$$

## Lower Limit Cut Diameter for Cyclone I for $N_{re} < 3,162$

$$\text{eq 5} \quad D_{50LL} = 9.507 \cdot C^{0.3007} \cdot \left( \frac{M_w \cdot P_s}{T_s} \right)^{0.1993}$$

## Cut Diameter for Cyclone I for the Middle of the Overlap Zone

$$\text{eq 6} \quad D_{50T} = \frac{(11 + D_{50LL})}{2}$$

## Sampling Rate Using Both PM10 and PM2.5 Cyclones

$$\text{eq 7} \quad Q_s = Q_i = 0.07296 \cdot \mu \cdot \left( \frac{T_s}{M_w \cdot P_s} \right)^{0.2949} \cdot (1 / D_{50T})^{1.4102}$$

## Sampling Rate Using Only PM2.5 Cyclone

$$\text{eq 8 and 9} \quad Q_{IV} = \text{Not applicable.}$$

## Reynolds Number

$$\text{eq 10} \quad N_{re} = (8.64 \cdot 10^5) \cdot \left( \frac{P_s \cdot M_w}{T_s} \right) \cdot (Q_s / \mu)$$

# EPA METHOD 201A EQUATIONS

## Meter Box Orifice Pressure Drop

$$\text{eq 11} \quad \Delta H = \frac{((Q_s(1-B_{ws})P_s)/T_s)^2 * ((1.083 * T_m * M_d * \Delta H_0) / P_{bar})}{}$$

## Lower Limit Cut Diameter for Cyclone I for $N_{re} \geq 3,162$

$$\text{eq 12} \quad D_{50LL} = 10.0959 * C^{0.4400} * ((M_w * P_s) / T_s)^{0.0600}$$

## Velocity of Stack Gas

$$\text{eq 13} \quad V_s = K_p * C_p * (\Delta p^{0.5})_{avg} * (T_s / (P_s * M_w))^{0.5}$$

## Calculated Nozzle Diameter for Acceptable Sampling Rate

$$\text{eq 14} \quad D = ((3.056 * Q_s) / V_s)^{0.5}$$

## Velocity of Gas in Nozzle

$$\text{eq 15} \quad V_n = (Q_s / 60) / A_n$$

## Minimum Nozzle/Stack Velocity Ratio Parameter

$$\text{eq 16} \quad R_{min} = 0.2457 + (0.3072 - ((0.2603 * \mu * Q_s^{0.5}) / V_n^{1.5})^{0.5})$$

## Maximum Nozzle/Stack Velocity Ratio Parameter

$$\text{eq 17} \quad R_{max} = 0.4457 + (0.5690 - ((0.2603 * \mu * Q_s^{0.5}) / V_n^{1.5})^{0.5})$$

## Minimum Gas Velocity for $R_{min} < 0.5$

$$\text{eq 18} \quad R_{min} < 0.5 \quad V_{min} = V_n * 0.5$$



# EPA METHOD 201A EQUATIONS

## Minimum Gas Velocity for $R_{min} \geq 0.5$

eq 19       $R_{min} \geq 0.5$                        $V_{min} = V_n * R_{min}$

## Maximum Gas Velocity for $R_{max} < 1.5$

eq 20       $R_{max} < 1.5$                        $V_{max} = V_n * R_{max}$

## Maximum Gas Velocity for $R_{max} \geq 1.5$

eq 21       $R_{max} \geq 1.5$                        $V_{max} = V_n * 1.5$

## Minimum Velocity Pressure

eq 22     $\Delta P_{min} = (1.3686 * 10^{-4}) * (P_s * M_w / T_s) * (V_{min} / C_p)^2$

## Maximum Velocity Pressure

eq 23     $\Delta P_{max} = (1.3686 * 10^{-4}) * (P_s * M_w / T_s) * (V_{max} / C_p)^2$

## Sampling Dwell Time at Each Point

eq 24     $t_n = (C_p * (\Delta P_1)^{0.5}) / (C'_p * (\Delta P_1)^{0.5})_{avg} * (tr / N t_p)$

## Adjusted Velocity Pressure

eq 25     $\Delta p_s = \Delta P_m * (C_p / C'_p)^2$

## Average Probe Blockage Factor

eq 26     $bf = 22.0 / A$

# EPA METHOD 201A EQUATIONS

## Velocity Pressure

$$\text{eq 27} \quad \Delta p_{s2} = \Delta p_{s1} * (1 / (1 - b_f))^2$$

## Dry Gas Volume Sampled at Standard Conditions

$$\text{eq 28} \quad V_{ms} = (528 * 29.92) * (Y * V_m) * ((P_{bar} + (\Delta H / 13.6)) / T_m)$$

## Sample Flow Rate at Standard Conditions

$$\text{eq 29} \quad Q_{sST} = V_{ms} / \theta$$

## Volume of Water Vapor

$$\text{eq 30} \quad V_{wc} = 0.04707 * V_c \quad (\text{for liquid impingers})$$

$$V_{sg} = 0.04715 * V_c \quad (\text{for silica gel impinger})$$

$$V_{ws} = V_{wc} + V_{sg}$$

## Moisture Content of Gas Stream

$$\text{eq 31} \quad B_{ws} = V_{ws} / (V_{ms} + V_{ws})$$

## Sampling Rate

$$\text{eq 32} \quad Q_s = (29.92 / 528) * Q_{sST} * (1 / (1 - B_{ws})) * (T_s / P_s)$$

## Actual Particle Cut Diameter for Cyclone I

$$\text{eq 33} \quad D_{50} = 0.15625 * (T_s / (M_w * P_s))^{0.2091} * (\mu / Q_s)^{0.7091}$$

## Particle Cut Diameter for $N_{re} < 3,162$ for Cyclone IV

$$\text{eq 34} \quad D_{50} = 0.0024302 * (\mu / Q_s)^{1.1791} * ((1/C)^{0.5}) * (T_s / (P_s * M_w))^{0.6790}$$

# EPA METHOD 201A EQUATIONS

## Particle Cut Diameter for $N_{re} \geq 3,162$ for Cyclone IV

eq 35  $D_{50} = 0.019723 * ((\mu/Qs)^{0.8058}) * ((1/C)^{0.5}) * ((Ts/(Ps*Mw))^{0.3058})$

## Re-estimated Cunningham Correction Factor

eq 36  $Cr = 1 + 0.0057193 * (\mu / (Ps * D_{50})) * (Ts / Mw)^{0.5}$

## Re-calculated Particle Cut Diameter for $N_{re} < 3,162$

eq 37  $D_{50-1} = 0.0024302 * ((\mu/Qs)^{1.1791}) * ((1/Cr)^{0.5}) * ((Ts/(Ps*Mw))^{0.3058})$

## Re-calculated Particle Cut Diameter for $N_{re} \geq 3,162$

eq 38  $D_{50-1} = 0.019723 * ((\mu/Qs)^{0.8058}) * ((1/Cr)^{0.5}) * ((Ts/(Ps*Mw))^{0.3058})$

## Ratio (Z) Between D50 and D50-1 Values

eq 39  $Z = D_{50-1} / D_{50}$

## Acceptance Criteria for Z Values

eq 40  $0.99 \leq [ Z = (D_{50N} / D_{50N+1}) ] \leq 1.01$

## Percent Isokinetic Sampling

eq 41  $I = (100 * Ts * Vms * 29.92) / (60 * Vs * \theta * An * Ps * (1 - Bws) * 528)$

## Acetone Blank Concentration

eq 42  $Ca = ma / (Va * pa)$

# EPA METHOD 201A EQUATIONS

## Acetone Blank Correction Weight

$$\text{eq 43} \quad M_{(2)} = W_{(2)} - Wa_{(2)}$$

$$M_{(3,4)} = W_{(3,4)} - Wa_{(3,4)}$$

## Acetone Blank Weight

$$\text{eq 44} \quad Wa = Ca \cdot Vaw \cdot pa$$

## Concentration of Total Filterable Particulate Matter

$$\text{eq 45} \quad C_{tf} = (7000/453592) \cdot ((M1+M2+M3+M4)/Vms)$$

## Concentration of Filterable PM10 Particulate Matter

$$\text{eq 46} \quad C_{f \text{ PM10}} = (7000/453592) \cdot ((M1+M3+M4)/Vms)$$

## Concentration of Filterable PM2.5 Particulate Matter

$$\text{eq 47} \quad C_{f \text{ PM2.5}} = (7000/453592) \cdot ((M1+M4)/Vms)$$

# EPA METHOD 201A EQUATIONS

## Nomenclature

A = Area of stack or duct at sampling location, square inches.

$A_n$  = Area of nozzle, square feet.

$b_f$  = Average blockage factor calculated in Equation 26, dimensionless.

$B_{ws}$  = Moisture content of gas stream, fraction (e.g., 10 percent H<sub>2</sub>O is  $B_{ws} = 0.10$ ).

C = Cunningham correction factor for particle diameter,  $D_p$ , and calculated using the actual stack gas temperature, dimensionless.

%CO<sub>2</sub> = Carbon Dioxide content of gas stream, percent by volume.

$C_a$  = Acetone blank concentration, mg/mg.

$C_{fPM_{10}}$  = Conc. of filterable PM<sub>10</sub>, gr/DSCF.

$C_{fPM_{2.5}}$  = Conc. of filterable PM<sub>2.5</sub>, gr/DSCF.

$C_p$  = Pitot coefficient for the combined cyclone pitot, dimensionless.

$C_p'$  = Coefficient for the pitot used in the preliminary traverse, dimensionless.

$C_r$  = Re-estimated Cunningham correction factor for particle diameter equivalent to the actual cut size diameter and calculated using the actual stack gas temperature, dimensionless.

$C_{tf}$  = Conc. of total filterable PM, gr/DSCF.

$C_1 = -150.3162$  (micropoise)

$C_2 = 18.0614$  (micropoise/ $K^{0.5}$ )  
 $= 13.4622$  (micropoise/ $R^{0.5}$ )

$C_3 = 1.19183 \times 10^6$  (micropoise/ $K^2$ )  
 $= 3.86153 \times 10^6$  (micropoise/ $R^2$ )

$C_4 = 0.591123$  (micropoise)

$C_5 = 91.9723$  (micropoise)

$C_6 = 4.91705 \times 10^{-5}$  (micropoise/ $K^2$ )  
 $= 1.51761 \times 10^{-5}$  (micropoise/ $R^2$ )

D = Inner diameter of sampling nozzle mounted on Cyclone I, inches.

$D_p$  = Physical particle size, micrometers.

## EPA METHOD 201A EQUATIONS

$D_{50}$  = Particle cut diameter, micrometers.

$D_{50-1}$  = Re-calculated particle cut diameters based on re-estimated  $C_r$ , micrometers.

$D_{50LL}$  = Cut diameter for cyclone I corresponding to the 2.25 micrometer cut diameter for cyclone IV, micrometers.

$D_{50N}$  =  $D_{50}$  value for cyclone IV calculated during the Nth iterative step, micrometers.

$D_{50(N+1)}$  =  $D_{50}$  value for cyclone IV calculated during the N+1 iterative step, micrometers.

$D_{50T}$  = Cyclone I cut diameter corresponding to the middle of the overlap zone shown in Figure 10 of Section 17, micrometers.

$I$  = Percent isokinetic sampling, dimensionless.

$K_p$  = 85.49, ((ft/sec)/(pounds/mole  $^{-\circ}R$ )).

$m_a$  = Mass of residue of acetone after evaporation, mg.

$M_d$  = Molecular weight of dry gas, pounds/pound mole.

mg = Milligram.

mg/L = Milligram per liter.

$M_w$  = Molecular weight of wet gas, pounds/pound mole.

$M_1$  = Milligrams of PM collected on the filter, less than or equal to 2.5 micrometers.

$M_2$  = Milligrams of PM recovered from Container #2 (acetone blank corrected), greater than 10 micrometers.

$M_3$  = Milligrams of PM recovered from Container #3 (acetone blank corrected), less than or equal to 10 and greater than 2.5 micrometers.

$M_4$  = Milligrams of PM recovered from Container #4 (acetone blank corrected), less than or equal to 2.5 micrometers.

$N_{tp}$  = Number of iterative steps or total traverse points.

$N_{re}$  = Reynolds number, dimensionless.

## EPA METHOD 201A EQUATIONS

$\%O_{2,wet}$  = Oxygen content of gas stream, % by volume of wet gas. (Note: The oxygen percentage used in Equation 3 is on a wet gas basis. That means that since oxygen is typically measured on a dry gas basis, the measured percent  $O_2$  must be multiplied by the quantity  $(1 - B_{ws})$  to convert to the actual volume fraction. Therefore,  $\%O_{2,wet} = (1 - B_{ws}) * \%O_{2,dry}$ )

$P_{bar}$  = Barometric pressure, inches Hg.

$P_s$  = Absolute stack gas pressure, inches Hg.

$Q_s$  = Sampling rate for cyclone I to achieve specified  $D_{50}$ .

$Q_{sST}$  = Dry gas sampling rate through the sampling assembly, DSCFM.

$Q_I$  = Sampling rate for cyclone I to achieve specified  $D_{50}$ .

$R_{max}$  = Nozzle/stack velocity ratio parameter, dimensionless.

$R_{min}$  = Nozzle/stack velocity ratio parameter, dimensionless.

$T_m$  = Meter box and orifice gas temperature, °R.

$t_n$  = Sampling time at point n, min.

$t_r$  = Total projected run time, min.

$T_s$  = Absolute stack gas temperature, °R.

$t_1$  = Sampling time at point 1, min.

$v_{max}$  = Maximum gas velocity calculated from Equations 18 or 19, ft/sec.

$v_{min}$  = Minimum gas velocity calculated from Equations 16 or 17, ft/sec.

$v_n$  = Sample gas velocity in the nozzle, ft/sec.

$v_s$  = Velocity of stack gas, ft/sec.

$V_a$  = Volume of acetone blank, ml.

$V_{aw}$  = Volume of acetone used in sample recovery wash, ml.

$V_c$  = Quantity of water captured in impingers and silica gel, ml.

$V_m$  = Dry gas meter volume sampled, ACF.

$V_{ms}$  = Dry gas meter volume sampled, corrected to standard conditions, DSCF.

$V_{ws}$  = Volume of water vapor, SCF.

## EPA METHOD 201A EQUATIONS

$V_b$  = Volume of aliquot taken for IC analysis, ml.

$V_{ic}$  = Volume of impinger contents sample, ml.

$W_a$  = Weight of blank residue in acetone used to recover samples, mg.

$W_{2,3,4}$  = Weight of PM recovered from Containers #2, #3, and #4, mg.

$Z$  = Ratio between estimated cyclone IV D50 values, dimensionless.

$\Delta H$  = Meter box orifice pressure drop, inches W.C.

$\Delta H_{@}$  = Pressure drop across orifice at flow rate of 0.75 SCFM at standard conditions, inches W.C. (Note: Specific to each orifice and meter box.)

$[(\Delta p)^{0.5}]_{avg}$  = Average of square roots of the velocity pressures measured during the preliminary traverse, inches W.C.

$\Delta p_m$  = Observed velocity pressure using S-type pitot tube in preliminary traverse, inches W.C.

$\Delta p_{avg}$  = Average velocity pressure, inches W.C.

$\Delta p_{max}$  = Maximum velocity pressure, inches W.C.

$\Delta p_{min}$  = Minimum velocity pressure, inches W.C.

$\Delta p_n$  = Velocity pressure measured at point n during the test run, inches W.C.

$\Delta p_s$  = Velocity pressure calculated in Equation 25, inches W.C.

$\Delta p_{s1}$  = Velocity pressure adjusted for combined cyclone pitot tube, inches W.C.

$\Delta p_{s2}$  = Velocity pressure corrected for blockage, inches W.C.

$\Delta p_1$  = Velocity pressure measured at point 1, inches W.C.

$\gamma$  = Dry gas meter gamma value, dimensionless.

$\mu$  = Gas viscosity, micropoise.

$\theta$  = Total run time, min.

$\rho_a$  = Density of acetone, mg/ml.

12.0 = Constant calculated as 60 percent of 20.5 square inch cross-sectional area of combined cyclone head, square inches.



**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 1 OUTLET**  
**U1O-M201A/202-R1**

---

**Molecular Weight of Dry Gas**

$$\begin{aligned} \text{eq 1} \quad M_d &= 0.44 \cdot \text{CO}_2 + 0.32 \cdot \text{O}_2 + 0.28 \cdot (100 - \text{O}_2 - \text{CO}_2) \\ &= 29.93 \end{aligned}$$

**Molecular Weight of Wet Gas**

$$\begin{aligned} \text{eq 2} \quad M_w &= M_d \cdot (1 - B_{ws}) + 18 \cdot B_{ws} \\ &= 27.70 \end{aligned}$$

**Gas Stream Viscosity**

$$\begin{aligned} \text{eq 3} \quad \mu &= C_1 + C_2 \cdot (T_s^{0.5}) + C_3 \cdot (T_s^{-2}) + C_4 \cdot (\text{O}_{2\text{wet}}) - C_5 \cdot B_{ws} + C_6 \cdot B_{ws} \cdot T_s^{-2} \\ &= 222.23 \end{aligned}$$

**Cunningham Correction Factor**

$$\begin{aligned} \text{eq 4} \quad C &= 1 + 0.0057193 \cdot (\mu / (P_s \cdot D_p)) \cdot (T_s / M_w)^{0.5} \\ &= 1.09 \end{aligned}$$

**Lower Limit Cut Diameter for Cyclone I for Nre < 3,162**

$$\begin{aligned} \text{eq 5} \quad D_{50LL} &= 9.507 \cdot C^{0.3007} \cdot ((M_w \cdot P_s) / T_s)^{0.1993} \\ &= 9.82 \end{aligned}$$

**Cut Diameter for Cyclone I for the Middle of the Overlap Zone**

$$\begin{aligned} \text{eq 6} \quad D_{50T} &= ((11 + D_{50LL}) / 2) \\ &= 10.41 \text{ (Depends on value of Nre from Eq. 10)} \end{aligned}$$

**Sampling Rate Using Both PM10 and PM2.5 Cyclones**

$$\begin{aligned} \text{eq 7} \quad Q_s = Q_i &= 0.07296 \cdot \mu \cdot (T_s / (M_w \cdot P_s))^{0.2949} \cdot (1 / D_{50T})^{1.4102} \\ &= 0.591 \end{aligned}$$

**Sampling Rate Using Only PM2.5 Cyclone**

$$\text{eq 8 and 9} \quad Q_{IV} = \text{Not applicable.}$$

**Reynolds Number**

$$\begin{aligned} \text{eq 10} \quad N_{re} &= (8.64 \cdot 10^5) \cdot ((P_s \cdot M_w) / T_s) \cdot (Q_s / \mu) \\ &\quad Q_s \text{ obtained from Eq. 32} \\ &= 2392 \end{aligned}$$

**Meter Box Orifice Pressure Drop**

$$\begin{aligned} \text{eq 11} \quad \Delta H &= (((Q_s \cdot (1 - B_{ws}) \cdot P_s) / T_s)^2) \cdot ((1.083 \cdot T_m \cdot M_d \cdot \Delta H_{@}) / P_{bar}) \\ &= 0.32 \end{aligned}$$

**Lower Limit Cut Diameter for Cyclone I for Nre ≥ 3,162**

$$\begin{aligned} \text{eq 12} \quad D_{50LL} &= 10.0959 \cdot C^{0.4400} \cdot ((M_w \cdot P_s) / T_s)^{0.0600} \\ &= 10.52 \end{aligned}$$

**Velocity of Stack Gas**

$$\begin{aligned} \text{eq 13} \quad V_s &= K_p \cdot C_p \cdot (\Delta p^{0.5})_{\text{avg}} \cdot (T_s / (P_s \cdot M_w))^{0.5} \\ &= 85.49 \cdot C_p \cdot (\Delta p^{0.5})_{\text{avg}} \cdot (T_s / (P_s \cdot M_w))^{0.5} \\ &= 49.08 \end{aligned}$$

**Calculated Nozzle Diameter for Acceptable Sampling Rate**

$$\begin{aligned} \text{eq 14} \quad D &= ((3.056 \cdot Q_s) / V_s)^{0.5} \\ &= 0.193 \end{aligned}$$

**Velocity of Gas in Nozzle**

$$\begin{aligned} \text{eq 15} \quad V_n &= (Q_s / 60) / A_n \\ &= 55.36 \end{aligned}$$

**Minimum Nozzle/Stack Velocity Ratio Parameter**

$$\begin{aligned} \text{eq 16} \quad R_{\min} &= 0.2457 + (0.3072 - ((0.2603 \cdot \mu \cdot Q_s^{0.5}) / V_n^{1.5})^{0.5}) \\ &= 0.692 \end{aligned}$$

**Maximum Nozzle/Stack Velocity Ratio Parameter**

$$\begin{aligned} \text{eq 17} \quad R_{\max} &= 0.4457 + (0.5690 - ((0.2603 \cdot \mu \cdot Q_s^{0.5}) / V_n^{1.5})^{0.5}) \\ &= 1.268 \end{aligned}$$

**Minimum Gas Velocity for  $R_{\min} < 0.5$** 

$$\begin{aligned} \text{eq 18} \quad R_{\min} < 0.5 \quad V_{\min} &= V_n \cdot 0.5 \\ &= \text{Not applicable} \end{aligned}$$

**Minimum Gas Velocity for  $R_{\min} \geq 0.5$** 

$$\begin{aligned} \text{eq 19} \quad R_{\min} \geq 0.5 \quad V_{\min} &= V_n \cdot R_{\min} \\ &= 38.317 \end{aligned}$$

**Maximum Gas Velocity for  $R_{\max} < 1.5$** 

$$\begin{aligned} \text{eq 20} \quad R_{\max} < 1.5 \quad V_{\max} &= V_n \cdot R_{\max} \\ &= 70.228 \end{aligned}$$

**Maximum Gas Velocity for  $R_{\max} \geq 1.5$** 

$$\begin{aligned} \text{eq 21} \quad R_{\max} \geq 1.5 \quad V_{\max} &= V_n \cdot 1.5 \\ &= \text{Not applicable} \end{aligned}$$

**Minimum Velocity Pressure**

$$\begin{aligned} \text{eq 22} \quad \Delta P_{\min} &= (1.3686 \cdot 10^{-4}) \cdot ((P_s \cdot M_w) / T_s) \cdot (V_{\min} / C_p)^2 \\ &= 0.298 \end{aligned}$$

**Maximum Velocity Pressure**

$$\begin{aligned} \text{eq 23} \quad \Delta P_{\max} &= (1.3686 \cdot 10^{-4}) \cdot ((P_s \cdot M_w) / T_s) \cdot (V_{\max} / C_p)^2 \\ &= 0.990 \end{aligned}$$

**Sampling Dwell Time at Each Point**

$$\begin{aligned} \text{eq 24} \quad t_n &= (C_p \cdot (\Delta P_1)^{0.5}) / (C_p \cdot (\Delta P_1^{0.5})_{\text{avg}}) \cdot (t_r / N_{tp}) \\ &= 1.96 \end{aligned}$$

**Adjusted Velocity Pressure**

$$\begin{aligned} \text{eq 25} \quad \Delta p_s &= \Delta P_m \cdot (C_p / C_p)^2 \\ &= 0.44 \text{ (Point 1 from preliminary traverse)} \end{aligned}$$

**Average Probe Blockage Factor**

$$\begin{aligned} \text{eq 26} \quad bf &= 22.0 / A \\ &= \text{Not Applicable} \end{aligned}$$

**Velocity Pressure**

$$\begin{aligned} \text{eq 27} \quad \Delta p_{s2} &= \Delta p_{s1} \cdot (1/(1-bf))^2 \\ &= \text{Not Applicable} \end{aligned}$$

**Dry Gas Volume Sampled at Standard Conditions**

$$\begin{aligned} \text{eq 28} \quad V_{ms} &= (528 \cdot 29.92) \cdot (Y \cdot V_m) \cdot ((P_{bar} + (\Delta H / 13.6)) / T_m) \\ &= 18.964 \end{aligned}$$

**Sample Flow Rate at Standard Conditions**

$$\begin{aligned} \text{eq 29} \quad Q_{sST} &= V_{ms} / \theta \\ &= \text{Meter Volume at Std. Cond. / minutes of test duration} \\ &= 0.319 \end{aligned}$$

**Volume of Water Vapor**

$$\begin{aligned} \text{eq 30} \quad V_{wc} &= 0.04707 \cdot V_c \quad (\text{for liquid impingers}) \\ &= 3.860 \\ V_{sg} &= 0.04715 \cdot V_c \quad (\text{for silica gel impinger}) \\ &= 0.495 \\ V_{ws} &= V_{wc} + V_{sg} \\ &= 4.355 \end{aligned}$$

**Moisture Content of Gas Stream**

$$\begin{aligned} \text{eq 31} \quad B_{ws} &= V_{ws} / (V_{ms} + V_{ws}) \\ &= 0.1867 \end{aligned}$$

**Sampling Rate**

$$\begin{aligned} \text{eq 32} \quad Q_s &= (29.92/528) \cdot Q_{sST} \cdot (1/(1-B_{ws})) \cdot (T_s/P_s) \\ &= 0.598 \end{aligned}$$

**Actual Particle Cut Diameter for Cyclone I**

$$\begin{aligned} \text{eq 33} \quad D_{50} &= 0.15625 \cdot ((T_s/(M_w \cdot P_s))^{0.2091}) \cdot (\mu/Q_s)^{0.7091} \\ &= 10.32 \quad (\text{Not applicable to PM}_{2.5} \text{ only.}) \end{aligned}$$

**Particle Cut Diameter for  $N_{re} < 3,162$  for Cyclone IV**

$$\begin{aligned} \text{eq 34} \quad D_{50} &= 0.0024302 \cdot ((\mu/Q_s)^{1.1791}) \cdot ((1/C)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.6790}) \\ &= 2.45 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Particle Cut Diameter for  $N_{re} \geq 3,162$  for Cyclone IV**

$$\begin{aligned} \text{eq 35} \quad D_{50} &= 0.019723 \cdot ((\mu/Q_s)^{0.8058}) \cdot ((1/C)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.3058}) \\ &= \text{Not applicable} \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-estimated Cunningham Correction Factor**

$$\begin{aligned} \text{eq 36} \quad C_r &= 1 + 0.0057193 \cdot (\mu/(P_s \cdot D_{50})) \cdot (T_s/M_w)^{0.5} \\ &= 1.25 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-calculated Particle Cut Diameter for  $N_{re} < 3,162$** 

$$\begin{aligned} \text{eq 37} \quad D_{50-1} &= 0.0024302 \cdot ((\mu/Q_s)^{1.1791}) \cdot ((1/C_r)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.3058}) \\ &= 2.28 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-calculated Particle Cut Diameter for  $N_{re} \geq 3,162$** 

$$\begin{aligned} \text{eq 38} \quad D_{50-1} &= 0.019723 \cdot ((\mu/Q_s)^{0.8058}) \cdot ((1/C_r)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.3058}) \\ &= \text{Not applicable} \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Ratio (Z) Between D50 and D50-1 Values**

$$\begin{aligned} \text{eq 39} \quad Z &= D50-1 / D50 \\ &= 0.93 \text{ (Not applicable to PM10 only.)} \\ &\quad \text{(final Z value is below in eq 40)} \end{aligned}$$

**Acceptance Criteria for Z Values**

$$\begin{aligned} \text{eq 40} \quad 0.99 \leq [ Z &= (D50N / D50N+1) ] \leq 1.01 \\ &= 1.00 \text{ (Not applicable to PM10 only.)} \end{aligned}$$

**Percent Isokinetic Sampling**

$$\begin{aligned} \text{eq 41} \quad I &= (100 \cdot T_s \cdot V_{ms} \cdot 29.92) / (60 \cdot V_s \cdot \theta \cdot A_n \cdot P_s \cdot (1 - B_{ws}) \cdot 528) \\ &= 116.0\% \end{aligned}$$

**Acetone Blank Concentration**

$$\begin{aligned} \text{eq 42} \quad C_a &= m_a / (V_a \cdot p_a) \\ &= 1.22E-05 \end{aligned}$$

**Acetone Blank Correction Weight**

$$\begin{aligned} \text{eq 43} \quad M_{(4)} &= W_{(4)} - W_{a(4)} \\ &= 0.00000 \end{aligned}$$

**Acetone Blank Weight**

$$\begin{aligned} \text{eq 44} \quad W_a &= C_a \cdot V_{aw} \cdot p_a \\ &= 0.00163 \text{ (for PM2.5 fraction)} \end{aligned}$$

**Concentration of Total Filterable Particulate Matter**

$$\begin{aligned} \text{eq 45} \quad C_{tf} &= (7000/453592) \cdot ((M1+M2+M3+M4)/V_{ms}) \\ &= \text{Not applicable to PM2.5 only} \end{aligned}$$

**Concentration of Filterable PM10 Particulate Matter**

$$\begin{aligned} \text{eq 46} \quad C_{f \text{ PM10}} &= (7000/453592) \cdot ((M1+M3+M4)/V_{ms}) \\ &= \text{Not applicable to PM2.5 only} \end{aligned}$$

**Concentration of Filterable PM2.5 Particulate Matter**

$$\begin{aligned} \text{eq 47} \quad C_{f \text{ PM2.5}} &= (7000/453592) \cdot ((M1+M4)/V_{ms}) \\ &= 0.0006 \end{aligned}$$

**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 2 OUTLET**  
**U2O-M201A/202-R1**

---

**Molecular Weight of Dry Gas**

$$\begin{aligned} \text{eq 1} \quad \text{Md} &= 0.44 \cdot \text{CO}_2 + 0.32 \cdot \text{O}_2 + 0.28 \cdot (100 - \text{O}_2 - \text{CO}_2) \\ &= 29.86 \end{aligned}$$

**Molecular Weight of Wet Gas**

$$\begin{aligned} \text{eq 2} \quad \text{Mw} &= \text{Md} \cdot (1 - \text{Bws}) + 18 \cdot (\text{Bws}) \\ &= 27.94 \end{aligned}$$

**Gas Stream Viscosity**

$$\begin{aligned} \text{eq 3} \quad \mu &= \text{C1} + \text{C2} \cdot (\text{Ts}^{0.5}) + \text{C3} \cdot (\text{Ts}^{-2}) + \text{C4} \cdot (\text{O}_2 \text{wet}) - \text{C5} \cdot \text{Bws} + \text{C6} \cdot \text{Bws} \cdot \text{Ts}^{-2} \\ &= 219.43 \end{aligned}$$

**Cunningham Correction Factor**

$$\begin{aligned} \text{eq 4} \quad \text{C} &= 1 + 0.0057193 \cdot (\mu / (\text{Ps} \cdot \text{Dp})) \cdot (\text{Ts} / \text{Mw})^{0.5} \\ &= 1.09 \end{aligned}$$

**Lower Limit Cut Diameter for Cyclone I for Nre < 3,162**

$$\begin{aligned} \text{eq 5} \quad \text{D50LL} &= 9.507 \cdot \text{C}^{0.3007} \cdot ((\text{Mw} \cdot \text{Ps}) / \text{Ts})^{0.1993} \\ &= 9.88 \end{aligned}$$

**Cut Diameter for Cyclone I for the Middle of the Overlap Zone**

$$\begin{aligned} \text{eq 6} \quad \text{D50T} &= ((11 + \text{D50LL}) / 2) \\ &= 10.44 \text{ (Depends on value of Nre from Eq. 10)} \end{aligned}$$

**Sampling Rate Using Both PM10 and PM2.5 Cyclones**

$$\begin{aligned} \text{eq 7} \quad \text{Qs} = \text{Qi} &= 0.07296 \cdot \mu \cdot ((\text{Ts} / (\text{Mw} \cdot \text{Ps}))^{0.2949}) \cdot (1 / \text{D50T})^{1.4102} \\ &= 0.575 \end{aligned}$$

**Sampling Rate Using Only PM2.5 Cyclone**

$$\text{eq 8 and 9} \quad \text{QIV} = \text{Not applicable.}$$

**Reynolds Number**

$$\begin{aligned} \text{eq 10} \quad \text{Nre} &= (8.64 \cdot 10^5) \cdot ((\text{Ps} \cdot \text{Mw}) / \text{Ts}) \cdot (\text{Qs} / \mu) \\ &\quad \text{Qs obtained from Eq. 32} \\ &= 2457 \end{aligned}$$

**Meter Box Orifice Pressure Drop**

$$\begin{aligned} \text{eq 11} \quad \Delta\text{H} &= (((\text{Qs} \cdot (1 - \text{Bws}) \cdot \text{Ps}) / \text{Ts})^2) \cdot ((1.083 \cdot \text{Tm} \cdot \text{Md} \cdot \Delta\text{H} @ / \text{Pbar})) \\ &= 0.33 \end{aligned}$$

**Lower Limit Cut Diameter for Cyclone I for Nre ≥ 3,162**

$$\begin{aligned} \text{eq 12} \quad \text{D50LL} &= 10.0959 \cdot \text{C}^{0.4400} \cdot ((\text{Mw} \cdot \text{Ps}) / \text{Ts})^{0.0600} \\ &= 10.53 \end{aligned}$$

**Velocity of Stack Gas**

$$\begin{aligned} \text{eq 13} \quad \text{Vs} &= \text{Kp} \cdot \text{Cp} \cdot (\Delta\text{p}^{0.5})_{\text{avg}} \cdot (\text{Ts} / (\text{Ps} \cdot \text{Mw}))^{0.5} \\ &= 85.49 \cdot \text{Cp} \cdot (\Delta\text{p}^{0.5})_{\text{avg}} \cdot (\text{Ts} / (\text{Ps} \cdot \text{Mw}))^{0.5} \\ &= 44.93 \end{aligned}$$

**Calculated Nozzle Diameter for Acceptable Sampling Rate**

$$\begin{aligned} \text{eq 14} \quad D &= ((3.056 \cdot Q_s) / V_s)^{0.5} \\ &= 0.194 \end{aligned}$$

**Velocity of Gas in Nozzle**

$$\begin{aligned} \text{eq 15} \quad V_n &= (Q_s / 60) / A_n \\ &= 47.50 \end{aligned}$$

**Minimum Nozzle/Stack Velocity Ratio Parameter**

$$\begin{aligned} \text{eq 16} \quad R_{\min} &= 0.2457 + (0.3072 - ((0.2603 \cdot \mu \cdot Q_s^{0.5}) / V_n^{1.5})^{0.5}) \\ &= 0.664 \end{aligned}$$

**Maximum Nozzle/Stack Velocity Ratio Parameter**

$$\begin{aligned} \text{eq 17} \quad R_{\max} &= 0.4457 + (0.5690 - ((0.2603 \cdot \mu \cdot Q_s^{0.5}) / V_n^{1.5})^{0.5}) \\ &= 1.283 \end{aligned}$$

**Minimum Gas Velocity for  $R_{\min} < 0.5$** 

$$\begin{aligned} \text{eq 18} \quad R_{\min} < 0.5 \quad V_{\min} &= V_n \cdot 0.5 \\ &= \text{Not applicable} \end{aligned}$$

**Minimum Gas Velocity for  $R_{\min} \geq 0.5$** 

$$\begin{aligned} \text{eq 19} \quad R_{\min} \geq 0.5 \quad V_{\min} &= V_n \cdot R_{\min} \\ &= 31.543 \end{aligned}$$

**Maximum Gas Velocity for  $R_{\max} < 1.5$** 

$$\begin{aligned} \text{eq 20} \quad R_{\max} < 1.5 \quad V_{\max} &= V_n \cdot R_{\max} \\ &= 60.953 \end{aligned}$$

**Maximum Gas Velocity for  $R_{\max} \geq 1.5$** 

$$\begin{aligned} \text{eq 21} \quad R_{\max} \geq 1.5 \quad V_{\max} &= V_n \cdot 1.5 \\ &= \text{Not applicable} \end{aligned}$$

**Minimum Velocity Pressure**

$$\begin{aligned} \text{eq 22} \quad \Delta P_{\min} &= (1.3686 \cdot 10^{-4}) \cdot ((P_s \cdot M_w) / T_s) \cdot (V_{\min} / C_p)^2 \\ &= 0.208 \end{aligned}$$

**Maximum Velocity Pressure**

$$\begin{aligned} \text{eq 23} \quad \Delta P_{\max} &= (1.3686 \cdot 10^{-4}) \cdot ((P_s \cdot M_w) / T_s) \cdot (V_{\max} / C_p)^2 \\ &= 0.766 \end{aligned}$$

**Sampling Dwell Time at Each Point**

$$\begin{aligned} \text{eq 24} \quad t_n &= (C_p \cdot (\Delta P_1)^{0.5}) / (C_p \cdot (\Delta P_1^{0.5})_{\text{avg}}) \cdot (t_r / N_{tp}) \\ &= 2.12 \end{aligned}$$

**Adjusted Velocity Pressure**

$$\begin{aligned} \text{eq 25} \quad \Delta p_s &= \Delta P_m \cdot (C_p / C_p)^2 \\ &= 0.49 \text{ (Point 1 from preliminary traverse)} \end{aligned}$$

**Average Probe Blockage Factor**

$$\begin{aligned} \text{eq 26} \quad bf &= 22.0 / A \\ &= \text{Not Applicable} \end{aligned}$$

**Velocity Pressure**

$$\begin{aligned} \text{eq 27} \quad \Delta p_{s2} &= \Delta p_{s1} \cdot (1/(1-bf))^2 \\ &= \text{Not Applicable} \end{aligned}$$

**Dry Gas Volume Sampled at Standard Conditions**

$$\begin{aligned} \text{eq 28} \quad V_{ms} &= (528 \cdot 29.92) \cdot (Y \cdot V_m) \cdot ((P_{bar} + (\Delta H / 13.6)) / T_m) \\ &= 21.895 \end{aligned}$$

**Sample Flow Rate at Standard Conditions**

$$\begin{aligned} \text{eq 29} \quad Q_{sST} &= V_{ms} / \theta \\ &= \text{Meter Volume at Std. Cond. / minutes of test duration} \\ &= 0.330 \end{aligned}$$

**Volume of Water Vapor**

$$\begin{aligned} \text{eq 30} \quad V_{wc} &= 0.04707 \cdot V_c \quad (\text{for liquid impingers}) \\ &= 3.907 \\ V_{sg} &= 0.04715 \cdot V_c \quad (\text{for silica gel impinger}) \\ &= 0.330 \\ V_{ws} &= V_{wc} + V_{sg} \\ &= 4.237 \end{aligned}$$

**Moisture Content of Gas Stream**

$$\begin{aligned} \text{eq 31} \quad B_{ws} &= V_{ws} / (V_{ms} + V_{ws}) \\ &= 0.1621 \end{aligned}$$

**Sampling Rate**

$$\begin{aligned} \text{eq 32} \quad Q_s &= (29.92/528) \cdot Q_{sST} \cdot (1/(1-B_{ws})) \cdot (T_s/P_s) \\ &= 0.585 \end{aligned}$$

**Actual Particle Cut Diameter for Cyclone I**

$$\begin{aligned} \text{eq 33} \quad D_{50} &= 0.15625 \cdot ((T_s/(M_w \cdot P_s))^{0.2091}) \cdot (\mu/Q_s)^{0.7091} \\ &= 10.31 \quad (\text{Not applicable to PM}_{2.5} \text{ only.}) \end{aligned}$$

**Particle Cut Diameter for  $N_{re} < 3,162$  for Cyclone IV**

$$\begin{aligned} \text{eq 34} \quad D_{50} &= 0.0024302 \cdot ((\mu/Q_s)^{1.1791}) \cdot ((1/C)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.6790}) \\ &= 2.42 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Particle Cut Diameter for  $N_{re} \geq 3,162$  for Cyclone IV**

$$\begin{aligned} \text{eq 35} \quad D_{50} &= 0.019723 \cdot ((\mu/Q_s)^{0.8058}) \cdot ((1/C)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.3058}) \\ &= \text{Not applicable} \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-estimated Cunningham Correction Factor**

$$\begin{aligned} \text{eq 36} \quad C_r &= 1 + 0.0057193 \cdot (\mu/(P_s \cdot D_{50})) \cdot (T_s/M_w)^{0.5} \\ &= 1.24 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-calculated Particle Cut Diameter for  $N_{re} < 3,162$** 

$$\begin{aligned} \text{eq 37} \quad D_{50-1} &= 0.0024302 \cdot ((\mu/Q_s)^{1.1791}) \cdot ((1/C_r)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.6790}) \\ &= 2.26 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-calculated Particle Cut Diameter for  $N_{re} \geq 3,162$** 

$$\begin{aligned} \text{eq 38} \quad D_{50-1} &= 0.019723 \cdot ((\mu/Q_s)^{0.8058}) \cdot ((1/C_r)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.3058}) \\ &= \text{Not applicable} \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Ratio (Z) Between D50 and D50-1 Values**

$$\begin{aligned} \text{eq 39} \quad Z &= D50-1 / D50 \\ &= 0.94 \text{ (Not applicable to PM10 only.)} \\ &\quad \text{(final Z value is below in eq 40)} \end{aligned}$$

**Acceptance Criteria for Z Values**

$$\begin{aligned} \text{eq 40} \quad 0.99 \leq [ Z &= (D50N / D50N+1) ] \leq 1.01 \\ &= 1.00 \text{ (Not applicable to PM10 only.)} \end{aligned}$$

**Percent Isokinetic Sampling**

$$\begin{aligned} \text{eq 41} \quad I &= (100 \cdot T_s \cdot V_{ms} \cdot 29.92) / (60 \cdot V_s \cdot \theta \cdot A_n \cdot P_s \cdot (1 - B_{ws}) \cdot 528) \\ &= 109.0\% \end{aligned}$$

**Acetone Blank Concentration**

$$\begin{aligned} \text{eq 42} \quad C_a &= m_a / (V_a \cdot p_a) \\ &= 1.22E-05 \end{aligned}$$

**Acetone Blank Correction Weight**

$$\begin{aligned} \text{eq 43} \quad M_{(4)} &= W_{(4)} - W_{a(4)} \\ &= 0.00000 \end{aligned}$$

**Acetone Blank Weight**

$$\begin{aligned} \text{eq 44} \quad W_a &= C_a \cdot V_{aw} \cdot p_a \\ &= 0.00221 \text{ (for PM2.5 fraction)} \end{aligned}$$

**Concentration of Total Filterable Particulate Matter**

$$\begin{aligned} \text{eq 45} \quad C_{tf} &= (7000/453592) \cdot ((M1+M2+M3+M4)/V_{ms}) \\ &= \text{Not applicable to PM2.5 only} \end{aligned}$$

**Concentration of Filterable PM10 Particulate Matter**

$$\begin{aligned} \text{eq 46} \quad C_{f \text{ PM10}} &= (7000/453592) \cdot ((M1+M3+M4)/V_{ms}) \\ &= \text{Not applicable to PM2.5 only} \end{aligned}$$

**Concentration of Filterable PM2.5 Particulate Matter**

$$\begin{aligned} \text{eq 47} \quad C_{f \text{ PM2.5}} &= (7000/453592) \cdot ((M1+M4)/V_{ms}) \\ &= 0.0003 \end{aligned}$$



**EPA METHOD 201A CALCULATIONS**  
**PINELLAS COUNTY RESOURCE RECOVERY FACILITY**  
**UNIT 3 OUTLET**  
**U3O-M201A/202-R1**

---

**Molecular Weight of Dry Gas**

$$\begin{aligned} \text{eq 1} \quad M_d &= 0.44 \cdot \text{CO}_2 + 0.32 \cdot \text{O}_2 + 0.28 \cdot (100 - \text{O}_2 - \text{CO}_2) \\ &= 29.96 \end{aligned}$$

**Molecular Weight of Wet Gas**

$$\begin{aligned} \text{eq 2} \quad M_w &= M_d \cdot (1 - B_{ws}) + 18 \cdot B_{ws} \\ &= 27.51 \end{aligned}$$

**Gas Stream Viscosity**

$$\begin{aligned} \text{eq 3} \quad \mu &= C_1 + C_2 \cdot (T_s)^{0.5} + C_3 \cdot (T_s)^{-2} + C_4 \cdot (\text{O}_2)_{\text{wet}} - C_5 \cdot B_{ws} + C_6 \cdot B_{ws} \cdot T_s^{-2} \\ &= 217.25 \end{aligned}$$

**Cunningham Correction Factor**

$$\begin{aligned} \text{eq 4} \quad C &= 1 + 0.0057193 \cdot (\mu / (P_s \cdot D_p)) \cdot (T_s / M_w)^{0.5} \\ &= 1.09 \end{aligned}$$

**Lower Limit Cut Diameter for Cyclone I for Nre < 3,162**

$$\begin{aligned} \text{eq 5} \quad D_{50LL} &= 9.507 \cdot C \cdot 0.3007 \cdot ((M_w \cdot P_s) / T_s)^{0.1993} \\ &= 9.84 \end{aligned}$$

**Cut Diameter for Cyclone I for the Middle of the Overlap Zone**

$$\begin{aligned} \text{eq 6} \quad D_{50T} &= ((11 + D_{50LL}) / 2) \\ &= 10.42 \text{ (Depends on value of Nre from Eq. 10)} \end{aligned}$$

**Sampling Rate Using Both PM10 and PM2.5 Cyclones**

$$\begin{aligned} \text{eq 7} \quad Q_s = Q_i &= 0.07296 \cdot \mu \cdot ((T_s / (M_w \cdot P_s))^{0.2949}) \cdot (1 / D_{50T})^{1.4102} \\ &= 0.575 \end{aligned}$$

**Sampling Rate Using Only PM2.5 Cyclone**

$$\text{eq 8 and 9} \quad Q_{IV} = \text{Not applicable.}$$

**Reynolds Number**

$$\begin{aligned} \text{eq 10} \quad N_{re} &= (8.64 \cdot 10^5) \cdot ((P_s \cdot M_w) / T_s) \cdot (Q_s / \mu) \\ &\quad Q_s \text{ obtained from Eq. 32} \\ &= 2428 \end{aligned}$$

**Meter Box Orifice Pressure Drop**

$$\begin{aligned} \text{eq 11} \quad \Delta H &= (((Q_s \cdot (1 - B_{ws}) \cdot P_s) / T_s)^2) \cdot ((1.083 \cdot T_m \cdot M_d \cdot \Delta H_{@}) / P_{bar}) \\ &= 0.35 \end{aligned}$$

**Lower Limit Cut Diameter for Cyclone I for Nre ≥ 3,162**

$$\begin{aligned} \text{eq 12} \quad D_{50LL} &= 10.0959 \cdot C \cdot 0.4400 \cdot ((M_w \cdot P_s) / T_s)^{0.0600} \\ &= 10.51 \end{aligned}$$

**Velocity of Stack Gas**

$$\begin{aligned} \text{eq 13} \quad V_s &= K_p \cdot C_p \cdot (\Delta p^{0.5})_{\text{avg}} \cdot (T_s / (P_s \cdot M_w))^{0.5} \\ &= 85.49 \cdot C_p \cdot (\Delta p^{0.5})_{\text{avg}} \cdot (T_s / (P_s \cdot M_w))^{0.5} \\ &= 50.50 \end{aligned}$$

**Calculated Nozzle Diameter for Acceptable Sampling Rate**

$$\begin{aligned} \text{eq 14} \quad D &= ((3.056 \cdot Q_s) / V_s)^{0.5} \\ &= 0.187 \end{aligned}$$

**Velocity of Gas in Nozzle**

$$\begin{aligned} \text{eq 15} \quad V_n &= (Q_s / 60) / A_n \\ &= 54.67 \end{aligned}$$

**Minimum Nozzle/Stack Velocity Ratio Parameter**

$$\begin{aligned} \text{eq 16} \quad R_{\min} &= 0.2457 + (0.3072 - ((0.2603 \cdot \mu \cdot Q_s^{0.5}) / V_n^{1.5})^{0.5}) \\ &= 0.694 \end{aligned}$$

**Maximum Nozzle/Stack Velocity Ratio Parameter**

$$\begin{aligned} \text{eq 17} \quad R_{\max} &= 0.4457 + (0.5690 - ((0.2603 \cdot \mu \cdot Q_s^{0.5}) / V_n^{1.5})^{0.5}) \\ &= 1.267 \end{aligned}$$

**Minimum Gas Velocity for  $R_{\min} < 0.5$** 

$$\begin{aligned} \text{eq 18} \quad R_{\min} < 0.5 \quad V_{\min} &= V_n \cdot 0.5 \\ &= \text{Not applicable} \end{aligned}$$

**Minimum Gas Velocity for  $R_{\min} \geq 0.5$** 

$$\begin{aligned} \text{eq 19} \quad R_{\min} \geq 0.5 \quad V_{\min} &= V_n \cdot R_{\min} \\ &= 37.947 \end{aligned}$$

**Maximum Gas Velocity for  $R_{\max} < 1.5$** 

$$\begin{aligned} \text{eq 20} \quad R_{\max} < 1.5 \quad V_{\max} &= V_n \cdot R_{\max} \\ &= 69.280 \end{aligned}$$

**Maximum Gas Velocity for  $R_{\max} \geq 1.5$** 

$$\begin{aligned} \text{eq 21} \quad R_{\max} \geq 1.5 \quad V_{\max} &= V_n \cdot 1.5 \\ &= \text{Not applicable} \end{aligned}$$

**Minimum Velocity Pressure**

$$\begin{aligned} \text{eq 22} \quad \Delta P_{\min} &= (1.3686 \cdot 10^{-4}) \cdot ((P_s \cdot M_w) / T_s) \cdot (V_{\min} / C_p)^2 \\ &= 0.298 \end{aligned}$$

**Maximum Velocity Pressure**

$$\begin{aligned} \text{eq 23} \quad \Delta P_{\max} &= (1.3686 \cdot 10^{-4}) \cdot ((P_s \cdot M_w) / T_s) \cdot (V_{\max} / C_p)^2 \\ &= 0.999 \end{aligned}$$

**Sampling Dwell Time at Each Point**

$$\begin{aligned} \text{eq 24} \quad t_n &= (C_p \cdot (\Delta P_1)^{0.5}) / (C_p \cdot (\Delta P_1^{0.5})_{\text{avg}}) \cdot (t_r / N_{tp}) \\ &= 1.99 \end{aligned}$$

**Adjusted Velocity Pressure**

$$\begin{aligned} \text{eq 25} \quad \Delta p_s &= \Delta P_m \cdot (C_p / C_p)^2 \\ &= 0.52 \text{ (Point 1 from preliminary traverse)} \end{aligned}$$

**Average Probe Blockage Factor**

$$\begin{aligned} \text{eq 26} \quad bf &= 22.0 / A \\ &= \text{Not Applicable} \end{aligned}$$

**Velocity Pressure**

$$\begin{aligned} \text{eq 27} \quad \Delta p_{s2} &= \Delta p_{s1} \cdot (1/(1-bf))^2 \\ &= \text{Not Applicable} \end{aligned}$$

**Dry Gas Volume Sampled at Standard Conditions**

$$\begin{aligned} \text{eq 28} \quad V_{ms} &= (528 \cdot 29.92) \cdot (Y \cdot V_m) \cdot ((P_{bar} + (\Delta H/13.6))/T_m) \\ &= 17.918 \end{aligned}$$

**Sample Flow Rate at Standard Conditions**

$$\begin{aligned} \text{eq 29} \quad Q_{sST} &= V_{ms} / \theta \\ &= \text{Meter Volume at Std. Cond. / minutes of test duration} \\ &= 0.312 \end{aligned}$$

**Volume of Water Vapor**

$$\begin{aligned} \text{eq 30} \quad V_{wc} &= 0.04707 \cdot V_c \quad (\text{for liquid impingers}) \\ &= 4.001 \\ V_{sg} &= 0.04715 \cdot V_c \quad (\text{for silica gel impinger}) \\ &= 0.599 \\ V_{ws} &= V_{wc} + V_{sg} \\ &= 4.600 \end{aligned}$$

**Moisture Content of Gas Stream**

$$\begin{aligned} \text{eq 31} \quad B_{ws} &= V_{ws} / (V_{ms} + V_{ws}) \\ &= 0.2043 \end{aligned}$$

**Sampling Rate**

$$\begin{aligned} \text{eq 32} \quad Q_s &= (29.92/528) \cdot Q_{sST} \cdot (1/(1-B_{ws})) \cdot (T_s/P_s) \\ &= 0.586 \end{aligned}$$

**Actual Particle Cut Diameter for Cyclone I**

$$\begin{aligned} \text{eq 33} \quad D_{50} &= 0.15625 \cdot ((T_s/(M_w \cdot P_s))^{0.2091}) \cdot (\mu/Q_s)^{0.7091} \\ &= 10.27 \quad (\text{Not applicable to PM}_{2.5} \text{ only.}) \end{aligned}$$

**Particle Cut Diameter for  $N_{re} < 3,162$  for Cyclone IV**

$$\begin{aligned} \text{eq 34} \quad D_{50} &= 0.0024302 \cdot ((\mu/Q_s)^{1.1791}) \cdot ((1/C)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.6790}) \\ &= 2.42 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Particle Cut Diameter for  $N_{re} \geq 3,162$  for Cyclone IV**

$$\begin{aligned} \text{eq 35} \quad D_{50} &= 0.019723 \cdot ((\mu/Q_s)^{0.8058}) \cdot ((1/C)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.3058}) \\ &= \text{Not applicable} \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-estimated Cunningham Correction Factor**

$$\begin{aligned} \text{eq 36} \quad C_r &= 1 + 0.0057193 \cdot (\mu/(P_s \cdot D_{50})) \cdot (T_s/M_w)^{0.5} \\ &= 1.25 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-calculated Particle Cut Diameter for  $N_{re} < 3,162$** 

$$\begin{aligned} \text{eq 37} \quad D_{50-1} &= 0.0024302 \cdot ((\mu/Q_s)^{1.1791}) \cdot ((1/C_r)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.6790}) \\ &= 2.25 \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Re-calculated Particle Cut Diameter for  $N_{re} \geq 3,162$** 

$$\begin{aligned} \text{eq 38} \quad D_{50-1} &= 0.019723 \cdot ((\mu/Q_s)^{0.8058}) \cdot ((1/C_r)^{0.5}) \cdot ((T_s/(P_s \cdot M_w))^{0.3058}) \\ &= \text{Not applicable} \quad (\text{Not applicable to PM}_{10} \text{ only.}) \end{aligned}$$

**Ratio (Z) Between D50 and D50-1 Values**

$$\begin{aligned} \text{eq 39} \quad Z &= D50-1 / D50 \\ &= 0.93 \text{ (Not applicable to PM10 only.)} \\ &\quad \text{(final Z value is below in eq 40)} \end{aligned}$$

**Acceptance Criteria for Z Values**

$$\begin{aligned} \text{eq 40} \quad 0.99 \leq [ Z &= (D50N / D50N+1) ] \leq 1.01 \\ &= 1.00 \text{ (Not applicable to PM10 only.)} \end{aligned}$$

**Percent Isokinetic Sampling**

$$\begin{aligned} \text{eq 41} \quad I &= (100 \cdot T_s \cdot V_{ms} \cdot 29.92) / (60 \cdot V_s \cdot \theta \cdot A_n \cdot P_s \cdot (1 - B_{ws}) \cdot 528) \\ &= 111.0\% \end{aligned}$$

**Acetone Blank Concentration**

$$\begin{aligned} \text{eq 42} \quad C_a &= m_a / (V_a \cdot p_a) \\ &= 1.22E-05 \end{aligned}$$

**Acetone Blank Correction Weight**

$$\begin{aligned} \text{eq 43} \quad M_{(4)} &= W_{(4)} - W_{a(4)} \\ &= 0.00282 \end{aligned}$$

**Acetone Blank Weight**

$$\begin{aligned} \text{eq 44} \quad W_a &= C_a \cdot V_{aw} \cdot p_a \\ &= 0.00144 \text{ (for PM2.5 fraction)} \end{aligned}$$

**Concentration of Total Filterable Particulate Matter**

$$\begin{aligned} \text{eq 45} \quad C_{tf} &= (7000/453592) \cdot ((M1+M2+M3+M4)/V_{ms}) \\ &= \text{Not applicable to PM2.5 only} \end{aligned}$$

**Concentration of Filterable PM10 Particulate Matter**

$$\begin{aligned} \text{eq 46} \quad C_{f \text{ PM10}} &= (7000/453592) \cdot ((M1+M3+M4)/V_{ms}) \\ &= \text{Not applicable to PM2.5 only} \end{aligned}$$

**Concentration of Filterable PM2.5 Particulate Matter**

$$\begin{aligned} \text{eq 47} \quad C_{f \text{ PM2.5}} &= (7000/453592) \cdot ((M1+M4)/V_{ms}) \\ &= 0.00278 \end{aligned}$$

## EPA METHOD 202 CONDENSABLE PM EMISSIONS CALCULATIONS

**1. Mass of Field Blank**

$$M_{FB} = M_{ib} * IS_{vol} / IB_{vol} + M_{ob} * OS_{vol} / OB_{vol}$$

*\*Note: The max allowable field blank is 0.002 grams*

**2. Total Condensable Particulate Matter (CPM)**

$$M_{CPM} = M_{ic} + M_o - M_{FB}$$

**3. Particulate Concentration**

$$C_{sd} \text{ (gr/dscf)} = \frac{M_{CPM}}{V_{m(std)}} * \frac{7000}{453.593}$$

or

$$C_{sd} \text{ (mg/dscm)} = \frac{M_{CPM}}{V_{m(std)}} * \frac{1000 * 35.3145}{1}$$

**4. Particulate Concentration Corrected to 7% O<sub>2</sub>**

$$C_{sd@7\%} = C_{sd} * \frac{20.9 - 7.0}{(20.9 - \%O_2)}$$

**5. Particulate Concentration Corrected to 12% CO<sub>2</sub>**

$$C_{sd@12\%} = C_{sd} * \frac{12}{\%CO_2}$$

**6. Particulate Emissions Rate**

$$M_p = \frac{\sum(M_i)}{V_{m(std)}} * Q_{sd} * \frac{60}{453.593}$$

**7. Heat Input (O<sub>2</sub> based)**

$$T_{C-O_2} = \frac{60 * Q_{sd}}{F_d} * \frac{20.9 - \%O_2}{20.9}$$

## EPA METHOD 202 CONDENSABLE PM EMISSIONS CALCULATIONS (continued)

### 8. Particulate Mass Rate (O<sub>2</sub> based)

$$E_{O_2} = \frac{M_p}{T_{C-O_2}}$$

### 9. Heat Input (CO<sub>2</sub> based)

$$T_{C-CO_2} = \frac{60 * Q_{sd} * \%CO_2}{F_c * 100}$$

### 10. Particulate Mass Rate (CO<sub>2</sub> based)

$$E_{CO_2} = \frac{M_p}{T_{C-CO_2}}$$

### Nomenclature for EPA Method 202 Condensable PM Emissions Calculations

IB <sub>vol</sub>	=	Inorganic blank volume (milliliters)
IS <sub>vol</sub>	=	Inorganic sample volume (milliliters)
OB <sub>vol</sub>	=	Organic blank volume (milliliters)
OS <sub>vol</sub>	=	Organic sample volume (milliliters)
M <sub>ib</sub>	=	Inorganic blank weight (grams)
M <sub>ob</sub>	=	Organic blank correction (grams)
M <sub>FB</sub>	=	Total mass of Inorganic + Organic blank correction (grams)
M <sub>CPM</sub>	=	Total mass of CPM in sample (grams)
M <sub>ic</sub>	=	Mass of Inorganic CPM in sample (grams)
M <sub>o</sub>	=	Mass of Organic CPM in sample (grams)
Q <sub>sd</sub>	=	Stack gas flow rate (dscfm)
M <sub>p</sub>	=	Mass rate of particulate emissions (lb/hr)
V <sub>mstd</sub>	=	The volume of gas sampled at STP (dscf)
C <sub>sd</sub>	=	Particulate concentration (gr/dscf or mg/dscm)
C <sub>sd@7%</sub>	=	Particulate concentration @7% O <sub>2</sub> (gr/dscf or mg/dscm)
C <sub>sd@12%</sub>	=	Particulate concentration @12% CO <sub>2</sub> (gr/dscf or mg/dscm)
%O <sub>2</sub>	=	Oxygen content in stack gas (dry %)
%CO <sub>2</sub>	=	Carbon dioxide content in stack gas (dry %)
T <sub>CO2</sub>	=	Heat input, CO <sub>2</sub> based (MMBtu/hr)
T <sub>O2</sub>	=	Heat input, O <sub>2</sub> based (MMBtu/hr)
E <sub>CO2</sub>	=	Particulate Mass Emissions rate, CO <sub>2</sub> based (lb/MMBtu)
E <sub>O2</sub>	=	Particulate Mass Emissions rate, O <sub>2</sub> based (lb/MMBtu)
60	=	min/hr
7000	=	grains/lb
453.593	=	grams/lb
35.3145	=	cubic feet per cubic meter
1000	=	milligrams per gram

**EPA METHOD 202 CONDENSABLE PM EMISSIONS CALCULATIONS**

**EPA Method 201A: Gravimetric Data and Results  
UNIT 1 OUTLET  
U1O-M201A/202-R1**

**1. Mass of Field Blank**

$$M_{FB} = M_{IS} * IS_{vol} / IB_{vol} + M_{OS} * OS_{vol} / OB_{vol}$$

\*Note: The max allowable field blank is 0.002 grams

$$\begin{aligned} &= 0.0028 * 260 / 180 + 0.0004 * 232 / 240 \\ &= 0.0044 \text{ g} \\ &= 0.002 \text{ g} \quad (\text{max allowed}) \end{aligned}$$

**2. Total Condensable Particulate Matter (CPM)**

$$\begin{aligned} M_{CPM} &= M_k + M_o - M_{FB} \\ &= 0.0036 + 0.0076 - 0.002 \\ &= 0.0092 \text{ g} \end{aligned}$$

**3. Particulate Concentration**

$$\begin{aligned} C_{sd} &= \frac{M_{CPM}}{V_{m(std)}} * \frac{7000}{453.593} \\ \text{O} \pm &= \frac{M_{CPM}}{V_{m(std)}} * \frac{1000 * 35.3145}{1} \\ &= 0.0092 / 18.964 * 7000 / 453.593 \\ &= 0.0075 \text{ gr/dscf} \\ \text{or} &= 0.0092 * 1000 * 35.3145 / 18.964 \\ &= 17.13 \text{ mg/dscm} \end{aligned}$$

**4. Particulate Concentration Corrected to 7% O<sub>2</sub>**

$$\begin{aligned} C_{sd@7\%} &= C_{sd} * \frac{20.9 - 7.0}{(20.9 - \%O_2)} \\ &= 0.0075 * (20.9 - 7) / (20.9 - 9.47) \\ &= 0.0091 \text{ gr/dscf @ 7\%O}_2 \\ \text{or} &= 17.13 * (20.9 - 7) / (20.9 - 9.47) \\ &= 20.83 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

**5. Particulate Concentration Corrected to 12% CO<sub>2</sub>**

$$\begin{aligned} C_{sd@12\%} &= C_{sd} * \frac{12}{\%CO_2} \\ &= 0.0075 * 12 / 9.67 \\ &= 0.0093 \text{ gr/dscf @ 7\%O}_2 \\ \text{or} &= 17.13 * 12 / 9.67 \\ &= 21.26 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

**6. Particulate Emissions Rate**

$$\begin{aligned} M_p &= \frac{\sum(M_i)}{V_{m(std)}} * Q_{sd} * \frac{60}{453.593} \\ &= 0.0092 / 18.964 * 151039 * 60 / 453.593 \\ &= 9.69 \end{aligned}$$

**7. Heat Input (O<sub>2</sub> based)**

$$\begin{aligned} T_{C-O_2} &= \frac{60 * Q_{sd}}{F_d} * \frac{20.9 - \%O_2}{20.9} \\ &= \text{Not Applicable} \end{aligned}$$

**8. Particulate Mass Rate (O<sub>2</sub> based)**

$$\begin{aligned} E_{O_2} &= \frac{M_p}{T_{C-O_2}} \\ &= \text{Not Applicable} \end{aligned}$$

**9. Heat Input (CO<sub>2</sub> based)**

$$\begin{aligned} T_{C-CO_2} &= \frac{60 * Q_{sd} * \%CO_2}{F_c * 100} \\ &= \text{Not Applicable} \end{aligned}$$

**10. Particulate Mass Rate (CO<sub>2</sub> based)**

$$\begin{aligned} E_{CO_2} &= \frac{M_p}{T_{C-CO_2}} \\ &= \text{Not Applicable} \end{aligned}$$

**EPA METHOD 202 CONDENSABLE PM EMISSIONS CALCULATIONS**

**EPA Method 201A: Gravimetric Data and Results  
UNIT 2 OUTLET  
U2O-M201A/202-R1**

**1. Mass of Field Blank**

$$M_{FB} = M_{IS} * IS_{vol} / IB_{vol} + M_{OS} * OS_{vol} / OB_{vol}$$

\*Note: The max allowable field blank is 0.002 grams

$$\begin{aligned} &= 0.0028 * 260 / 180 + 0.0004 * 232 / 240 \\ &= 0.0044 \text{ g} \\ &= 0.002 \text{ g} \quad (\text{max allowed}) \end{aligned}$$

**2. Total Condensable Particulate Matter (CPM)**

$$M_{CPM} = M_c + M_o - M_{FB}$$

$$\begin{aligned} &= 0.0324 + 0.0088 - 0.002 \\ &= 0.0392 \text{ g} \end{aligned}$$

**3. Particulate Concentration**

$$\begin{aligned} C_{sd} &= \frac{M_{CPM}}{V_{m(std)}} * \frac{7000}{453.593} \\ O_2 &= \frac{M_{CPM}}{V_{m(std)}} * \frac{1000 * 35.3145}{1} \\ &= 0.0392 / 21.895 * 7000 / 453.593 \\ &= 0.0276 \text{ gr/dscf} \\ \text{or} \\ &= 0.0392 * 1000 * 35.3145 / 21.895 \\ &= 63.23 \text{ mg/dscm} \end{aligned}$$

**4. Particulate Concentration Corrected to 7% O<sub>2</sub>**

$$\begin{aligned} C_{sd@7\%} &= C_{sd} * \frac{20.9 - 7.0}{(20.9 - \%O_2)} \\ &= 0.0276 * (20.9 - 7) / (20.9 - 9.98) \\ &= 0.0351 \text{ gr/dscf @ 7\%O}_2 \\ \text{or} \\ &= 63.23 * (20.9 - 7) / (20.9 - 9.98) \\ &= 80.49 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

**5. Particulate Concentration Corrected to 12% CO<sub>2</sub>**

$$\begin{aligned} C_{sd@12\%} &= C_{sd} * \frac{12}{\%CO_2} \\ &= 0.0276 * 12 / 9.16 \\ &= 0.0362 \text{ gr/dscf @ 7\%O}_2 \\ \text{or} \\ &= 63.23 * 12 / 9.16 \\ &= 82.83 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

**6. Particulate Emissions Rate**

$$\begin{aligned} M_p &= \frac{\sum(M_i)}{V_{m(std)}} * Q_{sd} * \frac{60}{453.593} \\ &= 0.0392 / 21.895 * 146594 * 60 / 453.593 \\ &= 34.72 \end{aligned}$$

**7. Heat Input (O<sub>2</sub> based)**

$$\begin{aligned} T_{C-O_2} &= \frac{60 * Q_{sd}}{F_d} * \frac{20.9 - \%O_2}{20.9} \\ &= \text{Not Applicable} \end{aligned}$$

**8. Particulate Mass Rate (O<sub>2</sub> based)**

$$\begin{aligned} E_{O_2} &= \frac{M_p}{T_{C-O_2}} \\ &= \text{Not Applicable} \end{aligned}$$

**9. Heat Input (CO<sub>2</sub> based)**

$$\begin{aligned} T_{C-CO_2} &= \frac{60 * Q_{sd} * \%CO_2}{F_c * 100} \\ &= \text{Not Applicable} \end{aligned}$$

**10. Particulate Mass Rate (CO<sub>2</sub> based)**

$$\begin{aligned} E_{CO_2} &= \frac{M_p}{T_{C-CO_2}} \\ &= \text{Not Applicable} \end{aligned}$$



**EPA METHOD 202 CONDENSABLE PM EMISSIONS CALCULATIONS**

EPA Method 201A: Gravimetric Data and Results  
 UNIT 3 OUTLET  
 U3O-M201A/202-R1

**1. Mass of Field Blank**

$$M_{FB} = M_{IS} * IS_{vol} / IB_{vol} + M_{OS} * OS_{vol} / OB_{vol}$$

\*Note: The max allowable field blank is 0.002 grams

$$\begin{aligned} &= 0.0028 * 260 / 180 + 0.0004 * 232 / 240 \\ &= 0.0044 \text{ g} \\ &= 0.002 \text{ g} \quad (\text{max allowed}) \end{aligned}$$

**2. Total Condensable Particulate Matter (CPM)**

$$M_{CPM} = M_c + M_o - M_{FB}$$

$$\begin{aligned} &= 0.0050 + 0.0053 - 0.002 \\ &= 0.0083 \text{ g} \end{aligned}$$

**3. Particulate Concentration**

$$\begin{aligned} C_{sd} &= \frac{M_{CPM}}{V_{m(std)}} * \frac{7000}{453.593} \\ \text{O} \cdot \text{I} &= \frac{M_{CPM}}{V_{m(std)}} * \frac{1000 * 35.3145}{1} \\ &= 0.0083 / 17.918 * 7000 / 453.593 \\ &= 0.0071 \text{ gr/dscf} \\ \text{or} &= 0.0083 * 1000 * 35.3145 / 17.918 \\ &= 16.36 \text{ mg/dscm} \end{aligned}$$

**4. Particulate Concentration Corrected to 7% O<sub>2</sub>**

$$\begin{aligned} C_{sd@7\%} &= C_{sd} * \frac{20.9 - 7.0}{(20.9 - \%O_2)} \\ &= 0.0071 * (20.9 - 7) / (20.9 - 9.57) \\ &= 0.0087 \text{ gr/dscf @ 7\%O}_2 \\ \text{or} &= 16.36 * (20.9 - 7) / (20.9 - 9.57) \\ &= 20.07 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

**5. Particulate Concentration Corrected to 12% CO<sub>2</sub>**

$$\begin{aligned} C_{sd@12\%} &= C_{sd} * \frac{12}{\%CO_2} \\ &= 0.0071 * 12 / 9.84 \\ &= 0.0087 \text{ gr/dscf @ 7\%O}_2 \\ \text{or} &= 16.36 * 12 / 9.84 \\ &= 19.95 \text{ mg/dscm @ 7\%O}_2 \end{aligned}$$

**6. Particulate Emissions Rate**

$$\begin{aligned} M_p &= \frac{\sum(M_i)}{V_{m(std)}} * Q_{sd} * \frac{60}{453.593} \\ &= 0.0083 / 17.918 * 154991 * 60 / 453.593 \\ &= 9.50 \end{aligned}$$

**7. Heat Input (O<sub>2</sub> based)**

$$\begin{aligned} T_{C-O_2} &= \frac{60 * Q_{sd}}{F_d} * \frac{20.9 - \%O_2}{20.9} \\ &= \text{Not Applicable} \end{aligned}$$

**8. Particulate Mass Rate (O<sub>2</sub> based)**

$$\begin{aligned} E_{O_2} &= \frac{M_p}{T_{C-O_2}} \\ &= \text{Not Applicable} \end{aligned}$$

**9. Heat Input (CO<sub>2</sub> based)**

$$\begin{aligned} T_{C-CO_2} &= \frac{60 * Q_{sd} * \%CO_2}{F_c * 100} \\ &= \text{Not Applicable} \end{aligned}$$

**10. Particulate Mass Rate (CO<sub>2</sub> based)**

$$\begin{aligned} E_{CO_2} &= \frac{M_p}{T_{C-CO_2}} \\ &= \text{Not Applicable} \end{aligned}$$

## **Appendix G**

### **EPA Method 1 Cyclonic Flow Checks**

**CYCLONIC FLOW CHECK**  
**40 CFR 60, APPENDIX A, METHOD 1, SECTION 11.4**

Facility: Pinellas County RRF  
 Location: Unit 1 Inlet  
 Date: 4/8/2013

Load Condition: Compliance  
 Start Time: 10:43  
 End Time: 11:04

Port/Point	Angle Degree ( $\alpha$ )
A 1	4
2	8
3	5
4	5
5	2
6	4
7	0
8	2
9	10
10	8
11	4
12	2

Port/Point	Angle Degree ( $\alpha$ )
B 1	2
2	4
3	0
4	5
5	8
6	5
7	11
8	6
9	2
10	0
11	8
12	5

Sum of the Absolute Value of the Rotation Angles ( $\sum |\alpha|_{i=1,n}$ ): 110  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

Average Rotation Angle ( $\frac{\sum |\alpha|_{i=1,n}}{n}$ ): 4.6 (Pass\*)  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

\* Note: the flow is determined to be cyclonic if the Average Rotation Angle is greater than 20°.

Flow Check Done by: JS

**CYCLONIC FLOW CHECK**  
**40 CFR 60, APPENDIX A, METHOD 1, SECTION 11.4**

Facility: Pinellas County RRF  
 Location: Unit 2 Inlet  
 Date: 4/10/2013

Load Condition: Compliance  
 Start Time: 7:16  
 End Time: 7:41

Port/Point	Angle Degree ( $\alpha$ )
A 1	8
2	4
3	10
4	2
5	4
6	5
7	0
8	2
9	4
10	5
11	0
12	6

Port/Point	Angle Degree ( $\alpha$ )
B 1	2
2	5
3	0
4	3
5	5
6	4
7	10
8	6
9	2
10	0
11	4
12	2

Sum of the Absolute Value of the Rotation Angles ( $\sum |\alpha|_{i=1,n}$ ): 93  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

Average Rotation Angle ( $\frac{\sum |\alpha|_{i=1,n}}{n}$ ): 3.9 (Pass\*)  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

\* Note: the flow is determined to be cyclonic if the Average Rotation Angle is greater than 20°.

Flow Check Done by: JS

**CYCLONIC FLOW CHECK**  
**40 CFR 60, APPENDIX A, METHOD 1, SECTION 11.4**

Facility: Pinellas County RRF  
 Location: Unit 3 Inlet  
 Date: 4/5/2013

Load Condition: Compliance  
 Start Time: 7:13  
 End Time: 7:37

Port/Point	Angle Degree ( $\alpha$ )
A 1	8
2	4
3	2
4	0
5	4
6	6
7	5
8	3
9	7
10	8
11	5
12	4

Port/Point	Angle Degree ( $\alpha$ )
B 1	2
2	0
3	4
4	5
5	2
6	10
7	4
8	5
9	2
10	0
11	4
12	9

Sum of the Absolute Value of the Rotation Angles ( $\sum |\alpha|_{i=1,n}$ ): 103  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

Average Rotation Angle ( $\frac{\sum |\alpha|_{i=1,n}}{n}$ ): 4.3 (Pass\*)  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

\* Note: the flow is determined to be cyclonic if the Average Rotation Angle is greater than 20°.

Flow Check Done by: JS

**CYCLONIC FLOW CHECK**  
**40 CFR 60, APPENDIX A, METHOD 1, SECTION 11.4**

Facility: Pinellas County RRF  
 Location: Unit 1 Outlet  
 Date: 4/8/2013

Load Condition: Compliance  
 Start Time: 13:16  
 End Time: 13:52

Port/Point	Angle Degree ( $\alpha$ )
A 1	2
2	6
3	4
4	10
5	5
B 1	7
2	2
3	5
4	10
5	12
C 1	14
2	2
3	4
4	6
5	8

Port/Point	Angle Degree ( $\alpha$ )
D 1	15
2	5
3	4
4	0
5	6
E 1	16
2	8
3	6
4	4
5	7
F 1	14
2	10
3	4
4	8
5	7

Sum of the Absolute Value of the Rotation Angles ( $\sum |\alpha|_{i=1,n}$ ): 211  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

Average Rotation Angle ( $\frac{\sum |\alpha|_{i=1,n}}{n}$ ): 7.0 (Pass\*)  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

\* Note: the flow is determined to be cyclonic if the Average Rotation Angle is greater than 20°.

Flow Check Done by: IAW & MSH

**CYCLONIC FLOW CHECK**  
**40 CFR 60, APPENDIX A, METHOD 1, SECTION 11.4**

Facility: Pinellas County RRF  
 Location: Unit 2 Outlet  
 Date: 4/10/2013

Load Condition: Compliance  
 Start Time: 7:53  
 End Time: 8:23

Port/Point	Angle Degree ( $\alpha$ )
A 1	10
2	8
3	5
4	7
5	4
B 1	5
2	8
3	12
4	10
5	9
C 1	5
2	8
3	7
4	11
5	8

Port/Point	Angle Degree ( $\alpha$ )
D 1	4
2	6
3	5
4	8
5	9
E 1	11
2	12
3	5
4	9
5	6
F 1	12
2	14
3	9
4	7
5	7

Sum of the Absolute Value of the Rotation Angles ( $\sum |\alpha|_{i=1,n}$ ): 241  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

Average Rotation Angle ( $\frac{\sum |\alpha|_{i=1,n}}{n}$ ): 8.0 (Pass\*)  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

\* Note: the flow is determined to be cyclonic if the Average Rotation Angle is greater than 20°.

Flow Check Done by: IAW & MRW

**CYCLONIC FLOW CHECK**  
**40 CFR 60, APPENDIX A, METHOD 1, SECTION 11.4**

Facility: Pinellas County RRF  
 Location: Unit 3 Outlet  
 Date: 4/5/2013

Load Condition: Compliance  
 Start Time: 13:50  
 End Time: 14:38

Port/Point	Angle Degree ( $\alpha$ )
F 1	4
2	2
3	0
4	5
5	2
E 1	4
2	8
3	5
4	6
5	10
D 1	4
2	9
3	8
4	2
5	0

Port/Point	Angle Degree ( $\alpha$ )
C 1	2
2	5
3	4
4	0
5	2
B 1	8
2	10
3	2
4	5
5	0
A 1	5
2	2
3	4
4	2
5	2

Sum of the Absolute Value of the Rotation Angles ( $\sum |\alpha|_{i=1,n}$ ): 122  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

Average Rotation Angle ( $\frac{\sum |\alpha|_{i=1,n}}{n}$ ): 4.1 (Pass\*)  
 where:  $\alpha$  = rotation angle for point i, and  
 n = number of sampling points.

\* Note: the flow is determined to be cyclonic if the Average Rotation Angle is greater than 20°.

Flow Check Done by: JS



**Appendix H**  
**EPA Method 29 Raw Field Data**

## **Appendix H.1**

### **EPA Method 29 Raw Field Data: Unit 1 FF Outlet**

FACILITY: Veolia Pirellas TEST LOCATION: unit 1 outlet DATE: 4/9/13  
 TECHNICIAN: JAW P<sub>BAR</sub>: 30.02 POLLUTANT: metals RUN I.D.: u10 -M29 -R1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME FT <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A 1	0	09:05		312	.42	1.6	199.714	75	75	63	248	5
2	4			314	.43	1.6	202.5	76	75	66	259	5
3	8			316	.44	1.6	205.4	76	75	65	260	5
4	12		-11.5"	316	.43	1.6	208.3	77	75	63	248	5
5	16			318	.46	1.7	211.1	80	76	60	251	6
B 1	20	<del>0925</del> 0926		316	.44	1.6	213.9	81	77	58	268	6
2	24	<del>0930</del> 0939		316	.43	1.6	216.5	82	77	57	255	6
3	28			314	.41	1.5	219.1	81	77	55	252	6
4	32		-12"	314	.42	1.6	221.7	81	77	54	266	6
5	36			315	.43	1.6	224.4	83	77	53	256	6
C 1	40	<del>0955</del> 0956		315	.48	1.8	227.1	84	78	53	256	6
2	44			317	.48	1.8	229.9	84	78	54	257	6
3	48		-11"	315	.45	1.7	232.7	86	79	55	252	6
4	52			315	.43	1.6	235.5	87	79	54	252	6
5	56			316	.42	1.6	238.2	88	80	56	250	6
	60	1016		—	—	—	240.988	—	—	—	—	—
D 1	60	1026		315	.40	1.5	241.997	86	83	55	261	5
2	64			315	.39	1.5	244.4	87	84	57	255	6
3	68		-11.5"	315	.41	1.5	246.9	88	84	57	253	6
4	72			315	.42	1.6	249.4	88	84	58	252	6
5	76			315	.42	1.6	252.2	90	85	61	253	6
E 1	80	<del>1046</del> 1047		316	.44	1.6	254.9	90	85	64	257	6
2	84			316	.45	1.7	257.6	90	85	64	259	6
3	88		-11.5"	318	.44	1.6	260.4	91	85	64	256	6
4	92			317	.42	1.6	263.1	92	86	62	253	6

\*tripped power

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	300	Filter
	302	Fluoroc
	303	Imp 1-3
	304	Imp 4
	305	Imp 5-6
	306	UCC 2450
	307	S.I.C

LEAK CHECK:

K=3.7

VACUUM	11"	11"	11"			PITOT
RATE	.006	.006	.007			PRE: <input checked="" type="checkbox"/>
						POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	228
#2	100	247
#3	100	146
#4	0	6
#5	100	101
#6	100	92
#7	250. ✓	2700

NOZZLE Φ	C11 0.280
PITOT #	158
BOX ID	18
GAMMA γ	0.9604
ΔH@	2.0614
PROBE ID	PL 9-6
SYSTEM ID	u-50-2/444/m-p-1
FILTER ID	—

ISOKINETIC SAMPLING DATA SHEET

FACILITY: Vesta-Pinellas TEST LOCATION: unit 1 outlet DATE: 4/9/13  
 TECHNICIAN: JAW POLLUTANT: metals RUN I.D.: 40-M 29-R 1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft³	DGM IN TEMP.	DGM OUT TEMP.	EXIT TEMP	FILTER TEMP.	METER VAC.
5	96			316	.43	1.7	265.8	91	86	63	253	6
F 1	100	<del>1107</del> <del>1108</del>		317	.44	1.7	268.5	93	87	63	254	6
2	104			315	.45	1.7	271.2	93	87	62	248	6
3	108		-11"	320	.43	1.6	274.0	94	87	63	250	6
4	112			320	.41	1.5	276.7	95	88	64	249	6
5	116			320	.40	1.5	279.4	95	88	64	255	6
	120	1128		---	---	---	282.107	---	---	---	---	---

FACILITY: Veolia Pinellas TEST LOCATION: unit 1 outlet DATE: 4/9/13

TECHNICIAN: JAW P<sub>BAR</sub>: 30.04 POLLUTANT: metals RUN I.D.: w/o -M 29 -R 2

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
F 1	0	1324		306	.43	1.5	299.826	89	89	62	263	5
2	4			312	.44	1.5	292.05	90	89	64	266	5
3	8		-11"	317	.46	1.6	295.1	90	89	66	259	5
4	12			316	.47	1.6	297.8	91	90	66	252	5
5	16			315	.42	1.5	300.5	92	90	65	252	5
E 1	20	<u>1344</u> <u>1345</u>		313	.42	1.5	303.2	94	91	65	251	5
2	24			313	.45	1.6	305.8	95	91	64	262	5
3	28		-11"	318	.43	1.5	308.6	95	91	64	256	5
4	32			328	.45	1.6	311.2	96	92	63	255	5
5	36			330	.46	1.6	313.9	97	92	64	259	5
D 1	40	<u>1405</u> <u>1406</u>		320	.45	1.6	316.7	98	93	64	258	5
2	44			321	.40	1.4	319.4	98	93	63	255	5
3	48		-11.5"	320	.43	1.5	322.0	98	93	64	225	5
4	52			321	.42	1.5	324.6	99	94	64	254	5
5	56			321	.43	1.5	327.3	100	94	65	255	5
	60	1426		-	-	-	330-015	-	-	-	-	-
C 1	60	<u>1439</u>		316	.43	1.5	331-010	95	94	62	259	5
2	64			318	.45	1.6	333.7	97	94	61	263	5
3	68			320	.46	1.6	336.4	98	94	61	262	5
4	72		-11"	317	.44	1.5	339.2	97	94	62	254	5
5	76			316	.43	1.5	341.9	96	94	62	246	5
B 1	80	<u>1454</u> <u>1455</u>		313	.48	1.7	344.6	93	91	61	264	5
2	84			315	.48	1.7	347.3	93	91	62	262	5
3	88			315	.45	1.6	350.2	94	90	63	257	5
4	92		-11.5"	316	.46	1.6	353.0	94	90	64	255	5

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	308	FILTER
	310	FILTRIC
	311	Imp 3
	312	Imp 4
	313	Imp 5-6
	314	HEALTH
	315	S. 64

LEAK CHECK:

K=3.5

VACUUM	11"	11"	11"			PITOT PRE: <input checked="" type="checkbox"/>
RATE	.007	.007	.010			POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	248
#2	100	233
#3	100	122
#4	0	5
#5	100	104
#6	100	103
#7	250	270.7

PITOT

NOZZLE Ø	C11 0.280
PITOT #	<del>158</del> 322
BOX ID	18
GAMMA γ	0.9604
ΔH@	2.0614
PROBE ID	PL 9-6 PL 9-1
SYSTEM ID	u-0-2/0A4/M-pl
FILTER ID	

(JAW)

Pinellas Co RRF

ISOKINETIC SAMPLING DATA SHEET

FACILITY: ~~Veolia - Pinellas~~ TEST LOCATION: unit 1 outlet

DATE: 4/9/13

TECHNICIAN: JAW POLLUTANT: metals

RUN I.D.: U10-M29-R2

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM IN TEMP.	DGM OUT TEMP.	EXIT TEMP	FILTER TEMP.	METER VAC.
S	96			312	.48	1.7	355.8	96	90	63	262	S
A 1	100	<del>1515</del> 1516		314	.48	1.7	358.5	96	90	64	250	S
2	104			316	.50	1.8	361.4	96	90	64	260	S
3	108		-11"	316	.47	1.7	364.2	97	90	65	248	S
4	112			317	.45	1.6	367.1	97	90	66	257	S
5	116			317	.44	1.5	369.8	97	90	66	258	S
	120	1536		—	—	—	372.498	—	—	—	—	—

FACILITY: ~~Health~~ Pinellas County RRF TEST LOCATION: unit 1 outlet DATE: 4/9/13  
 TECHNICIAN IAW P<sub>BAR</sub> 30.04 POLLUTANT: Metals RUN I.D.: u10 - M 29 - R 3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A 1	0	1622		314	.40	1.4	374.091	86	86	65	255	5
2	4			316	.40	1.4	376.6	87	86	64	260	5
3	8			316	.44	1.5	379.2	88	87	63	257	6
4	12		-11"	316	.45	1.6	381.8	89	87	62	260	6
9	16			315	.46	1.6	384.8	89	87	62	253	6
B 1	20	<del>1642</del> 1643		315	.43	1.5	387.3	91	88	63	255	6
2	24			315	.44	1.5	389.9	92	88	61	261	6
3	28		-16.5"	317	.46	1.6	392.6	93	88	61	257	6
4	32			317	.47	1.6	395.3	94	89	62	255	6
5	36			317	.46	1.6	398.0	94	89	62	257	6
C 1	40	<del>1703</del> 1704		318	.46	1.6	400.7	95	91	62	256	6
2	44			319	.48	1.7	403.5	95	92	62	248	6
3	48			318	.48	1.7	406.2	95	91	62	258	6
4	52		<11"	319	.47	1.6	409.0	96	90	62	254	6
5	56			319	.45	1.6	411.8	96	90	63	255	6
	60	1724		—	—	—	414.596	—	—	—	—	—
D 1	60	1731		315	.45	1.6	414.732	92	89	59	251	6
2	64			315	.48	1.7	417.6	93	89	58	255	6
3	68		-11"	316	.45	1.6	420.4	93	89	59	250	6
4	72			317	.44	1.5	423.2	93	89	60	250	6
5	76			317	.46	1.6	425.8	94	89	61	255	6
E 1	80	<del>1751</del> 1752		314	.44	1.5	428.5	95	90	62	253	6
2	84			315	.45	1.6	431.2	97	90	62	248	6
3	88		-11.5"	317	.43	1.5	433.9	97	90	63	250	6
4	92			317	.44	1.5	436.6	97	90	64	255	6

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	316	FILTER
	318	FUN. TRIC
	319	Imp 1-3
	320	Imp 4
	321	Imp 5-6
	322	HCl 4, 6, 0
	327	S.H.I

LEAK CHECK:

K = 3.5

VACUUM	10"	11"	11"			PITOT PRE: <input checked="" type="checkbox"/>
RATE	.008	.009	.007			POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	308
#2	100	230
#3	100	112
#4	0	4
#5	100	90
#6	100	104
#7	250.0	272.0

NOZZLE Ø	C11 0.280
PITOT #	158
BOX ID	18
GAMMA γ	0.9604
ΔH@	2.0614
PROBE ID	PL 9-6
SYSTEM ID	u-50-2/uA4/ m-pl
FILTER ID	

ISOKINETIC SAMPLING DATA SHEET

FACILITY: Westra - Pinellas County RRF TEST LOCATION: unit 1 DATE: 4/9/13  
TECHNICIAN: DAW POLLUTANT: metals RUN I.D.: 410 - M 29 - R 3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft³	DGM IN TEMP.	DGM OUT TEMP.	EXIT TEMP	FILTER TEMP.	METER VAC.
5	96			320	.46	1.6	439.2	97	91	64	250	6
F 1	100	<del>1812</del> 1813		320	.50	1.8	442.0	96	92	64	257	6
2	104			317	.47	1.8	444.8	93	91	65	260	6
3	108		-11"	319	.47	1.7	447.7	92	90	65	253	6
4	112			318	.45	1.6	450.5	92	90	64	255	6
5	116			318	.44	1.5	453.2	92	89	65	261	6
	120	1833		-	-	-	456.046	-	-	-	-	-



## **Appendix H.2**

### **EPA Method 29 Raw Field Data: Unit 1 SDA Inlet**

FACILITY: PINELLAS COUNTY PRC TEST LOCATION: UNIT 1 ENLET DATE: 4-9-12

TECHNICIAN JS P<sub>BAR</sub> 30.02 POLLUTANT: METALS RUN I.D.: UIE-M29-R1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A 1	6	905		587	.54	1.4	472.068	73	73	65	254	4
2	5			586	.62	1.6	475.2	74	73	53	251	4
3	10			587	.66	1.7	478.5	75	73	55	252	5
4	15			587	.65	1.7	482.0	76	73	57	249	7
5	20			586	.68	1.8	485.5	76	73	58	250	8
6	25	930 939	-1.5	588	.66	1.7	489.1	77	73	59	246	8
7	30			587	.64	1.7	492.6	77	74	58	251	9
8	35			587	.65	1.7	496.1	77	74	59	247	10
9	40			590	.63	1.6	499.5	79	75	60	250	10
10	45			591	.63	1.6	502.9	78	75	61	248	11
11	50			592	.59	1.5	506.3	78	75	61	251	11
12	55			592	.62	1.6	509.6	78	75	61	253	11
	60	1014					513.015					
B 1	60	1026		592	.50	1.3	513.244	76	76	62	247	11
2	65			593	.54	1.4	516.4	77	76	63	245	11
3	70			593	.60	1.6	519.6	78	76	63	251	12
4	75			593	.60	1.6	522.9	78	76	64	254	13
5	80			592	.62	1.6	526.2	77	76	63	252	13
6	85		-1.3	592	.61	1.6	529.5	77	75	61	250	14
7	90			593	.62	1.6	532.9	78	75	61	252	14
8	95			593	.63	1.6	536.2	77	75	60	254	15
9	100			592	.61	1.6	539.4	78	76	61	255	15
10	105			592	.60	1.6	542.7	78	76	61	251	16
11	110			592	.57	1.5	546.0	78	77	64	253	17
12	115			590	.54	1.4	549.3	78	77	65	251	18

CHAIN OF CUSTODY: <sup>110</sup> <sup>1126</sup>

CONTAINER	SAMPLE I.D.	DESCRIPTION
	100	Filter
	101	FH WTRIC
	102	IMP 1-3
	103	IMP 4
	104	IMP 5-6
	105	HCL 226.0
	106	SIL GEL

LEAK CHECK: 552.588

LEAK CHECK:				PITOT	
VACUUM	15	15	15	PRE:	<input checked="" type="checkbox"/>
RATE	.008	.006	.005	POST:	<input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	133
#2	100	250
#3	100	137
#4	0	2
#5	100	100
#6	100	94
#7	250.0	278.3

NOZZLE Ø	A-11, .280
PITOT #	105 A
BOX ID	17
GAMMA Y	0.9798
ΔH@	1.8708
PROBE ID	PL-10-1
SYSTEM ID	U-50-4, PNH-B-1, UA-17
FILTER ID	UNTARED

FACILITY: Pinellas County RRC TEST LOCATION: UNIT 1 INLET DATE: 4-9-13  
 TECHNICIAN JS P<sub>BAR</sub> 30.02 POLLUTANT: METALS RUN I.D.: 4-9-13 29-R2

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
R 1	0	1344		597	.62	1.6	553.523	81	82	63	256	4
2	5			598	.64	1.7	556.9	85	82	61	249	5
3	10			599	.66	1.7	560.4	85	82	62	251	5
4	15			599	.65	1.7	563.9	85	82	63	250	6
5	20			598	.67	1.7	567.4	86	83	62	247	7
6	25			599	.67	1.7	570.8	86	83	59	249	8
7	30		-1.6	599	.66	1.7	574.3	86	83	58	252	9
8	35			600	.64	1.7	577.7	86	83	58	249	10
9	40			600	.65	1.7	581.2	86	84	58	248	10
10	45			599	.63	1.6	584.7	86	84	58	251	11
11	50			598	.60	1.6	588.1	86	84	59	254	11
12	55			598	.58	1.5	591.5	86	84	60	253	11
	60	1444					594.857					
A 1	60	1434		597	.56	1.5	595.066	83	83	62	251	11
2	65			598	.61	1.6	598.3	85	83	60	250	12
3	70			598	.63	1.6	601.7	84	83	59	248	13
4	75			599	.65	1.7	605.1	84	83	60	246	14
5	80			595	.65	1.7	608.6	83	83	60	253	15
6	85			593	.64	1.7	612.0	82	82	61	253	15
7	90		-1.4	594	.63	1.6	615.4	83	82	60	255	16
8	95			594	.65	1.7	618.8	83	82	61	253	17
9	100			595	.62	1.6	622.2	84	82	61	251	17
10	105			594	.62	1.6	625.5	84	82	62	248	17
11	110			595	.60	1.6	628.8	84	83	62	247	18
12	115			595	.59	1.5	632.1	84	83	63	250	18

CHAIN OF CUSTODY: 120 1534

CONTAINER	SAMPLE I.D.	DESCRIPTION
	107	Filter
	108	PHN. Pic
	109	Imp 13
	110	Imp 4
	111	Imp 56
	112	HCL/H <sub>2</sub> O
	113	Sol

LEAK CHECK: 635.428

VACUUM	15	15	20	75/55		PITOT
RATE	.025	.004	.004			PRE: <input checked="" type="checkbox"/>
						POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	154
#2	100	218
#3	100	140
#4	0	2
#5	100	104
#6	100	100
#7	251.4	278.6

NOZZLE Φ	8-10 4-11 280
PITOT #	125 152
BOX ID	17
GAMMA γ	0.9798
ΔH@	1.8708
PROBE ID	PL-10-2
SYSTEM ID	U-50-4, PNHR-1, UA 17
FILTER ID	UNSTARRED

FACILITY: PINELLAS COUNTY RRE TEST LOCATION: UNIT 1 INLET DATE: 4-9-13

TECHNICIAN: JS P<sub>BAR</sub>: 30.04 POLLUTANT: METALS RUN I.D.: DLZ-M29-R3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A1	0	1622		594	.55	1.4	636.623	85	85	62	245	4
2	5			595	.59	1.5	639.8	84	83	60	248	4
3	10			598	.62	1.6	643.0	85	83	61	251	5
4	15			598	.63	1.6	646.3	86	83	60	249	5
5	20			599	.63	1.6	649.6	86	86	59	251	6
6	25			598	.65	1.7	652.9	86	84	59	253	7
7	30		-1.6	599	.64	1.7	656.3	86	84	60	249	8
8	35			599	.64	1.7	659.8	87	83	60	246	8
9	40			599	.65	1.7	663.3	87	83	61	245	9
10	45			600	.63	1.6	666.8	87	84	60	247	9
11	50			600	.63	1.6	670.2	87	84	59	255	10
12	55			600	.61	1.6	673.8	87	84	59	252	10
	60	1722					677.299					
B1	60	1731		600	.60	1.6	678.967	85	84	63	255	11
2	65			601	.63	1.6	682.4	88	85	61	254	12
3	70			600	.62	1.6	685.3	88	85	60	251	12
4	75			600	.65	1.7	688.6	88	85	60	253	13
5	80			600	.64	1.7	692.1	88	85	59	251	13
6	85			601	.63	1.6	695.6	88	86	59	248	14
7	90		-1.7	601	.63	1.6	699.0	88	86	60	256	14
8	95			601	.62	1.6	702.4	87	86	61	251	15
9	100			601	.60	1.6	705.6	87	86	62	246	15
10	105			600	.61	1.6	709.0	88	86	62	253	16
11	110			600	.58	1.5	712.3	89	87	62	254	16
12	115			600	.53	1.4	715.5	89	87	63	246	16

CHAIN OF CUSTODY: <sup>130 1831</sup>

CONTAINER	SAMPLE I.D.	DESCRIPTION
	114	FILTER
	115	FUNNEL
	116	Imp 1-3
	117	Imp 4
	118	Imp 5-6
	119	UCL 4.0
	120	S.601

LEAK CHECK: 718.752

VACUUM	15	15	<sup>20</sup> <del>20</del>			PITOT PRE: <input checked="" type="checkbox"/>
RATE	.007	.006	.005			POST: <input checked="" type="checkbox"/>

IMPINGER	INITIAL	FINAL
#1	0	145
#2	100	235
#3	100	130
#4	0	11
#5	100	115
#6	100	95
#7	250.4	2747

NOZZLE Φ	A-11, .280
PITOT #	125A
BOX ID	17
GAMMA γ	0.9798
ΔH@	1.8708
PROBE ID	PL-10-1
SYSTEM ID	U-50-4, PCH-1, U9-17
FILTER ID	UNTARED

## **Appendix H.3**

### **EPA Method 29 Raw Field Data: Unit 2 FF Outlet**

FACILITY: Pinellas County RRF TEST LOCATION: unit 2 DATE: 4/10/13  
 TECHNICIAN RAW P<sub>BAR</sub> 29.99 POLLUTANT: metals RUN I.D.: u20-M 29-R 1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP.	FILTER TEMP.	METER VAC.
F 1	0	0845		282	.48	1.8	470.436	70	70	55	258	5
2	4			297	.48	1.8	473.8	72	71	54	255	5
3	8	<del>0857</del> 0859	-11"	298	.45	1.7	476.6	73	71	55	256	5
4	12			291	.40	1.5	479.5	75	71	56	256	5
5	16			302	.33	1.3	482.1	75	71	57	257	5
E 1	20	<del>0907</del> 0908		292	.47	1.8	484.7	77	72	58	248	5
2	24			292	.49	1.9	487.6	78	73	59	255	5
3	28			293	.46	1.7	490.4	78	74	59	256	5
4	32		-10.5"	298	.42	1.6	493.2	79	74	59	254	5
5	36			303	.34	1.3	495.9	80	75	61	256	5
D 1	40	<del>0928</del> 0929		292	.45	1.7	498.3	81	75	62	248	5
2	44			297	.47	1.8	500.9	79	75	62	253	5
3	48	<del>0933</del> 0940		288	.44	1.7	503.8	80	75	62	247	5
4	52		-11"	291	.43	1.6	506.6	80	75	63	252	5
5	56			293	.35	1.3	509.3	80	75	63	255	5
	60	0959		—	—	—	511.836	—	—	—	—	—
C 1	60	1004		288	.48	1.8	511.997	78	76	63	252	5
2	64			290	.47	1.8	514.6	79	76	62	255	5
3	68		-10.5"	305	.43	1.6	517.5	79	76	63	257	5
4	72			299	.40	1.5	520.2	80	76	63	260	5
5	76			289	.33	1.3	522.8	81	76	64	254	5
B 1	80	<del>1024</del> 1025		291	.47	1.8	525.8	81	77	60	255	5
2	84			292	.45	1.7	528.0	82	77	60	253	5
3	88		-11"	290	.45	1.7	530.7	82	77	59	260	5
4	92	<del>1035</del> 1044		291	.40	1.5	533.3	80	78	58	261	5

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	324	FILTER
	326	Punct.
	327	Imp 3
	328	Imp 4
	329	Imp 5-6
	330	HC1 & H2
	331	S-bul

LEAK CHECK:

VACUUM	10"	10"	11"			PITOT PRE: <input checked="" type="checkbox"/>
RATE	.008	.009	.011			POST: <input checked="" type="checkbox"/>

K=3.8

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0 50	176
#2	60 100	228
#3	100 100	132
#4	0 100	8
#5	100 100	97
#6	100 250	107
#7	250 250	282.6

NOZZLE Ø	D10 0.280
PITOT #	322
BOX ID	18
GAMMA γ	0.4604
ΔH@	2.0614
PROBE ID	PL 9-1
SYSTEM ID	u-50-2/244/mpl
FILTER ID	

ISOKINETIC SAMPLING DATA SHEET

FACILITY: Pinellas County RRF TEST LOCATION: Unit 2

DATE: 4/10/13

TECHNICIAN: IAW

POLLUTANT: metals

RUN I.D.: U20-M 2A-R 1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM IN TEMP.	DGM OUT TEMP.	EXIT TEMP	FILTER TEMP.	METER VAC.
S	96			300	.35	1.3	536.0	80	78	64	252	5
A1	100	1054 10-55		291	.40	1.5	538.5	81	78	63	261	5
2	104			291	.43	1.6	541.2	82	78	63	257	5
3	109		-10.5"	292	.43	1.6	543.9	83	78	64	254	5
4	112			297	.41	1.5	546.6	83	78	65	258	5
5	116			300	.35	1.3	549.2	84	79	65	255	5
	120	1115		—	—	—	591.290	—	—	—	—	—

FACILITY: Pinellas County RRF TEST LOCATION: unit 2 DATE: 4/10/13  
 TECHNICIAN: PAW P<sub>BAR</sub>: 29.95 POLLUTANT: metals RUN I.D.: 620 - M 29 - R 2

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A1	0	1209		294	.48	1.8	556.062	84	81	64	242	5
2	4	<del>1212</del> 1222		294	.48	1.8	558.7	85	81	60	255	5
3	8		-11"	298	.45	1.7	561.5	84	82	55	255	5
4	12			297	.41	1.6	564.4	85	82	56	256	5
5	16			295	.35	1.3	567.1	86	82	56	254	5
B1	20	<del>1239</del> 1240		295	.45	1.7	569.5	87	83	56	258	5
2	24			295	.46	1.7	572.2	88	83	57	260	5
3	28		-10.5"	297	.44	1.7	574.9	88	83	57	257	5
4	32			294	.40	1.5	577.7	88	84	58	255	5
5	36			292	.36	1.4	580.3	89	84	58	260	5
C1	40	<del>1300</del> 1301		292	.47	1.8	583.0	89	84	59	261	5
2	44			296	.48	1.8	585.8	90	85	59	255	5
3	48			302	.45	1.7	588.7	90	85	60	253	5
4	52		-10.5"	294	.41	1.6	591.4	90	85	60	257	5
5	56			292	.37	1.4	594.1	91	85	61	255	5
	60	1321		-	-	-	596.820	-	-	-	-	-
D1	60	1326		293	.49	1.9	596.967	89	87	61	258	5
2	64			293	.47	1.8	599.6	89	87	62	260	5
3	68		-11"	300	.44	1.7	602.4	90	87	62	255	5
4	72			304	.41	1.6	605.2	90	87	62	260	5
5	76			292	.35	1.3	608.0	90	88	63	258	5
E1	80	<del>1346</del> 1347		292	.51	1.9	610.5	91	88	63	261	5
2	84			294	.50	1.9	613.5	91	88	64	258	5
3	88		-11"	304	.48	1.8	616.4	92	89	64	255	5
4	92			305	.43	1.6	619.5	93	90	64	253	5

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	332	Filter
	334	Function
	335	Imp 1-3
	336	Imp 4
	337	Imp 5-6
	338	HCl + H <sub>2</sub> O
	339	S. 6.1

LEAK CHECK:

VACUUM	11"	11"	0"			PITOT
RATE	.005	.007	.008			PRE: <input checked="" type="checkbox"/>
						POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	213
#2	100	235
#3	100	120
#4	0	0
#5	100	98
#6	100	95
#7	250	268.4

NOZZLE Φ	C11 0.280
PITOT #	158
BOX ID	18
GAMMA γ	0.9604
ΔH@	2.0614
PROBE ID	PL 9-6
SYSTEM ID	W-50-2/VA4/m-p1
FILTER ID	7





FACILITY: Pinellas County RRF TEST LOCATION: unit 2 DATE: 4/10/13  
 TECHNICIAN ZAW P<sub>BAR</sub> 29.95 POLLUTANT: metals RUN I.D.: 620-M 29-R 3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME F <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
F 1	0	1525		298	.40	1.5	643.160	94	94	55	260	5
2	4			301	.48	1.8	645.8	96	93	55	256	5
3	8		-10.5"	294	.50	1.9	648.8	97	95	58	282	5
4	12			294	.46	1.7	651.8	96	97	59	260	5
5	16			293	.40	1.5	654.5	97	98	60	251	5
F 1	20	<del>1545</del> 1546		294	.48	1.8	657.2	99	100	61	256	5
2	24			295	.47	1.8	660.0	99	100	61	260	5
3	28			292	.44	1.6	663.1	101	101	61	249	5
4	32		-11"	298	.44	1.6	665.8	101	102	62	251	5
5	36			298	.38	1.4	668.5	102	102	62	252	5
D 1	40	<del>1606</del> 1607		292	.50	1.9	671.0	102	102	62	252	5
2	44			299	.46	1.7	673.9	103	104	63	254	5
3	48			304	.48	1.8	676.8	103	104	63	255	5
4	52		-10.5"	306	.44	1.6	679.9	103	104	63	254	5
5	56			300	.38	1.4	682.7	101	102	64	256	5
	60	1627		—	—	—	685.316	—	—	—	—	—
C 1	60	1633		292	.45	1.7	685.620	102	103	60	248	5
2	64			292	.46	1.7	688.5	102	103	60	257	5
3	68			294	.43	1.6	691.3	102	103	61	256	5
4	72		-11"	294	.41	1.5	694.0	102	103	61	260	5
5	76			308	.35	1.3	696.7	101	102	61	255	5
B 1	80	<del>1653</del> 1654		306	.40	1.5	699.1	101	102	62	253	5
2	84			292	.44	1.6	701.8	102	101	60	254	5
3	88		-11"	292	.44	1.6	704.5	102	102	61	255	5
4	92			303	.38	1.4	707.2	101	99	61	254	5

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	340	F.16
	342	FM N.T.C
	343	Imp 1-3
	344	Imp 4
	345	Imp 5-6
	346	HCl H <sub>2</sub> O
	347	S.601

LEAK CHECK:

VACUUM	10"	11"				PITOT PRE: <input checked="" type="checkbox"/>
RATE	.004	.007				POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	133
#2	100	241
#3	100	134
#4	0	7
#5	100	101
#6	100	95
#7	250 <sup>0</sup>	270.6

NOZZLE Ø	10 0.280
PITOT #	322
BOX ID	18
GAMMA γ	0.9604
ΔH@	2.0614
PROBE ID	PL 9-1
SYSTEM ID	u-20-2/UA4/m-p1
FILTER ID	—



## **Appendix H.4**

### **EPA Method 29 Raw Field Data: Unit 2 SDA Inlet**

FACILITY: PINELLAS CO RRC TEST LOCATION: UNIT 2 INLET DATE: 4-10-13

TECHNICIAN JS P<sub>BAR</sub> 29.99 POLLUTANT: METALS RUN I.D.: 02E-M 29 -R 1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A 1	0	845		518	.46	1.3	727.148	69	68	58	246	4
2	5			519	.50	1.4	730.3	72	70	51	245	5
3	10			519	.52	1.5	733.3	73	70	54	249	6
4	15	<del>857</del> 859		520	.54	1.5	736.5	73	71	58	251	7
5	20			518	.54	1.5	739.7	73	70	58	247	7
6	25			517	.55	1.5	743.0	74	71	59	242	8
7	30		-1.1	517	.58	1.6	746.2	73	71	60	246	9
8	35			516	.59	1.7	749.6	73	70	61	252	9
9	40			516	.58	1.6	753.0	73	71	62	250	10
10	45	<del>932</del> 940		515	.60	1.7	756.4	74	71	63	251	10
11	50			515	.59	1.7	759.8	74	71	63	254	11
12	55			516	.59	1.7	763.3	75	72	64	253	11
	60	955					766.703					
B 1	60	1004		516	.43	1.2	766.913	73	72	64	249	10
2	65			515	.46	1.3	770.0	74	73	56	256	10
3	70			515	.49	1.4	772.9	74	72	56	256	11
4	75			515	.50	1.4	776.0	74	73	56	251	12
5	80			516	.51	1.4	779.2	74	72	56	253	12
6	85			515	.54	1.5	782.3	75	72	57	251	13
7	90	<del>1035</del> <del>1040</del> 1044	-1.0	515	.57	1.6	785.6	75	73	57	247	13
8	95			515	.58	1.6	788.5	74	73	56	248	13
9	100			516	.58	1.6	791.9	75	74	58	251	14
10	105			516	.60	1.7	795.3	75	74	61	256	14
11	110			515	.59	1.7	798.7	75	74	62	246	15
12	115			515	.60	1.7	803.1	75	74	62	249	15

CHAIN OF CUSTODY: 120 1113

CONTAINER	SAMPLE I.D.	DESCRIPTION
	121 <del>120</del>	FILTER
	122 RT	Fun-trial
	123 122	Imp 1-3
	124 123	Imp 4
	125 124	Imp 5-6
	126 125	Heil 2420
	127 126	S. bel
	129	
	(12)	

LEAK CHECK: 806.519

LEAK CHECK:					PITOT	
VACUUM	15	15	15		PRE:	✓
RATE	.005	.004	.004		POST:	✓

IMPINGER CONTENTS:		
IMPINGER	INITIAL	FINAL
#1	0	94
#2	100	237
#3	100	157
#4	0	12
#5	100	106
#6	100	101
#7	250.4	273.5

NOZZLE Ø	R-10, .280
PITOT #	152
BOX ID	17
GAMMA γ	0.9798
ΔH@	1.8708
PROBE ID	PL-10-2
SYSTEM ID	U-50-4, PWRB-1, VAR-17
FILTER ID	UNTAPED

FACILITY: PINELLAS CO. REC TEST LOCATION: UNIT 2 INLET DATE: 4-10-13

TECHNICIAN SS P<sub>BAR</sub> 29.98 POLLUTANT: METALS RUN I.D.: U2EM29-R2

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME F <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
B 1	0	1209		515	.44	1.2	807.109	77	77	63	243	4
2	5	<del>1213</del> 1222		515	.47	1.3	810.0	78	78	61	247	5
3	10			516	.49	1.4	813.1	80	78	60	243	6
4	15			516	.52	1.5	816.3	82	79	60	247	7
5	20			515	.53	1.5	819.6	83	81	59	243	7
6	25			515	.55	1.5	822.8	85	82	61	245	8
7	30		-98	516	.55	1.5	826.0	89	84	61	249	8
8	35			519	.58	1.6	829.2	89	84	62	252	9
9	40			523	.56	1.6	832.6	88	84	61	250	9
10	45			522	.57	1.6	836.0	88	83	62	254	10
11	50			522	.55	1.5	839.3	89	83	63	253	10
12	55			523	.56	1.6	842.7	88	83	62	250	11
	60	1318					846.015					
A 1	60	1326		523	.46	1.3	846.307	83	83	64	245	11
2	65			522	.47	1.3	849.5	86	83	62	249	11
3	70			522	.49	1.4	852.5	87	84	61	252	12
4	75			523	.51	1.4	855.7	88	83	61	251	12
5	80			522	.53	1.5	858.9	87	83	60	257	13
6	85			522	.53	1.5	862.2	87	84	60	255	13
7	90		-1.1	523	.55	1.5	865.5	87	84	61	251	14
8	95			522	.56	1.6	868.7	87	85	61	253	14
9	100			522	.55	1.5	872.0	86	84	62	248	14
10	105			521	.57	1.6	875.3	86	84	62	251	14
11	110			521	.56	1.6	878.6	86	85	62	250	15
12	115			520	.56	1.6	881.9	86	85	62	246	15

CHAIN OF CUSTODY: 120 1426

LEAK CHECK: 885.253

PITOT

CONTAINER	SAMPLE I.D.	DESCRIPTION
	128	FILTER
	129	FUNNEL
	130	Imp 1-3
	131	Imp 4
	132	Imp 5-6
	133	HCl + H <sub>2</sub> O
	134	Subel

VACUUM	15	15	15			PRE: <input checked="" type="checkbox"/>
RATE	.007	.005	.005			POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	116
#2	100	240
#3	100	129
#4	0	10
#5	100	100
#6	100	105
#7	250.0	278.0

NOZZLE Ø	A-11, .280
PITOT #	125A
BOX ID	17
GAMMA Y	0.9798
ΔH@	1.8708
PROBE ID	PL-10-1
SYSTEM ID	U-50-4, PNOX-1, 4017
FILTER ID	UNTAGGED

3.0  
2.8  
2.8

FACILITY: PINELLAS CO. PRC TEST LOCATION: UNIT 2 INLET DATE: 4-10-13  
 TECHNICIAN JS P<sub>BAR</sub> 29.95 POLLUTANT: METALS RUN I.D.: U2E-M29-R3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A1	0	1525		521	.43	1.2	886.015	85	86	64	251	4
2	5			522	.45	1.3	889.0	86	87	62	253	5
3	10			522	.46	1.3	892.1	88	86	61	250	5
4	15			521	.49	1.4	895.2	90	88	62	252	6
5	20			523	.51	1.5	898.4	90	88	62	246	7
6	25			520	.51	1.5	901.7	92	88	61	249	7
7	30		-1.1	519	.54	1.6	905.0	94	89	60	251	8
8	35			518	.57	1.7	908.4	94	90	61	252	9
9	40			519	.56	1.7	911.8	95	91	61	249	9
10	45			520	.58	1.7	915.4	95	92	62	243	10
11	50			520	.58	1.7	918.9	95	91	62	247	10
12	55			520	.57	1.7	922.5	93	91	63	250	11
	60	1625					926.124					
B1	60	1633		520	.40	1.2	926.355	88	88	63	252	11
2	65			521	.44	1.3	929.5	95	90	61	250	11
3	70			520	.46	1.3	932.5	98	92	60	251	12
4	75			519	.49	1.4	935.6	101	95	60	250	13
5	80			519	.52	1.6	938.7	102	96	61	256	13
6	85			520	.52	1.6	942.0	103	97	61	253	14
7	90		-1.0	519	.55	1.7	945.4	104	99	60	251	14
8	95			518	.55	1.7	948.9	106	100	61	251	14
9	100			518	.57	1.7	952.4	106	101	61	246	15
10	105			519	.58	1.7	955.9	105	102	62	248	16
11	110			520	.56	1.7	959.4	105	103	62	251	16
12	115			520	.56	1.7	962.9	104	103	63	247	17

CHAIN OF CUSTODY: 140 1733

CONTAINER	SAMPLE I.D.	DESCRIPTION
	135	Filter
	136	PUMPING
	137	Imp 1-3
	138	Imp 4
	139	Imp 5-6
	140	ACI H <sub>2</sub> O
	141	S. 6.1

LEAK CHECK: 966.437

LEAK CHECK:				PITOT	
VACUUM	15	15	18	PRE:	<input checked="" type="checkbox"/>
RATE	.007	.004	.002	POST:	<input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	71
#2	100	232
#3	100	137
#4	0	13
#5	100	100
#6	100	97
#7	250.0	273.2

NOZZLE Ø	152
PITOT #	B-10, (280)
BOX ID	17
GAMMA γ	0.9798
ΔH@	1.8708
PROBE ID	PL-10-2
SYSTEM ID	U-50-4, PARR-1, UAT-7
FILTER ID	UNTARGETED

## **Appendix H.5**

### **EPA Method 29 Raw Field Data: Unit 3 FF Outlet**



FACILITY: Pinellas County RRF TEST LOCATION: Unit 3 DATE: 4/17/18  
 TECHNICIAN JAW P<sub>BAR</sub> 29.84 POLLUTANT: metals RUN I.D.: W30 -M 29 -R 1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME FT <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A 1	0	837		311	.45	1.7	739.169	75	74	60	249	S
2	4			310	.45	1.7	742.3	76	74	61	252	S
3	8		-11"	312	.43	1.6	745.0	76	74	58	259	S
4	12			312	.40	1.5	747.7	77	74	57	256	S
5	16			312	.34	1.3	750.3	78	74	58	255	S
B 1	20	<del>857</del> 858		320	.44	1.7	752.8	79	75	59	252	S
2	24			320	.45	1.7	755.5	80	75	60	257	S
3	28		-11"	309	.41	1.6	758.2	80	76	61	253	S
4	32			304	.39	1.5	760.9	81	76	61	254	S
5	36			306	.35	1.3	763.5	82	77	61	247	S
L 1	40	<del>814</del> 819		307	.43	1.6	766.0	82	77	60	255	S
2	44			307	.42	1.6	768.6	83	77	61	249	S
3	48			308	.40	1.5	771.2	82	78	61	261	S
4	52		-11"	308	.38	1.5	773.8	83	78	62	258	S
5	56			307	.35	1.3	776.4	83	78	62	255	S
	60	939		—	—	—	779.116	—	—	—	—	—
D 1	60	0954		306	.43	1.6	779.360	79	78	59	248	S
2	64			306	.42	1.6	782.0	80	79	60	252	S
3	68		-11"	307	.41	1.6	784.7	81	79	60	256	S
4	72			307	.40	1.5	787.2	82	79	61	261	S
5	76			308	.34	1.3	789.8	82	79	61	257	S
E 1	80	<del>1014</del> 1015		306	.42	1.6	792.3	83	80	61	261	S
2	84			306	.41	1.6	794.9	84	80	62	262	S
3	88		-11"	306	.41	1.6	797.5	84	80	62	257	S
4	92			306	.39	1.5	800.0	85	80	62	260	S

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	348	Filter
	350	Function
	351	Imp 1-3
	352	Imp 4
	353	Imp 5-6
	354	HCl vials
	355	S. bel

LEAK CHECK:

K=3.8

VACUUM	11"	10"	10"			PITOT
RATE	.010	.007	.008			PRE: <input checked="" type="checkbox"/>
						POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	160
#2	100	335
#3	100	153
#4	0	5
#5	100	100
#6	100	98
#7	250	270

NOZZLE Ø	C11 0.290
PITOT #	158
BOX ID	18
GAMMA γ	0.9604
ΔH@	2.0614
PROBE ID	PL 9-6
SYSTEM ID	4-30-2/44/m-pl
FILTER ID	—



FACILITY: Pinellas County RRF TEST LOCATION: unit 3 DATE: 4/11/13  
 TECHNICIAN: JAW P<sub>BAR</sub>: 29.87 POLLUTANT: metals RUN I.D.: U30-M29-R2

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME FT <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
F1	0	1145		292	.44	1.7	821.630	84	83	59	252	5
2	4			298	.45	1.7	824.3	84	83	58	255	5
3	8		011	305	.43	1.6	827.1	85	83	58	251	5
4	12			305	.41	1.6	829.8	86	83	59	256	5
5	16			307	.38	1.4	832.5	86	83	59	255	5
E1	20	<del>1205</del> 1206		301	.43	1.6	835.0	87	83	60	254	5
2	24			306	.43	1.6	837.6	88	84	60	262	5
3	28		-11	306	.40	1.5	840.3	88	84	60	264	5
4	32			307	.38	1.4	843.0	89	84	60	255	5
5	36			307	.34	1.3	845.6	89	85	60	255	5
D1	40	<del>1226</del> 1227		306	.45	1.7	848.0	90	85	61	250	5
2	44			306	.44	1.7	850.7	91	85	61	251	5
3	48			306	.41	1.6	853.6	91	85	61	261	5
4	52		-11	306	.41	1.6	856.1	92	85	62	250	5
5	56			306	.34	1.3	858.8	91	86	62	252	5
	60	1247		—	—	—	861.484	—	—	—	—	—
C1	60	1252		304	.43	1.6	861.650	89	87	61	260	5
2	64			304	.44	1.6	864.2	89	87	61	255	5
3	68		-11	306	.41	1.6	867.0	91	88	62	250	5
4	72			306	.34	1.5	869.7	91	88	62	266	5
5	76			306	.35	1.3	872.4	92	89	63	254	5
B1	80	<del>1312</del> 1313		307	.43	1.6	875.0	92	89	63	250	5
2	84			307	.43	1.6	877.6	93	90	63	248	5
3	88		-11	307	.41	1.6	880.2	93	90	64	255	5
4	92			307	.39	1.5	882.8	94	90	64	257	5

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	356	Filter
	358	Funnel
	359	Imp 1-3
	360	Imp 4
	361	Imp 5-6
	362	HCl + H <sub>2</sub> O
	363	sil gel

LEAK CHECK:

VACUUM	10"	10"	11"			PRE: <input checked="" type="checkbox"/>
RATE	1.007	.008	.010			POST: <input checked="" type="checkbox"/>

PITOT

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	273
#2	100	260
#3	100	136
#4	0	4
#5	100	100
#6	100	101
#7	250.0	273.6

NOZZLE Ø	C10 0.280
PITOT #	322
BOX ID	18
GAMMA γ	0.9604
ΔH@	2.0614
PROBE ID	PL9-1
SYSTEM ID	U-90-2/044/m-p1
FILTER ID	—



FACILITY: Pinnellas County BRF TEST LOCATION: unit 3 DATE: 4/11/13  
 TECHNICIAN: JAW P<sub>BAR</sub>: 29.85 POLLUTANT: metals RUN I.D.: W30-M29-R3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME F <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A1	0	1436		305	.43	1.6	901.177	92	91	55	283	5
2	4			305	.44	1.6	903.6	92	91	56	254	5
3	8			305	.41	1.5	906.2	92	91	56	253	5
4	12		-11	308	.40	1.4	908.8	93	91	57	281	5
5	16			307	.35	1.3	911.3	94	91	57	260	5
B1	20	<del>1456</del> 1457		306	.42	1.5	912.9	95	92	58	251	5
2	24			306	.43	1.5	916.6	96	92	58	253	5
3	28		-11	307	.40	1.4	919.0	96	93	59	262	5
4	32	<del>1507</del> 1523		307	.40	1.4	921.6	97	93	55	255	5
5	36			304	.35	1.3	924.0	99	98	55	251	5
C1	40	<del>1533</del> 1534		304	.44	1.6	926.5	99	98	56	258	5
2	44			308	.45	1.6	929.1	100	98	56	262	5
3	48		-11	306	.44	1.6	931.8	102	99	57	257	5
4	52			306	.40	1.4	934.5	104	99	59	254	5
5	56			306	.34	1.2	937.1	104	99	60	255	5
	60	1555		—	—	—	939.704	—	—	—	—	—
D1	60	1602		306	.40	1.4	939.884	103	102	62	259	5
2	64			307	.45	1.6	942.5	103	102	62	260	5
3	68		-11	307	.44	1.6	945.1	104	103	62	247	5
4	72			306	.41	1.4	947.8	105	103	63	253	5
5	76			306	.36	1.3	950.4	105	103	60	254	5
E1	80	<del>1632</del> 1623		306	.43	1.5	952.9	104	103	61	255	5
2	84		-11	306	.43	1.5	955.4	103	102	62	261	5
3	88			306	.40	1.4	958.0	102	101	62	262	5
4	92			306	.39	1.4	960.6	101	100	62	255	5

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	364	F. ltr.
	366	Funtric
	367	Imp 1-3
	368	Imp 4
	369	Imp 5-6
	370	HCl vials
	371	S. ltr.

LEAK CHECK:

k=3.8

VACUUM	11"	11"	11"			PITOT
RATE	.003	.004	.005			PRE: <input checked="" type="checkbox"/>
						POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	196
#2	100	294
#3	100	144
#4	0	8
#5	100	106
#6	100	100
#7	250.0	266.9

NOZZLE Ø	CM Ø280
PITOT #	158
BOX ID	18
GAMMA γ	0.9604
ΔH@	2.0614
PROBE ID	PL 9-6
SYSTEM ID	4-902/UA4/mpl
FILTER ID	—



## **Appendix H.6**

### **EPA Method 29 Raw Field Data: Unit 3 SDA Inlet**

FACILITY: Pinellas Co. RRC TEST LOCATION: unit 3 = WLET DATE: 4-11-13

TECHNICIAN JS PBAR 2984 POLLUTANT: METALS RUN I.D.: USE - M 29 - R 1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A1	0	837		606	.44	1.1	976.029	73	73	62	240	4
2	5			608	.48	1.2	979.0	74	73	57	247	5
3	10			609	.52	1.4	981.9	76	73	58	249	6
4	15			610	.51	1.3	985.0	77	73	58	250	6
5	20			610	.53	1.4	987.9	78	73	59	251	7
6	25			609	.53	1.4	991.6	77	74	59	252	7
7	30		-1.4	609	.54	1.4	994.1	78	74	60	250	8
8	35			610	.57	1.5	997.3	78	74	60	249	9
9	40			616	.58	1.5	000.5	78	74	61	246	10
10	45			610	.58	1.5	003.8	78	75	61	249	10
11	50			609	.57	1.5	007.0	78	75	62	256	10
12	55			609	.59	1.5	010.1	78	75	62	253	11
	60	937					013.419					
B1	60	934 94703		609	.46	1.2	013.604	75	75	64	251	11
2	65			610	.49	1.3	016.5	77	75	61	253	12
3	70			610	.53	1.4	019.3	78	75	58	249	13
4	75			611	.52	1.4	022.4	78	75	58	251	13
5	80		-1.4	611	.54	1.4	025.5	78	76	57	252	14
6	85			610	.56	1.5	028.6	78	76	57	251	15
7	90			610	.56	1.5	031.9	77	76	58	253	15
8	95			611	.58	1.5	035.2	78	76	58	251	16
9	100			610	.57	1.5	038.5	78	76	59	247	16
10	105			610	.59	1.5	041.8	78	77	59	248	17
11	110			609	.59	1.5	045.1	78	77	60	251	17
12	115			610	.58	1.5	048.4	78	77	60	254	18

CHAIN OF CUSTODY: 120 1054

CONTAINER	SAMPLE I.D.	DESCRIPTION
	145	FILTER
	150	Funitor
	151	Imp 1-3
	152	Imp 4
	153	Imp 5-6
	154	HC124.0
	155	S. bal

LEAK CHECK: 051.763

LEAK CHECK:					PITOT
VACUUM	15	15	20		PRE: <input checked="" type="checkbox"/>
RATE	.007	.005	.005		POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	119
#2	100	264
#3	100	141
#4	0	12
#5	100	100
#6	100	106
#7	250	262.7

NOZZLE Ø	4-11, .280
PITOT #	125A
BOX ID	17
GAMMA γ	0.9798
ΔH@	1.8708
PROBE ID	PL-10-1
SYSTEM ID	6-50-4, P10HB-1, UA 17
FILTER ID	UNTESTED



ISOKINETIC SAMPLING DATA SHEET

FACILITY: Pinnellas Co. ORC TEST LOCATION: Unit 3 Intake DATE: 4-11-13

TECHNICIAN JS P<sub>BAR</sub> 29.85 POLLUTANT: METALS RUN I.D.: 03E - M29 - R2

26  
27

29.82 (WV)

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
B1	0	1145		610	.41	1.1	052.247	80	79	65	243	4
2	5			609	.45	1.2	055.3	81	79	62	248	5
3	10			610	.49	1.3	058.3	82	79	61	251	6
4	15			609	.51	1.3	061.3	83	79	61	249	6
5	20			610	.52	1.4	064.3	83	80	60	253	7
6	25			611	.54	1.4	067.5	84	80	60	252	7
7	30		-1.0	612	.54	1.4	070.5	84	80	61	254	8
8	35			611	.56	1.5	073.7	85	81	61	254	9
9	40			610	.58	1.6	076.8	85	81	62	255	10
10	45			610	.58	1.6	079.9	85	82	62	251	10
11	50			610	.59	1.6	083.2	85	82	63	247	11
12	55			609	.58	1.6	086.5	85	82	62	246	11
	60	1245					089.952					
A1	60	1252		610	.43	1.2	090.229	82	82	64	245	11
2	65			610	.47	1.3	093.0	85	83	61	247	11
3	70			609	.50	1.4	095.9	86	84	61	251	12
4	75			609	.52	1.4	099.1	88	84	60	250	12
5	80			608	.55	1.5	102.2	88	84	60	252	13
6	85			608	.56	1.5	105.4	88	84	61	254	13
7	90		-98	609	.57	1.5	108.7	88	85	61	251	14
8	95			609	.58	1.6	111.8	87	85	62	253	14
9	100			610	.58	1.6	115.2	86	85	62	252	15
10	105			610	.57	1.5	118.5	86	84	63	251	16
11	110			610	.57	1.5	121.7	86	84	63	246	16
12	115			609	.58	1.6	124.9	87	84	63	249	17

CHAIN OF CUSTODY: 120 1352

CONTAINER	SAMPLE I.D.	DESCRIPTION
	149	FILTER
	150	FUNNY
	151	Imp 3
	152	Imp 4
	153	Imp 5-6
	154	HCl H <sub>2</sub> O
	155	S. 6-1

LEAK CHECK: 128.243

VACUUM	15	15	18			PITOT
RATE	.008	.005	.004			PRE: <input checked="" type="checkbox"/>
						POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	83
#2	100	275
#3	100	168
#4	0	16
#5	100	106
#6	100	106
#7	251.0	272.0

NOZZLE Φ	K-10, .280
PITOT #	152
BOX ID	17
GAMMA Y	0.9798
ΔH@	1.8708
PROBE ID	PL-10-2
SYSTEM ID	U-50-4, PNH3-1, UA-17
FILTER ID	UNTAGGED

FACILITY: PINELLAS CO. RRC TEST LOCATION: UNIT 3 INLET DATE: 4-11-13

TECHNICIAN JS P<sub>BAR</sub> 29.85 POLLUTANT: METALS RUN I.D.: VZE-M29-R3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A 1	0	1436		609	.42	1.1	129.249	87	86	65	243	4
2	5			610	.46	1.2	132.1	89	87	61	247	5
3	10			610	.49	1.3	135.1	90	87	61	251	6
4	15			610	.52	1.4	138.2	92	87	60	253	7
5	20			609	.53	1.4	141.4	93	88	60	248	7
6	25			610	.53	1.4	144.6	93	88	61	251	8
7	30		-1.6	609	.55	1.5	147.8	93	89	61	250	8
8	35	1506 1527		609	.56	1.5	151.1	93	91	62	247	9
9	40			610	.59	1.6	154.4	94	90	60	249	9
10	45			610	.58	1.6	157.8	94	91	60	255	10
11	50			610	.58	1.6	161.3	92	90	62	253	10
12	55			610	.59	1.6	164.5	91	89	61	254	11
	60	1553					167.915					
B 1	60	1602		609	.44	1.2	168.242	87	87	63	251	11
2	65			609	.47	1.3	171.4	90	87	60	253	12
3	70			609	.49	1.3	174.5	92	88	61	252	12
4	75			610	.51	1.4	177.5	93	89	61	256	13
5	80			610	.53	1.4	180.7	93	91	60	247	13
6	85			609	.53	1.4	183.9	93	91	60	243	14
7	90		-1.1	609	.56	1.5	187.1	92	91	61	246	14
8	95			609	.57	1.5	190.4	91	90	61	249	15
9	100			610	.58	1.6	193.7	90	89	61	253	16
10	105			610	.58	1.6	197.0	89	88	62	251	16
11	110			609	.57	1.5	200.4	87	88	62	249	17
12	115			610	.59	1.6	203.7	87	88	64	246	17

CHAIN OF CUSTODY: 120 1702

CONTAINER	SAMPLE I.D.	DESCRIPTION
	156	FILTER
	157	FUNTRIC
	158	Imp 1-3
	159	Imp 4
	160	Imp 5-6
	161	WCLH <sub>2</sub> O
	112	S.6-1

LEAK CHECK: 207.149

VACUUM	15	15	15	PITOT
RATE	.009	.007	.007	PRE: <input checked="" type="checkbox"/>
				POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	138
#2	100	248
#3	100	135
#4	0	9
#5	100	109
#6	100	101
#7	251.2	269.7

NOZZLE Ø	A-11, 280
PITOT #	125A
BOX ID	17
GAMMA γ	0.9788
ΔH@	1.8708
PROBE ID	PL-10-2
SYSTEM ID	V-50-4, P-048-1, 44-17
FILTER ID	UNTAGGED

## **Appendix I**

### **EPA Methods 5 and 26A Raw Field Data**

## **Appendix I.1**

### **EPA Method 5/26A Raw Field Data: Unit 1 FF Outlet**

FACILITY: Veolia Pinellas TEST LOCATION: unit 1 outlet DATE: 04.09.13  
 TECHNICIAN MRW P<sub>BAR</sub> 30.02 POLLUTANT: HCl/PM RUN I.D.: U10.M26A.R.1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
F 5	0	905		313	.33	1.1	176.584	74	77	55	311	6
4	4			314	.33	1.1	180.0	75	77	55	312	6
3	8		-10	313	.45	1.5	183.5	76	77	54	312	7
2	12			313	.45	1.5	184.2	76	77	54	313	7
1	14			315	.40	1.3	186.9	76	77	58	310	7
E 5	20	<del>935</del> 936		312	.35	1.2	189.4	78	77	59	312	7
4	24	<del>930</del> 939		314	.37	1.2	191.7	81	80	58	311	7
3	28		-11	312	.42	1.4	194.3	81	80	59	311	7
2	32			313	.42	1.4	196.9	80	81	61	312	7
1	36			312	.40	1.3	199.5	84	80	60	312	7
D 5	40	<del>955</del> 956		315	.40	1.3	202.1	83	83	61	311	7
4	44			314	.42	1.4	204.5	84	83	60	312	7
3	48		-10	314	.45	1.5	207.0	84	82	62	313	7
2	52			313	.43	1.4	209.6	84	82	60	310	7
1	56			312	.42	1.4	212.2	85	82	61	312	7
C 5	60	<del>1014</del> 1026		313	.43	1.4	<del>214.945</del> 215.137	82	83	64	313	7
4	64			315	.44	1.5	217.5	82	84	62	310	7
3	68		-10	316	.44	1.5	220.3	82	81	61	311	7
2	72			315	.42	1.4	222.8	79	79	60	312	7
1	76			315	.42	1.4	225.4	79	78	60	312	7
B 5	80	<del>1046</del> 1047		316	.41	1.4	227.9	77	76	59	311	7
4	84			315	.42	1.4	230.5	77	76	59	311	7
3	88		-11	315	.42	1.4	233.0	78	77	60	312	7
2	92			317	.43	1.4	235.5	77	76	61	312	7
1	96			315	.40	1.3	238.0	77	76	60	311	7

CHAIN OF CUSTODY: 3-3

CONTAINER	SAMPLE I.D.	DESCRIPTION
	800	FILTER
	801	Fu Acthrn
	802	Acid Emgr
	803	S-6-1

LEAK CHECK:

VACUUM	15"	14"	15"			PITOT PRE: <input checked="" type="checkbox"/>
RATE	.010	.007	.005			POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	302
#2	100	250
#3	100	118
#4	100	97
#5	100	102
#6	250.2	272.5
#7		

NOZZLE Φ	C10 .280
PITOT #	319
BOX ID	4
GAMMA γ	1.0215
ΔH@	1.6942
PROBE ID	PL 9-7
SYSTEM ID	p4561/mu3-10/UA-12
FILTER ID	Q 12-42



FACILITY: Veolia Pinellas TEST LOCATION: Unit 1 outlet DATE: 04.09.13  
 TECHNICIAN MRW P<sub>BAR</sub> 30.04 POLLUTANT: HCL / Pm RUN I.D.: U10 - M20A - RZ

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A 5	0	1324		315	.43	1.3	254.215	79	81	64	311	6
4	4			315	.43	1.3	256.7	80	81	62	313	6
3	8		-10	315	.42	1.3	259.3	80	80	60	315	6
2	12			315	.42	1.3	261.8	81	80	59	313	6
1	16			313	.44	1.4	264.4	81	80	60	314	6
B 5	20	<del>1344</del> 1345		312	.44	1.4	267.0	82	80	62	313	6
4	24			314	.46	1.4	269.5	82	80	60	311	6
3	28		-12	313	.45	1.4	272.1	82	80	60	310	6
2	32			314	.46	1.4	275.0	82	80	59	312	6
1	36			330	.45	1.4	277.7	83	81	60	313	6
C 5	40	<del>1405</del> 1406		320	.43	1.3	280.5	83	82	61	310	6
4	44			320	.43	1.3	283.1	83	82	60	311	6
3	48		-10	318	.43	1.3	285.6	83	83	59	313	6
2	52			318	.42	1.3	288.2	83	82	61	312	6
1	56			320	.42	1.3	290.7	82	81	60	310	6
D 5	60	<del>1425</del> 1434		315	.45	1.4	<del>293.353</del> 293.430	82	81	63	311	6
4	64			314	.46	1.4	296.1	82	81	61	311	6
3	68		-11	315	.46	1.4	298.7	82	81	60	312	6
2	72			313	.45	1.4	301.3	82	81	59	312	6
1	76			313	.45	1.4	303.8	82	81	61	310	6
E 5	80	<del>1454</del> 1455		313	.40	1.3	306.7	81	80	60	311	6
4	84			314	.40	1.3	309.3	81	80	63	311	6
3	88		-11	313	.41	1.3	311.7	81	79	64	312	6
2	92			314	.43	1.3	314.2	81	79	63	313	6
1	96			315	.43	1.3	317.1	83	80	62	311	6

CHAIN OF CUSTODY:

K 3.1

LEAK CHECK:

PITOT

CONTAINER	SAMPLE I.D.	DESCRIPTION
	804	Filter
	805	Arbors
	806	Arbors Imps

VACUUM	15"	12"	12"			PRE:
RATE	.009	.006	.005			POST:

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	290
#2	100	246
#3	600	128
#4	100	102
#5	100	100
#6	251.0	273.5
#7		

NOZZLE Ø	C10 280
PITOT #	117
BOX ID	4
GAMMA γ	1.0215
ΔH@	1.6942
PROBE ID	PL 9-5
SYSTEM ID	U10-M20A/0412
FILTER ID	Q12-43





FACILITY: Pinellas County BRF  
Wesley Pinellas

TEST LOCATION: Unit 1 Outlet

DATE: 04.09.13

TECHNICIAN MEW P<sub>BAR</sub> 30.04

POLLUTANT: HCL/PM

RUN I.D.: U10 - M26A - R 3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
F 5	0	1622		314	.40	1.2	334.140	80	78	63	313	6
4	4			314	.45	1.4	336.7	81	79	60	312	6
3	8		-11	314	.45	1.4	339.3	80	79	60	313	6
2	12			316	.44	1.3	342.1	81	80	61	312	6
1	16			318	.49	1.5	344.7	81	80	60	312	6
E 5	20	<del>1642</del> 1643		315	.40	1.2	347.4	82	80	61	313	6
4	24			318	.43	1.3	350.0	82	80	62	311	6
3	28		-10	318	.43	1.3	352.6	82	80	60	311	6
2	32			319	.47	1.4	355.2	81	79	61	313	6
1	36			317	.45	1.4	357.9	81	79	61	312	6
D 5	40	<del>1703</del> 1704		317	.42	1.3	360.6	81	78	60	312	6
4	44			318	.46	1.4	363.2	81	79	61	312	6
3	48		-10	317	.46	1.4	365.8	81	79	61	313	6
2	52			317	.45	1.4	368.4	82	78	59	310	6
1	56			318	.46	1.4	371.2	82	79	60	312	6
C 5	60	<del>1724</del> 1731		315	.43	1.3	<del>374.800</del> 374.342	80	78	64	312	6
4	64			316	.43	1.3	377.0	80	79	60	312	6
3	68		-12	315	.46	1.4	379.5	80	79	60	313	6
2	72			315	.47	1.4	382.0	80	79	60	311	6
1	76			317	.45	1.4	384.6	81	79	59	312	6
B 5	80	<del>1751</del> 1752		316	.43	1.3	387.6	82	79	61	311	6
4	84			315	.43	1.3	390.1	82	80	62	312	6
3	88		-11	319	.45	1.4	392.8	82	80	63	312	6
2	92			319	.45	1.4	395.3	83	80	62	312	6
1	96			318	.46	1.4	397.9	83	80	61	310	6

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	808	FILTER
	809	Accum
	810	Imp
	811	S. bul

K=3.0

LEAK CHECK:

VACUUM	14"	12"	12"			PITOT PRE: <input checked="" type="checkbox"/>
RATE	.010	.008	.005			POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	328
#2	100	246
#3	100	116
#4	100	100
#5	100	100
#6	250.0	267.4
#7		

PITOT

NOZZLE Ø	C10 .280
PITOT #	319
BOX ID	4
GAMMA γ	1.0215
ΔH@	1.6942
PROBE ID	PL 9-7
SYSTEM ID	2056-1/NA510/UA 12
FILTER ID	Q 12-44



## **Appendix I.2**

### **EPA Method 5/26A Raw Field Data: Unit 2 FF Outlet**

FACILITY: Pineblas County RRF TEST LOCATION: Unit 2 Outlet DATE: 04.10.13  
 TECHNICIAN MLW P<sub>BAR</sub> 29.99 POLLUTANT: HCL/PM RUN I.D.: U20-M2GA-R 1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A5	0	845		295	.35	1.1	451.437	67	64	64	311	6
4	4	857		298	.40	1.3	453.8	69	65	60	311	6
3	8	869	-11	298	.40	1.3	454.9	69	65	60	313	6
2	12			295	.40	1.3	452.4	69	65	61	313	6
1	16			295	.42	1.3	459.9	71	66	60	311	6
B5	20	<del>907</del> 908		298	.43	1.3	463.6	71	66	59	312	6
4	24			293	.49	1.5	465.2	72	68	55	312	6
3	28		-12	293	.48	1.5	467.8	73	67	55	313	6
2	32			299	.48	1.5	470.4	73	67	56	312	6
1	36			297	.47	1.5	473.3	74	68	57	311	6
C5	40	<del>923</del> 924		295	.45	1.4	476.0	73	69	58	312	6
4	44			295	.45	1.4	478.6	73	70	59	312	6
3	48	<del>432</del> 940	-11	298	.45	1.4	481.2	73	71	56	313	6
2	52			295	.49	1.5	483.9	73	69	56	312	6
1	56			293	.49	1.5	486.7	74	70	57	311	6
D5	60	<del>949</del> 1004		295	.48	1.5	<del>489.540</del> 489.742	73	70	60	312	6
4	64			295	.49	1.5	492.4	74	71	60	313	6
3	68		-11	295	.47	1.5	495.0	74	71	60	311	6
2	72			296	.47	1.5	497.7	74	71	61	312	6
1	76			299	.44	1.4	500.6	75	71	62	313	6
E5	80	<del>1024</del> 1025		290	.47	1.5	503.3	76	70	61	311	6
4	84			291	.47	1.5	506.0	75	72	63	313	6
3	88	<del>1035</del> 1044	-12	293	.46	1.4	508.6	76	71	63	313	6
2	92	<del>1044</del> 1045		294	.47	1.5	511.5	78	73	60	311	6
1	96			295	.34	1.1	513.9	78	73	60	312	6

CHAIN OF CUSTODY:

3.1

CONTAINER	SAMPLE I.D.	DESCRIPTION
	816	Filter
	817	Acetone
	818	Impinger
	819	S.I.C

LEAK CHECK:

VACUUM	14"	12"	12"		PITOT PRE:
RATE	.007	.008	.005		POST: ✓

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	255
#2	100	205
#3	100	113
#4	100	100
#5	100	100
#6	250.4	269.8
#7		

NOZZLE Ø	C16 .280
PITOT #	117
BOX ID	4
GAMMA γ	1.0215
ΔH@	1.6942
PROBE ID	PL 9-5
SYSTEM ID	94561/NHS10/UA12
FILTER ID	Q 12-45



FACILITY: Pinellas County RRT TEST LOCATION: Unit 2 Outlet DATE: 04.10.13

TECHNICIAN MRW P<sub>BAR</sub> 29.53 POLLUTANT: HCL / PM RUN I.D.: V20 - MGA - R 2

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
F5	0120	1209		297	.33	1.0	530.465	80	76	64	311	5
4	4	<del>1212</del> 1222		298	.45	1.4	532.9	80	79	63	312	6
3	8		-11	298	.45	1.4	535.4	80	79	62	312	6
2	12			299	.49	1.5	538.1	80	78	60	311	6
1	16			298	.49	1.5	540.8	80	78	59	313	6
E5	20	<del>1231</del> 1240		295	.48	1.5	543.7	81	78	60	312	6
4	24			296	.49	1.5	546.4	82	79	61	312	6
3	28		-10	299	.49	1.5	549.1	83	79	59	311	6
2	32			297	.47	1.5	551.9	83	79	59	310	6
1	36			294	.35	1.1	554.7	83	79	60	302	6
D5	40	<del>1300</del> 1301		292	.49	1.5	557.1	84	80	62	311	6
4	44			296	.49	1.5	560.0	85	78	60	310	6
3	48		-11	295	.47	1.5	562.8	85	79	61	312	6
2	52			293	.46	1.4	565.5	85	79	60	311	6
1	56			297	.35	1.1	568.3	86	78	61	312	6
C5	60	<del>1321</del> 1324		296	.49	1.5	<del>570.850</del> 570.960	86	81	63	311	7
4	64			298	.49	1.5	573.6	86	82	63	312	7
3	68		-11	297	.48	1.5	576.3	86	82	62	311	7
2	72			298	.47	1.5	579.0	87	81	63	311	7
1	76			298	.33	1.0	581.9	86	82	61	310	6
B5	80	<del>1346</del> 1347		299	.50	1.6	584.3	87	82	63	312	7
4	84			301	.48	1.5	587.2	88	82	62	312	7
3	88		-10	300	.49	1.5	590.0	89	83	61	311	7
2	92			298	.42	1.3	592.8	89	84	60	312	7
1	96			297	.37	1.2	595.3	90	84	60	312	7

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	816	Filter
	817	Filter
	818	Imp
	819	Sub

LEAK CHECK:

VACUUM	15"	14"	12"			PITOT
RATE	.009	.007	.005			PRE: <input checked="" type="checkbox"/>
						POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	272
#2	100	214
#3	100	114
#4	100	100
#5	100	100
#6	250	271.5
#7		

NOZZLE Φ	C10 .280
PITOT #	319
BOX ID	4
GAMMA γ	1.0215
ΔH@	1.6942
PROBE ID	PL 9-7
SYSTEM ID	P4561 / W4810 / UA12
FILTER ID	Q 12-48



ISOKINETIC SAMPLING DATA SHEET

FACILITY: Pinnacles County BRF TEST LOCATION: Unit 2 Outlet DATE: 04.10.13

TECHNICIAN MW P<sub>BAR</sub> 29.95 POLLUTANT: HCl / Pm RUN I.D.: U20 - M 20A-R 3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME F <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A 5	0	1525		293	.49	1.5	611.600	94	90	63	312	6
4	4			298	.48	1.5	614.2	94	90	60	312	6
3	8		-10	297	.42	1.3	616.9	96	91	60	311	6
2	12			295	.40	1.3	619.5	96	91	61	312	6
1	16			296	.32	1.0	622.1	96	91	60	313	6
B 5	20	<del>1543</del> 1546		293	.47	1.5	624.4	98	92	62	313	6
4	24			293	.47	1.5	627.2	99	92	61	312	6
3	28		-12	295	.48	1.5	629.9	100	92	60	311	6
2	32			296	.40	1.2	632.7	100	93	60	312	6
1	36			294	.36	1.1	635.3	100	93	61	313	6
C 5	40	<del>1606</del> 1607		298	.49	1.5	637.6	102	95	62	312	7
4	44			296	.49	1.5	640.3	100	94	61	313	7
3	48		-11	297	.48	1.5	643.1	100	95	62	312	7
2	52			299	.44	1.4	645.9	96	92	63	311	6
1	56			297	.37	1.2	648.5	96	92	63	312	6
D 5	60	<del>1627</del> 1633		293	.47	1.5	<del>651.425</del> 651.550	94	89	64	313	7
4	64			293	.46	1.4	654.2	94	90	62	313	7
3	68		-11	295	.45	1.4	656.8	95	89	61	311	7
2	72			292	.45	1.4	659.4	95	88	60	312	7
1	76			292	.38	1.2	662.3	95	88	58	312	7
E 5	80	<del>1653</del> 1654		300	.49	1.5	665.0	96	90	63	311	7
4	84			300	.49	1.5	667.7	98	91	62	311	7
3	88		-10	298	.47	1.5	670.5	100	92	62	310	7
2	92			295	.43	1.3	673.2	101	93	60	310	7
1	96			295	.37	1.2	676.0	101	94	57	310	7

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	820	F.1hr
	821	FH Aachen
	822	Imp,
	823	S.6-1

LEAK CHECK:

VACUUM	15"	14"	12"		PITOT
RATE	.009	.008	.005		PRE: <input checked="" type="checkbox"/>
					POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	183
#2	100	234
#3	100	128
#4	100	108
#5	100	104
#6	250.5	274.6
#7		

NOZZLE Ø	C10 .280
PITOT #	117
BOX ID	4
GAMMA γ	1.0215
ΔH@	1.6942
PROBE ID	PL 9-5
SYSTEM ID	PU56-1/NA816/UA12
FILTER ID	Q 12-49





## **Appendix I.3**

### **EPA Method 5/26A Raw Field Data: Unit 3 FF Outlet**

ISOKINETIC SAMPLING DATA SHEET

FACILITY: Pinalos County RR TEST LOCATION: Unit 3 outfall DATE: 04.11.17

TECHNICIAN MRW P<sub>BAR</sub> 2937 POLLUTANT: HCL/PM RUN I.D.: U30 - M20A - R 1

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME F <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
F5	0	837		303	.45	1.4	725.336	74	70	63	312	6
4	4			305	.40	1.2	728.0	71	69	60	312	6
3	8		-11	310	.42	1.3	730.5	72	70	57	311	6
2	12			311	.43	1.3	733.1	72	70	57	311	6
1	16			308	.34	1.1	735.7	72	69	50	310	6
E5	20	<del>851</del> 852		318	.40	1.4	738.1	73	70	60	312	6
4	24			313	.41	1.3	740.6	75	71	57	312	6
3	28		-10	315	.41	1.3	743.2	75	71	57	311	6
2	32			305	.41	1.3	745.8	75	71	60	312	6
1	36			308	.35	1.1	748.4	76	71	59	312	6
D5	40	<del>918</del> 919		304	.44	1.4	750.8	76	73	60	311	6
4	44			305	.44	1.4	753.5	76	73	60	318	6
3	48		-10	305	.43	1.3	756.2	77	72	60	313	6
2	52			306	.40	1.2	758.8	78	73	61	313	6
1	56			304	.33	1.0	761.3	78	74	60	311	6
C5	60	<del>939</del> 940		305	.45	1.4	<del>763.808</del> 765.808	77	74	63	312	6
4	64	<del>947</del> 944		303	.45	1.4	<del>765.830</del> 766.7	77	75	62	312	6
3	68		-11	304	.44	1.4	769.4	78	75	62	311	6
2	72			305	.41	1.5	772.1	79	76	61	311	6
1	76			306	.30	1.1	774.7	78	75	62	312	6
B5	80	<del>1014</del> 1015		305	.43	1.3	777.1	79	75	63	312	6
4	84			306	.43	1.3	779.7	79	75	62	312	6
3	88		-11	305	.42	1.3	782.3	80	76	60	311	6
2	92			303	.41	1.3	784.9	79	76	61	310	6
1	96			303	.32	1.0	787.6	79	76	61	312	6

CHAIN OF CUSTODY: 3.1

CONTAINER	SAMPLE I.D.	DESCRIPTION
	824	F. ltr
	825	FH Analyzer
	826	Imps
	827	S. ltr

LEAK CHECK:

VACUUM	15"	13"	12"	13'	PITOT
RATE	.008	.007	.006	.005	PRE: <input checked="" type="checkbox"/>
					POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	305
#2	100	263
#3	100	121
#4	100	100
#5	100	104
#6	250	282.2
#7		

NOZZLE Φ	C10 .280
PITOT #	319
BOX ID	4
GAMMA γ	1.0215
ΔH@	1.6842
PROBE ID	PL 9-7
SYSTEM ID	pu361/NH810/4412
FILTER ID	Q 12-50



FACILITY: Pinnacles County RRF TEST LOCATION: Unit 3 outlet DATE: 04.11.13

TECHNICIAN MBW P<sub>BAR</sub> 2937 POLLUTANT: HCL / PM RUN I.D.: U30 - M26A - R 2

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME FT <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
A5	0	1145		303	.46	1.4	803.450	81	80	63	312	6
4	4			303	.46	1.4	806.1	81	80	62	312	6
3	8		-11	300	.44	1.4	808.8	81	80	62	311	6
2	12			301	.40	1.2	811.7	81	81	61	312	6
1	16			302	.36	1.1	814.1	82	81	60	312	6
B5	20	<del>1205</del> 1206		301	.43	1.3	816.5	82	80	61	313	6
4	24			303	.43	1.3	819.1	83	80	60	313	6
3	28		-11	301	.43	1.3	821.7	83	80	61	312	6
2	32			302	.41	1.3	824.3	84	80	60	312	6
1	36			301	.37	1.2	826.9	84	81	59	311	6
C5	40	<del>1226</del> 1227		301	.45	1.4	829.4	84	81	57	312	6
4	44			302	.44	1.4	832.1	85	81	59	312	6
3	48		-10	302	.44	1.4	834.8	85	82	59	312	6
2	52			302	.38	1.2	837.4	85	82	60	311	6
1	56			302	.38	1.2	839.9	85	82	61	311	6
D5	60	<del>1247</del> 1252		301	.46	1.4	<del>842.425</del> 842.627	86	83	63	312	6
4	64			301	.46	1.4	845.5	86	83	61	312	6
3	68		-11	302	.44	1.4	848.2	86	82	60	312	6
2	72			301	.37	1.2	851.0	86	83	60	311	6
1	76			300	.37	1.2	853.5	87	83	61	312	6
E5	80	<del>1312</del> 1313		302	.44	1.4	856.0	88	84	62	311	6
4	84			302	.44	1.4	858.7	88	84	61	313	6
3	88		-10	301	.43	1.3	861.2	88	85	60	313	6
2	92			302	.40	1.2	863.8	89	84	60	312	6
1	96			301	.35	1.1	866.4	88	84	60	312	6

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	828	Filter
	829	Acidline
	830	Imp 2
	831	Sub 1

LEAK CHECK:

VACUUM	13"	14"	12"			PITOT
RATE	.009	.009	.006			PRE: <input checked="" type="checkbox"/>
						POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	336
#2	100	243
#3	100	152
#4	100	106
#5	100	102
#6	250.0	272.6
#7		

NOZZLE Ø	210 .280
PITOT #	117
BOX ID	4
GAMMA γ	1.0215
ΔH@	1.6942
PROBE ID	PL 9-5
SYSTEM ID	PUK-1 / NAB10 / UA17
FILTER ID	Q 12-52



FACILITY: Pinnellas County PRF TEST LOCATION: Unit 3 Outlet DATE: 04.11.13

TECHNICIAN MRW P<sub>BAR</sub> 29-85 POLLUTANT: HCL / PM RUN I.D.: 030 - M26A - R 3

POINT	RUN TIME	TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME Ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	EXIT TEMP	FILTER TEMP.	METER VAC.
F5	0	1430		300	.45	1.4	882.264	91	89	63	311	7
4	4			304	.45	1.4	885.4	91	89	60	312	7
3	8		-11	302	.44	1.2	887.5	92	90	60	312	7
2	12			305	.41	1.2	890.0	94	92	59	311	7
1	16			305	.37	1.0	892.4	95	89	60	313	7
E5	20	1450		308	.44	1.2	894.7	94	89	60	313	7
4	24	1457		307	.43	1.2	896.9	94	88	59	312	7
3	28		-10	308	.42	1.2	899.4	96	90	60	311	7
2	32	1504		307	.38	1.1	901.8	96	90	61	313	7
1	36	1523		308	.36	1.0	904.9	96	90	62	311	7
D5	40	1533		305	.45	1.3	908.9	98	90	63	313	7
4	44	1535		305	.45	1.3	909.4	99	91	62	312	7
3	48		-11	306	.44	1.2	911.9	95	95	60	313	7
2	52			308	.44	1.2	914.6	96	95	61	313	7
1	56			307	.35	1.0	917.1	96	94	63	312	7
C5	60	1554		306	.46	1.3	919.757	95	92	63	311	7
4	64	1607		303	.44	1.2	922.2	94	91	62	313	7
3	68		-10	303	.43	1.2	924.7	95	91	60	313	7
2	72			301	.40	1.1	927.3	95	92	60	311	7
1	76			301	.39	1.1	929.6	95	92	59	312	7
B5	80	1622		304	.43	1.2	932.1	95	92	60	311	7
4	84	1623		305	.43	1.2	934.6	95	93	61	310	7
3	88		-10	305	.41	1.2	937.1	95	93	60	312	7
2	92			304	.41	1.2	938.6	95	93	59	312	7
1	96			307	.37	1.0	939.8	94	93	61	312	7

CHAIN OF CUSTODY: X 2.8

LEAK CHECK: X 2.8

PITOT

CONTAINER	SAMPLE I.D.	DESCRIPTION
	832	F.1tr
	833	Fu Archae
	834	F.1tr
	835	S.6el

VACUUM	15"	12"	14"		PRE: <input checked="" type="checkbox"/>
RATE	.010	.007	.006		POST: <input checked="" type="checkbox"/>

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	50	264
#2	100	292
#3	100	137
#4	100	104
#5	100	102
#6	250.0	272.3
#7		

NOZZLE Ø	B 16 .280
PITOT #	319
BOX ID	4
GAMMA Y	1.0215
ΔH@	1.6942
PROBE ID	PL 9-7
SYSTEM ID	PURGE-1/NR10/UA10
FILTER ID	Q 12 - 52 53

(50)





## **Appendix J**

### **EPA Methods 201A and 202 Raw Field Data**

## **Appendix J.1**

### **EPA Methods 201A and 202 Raw Field Data: Unit 1 FF Outlet**

FACILITY: Pinellas Co. RRF

TEST LOCATION: Unit 1 outlet

DATE: 4-10-13

TECHNICIAN: MSM  
30-99

PBAR: 29.97

POLLUTANT: Pm 2.5

RUN I.D.: U10 - M21A/202R 1

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft³	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.
A	1	1008	0		320	.47	.32	594.831	82	81	65	63	252	74	3
	2		1.96		329	.48		595.3	83	81	65	65	253	74	3
	3		3.96	-11	324	.46		596.0	84	81	65	65	253	75	3
	4		5.9		328	.45		596.7	84	81	63	62	250	74	3
	5		7.8		329	.48		597.3	84	81	60	59	252	73	3
B	1		9.8		319	.49		598.0	84	82	58	57	253	73	3
	2		11.8	-10	324	.47		598.7	84	82	58	56	251	72	3
	3		13.8		327	.49		599.4	84	82	58	55	254	72	3
	4		15.8		325	.46		600.0	84	82	59	56	251	73	3
	5		17.7		325	.45		600.6	84	82	59	57	252	73	3
C	1		19.6		321	.48		601.2	84	82	59	58	252	74	3
	2		21.6		327	.44		601.9	84	82	59	58	254	74	3
	3		23.5	-12	325	.46		602.6	84	82	60	58	250	74	3
	4		25.4		324	.48		603.2	84	82	61	58	253	74	3
	5		27.4		323	.45		603.9	84	82	61	59	252	75	3
D	1		29.3		325	.48		604.5	84	82	61	59	253	75	3
	2		31.3	-11	327	.54		605.2	84	81	60	60	254	75	3
	3		33.4		326	.50		605.9	83	81	60	60	255	77	3
	4		35.4		325	.48		606.6	83	81	62	60	254	77	3
	5		37.4		324	.47		607.3	83	81	62	60	252	77	3
E	1		39.4		326	.54		607.9	83	81	62	60	253	78	3
	2		41.5		326	.52		608.6	83	81	63	60	253	78	3
	3		43.6	-12	328	.48		609.3	84	81	64	60	253	78	3
	4		45.6		325	.51		610.0	84	81	64	61	253	78	3
	5		47.6		323	.50	.32	610.6	84	81	64	61	252	79	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4000	< 2.5 F.1kr
	4001	> Pm2.5 Rm
	4002	< Pm2.5 Rm
	4003	Aqueous
	4004	Organic
	4005	Cond. Pm Filter
	4006	2.6-1

LEAK CHECK:

VACUUM	14"	9"
RATE	.013	.008

PITOT

DWELL TIME POINT 1 = t <sub>i</sub>	1.96
t <sub>i</sub> /ΔP <sub>i</sub> = K	K = 2.85
Subsequent Dwell Times = K x √ΔP <sub>n</sub>	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	80
#2	0	0
#3	100	102
#4	250	260.5
#5		
#6		
#7		

NOZZLE Φ	AS .179
PITOT #	319
BOX ID	16
GAMMA γ	0.9910
ΔH@	1.7473
PROBE ID	P1-9-4
SYSTEM ID	P.6-2 VA-15 AMB-3
FILTER	12-38

FACILITY: Pinellas Co. RRF

TEST LOCATION: Unit 1 outlet

DATE: 4-10-13

TECHNICIAN: MSH

PBAR: 29.98

POLLUTANT: Pb 2.5

RUN I.D.: 410 - N011/262R 1

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft³	DGM TEMP. INLET	DGM TEMP. OUTLET	FILTER TEMP	COND TEMP	CPM FILTER TEMP	EXIT TEMP.	METER VAC.
F 1		49.6	2.0		328	.49	.32	611.3	83	81	253	64	79	62	3
2		51.6	2.0	-12	326	.48		612.0	83	81	254	65	80	62	3
3		53.6	2.0		325	.47		612.6	83	81	252	65	80	62	3
4		55.6	1.9		324	.45		613.2	83	81	250	65	80	63	3
5		57.5	2.0		319	.48	.32	613.8	83	81	251	65	80	62	3
	1104	59.5	-	-	-	-	-	614.437	-	-	-	-	-	-	-

FACILITY: Phonias Co. Ref

TEST LOCATION: Vmt 1 outlet

DATE: 4-10-13

TECHNICIAN: MS4 P<sub>BAR</sub> 29.98

POLLUTANT: Pm 2.5

RUN I.D.: U10 - MADA/DR 2

Range: 30-1.0

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.
A	1	12.11	0		314	.47	.31	615.264	82	82	63	58	248	72	3
	2		2.05		318	.49	.31	615.9	82	82	60	57	252	72	3
	3		4.1	-12	322	.46		616.6	82	82	60	54	252	72	3
	4		6.2		324	.46		617.3	83	82	61	54	252	73	3
	5		8.2		327	.45		618.0	83	82	61	54	252	73	3
B	1		10.2		325	.48		618.6	83	82	60	53	250	73	3
	2		12.3		323	.47		619.3	83	82	60	53	250	74	3
	3		14.3	-11	325	.49		620.0	83	82	58	54	252	74	3
	4		16.5		323	.46		620.7	83	82	58	54	252	74	3
	5		18.3		320	.46		621.3	83	82	58	54	252	74	3
C	1		20.3		327	.49		622.0	85	83	58	55	254	74	3
	2		22.4		326	.52		622.7	85	83	59	55	253	74	3
	3		24.6	-11	325	.48		623.1	86	84	61	56	255	74	3
	4		26.7		325	.43		624.1	86	84	61	56	252	75	3
	5		28.7		327	.41		624.8	88	84	63	57	251	75	3
D	1		30.6		325	.49		625.1	88	84	64	58	250	75	3
	2		32.7		327	.53		626.0	88	84	64	58	253	75	3
	3		34.9		326	.54		626.7	87	84	65	59	251	76	3
	4		37.1	-12	323	.47		627.5	87	86	65	60	253	77	3
	5		39.1		320	.44		628.1	87	86	65	60	252	77	3
E	1		41.1		324	.45		628.8	87	86	66	62	253	77	3
	2		43.1		325	.42		629.5	87	86	66	63	252	78	3
	3		45.0		327	.42		630.1	87	86	66	64	251	78	3
	4		46.9	-11	326	.46		630.7	88	86	65	64	252	78	3
	5		48.9		328	.49	.31	631.3	88	86	64	63	254	78	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4007	2.5 F14
	4008	2.5 R24
	4009	2.5 M11
	4010	Aqueous
	4011	Organic
	4012	Cond. Pm P. 14
	4013	S.W.C

LEAK CHECK:

VACUUM	15"	10"
RATE	.010	.008

PITOT

DWELL TIME POINT 1 = t <sub>1</sub>	2.05
t <sub>1</sub> /√ΔP <sub>1</sub> = K	K = 2.99
Subsequent Dwell Times = K x √ΔP <sub>n</sub>	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	93
#2	0	0
#3	100	98
#4	250.0	256.4
#5		
#6		
#7		

NOZZLE φ	AS .179
PITOT #	159
BOX ID	16
GAMMA γ	0.9910
ΔH@	1.7473
PROBE ID	PL-9-2
SYSTEM ID	P0-50-2 UA-15 P01B-3
FILTER	12-45



FACILITY: Phellas Co. RRF

TEST LOCATION: Unit 1 outlet

DATE: 4-10-13

TECHNICIAN: MSP  
30-1.0

P<sub>BAR</sub>: 29.96

POLLUTANT: Pm 2.5

RUN I.D.: V10 - M201A/202R3

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.
A	1	15:03	0		317	.47	.31	636.637	87	86	65	65	253	73	3
	2		2		310	.45		637.3	87	86	64	65	255	73	3
	3		4	1.9	-12	312	.43	637.9	85	85	62	64	254	73	3
	4		5.9	2.0		313	.46	638.5	86	85	61	62	251	74	3
	5		7.9	2.0		310	.45	639.2	86	85	60	58	252	74	3
B	1		9.9	2.1		316	.49	639.8	86	85	59	56	250	73	3
	2		12.0	2.1		309	.50	640.5	86	85	58	54	253	72	3
	3		14.1	2.0	-12	310	.47	641.2	86	85	58	54	251	72	3
	4		16.1	2.1		312	.49	641.8	87	86	59	55	254	73	3
	5		18.2	2.1		314	.50	642.5	87	86	59	55	255	73	3
C	1		20.3	2.1		308	.51	643.2	87	86	59	54	253	74	3
	2		22.4	2.1		311	.53	643.9	87	86	59	54	252	74	3
	3		24.5	2.0	-10	313	.46	644.5	87	86	59	54	251	74	3
	4		26.5	1.9		310	.42	645.1	88	86	60	55	253	74	3
	5		28.4	1.9		313	.40	645.8	88	86	60	57	252	75	3
D	1		30.3	1.9		312	.43	646.5	88	86	60	58	254	77	3
	2		32.2	2.0		314	.47	647.2	88	86	60	59	254	76	3
	3		34.2	2.0	-11	310	.48	647.8	88	86	61	59	255	77	3
	4		36.2	2.0		312	.45	648.5	88	86	61	59	252	77	3
	5		38.2	1.9		307	.44	649.1	88	86	61	59	252	77	3
E	1		40.1	2.0		313	.46	649.8	88	86	61	60	253	78	3
	2		42.1	2.0		315	.47	650.4	88	86	61	60	252	78	3
	3		44.1	1.9	-11	309	.44	651.1	89	87	62	60	253	79	3
	4		46.0	2.0		310	.45	651.7	89	87	62	60	251	79	3
	5		48.0	2.0		308	.45	652.4	89	87	62	61	250	79	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4014	2.5 Pm Filter
	4015	2 Pm 2.5 Rinse
	4016	2 Pm 2.5 Rinse
	4017	Aqueous
	4018	Organic
	4019	Cond. Pm Filter
	4020	5.6 μ

LEAK CHECK:

VACUUM	14"	10"
RATE	.007	.005

PITOT

DWELL TIME POINT 1 = t <sub>1</sub>	2.01
t <sub>1</sub> /√ΔP <sub>1</sub> = K	K = 293
Subsequent Dwell Times = K x √ΔP <sub>n</sub>	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	92
#2	0	0
#3	100	85
#4	250	2644
#5		
#6		
#7		

NOZZLE Ø	AS .179
PITOT #	319
BOX ID	16
GAMMA γ	0.9910
ΔH@	1.7475
PROBE ID	P1-9-21
SYSTEM ID	P1302
FILTER	D-416





## **Appendix J.2**

### **EPA Methods 201A and 202 Raw Field Data: Unit 2 FF Outlet**

FACILITY: Amelias Co. RR#

TEST LOCATION: Unit 2 outlet

DATE: 4-1-13

TECHNICIAN MSN  
24-097

PBAR 29.84

POLLUTANT: Pm 2.5

RUN I.D.: U20 - M<sup>201A/202</sup> - R 1

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.	
A	1	07:32	0	2.12		304	.38	.33	667.676	72	72	63	63	253	70	3
	2		2.1	2.2		304	.40	.34	668.3	72	72	63	63	252	70	3
	3		4.3	2.2		305	.43		669.1	73	72	63	61	253	70	3
	4		6.5	2.2	-10	305	.42		669.7	73	72	60	59	255	71	3
	5		8.7	2.3		301	.44		670.3	74	72	60	57	251	71	3
B	1		11	2.2		302	.45		670.0	74	72	58	56	253	71	3
	2		13.2	2.2		303	.40		670.7	74	72	57	56	252	71	3
	3		15.4	2.1	>9	302	.37		670.4	74	72	56	54	255	71	3
	4		17.5	2.1		301	.39		673.2	74	72	56	54	253	71	3
	5		19.6	2.1		302	.38		674.1	74	72	55	52	253	71	3
C	1		21.5	2.4		301	.47		674.8	74	72	55	52	251	71	3
	2		23.9	2.3	-10	302	.45		675.6	74	72	55	52	250	72	3
	3		26.2	2.2		301	.43		676.3	74	72	58	50	252	72	3
	4		28.4	2.2		302	.43		677.1	74	72	56	51	253	72	3
	5		30.6	2.2		301	.40		677.8	75	73	57	51	253	72	3
D	1		32.8	2.3		302	.46		678.6	75	73	57	52	251	72	3
	2		35.1	2.3		300	.44		679.3	75	73	57	52	253	73	3
	3		37.4	2.2		303	.43		680.1	77	74	57	52	251	73	3
	4		39.6	2.2	-10	302	.41		680.9	77	74	58	53	250	74	3
	5		41.8	2.2		304	.39		681.7	77	74	58	53	252	74	3
E	1		43.9	2.1		303	.45		682.4	77	74	58	54	250	75	3
	2		46.2	2.3		301	.42		683.2	77	74	58	55	251	75	3
	3		48.4	2.2	-10	302	.42		684.0	77	74	58	55	252	75	3
	4		50.6	2.2		303	.40		684.8	77	74	58	55	252	75	3
	5		52.8	2.3		301	.44	.33	685.6	77	75	58	55	251	75	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4021	2.5 Filtr
	4022	72.5 Rms
	4023	22.5 Rms
	4024	Aqueous
	4025	Organic
	4026	Cond. Pm Filter
	4027	Subl

LEAK CHECK:

VACUUM	15"	11"
RATE	.012	1008

PITOT

DWELL TIME POINT 1 = t <sub>1</sub>	2.12
t <sub>1</sub> /ΔP <sub>1</sub> = K	K = 3.43
Subsequent Dwell Times = K x √ΔP <sub>n</sub>	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	90
#2	0	0
#3	100	93
#4	257.0	257.0
#5		
#6		
#7		

NOZZLE Φ	AB 779 .19 (2)
PITOT #	319
BOX ID	16
GAMMA γ	0.9410
ΔH@	1.7473
PROBE ID	PL-941
SYSTEM ID	PL-941-VA-15-PM13-3
FILTER	10-47



FACILITY: Pinedale Co. RRF

TEST LOCATION: Unit 2 outlet

DATE: 4-1-13

TECHNICIAN MSM  
29-96

P<sub>BAR</sub> 29.86

POLLUTANT: Pm 2.5

RUN I.D.: 020 - M <sup>201A</sup> 202 - R 2

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.
A	1	0	1.9		300	.38	.31	<del>641.745</del> 642.757	77	77	62	60	251	72	3
	2	1.9	2.1		302	.47		643.4	79	78	64	60	252	72	3
	3	4.0	2.2		303	.49		644.0	79	79	62	58	250	73	3
	4	6.2	2.0	-9	303	.44		644.8	79	78	60	58	251	73	3
	5	8.2	2.0		302	.41		645.6	79	78	60	57	250	73	3
B	1	10.2	2.0		301	.43		646.2	80	79	60	57	250	73	3
	2	12.2	2.0		301	.43		646.8	80	79	60	56	250	73	3
	3	14.2	2.0	-10	302	.44		647.4	80	78	60	55	252	73	3
	4	16.2	2.1		301	.46		648.1	81	79	59	55	252	73	3
	5	18.3	2.0		302	.42		648.8	81	79	59	55	252	73	3
C	1	20.3	2.1		300	.45		649.4	81	79	58	53	250	74	3
	2	22.4	2.0		302	.42		700.1	82	79	58	53	251	74	3
	3	24.4	2.0	-10	303	.42		700.8	82	79	58	53	251	74	3
	4	26.4	2.1		301	.46		701.4	82	79	58	54	253	74	3
	5	28.5	1.9		301	.40		702.1	83	80	59	55	253	75	3
D	1	30.4	2.1		304	.47		702.8	83	80	59	55	252	76	3
	2	32.5	2.1	-11	301	.45		703.5	83	80	59	55	250	77	3
	3	34.6	2.1		303	.48		704.2	83	81	60	57	254	78	3
	4	36.7	2.0		304	.42		704.9	83	81	60	57	250	78	3
	5	38.7	2.0		302	.41		705.6	83	81	60	57	250	78	3
E	1	40.7	1.9		305	.40		706.3	83	81	60	58	251	78	3
	2	42.6	1.9		303	.38		707.0	84	81	61	58	251	78	3
	3	44.5	2.0	-10	303	.41		707.6	84	81	61	58	253	79	3
	4	46.5	2.0		301	.43		708.2	84	81	62	59	252	79	3
	5	48.5	2.1		300	.45	.31	708.9	84	82	62	59	252	79	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4028	2.5 Filter
	4029	7.25 Rinse
	4030	2.5 Rinse
	4031	Aqueous
	4032	Organic
	4033	Cond. Pm Filter
	4034	Subl

LEAK CHECK:

VACUUM	14"	9"
RATE	1013	1006

PITOT

DWELL TIME POINT 1 = t <sub>1</sub>	1.91
$t_1/\Delta P_1 = K$	K=308
Subsequent Dwell Times = K x $\sqrt{\Delta P_n}$	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	81
#2	0	0
#3	100	88
#4	250.5	263.1
#5		
#6		
#7		

NOZZLE Φ	AS .174
PITOT #	754 314
BOX ID	16
GAMMA γ	0.9910
ΔH@	1.7773
PROBE ID	<del>P150-2</del> P150-2
SYSTEM ID	P150-2 UA-15-PH153
FILTER	12-47



FACILITY: Pinellas Co. RRF

TEST LOCATION: Unit 2 outlet

DATE: 4-11-13

TECHNICIAN MSH  
29-96

P<sub>BAR</sub> 29.87

POLLUTANT: Pm 2.5

RUN I.D.: 020 - M<sup>201A</sup> 202-R 3

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.
A	1	12.08	0		302	.38	.31	718.174	86	84	66	63	251	75	3
	2		1.88		303	.40		718.7	87	84	65	61	254	75	3
	3		3.8	-10	302	.42		719.4	87	84	64	60	253	75	3
	4		5.8		304	.44		720.0*	86	84	62	58	252	75	3
	5		7.8		302	.43		720.7	86	84	59	56	254	75	3
B	1		9.8		302	.44		721.4	86	84	59	56	254	75	3
	2		11.9		309	.42		722.1	86	84	57	55	253	75	3
	3		13.9		310	.47		722.8	86	84	57	55	250	76	3
	4		16.0	-11	307	.41		723.5	87	84	55	51	253	78	3
	5		17.9		303	.43		724.1	87	85	55	51	254	78	3
C	1		19.9		304	.45		724.8	87	85	58	51	253	78	3
	2		21.9		303	.46		725.4	87	85	56	51	255	78	3
	3		23.0	-11	304	.43		726.1	87	85	57	52	255	78	3
	4		26.0		304	.42		726.8	88	85	57	52	253	78	3
	5		28.0		303	.40		727.5	88	85	58	52	255	78	3
D	1	(MSH)	29.9	<del>2.0</del>	305	.51		728.2	88	85	58	52	252	79	3
	2		32.1		303	.48		728.9	88	85	58	52	255	79	3
	3		34.2		306	.45		729.6	88	85	58	52	251	79	3
	4		36.2	-9	303	.44		730.3	89	86	59	53	253	79	3
	5		38.2		300	.46		731.0	89	86	60	54	255	79	3
E	1		40.3		302	.47		731.7	89	86	60	56	255	79	3
	2		42.4		305	.52		732.4	88	86	60	56	251	79	3
	3		44.6	-10	307	.45		733.1	88	86	61	57	250	80	3
	4		46.6		308	.44		733.7	88	86	61	57	250	81	3
	5		48.6		305	.40	.31	734.4	88	86	62	58	253	81	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4035	2.5 Filter
	4036	72.5 Acetone
	4037	2.5 Acetone
	4038	Aqueous
	4039	Organic
	4040	Condensation Filter
	4041	S. 6.1

LEAK CHECK:

VACUUM	14"	10
RATE	.009	.007

PITOT

DWELL TIME POINT 1 = t <sub>1</sub>	1.88
t <sub>1</sub> /ΔP <sub>1</sub> = K	K=3.04
Subsequent Dwell Times = K x ΔP <sub>n</sub>	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	77
#2	0	1
#3	100	96
#4	250.0	261.3
#5		
#6		
#7		

NOZZLE Φ	AS .179
PITOT #	319
BOX ID	16
GAMMA γ	0.9910
ΔH@	1.7473
PROBE ID	PL 9-4
SYSTEM ID	P <sub>0</sub> -30-2
FILTER	Q-49



## **Appendix J.3**

### **EPA Methods 201A and 202 Raw Field Data: Unit 3 FF Outlet**



FACILITY: Pinellas Co. RRF

TEST LOCATION: Unit 3 outlet

DATE: 4-9-13

TECHNICIAN MSTH

PBAR 30.04

POLLUTANT: Pm 2.5

RUN I.D.: 030 - M<sup>201A</sup>/<sub>202</sub>-R 1

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.
A 1	1156	0	2.0		303	.55	.35	517.799	75	75	66	59	252	72	3
2		2.0	2.0		304	.53		518.4	78	78	59	57	253	74	3
3		4.0	1.9	-12	309	.52		519.1	82	81	57	55	253	75	3
4		5.9	1.9		310	.50		519.7	83	81	58	54	252	74	3
5		7.8	1.9		310	.51		520.3	83	81	58	55	252	77	3
B 1		9.7	2.0		308	.56		520.9	83	81	57	55	255	77	3
2		11.7	1.9		302	.51		521.5	84	82	57	56	257	77	3
3		13.6	1.9	-13	310	.52		522.2	84	82	57	55	257	77	3
4		15.5	1.9		316	.54		522.9	84	82	56	56	255	77	3
5		17.4	2.0		320	.53		523.6	85	82	56	55	252	76	3
C 1		19.4	1.9		312	.50		524.2	85	82	57	55	252	75	3
2		21.3	1.9		310	.52		524.8	85	82	58	56	252	75	3
3		23.2	2.0		315	.55		525.4	85	83	59	57	254	76	3
4		25.2	1.9	-12	308	.49		526.0	86	83	59	57	256	76	3
5		27.1	2.0		307	.57		526.6	86	83	60	57	255	75	3
D 1		29.1	1.9		310	.50		527.2	86	83	62	58	255	75	3
2		31.0	1.8		313	.47		527.8	86	83	61	58	254	75	3
3		32.8	1.9		308	.52		528.4	87	83	61	57	255	76	3
4		34.7	1.8	-11	307	.46		529.0	87	83	61	57	255	76	3
5		36.5	1.9		306	.50		529.6	87	83	61	57	256	77	3
E 1		38.4	1.9		310	.48		530.2	87	83	61	58	256	76	3
2		40.3	2.0		312	.54		530.9	87	83	62	58	257	76	3
3		42.3	1.9		314	.52		531.5	87	83	62	59	257	75	3
4		44.2	2.0	-12	314	.57		532.1	87	83	62	59	255	74	3
5		46.2	1.9		310	.53	-.35	532.7	87	84	62	59	252	74	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4042	2.5 Filter
	4043	72.5 Rinse
	4044	2.5 Rinse
	4045	Aqueous
	4046	organic
	4047	Cond. PMF, etc

LEAK CHECK:

VACUUM	15"	12"
RATE	.011	.007

PITOT

DWELL TIME POINT 1 = t <sub>1</sub>	2.00
t <sub>1</sub> /ΔP <sub>1</sub> = K	K = 2.69
Subsequent Dwell Times = K x √ΔP <sub>n</sub>	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	86
#2	0	10
#3	100	39 (50)
#4	250.5	262.7 (250)
#5		
#6		
#7		

NOZZLE Φ	A5 .179
PITOT #	319
BOX ID	16
GAMMA γ	0.9910
ΔH@	1.74173
PROBE ID	PL-9-4
SYSTEM ID	Pm-2.5 UA-15-PMHS-3
FILTER	12-35



FACILITY: Pineellas Co. RRF

TEST LOCATION: Unit 3 outlet

DATE: 4-9-13

TECHNICIAN MSM  
29-97

P<sub>BAR</sub> 30.04

POLLUTANT: Pm 2.5

RUN I.D.: V30 - M201A R2

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.
A 1	1408	0	2.05		298	.55	.31	544.278	92	88	68	64	254	79	3
2		2.0	2.0		299	.52		544.8	93	89	64	64	252	80	3
3		4.0	2.0	-13	301	.56		545.41	93	92	63	61	250	78	3
4		6.0	2.0		303	.51		546.0	93	92	62	60	254	77	3
5		7.9	1.9		309	.47		546.6	94	91	60	57	252	75	3
B 1		9.9	2.0		313	.54		547.2	93	91	60	56	252	73	3
2		11.8	1.9		309	.51		547.8	94	91	60	55	253	72	3
3		13.7	2.0	-11	310	.55		548.4	94	91	59	53	252	70	3
4		15.7	2.0		309	.53		549.0	94	91	58	52	250	68	3
5		17.7	2.0		307	.50		549.6	94	92	58	52	252	69	3
C 1		19.7	1.9		309	.49		550.3	94	92	59	53	252	70	3
2		21.6	2.1		312	.57		550.9	94	92	59	53	250	70	3
3		23.7	2.0	-12	313	.50		551.5	94	91	60	54	250	71	3
4		25.7	1.9		309	.48		552.1	94	91	61	54	250	71	3
5		27.6	1.9		311	.48		552.7	94	92	61	55	254	72	3
D 1		29.5	1.9		314	.46		553.3	94	91	61	57	255	72	3
2		31.4	2.0		317	.52		553.9	94	91	61	57	254	72	3
3		33.4	2.0	-11	314	.53		554.5	94	91	61	58	252	72	3
4		35.4	2.0		309	.50		555.2	93	91	62	58	251	74	3
5		37.4	2.0		309	.52		555.9	93	91	62	59	252	74	3
E 1		39.4	2.0		311	.54		556.5	93	91	61	59	250	75	3
2		41.4	2.0		310	.52		557.1	93	91	62	60	252	75	3
3		43.4	1.9	-12	308	.49		557.8	93	91	62	60	250	76	3
4		45.3	2.0		309	.51		558.4	93	91	63	61	250	76	3
5		47.3	2.0		305	.50	.31	559.0	93	90	63	61	252	76	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4049	22.5 F. Hr
	4050	72.5 Rinse
	4051	22.5 Rinse
	4052	Aqueous
	4053	Organic
	4054	Cond. Filter
	4055	Subl

LEAK CHECK:

VACUUM	14"	10"
RATE	.013	.0

PITOT

DWELL TIME POINT 1 = t <sub>1</sub>	2.05
t <sub>1</sub> /√ΔP <sub>1</sub> = K	K=2.76
Subsequent Dwell Times = K x √ΔP <sub>n</sub>	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	72
#2	0	10
#3	100	94
#4	250.0	264.8
#5		
#6		
#7		

NOZZLE Ø	AS .179
PITOT #	319
BOX ID	16
GAMMA γ	0.9910
ΔH@	1.7473
PROBE ID	<del>PL-9-4</del> 9-2
SYSTEM ID	Pu-50-2 UA-15 PMHS-3
FILTER	D-36



FACILITY: Pinellas Co. RRF

TEST LOCATION: Unit 3 outlet

DATE: 4-9-13

TECHNICIAN: MGM  
2A-647

PBAR: 30.02

POLLUTANT: Pm 2.5

RUN I.D.: U30 - M201A/202-R3

POINT	TIME	RUN TIME	DWELL TIME	STATIC	STACK TEMP.	STACK ΔP	METER ΔH	DGM VOLUME ft <sup>3</sup>	DGM TEMP. INLET	DGM TEMP. OUTLET	COND TEMP	EXIT TEMP	FILTER TEMP	CPM FILTER TEMP.	METER VAC.
A 1	1638	0	2.07		301	.55	.31	565.211	93	93	67	67	252	80	3
2		2.0	2.0		302	.53	.31	565.9	97	94	64	63	253	77	3
3		4.0	2.0		300	.50	.31	566.4	96	93	62	60	251	74	3
4		6.0	2.0	-12	300	.50		567.0	96	93	62	60	250	74	3
5		8.0	1.9		305	.48		567.7	97	93	60	58	252	73	3
B 1		9.9	2.1		303	.57		568.3	95	93	60	57	254	73	3
2		12.0	2.0		304	.53		569.0	94	93	59	55	251	71	3
3		14.0	2.0	-11	309	.51		569.6	94	93	59	55	252	71	3
4		16.0	2.0		311	.50		570.2	94	93	59	55	253	70	3
5		18	1.9		314	.46		570.9	94	93	58	55	253	70	3
C 1		19.9	1.8		307	.43		571.5	94	92	57	54	252	70	3
2		21.7	2.0		313	.50		572.1	94	92	57	54	252	71	3
3		23.7	2.0	-11	317	.49		572.7	94	92	57	54	253	71	3
4		25.7	1.9		315	.44		573.4	93	92	56	54	252	72	3
5		27.6	2.0		313	.49		574.0	93	92	56	55	254	72	3
D 1		29.6	2.1		306	.57		574.7	94	91	58	56	252	72	3
2		31.7	2.0		311	.53		575.3	94	91	58	56	252	72	3
3		33.7	2.0	-13	310	.53		576.0	94	91	58	57	254	72	3
4		35.7	2.0		308	.50		576.6	94	91	59	57	251	73	3
5		37.7	2.0		309	.51		577.3	94	91	60	58	252	74	3
E 1		39.7	2.1		302	.54		577.9	92	90	60	58	251	74	3
2		41.8	2.1		309	.58		578.6	92	90	60	58	252	75	3
3		43.9	2.0	-12	312	.53		579.2	92	90	61	58	252	75	3
4		45.9	2.0		310	.50		579.9	92	90	62	59	254	75	3
5		47.9	1.9		308	.46	.31	580.6	92	90	62	59	254	77	3

CHAIN OF CUSTODY:

CONTAINER	SAMPLE I.D.	DESCRIPTION
	4056	2.5 Filter
	4057	2.5 Rinse
	4058	2.5 Rinse
	4059	Aqueous
	4060	Organic
	4061	Cond. Pm Filter
	4062	5.0 μ

LEAK CHECK:

VACUUM	16"	12"
RATE	.008	.006

PITOT

DWELL TIME POINT 1 = t <sub>1</sub>	2.07
t <sub>1</sub> /√ΔP <sub>1</sub> = K	K = 2.79
Subsequent Dwell Times = K × √ΔP <sub>n</sub>	

IMPINGER CONTENTS:

IMPINGER	INITIAL	FINAL
#1	0	100
#2	0	0
#3	100	90
#4	250.4	268.4
#5		
#6		
#7		

NOZZLE φ	AS .179
PITOT #	319
BOX ID	16
GAMMA γ	0.9910
ΔH@	1.7473
PROBE ID	P2-9-4
SYSTEM ID	P2-50-2 VA-15 PMS-3
FILTER	21-37



## **Appendix K**

### **EPA Methods 9 and 22 Raw Field Data**

## **Appendix K.1**

### **EPA Method 9 Raw Field Data: Unit 1 Stack**



# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9      203A      203B      Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page 1 of 1  
 Continued on VEO Form Number \_\_\_\_\_  
110-M9-R1

Company Name: PINELLAS COUNTY RCF  
 Facility Name: \_\_\_\_\_  
 Street Address: \_\_\_\_\_  
 City: CLEARWATER State: FL Zip: \_\_\_\_\_


Process: Municipal Waste in Unit # 1 Operating Mode: NORMAL  
 Control Equipment: WAGHOUSE Operating Mode: NORMAL

Describe Emission Point:  
SOUTHERN STACK PROTRUDING FROM THE ANNULUS.  
 Height of Emis. Pt. Start 200 End 200 Height of Emis. Pt. Rel. to Observer Start 200 End 200  
 Distance to Emis. Pt. Start 800 End 800 Direction to Emis. Pt. (Degrees) Start 270 End 270

Vertical Angle to Obs. Pt. Start 8 End SAME Direction to Obs. Pt. (Degrees) Start 270 End 270  
 Distance and Direction to Observation Point from Emission Point Start SAME End SAME

Describe Emitters:  
 Start NONE End NONE Water Droplet Pume: \_\_\_\_\_  
 Emission Color: \_\_\_\_\_ Attached  Detached  Nonrefl

Describe Pume Background:  
 Start SKY End SAME Sky Conditions: \_\_\_\_\_  
 Background Color: \_\_\_\_\_ Wind Speed: \_\_\_\_\_  
 Start GRAY End SAME Start OVERCAST End SAME Wind Direction: \_\_\_\_\_  
 Start 9 MPH End 14 MPH Start S End SW  
 Ambient Temp.: \_\_\_\_\_ Wet Bulb Temp.: \_\_\_\_\_ RH Percent: \_\_\_\_\_  
 Start 77 End 78 Start 73 End 86



Additional Information:  
NONE

Min	Observation Date				Min	Time Zone				Start Time				End Time			
	0	15	30	45		0	15	30	45	0	15	30	45	0	15	30	45
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0	
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0	
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0	
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0	
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0	
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0	
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0	
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0	
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0	
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0	
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0	
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0	
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0	
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0	
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0	
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0	
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0	
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0	
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0	
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0	
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0	
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0	
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0	
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0	
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0	
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0	
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0	
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0	

Observer's Name (Print): JAMES STUTZ  
 Observer's Signature: [Signature] Date: 4-12-13  
 Organization: ACG  
 Certified by: ETA Date: \_\_\_\_\_

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9      203A      203B      Other: \_\_\_\_\_

Company Name: **PINELLAS COUNTY RRF**  
 Facility Name: \_\_\_\_\_  
 Street Address: \_\_\_\_\_  
 City: **CLEARWATER**      State: **FL**      Zip: \_\_\_\_\_


Process: **MUNICIPAL WASTE PLANT**      Unit #: **1**      Operating Mode: **NORMAL**  
 Control Equipment: **BAGHOUSE**      Operating Mode: **NORMAL**

Describe Emission Point:  
**SOUTHERN STACK PROTRUDING FROM THE ANNUALS**  
 Height of Emis. Pt. Start **200** End **200**      Height of Emis. Pt. Rel. to Observer Start **200** End **200**  
 Distance to Emis. Pt. Start **800** End **800**      Direction to Emis. Pt. (Degrees) Start **270** End **270**

Vertical Angle to Obs. Pt. Start **5** End **5**      Direction to Obs. Pt. (Degrees) Start **270** End **270**  
 Distance and Direction to Observation Point from Emission Point Start **SAME** End **SAME**

Describe Emissions:  
 Start **NONE** End **NONE**      Water Droplet Plume Attached  Detached  None   
 Emission Color Start **N/A** End **N/A**

Describe Plume Background:  
 Start **SKY** End **SAME**      Sky Conditions Start **OVERCAST** End **SAME**  
 Background Color Start **GRAY** End **SAME**      Wind Direction Start **SW** End **SW**  
 Wind Speed Start **9 MPH** End **14 MPH**      Wet Bulb Temp. Start **71**      RH Percent End **84**  
 Ambient Temp. Start **78** End **79**



Longitude: \_\_\_\_\_ Latitude: \_\_\_\_\_ Direction: \_\_\_\_\_  
 Additional Information: **NONE**

Form Number: \_\_\_\_\_ Page: **1** of **1**  
 Continued on VEO Form Number: **1210-M9-R0**

Min	Observation Date				Min	Time Zone				Start Time				End Time			
	0	15	30	45		0	15	30	45	0	15	30	45	0	15	30	45
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0	0
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0	0
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0	0
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0	0
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0	0
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0	0
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0	0
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0	0
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0	0
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0	0
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0	0

Observer's Name (Print): **JAMES STUIZ**  
 Observer's Signature: \_\_\_\_\_ Date: **4-12-13**  
 Organization: **ACG**  
 Certified by: **EPA** Date: \_\_\_\_\_

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9      203A      203B      Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page 1 of 1  
 Continued on VEO Form Number U10-M9-RT

Company Name: PINELLAS COUNTY RLF  
 Facility Name \_\_\_\_\_  
 Street Address \_\_\_\_\_  
 City CLEARWATER State FL Zip \_\_\_\_\_


Process Municipal WASTE EN Unit # 1 Operating Mode NORMAL  
 Control Equipment BOGHOUSE Operating Mode NORMAL

Describe Emission Point  
Southern Stack protruding from  
the annulus  
 Height of Emis. Pt. Start 200 End 200 Height to Emis. Pt. Rel. to Observer Start 200 End 200  
 Distance to Emis. Pt. Start 800 End 600 Direction to Emis. Pt. (Degrees) Start 270 End 270

Vertical Angle to Obs. Pt. Start 8 End 8 Direction to Obs. Pt. (Degrees) Start 270 End 270  
 Distance and Direction to Observation Point from Emission Point Start SAME End SAME

Describe Emissions  
 Start NONE End NONE  
 Emission Color Start N/A End N/A  
 Water Droplet Plume Attached  Detached  None

Describe Plume Background  
 Start SKY End SAME  
 Background Color Start Gray End SAME Sky Conditions Start VELOCIT End SAME  
 Wind Speed Start 14 mph End 16 mph Wind Direction Start SW End SW  
 Ambient Temp. Start 79 End 80 Wet Bulb Temp. Start 75 RH Percent 82



Longitude \_\_\_\_\_ Latitude \_\_\_\_\_ Declination \_\_\_\_\_

Additional Information  
NONE

Min	Observation Date				Min	Time Zone				Start Time				End Time			
	0	15	30	45		0	15	30	45	0	15	30	45	0	15	30	45
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0	
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0	
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0	
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0	
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0	
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0	
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0	
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0	
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0	
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0	
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0	
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0	
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0	
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0	
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0	
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0	
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0	
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0	
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0	
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0	
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0	
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0	
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0	
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0	
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0	
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0	
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0	
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0	

Observer's Name (Print) JAMES STULTZ  
 Observer's Signature [Signature] Date 4-10-13  
 Organization ACG  
 Certified by ETA Date \_\_\_\_\_

## **Appendix K.2**

### **EPA Method 9 Raw Field Data: Unit 2 Stack**

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 (Method 9) 203A 203B Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page \_\_\_\_\_ of \_\_\_\_\_  
 Continued on VEO Form Number 129-62-R1 IAW 120-69-R1

Company Name \_\_\_\_\_  
 Facility Name Pinellas Co. RRF  
 Street Address \_\_\_\_\_  
 City St. Petersburg State FL Zip \_\_\_\_\_

Observation Date 4-10-13 Time Zone EST Start Time 0851 End Time 0951

Process Waste Incinerator Unit # 2 Operating Mode \_\_\_\_\_  
 Control Equipment Baghouse Operating Mode \_\_\_\_\_

Min	Sec				Min	Sec			
	0	15	30	45		0	15	30	45

Describe Emission Point  
Amulus w/ 3 stacks. Testing observing  
Unit 2 Stack  
 Height of Emiss. Pt. Start 260' End \_\_\_\_\_ Height of Emiss. Pt. Rel. to Observer Start 240' End 240'  
 Distance to Emiss. Pt. Start 300 yds End 300 yds Direction to Emiss. Pt. (Degrees) Start SE 162° End \_\_\_\_\_


1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0

Vertical Angle to Obs. Pt. Start 10° End \_\_\_\_\_ Direction to Obs. Pt. (Degrees) Start SE 162° End SE 162°  
 Distance and Direction to Observation Point from Emission Point Start 0' End \_\_\_\_\_

31	0	0	0	0	0	0	0	0	0
32	0	0	0	0	0	0	0	0	0
33	0	0	0	0	0	0	0	0	0
34	0	0	0	0	0	0	0	0	0
35	0	0	0	0	0	0	0	0	0
36	0	0	0	0	0	0	0	0	0
37	0	0	0	0	0	0	0	0	0
38	0	0	0	0	0	0	0	0	0
39	0	0	0	0	0	0	0	0	0
40	0	0	0	0	0	0	0	0	0
41	0	0	0	0	0	0	0	0	0
42	0	0	0	0	0	0	0	0	0
43	0	0	0	0	0	0	0	0	0
44	0	0	0	0	0	0	0	0	0
45	0	0	0	0	0	0	0	0	0
46	0	0	0	0	0	0	0	0	0
47	0	0	0	0	0	0	0	0	0
48	0	0	0	0	0	0	0	0	0
49	0	0	0	0	0	0	0	0	0
50	0	0	0	0	0	0	0	0	0
51	0	0	0	0	0	0	0	0	0
52	0	0	0	0	0	0	0	0	0
53	0	0	0	0	0	0	0	0	0
54	0	0	0	0	0	0	0	0	0
55	0	0	0	0	0	0	0	0	0
56	0	0	0	0	0	0	0	0	0
57	0	0	0	0	0	0	0	0	0
58	0	0	0	0	0	0	0	0	0
59	0	0	0	0	0	0	0	0	0
60	0	0	0	0	0	0	0	0	0

Describe Emissions Start N/A End N/A Water Droplet Plume \_\_\_\_\_  
 Emission Color Start N/A End N/A Attached  Detached  None

Describe Plume Background Start Skyl End Skyl Sky Conditions Start Clear End Clear  
 Background Color Start Blue End \_\_\_\_\_ Wind Direction Start E End E  
 Wind Speed Start 9 mph End ~9 mph Wet Bulb Temp. Start 64 RH Percent 97%  
 Ambient Temp. Start 65 End \_\_\_\_\_



50	0	0	0	0	0	0	0	0	0
51	0	0	0	0	0	0	0	0	0
52	0	0	0	0	0	0	0	0	0
53	0	0	0	0	0	0	0	0	0
54	0	0	0	0	0	0	0	0	0
55	0	0	0	0	0	0	0	0	0
56	0	0	0	0	0	0	0	0	0
57	0	0	0	0	0	0	0	0	0
58	0	0	0	0	0	0	0	0	0
59	0	0	0	0	0	0	0	0	0
60	0	0	0	0	0	0	0	0	0

Longitude \_\_\_\_\_ Latitude \_\_\_\_\_ Declination \_\_\_\_\_

Observer's Name (Print) Mike Henry  
 Observer's Signature \_\_\_\_\_ Date 4-10-13  
 Organization Air Compliance Group  
 Certified by ETS Date 3-2013

Additional Information \_\_\_\_\_

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method (Check One)  
 Method 9    203A    2038    Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page 1 of 1  
 Continued on VEO Form Number U20-M9-R1

Company Name  
Pineelles County PRF

Facility Name \_\_\_\_\_

Street Address \_\_\_\_\_

City CLEARWATER State FL Zip \_\_\_\_\_

Process Municipal WASTE W Unit # 2 Operating Mode NORMAL

Control Equipment BagHouse Operating Mode NORMAL

Describe Emission Point  
NORTHERN STACK PROTRUDING FROM THE ANNULUS

Height of Emiss. Pt.  
Start 200 End 200 Height of Emiss. Pt. Rel. to Observer  
Start 200 End 200

Distance to Emiss. Pt.  
Start 800 End 800 Direction to Emiss. Pt. (Degrees)  
Start 270 End 270

Vertical Angle to Obs. Pt.  
Start 8 End 8 Direction to Obs. Pt. (Degrees)  
Start 270 End 270

Distance and Direction to Observation Point from Emission Point  
Start SAME End SAME

Describe Emissions  
Start NONE End NONE


Emission Color  
Start N/A End N/A Water Droplet Plume Attached  Detached  None

Describe Plume Background  
Start sky End sky

Background Color  
Start GRAY End GRAY Sky Condition  
Start OVERCAST End OVERCAST

Wind Speed  
Start 16 mph End 14 mph Wind Direction  
Start SW End SW

Ambient Temp.  
Start 86 End 78 Wet Bulb Temp.  
Start 79 End 75 RH Percent \_\_\_\_\_



Additional Information  
NONE

Sec	Observation Date				Sec	Time Zone				Start Time				End Time			
	0	15	30	45		0	15	30	45	0	15	30	45	0	15	30	45
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0	
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0	
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0	
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0	
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0	
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0	
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0	
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0	
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0	
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0	
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0	
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0	
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0	
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0	
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0	
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0	
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0	
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0	
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0	
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0	
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0	
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0	
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0	
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0	
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0	
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0	
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0	
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0	

Observer's Name (Print) JAMES STUIVE

Observer's Signature [Signature] Date 4-12-15

Organization ACG

Certified By ETA Date \_\_\_\_\_

VEOF 1.1

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9      203A      2038      Other: \_\_\_\_\_

Company Name: Pineellas County RRF  
 Facility Name: \_\_\_\_\_  
 Street Address: \_\_\_\_\_  
 City: CLEARWATER      State: FL      Zip: \_\_\_\_\_


Process: Municipal WASTE      Unit #: 2      Operating Mode: NORMAL  
 Control Equipment: BAGHOUSE      Operating Mode: NORMAL

Describe Emission Point:  
NORTHERN STACK PROTRUDING FROM THE ANNULUS  
 Height of Emiss. Pt.: \_\_\_\_\_      Height of Emiss. Pt. Rel. to Observer: \_\_\_\_\_  
 Start: 200      End: 200      Start: 200      End: 200  
 Direction to Emiss. Pt. (Degrees): \_\_\_\_\_      Direction to Emiss. Pt. (Degrees): \_\_\_\_\_  
 Start: 800      End: 800      Start: 270      End: 270

Vertical Angle to Obs. Pt.: \_\_\_\_\_      Direction to Obs. Pt. (Degrees): \_\_\_\_\_  
 Start: 8      End: 8      Start: 270      End: 270  
 Distance and Direction to Observation Point from Emission Point:  
 Start: SAME      End: SAME

Describe Emissions:  
 Start: NONE      End: NONE  
 Emission Color: \_\_\_\_\_      Water Droplet Plume: \_\_\_\_\_  
 Start: N/A      End: N/A      Attached:       Detached:       None:

Describe Plume Background:  
 Start: sky      End: sky  
 Background Obs.: \_\_\_\_\_      Sky Conditions: \_\_\_\_\_  
 Start: GRAY      End: SAME      Start: OVERCAST      End: SAME  
 Wind Speed: \_\_\_\_\_      Wind Direction: \_\_\_\_\_  
 Start: 14 mph      End: 15 mph      Start: SW      End: SW  
 Ambient Temp.: \_\_\_\_\_      Wet Bulb Temp.: \_\_\_\_\_      RH Percent: \_\_\_\_\_  
 Start: 78      End: 78      74      84



Longitude: \_\_\_\_\_      Latitude: \_\_\_\_\_      Declination: \_\_\_\_\_

Additional Information:  
NONE

Form Number: \_\_\_\_\_      Page: 1      Of: 1  
 Continued on VEO Form Number: U20-M9-R3

Obs. No.	Observation Date				Time Zone				Start Time				End Time			
	0	15	30	45	0	15	30	45	0	15	30	45	0	15	30	45
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0

Observer's Name (Print): JAMES STULTZ  
 Observer's Signature: \_\_\_\_\_      Date: 4-12-13  
 Organization: ACG  
 Certified By: ETA      Date: \_\_\_\_\_

VEOF 1.1

## **Appendix K.3**

### **EPA Method 9 Raw Field Data: Unit 3 Stack**



# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9      203A      203B      Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page 1 of 1  
 Continued on VEO Form Number 235-M9-R1

Company Name PINELLAS COUNTY RRF  
 Facility Name \_\_\_\_\_  
 Street Address \_\_\_\_\_  
 City CLEARWATER State FL Zip \_\_\_\_\_


Process MUNICIPAL WASTE IN Unit # 3 Operating Mode NORMAL  
 Control Equipment ISAGHOUSE Operating Mode NORMAL

Describe Emission Point  
EASTERN STACK PROTRUDING FROM THE ANNULUS  
 Height of Emis. Pt. Start 200 End 200 Height of Emis. Pt. Rel. to Observer Start 200 End 200  
 Direction to Emis. Pt. Start 800 End 800 Direction to Emis. Pt. (Degrees) Start 270 End 270

Vertical Angle to Obs. Pt. Start 8 End SAME Direction to Obs. Pt. (Degrees) Start 270 End 270  
 Distance and Direction to Observation Point from Emission Point Start SAME End SAME

Describe Emission  
 Start NONE End NONE  
 Emission Color Start N/A End N/A Water Droplet Plume Attached  Detached  None

Describe Plume Background  
 Start SKY End SKY  
 Background Color Start GRAY End GRAY Sky Conditions Start OVERCAST End SAME  
 Wind Speed Start 9 MPH End 14 MPH Wind Direction Start S End SW  
 Ambient Temp Start 77 End 78 Wet Bulb Temp 73 RH Percent 86



Longitude \_\_\_\_\_ Latitude \_\_\_\_\_ Declination \_\_\_\_\_  
 Additional Information NONE

Obs. No.	Observation Date				Time Zone	Start Time				End Time						
	hr	0	15	30		45	hr	0	15	30	45	hr	0	15	30	45
1	4	0	0	0	0	EST	10	13	0	0	0	0	0	0	0	0
2	0	0	0	0	0		31	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0		32	0	0	0	0	0	0	0	0	0
4	0	0	0	0	0		33	0	0	0	0	0	0	0	0	0
5	0	0	0	0	0		34	0	0	0	0	0	0	0	0	0
6	0	0	0	0	0		35	0	0	0	0	0	0	0	0	0
7	0	0	0	0	0		36	0	0	0	0	0	0	0	0	0
8	0	0	0	0	0		37	0	0	0	0	0	0	0	0	0
9	0	0	0	0	0		38	0	0	0	0	0	0	0	0	0
10	0	0	0	0	0		39	0	0	0	0	0	0	0	0	0
11	0	0	0	0	0		40	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0		41	0	0	0	0	0	0	0	0	0
13	0	0	0	0	0		42	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0		43	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0		44	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0		45	0	0	0	0	0	0	0	0	0
17	0	0	0	0	0		46	0	0	0	0	0	0	0	0	0
18	0	0	0	0	0		47	0	0	0	0	0	0	0	0	0
19	0	0	0	0	0		48	0	0	0	0	0	0	0	0	0
20	0	0	0	0	0		49	0	0	0	0	0	0	0	0	0
21	0	0	0	0	0		50	0	0	0	0	0	0	0	0	0
22	0	0	0	0	0		51	0	0	0	0	0	0	0	0	0
23	0	0	0	0	0		52	0	0	0	0	0	0	0	0	0
24	0	0	0	0	0		53	0	0	0	0	0	0	0	0	0
25	0	0	0	0	0		54	0	0	0	0	0	0	0	0	0
26	0	0	0	0	0		55	0	0	0	0	0	0	0	0	0
27	0	0	0	0	0		56	0	0	0	0	0	0	0	0	0
28	0	0	0	0	0		57	0	0	0	0	0	0	0	0	0
29	0	0	0	0	0		58	0	0	0	0	0	0	0	0	0
30	0	0	0	0	0		59	0	0	0	0	0	0	0	0	0
							60	0	0	0	0	0	0	0	0	0

Observer's Name (Print) JAMES SWITZ  
 Observer's Signature [Signature] Date 4-14-13  
 Organization ACG  
 Certified by ETA Date \_\_\_\_\_

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method (Use Handbook One) Method 9 203A 2038 Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page 1 of 1  
Continued on VEO Form Number 630-M9-R2

Company Name PINEHOLLS COUNTY RCF  
Facility Name \_\_\_\_\_  
Street Address \_\_\_\_\_  
City CLEARWATER State FL Zip \_\_\_\_\_


Process MUNICIPAL WASTE EN Unit # 3 Operating Mode NORMAL  
Control Equipment BAGHOUSE Operating Mode NORMAL

Describe Emission Point  
EASTERN STACK protruding from THE ANNULUS  
Height of Emiss. Pt. Start 200 End 200 Height of Emiss. Pt. Rel. to Observer Start 200 End 200  
Direction to Emiss. Pt. Start 000 End 800 Direction to Emiss. Pt. (Degrees) Start 270 End 270

Vertical Angle to Obs. Pt. Start 8 End 8 Direction to Obs. Pt. (Degrees) Start 270 End 270  
Distance and Direction to Observation Point from Emission Point Start SAME End SAME

Describe Emissions  
Start NONE End NONE  
Emission Color Start N/A End N/A Water Droplet Plume Attached  Detached  None

Describe Plume Background  
Start SKY End SAME Sky Conditions Start OVERCAST End SAME  
Background Obs. Start Cloud End SAME Wind Direction Start SW End SW  
Wind Speed Start 14 mph End 14 mph Wet Bulb Temp. Start 78 End 79 RH Percent Start 71 End 84



Longitude \_\_\_\_\_ Latitude \_\_\_\_\_ Declination \_\_\_\_\_  
Additional Information NONE

Min	Observation Date				Time Zone				Start Time				End Time				
	0	15	30	45	0	15	30	45	0	15	30	45	0	15	30	45	
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0	0
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0	0
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0	0
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0	0
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0	0
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0	0
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0	0
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0	0
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0	0
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0	0
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0	0

Observer's Name (Print) JAMES SWITZ  
Observer's Signature [Signature] Date 4-12-13  
Organization ACC  
Certified By ETA Date \_\_\_\_\_

VEOF 1.1

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Check One)  
 Method 9    203A    203B    Other: \_\_\_\_\_

Company Name  
**Pinellas County RRF**

Facility Name

Street Address

City **CLEARWATER**    State **FL**    Zip

Process **Municipal Waste Wt.**    Unit # **3**    Operating Mode **NORMAL**

Control Equipment **IBAGHOUSE**    Operating Mode **NORMAL**

Describe Emission Point  
**EASTERN STACK PROTRUDING FROM THE ANNULUS**

Height of Emiss. Pt.    Height of Emiss. Pt. Rel. to Observer  
 Start **200** End **200**    Start **200** End **200**

Distance to Emiss. Pt.    Direction to Emiss. Pt. (Degrees)  
 Start **800** End **800**    Start **270** End **270**

Vertical Angle to Obs. Pt.    Direction to Obs. Pt. (Degrees)  
 Start **8** End **8**    Start **270** End **270**

Distance and Direction to Observation Point from Emission Point  
 Start **SAME** End **SAME**

Describe Emissions  
 Start **NONE** End **NONE**


Emission Color    Water Droplet Plume  
 Start **N/A** End **N/A**    Attached  Detached  None

Describe Plume Background  
 Start **SKY** End **SKY**

Background Color    Sky Conditions  
 Start **GRAY** End **GRAY**    Start **OVERCAST** End **SAME**

Wind Speed    Wind Direction  
 Start **14 mph** End **16 mph**    Start **SW** End **SW**

Ambient Temp.    Wet Bulb Temp.    RH Percent  
 Start **79** End **80**    Start **75**    **82**



Longitude    Latitude    Declination

Additional Information  
**NONE**

Form Number \_\_\_\_\_ Page **1** of **1**

Continued on VEO Form Number **030-M9-23**

Obs. No.	Observation Date				Time Zone				Start Time				End Time			
	0	15	30	45	0	15	30	45	0	15	30	45	0	15	30	45
1	0	0	0	0	EST	12	13	0	0	0	0	0	0	0	0	0
2	0	0	0	0					32	0	0	0	0	0	0	0
3	0	0	0	0					33	0	0	0	0	0	0	0
4	0	0	0	0					34	0	0	0	0	0	0	0
5	0	0	0	0					35	0	0	0	0	0	0	0
6	0	0	0	0					36	0	0	0	0	0	0	0
7	0	0	0	0					37	0	0	0	0	0	0	0
8	0	0	0	0					38	0	0	0	0	0	0	0
9	0	0	0	0					39	0	0	0	0	0	0	0
10	0	0	0	0					40	0	0	0	0	0	0	0
11	0	0	0	0					41	0	0	0	0	0	0	0
12	0	0	0	0					42	0	0	0	0	0	0	0
13	0	0	0	0					43	0	0	0	0	0	0	0
14	0	0	0	0					44	0	0	0	0	0	0	0
15	0	0	0	0					45	0	0	0	0	0	0	0
16	0	0	0	0					46	0	0	0	0	0	0	0
17	0	0	0	0					47	0	0	0	0	0	0	0
18	0	0	0	0					48	0	0	0	0	0	0	0
19	0	0	0	0					49	0	0	0	0	0	0	0
20	0	0	0	0					50	0	0	0	0	0	0	0
21	0	0	0	0					51	0	0	0	0	0	0	0
22	0	0	0	0					52	0	0	0	0	0	0	0
23	0	0	0	0					53	0	0	0	0	0	0	0
24	0	0	0	0					54	0	0	0	0	0	0	0
25	0	0	0	0					55	0	0	0	0	0	0	0
26	0	0	0	0					56	0	0	0	0	0	0	0
27	0	0	0	0					57	0	0	0	0	0	0	0
28	0	0	0	0					58	0	0	0	0	0	0	0
29	0	0	0	0					59	0	0	0	0	0	0	0
30	0	0	0	0					60	0	0	0	0	0	0	0

Observer's Name (Print) **JAMES STULTZ**

Observer's Signature *[Signature]*    Date **4-12-13**

Organization **ACB**

Certified By **ETA**    Date

## **Appendix K.4**

### **EPA Method 9 Raw Field Data: Silos and Vents**

**Ash Conditioning Building**

**Residue Storage and Processing Bldg.**

**Activated Carbon Storage Silo**

**Lime Storage Silo for SDA**

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method 2034 (Circle One) 2034 2038 Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page \_\_\_\_\_ of \_\_\_\_\_  
Continued on VEO Form Number M9-ACD0-R1

Company Name \_\_\_\_\_  
Facility Name Pinellas Co. RRF  
Street Address \_\_\_\_\_  
City St. Petersburg State FL Zip \_\_\_\_\_


Process Ash handling vent Unit # \_\_\_\_\_ Operating Mode \_\_\_\_\_  
Control Equipment \_\_\_\_\_ Operating Mode \_\_\_\_\_

Describe Emission Point  
From Eastern most ad of cooling tower if you look between the waste water tank and line 510 there is a small gray vent with a cone shape cap  
Height of Emiss. Pt. Start 100 End 100' Height of Emiss. Pt. Rel. to Observer Start \_\_\_\_\_ End \_\_\_\_\_  
Distance to Emiss. Pt. Start 300 End 300' Direction to Emiss. Pt. (Degrees) Start SE 154° End SE 154°

Vertical Angle to Obs. Pt. Start 14° End 14° Direction to Obs. Pt. (Degrees) Start SE 154° End SE 154°  
Distance and Direction to Observation Point from Emission Point Start N/A End N/A

Describe Emissions  
Emission Color \_\_\_\_\_ End \_\_\_\_\_  
Water Droplet Plume Attached  Detached  None

Describe Plume Background  
Start Skyl End Skyl  
Background Color Start Blue End Blue Sky Conditions Start Clear End Clear  
Wind Speed Start ~3 mph End ~3 mph Wind Direction Start NE End NE  
Ambient Temp Start 79° End 83 Wet Bulb Temp 67° RH Percent 66%



Longitude \_\_\_\_\_ Latitude \_\_\_\_\_ Declination \_\_\_\_\_  
Additional Information \_\_\_\_\_

Sec	Observation Date				Time Zone	Start Time			End Time		
	0	15	30	45		min	0	15	30	45	
1	0	0	0	0	EST	12	15	0	0	0	0
2	0	0	0	0		31	0	0	0	0	0
3	0	0	0	0		32	0	0	0	0	0
4	0	0	0	0		33	0	0	0	0	0
5	0	0	0	0		34	0	0	0	0	0
6	0	0	0	0		35	0	0	0	0	0
7	0	0	0	0		36	0	0	0	0	0
8	0	0	0	0		37	0	0	0	0	0
9	0	0	0	0		38	0	0	0	0	0
10	0	0	0	0		39	0	0	0	0	0
11	0	0	0	0		40	0	0	0	0	0
12	0	0	0	0		41	0	0	0	0	0
13	0	0	0	0		42	0	0	0	0	0
14	0	0	0	0		43	0	0	0	0	0
15	0	0	0	0		44	0	0	0	0	0
16	0	0	0	0		45	0	0	0	0	0
17	0	0	0	0		46	0	0	0	0	0
18	0	0	0	0		47	0	0	0	0	0
19	0	0	0	0		48	0	0	0	0	0
20	0	0	0	0		49	0	0	0	0	0
21	0	0	0	0		50	0	0	0	0	0
22	0	0	0	0		51	0	0	0	0	0
23	0	0	0	0		52	0	0	0	0	0
24	0	0	0	0		53	0	0	0	0	0
25	0	0	0	0		54	0	0	0	0	0
26	0	0	0	0		55	0	0	0	0	0
27	0	0	0	0		56	0	0	0	0	0
28	0	0	0	0		57	0	0	0	0	0
29	0	0	0	0		58	0	0	0	0	0
30	0	0	0	0		59	0	0	0	0	0
						60	0	0	0	0	0

Observer's Name (Print) W. H. H. H.  
Observer's Signature [Signature] Date 4-13-04  
Organization ACG  
Certified By ETS Date 3-13

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Form Number:    Page 1 of 1  
Continued on VEO Form Number MG-RSPB-R1

Method Used (Circle One)  
Method 7 203A 203B Other:           

Company Name:             
Facility Name: Pinellas Co. RRF  
Street Address: 3001 - 116th Avenue North  
City: St. Petersburg State: FL Zip: 33712


Process: ASH handling via RSPB Unit #:            Operating Mode: Running  
Control Equipment: Bag House Operating Mode:           

Describe Emission Point:  
Square duct attached to Gray ash hopper in the corner of the ash building to right of green water tank  
Height of Emiss. Pt. Start: 30' End: 30' Height of Emiss. Pt. Rel. to Observer Start: 30' End: 30'  
Distance to Emiss. Pt. Start: 200' End: 200' Direction to Emiss. Pt. (Degrees) Start: S 180° End: S 180°

Vertical Angle to Obs. Pt. Start: 10° End: 10° Direction to Obs. Pt. (Degrees) Start: S 180° End: S 180°  
Distance and Direction to Observation Point from Emission Point Start: S 180° No Distance End: S 180° No Dist.

Describe Emissions:  
Start: N/A End: N/A Emission Color: N/A  
Water Droplet Plume: Attached  Detached  None

Describe Plume Background:  
Start: Ash building End: Ash building Background Color: Tan/Brown Sky Conditions: overcast  
Wind Speed: Start: 14-24 mph End: 14-24 mph Wind Direction: Start: S End: S  
Ambient Temp.: Start: 77 End: 75 Wet Bulb Temp.: 73 RH Percent: 86%



Longitude:            Latitude:            Declination:             
Additional Information:           

Obs. Min	Observation Date: <u>4-12-13</u>				Time Zone: <u>EST</u>				Start Time: <u>1347</u>				End Time: <u>1747</u>			
	0	15	30	45	0	15	30	45	0	15	30	45	0	15	30	45
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0

Observer's Name (Print): M. W. Head  
Observer's Signature: [Signature] Date: 4-12-13  
Organization: ACG  
Certified By: ETS Date: 3-2013

VEOF1.1

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One) Method 9 2034 2038 Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page 1 of 1  
Continued on VEO Form Number CS-M9-R1

Company Name Pinellas County RRF  
Facility Name \_\_\_\_\_  
Street Address \_\_\_\_\_  
City CLEARWATER State FL Zip \_\_\_\_\_

Process Carbon Silo Unit # N/A Operating Mode NORMAL  
Control Equipment \_\_\_\_\_ Operating Mode \_\_\_\_\_


Describe Emission Point  
Blowdown Silo TO THE NORTHWEST

Height of Emis. Pt. Start 60 End SAME Height of Emis. Pt. Rel. to Observer Start 60 End SAME  
Distance to Emis. Pt. Start 200 End SAME Direction to Emis. Pt. (Degrees) Start 290 End SAME

Vertical Angle to Obs. Pt. Start 6 End SAME Direction to Obs. Pt. (Degrees) Start 290 End SAME  
Distance and Direction to Observation Point from Emission Point Start SAME End SAME

Describe Emitters  
Start NONE End SAME  
Emission Color \_\_\_\_\_ Water Droplet Plume \_\_\_\_\_  
Start N/A End N/A Attached  Detached  None

Describe Plume Background  
Start BUILDING End SAME  
Background Color \_\_\_\_\_ Sky Conditions \_\_\_\_\_  
Start BROWN End SAME Start OVERCAST End SAME  
Wind Speed \_\_\_\_\_ Wind Direction \_\_\_\_\_  
Start 9 mph End 7 mph Start SW End S  
Ambient Temp. \_\_\_\_\_ Wet Bulb Temp. \_\_\_\_\_ RH Percent \_\_\_\_\_  
Start 75 End 77 Start 75 End 92



Longitude \_\_\_\_\_ Latitude \_\_\_\_\_ Declination \_\_\_\_\_  
Additional Information NONE

Min	Observation Date				Min	Time Zone				Start Time				End Time			
	0	15	30	45		0	15	30	45	0	15	30	45	0	15	30	45
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0	
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0	
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0	
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0	
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0	
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0	
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0	
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0	
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0	
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0	
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0	
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0	
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0	
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0	
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0	
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0	
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0	
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0	
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0	
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0	
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0	
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0	
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0	
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0	
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0	
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0	
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0	
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0	

Observer's Name (Print) JAMES S. ITO  
Observer's Signature \_\_\_\_\_ Date 4-12-13  
Organization \_\_\_\_\_  
Certified By \_\_\_\_\_ Date \_\_\_\_\_

VEOF 1.1

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 2034 2038 Other: \_\_\_\_\_

Form Number \_\_\_\_\_ Page 1 of 1  
 Continued on VEO Form Number  
 M9 - Pebble Line Silo - R1

Company Name  
 Facility Name  
 Pinellas Co. RRF  
 Street Address  
 City St. Petersburg State FL Zip

Process  
 Filling Pebble Line Silo Unit # Operating Mode Filling Silo  
 Control Equipment Bag House Operating Mode


Describe Emission Point  
 Duct on Top of Brown Pebble Line Silo

Height of Emiss. Pt. Start 120' End 120'  
 Height of Emiss. Pt. Rel. to Observer Start 180' End 110'  
 Direction to Emiss. Pt. Start E 72° End E 72°

Vertical Angle to Obs. Pt. Start 14° End 14°  
 Direction to Obs. Pt. (Degrees) Start E 72° End E 72°  
 Distance and Direction to Observation Point from Emission Point Start 0' End 0'

Describe Emissions  
 Start N/A End N/A  
 Emission Color Start N/A End N/A  
 Water Droplet Plume Attached  Detached  None

Describe Plume Background  
 Start Sky End Sky  
 Background Color Start Blue End Blue  
 Sky Condition Start Clear End Clear  
 Wind Speed Start ~ 4 mph End ~ 8 mph  
 Wind Direction Start ESE End  
 Ambient Temp. Start 71° End 71°  
 Wet Bulb Temp. 64° RH Percent 40%



Additional Information

Min	Observation Date				Min	Time Zone				Start Time				End Time			
	0	15	30	45		0	15	30	45	0	15	30	45	0	15	30	45
	4-9-13					EST				1022				1122			
1	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	32	0	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	33	0	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	34	0	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	35	0	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	36	0	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	37	0	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	38	0	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	39	0	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	40	0	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	41	0	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	42	0	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	44	0	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	46	0	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	47	0	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	49	0	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	50	0	0	0	0	0	0	0	0	0	0	0	0
21	0	0	0	0	51	0	0	0	0	0	0	0	0	0	0	0	0
22	0	0	0	0	52	0	0	0	0	0	0	0	0	0	0	0	0
23	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0	0
24	0	0	0	0	54	0	0	0	0	0	0	0	0	0	0	0	0
25	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0	0
26	0	0	0	0	56	0	0	0	0	0	0	0	0	0	0	0	0
27	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0	0
28	0	0	0	0	58	0	0	0	0	0	0	0	0	0	0	0	0
29	0	0	0	0	59	0	0	0	0	0	0	0	0	0	0	0	0
30	0	0	0	0	60	0	0	0	0	0	0	0	0	0	0	0	0

Observer's Name (Print) Mike Henry  
 Observer Signature [Signature] Date 4-9-2013  
 Organization Air Compliance Group  
 Certified by ETS Date 3-2013

VEOF 1.1




## **Appendix K.5**

### **EPA Method 22 Raw Field Data: Ash Handling System**

## FUGITIVE OR SMOKE EMISSION INSPECTION: OUTDOOR LOCATION

Company <i>Phellas Co. RRF</i>	Observer <i>Mike Henry</i>
Location <i>Ash handling Building / System</i>	Affiliation <i>Air Compliance Group</i>
Company contact <i>Bobby</i>	Date <i>4-12-13</i>
Sky conditions <i>overcast</i>	Wind direction <i>SSE</i>
Precipitation <i>0</i>	Wind speed <i>~ 8mph</i>
Industry <i>MWI</i>	Process unit <i>Ash Handling</i>

Sketch process unit: indicate observer position relative to source and sun; indicate potential emission points and/or actual emission points.




### OBSERVATIONS

	Clock Time	Observation Period Duration (min:sec)	Accumulated Emission Time (min:sec)
Begin Observation	<u>0858</u>	<u>20:00 min</u>	<u>0</u>
	<u>0923</u>	<u>20:00 min</u>	<u>0</u>
	<u>0948</u>	<u>20:00 min</u>	<u>0</u>
	<u>1013</u>	<u>20:00 min</u>	<u>0</u>
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
End Observation	_____	_____	_____

## FUGITIVE OR SMOKE EMISSION INSPECTION: OUTDOOR LOCATION

Company <i>Pinellas Co. RRF</i>	Observer <i>Mike Henry</i>
Location <i>Ash handling Building</i>	Affiliation <i>Air Compliance Group</i>
Company contact <i>Becky</i>	Date <i>4-12-13</i>
Sky conditions <i>Overcast</i>	Wind direction <i>SSE</i>
Precipitation <i>None</i>	Wind speed <i>~9 mph</i>
Industry <i>MWI</i>	Process unit <i>Ash handling</i>

Sketch process unit: indicate observer position relative to source and sun; indicate potential emission points and/or actual emission points.




### OBSERVATIONS

	Clock Time	Observation Period Duration (min:sec)	Accumulated Emission Time (min:sec)
Begin Observation	10:22	20:00 min	0
	10:47	20:00 min	0
	11:12	20:00 min	0
	11:37		
End Observation			

## FUGITIVE OR SMOKE EMISSION INSPECTION: OUTDOOR LOCATION

Company <i>Pinellas Co. RRF</i>	Observer <i>Mike Henry</i>
Location <i>Ash handling building</i>	Affiliation <i>Air Compliance Group</i>
Company contact <i>Becky</i>	Date <i>4-12-13</i>
Sky conditions <i>Overcast</i>	Wind direction <i>SSE</i>
Precipitation <i>None</i>	Wind speed <i>~7-9 mph</i>
Industry <i>MWI</i>	Process unit <i>Ash handling</i>

Sketch process unit: indicate observer position relative to source and sun; indicate potential emission points and/or actual emission points.



### OBSERVATIONS

	Clock Time	Observation Period Duration (min:sec)	Accumulated Emission Time (min:sec)
Begin Observation	11:45	20:00 min	0
	12:10	20:00 min	0
	12:35	20:00 min	0
	13:00	20:00 min	0
End Observation			

**Appendix L**  
**Analytical Data**

## **Appendix L.1**

### **EPA Method 3A Analytical Data**

**INTEGRATED BAG ANALYSIS DATA**

<b>Job Name</b>	<b>Pinellas County RRF</b>
<b>Contract</b>	<b>V13030</b>
<b>Method of Analysis</b>	<b>EPA Method 3/3A</b>
<b>Date</b>	<b>April 9-13, 2013</b>

<b>Run Number</b>	<b>%O<sub>2</sub></b>	<b>%CO<sub>2</sub></b>	
U1O-M29-R1	9.98	9.37	
U1O-M29-R2	10.06	9.35	
U1O-M29-R3	10.33	9.11	
U2O-M29-R1	10.60	8.60	
U2O-M29-R2	11.16	8.19	
U2O-M29-R3	11.72	7.70	
U3O-M29-R1	8.54	10.45	
U3O-M29-R2	8.52	10.51	
U3O-M29-R3	8.17	10.65	
U1I-M29-R1	8.10	10.90	
U1I-M29-R2	8.54	10.55	
U1I-M29-R3	8.29	10.97	
U2I-M29-R1	8.56	10.31	
U2I-M29-R2	9.01	9.94	
U2I-M29-R3	9.84	9.25	
U3I-M29-R1	6.79	12.05	
U3I-M29-R2	6.98	11.72	
U3I-M29-R3	7.11	11.49	

### INTEGRATED BAG ANALYSIS DATA

<b>Job Name</b>	<b>Pinellas County RRF</b>
<b>Contract</b>	<b>V13030</b>
<b>Method of Analysis</b>	<b>EPA Method 3/3A</b>
<b>Date</b>	<b>April 9-13, 2013</b>

<b>Run Number</b>	<b>%O<sub>2</sub></b>	<b>%CO<sub>2</sub></b>	
U1O-M26A-R1	9.56	9.62	
U1O-M26A-R2	10.22	9.10	
U1O-M26A-R3	10.24	9.01	
U2O-M26A-R1	10.74	8.52	
U2O-M26A-R2	10.93	8.42	
U2O-M26A-R3	11.63	7.72	
U3O-M26A-R1	8.33	10.67	
U3O-M26A-R2	7.83	11.15	
U3O-M26A-R3	8.00	10.86	



**INTEGRATED BAG ANALYSIS DATA**

<b>Job Name</b>	<b>Pinellas County RRF</b>
<b>Contract</b>	<b>V13030</b>
<b>Method of Analysis</b>	<b>EPA Method 3/3A</b>
<b>Date</b>	<b>April 9-13, 2013</b>

<b>Run Number</b>	<b>%O<sub>2</sub></b>	<b>%CO<sub>2</sub></b>	
U1O-M201A/202-R1	9.47	9.67	
U1O-M201A/202-R2	8.84	10.17	
U1O-M201A/202-R3	9.30	9.88	
U2O-M201A/202-R1	9.98	9.16	
U2O-M201A/202-R2	9.51	9.59	
U2O-M201A/202-R3	9.81	9.44	
U3O-M201A/202-R1	9.57	9.84	
U3O-M201A/202-R2	8.85	10.33	
U3O-M201A/202-R3	9.71	9.57	

## **Appendix L.2**

### **EPA Method 5 Gravimetric Analytical Data**

**GRAVIMETRIC LABORATORY DATA  
FINAL BEAKER WEIGHTS**

JOB NAME: Pinellas County RRF  
CONTRACT NO: V13030

RUN ID	U10-M26A-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	800 / L13-0024	(2) 66.5988	(7) 66.5988
BEAKER #	13-037	(3)	(8)
FILTER #	Q12-42	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		66.5988	
BEAKER TARE (g)		66.2259	
NET BEAKER GAIN (g)		0.3729	
FILTER TARE (g)		0.3703	
NET FILTER GAIN (g)		0.0026	

RUN ID	U10-M26A-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	801 / L13-0025	(2) 65.2147	(7) 65.2145
BEAKER #	13-038	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	100	(5)	(10)
CONSTANT WT. (g)		65.2145	
BEAKER TARE (g)		65.2035	
NET BEAKER GAIN (g)		0.0110	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U10-M26A-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	804 / L13-0026	(2) 69.3464	(7) 69.3464
BEAKER #	13-039	(3)	(8)
FILTER #	Q12-43	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		69.3464	
BEAKER TARE (g)		68.9743	
NET BEAKER GAIN (g)		0.3721	
FILTER TARE (g)		0.3702	
NET FILTER GAIN (g)		0.0019	

RUN ID	U10-M26A-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	805 / L13-0027	(2) 66.0004	(7) 66.0004
BEAKER #	13-040	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	105	(5)	(10)
CONSTANT WT. (g)		66.0004	
BEAKER TARE (g)		65.9841	
NET BEAKER GAIN (g)		0.0163	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U10-M26A-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	808 / L13-0028	(2) 67.0571	(7) 67.0575
BEAKER #	13-041	(3)	(8)
FILTER #	Q12-44	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		67.0575	
BEAKER TARE (g)		66.6880	
NET BEAKER GAIN (g)		0.3695	
FILTER TARE (g)		0.3663	
NET FILTER GAIN (g)		0.0032	

RUN ID	U10-M26A-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	809 / L13-0029	(2) 66.0807	(7) 66.0807
BEAKER #	13-042	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	105	(5)	(10)
CONSTANT WT. (g)		66.0807	
BEAKER TARE (g)		66.0690	
NET BEAKER GAIN (g)		0.0117	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U20-M26A-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	812 / L13-0030	(2) 66.5862	(7) 66.5862
BEAKER #	13-043	(3)	(8)
FILTER #	Q12-45	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		66.5862	
BEAKER TARE (g)		66.2036	
NET BEAKER GAIN (g)		0.3826	
FILTER TARE (g)		0.3813	
NET FILTER GAIN (g)		0.0013	

RUN ID	U20-M26A-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	813 / L13-0031	(2) 66.3375	(7) 66.3375
BEAKER #	13-044	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	100	(5)	(10)
CONSTANT WT. (g)		66.3375	
BEAKER TARE (g)		66.3244	
NET BEAKER GAIN (g)		0.0131	
FILTER TARE (g)			
NET FILTER GAIN (g)			

WEIGHING	DATE	TIME	REL. HUMIDITY (%)	TEMP (°F)	INITIAL ZERO CAL RESPONSE (g)	WEIGHT ID	INITIAL HIGH CAL RESPONSE (g)	SECONDARY HIGH CAL RESPONSE	TECHNICIAN
(1)	4/18/2013	10:12	44	75	0.0000	38998	99.9999	100.0000	JS
(2)	4/19/2013	8:40	45	71	0.0001	38998	100.0001	100.0000	JS
(3)									
(4)									
(5)									
(6)									
(7)									
(8)									
(9)									
(10)									

Final Weights Meet Acceptance Criteria:  YES  NO

I Certify That This Sheet Has Been Checked For Accuracy and Completeness: 

**GRAVIMETRIC LABORATORY DATA  
FINAL BEAKER WEIGHTS**

JOB NAME: Pinellas County RRF  
CONTRACT NO: V13030

RUN ID	U20-M26A-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	816 / L13-0032	(2) 66.0109	(7)
BEAKER #	13-045	(3)	(8)
FILTER #	Q12-48	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		66.0109	
BEAKER TARE (g)		65.5673	
NET BEAKER GAIN (g)		0.4436	
FILTER TARE (g)		0.4354	
NET FILTER GAIN (g)		0.0082	

RUN ID	U20-M26A-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	817 / L13-0033	(2) 65.3230	(7)
BEAKER #	13-046	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	100	(5)	(10)
CONSTANT WT. (g)		65.3230	
BEAKER TARE (g)		65.3171	
NET BEAKER GAIN (g)		0.0059	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U20-M26A-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	820 / L13-0034	(2) 66.7695	(7)
BEAKER #	13-047	(3)	(8)
FILTER #	Q12-49	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		66.7695	
BEAKER TARE (g)		66.4034	
NET BEAKER GAIN (g)		0.3661	
FILTER TARE (g)		0.3649	
NET FILTER GAIN (g)		0.0012	

RUN ID	U20-M26A-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	821 / L13-0035	(2) 68.9760	(7)
BEAKER #	13-048	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	140	(5)	(10)
CONSTANT WT. (g)		68.9760	
BEAKER TARE (g)		68.9617	
NET BEAKER GAIN (g)		0.0143	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U30-M26A-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	824 / L13-0036	(2) 67.0193	(7)
BEAKER #	13-049	(3)	(8)
FILTER #	Q12-50	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		67.0193	
BEAKER TARE (g)		66.6487	
NET BEAKER GAIN (g)		0.3706	
FILTER TARE (g)		0.3696	
NET FILTER GAIN (g)		0.0010	

RUN ID	U30-M26A-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	825 / L13-0037	(2) 67.1468	(7)
BEAKER #	13-050	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	190	(5)	(10)
CONSTANT WT. (g)		67.1468	
BEAKER TARE (g)		67.1311	
NET BEAKER GAIN (g)		0.0157	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U30-M26A-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	828 / L13-0038	(2) 66.3530	(7)
BEAKER #	13-051	(3)	(8)
FILTER #	Q12-52	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		66.3530	
BEAKER TARE (g)		65.9067	
NET BEAKER GAIN (g)		0.4463	
FILTER TARE (g)		0.4452	
NET FILTER GAIN (g)		0.0011	

RUN ID	U30-M26A-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	829 / L13-0039	(2) 65.8490	(7)
BEAKER #	13-052	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	100	(5)	(10)
CONSTANT WT. (g)		65.8490	
BEAKER TARE (g)		65.8345	
NET BEAKER GAIN (g)		0.0145	
FILTER TARE (g)			
NET FILTER GAIN (g)			

WEIGHING	DATE	TIME	REL. HUMIDITY (%)	TEMP (°F)	INITIAL ZERO CAL RESPONSE (g)	WEIGHT ID	INITIAL HIGH CAL RESPONSE (g)	SECONDARY HIGH CAL RESPONSE	TECHNICIAN
(1)	4/18/2013	10:12	44	75	0.0000	38998	99.9999	100.0000	JS
(2)	4/19/2013	8:40	45	71	0.0001	38998	100.0001	100.0000	JS
(3)									
(4)									
(5)									
(6)									
(7)									
(8)									
(9)									
(10)									

Final Weights Meet Acceptance Criteria:  YES  NO

I Certify That This Sheet Has Been Checked For Accuracy and Completeness: 

**GRAVIMETRIC LABORATORY DATA  
FINAL BEAKER WEIGHTS**

JOB NAME: Pinellas County RRF  
CONTRACT NO: V13030

RUN ID	U30-M26A-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	832 / L13-0040	(2) 67.3143	(7)
BEAKER #	13-053	(3)	(8)
FILTER #	Q12-53	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		67.3143	
BEAKER TARE (g)		66.8540	
NET BEAKER GAIN (g)		0.4603	
FILTER TARE (g)		0.4594	
NET FILTER GAIN (g)		0.0009	

RUN ID	U30-M26A-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	833 / L13-0041	(2) 66.3955	(7)
BEAKER #	13-054	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	100	(5)	(10)
CONSTANT WT. (g)		66.3955	
BEAKER TARE (g)		66.3811	
NET BEAKER GAIN (g)		0.0144	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	Blank M26A	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	836 / L13-0042	(2) 66.2758	(7)
BEAKER #	13-086	(3)	(8)
FILTER #	Q12-09	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		66.2758	
BEAKER TARE (g)		65.8868	
NET BEAKER GAIN (g)		0.3890	
FILTER TARE (g)		0.3891	
NET FILTER GAIN (g)		-0.0001	

RUN ID	Blank M26A	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	837 / L13-0043	(2) 69.9915	(7)
BEAKER #	13-087	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	150	(5)	(10)
CONSTANT WT. (g)		69.9915	
BEAKER TARE (g)		69.9920	
NET BEAKER GAIN (g)		-0.0005	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U10-M26A-R1 Duplicate	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	800 / L13-0024	(2) 66.5987	(7)
BEAKER #	13-037	(3)	(8)
FILTER #	Q12-42	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		66.5987	
BEAKER TARE (g)		66.2259	
NET BEAKER GAIN (g)		0.3728	
FILTER TARE (g)		0.3703	
NET FILTER GAIN (g)		0.0025	

RUN ID	2nd Control	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	0336 / L13-0044	(2) 200.0000	(7)
BEAKER #	--	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		200.0000	
BEAKER TARE (g)			
NET BEAKER GAIN (g)		200.0000	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID		BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #		(2)	(7)
BEAKER #		(3)	(8)
FILTER #		(4)	(9)
PW VOL. (mL)		(5)	(10)
CONSTANT WT. (g)			
BEAKER TARE (g)			
NET BEAKER GAIN (g)		0.0000	
FILTER TARE (g)			
NET FILTER GAIN (g)		0.0000	

RUN ID		BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #		(2)	(7)
BEAKER #		(3)	(8)
FILTER #		(4)	(9)
PW VOL. (mL)		(5)	(10)
CONSTANT WT. (g)			
BEAKER TARE (g)			
NET BEAKER GAIN (g)		0.0000	
FILTER TARE (g)			
NET FILTER GAIN (g)			

WEIGHING	DATE	TIME	REL. HUMIDITY (%)	TEMP (°F)	INITIAL ZERO CAL RESPONSE (g)	WEIGHT ID	INITIAL HIGH CAL RESPONSE (g)	SECONDARY HIGH CAL RESPONSE	TECHNICIAN
(1)	4/18/2013	10:12	44	75	0.0000	38998	99.9999	100.0000	JS
(2)	4/19/2013	8:40	45	71	0.0001	38998	100.0001	100.0000	JS
(3)									
(4)									
(5)									
(6)									
(7)									
(8)									
(9)									
(10)									

Final Weights Meet Acceptance Criteria:  YES  NO

I Certify That This Sheet Has Been Checked For Accuracy and Completeness: 

## **Appendix L.3**

### **EPA Method 201A Gravimetric Analytical Data**

**GRAVIMETRIC LABORATORY DATA  
FINAL BEAKER WEIGHTS**

JOB NAME: Pinellas County RRF  
CONTRACT NO: V13030

RUN ID	U10-M201A/202-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4000 / L13-0045	(2) 64.7670	(7) 64.7670
BEAKER #	13-055	(3)	(8)
FILTER #	12-38	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		64.7670	
BEAKER TARE (g)		64.4195	
NET BEAKER GAIN (g)		0.3475	
FILTER TARE (g)		0.3468	
NET FILTER GAIN (g)		0.0007	

RUN ID	U10-M201A/202-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4002 / L13-0046	(2) 67.0132	(7) 67.0132
BEAKER #	13-057	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	170	(5)	(10)
CONSTANT WT. (g)		67.0132	
BEAKER TARE (g)		67.0124	
NET BEAKER GAIN (g)		0.0008	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U10-M201A/202-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4007 / L13-0047	(2) 66.4996	(7) 66.4996
BEAKER #	13-058	(3)	(8)
FILTER #	12-45	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		66.4996	
BEAKER TARE (g)		66.1384	
NET BEAKER GAIN (g)		0.3612	
FILTER TARE (g)		0.3603	
NET FILTER GAIN (g)		0.0009	

RUN ID	U10-M201A/202-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4009 / L13-0048	(2) 66.3319	(7) 66.3319
BEAKER #	13-060	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	140	(5)	(10)
CONSTANT WT. (g)		66.3319	
BEAKER TARE (g)		66.3309	
NET BEAKER GAIN (g)		0.0010	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U10-M201A/202-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4014 / L13-0049	(2) 65.9601	(7) 65.9601
BEAKER #	13-061	(3)	(8)
FILTER #	12-46	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		65.9601	
BEAKER TARE (g)		65.6109	
NET BEAKER GAIN (g)		0.3492	
FILTER TARE (g)		0.3482	
NET FILTER GAIN (g)		0.0010	

RUN ID	U10-M201A/202-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4016 / L13-0050	(2) 65.3949	(7) 65.3949
BEAKER #	13-063	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	210	(5)	(10)
CONSTANT WT. (g)		65.3949	
BEAKER TARE (g)		65.3940	
NET BEAKER GAIN (g)		0.0009	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U20-M201A/202-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4021 / L13-0051	(2) 64.2094	(7) 64.2094
BEAKER #	13-064	(3)	(8)
FILTER #	12-48	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		64.2090	
BEAKER TARE (g)		63.8617	
NET BEAKER GAIN (g)		0.3473	
FILTER TARE (g)		0.3469	
NET FILTER GAIN (g)		0.0004	

RUN ID	U20-M201A/202-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4023 / L13-0052	(2) 64.3684	(7) 64.3684
BEAKER #	13-066	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	230	(5)	(10)
CONSTANT WT. (g)		64.3684	
BEAKER TARE (g)		64.3671	
NET BEAKER GAIN (g)		0.0013	
FILTER TARE (g)			
NET FILTER GAIN (g)			

WEIGHING	DATE	TIME	REL. HUMIDITY (%)	TEMP (°F)	INITIAL ZERO CAL RESPONSE (g)	WEIGHT ID	INITIAL HIGH CAL RESPONSE (g)	SECONDARY HIGH CAL RESPONSE	TECHNICIAN
(1)	4/18/2013	10:33	44	76	0.0000	38998	100.0001	100.0000	JS
(2)	4/19/2013	8:59	44	72	0.0001	38998	99.9999	100.0000	JS
(3)	4/22/2013	9:10	46	65	0.0000	38998	100.0000	99.9999	JS
(4)									
(5)									
(6)									
(7)									
(8)									
(9)									
(10)									

Final Weights Meet Acceptance Criteria:  YES  NO

I Certify That This Sheet Has Been Checked For Accuracy and Completeness: 

**GRAVIMETRIC LABORATORY DATA  
FINAL BEAKER WEIGHTS**

JOB NAME: Pinellas County RRF  
CONTRACT NO: V13030

RUN ID	U20-M201A/202-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4028 / L13-0053	(2) 65.8518	(7) 65.8518
BEAKER #	13-067	(3)	(8)
FILTER #	12-47	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		65.8518	
BEAKER TARE (g)		65.4955	
NET BEAKER GAIN (g)		0.3563	
FILTER TARE (g)		0.3559	
NET FILTER GAIN (g)		0.0004	

RUN ID	U20-M201A/202-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4030 / L13-0054	(2) 69.0592	(7) 69.0592
BEAKER #	13-069	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	260	(5)	(10)
CONSTANT WT. (g)		69.0592	
BEAKER TARE (g)		69.0587	
NET BEAKER GAIN (g)		0.0005	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U20-M201A/202-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4035 / L13-0055	(2) 67.0709	(7) 67.0709
BEAKER #	13-070	(3)	(8)
FILTER #	12-49	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		67.0709	
BEAKER TARE (g)		66.7118	
NET BEAKER GAIN (g)		0.3591	
FILTER TARE (g)		0.3586	
NET FILTER GAIN (g)		0.0005	

RUN ID	U20-M201A/202-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4037 / L13-0056	(2) 63.9051	(7) 63.9051
BEAKER #	13-072	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	120	(5)	(10)
CONSTANT WT. (g)		63.9051	
BEAKER TARE (g)		63.9044	
NET BEAKER GAIN (g)		0.0007	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U30-M201A/202-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4042 / L13-0057	(2) 70.2145	(7) 70.2145
BEAKER #	13-074	(3)	(8)
FILTER #	12-35	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		70.2145	
BEAKER TARE (g)		69.8543	
NET BEAKER GAIN (g)		0.3602	
FILTER TARE (g)		0.3598	
NET FILTER GAIN (g)		0.0004	

RUN ID	U30-M201A/202-R1	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4044 / L13-0058	(2) 65.3932	(7) 65.3932
BEAKER #	13-076	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	150	(5)	(10)
CONSTANT WT. (g)		65.3932	
BEAKER TARE (g)		65.3892	
NET BEAKER GAIN (g)		0.0040	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U30-M201A/202-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4049 / L13-0059	(2) 67.1324	(7) 67.1324
BEAKER #	13-077	(3)	(8)
FILTER #	12-36	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		67.1324	
BEAKER TARE (g)		66.7734	
NET BEAKER GAIN (g)		0.3590	
FILTER TARE (g)		0.3581	
NET FILTER GAIN (g)		0.0009	

RUN ID	U30-M201A/202-R2	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4051 / L13-0060	(2) 67.5397	(7) 67.5397
BEAKER #	13-079	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	170	(5)	(10)
CONSTANT WT. (g)		67.5397	
BEAKER TARE (g)		67.5381	
NET BEAKER GAIN (g)		0.0016	
FILTER TARE (g)			
NET FILTER GAIN (g)			

WEIGHING	DATE	TIME	REL. HUMIDITY (%)	TEMP (°F)	INITIAL ZERO CAL RESPONSE (g)	WEIGHT ID	INITIAL HIGH CAL RESPONSE (g)	SECONDARY HIGH CAL RESPONSE	TECHNICIAN
(1)	4/18/2013	10:33	44	76	0.0000	38998	100.0001	100.0000	JS
(2)	4/19/2013	8:59	44	72	0.0001	38998	99.9999	100.0000	JS
(3)									
(4)									
(5)									
(6)									
(7)									
(8)									
(9)									
(10)									

Final Weights Meet Acceptance Criteria:  YES  NO

I Certify That This Sheet Has Been Checked For Accuracy and Completeness: 



**GRAVIMETRIC LABORATORY DATA  
FINAL BEAKER WEIGHTS**

JOB NAME: Pinellas County RRF  
CONTRACT NO: V13030

RUN ID	U30-M201A/202-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4056 / L13-0061	(2) 67.8987	(7) 67.8987
BEAKER #	13-080	(3)	(8)
FILTER #	12-37	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		67.8987	
BEAKER TARE (g)		67.5390	
NET BEAKER GAIN (g)		0.3597	
FILTER TARE (g)		0.3591	
NET FILTER GAIN (g)		0.0006	

RUN ID	U30-M201A/202-R3	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4058 / L13-0062	(2) 66.6945	(7) 66.6941
BEAKER #	13-082	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	165	(5)	(10)
CONSTANT WT. (g)		66.6941	
BEAKER TARE (g)		66.6928	
NET BEAKER GAIN (g)		0.0013	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	Blank M201A/202	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4063 / L13-0063	(2) 64.6508	(7) 64.6508
BEAKER #	13-083	(3)	(8)
FILTER #	12-50	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		64.6508	
BEAKER TARE (g)		64.3030	
NET BEAKER GAIN (g)		0.3478	
FILTER TARE (g)		0.3477	
NET FILTER GAIN (g)		0.0001	

RUN ID	Blank M201A/202	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4065 / L13-0064	(2) 67.9245	(7) 67.9245
BEAKER #	13-085	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	125	(5)	(10)
CONSTANT WT. (g)		67.9245	
BEAKER TARE (g)		67.9233	
NET BEAKER GAIN (g)		0.0012	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID	U10-M201A/202-R1 Duplicate	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	4000 / L13-0045	(2) 64.7673	(7) 64.7673
BEAKER #	13-055	(3)	(8)
FILTER #	12-38	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		64.7673	
BEAKER TARE (g)		64.4195	
NET BEAKER GAIN (g)		0.3478	
FILTER TARE (g)		0.3468	
NET FILTER GAIN (g)		0.0010	

RUN ID	2nd Control	BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #	0336 / L13-0065	(2) 200.0000	(7) 200.0000
BEAKER #	--	(3)	(8)
FILTER #	--	(4)	(9)
PW VOL. (mL)	--	(5)	(10)
CONSTANT WT. (g)		200.0000	
BEAKER TARE (g)			
NET BEAKER GAIN (g)		200.0000	
FILTER TARE (g)			
NET FILTER GAIN (g)			

RUN ID		BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #		(2)	(7)
BEAKER #		(3)	(8)
FILTER #		(4)	(9)
PW VOL. (mL)		(5)	(10)
CONSTANT WT. (g)			
BEAKER TARE (g)			
NET BEAKER GAIN (g)		0.0000	
FILTER TARE (g)			
NET FILTER GAIN (g)		0.0000	

RUN ID		BEAKER WT. (g)	
		(1)	(6)
SAMPLE / LAB ID #		(2)	(7)
BEAKER #		(3)	(8)
FILTER #		(4)	(9)
PW VOL. (mL)		(5)	(10)
CONSTANT WT. (g)			
BEAKER TARE (g)			
NET BEAKER GAIN (g)		0.0000	
FILTER TARE (g)			
NET FILTER GAIN (g)			

WEIGHING	DATE	TIME	REL. HUMIDITY (%)	TEMP (°F)	INITIAL ZERO CAL RESPONSE (g)	WEIGHT ID	INITIAL HIGH CAL RESPONSE (g)	SECONDARY HIGH CAL RESPONSE	TECHNICIAN
(1)	4/18/2013	10:33	44	76	0.0000	38998	100.0001	100.0000	JS
(2)	4/19/2013	8:59	44	72	0.0001	38998	99.9999	100.0000	JS
(3)									
(4)									
(5)									
(6)									
(7)									
(8)									
(9)									
(10)									

Final Weights Meet Acceptance Criteria:  YES  NO

I Certify That This Sheet Has Been Checked For Accuracy and Completeness: 

## **Appendix L.4**

### **EPA Method 202 Laboratory Analytical Data**

# The Air Compliance Group, LLC


5075 Hollins Rd.  
Roanoke, VA 24019

Project ID: V13030

Condensables

EPA Method 202

Analytical Report  
20344



Element One, Inc.  
6319-D Carolina Beach Rd., Wilmington, NC 28412  
910-793-0128 FAX: 910-792-6853 [e1lab@e1lab.com](mailto:e1lab@e1lab.com)

The following data for Analytical Report 20344  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Review by:

A handwritten signature in black ink, appearing to read 'Katie Strickland', written over a light gray horizontal line.

Katie Strickland, Chemist  
May 1, 2013

Report Reviewed and Finalized By:

A handwritten signature in black ink, appearing to read 'Ken Smith', written over a light gray horizontal line.

Ken Smith, Laboratory Director  
May 1, 2013

# SUMMARY OF RESULTS

## Summary of Analysis

### Summary of Method 202 Particulate Analysis

Fraction	U1-O-R1 e20344-39 Catch, mg	U1-O-R2 e20344-40 Catch, mg	U1-O-R3 e20344-41 Catch, mg
Inorganic CPM	3.6	4.8	7.9
Organic CPM	7.6	5.7	8.0
Total CPM	11.2	10.5	15.9

Fraction	U2-O-R1 e20344-42 Catch, mg	U2-O-R2 e20344-43 Catch, mg	U2-O-R3 e20344-44 Catch, mg
Inorganic CPM	32.4*	3.6	4.3
Organic CPM	8.8	6.4	8.7
Total CPM	41.2	10.0	13.0

Fraction	U3-O-R1 e20344-45 Catch, mg	U3-O-R2 e20344-46 Catch, mg	U3-O-R3 e20344-47 Catch, mg
Inorganic CPM	5.0	6.9	4.8
Organic CPM	5.3	6.6	6.8
Total CPM	10.3	13.5	11.6

Fraction	Blank e20344-48 Catch, mg
Inorganic CPM	2.8
Organic CPM	0.4
Total CPM	3.2

\*See Analytical Narrative p.6.

# ANALYTICAL NARRATIVE

## Element One Analytical Narrative

Client:	The Air Compliance Group, LLC	Element One #:	20344
Client ID:	V13030 Pinellas County RRF	Analyst:	LAL
Method:	M 202	Dates Received:	04.17.13
Analytes:	Condensables	Dates Analyzed:	04.23-05.01.13

### Summary of Analysis

The Method 202 samples were prepared and extracted according to method protocol. All samples were measured to a constant weight of  $\pm 0.5\text{mg}$ , and reported to the nearest 0.1mg.

Per EPA Dry Impinger Method 202 section 11.2.2.1 the  $\text{NH}_4\text{OH}$  titration is not necessary to subtract the  $\text{NH}_4^+$  retained in the sample when the residue can be weighed to a constant weight.

### Analysis QA/QC

All laboratory QA/QC guidelines were followed in the analysis of the samples.

### Additional Comments

The Method 202  $\text{NH}_4\text{OH}$  titration has not been implemented.  
The reported results have not been blank corrected for any blank values.  
There were visible particles in the Blank samples.

\*Ref. page4; sample U2-O-R1 inorganic fraction contains visibly more white, flakey residue than other inorganic samples.



# SAMPLE CUSTODY



20344

CHAIN OF CUSTODY										ANALYSIS WANTED		
CONTRACT ID		Pinellas County RRF								CPM by M202		
CONTRACT NUMBER		V13030										
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE			COMMENTS		
4024				Aq. Imp								
4025				Org Rinse						Measure Volumes		
4026		Unit 2 Exhaust	U20 - M201A/202 - R1	CPM Filter		KMH	4/11/2013					
4031				Aq. Imp								
4032				Org Rinse						Measure Volumes		
4033		Unit 2 Exhaust	U20 - M201A/202 - R2	CPM Filter		KMH	4/11/2013					
4038				Aq. Imp								
4039				Org Rinse						Measure Volumes		
4040		Unit 2 Exhaust	U20 - M201A/202 - R3	CPM Filter		KMH	4/11/2013					
COLLECTED BY:		DATE	RELINQUISHED BY:	DATE	RECEIVED BY:	DATE						
RECEIVED BY:		DATE	RELINQUISHED BY:	DATE	RECEIVED BY:	DATE						
RECEIVED BY:		DATE	RELINQUISHED BY:	DATE	RECEIVED BY:	DATE						
RECEIVED BY:		DATE	RELINQUISHED BY:	DATE	RECEIVED BY:	DATE						

Air Compliance Group, LLC  
5075 HOLLINS ROAD  
ROANOKE, VA 24012

1520

20344

CHAIN OF CUSTODY				ANALYSIS WANTED			
CONTRACT ID		Pinellas County RRF		CPM by M202			
CONTRACT NUMBER		V13030					
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE
4045				Aq. Imp			X
4046				Org Rinse			X
4047		Unit3 Exhaust	U30 - M201A/202 - R1	CPM Filter		KMH	4/9/2013
4052				Aq. Imp			X
5053				Org Rinse			X
5054		Unit3 Exhaust	U30 - M201A/202 - R2	CPM Filter		KMH	4/9/2013
4059				Aq. Imp			X
4060				Org Rinse			X
4061		Unit3 Exhaust	U30 - M201A/202 - R3	CPM Filter		KMH	4/9/2013
4066				Aq. Imp			X
4067				Org Rinse			X
4068		M202-Blank	M202-Blank	CPM Filter		KMH	4/12/2013
COLLECTED BY: [Signature]		DATE: 4/17/13	RELINQUISHED BY: [Signature]	DATE: 4/17/13	RECEIVED BY: [Signature]	DATE: 4/17/13	
RELINQUISHED BY: [Signature]		DATE: 4/17/13	RECEIVED BY: [Signature]	DATE: 4/17/13	RELINQUISHED BY: [Signature]	DATE: 4/17/13	
RECEIVED BY: [Signature]		DATE: 4/17/13	RELINQUISHED BY: [Signature]	DATE: 4/17/13	RECEIVED BY: [Signature]	DATE: 4/17/13	
				Air Compliance Group, LLC 5075 HOLLINS ROAD ROANOKE, VA 24012			

20344  
~~20334~~ XRB  
4.17.13

# THE AIR COMPLIANCE GROUP, LLC

---

April 16, 2013

ElementOne Inc.  
6319-D Carolina Beach Rd.  
Wilmington, NC 28412  
(910) 793-0128

**Subject: Method 202 Analyses**  
**ACG P.O. #: V13030-02**  
**ACG Contract: Pinellas County RRF**

Dear Sample Custodian:

Included with this letter are nine (10) sets of EPA Method 202 samples (9 runs and 1 blank). These samples are to be analyzed in accordance with EPA Method 202 for condensable particulate matter. I need a standard lab turnaround for all samples.

Chain-of-Custody sheets accompany the samples and should be checked to ensure that any holding time requirements are met.

Please include a narrative stating any problems, or lack thereof, with the sample processing or analyses.

The analyses are covered under purchase order # V13030-02. If you have any questions, please contact me at ACG (540-265-1987 ext. 219) or on my cell (540-556-6212).

Regards,

The Air Compliance Group, LLC

  
Kenley Houtz, QSTI  
Project Manager

---

The Air Compliance Group, LLC  
5075 Hollins Road  
Roanoke, VA 24019

Phone: (540) 265-1987  
Fax: (540) 265-0082

# ANALYTICAL DATA

elementOne

**AIR TESTING SAMPLE SUBMISSION FORM**

Lab ID **20344**

--

Analysis Due Date 04.25.13  
QA/QC/Report Due Date 04.29.13

Client	The Air Compliance Group, LLC
Project No	V13030

Date Rec	04.17.13
Time Rec	1520

Acetone Lot		Volume Marked <input checked="" type="radio"/> Yes <input type="radio"/> No	<b>Ref. Method: 202</b>
Hexane Lot	120502	Volume Loss Y/ <input checked="" type="radio"/> N?	
0.1N NH <sub>4</sub> OH Lot		Temp < 30°C Yes <input type="radio"/> No <input checked="" type="radio"/>	
Run Fractions Received: C1, C2, C3—LLB 04.17.13			

**Sample Identification**

39	U1-O-M202-R1	42	U2-O-M202-R1	45	U3-O-M202-R1
40	U1-O-M202-R2	43	U2-O-M202-R2	46	U3-O-M202-R2
41	U1-O-M202-R3	44	U2-O-M202-R3	47	U3-O-M202-R3
				48	Blank

**Analyses Requested**

Samples 39-48    Condensables

NOTE: After PM Analysis complete, reconstitute H<sub>2</sub>O Rinse with 100 mLs UPDI and archive.

**Runs / FB**

Lab ID	Imp. + H <sub>2</sub> O Rinse CPM Container 1		Hexane Rinse Container 2	CPM Filter Container 3	Cold Water Impinger Container 4	Comments
	BV, ml	Constant Wt				
39	232	Yes	232			
40	270	Yes	270			
41	250	Yes	202			
42	250	Yes	256			
43	240	Yes	206			
44	250	Yes	214			
45	240	Yes	306			
46	250	Yes	216			
47	230	Yes	198			
48	180	Yes				

**Lab Communications**

Filters 20344-47, 46, 45, 41, 39 all had a pink residue on them when received (LAL 4.24.13)

Bag # X72 (20344-42 Imp) has much more visible residue (white/flaky) than any other bag

Bag # 674 (20344-48 Blank Imp) has white, flaky debris in bag  
pix taken

SS Page 3 of 3  
SS by KCS  
4/22/2013 10:25:33 AM

M202 Prep By/Date \_\_\_\_\_  
M202 Prep By/Date LAL 4.23.13  
Labeled By/Date LAL 4.22.13  
ID Verification By/Date KCS 4.22.13

elementOne

Method 202 Particulate

Lab # e 20344

Client ACG

Page 1 of 2


Balance checks Date: 04.29.13 2 g = 1.9999  
 Date: 04.30.13 2g = 2.0000  
 Date: 05.01.13 2g = 2.0001

Impinger Water										
Sample ID #	Sample Water Volume, ml	Baggie ID	Baggie Tare, g	Date 04.29.13		Date 04.30.13		Date 05.01.13		Catch Description and Loading
				Initials	LAL	Initials	LAL	Initials	LAL	
				Time	Baggie & Sample Wt., g	Time	Baggie & Sample Wt., g	Time	Baggie & Sample Wt., g	
20344-39	260	X53	10.2547	2:15	10.2583	11:15	10.2587			
20344-40	270	504	10.0933	2:15	10.0981	11:15	10.0983			
20344-41	250	X15	9.9744	2:15	9.9823	11:15	9.9825			
20344-42	250	X72	10.4413	2:15	10.4737	11:15	10.4738			
20344-43	240	522	10.0902	2:15	10.0942	11:15	10.0938			
20344-44	250	600	10.1110	2:15	10.1161	11:15	10.1153	11:00	10.1153	
Client Water Blk	180	674	10.2701	2:15	10.2730	11:15	10.2729			
Element 1 Water Blk	100	698	10.5792	2:15	10.5793	11:15	10.5792			

Hexane Extract											
Sample ID #	Sample Hexane Volume, ml	Baggie ID	Baggie Tare, g	Date 04.29.13		Date 04.30.13		Date 05.01.13		Total Extraction Hexane Volume, ml	Catch Description and Loading
				Initials	LAL	Initials	LAL	Initials	LAL		
				Time	Baggie & Sample Wt., g	Time	Baggie & Sample Wt., g	Time	Baggie & Sample Wt., g		
20344-39	232	547	9.8376	2:15	9.8452	11:15	9.8456				
20344-40	270	505	10.2465	2:15	10.2522	11:15	10.2526				
20344-41	202	632	10.0061	2:15	10.0145	11:15	10.0141				
20344-42	256	503	10.3511	2:15	10.3615	11:15	10.3603	11:00	10.3599		
20344-43	206	559	10.4038	2:15	10.4106	11:15	10.4102				
20344-44	214	688	10.3185	2:15	10.3262	11:15	10.3275	11:00	10.3272		
Client Hexane Blk	240	699	10.1492	2:15	10.1498	11:15	10.1496				
Element 1 Hexane Blk	90	X01	10.4607	2:15	10.4610	11:15	10.4609				

Total Catches									
Sample ID #	NH4 added, mg	Baggie Tare, g	Baggie + Water Catch, g	Inorganic Catch, mg	Hexane Bag ID	Baggie Tare, g	Baggie + Hexane Weight, g	Organic Catch, mg	Total CPM Catch, mg
20344-39	0.0	10.2547	10.2583	3.6	547	9.8376	9.8452	7.6	11.2
20344-40	0.0	10.0933	10.0981	4.8	505	10.2465	10.2522	5.7	10.5
20344-41	0.0	9.9744	9.9823	7.9	632	10.0061	10.0141	8.0	15.9
20344-42	0.0	10.4413	10.4737	32.4	503	10.3511	10.3599	8.8	41.2
20344-43	0.0	10.0902	10.0938	3.6	559	10.4038	10.4102	6.4	10.0
20344-44	0.0	10.1110	10.1153	4.3	688	10.3185	10.3272	8.7	13.0
Client Blank		10.2701	10.2729	2.8	699	10.1492	10.1496	0.4	3.2
Element 1 Blank		10.5792	10.5792	< 0.1	X01	10.4607	10.4609	0.2	0.2

Element One, Inc. Form 137 - Revision 2.0



elementOne

20344 ACG M202 Report Packet

Page 14 of 15



elementOne

Method 202 Particulate

Lab # e 20344

Client ACG

Page 2 of 2

Balance checks Date: 04.29.13 2 g = 1.9999  
 Date: 04.30.13 2g = 2.0000  
 Date: 05.01.13 2g = 2.0001

Impinger Water											
Sample ID #	Sample Water Volume, ml	Baggie ID	Baggie Tare, g	Date 04.29.13		Date 04.30.13		Date		Catch Description and Loading	
				Initials LAL		Initials LAL		Initials			
				Time	Baggie & Sample Wt., g	Time	Baggie & Sample Wt., g	Time	Baggie & Sample Wt., g		
20344-45	240	581	10.2620	2:15	10.2673	11:15	10.2670				
20344-46	250	X87	10.7165	2:15	10.7234	11:15	10.7234				
20344-47	230	572	10.2445	2:15	10.2496	11:15	10.2493				
Client Water Blk 48	180	674	10.2701	2:15	10.2730	11:15	10.2729				
Element 1 Water Blk	100	698	10.5792	2:15	10.5793	11:15	10.5792				
Hexane Extract											
Sample ID #	Sample Hexane Volume, ml	Baggie ID	Baggie Tare, g	Date 04.29.13		Date 04.30.13		Date 05.01.13		Total Extraction Hexane Volume, ml	Catch Description and Loading
				Initials LAL		Initials LAL		Initials LAL			
				Time	Baggie & Sample Wt., g	Time	Baggie & Sample Wt., g	Time	Baggie & Sample Wt., g		
20344-45	306	X24	10.2664	2:15	10.2717	11:15	10.2719				
20344-46	216	645	10.0129	2:15	10.0208	11:15	10.0200	11:00	10.0195		
20344-47	198	561	10.0042	2:15	10.0115	11:15	10.0110				
Client Hexane Blk-48	240	699	10.1492	2:15	10.1498	11:15	10.1496				
Element 1 Hexane Blk	90	X01	10.4607	2:15	10.4610	11:15	10.4609				
Total Catches											
Sample ID #	NH4 added, mg	Baggie Tare, g	Baggie+ Water Catch, g	Inorganic Catch, mg	Hexane Bag ID	Baggie Tare, g	Baggie + Hexane Weight, g	Organic Catch, mg	Total CPM Catch, mg		
20344-45	0.0	10.2620	10.2670	5.0	X24	10.2664	10.2717	5.3	10.3		
20344-46	0.0	10.7165	10.7234	6.9	645	10.0129	10.0195	6.6	13.5		
20344-47	0.0	10.2445	10.2493	4.8	561	10.0042	10.0110	6.8	11.6		
Client Blank		10.2701	10.2729	2.8	699	10.1492	10.1496	0.4	3.2		
Element 1 Blank		10.5792	10.5792	< 0.1	X01	10.4607	10.4609	0.2	0.2		

Element One, Inc. Form 137 - Revision 2.0

## **Appendix L.5**

### **EPA Method 26A Laboratory Analytical Data**

**(See Attached CD for Full Lab Report)**

# The Air Compliance Group, LLC


5075 Hollins Road  
Roanoke, VA 24019

Project No: V13030

Hydrogen Chloride

EPA Method 26A


Analytical Report  
20344



Element One, Inc.  
6319-D Carolina Beach Rd., Wilmington, NC 28412  
910-793-0128 FAX: 910-792-6853 [e1lab@e1lab.com](mailto:e1lab@e1lab.com)

The following data for Analytical Report 20344  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Review by:

A handwritten signature in black ink, appearing to read 'KS', written over a light gray rectangular background.

Katie Strickland, Chemist  
May 1, 2013

Report Reviewed and Finalized By:

A handwritten signature in black ink, appearing to read 'Ken Smith', written over a light gray rectangular background.

Ken Smith, Laboratory Director  
May 1, 2013

# SUMMARY OF RESULTS

## Summary of Analysis

### Summary of Method 26A Analysis

Element	U1-I-R1 e20344-20 Total mg	U1-I-R2 e20344-21 Total mg	U1-I-R3 e20344-22 Total mg
HCl	1577	1860	1581

Element	U1-O-R1 e20344-23 Total mg	U1-O-R2 e20344-24 Total mg	U1-O-R3 e20344-25 Total mg
HCl	20.3	27.5	33.8

Element	U2-I-R1 e20344-26 Total mg	U2-I-R2 e20344-27 Total mg	U2-I-R3 e20344-28 Total mg
HCl	1430	1272	1385

Element	U2-O-R1 e20344-29 Total mg	U2-O-R2 e20344-30 Total mg	U2-O-R3 e20344-31 Total mg
HCl	24.1	19.9	22.8

Element	U3-I-R1 e20344-32 Total mg	U3-I-R2 e20344-33 Total mg	U3-I-R3 e20344-34 Total mg
HCl	1613	1603	1343

Element	U3-O-R1 e20344-35 Total mg	U3-O-R2 e20344-36 Total mg	U3-O-R3 e20344-37 Total mg
HCl	63.9	55.4	47.6

Element	Blank e20344-38 Total mg
HCl	< 0.115

# ANALYTICAL NARRATIVE

## Element One Analytical Narrative

Client:	The Air Compliance Group, LLC	Element One #:	20344
Client ID:	V13030 Pinellas County RRF	Analyst:	KLS
Method:	M26A	Dates Received:	04.17.13
Analytes:	HCl	Dates Analyzed:	04.29-30.13

### Summary of Analysis

The samples were prepared and analyzed according to Method 26A protocol. The samples were analyzed for chloride on a Metrohm 761/788 ion chromatograph system.

### Detection Limits

The Metrohm reporting limit was 0.1 µg/mL for chloride.

### Analysis QA/QC

Duplicate analyses relative percent difference (RPD) and spike recovery data are summarized in the Quality Control section. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values.



# QUALITY CONTROL SUMMARY

## Summary of Quality Control Data

### Summary of Method 26A Duplicate Analysis RPD

	U1-I-R1	U1-I-R2	U1-I-R3
Element	RPD	RPD	RPD
-----			
HCl	0.6%	0.3%	0.5%
	U1-O-R1	U1-O-R2	U1-O-R3
Element	RPD	RPD	RPD
-----			
HCl	0.3%	1.2%	1.6%
	U2-I-R1	U2-I-R2	U2-I-R3
Element	RPD	RPD	RPD
-----			
HCl	1.2%	1.4%	1.1%
	U2-O-R1	U2-O-R2	U2-O-R3
Element	RPD	RPD	RPD
-----			
HCl	3.2%	0.6%	1.7%
	U3-I-R1	U3-I-R2	U3-I-R3
Element	RPD	RPD	RPD
-----			
HCl	0.8%	0.1%	0.3%
	U3-O-R1	U3-O-R2	U3-O-R3
Element	RPD	RPD	RPD
-----			
HCl	2.4%	0.6%	0.7%
		Blank	
Element		RPD	
-----			
HCl		NA	

## Summary of Quality Control Data

### Summary of Method 26A Spike Recoveries

<u>Element</u>	<u>U1-I-R3 Recovery</u>	<u>U1-O-R3 Recovery</u>
HCl	103%	104%

<u>Element</u>	<u>U2-I-R3 Recovery</u>	<u>U2-O-R3 Recovery</u>
HCl	105%	106%

<u>Element</u>	<u>U3-I-R3 Recovery</u>	<u>U3-O-R3 Recovery</u>
HCl	105%	107%

# SAMPLE CUSTODY

20344

CHAIN OF CUSTODY										ANALYSIS WANTED		
CONTRACT ID <u>Pinellas County RRF</u>										H		
CONTRACT NUMBER <u>V13030</u>										C		
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE	COMMENTS				
8000		UNIT 1 INLET	U1 IN-M26A-R1	Train Contents		KMH	4/9/2013	X				
8001		UNIT 1 INLET	U1 IN-M26A-R2	Train Contents		KMH	4/9/2013	X				
8002		UNIT 1 INLET	U1 IN-M26A-R3	Train Contents		KMH	4/9/2013	X				
8003		UNIT 2 INLET	U2 IN-M26A-R1	Train Contents		KMH	4/10/2013	X				
8004		UNIT 2 INLET	U2 IN-M26A-R2	Train Contents		KMH	4/10/2013	X				
8005		UNIT 2 INLET	U2 IN-M26A-R3	Train Contents		KMH	4/10/2013	X				
8006		UNIT 3 INLET	U3 IN-M26A-R1	Train Contents		KMH	4/11/2013	X				
8007		UNIT 3 INLET	U3 IN-M26A-R2	Train Contents		KMH	4/11/2013	X				
8008		UNIT 3 INLET	U3 IN-M26A-R3	Train Contents		KMH	4/11/2013	X				
COLLECTED BY: <u>[Signature]</u>		DATE: <u>4/9/13</u>	RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>	RECEIVED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>						
RELINQUISHED BY: <u>[Signature]</u>		DATE: <u>4/17-13</u>	RECEIVED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>	RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>						
RECEIVED BY: <u>[Signature]</u>		DATE: <u>4/17-13</u>	RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>	RECEIVED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>						

Air Compliance Group, LLC  
5075 HOLLINS ROAD  
ROANOKE, VA 24012

*Samples received in good condition. No empty containers.*

20344

CHAIN OF CUSTODY										ANALYSIS WANTED		
CONTRACT ID <u>Pinebliss County RRF</u>										H		
CONTRACT NUMBER <u>V13030</u>										C		
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE	COMMENTS				
802		UNIT 1 OUTLET	U10-M26A-R1	Train Contents		KMH	4/9/2013	X				
806		UNIT 1 OUTLET	U10-M26A-R2	Train Contents		KMH	4/9/2013	X				
810		UNIT 1 OUTLET	U10-M26A-R3	Train Contents		KMH	4/9/2013	X				
814		UNIT 2 OUTLET	U20-M26A-R1	Train Contents		KMH	4/10/2013	X				
818		UNIT 2 OUTLET	U20-M26A-R2	Train Contents		KMH	4/10/2013	X				
822		UNIT 2 OUTLET	U20-M26A-R3	Train Contents		KMH	4/10/2013	X				
826		UNIT 3 OUTLET	U30-M26A-R1	Train Contents		KMH	4/11/2013	X				
830		UNIT 3 OUTLET	U30-M26A-R2	Train Contents		KMH	4/11/2013	X				
834		UNIT 3 OUTLET	U30-M26A-R3	Train Contents		KMH	4/11/2013	X				
838		BLANK	BLANK	Train Contents		KMH	4/12/2013	X				
COLLECTED BY:		DATE	RELINQUISHED BY:	DATE	RECEIVED BY:	DATE	Air Compliance Group, LLC 5075 HOLLINS ROAD ROANOKE, VA 24012					
<i>[Signature]</i>		4/19/13	<i>[Signature]</i>	4/17/13	<i>[Signature]</i>	4/17/13						
RELINQUISHED BY:		DATE	RECEIVED BY:	DATE	RELINQUISHED BY:	DATE						
<i>[Signature]</i>		4-17-13	<i>[Signature]</i>		<i>[Signature]</i>							
RECEIVED BY:		DATE	RELINQUISHED BY:	DATE	RECEIVED BY:	DATE						
					<i>[Signature]</i>	4/17/13	1520					

20334 AB 4.17

# THE AIR COMPLIANCE GROUP, LLC

April 16, 2013

ElementOne Inc.  
6319-D Carolina Beach Rd.  
Wilmington, NC 28412  
(910) 793-0128

**Subject: HCl Analyses for Pinellas County RRF**  
**ACG Inc. P.O. # V13030-02**

ATTN Sample Custodian:

Accompanying this letter are samples from nine (9) inlet and nine (9) outlet EPA Method 26A sampling runs plus a reagent blank. The samples are to be analyzed in accordance with EPA Method 26A procedures for HCl. I need standard lab turnaround on these analyses. Sampling was performed April 9-11, 2013. No sodium thiosulfate has been added to the samples.

An on-site HCl titration was done for preliminary HCl analysis. For the titration, a 40mL aliquot was taken. Please adjust the final volumes to correct for this.


Please note the following:

- ◆ Chain-of-Custody sheets accompany the samples and should be checked to ensure that any holding time requirements are met.
- ◆ Include a narrative stating any problems, or lack thereof, with the sample processing or analyses.

The analyses are covered under ACG purchase order #V13030-02. If you have any questions, please contact me at ACG (540-265-1987 ext. 219) or on my cell (540-556-6212).

Sincerely,

ACG, LLC.



Kenley Houtz, QSTI  
Project Manager

Enclosure

**The Air Compliance Group, LLC**  
5075 Hollins Road  
Roanoke, VA 24019

**Phone: (540) 265-1987**  
**Fax: (540) 265-0082**

**elementOne**

20344 ACG M26A Report Packet  
Page 13 of 24

## **Appendix L.6**

### **EPA Method 29 Laboratory Analytical Data**

**(See Attached CD for Full Lab Report)**



# The Air Compliance Group, LLC


5075 Hollins Road  
Roanoke, VA 24019

Project Number: V13030

Cadmium, Lead and Mercury

EPA Method 29 Analysis


Analytical Report  
20344



Element One, Inc.  
6319-D Carolina Beach Rd., Wilmington, NC 28412  
910-793-0128 FAX: 910-792-6853 [e1lab@e1lab.com](mailto:e1lab@e1lab.com)

The following data for Analytical Report 20344  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Review by:

A handwritten signature in black ink, appearing to be 'Katie Strickland', written over a light gray rectangular background.

Katie Strickland, Chemist  
May 1, 2013

Report Reviewed and Finalized By:

A handwritten signature in black ink, appearing to be 'Ken Smith', written over a light gray rectangular background.

Ken Smith, Laboratory Director  
May 1, 2013

# SUMMARY OF RESULTS

## Summary of Analysis

### Unit 1 - Summary of Method 29 Mercury Analysis

Run Number		Average Total Catch, µg	Front Half µg	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub> µg	Empty Impinger µg	KMnO <sub>4</sub> µg	HCl µg
U1-I-R1	#1	99.4	25.2	70.0	0.720	1.58	2.37
	#2		25.0	69.2	0.731	1.60	2.36
U1-I-R2	#1	92.9	24.2	63.9	0.965	0.770	3.54
	#2		23.8	63.3	0.981	0.768	3.52
U1-I-R3	#1	84.4	21.1	62.4	0.306	< 0.5	0.669
	#2		21.0	62.3	0.311	< 0.5	0.671
U1-O-R1	#1	6.13	0.100	6.07	< 0.2	< 0.5	< 0.4
	#2		0.104	5.99	< 0.2	< 0.5	< 0.4
U1-O-R2	#1	7.10	0.152	6.96	< 0.2	< 0.5	< 0.4
	#2		0.144	6.94	< 0.2	< 0.5	< 0.4
U1-O-R3	#1	7.72	0.421	7.31	< 0.2	< 0.5	< 0.4
	#2		0.415	7.29	< 0.2	< 0.5	< 0.4

### Unit 1 - Summary of Method 29 Metals Analysis

Element	U1-O-R1 e20344-4 Total µg	U1-O-R2 e20344-5 Total µg	U1-O-R2 e20344-5 dup Total µg	U1-O-R3 e20344-6 Total µg
Cadmium	4.51	2.77	2.85	5.55
Lead	26.0	22.3	22.6	37.9

## Summary of Analysis

### Unit 2 - Summary of Method 29 Mercury Analysis

Run Number		Average Total Catch, $\mu\text{g}$	Front Half $\mu\text{g}$	$\text{H}_2\text{O}_2$ / $\text{HNO}_3$ $\mu\text{g}$	Empty Impinger $\mu\text{g}$	$\text{KMnO}_4$ $\mu\text{g}$	$\text{HCl}$ $\mu\text{g}$
U2-I-R1	#1	77.7	45.7	30.1	0.316	< 0.5	1.55
	#2		45.8	30.1	0.322	< 0.5	1.57
U2-I-R2	#1	128	36.4	88.4	0.529	< 0.5	3.60
	#2		36.4	87.1	0.521	< 0.5	3.59
U2-I-R3	#1	166	55.3	109	0.625	< 0.5	1.52
	#2		55.2	107	0.631	< 0.5	1.53
U2-O-R1	#1	2.11	0.165	1.94	< 0.2	< 0.5	< 0.4
	#2		0.164	1.95	< 0.2	< 0.5	< 0.4
U2-O-R2	#1	5.53	0.983	4.57	< 0.2	< 0.5	< 0.4
	#2		0.985	4.52	< 0.2	< 0.5	< 0.4
U2-O-R3	#1	3.36	< 0.1	2.11	< 0.2	< 0.5	1.26
	#2		< 0.1	2.10	< 0.2	< 0.5	1.26

### Unit 2 - Summary of Method 29 Metals Analysis

Element	U2-O-R1 e20344-10 Total $\mu\text{g}$	U2-O-R2 e20344-11 Total $\mu\text{g}$	U2-O-R2 e20344-11 dup Total $\mu\text{g}$	U2-O-R3 e20344-12 Total $\mu\text{g}$
Cadmium	1.41	5.39	4.72	0.588
Lead	19.3	52.6	46.5	15.0

## Summary of Analysis

### Unit 3 - Summary of Method 29 Mercury Analysis

Run Number		Average Total Catch, $\mu\text{g}$	Front Half $\mu\text{g}$	$\text{H}_2\text{O}_2$ / $\text{HNO}_3$ $\mu\text{g}$	Empty Impinger $\mu\text{g}$	$\text{KMnO}_4$ $\mu\text{g}$	$\text{HCl}$ $\mu\text{g}$
U3-I-R1	#1	241	54.7	186	0.512	< 0.5	< 0.4
	#2		54.6	185	0.512	< 0.5	< 0.4
U3-I-R2	#1	111	62.0	38.2	1.37	< 0.5	9.84
	#2		61.6	37.6	1.37	< 0.5	9.89
U3-I-R3	#1	65.3	8.26	55.1	0.376	< 0.5	1.88
	#2		8.03	54.7	0.377	< 0.5	1.89
U3-O-R1	#1	12.0	< 0.1	12.0	< 0.2	< 0.5	< 0.4
	#2		< 0.1	11.9	< 0.2	< 0.5	< 0.4
U3-O-R2	#1	13.3	< 0.1	12.8	< 0.2	< 0.5	0.498
	#2		< 0.1	12.8	< 0.2	< 0.5	0.516
U3-O-R3	#1	11.3	< 0.1	11.3	< 0.2	< 0.5	< 0.4
	#2		< 0.1	11.2	< 0.2	< 0.5	< 0.4
Blank	#1	< 0.5	< 0.1	< 0.3	< 0.2	< 0.5	< 0.4
	#2		< 0.1	< 0.3	< 0.2	< 0.5	< 0.4

### Unit 3 - Summary of Method 29 Metals Analysis

Element	U3-O-R1 e20344-16 Total $\mu\text{g}$	U3-O-R2 e20344-17 Total $\mu\text{g}$	U3-O-R2 e20344-17 dup Total $\mu\text{g}$	U3-O-R3 e20344-18 Total $\mu\text{g}$	Blank e20344-19 Total $\mu\text{g}$
Cadmium	1.85	1.76	1.81	1.50	< 0.2
Lead	19.7	24.4	25.2	11.9	0.827

# ANALYTICAL NARRATIVE

## Element One Analytical Narrative

Client:	The Air Compliance Group, LLC	Element One #:	20344
Client ID:	V13030 Pinellas County RRF	Analyst:	LAL & DBW
Method:	Method 29	Dates Received:	04/17/13
Analytes:	Cd, Pb & Hg	Dates Analyzed:	04/23-30/13

### Summary of Analysis

The Method 29 samples were digested, prepared, and analyzed according to Method 29 protocol. Samples were analyzed for mercury on a PerkinElmer FIMS-100 CVAA mercury analyzer. The samples were analyzed for metals on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limits

The FIMS-100 CVAA instrument reporting limit for mercury was 0.004 µg per aliquot analyzed. The ICP-MS instrument reporting limit was 1.0µg/L for the other metals.

### Analysis QA/QC

Duplicate analyses relative percent difference (RPD), spike sample recovery and second source calibration verification data are summarized in the Quality Control Section. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. The ICP analysis of the blank sample revealed detectable concentrations of lead.



# QUALITY CONTROL SUMMARY

## Summary of Quality Control Data

### Mercury Duplicate Analysis RPD

(Method 29 QC limits: < 10% for RPD)

Run Number	Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U1-I-R1	0.7%	1.1%	1.4%	0.9%	0.4%
U1-I-R2	1.5%	1.1%	1.6%	0.3%	0.4%
U1-I-R3	0.5%	0.2%	1.4%	NA	0.4%
U1-O-R1	3.1%	1.3%	NA	NA	NA
U1-O-R2	5.5%	0.2%	NA	NA	NA
U1-O-R3	1.5%	0.3%	NA	NA	NA
U2-I-R1	0.1%	0.0%	1.9%	NA	1.2%
U2-I-R2	0.0%	1.4%	1.4%	NA	0.2%
U2-I-R3	0.1%	1.3%	1.0%	NA	0.6%
U2-O-R1	0.4%	0.3%	NA	NA	NA
U2-O-R2	0.3%	1.2%	NA	NA	NA
U2-O-R3	NA	0.3%	NA	NA	0.1%
U3-I-R1	0.3%	0.4%	0.1%	NA	NA
U3-I-R2	0.6%	1.6%	0.0%	NA	0.5%
U3-I-R3	2.8%	0.7%	0.4%	NA	0.7%
U3-O-R1	NA	0.5%	NA	NA	NA
U3-O-R2	NA	0.2%	NA	NA	3.4%
U3-O-R3	NA	1.3%	NA	NA	NA
Blank	NA	NA	NA	NA	NA

## Summary of Quality Control Data

### Mercury Spike Recoveries

*(Method 29 QC limits: 75-125% for Spike Recoveries)*

Run Number		Front Half	H <sub>2</sub> O <sub>2</sub> /HNO <sub>3</sub>	Empty Imp	KMnO <sub>4</sub>	HCl
U1-I-R3	#1	91%	85%	101%	95%	97%
	#2	90%	85%	101%	95%	97%
U1-O-R3	#1	90%	95%	101%	94%	101%
	#2	90%	94%	101%	94%	102%
U2-I-R3	#1	89%	85%	112%	92%	93%
	#2	88%	86%	112%	93%	93%
U2-O-R3	#1	91%	103%	96%	98%	93%
	#2	90%	103%	97%	99%	93%
U3-I-R3	#1	96%	105%	100%	93%	95%
	#2	96%	105%	101%	94%	93%
U3-O-R3	#1	99%	97%	104%	90%	103%
	#2	98%	96%	104%	90%	99%

## Summary of Quality Control Data

### Metals Duplicate Analysis RPD

(Method 29 QC limits: < 20% for RPD)

Element	U1-O-R2 RPD	U2-O-R2 RPD	U3-O-R2 RPD
Cadmium	2.9%	13.4%	3.0%
Lead	1.3%	12.3%	3.2%

### Metals Analysis Spike Recoveries

(Method 29 QC limits: 75-125% for Spike Recoveries)

Element	U1-O-R3 Recovery	U2-O-R3 Recovery	U3-O-R3 Recovery
Cadmium	107%	103%	122%
Lead	112%	120%	106%

### Second Source Calibration Check Recoveries

(QC limits: ±10% for Second Source Continuing Check Standard\*)

Element	1 ppb	50 ppb	100 ppb*	250 ppb
Cadmium	100%	104%	103%	106%
Lead	94%	110%	105%	103%

# SAMPLE CUSTODY

CHAIN OF CUSTODY

ANALYSIS WANTED

CONTRACT ID Pinellas County RRF

CONTRACT NUMBER V13030

H	
G	

20344

SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE	ANALYSIS WANTED		COMMENTS
100		UNIT 1 INLET	U11N-M29-R1	Filter		KMH	4/9/2013	X		
101		UNIT 1 INLET	U11N-M29-R1	FH Nitric		KMH	4/9/2013	X		
102		UNIT 1 INLET	U11N-M29-R1	Impinger 1-3		KMH	4/9/2013	X		
103		UNIT 1 INLET	U11N-M29-R1	Impinger 4		KMH	4/9/2013	X		
104		UNIT 1 INLET	U11N-M29-R1	Impinger 5-6		KMH	4/9/2013	X		
105		UNIT 1 INLET	U11N-M29-R1	HCl & H2O		KMH	4/9/2013	X		
107		UNIT 1 INLET	U11N-M29-R2	Filter		KMH	4/9/2013	X		
108		UNIT 1 INLET	U11N-M29-R2	FH Nitric		KMH	4/9/2013	X		
109		UNIT 1 INLET	U11N-M29-R2	Impinger 1-3		KMH	4/9/2013	X		
110		UNIT 1 INLET	U11N-M29-R2	Impinger 4		KMH	4/9/2013	X		
111		UNIT 1 INLET	U11N-M29-R2	Impinger 5-6		KMH	4/9/2013	X		
112		UNIT 1 INLET	U11N-M29-R2	HCl & H2O		KMH	4/9/2013	X		
114		UNIT 1 INLET	U11N-M29-R3	Filter		KMH	4/9/2013	X		
115		UNIT 1 INLET	U11N-M29-R3	FH Nitric		KMH	4/9/2013	X		
116		UNIT 1 INLET	U11N-M29-R3	Impinger 1-3		KMH	4/9/2013	X		
117		UNIT 1 INLET	U11N-M29-R3	Impinger 4		KMH	4/9/2013	X		
118		UNIT 1 INLET	U11N-M29-R3	Impinger 5-6		KMH	4/9/2013	X		
119		UNIT 1 INLET	U11N-M29-R3	HCl & H2O		KMH	4/9/2013	X		
COLLECTED BY: <u>[Signature]</u>		DATE: <u>4/9/13</u>	RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>						
RECEIVED BY: <u>[Signature]</u>		DATE: <u>4-17-13</u>	RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>						
RECEIVED BY: <u>[Signature]</u>		DATE: <u>4-17-13</u>	RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>						

Samples received in good condition. No empty containers.  
Per Kenley via phone, FH/8H Combined - 2/28 4:18:13

Air Compliance Group, LLC  
5075 HOLLINS ROAD  
ROANOKE, VA 24012

20344

CHAIN OF CUSTODY										ANALYSIS WANTED			
CONTRACT ID <u>Pinellas County RRF</u>										T	A	R	H
CONTRACT NUMBER <u>V13030</u>										G	G	G	
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE					COMMENTS	
300		UNIT 1 OUTLET	U10-M29-R1	Filter	KMH		4/9/2013	X	X				
302		UNIT 1 OUTLET	U10-M29-R1	FH Nitric	KMH		4/9/2013	X	X				Target metals are:
303		UNIT 1 OUTLET	U10-M29-R1	Impinger 1-3	KMH		4/9/2013	X	X				Cadmium
304		UNIT 1 OUTLET	U10-M29-R1	Impinger 4	KMH		4/9/2013	X	X				Lead
305		UNIT 1 OUTLET	U10-M29-R1	Impinger 5-6	KMH		4/9/2013	X	X				
306		UNIT 1 OUTLET	U10-M29-R1	HCl & H2O	KMH		4/9/2013	X	X				
308		UNIT 1 OUTLET	U10-M29-R2	Filter	KMH		4/9/2013	X	X				
310		UNIT 1 OUTLET	U10-M29-R2	FH Nitric	KMH		4/9/2013	X	X				
311		UNIT 1 OUTLET	U10-M29-R2	Impinger 1-3	KMH		4/9/2013	X	X				
312		UNIT 1 OUTLET	U10-M29-R2	Impinger 4	KMH		4/9/2013	X	X				
313		UNIT 1 OUTLET	U10-M29-R2	Impinger 5-6	KMH		4/9/2013	X	X				
314		UNIT 1 OUTLET	U10-M29-R2	HCl & H2O	KMH		4/9/2013	X	X				
316		UNIT 1 OUTLET	U10-M29-R3	Filter	KMH		4/9/2013	X	X				
318		UNIT 1 OUTLET	U10-M29-R3	FH Nitric	KMH		4/9/2013	X	X				
319		UNIT 1 OUTLET	U10-M29-R3	Impinger 1-3	KMH		4/9/2013	X	X				
320		UNIT 1 OUTLET	U10-M29-R3	Impinger 4	KMH		4/9/2013	X	X				
321		UNIT 1 OUTLET	U10-M29-R3	Impinger 5-6	KMH		4/9/2013	X	X				
322		UNIT 1 OUTLET	U10-M29-R3	HCl & H2O	KMH		4/9/2013	X	X				
COLLECTED BY: <u>[Signature]</u>		DATE: <u>4/11/13</u>	RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>	RECEIVED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>					Air Compliance Group, LLC 5075 HOLLINS ROAD ROANOKE, VA 24012		
RELINQUISHED BY: <u>[Signature]</u>		DATE: <u>4/17/13</u>	RECEIVED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>									
RECEIVED BY: <u>[Signature]</u>		DATE: <u>4/17/13</u>	RELINQUISHED BY: <u>[Signature]</u>	DATE: <u>4/17/13</u>									

20344

CHAIN OF CUSTODY										ANALYSIS WANTED	
CONTRACT ID _____										Pinellas County RRF	
CONTRACT NUMBER _____										V13030	
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE			COMMENTS	
121		UNIT 2 INLET	U2IN-M29-R1	Filter		KMH	4/10/2013	X			
122		UNIT 2 INLET	U2IN-M29-R1	FH Nitric		KMH	4/10/2013	X			
123		UNIT 2 INLET	U2IN-M29-R1	Impinger 1-3		KMH	4/10/2013	X			
124		UNIT 2 INLET	U2IN-M29-R1	Impinger 4		KMH	4/10/2013	X			
125		UNIT 2 INLET	U2IN-M29-R1	Impinger 5-6		KMH	4/10/2013	X			
126		UNIT 2 INLET	U2IN-M29-R1	HCl & H2O		KMH	4/10/2013	X			
128		UNIT 2 INLET	U2IN-M29-R2	Filter		KMH	4/10/2013	X			
129		UNIT 2 INLET	U2IN-M29-R2	FH Nitric		KMH	4/10/2013	X			
130		UNIT 2 INLET	U2IN-M29-R2	Impinger 1-3		KMH	4/10/2013	X			
131		UNIT 2 INLET	U2IN-M29-R2	Impinger 4		KMH	4/10/2013	X			
132		UNIT 2 INLET	U2IN-M29-R2	Impinger 5-6		KMH	4/10/2013	X			
133		UNIT 2 INLET	U2IN-M29-R2	HCl & H2O		KMH	4/10/2013	X			
135		UNIT 2 INLET	U2IN-M29-R3	Filter		KMH	4/10/2013	X			
136		UNIT 2 INLET	U2IN-M29-R3	FH Nitric		KMH	4/10/2013	X			
137		UNIT 2 INLET	U2IN-M29-R3	Impinger 1-3		KMH	4/10/2013	X			
138		UNIT 2 INLET	U2IN-M29-R3	Impinger 4		KMH	4/10/2013	X			
139		UNIT 2 INLET	U2IN-M29-R3	Impinger 5-6		KMH	4/10/2013	X			
140		UNIT 2 INLET	U2IN-M29-R3	HCl & H2O		KMH	4/10/2013	X			
COLLECTED BY: <i>[Signature]</i>		DATE: 4/10/13	RELINQUISHED BY: <i>[Signature]</i>		DATE: 4/17/13	RECEIVED BY: <i>[Signature]</i>		DATE: 4/17/13			
RELINQUISHED BY: <i>[Signature]</i>		DATE: 4-17-13	RECEIVED BY: <i>[Signature]</i>		DATE: 4/17/13	RECEIVED BY: <i>[Signature]</i>		DATE: 4/17/13			
RECEIVED BY: <i>[Signature]</i>		DATE: 4-17-13	RELINQUISHED BY: <i>[Signature]</i>		DATE: 4/17/13	RECEIVED BY: <i>[Signature]</i>		DATE: 4/17/13			

Air Compliance Group, LLC  
 5075 HOLLINS ROAD  
 ROANOKE, VA 24012



20344

CHAIN OF CUSTODY										ANALYSIS WANTED			
CONTRACT ID		Pinebliss County RRF								T	A	R	H
CONTRACT NUMBER		V13030								G	G	G	G
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE					COMMENTS	
324		UNIT 2 OUTLET	U20-M29-R1	Filter	KMH		4/10/2013	X	X				
326		UNIT 2 OUTLET	U20-M29-R1	FH Nitric	KMH		4/10/2013	X	X				Target metals are
327		UNIT 2 OUTLET	U20-M29-R1	Impinger 1-3	KMH		4/10/2013	X	X				Cadmium
328		UNIT 2 OUTLET	U20-M29-R1	Impinger 4	KMH		4/10/2013	X	X				Lead
329		UNIT 2 OUTLET	U20-M29-R1	Impinger 5-6	KMH		4/10/2013	X	X				
330		UNIT 2 OUTLET	U20-M29-R1	HCl & H2O	KMH		4/10/2013	X	X				
332		UNIT 2 OUTLET	U20-M29-R2	Filter	KMH		4/10/2013	X	X				
334		UNIT 2 OUTLET	U20-M29-R2	FH Nitric	KMH		4/10/2013	X	X				
336		UNIT 2 OUTLET	U20-M29-R2	Impinger 1-3	KMH		4/10/2013	X	X				
336		UNIT 2 OUTLET	U20-M29-R2	Impinger 4	KMH		4/10/2013	X	X				
337		UNIT 2 OUTLET	U20-M29-R2	Impinger 5-6	KMH		4/10/2013	X	X				
338		UNIT 2 OUTLET	U20-M29-R2	HCl & H2O	KMH		4/10/2013	X	X				
340		UNIT 2 OUTLET	U20-M29-R3	Filter	KMH		4/10/2013	X	X				
342		UNIT 2 OUTLET	U20-M29-R3	FH Nitric	KMH		4/10/2013	X	X				
343		UNIT 2 OUTLET	U20-M29-R3	Impinger 1-3	KMH		4/10/2013	X	X				
344		UNIT 2 OUTLET	U20-M29-R3	Impinger 4	KMH		4/10/2013	X	X				
345		UNIT 2 OUTLET	U20-M29-R3	Impinger 5-6	KMH		4/10/2013	X	X				
346		UNIT 2 OUTLET	U20-M29-R3	HCl & H2O	KMH		4/10/2013	X	X				
COLLECTED BY: <i>David G. Jones</i>		DATE: 4/10/13	RELINQUISHED BY: <i>David G. Jones</i>	DATE: 4/17/13	RECEIVED BY: <i>Joe Krizan</i>	DATE: 4/17/13					5:20		
RECEIVED BY: <i>David G. Jones</i>		DATE: 4/17/13	RELINQUISHED BY: <i>David G. Jones</i>	DATE: 4/17/13	RECEIVED BY: <i>Joe Krizan</i>	DATE: 4/17/13							

Air Compliance Group, LLC  
 5075 HOLLINS ROAD  
 ROANOKE, VA 24012

20344

CHAIN OF CUSTODY										ANALYSIS WANTED	
CONTRACT ID _____ Pinellas County RRF										<input type="checkbox"/>	<input type="checkbox"/>
CONTRACT NUMBER _____ V13030										<input type="checkbox"/>	<input type="checkbox"/>
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE			COMMENTS	
142		UNIT 3 INLET	U3IN-M29-R1	Filter		KMH	4/11/2013	X			
143		UNIT 3 INLET	U3IN-M29-R1	FH Nitric		KMH	4/11/2013	X			
144		UNIT 3 INLET	U3IN-M29-R1	Impinger 1-3		KMH	4/11/2013	X			
145		UNIT 3 INLET	U3IN-M29-R1	Impinger 4		KMH	4/11/2013	X			
146		UNIT 3 INLET	U3IN-M29-R1	Impinger 5-6		KMH	4/11/2013	X			
147		UNIT 3 INLET	U3IN-M29-R1	HCl & H2O		KMH	4/11/2013	X			
149		UNIT 3 INLET	U3IN-M29-R2	Filter		KMH	4/11/2013	X			
150		UNIT 3 INLET	U3IN-M29-R2	FH Nitric		KMH	4/11/2013	X			
151		UNIT 3 INLET	U3IN-M29-R2	Impinger 1-3		KMH	4/11/2013	X			
152		UNIT 3 INLET	U3IN-M29-R2	Impinger 4		KMH	4/11/2013	X			
153		UNIT 3 INLET	U3IN-M29-R2	Impinger 5-6		KMH	4/11/2013	X			
154		UNIT 3 INLET	U3IN-M29-R2	HCl & H2O		KMH	4/11/2013	X			
156		UNIT 3 INLET	U3IN-M29-R3	Filter		KMH	4/11/2013	X			
157		UNIT 3 INLET	U3IN-M29-R3	FH Nitric		KMH	4/11/2013	X			
158		UNIT 3 INLET	U3IN-M29-R3	Impinger 1-3		KMH	4/11/2013	X			
159		UNIT 3 INLET	U3IN-M29-R3	Impinger 4		KMH	4/11/2013	X			
160		UNIT 3 INLET	U3IN-M29-R3	Impinger 5-6		KMH	4/11/2013	X			
161		UNIT 3 INLET	U3IN-M29-R3	HCl & H2O		KMH	4/11/2013	X			
COLLECTED BY: <i>[Signature]</i>		DATE: 4/11/13	RELINQUISHED BY: <i>[Signature]</i>	DATE: 4/11/13	RECEIVED BY: <i>[Signature]</i>	DATE: 4/11/13	RELINQUISHED BY: <i>[Signature]</i>	DATE: 4/11/13	RECEIVED BY: <i>[Signature]</i>	DATE: 4/11/13	Air Compliance Group, LLC 5075 HOLLINS ROAD ROANOKE, VA 24012
RELINQUISHED BY: <i>[Signature]</i>		DATE: 4/11/13	RELINQUISHED BY: <i>[Signature]</i>	DATE: 4/11/13	RECEIVED BY: <i>[Signature]</i>	DATE: 4/11/13	RELINQUISHED BY: <i>[Signature]</i>	DATE: 4/11/13	RECEIVED BY: <i>[Signature]</i>	DATE: 4/11/13	
RECEIVED BY: <i>[Signature]</i>		DATE: 4/11/13	RELINQUISHED BY: <i>[Signature]</i>	DATE: 4/11/13	RECEIVED BY: <i>[Signature]</i>	DATE: 4/11/13	RELINQUISHED BY: <i>[Signature]</i>	DATE: 4/11/13	RECEIVED BY: <i>[Signature]</i>	DATE: 4/11/13	

20344

CHAIN OF CUSTODY										ANALYSIS WANTED													
CONTRACT ID _____ Pinellas County RRF										<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				
CONTRACT NUMBER _____ V13030										<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
SAMPLE ID	CONTAINER NUMBER	TEST LOCATION	RUN ID	SAMPLE TYPE	VOLUME	INITIALS	DATE													COMMENTS			
348		UNIT 3 OUTLET	U30-M29-R1	Filter		KMH	4/11/2013	X															
350		UNIT 3 OUTLET	U30-M29-R1	FH Nitric		KMH	4/11/2013	X												Target metals are:			
351		UNIT 3 OUTLET	U30-M29-R1	Impinger 1-3		KMH	4/11/2013	X												Cadmium			
352		UNIT 3 OUTLET	U30-M29-R1	Impinger 4		KMH	4/11/2013	X												Lead			
353		UNIT 3 OUTLET	U30-M29-R1	Impinger 5-6		KMH	4/11/2013	X															
354		UNIT 3 OUTLET	U30-M29-R1	HCl & H2O		KMH	4/11/2013	X															
356		UNIT 3 OUTLET	U30-M29-R2	Filter		KMH	4/11/2013	X															
358		UNIT 3 OUTLET	U30-M29-R2	FH Nitric		KMH	4/11/2013	X															
359		UNIT 3 OUTLET	U30-M29-R2	Impinger 1-3		KMH	4/11/2013	X															
360		UNIT 3 OUTLET	U30-M29-R2	Impinger 4		KMH	4/11/2013	X															
361		UNIT 3 OUTLET	U30-M29-R2	Impinger 5-6		KMH	4/11/2013	X															
362		UNIT 3 OUTLET	U30-M29-R2	HCl & H2O		KMH	4/11/2013	X															
364		UNIT 3 OUTLET	U30-M29-R3	Filter		KMH	4/11/2013	X															
366		UNIT 3 OUTLET	U30-M29-R3	FH Nitric		KMH	4/11/2013	X															
367		UNIT 3 OUTLET	U30-M29-R3	Impinger 1-3		KMH	4/11/2013	X															
369		UNIT 3 OUTLET	U30-M29-R3	Impinger 4		KMH	4/11/2013	X															
369		UNIT 3 OUTLET	U30-M29-R3	Impinger 5-6		KMH	4/11/2013	X															
370		UNIT 3 OUTLET	U30-M29-R3	HCl & H2O		KMH	4/11/2013	X															
COLLECTED BY: <i>Vanessa Shaw</i>		DATE: 4/11/13	RELINQUISHED BY: <i>Vanessa Shaw</i>		DATE: 4/17/13	RECEIVED BY: <i>Vanessa Shaw</i>		DATE: 4/17/13	RELINQUISHED BY: <i>Vanessa Shaw</i>		DATE: 4/17/13	RECEIVED BY: <i>Vanessa Shaw</i>		DATE: 4/17/13	RELINQUISHED BY: <i>Vanessa Shaw</i>		DATE: 4/17/13	RECEIVED BY: <i>Vanessa Shaw</i>		DATE: 4/17/13	RELINQUISHED BY: <i>Vanessa Shaw</i>		DATE: 4/17/13
RECEIVED BY: _____		DATE: _____	RELINQUISHED BY: _____		DATE: _____	RECEIVED BY: _____		DATE: _____	RELINQUISHED BY: _____		DATE: _____	RECEIVED BY: _____		DATE: _____	RELINQUISHED BY: _____		DATE: _____	RECEIVED BY: _____		DATE: _____	RELINQUISHED BY: _____		DATE: _____

Air Compliance Group, LLC  
5075 HOLLINS ROAD  
ROANOKE, VA 24012

1520



20344  
~~20334~~ #AB  
4/17/13

# THE AIR COMPLIANCE GROUP, LLC

April 16, 2013

ElementOne Inc.  
6319-D Carolina Beach Rd.  
Wilmington, NC 28412  
(910) 793-0128

**Subject: Metals Analyses for Pinellas County RRF**  
**ACG Inc. P.O. # V13030-02**  
**ACG Contract # V13030**

ATTN Sample Custodian:

Accompanying this letter are samples from ten (10) EPA Method 29 outlet samples (9 runs and 1 field blank). The samples are to be analyzed in accordance with EPA Method 29 for a) Cadmium, b) Lead, and c) Mercury.

There are also nine (9) EPA Method 29 inlet samples, which are to be analyzed for mercury only.

Please note the following:

- ◆ Chain-of-Custody sheets accompany the samples and should be checked to ensure that any holding time requirements are met.
- ◆ Please submit complete documentation for the analysis of one single sampling run.
- ◆ Please include a narrative stating any problems, or lack thereof, with the sample processing or analyses.

The analyses are covered under ACG purchase order #V13030-02. If you have any questions, please contact me at ACG (540-265-1987 ext. 219) or on my cell (540-556-6212).

Sincerely,  
The Air Compliance Group, LLC  
  
Kenley Houtz, QSTI  
Project Manager

The Air Compliance Group, LLC  
5075 Hollins Road  
Roanoke, VA 24019

Phone: (540) 265-1987  
Fax: (540) 265-0082

**Appendix M**  
**Field Equipment Calibration Data**

## **Appendix M.1**

### **Pitot Tube, Barometer and Nozzle Calibration Data**

## TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes  X      no

PITOT TUBE OPENINGS DAMAGED?

yes       no  X if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED?

yes       no  X

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By:

Kim Vylaman

Date: 10/11/2012



## TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes  no

PITOT TUBE OPENINGS DAMAGED?

yes  no  if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED?      yes       no

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By: *David Recello*

Date: 1/15/2013

## TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes  no

PITOT TUBE OPENINGS DAMAGED?

yes  no  if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED?      yes       no

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By: *David Recello*

Date: 1/15/2013

## TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes  no

PITOT TUBE OPENINGS DAMAGED?

yes  no  if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED?      yes       no

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By: *David Recello*

Date: 1/15/2013

## TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes  no

PITOT TUBE OPENINGS DAMAGED?

yes  no  if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED? yes  no

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By: *David Recello*

Date: 1/15/2013

## TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes  no

PITOT TUBE OPENINGS DAMAGED?

yes  no  if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED?      yes       no

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By: *David Recello*

Date: 1/15/2013

## TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes  no

PITOT TUBE OPENINGS DAMAGED?

yes  no  if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED? yes  no

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By: *David Recello*

Date: 1/15/2013

## TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes  no

PITOT TUBE OPENINGS DAMAGED?

yes  no  if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED?      yes       no

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By: *David Recello*

Date: 1/15/2013

# TYPE S PITOT TUBE INSPECTION DATA FORM

PITOT TUBE ID

DATE

PITOT TUBE ASSEMBLY LEVEL?

yes

no

PITOT TUBE OPENINGS DAMAGED?

yes

no  if yes, see Note A

alpha1  < 10°

alpha2  < 10°

beta1  < 5°

beta2  < 5°

z  < 0.32 cm

w  < 0.08 cm

Pa  = Pb

Pb  = Pa

Dt  0.48 - 0.95 cm

Pa = Pb = [1.05 - 1.50] x Dt

Note A

Other comments

CALIBRATION REQUIRED?

no

IF NO CALIBRATION REQUIRED, BY DEFAULT PITOT COEFFICIENT (Cp) = 0.84

INSPECTED BY

QA/QC Performed By: *David Recello*

Date: 1/15/2013



Field Barometer Calibration Form

JOB ID V13030      Facility ID Pinellas County RRF

DATE	Field Barometer ID	Reference Barometer ("Hg)	Field Barometer ("Hg)	Diff "Hg	Pass/ Fail	Tech
4/6/2013	ACG-BAR-3	29.10	29.11	0.01	Pass	KMH
4/17/2013	ACG-BAR-3	29.07	29.05	0.02	Pass	KMH

For acceptance, the field barometer must be within 0.1" Hg of the absolute barometric pressure obtained from the nearby National Weather Service Station (adjusted for elevation differences).

### ACG Field Nozzle Calibration Form

Nozzle Set I.D. \_\_\_\_\_ Glass Set A \_\_\_\_\_

Technician: FPC

Date: 10/25/2012

Nozzle Identification Number	Nozzle Diameter <sup>a</sup>			$\Delta D$ , <sup>b</sup> inches	$D_{avg}$ <sup>c</sup>	Pass/Fail
	D <sub>1</sub> , inches	D <sub>2</sub> , inches	D <sub>3</sub> , inches			
A1	0.156	0.156	0.156	0.000	0.156	Pass
A2	0.156	0.156	0.155	0.001	0.156	Pass
A3	0.191	0.190	0.191	0.001	0.191	Pass
A4	0.185	0.185	0.185	0.000	0.185	Pass
A5	0.217	0.218	0.218	0.001	0.218	Pass
A6	0.218	0.219	0.218	0.001	0.218	Pass
A7	0.250	0.250	0.250	0.000	0.250	Pass
A8	0.250	0.249	0.250	0.001	0.250	Pass
A9	0.250	0.250	0.250	0.000	0.250	Pass
A10	0.279	0.280	0.280	0.001	0.280	Pass
A11	0.281	0.280	0.280	0.001	0.280	Pass
A12	0.312	0.312	0.312	0.000	0.312	Pass
A13	0.310	0.310	0.310	0.000	0.310	Pass
A14	0.375	0.375	0.375	0.000	0.375	Pass
A15	0.375	0.375	0.375	0.000	0.375	Pass
A16	0.437	0.438	0.437	0.001	0.437	Pass
A17	0.437	0.437	0.437	0.000	0.437	Pass
A18	0.495	0.495	0.495	0.000	0.495	Pass
A19	0.502	0.502	0.502	0.000	0.502	Pass
A20	0.620	0.620	0.620	0.000	0.620	Pass
A21	0.622	0.622	0.621	0.001	0.622	Pass
A22	0.809	0.809	0.809	0.000	0.809	Pass
A23	0.741	0.741	0.740	0.001	0.741	Pass

where:

<sup>a</sup> D<sub>1,2,3</sub> = three different nozzles diameters, mm (in.); measure to the nearest 0.025 mm (0.001 in.)

<sup>b</sup>  $\Delta D$  = maximum difference between any two diameters, mm (in.),  $\Delta D \neq (0.10 \text{ mm}) 0.004 \text{ in.}$

<sup>c</sup>  $D_{avg}$  = average of D<sub>1</sub>, D<sub>2</sub>, and D<sub>3</sub>.

### ACG Field Nozzle Calibration Form

Nozzle Set I.D. \_\_\_\_\_ Glass Set B \_\_\_\_\_

Technician: FPC

Date: 4/9/2013

Nozzle Identification Number	Nozzle Diameter <sup>a</sup>			$\Delta D$ , <sup>b</sup> inches	$D_{avg}$ <sup>c</sup>	Pass/Fail
	D <sub>1</sub> , inches	D <sub>2</sub> , inches	D <sub>3</sub> , inches			
B1	0.156	0.156	0.156	0.000	0.156	Pass
B2	0.156	0.156	0.156	0.000	0.156	Pass
B3	0.185	0.185	0.185	0.000	0.185	Pass
B4	0.185	0.185	0.185	0.000	0.185	Pass
B5	0.219	0.219	0.219	0.000	0.219	Pass
B6	0.225	0.226	0.225	0.001	0.225	Pass
B7	0.250	0.250	0.250	0.000	0.250	Pass
B8	0.250	0.250	0.250	0.000	0.250	Pass
B9	0.250	0.252	0.253	0.003	0.252	Pass
B10	0.280	0.280	0.280	0.000	0.280	Pass
B11	0.280	0.280	0.279	0.001	0.280	Pass
B12	0.312	0.312	0.312	0.000	0.312	Pass
B13	0.311	0.312	0.312	0.001	0.312	Pass
B14	0.375	0.375	0.374	0.001	0.375	Pass
B15	0.375	0.375	0.375	0.000	0.375	Pass
B16	0.440	0.440	0.440	0.000	0.440	Pass
B17	0.437	0.437	0.437	0.000	0.437	Pass
B18	0.500	0.500	0.500	0.000	0.500	Pass
B19	0.500	0.500	0.500	0.000	0.500	Pass
B20	0.624	0.624	0.624	0.000	0.624	Pass
B21	0.625	0.625	0.625	0.000	0.625	Pass
B22	0.750	0.750	0.750	0.000	0.750	Pass
B24	0.750	0.750	0.750	0.000	0.750	Pass

where:

<sup>a</sup> D<sub>1,2,3</sub> = three different nozzles diameters, mm (in.); measure to the nearest 0.025 mm (0.001 in.)

<sup>b</sup>  $\Delta D$  = maximum difference between any two diameters, mm (in.),  $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

<sup>c</sup>  $D_{avg}$  = average of D<sub>1</sub>, D<sub>2</sub>, and D<sub>3</sub>.

### ACG Field Nozzle Calibration Form

Nozzle Set I.D. \_\_\_\_\_ Glass Set C \_\_\_\_\_

Technician:     JBS    

Date:     6/6/2012    

Nozzle Identification Number	Nozzle Diameter <sup>a</sup>			$\Delta D$ , <sup>b</sup> inches	$D_{avg}$ <sup>c</sup>	Pass/Fail
	D <sub>1</sub> , inches	D <sub>2</sub> , inches	D <sub>3</sub> , inches			
C1	0.155	0.155	0.155	0.000	0.155	Pass
C2	0.155	0.154	0.155	0.001	0.155	Pass
C3	0.185	0.185	0.184	0.001	0.185	Pass
C4	0.184	0.185	0.185	0.001	0.185	Pass
C5	0.218	0.218	0.218	0.000	0.218	Pass
C6	0.218	0.217	0.218	0.001	0.218	Pass
C7	0.250	0.249	0.250	0.001	0.250	Pass
C8	0.250	0.250	0.250	0.000	0.250	Pass
C9	0.256	0.256	0.256	0.000	0.256	Pass
C10	0.280	0.280	0.280	0.000	0.280	Pass
C11	0.279	0.280	0.280	0.001	0.280	Pass
C12	0.312	0.311	0.312	0.001	0.312	Pass
C13	0.310	0.310	0.310	0.000	0.310	Pass
C14	0.375	0.375	0.374	0.001	0.375	Pass
C15	0.375	0.375	0.375	0.000	0.375	Pass
C16	0.428	0.428	0.428	0.000	0.428	Pass
C17	0.437	0.436	0.436	0.001	0.436	Pass
C18	0.501	0.502	0.502	0.001	0.502	Pass
C19	0.500	0.500	0.500	0.000	0.500	Pass
C20	0.624	0.625	0.625	0.001	0.625	Pass
C21	0.625	0.625	0.624	0.001	0.625	Pass
C22	0.750	0.750	0.750	0.000	0.750	Pass
C23	0.804	0.804	0.804	0.000	0.804	Pass

where:

<sup>a</sup> D<sub>1,2,3</sub> = three different nozzles diameters, mm (in.); measure to the nearest 0.025 mm (0.001 in.)

<sup>b</sup>  $\Delta D$  = maximum difference between any two diameters, mm (in.),  $\Delta D \#(0.10 \text{ mm}) 0.004 \text{ in.}$

<sup>c</sup>  $D_{avg}$  = average of D<sub>1</sub>, D<sub>2</sub>, and D<sub>3</sub>.

## **Appendix M.2**

### **Meter Console and Thermocouple Calibration Data**

**The Air Compliance Group, LLC**  
**EPA Method 5**  
**Meter Box Calibration**  
**Pre-Test Orifice Method**

Meter Box # 4Barometric Pressure: 29.300 (in. Hg)Date: 03/16/13Theoretical Critical Vacuum: 13.82 (in. Hg)Calibration Technician: MRW

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
0.27	5	85.117	86.647	1.530	61	63	61	63
0.27	5	86.647	88.163	1.516	61	63	61	62
0.6	6	88.163	90.826	2.663	63	63	61	62
0.6	6	90.826	93.514	2.688	61	62	61	61
1.1	5	93.514	96.408	2.894	61	61	61	61
1.1	5	96.408	99.308	2.900	61	61	62	61
1.9	6	99.308	103.910	4.602	62	61	64	61
1.9	6	103.910	108.527	4.617	64	61	66	62
3.4	5	108.527	113.673	5.146	66	62	68	63
3.4	5	113.673	118.818	5.145	68	63	69	63

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in. Hg)	Ambient Temperature			Average Temperature		
			Initial (deg F)	Final (deg F)	Average (deg F)	DGM Outlet (deg R)	DGM Overall (deg R)	Ambient Temp (deg R)
KV-40	0.2404	24	62	62	62	523	522	522
KV-40	0.2404	24	62	62	62	523	522	522
KV-48	0.3504	23	62	62	62	523	522	522
KV-48	0.3504	23	62	62	62	522	521	522
KV-55	0.4616	22	62	62	62	521	521	522
KV-55	0.4616	22	62	62	62	521	521	522
KV-63	0.6012	20	62	62	62	521	522	522
KV-63	0.6012	20	62	62	62	522	523	522
KV-73	0.8227	18	62	62	62	523	525	522
KV-73	0.8227	18	62	62	62	523	526	522

**IMPORTANT:**

For valid test results, the Actual Vacuum should be at least 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

The Air Compliance Group, LLC  
 EPA Method 5  
 Meter Box Calibration  
 Pre-Test Orifice Method

Meter Box # 4  
 Date: 03/16/13

Barometric Pressure: 29.30 (in. Hg)  
 Theoretical Critical Vacuum: 13.82 (in. Hg)  
 Calibration Technician: MRW

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR. Vm(std) (ft <sup>3</sup> )	VOLUME CORR. Vm(std) (liters)
1.516	42.9
1.503	42.6
2.639	74.7
2.669	75.6
2.879	81.5
2.883	81.7
4.578	129.7
4.582	129.8
5.112	144.8
5.101	144.5

----- ORIFICE -----

VOLUME CORR. Vcr(std) (ft <sup>3</sup> )	VOLUME CORR. Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft <sup>3</sup> )
1.541	43.7	1.557
1.541	43.7	1.557
2.696	76.4	2.723
2.696	76.4	2.723
2.960	83.8	2.989
2.960	83.8	2.989
4.626	131.0	4.672
4.626	131.0	4.672
5.275	149.4	5.328
5.275	149.4	5.328

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number) <sup>1</sup>
1.0168	0.00
1.0257	0.00
1.0215	0.00
1.0101	-0.01
1.0281	0.01
1.0265	0.00
1.0104	-0.01
1.0095	-0.01
1.0320	0.01
1.0341	0.01
Average	1.0215 0.00

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H2O)	Value (mm H2O)	Variation (in H2O) <sup>2</sup>
1.5797	40.13	-0.1
1.5812	40.16	-0.1
1.6540	42.01	0.0
1.6571	42.09	0.0
1.7523	44.51	0.1
1.7523	44.51	0.1
1.7843	45.32	0.1
1.7826	45.28	0.1
1.7002	43.19	0.0
1.6986	43.14	0.0
Average	1.6942 43.03	0.0

Average Y =	1.0215
Average ΔH@ =	1.6942
Pass/Fail?	Pass

Notes:

<sup>1</sup> For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ± 0.02. Variations shown have been rounded to nearest 0.01.

<sup>2</sup> For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 deg F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is ± 0.2. Variations shown have been rounded to nearest 0.1.

QA/QC Performed By: David Recello

Date: 03/21/13

**The Air Compliance Group, LLC**  
**EPA Method 5**  
**Meter Box Calibration**  
**Post-Test Orifice Method**

Meter Box # 4  
 Date: 4/16/2013

Barometric Pressure: 29.090 (in. Hg)  
 Theoretical Critical Vacuum: 13.72 (in. Hg)  
 Calibration Technician: DCF

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	<u>Initial Temperature</u>		<u>Final Temperature</u>	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
1.20	5.0	234.022	236.944	2.922	78	76	79	77
1.20	5.0	236.944	239.891	2.947	79	77	80	77
1.20	5.0	239.891	242.821	2.930	80	77	80	77

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in Hg)	<u>Ambient Temperature</u>			<u>Average Temperature</u>		
			Initial (deg F)	Final (deg F)	Average (deg F)	DGM Outlet (deg R)	DGM Overall (deg R)	Ambient Temp (deg R)
KX-55	0.4578	20	72	72	72	537	538	532
KX-55	0.4578	20	72	72	72	537	538	532
KX-55	0.4578	20	72	72	72	537	539	532

**IMPORTANT:**

For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.



The Air Compliance Group, LLC  
 EPA Method 5  
 Meter Box Calibration  
 Post-Test Orifice Method

Meter Box # 4  
 Date: 04/16/13

Barometric Pressure: 29.09 (in. Hg)  
 Theoretical Critical Vacuum: 13.72 (in. Hg)  
 Calibration Technician: DCF

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR.	VOLUME CORR.
Vm(std) (ft <sup>3</sup> )	Vm(std) (liters)
2.798	79.2
2.818	79.8
2.801	79.3

----- ORIFICE -----

VOLUME CORR.	VOLUME CORR.	VOLUME NOMINAL
Vcr(std) (ft <sup>3</sup> )	Vcr(std) (liters)	Vcr (ft <sup>3</sup> )
2.887	81.8	2.993
2.887	81.8	2.993
2.887	81.8	2.993

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number)
1.0317	0.003
1.0244	-0.005
1.0308	0.002

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H <sub>2</sub> O)	Value (mm H <sub>2</sub> O)	Variation (in H <sub>2</sub> O)
1.9374	49.21	0.001
1.9356	49.16	-0.001
1.9356	49.16	-0.001

Average Y<sub>(post)</sub> 1.0290                      Average dH@<sub>(post)</sub> 1.9362                      49.18

<b>Calibration Factor Gamma (Y):</b>	<b>1.0215</b>
<b>Post Test Avg. Gamma (Y<sub>(post)</sub>):</b>	<b>1.0290</b>
<b>Variation:</b>	<b>0.0075</b>
<b>5% of Y:</b>	<b>0.0511</b>
<b>Variation ≤ 5% of Y?</b>	<b>Yes</b>

**Note:**  
 The Variation [absolute value of the Calibration Factor Gamma (Y) minus the Post Test Average Gamma (Y<sub>(post)</sub>)] must be less than or equal to 5% of Calibration Factor Gamma (Y).

QA/QC Performed By: David Recello

Date: 4/17/2013

**The Air Compliance Group, LLC**  
**EPA Method 5**  
**Meter Box Calibration**  
**Pre-Test Orifice Method**

Meter Box # 16Barometric Pressure: 29.46 (in. Hg)Date: 01/10/13Theoretical Critical Vacuum: 13.90 (in. Hg)Calibration Technician: CSB

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
0.28	5	35.040	36.615	1.575	68.0	66.0	68.0	67.0
0.28	5	36.615	38.205	1.590	68.0	67.0	69.0	67.0
0.64	5	38.205	40.504	2.299	69.0	67.0	69.0	68.0
0.64	5	40.504	42.822	2.318	69.0	68.0	70.0	68.0
1.1	5	42.822	45.858	3.036	70.0	68.0	70.0	69.0
1.1	5	45.858	48.905	3.047	70.0	69.0	71.0	69.0
1.9	5	48.905	52.812	3.907	71.0	69.0	72.0	70.0
1.9	5	52.812	56.714	3.902	72.0	70.0	73.0	71.0
3.5	5	56.714	61.978	5.264	73.0	71.0	73.0	71.0
3.5	5	61.978	67.229	5.251	73.0	71.0	74.0	72.0

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in. Hg)	Ambient Temperature			Average Temperature		Ambient Temp (deg R)
			Initial (deg F)	Final (deg F)	Average (deg F)	DGM Outlet (deg R)	DGM Overall (deg R)	
KX-40	0.2376	23.0	60.0	60.0	60.0	526.5	527.3	520.0
KX-40	0.2376	23.0	61.0	61.0	61.0	527.0	527.8	521.0
KX-48	0.3472	22.0	61.0	61.0	61.0	527.5	528.3	521.0
KX-48	0.3472	22.0	61.0	61.0	61.0	528.0	528.8	521.0
KX-55	0.4578	20.0	61.0	61.0	61.0	528.5	529.3	521.0
KX-55	0.4578	20.0	61.0	61.0	61.0	529.0	529.8	521.0
KX-63	0.5924	18.0	61.0	61.0	61.0	529.5	530.5	521.0
KX-63	0.5924	18.0	61.0	61.0	61.0	530.5	531.5	521.0
KX-73	0.8053	16.0	61.0	61.0	61.0	531.0	532.0	521.0
KX-73	0.8053	16.0	61.0	61.0	61.0	531.5	532.5	521.0

**IMPORTANT:**

For valid test results, the Actual Vacuum should be at least 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

The Air Compliance Group, LLC  
 EPA Method 5  
 Meter Box Calibration  
 Pre-Test Orifice Method

Meter Box # 16 Barometric Pressure: 29.46 (in. Hg)  
 Date: 01/10/13 Theoretical Critical Vacuum: 13.90 (in. Hg)  
 Calibration Technician: CSB

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR. Vm(std) (ft <sup>3</sup> )	VOLUME CORR. Vm(std) (liters)
1.553	44.0
1.567	44.4
2.265	64.2
2.282	64.6
2.989	84.7
2.997	84.9
3.845	108.9
3.833	108.6
5.187	146.9
5.169	146.4

----- ORIFICE -----

VOLUME CORR. Vcr(std) (ft <sup>3</sup> )	VOLUME CORR. Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft <sup>3</sup> )
1.535	43.5	1.536
1.533	43.4	1.537
2.241	63.5	2.246
2.241	63.5	2.246
2.954	83.7	2.962
2.954	83.7	2.962
3.823	108.3	3.833
3.823	108.3	3.833
5.197	147.2	5.210
5.197	147.2	5.210

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number) <sup>1</sup>
0.9880	0.00
0.9786	-0.01
0.9891	0.00
0.9819	-0.01
0.9883	0.00
0.9857	-0.01
0.9942	0.00
0.9973	0.01
1.0019	0.01
1.0053	0.01
Average	0.9910
	0.00

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H2O)	Value (mm H2O)	Variation (in H2O) <sup>2</sup>
1.6505	41.92	-0.1
1.6521	41.96	-0.1
1.7668	44.88	0.0
1.7651	44.83	0.0
1.7434	44.28	0.0
1.7417	44.24	0.0
1.7949	45.59	0.0
1.7916	45.51	0.0
1.7842	45.32	0.0
1.7826	45.28	0.0
Average	1.7473	0.0
	44.38	0.0

Average Y =	0.9910
Average ΔH@ =	1.7473
Pass/Fail?	Pass

Notes:

<sup>1</sup> For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ± 0.02. Variations shown have been rounded to nearest 0.01.

<sup>2</sup> For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 deg F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is ± 0.2. Variations shown have been rounded to nearest 0.1.

QA/QC Performed By: David Recello

Date: 1/11/2013

**The Air Compliance Group, LLC  
EPA Method 5  
Meter Box Calibration  
Post-Test Orifice Method**

Meter Box # 16  
Date: 4/16/2013

Barometric Pressure: 29.090 (in. Hg)  
Theoretical Critical Vacuum: 13.72 (in. Hg)  
Calibration Technician: DCF

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
1.10	5.0	13.590	16.446	2.856	70	69	71	70
1.10	5.0	16.446	19.423	2.977	71	70	72	71
1.10	5.0	19.423	22.378	2.955	72	71	74	74

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in Hg)	Ambient Temperature			Average Temperature		
			Initial (deg F)	Final (deg F)	Average (deg F)	DGM Outlet (deg R)	DGM Overall (deg R)	Ambient Temp (deg R)
KX-55	0.4578	18	68	68	68	530	530	528
KX-55	0.4578	18	68	68	68	531	531	528
KX-55	0.4578	18	68	68	68	533	533	528

**IMPORTANT:**

For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

The Air Compliance Group, LLC  
EPA Method 5  
Meter Box Calibration  
Post-Test Orifice Method

Meter Box # 16  
Date: 04/16/13

Barometric Pressure: 29.09 (in. Hg)  
Theoretical Critical Vacuum: 13.72 (in. Hg)  
Calibration Technician: DCF

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR. Vm(std) (ft <sup>3</sup> )	VOLUME CORR. Vm(std) (liters)
2.773	78.5
2.885	81.7
2.854	80.8

----- ORIFICE -----

VOLUME CORR. Vcr(std) (ft <sup>3</sup> )	VOLUME CORR. Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft <sup>3</sup> )
2.898	82.1	2.982
2.898	82.1	2.982
2.898	82.1	2.982

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number)
1.0451	0.023
1.0045	-0.017
1.0153	-0.006

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H2O)	Value (mm H2O)	Variation (in H2O)
1.7859	45.36	0.004
1.7825	45.28	0.001
1.7758	45.11	-0.006

Average Y<sub>(post)</sub> 1.0216

Average dH@<sub>(post)</sub> 1.7814 45.25

<b>Calibration Factor Gamma (Y):</b>	<b>0.9910</b>
<b>Post Test Avg. Gamma (Y<sub>(post)</sub>):</b>	<b>1.0216</b>
<b>Variation:</b>	<b>0.0306</b>
<b>5% of Y:</b>	<b>0.0496</b>
<b>Variation ≤ 5% of Y?</b>	<b>Yes</b>

Note:

The Variation [absolute value of the Calibration Factor Gamma (Y) minus the Post Test Average Gamma (Y<sub>(post)</sub>)] must be less than or equal to 5% of Calibration Factor Gamma (Y).

QA/QC Performed By: David Recello

Date: 4/17/2013

**The Air Compliance Group, LLC**  
**EPA Method 5**  
**Meter Box Calibration**  
**Pre-Test Orifice Method**

Meter Box # 17Barometric Pressure: 28.95 (in. Hg)Date: 02/12/13Theoretical Critical Vacuum: 13.66 (in. Hg)Calibration Technician: CSB

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
0.31	5	514.819	516.416	1.597	68	66	68	66
0.31	5	516.416	518.014	1.598	68	66	68	66
0.65	5	518.014	520.337	2.323	68	66	69	67
0.65	5	520.337	522.671	2.334	69	67	69	67
1.2	5	522.671	525.722	3.051	69	67	69	67
1.2	5	525.722	528.798	3.076	69	67	69	68
2.0	5	528.798	532.785	3.987	69	68	70	68
2.0	5	532.785	536.763	3.978	70	68	70	68
3.6	5	536.763	542.126	5.363	70	68	70	68
3.6	5	542.126	547.476	5.350	70	68	70	68

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in Hg)	Ambient Temperature			DGM Outlet (deg R)	DGM Overall (deg R)	Ambient Temp (deg R)
			Initial (deg F)	Final (deg F)	Average (deg F)			
KS-40	0.2406	24	60	60	60	526	527	520
KS-40	0.2406	24	60	60	60	526	527	520
KS-48	0.3497	23	60	60	60	527	528	520
KS-48	0.3497	23	60	60	60	527	528	520
KS-55	0.4591	21	60	60	60	527	528	520
KS-55	0.4591	21	60	60	60	528	528	520
KS-63	0.5898	19	60	60	60	528	529	520
KS-63	0.5898	19	60	60	60	528	529	520
KS-73	0.8057	17	60	60	60	528	529	520
KS-73	0.8057	17	60	60	60	528	529	520

**IMPORTANT:**

For valid test results, the Actual Vacuum should be at least 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

The Air Compliance Group, LLC  
 EPA Method 5  
 Meter Box Calibration  
 Pre-Test Orifice Method

Meter Box # 17 Barometric Pressure: 28.95 (in. Hg)  
 Date: 02/12/13 Theoretical Critical Vacuum: 13.66 (in. Hg)  
 Calibration Technician: CSB

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR.	VOLUME CORR.
Vm(std)	Vm(std)
(ft <sup>3</sup> )	(liters)
1.549	43.9
1.550	43.9
2.253	63.8
2.261	64.0
2.960	83.8
2.983	84.5
3.870	109.6
3.860	109.3
5.225	148.0
5.212	147.6

----- ORIFICE -----

VOLUME CORR.	VOLUME CORR.	VOLUME NOMINAL
Vcr(std)	Vcr(std)	Vcr
(ft <sup>3</sup> )	(liters)	(ft <sup>3</sup> )
1.527	43.3	1.555
1.527	43.3	1.555
2.220	62.9	2.260
2.220	62.9	2.260
2.914	82.5	2.967
2.914	82.5	2.967
3.744	106.0	3.812
3.744	106.0	3.812
5.114	144.8	5.208
5.114	144.8	5.208

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value	Variation
(number)	(number) <sup>1</sup>
0.9861	0.01
0.9855	0.01
0.9854	0.01
0.9817	0.00
0.9846	0.00
0.9770	0.00
0.9673	-0.01
0.9700	-0.01
0.9789	0.00
0.9813	0.00

Average 0.9798 0.00

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value	Value	Variation
(in H2O)	(mm H2O)	(in H2O) <sup>2</sup>
1.8152	46.11	-0.1
1.8152	46.11	-0.1
1.8000	45.72	-0.1
1.7983	45.68	-0.1
1.9262	48.93	0.1
1.9244	48.88	0.1
1.9415	49.31	0.1
1.9415	49.31	0.1
1.8727	47.57	0.0
1.8727	47.57	0.0

Average 1.8708 47.52 0.0

Average Y =	0.9798
Average ΔH@ =	1.8708
Pass/Fail?	Pass

Notes:

<sup>1</sup> For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ± 0.02. Variations shown have been rounded to nearest 0.01.

<sup>2</sup> For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 deg F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is ± 0.2. Variations shown have been rounded to nearest 0.1.

QA/QC Performed By: David Recello

Date: 2/12/2013

**The Air Compliance Group, LLC**  
**EPA Method 5**  
**Meter Box Calibration**  
**Post-Test Orifice Method**

Meter Box # 17  
 Date: 4/16/2013

Barometric Pressure: 29.900 (in. Hg)  
 Theoretical Critical Vacuum: 14.10 (in. Hg)  
 Calibration Technician: dcf

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
1.20	5.0	228.645	231.670	3.025	64	63	65	64
1.20	5.0	231.670	234.707	3.037	65	64	66	64
1.20	5.0	234.707	237.751	3.044	66	64	66	65

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in Hg)	Ambient Temperature			Average Temperature		
			Initial (deg F)	Final (deg F)	Average (deg F)	DGM Outlet (deg R)	DGM Overall (deg R)	Ambient Temp (deg R)
KX-55	0.4578	21	60	60	60	524	524	520
KX-55	0.4578	21	60	60	60	524	525	520
KX-55	0.4578	21	60	60	60	525	525	520

**IMPORTANT:**

For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.



The Air Compliance Group, LLC  
 EPA Method 5  
 Meter Box Calibration  
 Post-Test Orifice Method

Meter Box # 17  
 Date: 04/16/13

Barometric Pressure: 29.90 (in. Hg)  
 Theoretical Critical Vacuum: 14.10 (in. Hg)  
 Calibration Technician: dcf

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR. Vm(std) (ft <sup>3</sup> )	VOLUME CORR. Vm(std) (liters)
3.054	86.5
3.062	86.7
3.066	86.8

----- ORIFICE -----

VOLUME CORR. Vcr(std) (ft <sup>3</sup> )	VOLUME CORR. Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft <sup>3</sup> )
3.001	85.0	2.959
3.001	85.0	2.959
3.001	85.0	2.959

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number)
0.9828	0.002
0.9803	0.000
0.9790	-0.002

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H2O)	Value (mm H2O)	Variation (in H2O)
1.8881	47.96	0.002
1.8863	47.91	0.000
1.8845	47.87	-0.002

Average Y<sub>(post)</sub> 0.9807

Average dH@<sub>(post)</sub> 1.8863 47.91

Calibration Factor Gamma (Y):	0.9798
Post Test Avg. Gamma (Y <sub>(post)</sub> ):	0.9807
Variation:	0.0009
5% of Y:	0.0490
Variation ≤ 5% of Y?	Yes

Note:

The Variation [absolute value of the Calibration Factor Gamma (Y) minus the Post Test Average Gamma (Y<sub>(post)</sub>)] must be less than or equal to 5% of Calibration Factor Gamma (Y).

QA/QC Performed By: David Recello

Date: 4/17/2013

**The Air Compliance Group, LLC  
EPA Method 5  
Meter Box Calibration  
Pre-Test Orifice Method**

Meter Box # 18Barometric Pressure: 29.300 (in. Hg)Date: 03/16/13Theoretical Critical Vacuum: 13.82 (in. Hg)Calibration Technician: MRW

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
0.34	5	570.417	572.042	1.625	68	67	68	67
0.34	5	572.042	573.665	1.623	68	67	69	68
0.75	5	573.665	576.043	2.378	69	68	69	68
0.75	5	576.043	578.419	2.376	69	68	70	68
1.3	5	578.419	581.563	3.144	70	68	70	69
1.3	5	581.563	584.718	3.155	70	69	71	70
2.2	5	584.718	588.754	4.036	71	70	72	70
2.2	5	588.754	592.783	4.029	72	70	73	70
4.1	5	592.783	598.271	5.488	73	70	74	71
4.1	5	598.271	603.776	5.505	74	71	76	71

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in. Hg)	Ambient Temperature			DGM Outlet (deg R)	Average Temperature		Ambient Temp (deg R)
			Initial (deg F)	Final (deg F)	Average (deg F)		DGM Overall (deg R)	Average (deg R)	
HB-40	0.2414	25	72	72	72	527	528	532	
HB-40	0.2414	25	72	72	72	528	528	532	
HB-48	0.3525	23	72	72	72	528	529	532	
HB-48	0.3525	23	72	72	72	528	529	532	
HB-55	0.4629	22	72	72	72	529	529	532	
HB-55	0.4629	22	72	72	72	530	530	532	
HB-63	0.5923	20	72	72	72	530	531	532	
HB-63	0.5923	20	72	72	72	530	531	532	
HB-73	0.8236	18	72	72	72	531	532	532	
HB-73	0.8236	18	72	72	72	531	533	532	

**IMPORTANT:**

For valid test results, the Actual Vacuum should be at least 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

The Air Compliance Group, LLC  
 EPA Method 5  
 Meter Box Calibration  
 Pre-Test Orifice Method

Meter Box # 18 Barometric Pressure: 29.30 (in. Hg)  
 Date: 03/16/13 Theoretical Critical Vacuum: 13.82 (in. Hg)  
 Calibration Technician: MRW

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR. Vm(std) (ft <sup>3</sup> )	VOLUME CORR. Vm(std) (liters)
1.594	45.1
1.590	45.0
2.330	66.0
2.327	65.9
3.080	87.2
3.087	87.4
3.952	111.9
3.941	111.6
5.387	152.5
5.393	152.7

----- ORIFICE -----

VOLUME CORR. Vcr(std) (ft <sup>3</sup> )	VOLUME CORR. Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft <sup>3</sup> )
1.533	43.4	1.578
1.533	43.4	1.578
2.239	63.4	2.305
2.239	63.4	2.305
2.940	83.3	3.026
2.940	83.3	3.026
3.762	106.5	3.872
3.762	106.5	3.872
5.231	148.1	5.384
5.231	148.1	5.384

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number) <sup>1</sup>
0.9622	0.00
0.9643	0.00
0.9609	0.00
0.9622	0.00
0.9545	-0.01
0.9525	-0.01
0.9519	-0.01
0.9545	-0.01
0.9711	0.01
0.9700	0.01
Average	0.9604
	0.00

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H2O)	Value (mm H2O)	Variation (in H2O) <sup>2</sup>
1.9954	50.68	-0.1
1.9935	50.63	-0.1
2.0603	52.33	0.0
2.0603	52.33	0.0
2.0690	52.55	0.0
2.0651	52.45	0.0
2.1325	54.17	0.1
2.1325	54.17	0.1
2.0535	52.16	0.0
2.0516	52.11	0.0
Average	2.0614	0.0
	52.36	0.0

Average Y =	0.9604
Average ΔH@ =	2.0614
Pass/Fail?	Pass

Notes:

<sup>1</sup> For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ± 0.02. Variations shown have been rounded to nearest 0.01.

<sup>2</sup> For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 deg F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is ± 0.2. Variations shown have been rounded to nearest 0.1.

QA/QC Performed By: David Recello

Date: 03/21/13

**The Air Compliance Group, LLC  
EPA Method 5  
Meter Box Calibration  
Post-Test Orifice Method**

Meter Box # 18  
Date: 4/16/2013

Barometric Pressure: 29.090 (in. Hg)  
Theoretical Critical Vacuum: 13.72 (in. Hg)  
Calibration Technician: DCF

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
1.30	5.0	24.605	27.674	3.069	71	70	72	71
1.30	5.0	27.674	30.756	3.082	72	71	72	71
1.30	5.0	30.756	33.836	3.080	72	71	73	71

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in Hg)	Ambient Temperature			Average Temperature		
			Initial (deg F)	Final (deg F)	Average (deg F)	DGM Outlet (deg R)	DGM Overall (deg R)	Ambient Temp (deg R)
KX-55	0.4591	22	64	64	64	531	531	524
KX-55	0.4591	22	64	64	64	531	532	524
KX-55	0.4591	22	64	64	64	531	532	524

**IMPORTANT:**

For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

The Air Compliance Group, LLC  
EPA Method 5  
Meter Box Calibration  
Post-Test Orifice Method

Meter Box # 18

Barometric Pressure: 29.09 (in. Hg)

Date: 04/16/13

Theoretical Critical Vacuum: 13.72 (in. Hg)

Calibration Technician: DCF

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR. Vm(std) (ft <sup>3</sup> )	VOLUME CORR. Vm(std) (liters)
2.976	84.3
2.985	84.5
2.982	84.5

----- ORIFICE -----

VOLUME CORR. Vcr(std) (ft <sup>3</sup> )	VOLUME CORR. Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft <sup>3</sup> )
2.917	82.6	2.979
2.917	82.6	2.979
2.917	82.6	2.979

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number)
0.9804	0.002
0.9771	-0.001
0.9782	0.000

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H <sub>2</sub> O)	Value (mm H <sub>2</sub> O)	Variation (in H <sub>2</sub> O)
2.0788	52.80	0.001
2.0769	52.75	-0.001
2.0769	52.75	-0.001

Average Y<sub>(post)</sub> 0.9786

Average dH@<sub>(post)</sub> 2.0775 52.77

Calibration Factor Gamma (Y):	0.9604
Post Test Avg. Gamma (Y <sub>(post)</sub> ):	0.9786
Variation:	0.0182
5% of Y:	0.0480
Variation ≤ 5% of Y?	Yes

Note:

The Variation [absolute value of the Calibration Factor Gamma (Y) minus the Post Test Average Gamma (Y<sub>(post)</sub>)] must be less than or equal to 5% of Calibration Factor Gamma (Y).

QA/QC Performed By: David Recello

Date: 4/17/2013

**The Air Compliance Group, LLC**  
**EPA Method 5**  
**Meter Box Calibration**  
**Pre-Test Orifice Method**

Meter Box # 19Barometric Pressure: 29.30 (in. Hg)Date: 01/07/13Theoretical Critical Vacuum: 13.82 (in. Hg)Calibration Technician: MSH

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
0.29	5	825.214	826.789	1.575	67.0	63.0	68.0	64.0
0.29	5	826.789	828.345	1.556	68.0	64.0	69.0	65.0
0.65	5	828.345	830.637	2.292	69.0	65.0	70.0	66.0
0.65	5	830.637	832.926	2.289	70.0	66.0	71.0	67.0
1.1	5	836.117	839.154	3.037	71.0	67.0	73.0	69.0
1.1	5	839.154	842.186	3.032	73.0	69.0	74.0	69.0
1.9	5	842.186	846.120	3.934	74.0	69.0	75.0	70.0
1.9	5	846.120	850.069	3.949	75.0	70.0	76.0	71.0
3.6	5	850.069	855.407	5.338	76.0	71.0	77.0	72.0
3.6	5	855.407	860.749	5.342	77.0	72.0	79.0	73.0

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in Hg)	Ambient Temperature			Average Temperature		Ambient Temp (deg R)
			Initial (deg F)	Final (deg F)	Average (deg F)	DGM Outlet (deg R)	DGM Overall (deg R)	
KS-40	0.2406	25.0	58.0	58.0	58.0	523.5	525.5	518.0
KS-40	0.2406	25.0	58.0	58.0	58.0	524.5	526.5	518.0
KS-48	0.3497	24.0	58.0	58.0	58.0	525.5	527.5	518.0
KS-48	0.3497	24.0	60.0	60.0	60.0	526.5	528.5	520.0
KS-55	0.4591	23.0	60.0	60.0	60.0	528.0	530.0	520.0
KS-55	0.4591	23.0	60.0	60.0	60.0	529.0	531.3	520.0
KS-63	0.5898	21.0	60.0	60.0	60.0	529.5	532.0	520.0
KS-63	0.5898	21.0	60.0	60.0	60.0	530.5	533.0	520.0
KS-73	0.8057	18.0	60.0	60.0	60.0	531.5	534.0	520.0
KS-73	0.8057	18.0	60.0	60.0	60.0	532.5	535.3	520.0

**IMPORTANT:**

For valid test results, the Actual Vacuum should be at least 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

The Air Compliance Group, LLC  
 EPA Method 5  
 Meter Box Calibration  
 Pre-Test Orifice Method

Meter Box # 19 Barometric Pressure: 29.30 (in. Hg)  
 Date: 01/07/13 Theoretical Critical Vacuum: 13.82 (in. Hg)  
 Calibration Technician: MSH

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR. Vm(std) (ft <sup>3</sup> )	VOLUME CORR. Vm(std) (liters)
1.550	43.9
1.529	43.3
2.249	63.7
2.242	63.5
2.970	84.1
2.958	83.8
3.840	108.8
3.848	109.0
5.213	147.6
5.205	147.4

----- ORIFICE -----

VOLUME CORR. Vcr(std) (ft <sup>3</sup> )	VOLUME CORR. Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft <sup>3</sup> )
1.549	43.9	1.552
1.549	43.9	1.552
2.251	63.7	2.256
2.247	63.6	2.260
2.949	83.5	2.967
2.949	83.5	2.967
3.789	107.3	3.812
3.789	107.3	3.812
5.176	146.6	5.208
5.176	146.6	5.208

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number) <sup>1</sup>
0.9990	0.00
1.0132	0.02
1.0007	0.00
1.0020	0.01
0.9931	0.00
0.9971	0.00
0.9867	-0.01
0.9848	-0.01
0.9929	0.00
0.9945	0.00
Average	0.9964

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H2O)	Value (mm H2O)	Variation (in H2O) <sup>2</sup>
1.6793	42.66	-0.1
1.6761	42.57	-0.1
1.7750	45.09	0.0
1.7785	45.17	0.0
1.7413	44.23	0.0
1.7380	44.14	0.0
1.8172	46.16	0.0
1.8138	46.07	0.0
1.8381	46.69	0.1
1.8347	46.60	0.1
Average	1.7692	0.0

Average Y =	0.9964
Average ΔH@ =	1.7692
Pass/Fail?	Pass

Notes:

<sup>1</sup> For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ± 0.02. Variations shown have been rounded to nearest 0.01.

<sup>2</sup> For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 deg F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is ± 0.2. Variations shown have been rounded to nearest 0.1.

QA/QC Performed By: David Recello Date: 1/11/2013

**The Air Compliance Group, LLC  
EPA Method 5  
Meter Box Calibration  
Post-Test Orifice Method**

Meter Box # 19  
Date: 4/16/2013

Barometric Pressure: 29.090 (in. Hg)  
Theoretical Critical Vacuum: 13.72 (in. Hg)  
Calibration Technician: DCF

----- **DRY GAS METER READINGS** -----

$\Delta H$ (in H <sub>2</sub> O)	Time (min)	Volume Initial (ft <sup>3</sup> )	Volume Final (ft <sup>3</sup> )	Volume Total (ft <sup>3</sup> )	Initial Temperature		Final Temperature	
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)
1.10	5.0	93.920	96.906	2.986	73	72	75	73
1.10	5.0	96.906	99.908	3.002	75	73	75	73
1.10	5.0	99.908	102.913	3.005	75	73	76	74

----- **CRITICAL ORIFICE READINGS** -----

Orifice Serial# (number)	K' Orifice Coefficient	Actual Vacuum (in Hg)	Ambient Temperature			Average Temperature		
			Initial (deg F)	Final (deg F)	Average (deg F)	DGM Outlet (deg R)	DGM Overall (deg R)	Ambient Temp (deg R)
KX-55	0.4591	22	70	70	70	533	533	530
KX-55	0.4591	22	70	70	70	533	534	530
KX-55	0.4591	22	70	70	70	534	535	530

**IMPORTANT:**

For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.



The Air Compliance Group, LLC  
 EPA Method 5  
 Meter Box Calibration  
 Post-Test Orifice Method

Meter Box # 19  
 Date: 04/16/13

Barometric Pressure: 29.09 (in. Hg)  
 Theoretical Critical Vacuum: 13.72 (in. Hg)  
 Calibration Technician: DCF

\*\*\*\*\* RESULTS \*\*\*\*\*

----- DRY GAS METER -----

VOLUME CORR. Vm(std) (ft <sup>3</sup> )	VOLUME CORR. Vm(std) (liters)
2.881	81.6
2.893	81.9
2.893	81.9

----- ORIFICE -----

VOLUME CORR. Vcr(std) (ft <sup>3</sup> )	VOLUME CORR. Vcr(std) (liters)	VOLUME NOMINAL Vcr (ft <sup>3</sup> )
2.901	82.1	2.996
2.901	82.1	2.996
2.901	82.1	2.996

----- DRY GAS METER -----

CALIBRATION FACTOR	
"Y" Value (number)	Variation (number)
1.0066	0.003
1.0027	-0.001
1.0026	-0.001

----- ORIFICE -----

CALIBRATION FACTOR		
"ΔH@" Value (in H2O)	Value (mm H2O)	Variation (in H2O)
1.7725	45.02	0.002
1.7708	44.98	0.000
1.7691	44.94	-0.002

Average Y<sub>(post)</sub> 1.0040

Average dH@<sub>(post)</sub> 1.7708 44.98

Calibration Factor Gamma (Y):	0.9964
Post Test Avg. Gamma (Y <sub>(post)</sub> ):	1.0040
Variation:	0.0076
5% of Y:	0.0498
Variation ≤ 5% of Y?	Yes

Note:

The Variation [absolute value of the Calibration Factor Gamma (Y) minus the Post Test Average Gamma (Y<sub>(post)</sub>)] must be less than or equal to 5% of Calibration Factor Gamma (Y).

QA/QC Performed By: David Recello

Date: 4/17/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 4

Date: 1/12/2013

Meter Box Thermocouple: Stack Temp.

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	33	0.2
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	500	0.0
8	600	600	0.0
9	700	700	0.0
10	800	801	0.1
11	900	900	0.0

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be ≤ 1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/14/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 4

Date: 1/12/2013

Meter Box Thermocouple: Probe Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	52	4.1
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	500	0.0

<b>Average<sup>b</sup></b>	<b>0.6</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq 1.5\%$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/14/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 4

Date: 1/12/2013

Meter Box Thermocouple: Filter Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	33	0.2
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	500	0.0

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be ≤ 1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/14/2013

## THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 4

Date: 1/12/2013

Meter Box Thermocouple: Aux. (High)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	401	0.1
7	500	500	0.0
8	600	600	0.0
9	700	701	0.1
10	800	799	0.1
11	900	899	0.1

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq 1.5\%$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/14/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 4

Date: 1/12/2013

Meter Box Thermocouple: Impinger Exit / XAD Condenser

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	11	1
3	20	19	1
4	32	32	0
5	40	41	1
6	50	50	0
7	60	60	0
8	68	67	1

<b>Average</b>	<b>1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/14/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 4

Date: 1/12/2013

Meter Box Thermocouple: Aux. (Low)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	10	0
3	20	21	1
4	32	32	0
5	40	41	1
6	50	50	0
7	60	60	0
8	68	68	0
9	80	80	0
10	90	91	1
11	100	100	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/14/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 4

Date: 1/12/2013

Meter Box Thermocouple: Meter Inlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	32	0
3	50	50	0
4	68	68	0
5	80	80	0
6	90	90	0
7	100	101	1
8	110	111	1
9	120	121	1
10	130	130	0
11	140	140	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/14/2013



### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 4

Date: 1/12/2013

Meter Box Thermocouple: Meter Outlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	32	0
3	50	50	0
4	68	68	0
5	80	80	0
6	90	90	0
7	100	101	1
8	110	111	1
9	120	120	0
10	130	130	0
11	140	140	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4$  °F.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/14/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 16

Date: 1/12/2013

Meter Box Thermocouple: Stack Temp.

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	1	0.2
2	32	32	0.0
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	501	0.1
8	600	600	0.0
9	700	700	0.0
10	800	801	0.1
11	900	900	0.0

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq$  1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Vecellio*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 16

Date: 1/12/2013

Meter Box Thermocouple: Probe Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	33	0.2
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	501	0.1

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be ≤ 1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 16

Date: 1/12/2013

Meter Box Thermocouple: Filter Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	100	0.0
4	212	212	0.0
5	300	300	0.0
6	400	401	0.1
7	500	501	0.1

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be ≤ 1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

## THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 16

Date: 1/12/2013

Meter Box Thermocouple: Aux. (High)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	100	0.0
4	212	212	0.0
5	300	301	0.1
6	400	400	0.0
7	500	500	0.0
8	600	601	0.1
9	700	700	0.0
10	800	801	0.1
11	900	900	0.0

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq 1.5\%$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 16

Date: 1/12/2013

Meter Box Thermocouple: Impinger Exit / XAD Condenser

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	11	1
3	20	20	0
4	32	33	1
5	40	40	0
6	50	50	0
7	60	60	0
8	68	67	1

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 16

Date: 1/12/2013

Meter Box Thermocouple: Aux. (Low)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	10	0
3	20	20	0
4	32	32	0
5	40	40	0
6	50	51	1
7	60	61	1
8	68	68	0
9	80	80	0
10	90	90	0
11	100	100	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 16

Date: 1/12/2013

Meter Box Thermocouple: Meter Inlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	33	1
3	50	50	0
4	68	68	0
5	80	81	1
6	90	90	0
7	100	100	0
8	110	111	1
9	120	121	1
10	130	130	0
11	140	140	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013



### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 16

Date: 1/12/2013

Meter Box Thermocouple: Meter Outlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	32	0
3	50	50	0
4	68	67	1
5	80	80	0
6	90	91	1
7	100	100	0
8	110	110	0
9	120	121	1
10	130	130	0
11	140	140	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4$  °F.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 17

Date: 1/12/2013

Meter Box Thermocouple: Stack Temp.

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	100	0.0
4	212	212	0.0
5	300	301	0.1
6	400	400	0.0
7	500	500	0.0
8	600	601	0.1
9	700	700	0.0
10	800	800	0.0
11	900	901	0.1

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be ≤ 1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 17

Date: 1/12/2013

Meter Box Thermocouple: Probe Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	401	0.1
7	500	500	0.0

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq$  1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 17

Date: 1/12/2013

Meter Box Thermocouple: Filter Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	33	0.2
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	401	0.1
7	500	500	0.0

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be ≤ 1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

## THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 17

Date: 1/12/2013

Meter Box Thermocouple: Aux. (High)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	31	0.2
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	500	0.0
8	600	601	0.1
9	700	700	0.0
10	800	800	0.0
11	900	901	0.1

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq 1.5\%$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 17

Date: 1/12/2013

Meter Box Thermocouple: Impinger Exit / XAD Condenser

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	10	0
3	20	20	0
4	32	32	0
5	40	41	1
6	50	51	1
7	60	60	0
8	68	67	1

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 17

Date: 1/12/2013

Meter Box Thermocouple: Aux. (Low)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	10	0
3	20	20	0
4	32	32	0
5	40	40	0
6	50	50	0
7	60	60	0
8	68	68	0
9	80	80	0
10	90	90	0
11	100	100	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 17

Date: 1/12/2013

Meter Box Thermocouple: Meter Inlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	32	0
3	50	50	0
4	68	68	0
5	80	81	1
6	90	91	1
7	100	101	1
8	110	110	0
9	120	120	0
10	130	130	0
11	140	140	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013



### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 17

Date: 1/12/2013

Meter Box Thermocouple: Meter Outlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	32	0
3	50	50	0
4	68	67	1
5	80	80	0
6	90	90	0
7	100	101	1
8	110	111	1
9	120	120	0
10	130	130	0
11	140	140	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4$  °F.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 18

Date: 1/12/2013

Meter Box Thermocouple: Stack Temp.

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	100	0.0
4	212	213	0.1
5	300	300	0.0
6	400	400	0.0
7	500	501	0.1
8	600	601	0.1
9	700	700	0.0
10	800	799	0.1
11	900	900	0.0

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq$  1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Vecellio*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 18

Date: 1/12/2013

Meter Box Thermocouple: Probe Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	100	0.0
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	500	0.0

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq 1.5\%$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 18

Date: 1/12/2013

Meter Box Thermocouple: Filter Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	101	0.2
4	212	212	0.0
5	300	301	0.1
6	400	401	0.1
7	500	500	0.0

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be ≤ 1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

## THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 18

Date: 1/12/2013

Meter Box Thermocouple: Aux. (High)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	500	0.0
8	600	600	0.0
9	700	700	0.0
10	800	801	0.1
11	900	900	0.0

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq 1.5\%$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 18

Date: 1/12/2013

Meter Box Thermocouple: Impinger Exit / XAD Condenser

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	10	0
3	20	20	0
4	32	32	0
5	40	40	0
6	50	51	1
7	60	60	0
8	68	67	1

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 18

Date: 1/12/2013

Meter Box Thermocouple: Aux. (Low)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	10	0
3	20	20	0
4	32	32	0
5	40	40	0
6	50	50	0
7	60	60	0
8	68	67	1
9	80	81	1
10	90	90	0
11	100	100	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 18

Date: 1/12/2013

Meter Box Thermocouple: Meter Inlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	32	0
3	50	50	0
4	68	68	0
5	80	80	0
6	90	91	1
7	100	101	1
8	110	110	0
9	120	120	0
10	130	130	0
11	140	141	1

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013



### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 18

Date: 1/12/2013

Meter Box Thermocouple: Meter Outlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	32	0
3	50	51	1
4	68	67	1
5	80	81	1
6	90	90	0
7	100	100	0
8	110	110	0
9	120	120	0
10	130	130	0
11	140	141	1

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4$  °F.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 19

Date: 1/12/2013

Meter Box Thermocouple: Stack Temp.

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	1	0.2
2	32	32	0.0
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	501	0.1
8	600	600	0.0
9	700	700	0.0
10	800	801	0.1
11	900	900	0.0

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq$  1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Vecellio*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 19

Date: 1/12/2013

Meter Box Thermocouple: Probe Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	33	0.2
3	100	101	0.2
4	212	212	0.0
5	300	300	0.0
6	400	400	0.0
7	500	501	0.1

<b>Average<sup>b</sup></b>	<b>0.1</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be ≤ 1.5%.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 19

Date: 1/12/2013

Meter Box Thermocouple: Filter Heat

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	100	0.0
4	212	212	0.0
5	300	300	0.0
6	400	401	0.1
7	500	501	0.1

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq 1.5\%$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

## THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 19

Date: 1/12/2013

Meter Box Thermocouple: Aux. (High)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (%)
1	0	0	0.0
2	32	32	0.0
3	100	100	0.0
4	212	212	0.0
5	300	301	0.1
6	400	400	0.0
7	500	500	0.0
8	600	601	0.1
9	700	700	0.0
10	800	801	0.1
11	900	900	0.0

<b>Average<sup>b</sup></b>	<b>0.0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

a Difference, % (Based on degrees Rankin):

$$\text{Absolute Difference} = \frac{|(\text{Ref. Temp.} + 460) - (\text{TC Temp.} + 460)|}{\text{Ref. Temp.} + 460} \times 100$$

b Average Absolute Difference must be  $\leq 1.5\%$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 19

Date: 1/12/2013

Meter Box Thermocouple: Impinger Exit / XAD Condenser

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	11	1
3	20	20	0
4	32	33	1
5	40	40	0
6	50	50	0
7	60	60	0
8	68	67	1

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 19

Date: 1/12/2013

Meter Box Thermocouple: Aux. (Low)

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	10	10	0
3	20	20	0
4	32	32	0
5	40	40	0
6	50	51	1
7	60	61	1
8	68	68	0
9	80	80	0
10	90	90	0
11	100	100	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 2^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 19

Date: 1/12/2013

Meter Box Thermocouple: Meter Inlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	33	1
3	50	50	0
4	68	68	0
5	80	81	1
6	90	90	0
7	100	100	0
8	110	111	1
9	120	121	1
10	130	130	0
11	140	140	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4^\circ\text{F}$ .

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013



### THERMOCOUPLE CALIBRATION DATA

Meter Box ID: 19

Date: 1/12/2013

Meter Box Thermocouple: Meter Outlet

Reference Calibrator ID: T-259402

Reference Calibrator Model: HH-20-CAL

Reference Calibrator Type: J-K-T

Reference Point	Reference Temperature (°F)	Thermocouple Temperature (°F)	Absolute Difference <sup>a</sup> (°F)
1	0	0	0
2	32	32	0
3	50	50	0
4	68	67	1
5	80	80	0
6	90	91	1
7	100	100	0
8	110	110	0
9	120	121	1
10	130	130	0
11	140	140	0

<b>Average</b>	<b>0</b>
<b>Pass/Fail ?</b>	<b>Pass</b>

(a) Absolute Difference must be  $\leq 5.4$  °F.

Calibration Performed By: MRW

Date: 1/12/2013

QA/QC Check Performed By: *David Recello*

Date: 1/15/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/18/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 4

Probe Stack TC ID: FP 8-3

Umbilical ID: UF 100-2

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
68	<u>Probe Stack TC</u> 69	1	Pass
68	<u>Meter Inlet TC</u> 67	-1	Pass
68	<u>Meter Outlet TC</u> 66	-2	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/18/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/18/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 4

Probe Stack TC ID: PL 9-6

Umbilical ID: U-50-2

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
66	<u>Probe Stack TC</u> 67	1	Pass
66	<u>Meter Inlet TC</u> 65	-1	Pass
66	<u>Meter Outlet TC</u> 66	0	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/18/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/18/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 4

Probe Stack TC ID: PL 9-7

Umbilical ID: PU-56-1

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
70	<u>Probe Stack TC</u> 69	-1	Pass
70	<u>Meter Inlet TC</u> 69	-1	Pass
70	<u>Meter Outlet TC</u> 70	0	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/18/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/18/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 16

Probe Stack TC ID: PL 9-4

Umbilical ID: PU-50-2

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
70	<u>Probe Stack TC</u> 69	-1	Pass
71	<u>Meter Inlet TC</u> 70	-1	Pass
71	<u>Meter Outlet TC</u> 70	-1	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC     must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/18/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/19/2013

Job ID: reen Conversion System

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 16

Probe Stack TC ID: PL 9-2

Umbilical ID: PU-50-2

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
68	<u>Probe Stack TC</u> 67	-1	Pass
68	<u>Meter Inlet TC</u> 67	-1	Pass
67	<u>Meter Outlet TC</u> 66	-1	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/19/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/18/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 17

Probe Stack TC ID: PL 10-2

Umbilical ID: U-50-4

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
69	<u>Probe Stack TC</u> 70	1	Pass
67	<u>Meter Inlet TC</u> 69	2	Pass
69	<u>Meter Outlet TC</u> 70	1	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/18/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/19/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 17

Probe Stack TC ID: PL 10-1

Umbilical ID: U-50-4

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
68	<u>Probe Stack TC</u> 67	-1	Pass
67	<u>Meter Inlet TC</u> 67	0	Pass
67	<u>Meter Outlet TC</u> 67	0	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/19/2013



**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/18/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 18

Probe Stack TC ID: PL 9-6

Umbilical ID: U-50-2

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
70	<u>Probe Stack TC</u> 71	1	Pass
69	<u>Meter Inlet TC</u> 68	-1	Pass
70	<u>Meter Outlet TC</u> 70	0	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/18/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/19/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 18

Probe Stack TC ID: PL 9-1

Umbilical ID: U-50-2

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
66	<u>Probe Stack TC</u> 64	-2	Pass
66	<u>Meter Inlet TC</u> 65	-1	Pass
65	<u>Meter Outlet TC</u> 65	0	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/19/2013

**The Air Compliance Group, LLC**  
**Post-Test Thermocouple System Calibration Form**  
**(EPA ALT-011)**

Date: 4/18/2013

Job ID: Green Conversion Systems

Performed By: MSH

Contract No.: V13030

Reference Thermometer ID: ASTM 7

Meter Box ID: 19

Probe Stack TC ID: PL-7-4

Umbilical ID: U-50-1

Meter Inlet TC ID: DGM IN

Meter Outlet TC ID: DGM OUT

Reference Temp. (°F) <sup>1</sup>	Post-Test Temp. (°F)	Difference (°F) <sup>2</sup>	Pass/Fail
70	<u>Probe Stack TC</u> 69	-1	Pass
68	<u>Meter Inlet TC</u> 69	1	Pass
71	<u>Meter Outlet TC</u> 70	-1	Pass

Acceptance Criteria

<sup>1</sup> Must be at ambient temperature, or any other temperature, within the range specified by the manufacturer.

<sup>2</sup> Must meet the following temperature differences:

Probe Stack TC      must be within ± 2°F of the reference temperature.

Meter Inlet TC      must be within ± 2°F of the reference temperature.

Meter Outlet TC      must be within ± 2°F of the reference temperature.

QA/QC Performed By: 

Date: 4/18/2013

## **Appendix M.3**

### **Gas Analyzer Calibration and Related Data**

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number: E03NI77E15AC592	Reference Number: 54-124356176-1
Cylinder Number: CC202388	Cylinder Volume: 151.5 CF
Laboratory: ASG - Chicago - IL	Cylinder Pressure: 2015 PSIG
PGVP Number: B12013	Valve Outlet: 590
Gas Code: CO <sub>2</sub> ,O <sub>2</sub>	Certification Date: Jan 30, 2013

**Expiration Date: Jan 30, 2021**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

<b>ANALYTICAL RESULTS</b>					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	10.60 %	10.46 %	G1	+/- 1% NIST Traceable	01/30/2013
OXYGEN	12.00 %	11.84 %	G1	+/- 1% NIST Traceable	01/30/2013
NITROGEN	Balance				

<b>CALIBRATION STANDARDS</b>					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM/CO <sub>2</sub>	06120403	CC185079	19.66 % CARBON DIOXIDE/NITROGEN	+/- 0.5%	May 01, 2016
NTRM/O <sub>2</sub>	06120202	CC195927	20.9 % OXYGEN/NITROGEN	+/- 0.4%	Dec 01, 2015

<b>ANALYTICAL EQUIPMENT</b>		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
CO <sub>2</sub> -1 HORIBA VIA-510 V1E3H7P5	NDIR	Jan 28, 2013
O <sub>2</sub> -1 HORIBA MPA-510 3VUYL9NR	Paramagnetic	Jan 08, 2013

**Triad Data Available Upon Request**

Notes:

**Signature on file**

**Approved for Release**

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number: E03NI60E15A2996	Reference Number: 54-124307341-1
Cylinder Number: CC43457	Cylinder Volume: 158.9 CF
Laboratory: ASG - Chicago - IL	Cylinder Pressure: 2015 PSIG
PGVP Number: B12012	Valve Outlet: 590
Gas Code: OC2	Analysis Date: Mar 12, 2012

**Expiration Date: Mar 12, 2020**

This cylinder has been analytically certified as directly traceable to NIST with a total analytical uncertainty as stated below with a confidence level of 95%, in accordance with Airgas ISO procedures. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder Below 150 psig. i.e. 1 Mega Pascal

<b>ANALYTICAL RESULTS</b>				
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty
CARBON DIOXIDE	19.00 %	18.70 %	G1	+/- 1% NIST Traceable
OXYGEN	21.00 %	20.95 %	G1	+/- 1% NIST Traceable
NITROGEN	Balance			

<b>CALIBRATION STANDARDS</b>				
Type	Lot ID	Cylinder No	Concentration	Expiration Date
NTRM/CO2	06120403	CC184925	19.66 % CARBON DIOXIDE/NITROGEN	May 01, 2016
NTRM/O2	06120209	CC195927	20.9 % OXYGEN/NITROGEN	Dec 01, 2015

<b>ANALYTICAL EQUIPMENT</b>		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
CO2-1 HORIBA VIA-510 V1E3H7P5	NDIR	Feb 26, 2012
O2-1 HORIBA MPA-510 3VUYL9NR	Paramagnetic	Feb 27, 2012

**Triad Data Available Upon Request**

Notes:

**Signature on file**

---

**Approved for Release**

## CERTIFICATE OF BATCH ANALYSIS

### NITROGEN - CEM-CAL ZERO

Part Number:	NI CZ300	Reference Number:	40-400045487-1
Cylinder Analyzed:	SG1020754	Cylinder Volume:	304.0 CF
Laboratory:	MID - Saint Louis SGL (SAP) - MO	Cylinder Pressure:	2640 PSIG
Analysis Date:	Mar 05, 2012	Valve Outlet:	580
Lot Number:	40-400045487-1		

**Expiration Date: Mar 05, 2015**

---

#### ANALYTICAL RESULTS

Component	Requested Purity	Certified Concentration
CARBON DIOXIDE	< 1.0 PPM	<LDL 0.12 PPM
Moisture	< 1.0 PPM	0.080 PPM
NOx	< 0.1 PPM	0.10 PPM
SO2	< 0.1 PPM	0.10 PPM
THC	< 0.1 PPM	0.04 PPM
CARBON MONOXIDE	< 0.5 PPM	<LDL 0.12 PPM
Oxygen	< 0.5 PPM	0.47 PPM
NitrogenCEM	99.9995 %	99.9995 %

Permanent Notes: Airgas certifies that the contents of this cylinder meet the requirements of 40 CFR 72.

Cylinders in Batch:

38742, C66914, SG1020754

Notes:

---

**Impurities verified against analytical standards traceable to NIST by weight and/or analysis.**

Signature on file

---

**Approved for Release**

### ANALYZER CALIBRATION DATA

JOB I.D.:	GCS Pinellas
CONTRACT NO.:	V13030
TECHNICIAN:	KMH

TEST METHOD/ANALYTICAL METHOD: Test Method - Method 3 / Analytical Method - Method 3A

TEST LOCATION: Units 1 and 3

TEST DATE: 4/9/2013

ANALYZER: Oxygen

DATE OF ANALYSIS: 4/9/2013

REPORTING UNITS (ppm,%): % dv

SPAN: 20.95

RANGE	GAS CYLINDER ID	GAS VALUE (%dv)	ANALYZER RESPONSE (%dv)	ABSOLUTE DIFFERENCE (%dv)	CAL ERROR (% OF SPAN)
ZERO	70037	0.00	0.01	0.0	0.0
MID	4013	11.84	12.01	0.2	0.8
HIGH	4025	20.95	20.97	0.0	0.1
OTHER					

TEST METHOD/ANALYTICAL METHOD: Test Method - Method 3 / Analytical Method - Method 3A

TEST LOCATION: Units 1 and 3

TEST DATE: 4/9/2013

ANALYZER: Carbon Dioxide

DATE OF ANALYSIS: 4/9/2013

REPORTING UNITS (ppm,%): % dv

SPAN: 18.7

RANGE	GAS CYLINDER ID	GAS VALUE (%dv)	ANALYZER RESPONSE (%dv)	ABSOLUTE DIFFERENCE (%dv)	CAL ERROR (% OF SPAN)
ZERO	70037	0.00	-0.01	0.0	0.1
MID	4013	10.46	10.55	0.1	0.5
HIGH	4025	18.70	18.72	0.0	0.1
OTHER					

Note: The allowable calibration error is 2% of span.



### ANALYZER CALIBRATION DATA

JOB I.D.:	GCS Pinellas
CONTRACT NO.:	V13030
TECHNICIAN:	KMH

TEST METHOD/ANALYTICAL METHOD: Test Method - Method 3 / Analytical Method - Method 3A  
 TEST LOCATION: Units 1 and 2 TEST DATE: 4/10/2013  
 ANALYZER: Oxygen DATE OF ANALYSIS: 4/10/2013  
 REPORTING UNITS (ppm,%): % dv SPAN: 20.95

RANGE	GAS CYLINDER ID	GAS VALUE (%dv)	ANALYZER RESPONSE (%dv)	ABSOLUTE DIFFERENCE (%dv)	CAL ERROR (% OF SPAN)
ZERO	70037	0.00	-0.01	0.0	0.0
MID	4013	11.84	11.98	0.1	0.7
HIGH	4025	20.95	20.96	0.0	0.0
OTHER					

TEST METHOD/ANALYTICAL METHOD: Test Method - Method 3 / Analytical Method - Method 3A  
 TEST LOCATION: Units 1 and 2 TEST DATE: 4/10/2013  
 ANALYZER: Carbon Dioxide DATE OF ANALYSIS: 4/10/2013  
 REPORTING UNITS (ppm,%): % dv SPAN: 18.7

RANGE	GAS CYLINDER ID	GAS VALUE (%dv)	ANALYZER RESPONSE (%dv)	ABSOLUTE DIFFERENCE (%dv)	CAL ERROR (% OF SPAN)
ZERO	70037	0.00	0.00	0.0	0.0
MID	4013	10.46	10.53	0.1	0.4
HIGH	4025	18.70	18.72	0.0	0.1
OTHER					

Note: The allowable calibration error is 2% of span.

### ANALYZER CALIBRATION DATA

JOB I.D.:	GCS Pinellas
CONTRACT NO.:	V13030
TECHNICIAN:	KMH

TEST METHOD/ANALYTICAL METHOD: Test Method - Method 3 / Analytical Method - Method 3A  
 TEST LOCATION: Units 1 and 2 TEST DATE: 4/11/2013  
 ANALYZER: Oxygen DATE OF ANALYSIS: 4/11/2013  
 REPORTING UNITS (ppm,%): % dv SPAN: 20.95

RANGE	GAS CYLINDER ID	GAS VALUE (%dv)	ANALYZER RESPONSE (%dv)	ABSOLUTE DIFFERENCE (%dv)	CAL ERROR (% OF SPAN)
ZERO	70037	0.00	0.01	0.0	0.0
MID	4013	11.84	11.99	0.2	0.7
HIGH	4025	20.95	20.96	0.0	0.0
OTHER					

TEST METHOD/ANALYTICAL METHOD: Test Method - Method 3 / Analytical Method - Method 3A  
 TEST LOCATION: Units 1 and 2 TEST DATE: 4/11/2013  
 ANALYZER: Carbon Dioxide DATE OF ANALYSIS: 4/11/2013  
 REPORTING UNITS (ppm,%): % dv SPAN: 18.7

RANGE	GAS CYLINDER ID	GAS VALUE (%dv)	ANALYZER RESPONSE (%dv)	ABSOLUTE DIFFERENCE (%dv)	CAL ERROR (% OF SPAN)
ZERO	70037	0.00	0.00	0.0	0.0
MID	4013	10.46	10.52	0.1	0.3
HIGH	4025	18.70	18.71	0.0	0.1
OTHER					

Note: The allowable calibration error is 2% of span.



# Model 602 CO<sub>2</sub> Interference Data

## Interference Response

Date of Test \_\_\_\_\_ 6/28/2006  
Analyzer Type \_\_\_\_\_ CO2  
Model No. \_\_\_\_\_ 602  
Serial No. \_\_\_\_\_ T04050  
Calibration Span \_\_\_\_\_ 10%

Test Gas Type	Concentration	Analyzer Response	
		Wet	Dry
	(ppm)		
H2O	2.5%	0.01	0
CO	50	0	0
CH4	50	0.01	0
SO2	20	0	0
NH3	15	0	0
NO	13	0.01	0
N2O	11	0.02	0.01
NO2	9	0.01	0

## 10. MAINTENANCE

### Warning

All replacement parts must be as supplied and/or specified by California Analytical Instruments. Failure to use specified parts may reduce the safety features of the instrument or create a hazardous condition.

#### 10.1. Zero and Span Calibration

The zero and span levels should be checked and/or calibrated daily (or as often as required.)

**Note: On the 0-25% range of the analyzer ambient air may be used as span gas. While flowing ambient air to the analyzer adjust the span potentiometer to 20.9% O<sub>2</sub>.**

#### 10.2. Routine Maintenance:

Prepare and check the sample system. Adjust the flow of sample gas to about 1 L/min. The instrument should show a meter indication. The paramagnetic oxygen analyzer is designed for extended operation and may be left switched ON continuously.

#### 10.3. Cross sensitivity of gases

The paramagnetic measuring principle is based on the very high magnetic susceptibility of oxygen. In comparison to oxygen, other gases have such a minor susceptibility that most of them are insignificant. Exceptions to this are the nitrogen oxides. However, as these gases are in most cases present in a very low concentration, the error is still negligible.

##### 10.3.1. Example 1

The residual oxygen percentage is measured in a closed carbon dioxide (CO<sub>2</sub>) atmosphere. The "zero calibration" is done by means of nitrogen (N<sub>2</sub>)-0.1080

According to the list of cross-sensitivities, the error for 100 % CO<sub>2</sub> at 20° C is 0.27%. In order to obtain a higher accuracy, this means that for the zero calibration the reading should be adjusted at +0.27% with N<sub>2</sub>, in order to compensate the error of CO<sub>2</sub>.

Since the values of cross-sensitivities are based on 100% volume of that particular gas, the error at 50% by volume CO<sub>2</sub> and 50% by volume N<sub>2</sub> is 0.135%.

##### 10.3.2. Example 2

Given the following gas composition at a temperature of 20° C:

5% volume Oxygen (O <sub>2</sub> )	$+100.00 \times 10^{-2} \times 5$	=	+5.0000
40% volume Carbon Dioxide(CO <sub>2</sub> )	$-0.27 \times 10^{-2} \times 40$	=	-0.1080
1% volume Ethane(C <sub>2</sub> H <sub>6</sub> )	$-0.43 \times 10^{-2} \times 1$	=	-0.0043
54% volume Nitrogen (N <sub>2</sub> )	$0.00 \times 10^{-2} \times 54$	=	0.0000
Gives a reading (% by volume) of:			<u>+4.8877</u>

As this example shows, the total error (5.000 minus 4.8877) is 0.1123.

**Note: see Table 4-1 below for cross sensitivity values of typical gases.**

Table 4-1 Cross Sensitivity of gases

All values based on nitrogen 0% / oxygen 100%

Gas	Formula	20 °C	50 °C
Argon	Ar	-0.23	-0.25
Acetylene	C <sub>2</sub> H <sub>2</sub>	-0.26	-0.28
Acetone	C <sub>3</sub> H <sub>6</sub> O	-0.63	-0.69
Acetaidehyde	C <sub>2</sub> H <sub>4</sub> O	-0.31	-0.34
Ammonia	N <sub>3</sub>	-0.17	-0.19
Benzene	C <sub>6</sub> H <sub>4</sub>	-1.24	-1.34
Bromine	Br <sub>2</sub>	-1.78	-1.97
Butadiene	C <sub>4</sub> H <sub>6</sub>	-0.85	-0.93
Isobutylene	(CH <sub>3</sub> ) <sub>2</sub> CH=CH <sub>2</sub>	-0.94	-1.06
n-Butane	C <sub>4</sub> H <sub>10</sub>	-1.10	-1.22
Chlorine	CL <sub>2</sub>	-0.83	-0.91
Hydrogen Chloride	HCL	-0.31	-0.34
Nitrous Oxide	N <sub>2</sub> O	-0.20	-0.22
Diacetylene	(CHCl) <sub>2</sub>	-1.09-	-1.20
Ethane	C <sub>2</sub> H <sub>4</sub>	-0.43	-0.47
Ethylene Oxide	C <sub>2</sub> H <sub>4</sub> O <sub>2</sub>	-0.54	-0.60
Ethylene	C <sub>2</sub> H <sub>4</sub>	-0.20	-0.22
Ethylene Glycol	CH <sub>2</sub> OHCH <sub>2</sub> OH	-0.78	-0.88
Ethylbenzene	C <sub>8</sub> H <sub>10</sub>	-1.89	-2.08
Hydrogen Fluoride	HF	+0.12	+0.14
Furan	C <sub>4</sub> H <sub>4</sub> O	-0.90	-0.99
Helium	He	+0.29	+0.32
n-Hexane	C <sub>6</sub> H <sub>14</sub>	-1.78	-1.97
Krypton	Kr	-0.49	-0.54
Carbon Monoxide	CO	-0.06	-0.07
Carbon Dioxide	CO <sub>2</sub>	-0.27	-0.29
Methane	CH <sub>4</sub>	-0.16	-0.17
Methanol	CH <sub>4</sub> O	-0.27	-0.31
Methylene Chloride	CH <sub>2</sub> Cl <sub>2</sub>	-1.00	-1.10
Neon	Ne	+0.16	+0.17
n-Octane	C <sub>8</sub> H <sub>18</sub>	-2.45	-2.70
Phenol	C <sub>6</sub> H <sub>6</sub> O	-1.40	-1.54
Propane	C <sub>3</sub> H <sub>8</sub>	-0.77	-0.85
Propylene	C <sub>3</sub> H <sub>6</sub>	-0.57	-0.62
Propene	CH <sub>3</sub> CH=CH <sub>12</sub>	-0.58	-0.64
Propylene Oxide	C <sub>3</sub> H <sub>6</sub> O	-0.90	-1.00
Propylene Chloride	C <sub>3</sub> H <sub>7</sub> Cl	-1.42	-1.44
Silane	SiH <sub>4</sub>	-0.24	-0.27
Styrene	C <sub>7</sub> H <sub>6</sub> =CH <sub>2</sub>	-1.63	-1.80
Nitrogen	N <sub>2</sub>	-0.00	-0.00
Nitrogen Monoxide	NO	+42.70	+43.00
Nitrogen Dioxide	NO <sub>2</sub>	+5.00	+16.00
Oxygen	O <sub>2</sub>	+100.00	+100.00
Sulfur Dioxide	SO <sub>2</sub>	-0.18	-0.20
Sulfur Fluoride	SF <sub>6</sub>	-0.98	-1.05
Hydrogen Sulfide	H <sub>2</sub> S	-0.41	-0.43
Toluene	C <sub>7</sub> H <sub>8</sub>	-1.57	-1.73
Trichloroethylene	C <sub>2</sub> HCl <sub>3</sub>	-1.56	-1.72
Vinyl Chloride	C <sub>2</sub> H <sub>3</sub> Cl	-0.68	-0.74
Vinyl.Fluoride	CH <sub>3</sub> F	-0.49	-0.54
Water	H <sub>2</sub> O	-0.03	-0.03
Hydrogen	H <sub>2</sub>	+0.23	+0.26
Xenon	Xe	-0.95	-1.02

## **Appendix M.4**

### **Visible Emissions Evaluator Certification**



# VISIBLE EMISSIONS EVALUATOR

**James Stultz**

This is to certify that the above named observer has met the specifications of Federal Reference Method 9 and is qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates, Inc. of Raleigh, N.C.

This certificate is valid for six months from date of issue.

**410733**

Certificate Number

**STU705534**

Student ID Number

**3/6/2013**

Date of Certification

**Roanoke, VA**

Location

**9/5/2013**

Certification Expiration Date

**RICS12**

Last Lecture

*Marty Hughes*  
**Director of Training**



# VISIBLE EMISSIONS EVALUATOR

**Michael Henry**

This is to certify that the above named observer has met the specifications of Federal Reference Method 9 and is qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates, Inc. of Raleigh, N.C.

This certificate is valid for six months from date of issue.

**410699**

Certificate Number

**HEN721450**

Student ID Number

**3/6/2013**

Date of Certification

**Roanoke, VA**

Location

**9/5/2013**

Certification Expiration Date

**RICS12**

Last Lecture

*Marty Hughes*  
**Director of Training**



**Appendix N**  
**Facility Operating Data**

## **Appendix N.1**

### **Facility Operating Data: Unit 1**

**TEST LOG**  
**MWC Unit 1**  
**Pinellas County Resource Recovery Facility**  
**St. Petersburg, Florida**

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dscfm @7% oxygen</i>
Unit 1 FF Outlet	Opacity	EPA Method 9	U1-M9-R1	4/12/2013	10:13	11:13	228	Not Isokinetic
Unit 1 FF Outlet	Opacity	EPA Method 9	U1-M9-R2	4/12/2013	11:13	12:13	233	Not Isokinetic
Unit 1 FF Outlet	Opacity	EPA Method 9	U1-M9-R3	4/12/2013	12:13	13:13	229	Not Isokinetic

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <i>dscfm @7% oxygen</i>
Unit 1 FF Outlet	PM2.5	EPA Methods 201A/202	U1O-M201A/202-R1	4/10/2013	10:08	11:08	236	124,200
Unit 1 FF Outlet	PM2.5	EPA Methods 201A/202	U1O-M201A/202-R2	4/10/2013	12:11	13:12	233	128,232
Unit 1 FF Outlet	PM2.5	EPA Methods 201A/202	U1O-M201A/202-R3	4/10/2013	15:03	16:03	234	125,112

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dscfm @7% oxygen</i>
Unit 1 FF Outlet	Particulate and HCl	EPA Method 5/26A	U1O-M26A-R1	4/9/2013	9:05	11:28	233	111,893
Unit 1 FF Outlet	Particulate and HCl	EPA Method 5/26A	U1O-M26A-R2	4/9/2013	13:24	15:36	235	109,608
Unit 1 FF Outlet	Particulate and HCl	EPA Method 5/26A	U1O-M26A-R3	4/9/2013	16:22	18:33	236	109,652

Unit #1  
**STOP Times**  
 09:30-09:39  
 \* removed from avg

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dscfm @7% oxygen</i>	Activated Carbon <i>pounds per hour</i>
Unit 1 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U1O-M29-R1	4/9/2013	9:05	11:28	233	109,603	15
Unit 1 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U1O-M29-R2	4/9/2013	13:24	15:36	235	111327	15
Unit 1 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U1O-M29-R3	4/9/2013	16:22	18:33	236	107939	15

Unit #1  
**STOP Times**  
 09:30-09:39  
 \* removed from avg

<sup>(1)</sup> All air flows obtained from ACG using the EPA Methods 1-4 portions of the appropriate test method.

## **Appendix N.2**

### **Facility Operating Data: Unit 2**

**TEST LOG**  
**MWC UNIT 2**  
**Pinellas County Resource Recovery Facility**  
**St. Petersburg, Florida**

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dsclm @7% oxygen</i>
Unit 2 FF Outlet	Opacity	EPA Method 9	U2-M9-R1	4/10/2013	8:51	9:51	236	Not Isokinetic
Unit 2 FF Outlet	Opacity	EPA Method 9	U2-M9-R2	4/12/2013	13:20	14:20	233	Not Isokinetic
Unit 2 FF Outlet	Opacity	EPA Method 9	U2-M9-R3	4/12/2013	14:30	15:30	227	Not Isokinetic

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <i>dsclm @7% oxygen</i>
Unit 2 FF Outlet	PM2.5	EPA Methods 201A/202	U2O-M201A/202-R1	4/11/2013	7:32	8:38	231	115,166
Unit 2 FF Outlet	PM2.5	EPA Methods 201A/202	U2O-M201A/202-R2	4/11/2013	10:14	11:14	233	121,445
Unit 2 FF Outlet	PM2.5	EPA Methods 201A/202	U2O-M201A/202-R3	4/11/2013	12:08	13:08	232	117,041

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dsclm @7% oxygen</i>
Unit 2 FF Outlet	Particulate and HCl	EPA Method 5/26A	U2O-M26A-R1	4/10/2013	8:45	11:15	234	108,883
Unit 2 FF Outlet	Particulate and HCl	EPA Method 5/26A	U2O-M26A-R2	4/10/2013	12:09	14:28	234	107,068
Unit 2 FF Outlet	Particulate and HCl	EPA Method 5/26A	U2O-M26A-R3	4/10/2013	15:25	17:35	234	100,274

Unit #2  
**STOP Times**  
 08:57-08:59; 09:32-09:40; and 10:35-10:44.  
 \* removed from avg

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dsclm @7% oxygen</i>	Activated Carbon <i>pounds per hour</i>
Unit 2 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U2O-M29-R1	4/10/2013	8:45	11:15	234	107,639	15
Unit 2 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U2O-M29-R2	4/10/2013	12:09	14:28	234	102,434	15
Unit 2 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U2O-M29-R3	4/10/2013	15:25	17:35	234	98,240	15

Unit #2  
**STOP Times**  
 08:57-08:59; 09:32-09:40; and 10:35-10:44.  
 \* removed from avg

(1) All air flows obtained from ACG using the EPA Methods 1-4 portions of the appropriate test method.

**Appendix N.3**  
**Facility Operating Data: Unit 3**

**TEST LOG**  
**MWC UNIT 3**  
**Pinellas County Resource Recovery Facility**  
**St. Petersburg, Florida**

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dscfm @7% oxygen</i>
Unit 3 FF Outlet	Opacity	EPA Method 9	U3-M9-R1	4/12/2013	10:13	11:13	234	Not Isokinetic
Unit 3 FF Outlet	Opacity	EPA Method 9	U3-M9-R2	4/12/2013	11:13	12:13	242	Not Isokinetic
Unit 3 FF Outlet	Opacity	EPA Method 9	U3-M9-R3	4/12/2013	12:13	13:13	237	Not Isokinetic

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dscfm @7% oxygen</i>
Unit 3 FF Outlet	PM2.5	EPA Methods 201A/202	U3O-M201A/202-R1	4/9/2013	11:56	12:53	232	126,334
Unit 3 FF Outlet	PM2.5	EPA Methods 201A/202	U3O-M201A/202-R2	4/9/2013	14:08	15:08	240	135,575
Unit 3 FF Outlet	PM2.5	EPA Methods 201A/202	U3O-M201A/202-R3	4/9/2013	16:38	17:38	233	122,537

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dscfm @7% oxygen</i>
Unit 3 FF Outlet	Particulate and HCl	EPA Method 5/26A	U3O-M26A-R1	4/11/2013	8:37	10:56	235	122,486
Unit 3 FF Outlet	Particulate and HCl	EPA Method 5/26A	U3O-M26A-R2	4/11/2013	11:45	13:54	233	127,206
Unit 3 FF Outlet	Particulate and HCl	EPA Method 5/26A	U3O-M26A-R3	4/11/2013	14:36	17:04	236	125,640

Unit #3  
**STOP Times**  
 15:06-15:23  
 \* removed from avg

Test Location	Test Parameter	EPA Method	Run I.D.	Date	Start Time	End Time	Steam Flow <i>kilo-pounds</i>	Air Flow <sup>(1)</sup> <i>dscfm @7% oxygen</i>	Activated Carbon <i>pounds per hour</i>
Unit 3 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U3O-M29-R1	4/11/2013	8:37	10:56	235	117,952	16
Unit 3 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U3O-M29-R2	4/11/2013	11:45	13:54	233	117,619	15
Unit 3 FF Outlet	Cadmium, Lead and Mercury	EPA Method 29	U3O-M29-R3	4/11/2013	14:36	17:04	236	121,367	15

Unit #3  
**STOP Times**  
 15:06-15:23  
 \* removed from avg

<sup>(1)</sup> All air flows obtained from ACG using the EPA Methods 1-4 portions of the appropriate test method.