

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. Ronald Jomlin
City of Lakeland, Electric
501 E. Lemon St.
Lakeland, FL

33801-5079

2. Article Number (Copy from service label)

2 341 355 302

PS Form 3811, July 1999

Domestic Return Receipt

102595-99-M-1789

COMPLETE THIS SECTION ON DELIVERY

A. Received by (Please Print Clearly) B. Date of Delivery

6/1/00

C. Signature

X *Harry Joseph* ☐ Agent ☐ Addressee

D. Is delivery address different from item 1? ☐ Yes

If YES, enter delivery address below: ☐ No

3. Service Type

- ☒ Certified Mail ☐ Express Mail
☐ Registered ☐ Return Receipt for Merchandise
☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? (Extra Fee)

☐ Yes

2 341 355 302

US Postal Service
Receipt for Certified Mail

No Insurance Coverage Provided.
Do not use for International Mail (See reverse)

Sent to	<i>Ronald Jomlin</i>
Street & Number	<i>City of Lakeland</i>
Post Office, State, & ZIP Code	<i>Lakeland FL</i>
Postage	\$
Registered Fee	
Additional Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	<i>5-30-00</i>
<i>1050003-007-AC</i> <i>PSD-FI-166C</i>	

PS Form 3800, April 1995

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
NOTICE OF PERMIT

In the Matter of an
Application for Permit Modification by:

Mr. Ronald W. Tomlin
Assistant Managing Director
City of Lakeland, Electric Utilities
501 E. Lemon Street
Lakeland, Florida 33801-5079

DEP File No. 1050003-007-AC (PSD-FL-166C)
Combined Cycle Combustion Turbine 008
Inlet Foggers Installation
Larsen Power Plant
Polk County

Enclosed is the Final Permit Number 1050003-007-AC (PSD-FL-166C) for an air construction permit to install an evaporative cooling system on the existing 120MW combined cycle General Electric PG7111EA combustion turbine-electrical generator designated as Larsen Unit # 8. This unit is located at the City of Lakeland Larsen Power Plant in Polk County. This permit is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.



C. H. Fancy, P.E., Chief
Bureau of Air Regulation

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF FINAL PERMIT (including the FINAL permit) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 5-30-00 to the person(s) listed:

Ronald W. Tomlin, City of Lakeland*
Farzie Shelton, City of Lakeland
Ken Kosky P.E., Golder Associates
Bill Thomas, DEP SW
Gregg Worley, EPA

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date,
pursuant to §120.52, Florida Statutes, with the designated
Department Clerk, receipt of which is hereby acknowledged.


(Clerk)

5-30-00
(Date)


FINAL DETERMINATION

City of Lakeland Department of Electric Utilities
Charles Larsen Power Plant, Polk County
Inlet Foggers Installation
DEP File No: 1050003-007-AC

An Intent to Issue an air construction permit, authorizing the installation of an evaporative cooling system on the existing 120 MW combined cycle General Electric PG7111EA Combustion turbine-electrical generator designated as Larsen Unit # 8 at the Charles Larsen Power Plant was distributed on April 13, 2000. This facility is located at 2002 Hwy 92 East, Lakeland, Polk County, Florida.

The Public Notice of Intent to Issue Air Construction Permit was published in The Ledger on April 19, 2000. No comments were received as a result of the Public Notice period.

The final action of the Department will be to issue the permit as noted during the Public Notice period.



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

PERMITTEE:

City of Lakeland, Electric Utilities
501 E. Lemon Street
Lakeland, Florida 33801-5079

Authorized Representative:

Ronald W. Tomlin
Assistant Managing Director

DEP File No.	PSD-FL-166 C
Permit No.	1050003-007-AC
Project	Evaporative Cooling System
SIC No.	4911
Expires:	November 30, 2000

PROJECT AND LOCATION:

Installation of an evaporative cooling system on the existing 120 MW combined cycle General Electric PG7111EA combustion turbine-electrical generator designated as Larsen Unit 8. This permit is a re-issuance of the original air construction permit authorizing the construction of Unit 8 and incorporating subsequent modifications including the present project.

The unit is located at the City of Lakeland Larsen Power Plant, 2002 Hwy 92 East, Lakeland, Polk County.

The UTM coordinates are: Zone 17; 408.9 km E and 3102.5 km N.

STATEMENT OF BASIS:

This construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), and Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The above named permittee is authorized to modify the facility in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

ATTACHED APPENDICES MADE A PART OF THIS PERMIT:

Appendix GC	Construction Permit General Conditions
Appendix SC	Specific Conditions including Permits PSD-FL-166 (AC53-190437), PSD-FL-166A (1050003-001-AC) and PSD-FL-166B (1050003-005-AC)

Howard L. Rhodes, Director
Division of Air Resources
Management

"More Protection, Less Process"

Printed on recycled paper.

APPENDIX SC
SPECIFIC CONDITIONS

1. This permit, PSD-FL-166C (DEP File 1050003-007-AC), supersedes PSD permit PSD-FL-166B (DEP File 1050003-005-AC) issued on April 17, 1998.
2. The provisions of air construction permit PSD-FL-166 (AC53-190437) issued on 7/26/91 to construct Unit 8 and subsequent revisions PSD-FL-166A (1050003-001-AC) issued on 12/22/95 and PSD-FL-166B (1050003-005-AC) issued on 4/17/98 are attached and incorporated into this air construction permit in addition to the change that follows in Specific Condition 3 below.
3. An evaporative cooling system may be installed at the compressor inlet of Larsen Unit 8. The system may be operated at any time that Unit 8 is in operation.

APPENDIX GC
GENERAL PERMIT CONDITIONS [F.A.C. 62-4.160]

- G.1 The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
- G.2 This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings or exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
- G.3 As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
- G.4 This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- G.5 This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
- G.6 The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- G.7 The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
- a) Have access to and copy and records that must be kept under the conditions of the permit;
 - b) Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
 - c) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.
- Reasonable time may depend on the nature of the concern being investigated.
- G.8 If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
- a) A description of and cause of non-compliance; and
 - b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

APPENDIX GC
GENERAL PERMIT CONDITIONS [F.A.C. 62-4.160]

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

- G.9 In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- G.10 The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
- G.11 This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- G.12 This permit or a copy thereof shall be kept at the work site of the permitted activity.
- G.13 This re-issued permit incorporates previous determinations for:
- a) Best Available Control Technology (X)
 - b) Prevention of Significant Deterioration (X); and
 - c) New Source Performance Standards (X).
- G.14 The permittee shall comply with the following:
- a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
 - b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
 - c) Records of monitoring information shall include:
 - 1. The date, exact place, and time of sampling or measurements;
 - 2. The person responsible for performing the sampling or measurements;
 - 3. The dates analyses were performed;
 - 4. The person responsible for performing the analyses;
 - 5. The analytical techniques or methods used; and
 - 6. The results of such analyses.
- G.15 When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

PERMITTEE:

Lakeland Electric and Water
501 East Lemon Street
Lakeland, Florida 33801-5050

Permit No.	AC53-190437
PSD No.	PSD-FL-166B
File No.	1050003-005-AC
Expires	December 31, 1998
Facility	Charles Larsen Memorial Plant
Unit No.	Combined Cycle Combustion Turbine, Unit 8

Authorized Representative:

Ms. Farzie Shelton
Environmental Coordinator

LOCATED AT:

Charles Larsen Memorial Plant

Standard Industrial Classification Code (SIC): 4911

Polk County, Florida

Directions: Located on the south side of Lake Parker on US Highway 92 in Lakeland, Polk County

STATEMENT OF BASIS:

This construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), and the Florida Administrative Code (F.A.C.) Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297. The above named permittee is authorized to modify the facility in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department of Environmental Protection (Department).

Attached Appendices and Tables made a part of this permit:

Original construction permit: AC53-190437 / PSD-FL-166 issued 7/25/91

Modification: Dated 12/18/95, added a custom fuel monitoring schedule, clarified ISO correction, and adjusted SO₂ and H₂SO₄ limits

Table 1: Revised Emission limits

Curves: Oil Input vs Compressor Inlet Temperature

Howard L. Rhodes, Director
Division of Air Resources
Management

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

Printed on recycled paper.

AIR CONSTRUCTION PERMIT AC53-190437 / PSD-FL-166B
SPECIFIC CONDITIONS

SPECIFIC CONDITIONS:

I. This permit supersedes permit AC53-190437 / PSD-FL-166 dated July 25, 1991, as changed by amendment dated December 18, 1995.

II. The provisions of permit AC53-190437 / PSD-FL-166 are incorporated into this permit except for the following changes:

Specific Condition #1:

Table 1 referenced in this condition shall be replaced with the attached Table 1 (revised December 18, 1995 and April 13, 1998).

Specific Condition #2:

This condition is replaced with the following:

2. Emissions of mercury shall be limited by firing only natural gas or No. 2 fuel oil.

Specific Condition #6:

From:

6. The permitted materials and utilization rates for the combined cycle gas turbine shall not exceed the values as follows:

- Maximum No. 2 fuel oil consumption shall not exceed either of the following limitations: 9190 gal/hr; 23,914,800 gals/yr.
- Maximum annual firing using No. 2 fuel oil shall not exceed 1/3 of the annual capacity factor.
- Maximum sulfur (S) content in the No. 2 fuel oil shall not exceed 0.20 percent by weight.
- Maximum heat input shall not exceed 1055 MMBtu/hr (gas) or 1040 MMBtu/hr No. 2 fuel (oil).

TO:

6. The permitted materials and utilization rates for the combined cycle gas turbine shall not exceed the values as follows:

- Maximum No. 2 fuel oil consumption shall not exceed either of the following limitations: the values in the attached Oil Input VS Compressor Inlet Temperature curve and 23,914,800 gals/yr.
- Maximum annual firing using No. 2 fuel oil shall not exceed 1/3 of the annual capacity factor.
- Maximum sulfur (S) content in the No. 2 fuel oil shall not exceed 0.20 percent by weight.
- Maximum heat input shall not exceed 1055 MMBtu/hr (gas) or 1040 MMBtu/hr No. 2 fuel (oil).

AIR CONSTRUCTION PERMIT AC53-190437 / PSD-FL-166B
SPECIFIC CONDITIONS

Specific Condition #7:

From:

7. Any change in the method of operation, equipment or operating hours shall be submitted to the DER's Bureau of Air Regulation and Southwest District Offices.

TO:

7. The owner or operator shall submit to the Permitting Authority(s), for review any changes in, or modifications to: the method of operation; process or pollution control equipment; increased equipment capacities; or any change which would result in an increase in potential or actual emissions. Depending on the size and scope of the modification, it may be necessary to submit an application for, and obtain, an air construction permit prior to making the desired change. *Routine maintenance of equipment will not constitute a modification of this permit.* [Rule 62-4.030, 62-210.300 and 62-4.070(3), F.A.C.]

Specific Condition #19:

FROM:

This source shall comply with all applicable provisions of Chapter 403, Florida Statutes and Chapters 17-2 and 17-4, Florida Administrative Code.

TO:

This source shall comply with all applicable provisions of Chapter 403, Florida Statutes, and Chapters 62-4, 62-210, 62-212, 62-213, 62-214, 62-296, and 62-297, Florida Administrative Code. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;
- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
- c. Each NESHAP pollutant, if there is an applicable emission standard.


TABLE 1
ALLOWABLE EMISSION LIMITS
Combined Cycle Combustion Turbine
(Revised 12/18/95 and 4/13/98)

Pollutant	Gas Firing	Standards No. 2 Fuel Oil Firing	Gas Turbine and HRSG ^(a)		Basis
			Gas	Tons Per Year Oil	
NO _x	25 PPM at 15% oxygen on a dry basis	42 ppmv at 15 percent oxygen on a dry basis	425	244	BACT
SO ₂	Natural gas a fuel	0.20 percent S by weight	8.6	307	BACT
PM/PM ₁₀	0.006 lb/MMBtu	0.025 lb/MMBtu	22	22	BACT
VOC	-	-	9	6.7	BACT
CO	25 ppmv at 15 percent oxygen on a dry basis	25 ppmv at 15 percent oxygen on a dry basis			BACT
Sulfuric Acid Mist	Natural gas as fuel	Low sulfur content oil			BACT

(a) Emissions rates based on 100 percent capacity factor for natural gas and 1/3 capacity factor for oil firing.

Unit 8

Oil Input vs Compressor Inlet Temperature




+ Design Input #2 Oil * 95% Design Input #2 Oil

Peak Mode

Using LHV of #2 Oil

2/25/97



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

December 18, 1995

CERTIFIED MAIL RETURN RECEIPT REQUESTED

Ms. Farzie Shelton
Environmental Coordinator
Department of Electric and Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5050

Dear Ms. Shelton:

Re: Charles Larson Power Plant Unit 8--Combustion Turbine
PSD-FL-166/AC53-190437
Request to amend permit

The Department is in receipt of your June 27, 1995 request to amend the above referenced permit. You requested a customized fuel monitoring schedule for the sulfur and nitrogen content of the natural gas fired in the turbine. You also requested that the sulfur dioxide and sulfuric acid mist permit limits be changed. In addition, you requested clarification of the nitrogen oxides compliance testing requirements, i.e. the ISO correction, specified in the above referenced permit.

The Department acknowledges your oversight in neglecting the sulfur from mercaptans (which are added to the natural gas for safety reasons) in your estimate of annual SO₂ emissions. The Department also agrees that a typographical error was apparently made in the annual emission limits for sulfuric acid mist, both for natural gas and oil.

The Department hereby incorporates each of the following amendments to the above referenced permit:

Custom Fuel Monitoring Schedule

The proposed custom fuel monitoring schedule (attached) has been approved by EPA and is included as an attachment to the above referenced permit. This fuel monitoring schedule supersedes AC53-190437 / PSD-FL-166 condition 23 which

Ms. Farzie Shelton
December 18, 1995
page 2

requires annual reports for nitrogen content of the fuel being fired, as this condition applies to the firing of natural gas.

Annual Sulfur Dioxide And Sulfuric Acid Mist Limits

The annual sulfur dioxide and sulfuric acid mist limits is changed as follows:

TABLE 1

FROM:

SO₂..... 2.6 (tpy on gas)

Sulfuric Acid Mist..... - (tpy on gas)... 3.3×10^{-3} (tpy on oil)

TO:

SO₂..... 8.6 (tpy on gas)

Sulfuric Acid Mist..... 0.8 (tpy on gas)... 9.13 (tpy on oil)

Correction of NO_x Emissions to ISO Conditions

Based on the recent guidance memorandum on combustion turbines the Department hereby removes the requirement to correct the test data to ISO conditions for comparison with the NO_x emission limits established pursuant to the BACT determination for gas and oil firing. To institute this change, Permit PSD-FL-166/AC53-190437 Specific Condition 13 is amended as follows:

During the initial performance tests, to determine compliance with the proposed NSPS NO_x standard, measured NO_x emission at 15 percent oxygen will be adjusted to ISO

A copy of this amendment letter shall be attached to and

CUSTOMED FUEL MONITORING SCHEDULE

1. Monitoring of natural gas nitrogen content shall not be required in accordance with page 2 of the EPA guidance memorandum, attached.
2. Sulfur Monitoring
 - a. Analysis for sulfur content of the natural gas shall be conducted using one of the EPA-approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternate method. The reference methods are: ASTM D1072-80; ASTM D3031-81; ASTM D3246-81; and ASTM D4084-82 as referenced in 40 CFR § 60.335(b)(2).
 - b. Effective on the approval date of the customized fuel monitoring schedule, sulfur monitoring shall be conducted twice a month for six months. If this monitoring shows little variability in the sulfur content and indicates consistent compliance with 40 CFR § 60.333, then sulfur monitoring shall be conducted once per quarter for six quarters.
 - c. If the sulfur content monitoring required for natural gas by 2(b) above shows little variability and the calculated sulfur dioxide emissions represent consistent compliance with the sulfur dioxide emission limits specified under 40 CFR § 60.333, sample analysis shall be conducted twice per year. This monitoring shall be conducted during the first and third quarters of each calendar year.
 - d. Should any sulfur analysis as required by items 2(b) or 2(c) above indicate noncompliance with 40 CFR § 60.333, the City will notify the Department of Environmental Protection of such excess emission and the customized fuel monitoring schedule shall be reexamined. The sulfur content of the natural gas will be monitored weekly during the interim period while this monitoring schedule is being reexamined.
3. The City will notify the Department of Environmental Protection of any change in natural gas supply for reexamination of this monitoring schedule. A substantial change in natural gas quality (i.e., sulfur content varying greater than 10 grains/1000 cf gas) shall be considered as a change in natural gas supply. Sulfur content of the natural gas will be monitored weekly during the interim period when this monitoring schedule is being reexamined.
4. Records of sampling analysis and natural gas supply pertinent to this monitoring schedule shall be retained by the City for a period of three years, and shall be available for inspection by appropriate regulatory personnel.
5. The City will obtain the sulfur content of the natural gas from Florida Gas Transmission Company. (The data presented in Attachment B is based upon representative samples of natural gas taken by Florida Gas Transmission.)

Ms. Farzie Shelton
December 18, 1995
page 3

shall become a part of Air Construction Permit PSD-FL-166 /
AC53-190437.

Sincerely,



for Howard L. Rhodes, Director
Division of Air Resources
Management

CERTIFICATE OF SERVICE


The undersigned duly designated deputy clerk hereby certifies
that this PERMIT AMENDMENT and all copies were mailed by
certified mail before the close of business on 12-27-95 to
the listed persons.

Clerk Stamp
FILING AND ACKNOWLEDGMENT FILED,
on this date, pursuant to
120.52(11), Florida Statutes,
with the designated Department
Clerk, receipt of which is hereby
acknowledged.

Lynn J. Jihen 12-27-95
Clerk Date

Copies to be furnished to:

Jerry Kissel, SWD
Jewell Harper, EPA
Roy Harwood, Polk Co.



Florida Department of Environmental Regulation

Twin Towers Office Bldg. • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

Lawton Chiles, Governor

Carol M. Browner, Secretary

PERMITTEE:
City of Lakeland
501 E. Lemon Street
Lakeland, Florida 32961

Permit Number: AC 53-190437
Expiration Date: March 30, 1993
County: Polk
Latitude/Longitude: 28°02'56"N
81°55'25"W
Project: 120 MW Combined Cycle
Gas Turbine

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 17-2 and 17-4. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawings, plans, and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

For the construction of a 120 MW combined cycle gas turbine to be located at the City of Lakeland-Charles Larsen Power Plant in Lakeland, Florida. The turbine will fire natural gas as the primary fuel and have limited hours firing No. 2 fuel oil. The turbine is a GE PG7111 (EA) Frame 7 unit with water injection to reduce NOx emissions. Fuel flow rate for natural gas is 17,333 scfm @ ISO and 124.2 gal/min @ ISO for No. 2 fuel oil. The UTM coordinates are 409.185 km East and 3102.754 km North.

The source shall be constructed in accordance with the permit application, plans, documents, amendments and drawings, except as otherwise noted in the General and Specific Conditions.

Attachments are listed below:

1. City of Lakeland-Charles Larsen Power Plant's letter dated April 3, 1991.
2. EPA Region IV letter dated April 4, 1991.
3. National Park Service's letter dated May 3, 1991.
4. City of Lakeland's letter dated May 15, 1991.

PERMITTEE:
City of Lakeland

Permit Number: AC 53-190437
Expiration Date: March 30, 1993

GENERAL CONDITIONS:

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgement of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.

PERMITTEE:
City of Lakeland

Permit Number: AC 53-190437
Expiration Date: March 30, 1993

GENERAL CONDITIONS:

6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.

7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:

- a. Have access to and copy any records that must be kept under the conditions of the permit;
- b. Inspect the facility, equipment, practices, or operations regulated or required under this permit; and
- c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:

- a. a description of and cause of non-compliance; and
- b. the period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

PERMITTEE:
City of Lakeland

Permit Number: AC 53-190437
Expiration Date: March 30, 1993

GENERAL CONDITIONS:

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.

11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 17-4.120 and 17-30.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.

12. This permit or a copy thereof shall be kept at the work site of the permitted activity.

13. This permit also constitutes:

- (x) Determination of Best Available Control Technology (BACT)
- (x) Determination of Prevention of Significant Deterioration (PSD)
- (x) Compliance with New Source Performance Standards (NSPS)

14. The permittee shall comply with the following:

- a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.

PERMITTEE:
City of Lakeland

Permit Number: AC 53-190437
Expiration Date: March 30, 1993

GENERAL CONDITIONS:

b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.

c. Records of monitoring information shall include:

- the date, exact place, and time of sampling or measurements;
- the person responsible for performing the sampling or measurements;
- the dates analyses were performed;
- the person responsible for performing the analyses;
- the analytical techniques or methods used; and
- the results of such analyses.

15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

SPECIFIC CONDITIONS:

Emission Limits

1. The maximum allowable emissions from this facility shall not exceed the emission rates listed in Table 1.

2. Unless the Department has determined other concentrations are required to protect public health and safety, predicted acceptable ambient air concentrations (AAC) of the following pollutants shall not be exceeded:

PERMITTEE:
City of Lakeland

Permit Number: AC 53-190437
Expiration Date: March 30, 1993

SPECIFIC CONDITIONS:

Pollutant	Acceptable Ambient Concentrations		
	8-hrs	24-hrs	Annual
Beryllium	0.02	0.005	0.0004
Lead	1.5	0.36	0.09
Inorganic mercury compounds, all forms of vapor, as Hg	-	-	0.3

3. Visible emissions shall not exceed 10% opacity.

Operating Rates

4. This source is allowed to operate continuously (8760 hours per year).

5. This source is allowed to use natural gas as the primary fuel and No. 2 distillate oil as the secondary fuel (limited as shown in Specific Condition 6 below).

6. The permitted materials and utilization rates for the combined cycle gas turbine shall not exceed the values as follows:

- Maximum No. 2 fuel oil consumption shall not exceed either of the following limitations: 8,190 gals/hr; 23,914,800 gals/yr.
- Maximum annual firing using No. 2 fuel oil shall not exceed 1/3 of the annual capacity factor.
- Maximum sulfur (S) content in the No. 2 fuel oil shall not exceed 0.20 percent by weight.
- Maximum heat input shall not exceed 1055 MMBtu/hr (gas) or 1040 MMBtu/hr No. 2 fuel (oil).

7. Any change in the method of operation, equipment or operating hours shall be submitted to the DER's Bureau of Air Regulation and Southwest District offices.

8. Any other operating parameters established during compliance testing and/or inspection that will ensure the proper operation of this facility shall be included in the operating permit.

PERMITTEE:
City of Lakeland

Permit Number: AC 53-190437
Expiration Date: March 30, 1993

SPECIFIC CONDITIONS:

Compliance Determination

9. Initial (I) compliance tests shall be performed on each CT using both fuels. The stack test for each turbine shall be performed within 10 percent of the maximum heat rate input for the tested operating temperature. Annual (A) compliance tests shall be performed on each CT with the fuel(s) used for more than 400 hours in the preceding 12-month period. Tests shall be conducted using EPA reference methods in accordance with the November 2, 1989, version of 40 CFR 60 Appendix A:

- a. 5 or 17 for PM (I, A, for oil only)
- b. 10 for CO (I)
- c. 9 for VE (I, A)
- d. 20 for NO_x (I, A)
- e. Trace elements of Beryllium (Be) shall be tested (I, for oil only) using EMTIC Interim Test Method. As an alternative, Method 104 may be used; or Be may be determined from fuel sample analysis using either Method 7090 or 7091, and sample extraction using Method 3040 as described in the EPA solid waste regulations SW 846.
- f. Mercury (Hg) shall be tested using EPA Method 101 (40 CFR 61, Appendix B) (I, for oil only) or fuel sampling analysis using methods acceptable to the Department.

Other DER approved methods may be used for compliance testing after prior Departmental approval.

10. Method 5 or 17 must be used to determine the initial compliance status of this unit. Thereafter, the opacity emissions test may be used unless 10% opacity is exceeded.

11. Compliance with the SO₂ emission limit can also be determined by calculations based on fuel analysis using ASTM D2880-71 for the sulfur content of liquid.

12. Compliance with the total volatile organic compound emission limits will be assumed, provided the CO allowable emission rate is achieved; specific VOC compliance testing is not required.

PERMITTEE:
City of Lakeland

Permit Number: AC 53-190437
Expiration Date: March 30, 1993

SPECIFIC CONDITIONS:

13. During performance tests, to determine compliance with the proposed NO_x standard, measured NO_x emission at 15 percent oxygen will be adjusted to ISO ambient atmospheric conditions by the following correction factor:

$$NO_x = (NO_x \text{ obs}) \left(\frac{P_{\text{ref}}}{P_{\text{obs}}} \right)^{0.5} e^{19(H_{\text{obs}} - 0.00633)} \left(\frac{288^\circ K}{T_{\text{AMB}}} \right)^{1.53}$$

where:

NO_x = Emissions of NO_x at 15 percent oxygen and ISO standard ambient conditions.

NO_x obs = Measured NO_x emission at 15 percent oxygen, ppmv.

P_{ref} = Reference combustor inlet absolute pressure at 101.3 kilopascals (1 atmosphere) ambient pressure.

P_{obs} = Measured combustor inlet absolute pressure at test ambient pressure.

H_{obs} = Specific humidity of ambient air at test.

e = Transcendental constant (2.718).

T_{AMB} = Temperature of ambient air at test.

14. Test results will be the average of 3 valid runs. The Southwest District office will be notified at least 30 days in advance of the compliance test. The source shall operate between 90% and 100% of permitted capacity during the compliance test. Compliance test results shall be submitted to the Southwest District office no later than 45 days after completion.

15. Water injection shall be utilized for NO_x control. The water to fuel ratio at which compliance is achieved shall be incorporated into the permit and shall be continuously monitored. In addition, the Permittee shall install a duct module suitable for future installation of SCR equipment.

16. To determine compliance with the capacity factor condition for oil firing, the Permittee shall maintain daily records of fuel usage. All records shall be maintained for a minimum of three years after the date of each record and shall be made available to representatives of the Department upon request.

PERMITTEE:
City of Lakeland

Permit Number: AC 53-190437
Expiration Date: March 30, 1993

SPECIFIC CONDITIONS:

17. Sulfur, nitrogen content and lower heating value of the fuel being fired in the gas turbine shall also be recorded per fuel oil shipment. These records shall also be kept by the company for at least three years and made available for regulatory agency's inspection.

18. Compliance with the acceptable ambient concentrations for Be, Lead, and Hg emissions shall be demonstrated based on calculations certified by a Professional Engineer registered in Florida, using actual operating conditions. Determination of the ambient concentrations for chemical compounds shall be determined by Department approved dispersion modeling. This compliance determination shall be made available upon request.

Rule Requirements

19. This source shall comply with all applicable provisions of Chapter 403, Florida Statutes and Chapters 17-2 and 17-4, Florida Administrative Code.

20. This source shall comply with all requirements of 40 CFR 60, Subpart GG and F.A.C. Rule 17-2.660(2)(a), Standards of Performance for Stationary Gas Turbines.

21. Issuance of this permit does not relieve the facility owner or operator from compliance with any applicable federal, state, or local permitting requirements and regulations (F.A.C. Rule 17-2.210(1)).

22. This source shall comply with F.A.C. Rule 17-2.700, Stationary Point Source Emission Test Procedures.

23. Pursuant to F.A.C. Rule 17-2.210(2), Air Operating Permits, the permittee is required to submit annual reports on the actual operating rates and emissions from this facility. These reports shall include, but are not limited to the following: sulfur, nitrogen content and lower heating value of the fuel being fired, fuel usage, hours of operation, air emissions limits, etc. Annual reports shall be sent to the Department's Southwest District office.

24. The permittee, for good cause, may request that this construction permit be extended. Such a request shall be submitted to the Bureau of Air Regulation prior to 60 days before the expiration of the permit (F.A.C. Rule 17-4.090).

PERMITTEE:
City of Lakeland


Permit Number: AC 53-190437
Expiration Date: March 30, 1993

SPECIFIC CONDITIONS:

25. An application for an operation permit must be submitted to the Southwest District office at least 90 days prior to the expiration date of this construction permit or within 45 days after completion of compliance testing, whichever occurs first. To properly apply for an operation permit, the applicant shall submit the appropriate application form, fee, certification that construction was completed noting any deviations from the conditions in the construction permit, and compliance test reports as required by this permit (F.A.C. Rule 17-4.220).

Issued this 25th day
of July, 1991

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL REGULATION



Carol M. Browner, Secretary

TABLE 1
ALLOWABLE EMISSION LIMITS
Combined Cycle Combustion Turbine

Pollutant	Standards		Gas Turbine and HRSG ^(a)		Basis
	Gas Firing	No. 2 Fuel Oil Firing	Tons Per Year		
			Gas	Oil	
NO _x	25 ppm at 15% oxygen on a dry basis	42 ppmv at 15 percent oxygen on a dry basis	425	244	BACT
SO ₂	Natural gas as fuel	0.2 percent S by weight	2.6	307	BACT
PM/PM ₁₀	0.006 lb/MMBtu	0.025 lb/MMBtu	22	22	BACT
VOC	-	-	9	6.7	BACT
CO	-	-	232	79	BACT
Mercury (Hg)	-	3.0 x 10 ⁻⁶ lbs/MMBtu	-	.003	Est. by Appl.
Lead (Pb)	-	2.8 x 10 ⁻⁵ lbs/MMBtu	-	0.03	" "
Beryllium (be)	-	2.5 x 10 ⁻⁶ lbs/MMBtu	-	.003	BACT
Sulfuric Acid Mist	Natural gas as fuel	Low sulfur content oil	-	3.2 x 10 ⁻³	BACT

(a) Emissions rates based on 100 percent capacity factor for natural gas and 1/3 capacity factor for oil firing.

Best Available Control Technology (BACT) Determination
City of Lakeland-Charles Larsen Power Plant
Polk County

The applicant proposes to install a combustion turbine generator at their facility in Lakeland. The generator system will consist of a single nominal 80 megawatt (MW) combustion turbine, and a single heat recovery steam generator (HRSG) which will be used to repower an existing nominal 40 MW steam turbine.

The combustion turbine will be capable of both combined cycle and simple cycle operation. The applicant requested that the combustion turbine use either natural gas or distillate oil. The applicant has indicated the maximum annual tonnage of regulated air pollutants emitted from the facility based on 100 percent capacity and type of fuel fired at ISO conditions to be as follows:

Pollutant	Potential Emissions (tons/yr)		PSD Significant Emission Rate (tons/yr)
	Natural Gas	Fuel Oil	
NOx	425	732	40
SO ₂	2.6	920	40
PM	22.0	66	25
PM ₁₀	22.0	66	15
CO	232	237	100
VOC	9	20.0	40
H ₂ SO ₄	0.8	27.4	7
Be	0.0	0.01	0.0004
Hg	0.0	0.01	0.1
Pb	0.0	0.12	0.6

Florida Administrative Code Rule 17-2.500(2)(f)(3) requires a BACT review for all regulated pollutants emitted in an amount equal to or greater than the significant emission rates listed in the previous table.

Date of Receipt of a BACT Application

December 17, 1990

BACT Determination Requested by the Applicant

<u>Pollutant</u>	<u>Determination</u>
NOx	25 ppmvd @ 15% O ₂ (natural gas burning) 42 ppmvd @ 15% O ₂ (diesel oil firing)
SO ₂	Firing of natural gas or No. 2 fuel oil with a maximum sulfur content of 0.20%
PM and PM ₁₀	Combustion control
H ₂ SO ₄	Firing of No. 2 fuel oil with a maximum sulfur content of 0.20%.
Be	Firing of No. 2 fuel oil

BACT Determination Procedure

In accordance with Florida Administrative Code Chapter 17-2, Air Pollution, this BACT determination is based on the maximum degree of reduction of each pollutant emitted which the Department, on a case by case basis, taking into account energy, environmental and economic impacts, and other costs, determines is achievable through application of production processes and available methods, systems, and techniques. In addition, the regulations state that in making the BACT determination the Department shall give consideration to:

- (a) Any Environmental Protection Agency determination of Best Available Control Technology pursuant to Section 169, and any emission limitation contained in 40 CFR Part 60 (Standards of Performance for New Stationary Sources) or 40 CFR Part 61 (National Emission Standards for Hazardous Air Pollutants).
- (b) All scientific, engineering, and technical material and other information available to the Department.
- (c) The emission limiting standards or BACT determinations of any other state.
- (d) The social and economic impact of the application of such technology.

The EPA currently stresses that BACT should be determined using the "top-down" approach. The first step in this approach is to determine for the emission source in question the most stringent control available for a similar or identical source or source category. If it is shown that this level of control is technically or economically infeasible for the source in question, then the next most stringent level of control is determined and similarly evaluated. This process continues until the BACT level under consideration cannot be eliminated by any substantial or unique technical, environmental, or economic objections.

The air pollutant emissions from combined cycle power plants can be grouped into categories based upon what control equipment and techniques are available to control emissions from these facilities. Using this approach, the emissions can be classified as follows:

- o Combustion Products (Particulates and Heavy Metals). Controlled generally by good combustion of clean fuels.
- o Products of Incomplete Combustion (CO, VOC, Toxic Organic Compounds). Control is largely achieved by proper combustion techniques.
- o Acid Gases (SOx, NOx, HCl, F1). Controlled generally by gaseous control devices.

Grouping the pollutants in this manner facilitates the BACT analysis because it enables the equipment available to control the type or group of pollutants emitted and the corresponding energy, economic, and environmental impacts to be examined on a common basis. Although all of the pollutants addressed in the BACT analysis may be subject to a specific emission limiting standard as a result of PSD review, the control of "nonregulated" air pollutants is considered in imposing a more stringent BACT limit on a "regulated" pollutant (i.e., particulates, sulfur dioxide, fluorides, sulfuric acid mist, etc.), if a reduction in "nonregulated" air pollutants can be directly attributed to the control device selected as BACT for the abatement of the "regulated" pollutants.

Combustion Products

The City of Lakeland's projected emissions of particulate matter, PM₁₀, and beryllium surpass the significant emission rates given in Florida Administrative Code Rule 17-2.500, Table 500-2 for No. 2 fuel oil firing only.

A PM/PM₁₀ emissions limitation of .025 lb/MMBtu for No. 2 fuel oil firing is reasonable as BACT for the Lakeland facility.

In general, the BACT/LAER Clearinghouse does not contain specific emission limits for beryllium from turbines. BACT for these heavy metals is typically represented by the level of particulate control. As this is the case, the emission factor of .025 lb/MMBtu for particulate matter PM₁₀ is judged to also represent BACT for beryllium.

Products of Incomplete Combustion

The emissions of carbon monoxide exceeds the significant level and therefore requires a BACT analysis.

At the proposed BACT NO_x emissions of 25/42 ppmvd (gas/oil) the turbine will be capable of maintaining CO emission rates of 25 ppmvd for either natural gas or No. 2 fuel oil. The applicant states that catalytic reduction could be installed at a leveled cost of 1.0 million/year to further reduce the CO emissions by 140 tons/year while burning natural gas (8760 hrs/yr). The incremental removal cost of using such control would be approximately \$7340/ton of CO removed. This cost exceeds that which is consistent with BACT and is not economically justifiable.

Acid Gases

The emissions of sulfur dioxide, nitrogen oxides, and sulfuric acid mist, represent a significant proportion of the total emissions and need to be controlled if deemed appropriate. Sulfur dioxide emissions from combustion turbines are directly related to the sulfur content of the fuel being combusted.

The applicant has proposed the use of natural gas and No. 2 fuel oil with a maximum sulfur content of 0.20% to control sulfur dioxide emissions. A review of the latest edition (1990) of the BACT/LAER Clearinghouse indicates that sulfur dioxide emissions from combustion turbines have been controlled by limiting fuel oil sulfur content to a range of 0.1 to 0.3%, with the average for the facilities listed being approximately 0.24 percent. As this is the case, the applicant's proposal to use No. 2 fuel oil with a maximum sulfur content of 0.20% is judged to represent BACT.

The applicant has stated that BACT for nitrogen oxides will be met by using wet (water or steam) injection necessary to limit emissions to 42 ppmvd or 25 ppmvd at 15% oxygen when burning No. 2 fuel oil or natural gas, respectively.

A review of the EPA's BACT/LAER Clearinghouse indicates that the lowest NO_x emission limit established to date for a combustion turbine is 4.5 ppmvd at 15% percent oxygen. This level of control was accomplished through the use of water injection and a selective catalytic reduction (SCR) system.

Selective catalytic reduction is a post-combustion method for control of NO_x emissions. The SCR process combines vaporized ammonia with NO_x in the presence of a catalyst to form nitrogen and water. The vaporized ammonia is injected into the exhaust gases prior to passage through the catalyst bed. The SCR process can achieve up to 90% reduction of NO_x with a new catalyst. As the catalyst ages, the maximum NO_x reduction will decrease to approximately 86 percent.

Given the applicant's proposed BACT level for nitrogen oxides control stated above, an evaluation can be made of the cost and associated benefit of using SCR as follows:

The applicant has indicated that the total levelized annual cost (operating plus amortized capital cost) to install SCR for natural gas firing at 100 percent capacity factor is \$2,190,000. Taking into consideration the total levelized annual cost, a cost/benefit analysis of using SCR can now be developed.

Based on the information supplied by the applicant, it is estimated that the maximum annual NOx emissions with wet injection from the Lakeland facility will be 425 tons/year. Assuming that SCR would reduce the NOx emissions by an additional 80-85%, the SCR would control at least 340 tons of NOx annually for natural gas firing. When this reduction is taken into consideration with the total levelized annual cost of \$2,190,000, the cost per ton of controlling NOx is \$6,441. This calculated cost is higher than has previously been approved as BACT.

Since SCR has been determined to be BACT for several combined cycle facilities, the EPA has clearly stated that there must be unique circumstances to consider the rejection of such control on the basis of economics.

In a recent letter from EPA Region IV to the Department regarding the permitting of a combined cycle facility (Tropicana Products, Inc.), the following statement was made:

"In order to reject a control option on the basis of economic considerations, the applicant must show why the costs associated with the control are significantly higher for this specific project than for other similar projects that have installed this control system or in general for controlling the pollutant."

A review of the combined cycle facilities in which SCR has been established as a BACT requirement indicates that the majority of these facilities are also intended to operate at high capacity factors. As this is the case, the proposed project is similar to other facilities in which SCR has been established as BACT, thereby supporting SCR as BACT for the proposed facility.

For fuel oil firing, the cost associated with controlling NOx emissions must take into account the potential operating problems that can occur with using SCR in the oil firing mode.

A concern associated with the use of SCR on combined cycle projects is the formation of ammonium bisulfate. For the SCR process, ammonium bisulfate can be formed due to the reaction of sulfur in the fuel and the ammonia injected. The ammonium bisulfate formed has a tendency to plug the tubes of the heat recovery steam generator leading to operational problems. As this is the case, SCR has been judged to be technically infeasible for oil firing in some previous BACT determinations.

The latest information available now indicates that SCR can be used for oil firing provided that adjustments are made in the ammonia to NOx injection ratio. For natural gas firing operation NOx emissions can be controlled with up to a 90 percent efficiency using a 1 to 1 or greater injection ratio. By lowering the injection ratio for oil firing, testing has indicated that NOx can be controlled with efficiencies ranging from 60 to 75 percent. When the injection ratio is lowered there is not a problem with ammonium bisulfate formation since essentially all of the ammonia is able to react with the nitrogen oxides present in the combustion gases.

Based on this strategy SCR has been both proposed and established as BACT for oil fired combined cycle facilities with NOx emission limits ranging from 11.7 to 25 ppmvd depending on the efficiency of control established.

Assuming that the lowered ammonia injection ratio strategy was used to control NOx emissions by 65%, the SCR would control 386 tons of NOx annually for oil/gas firing, assuming a maximum capacity factor of 33 percent on oil. When this reduction is taken into consideration with the total annual cost of \$2,190,000, the cost per ton of controlling NOx is \$5,674. This cost is lower than that determined for natural gas firing alone; however, it is still higher than what has been previously accepted as BACT.

Environmental Impact Analysis

The predominant environmental impacts associated with this proposal are related to the use of SCR for NOx control. The use of SCR results in emissions of ammonia, which may increase with increasing levels of NOx control. In addition, some catalysts may contain substances which are listed as hazardous waste, thereby creating an additional environmental burden. Although the use of SCR does have some environmental impacts, the disadvantages do not outweigh the benefit which would be provided by reducing nitrogen oxide emissions by 80 percent. The overwhelming benefit of NOx control by using SCR is substantiated by the fact that nearly one half of all BACT determinations have established SCR as the control measure for nitrogen oxides over the last five years.

In addition to the criteria pollutants, the impacts of toxic pollutants associated with the combustion of natural gas and No. 2 fuel oil have been evaluated. Beryllium for oil fired operation exceeds PSD significant levels. Other toxics are expected to be emitted in minimal amounts, with the total emissions combined to be less than 0.1 tons per year.

Although the emissions of the toxic pollutants could be controlled by particulate control devices such as a baghouse or scrubber, the amount of emission reductions would not warrant the added expense. As this is the case, the Department does not believe that the BACT determination would be affected by the emissions of the toxic pollutants associated with the firing of natural gas or No. 2 fuel oil.

Potentially Sensitive Concerns

With regard to controlling NOx emissions with SCR, the applicant has identified the following technical limitations:

1. SCR would reduce output of combustion turbines by one percent.
2. SCR could result in the release of unreacted quantities of ammonia to the atmosphere.
3. SCR would require handling of ammonia by plant operators. Since it is a hazardous material, there is a concern about safety and productivity of operators.
4. SCR results in contaminated catalyst from flue gas trace elements which could be considered hazardous. Safety of operators and disposal of spent catalyst is a concern.

BACT Determination by DER

NOx Control

A review of the permitting activities for combined cycle proposals across the nation indicates that SCR has been required and most recently proposed for installations with a variety of operating conditions (i.e., natural gas, fuel oil, capacity factors ranging from low to high). However, the cost and other concerns expressed by the applicant are valid.

The information that the applicant presented and Department calculations indicates that the incremental cost of controlling NOx (\$6,441/ton) for natural gas is high compared to other BACT determinations which require SCR. However, the cost of controlling NOx emissions for oil firing (\$4,600/ton) could be considered reasonable. Based on the information presented by the applicant and the studies conducted, the Department believes that the use of SCR for NOx control is not justifiable at this time as BACT. Therefore, the Department is willing to accept low NOx combustors with the firing of natural gas as the primary fuel. However, No. 2 distillate oil firing must be limited to 1/3 of the annual capacity factor. The applicant is also expected to design the facility to accommodate SCR should additional oil usage become necessary and SCR becomes a BACT requirement in the future.

SO₂ Control

For sulfur dioxide BACT is represented by firing natural gas or No. 2 fuel oil with an average sulfur content not to exceed 0.20 percent.

Other Emissions Control

The emission limitations for PM and PM₁₀, are based on previous BACT determinations for similar facilities, with the heavy metal beryllium being addressed through the particulate limitation and sulfuric acid mist being addressed through the sulfur dioxide limitation.

The emission limits for the City of Lakeland project are thereby established as follows:


Pollutant	Emission Limit	
	Natural Gas Firing	No. 2 Fuel Oil Firing
NOx	25 ppmvd @ 15% O ₂	42 ppmvd @ 15% O ₂ *
SO ₂	Natural gas as fuel	Sulfur content not to exceed 0.20%
CO	25 ppmvd @ 15% O ₂	25 ppmvd @ 15% O ₂
PM & PM ₁₀	0.006 lb/MMBtu	0.025 lb/MMBtu
Sulfuric Acid Mist	Emissions limited by natural gas and No. 2 fuel oil firing	
Beryllium	Emissions limited by natural gas and No. 2 fuel oil firing	

* No. 2 fuel oil usage limited to 1/3 of the total heat input on an annual basis.

Details of the Analysis May be Obtained by Contacting:

Preston Lewis, P.E., BACT Coordinator
Department of Environmental Regulation
Bureau of Air Regulation
2600 Blair Stone Road
Tallahassee, Florida 32399-2400


Recommended by:


C. H. Fancy, P.E., Chief
Bureau of Air Regulation

Date

July 14, 1991

Approved by:


Carol M. Browner, Secretary
Dept. of Environmental Regulation

Date

July 26, 1991

Memorandum

Florida Department of Environmental Protection

TO: Howard L. Rhodes

THRU: Clair H. Fancy *CHF*
A.A. Linero *aa Linero* 5/19

FROM: Teresa Heron *TH*

DATE: May 22, 2000

SUBJECT: City of Lakeland Larsen Unit 8
DEP File No. 1050003-007-AC / PSD-FL-166C

BAH
RECEIVED
MAY 26 2000
BUREAU OF AIR REGULATION

Attached is the final package for the compressor inlet fogger project at the Larsen Power Plant. The permit is to install inlet foggers ahead of the compressor inlet of their combined cycle combustion turbine identified as Unit 8. The foggers will operate on hot days and days of relatively low humidity. The evaporative cooling effected by the foggers will allow the units to operate closer to their rated capacity.

Both short-term and annual emissions will increase because the heat rate through the units will increase when the foggers are used. Maximum short-term emissions will still occur during cold days when use of the foggers is not feasible. The units already comply with 40 CFR 60, Subpart GG, so NSPS applicability is not an issue.

Lakeland demonstrated that even continuous operation of the foggers will not trigger PSD. Conditions favorable for use of the foggers are naturally limited to low relative humidity and moderate to high temperatures (> 60 degrees F).

We recommend your signature and approval of the permit.

AAL/th

Attachments