



Farzie Shelton, chE; REM

Environmental Affairs Manager of Licensing & Permitting

RECEIVED

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

APR 28 2000

April 21, 2000

BUREAU OF AIR REGULATION

Mr. Clair Fancy P.E
Chief of the Bureau of Air Management
Division of Air Resources Management
Florida Department of Environmental Protection
111 S. Magnolia
Suite 4
Tallahassee, FL 32301

Dear Mr. Fancy:

Re: Draft Air Construction Permit, DEP File No. PSD-FL-166© and 1050003-007-AC
City of Lakeland, Department of Electric Utilities
Charles Larsen Memorial Power Plant – Inlet Fogger

We are in receipt of your letter dated April 13, 2000 and attached Draft Air Construction Permit , Technical Evaluation and Preliminary Determination, and Public Notice of Intent to Issue Air Construction Permit for the above referenced project.

Pursuant to Section 403.815, Florida Statutes and DEP Rule 62-103.150, F.A.C., on April 19, 2000 we published the "Public Notice of Intent to Issue Air Construction Permit " in the Lakeland Ledger. Therefore, enclosed please find Affidavit of Publication confirming publication of the Department's notice.

If you should have any questions, please do not hesitate to contact me.

Sincerely

A handwritten signature in black ink, appearing to read 'Farzie Shelton'.

Farzie Shelton

Enclosure

CC: SWD
EPA
T. Heron, BAR

City of Lakeland • Department of Electric Utilities

RECEIVED BY THE LIBRARY OF THE UNIVERSITY OF TORONTO

10

CITY OF TORONTO LIBRARY

MAY 21 1968

МОСКОВСКАЯ
ГИРДОВАЯ
ПРОДУКЦИЯ
ПОДДЕРЖИВАЕТ
СОВЕТСКИЙ
СОЮЗ
+
СМССР

Советский Союз и СССР поддерживает Москву
и Гирдову продукцию в борьбе за
свободу и демократию в Африке.

Советский Союз и СССР поддерживает Москву
и Гирдову продукцию в борьбе за демократию
и социальную справедливость в Африке.

Советский Союз и СССР поддерживает Москву
и Гирдову продукцию в борьбе за демократию
и социальную справедливость в Африке.

Советский Союз и СССР поддерживает Москву

и Гирдову продукцию в борьбе за демократию

и социальную справедливость в Африке.

Советский Союз и СССР поддерживает Москву

и Гирдову продукцию в борьбе за демократию

и социальную справедливость в Африке.

Советский Союз и СССР поддерживает Москву

и Гирдову продукцию в борьбе за демократию

и социальную справедливость в Африке.

Советский Союз и СССР поддерживает Москву

и Гирдову продукцию в борьбе за демократию

и социальную справедливость в Африке.

AFFIDAVIT OF PUBLICATION

THE LEDGER

Lakeland, Polk County, Florida

Case No

STATE OF FLORIDA)
COUNTY OF POLK)

Before the undersigned authority personally appeared Nelson Kirkland, who on oath says that he is Classified Advertising Manager of The Ledger, a daily newspaper published at Lakeland in Polk County, Florida; that the attached copy of advertisement, being a

..Notice of Intent to Issue Air Construction Permit.....

in the matter ofDEP File No. 1050003-007-AC (PSD-FL-166C).....

in the.....

Court, was published in said newspaper in the issues of.....

..4-19-2000.....

Affiant further says that said The Ledger is a newspaper published at Lakeland, in said Polk County, Florida, and that the said newspaper has heretofore been continuously published in said Polk County, Florida, daily, and has been entered as second class matter at the post office in Lakeland, in said Polk County, Florida, for a period of one year next preceding the first publication of the attached copy of advertisement; and affiant further says that he has neither paid nor promised any person, firm or corporation any discount, rebate, commission or refund for the purpose of securing this advertisement for publication in the said newspaper.

Signed.....

Nelson Kirkland
Classified Advertising Manager
Who is personally known to me.

Sworn to and subscribed before me this.....

day of April A.D. 2000

JENNIFER L. CLENDENING

JENNIFER L. CLENDENING



(Seal)

My Commission Expires.....

11/10/04

Attach Notice Here

PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
DEP File No. 1050003-007-AC (PSD-FL-166C)
City of Lakeland, Department of Electric Utilities
Lorenzen Power Plant - Inlet Fogger Project
Polk County

The Department of Environmental Protection (Department) gives notice of its intent to issue an air construction permit to the City of Lakeland. The permit is to install foggers at the compressor inlet of a dual fired GE General Electric PC711FA combined cycle combustion turbine electric power generator, identified as emission unit 008 of the Lorenzen Power Plant in Polk County. A Best Available Control Technology (BACT) determination was not required pursuant to Rule 62-212.400, F.A.C. The applicant's normal operating conditions are City of Lakeland, Department of Electric Utilities 501 E. Leon Street, Lakeland, Florida 33801-5079.

The combustion turbine, nominally rated at approximately 90 megawatts (MW), at 50 degrees when firing gas, this combustion turbine (exclusive of the steam cycle) normally achieves its maximum rated output of approximately 100 MW on cold (20 degrees) days because the greater compression inlet air density allows greater throughput in the rotor or expansion section of the combustion turbine. The maximum power output is only about 80 MW on hot (90 degrees) days because of the lower compressor inlet air density. The foggers will increase hot-day power output (under very dry conditions) by as much as 6 MW per the combustion turbine, thus almost restoring the units to their nominal ratings. Under the design conditions for the Florida site (90 degrees and 50 percent humidity), an improvement of about 3 MW can be expected.

The foggers provide no benefit under humid or cold (less than approximately 50 degrees) conditions and will not be used when it occurs. The maximum output of approximately 100 MW will continue to occur at low ambient temperature. The result is that maximum hourly emissions will not increase although actual annual emissions will increase within their permitted limits because more fuel will be used on hot, relatively dry days.

Although the number of days during which the foggers can economically operate limits emissions increases to levels below significance for the purposes of PSD applicability, the City calculated the Department accepts that the modifications may cause any meaningful change in the actual hours of operation of the combined cycle unit, the unit will still operate continuously and already have a very high availability factor. The maximum increase in annual emissions caused by the project in tons per year is summarized below along with the PSD significant levels.

Pollutants	Annual Emission Increase	PSD Significant Levels
PM ₁₀	1.32	25/15
SO ₂	7.43	40
NO _x	13.21	40
VOC	0.44	40
CO	5.99	100

An air quality impact analysis was not required or conducted. No significant impacts are expected to occur as a result of this project. It will not cause or contribute to a violation of any ambient air quality standard or increment.

The Department will issue the FINAL permit with the attached conditions unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments concerning the proposed permit issuance action for a period of thirty (30) days from the date of publication of "Public Notice of Intent to Issue Air Construction Permit". Written comments should be provided to the Department's Bureau of Air Regulation at 2400 Blair Stone Road, Mail Station #5005, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If written comments result in a significant change in the proposed agency action, the Department shall revise the proposed permit and resubmit, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57 of this chapter. Petitions for administrative hearing must contain the information set forth below and must be filed (received) in 3500 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions for administrative hearing must be filed within fourteen (14) days of receipt of the public notice or any comments filed by any persons other than those entitled to written notice under Section 120.503 of the Florida Administrative Code. The petition must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of the Department's proposed agency action. Under Section 120.503, however, any person who filed a notice, regardless of the date of filing, may file a petition within fourteen (14) days of receipt of the proposed agency action. The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The fact that any person to file a petition for an administrative hearing (under Sections 120.569 and 120.57 F.S.) or intervene in the proceeding and participate as a party to it. Any subsequent intervention will be out of the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-105.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) the name and address of each agency, bureau, and department, and agency file or identification number, if known, (b) the name, address, and telephone number of the petitioner, (c) the name, address, and telephone number of the petitioner's representative, if any, which shall be used for service purposes during the course of the proceeding, and an explanation of how the petitioner's substantive rights will be affected by the agency determination, (d) A statement of all disputed issues of material fact, if there are none, the petition must so indicate, (e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief, and (f) A demand for relief.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-105.301.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by the agency. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding in accordance with the requirements set forth above.

A completed project file is available for public inspection during normal business hours, 8 A.M. to 5 P.M., Monday through Friday, except legal holidays, at:

Department of Environmental Protection
Bureau of Air Regulation
1115 Magnolia Drive, Suite 4
Tallahassee, Florida 32301
Telephone: 850/488-0114
Fax: 850/222-6979

Department of Environmental Protection
Southwest District Office
300 South Coopersburg Drive
Tampa, Florida 33612-6218
Telephone: 813/744-6100
Fax: 813/744-5084

The complete project file includes the application, technical evaluation, Draft Permit, and the 403.111, F.S. Interested persons may contact the Administrator, New Resource Review Section at 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301, or call 850/488-0114, for additional information.

D-917 - 4-10-2000

**City of Lakeland
Power Production
3030 E. Lake Park
Lakeland, FL 338**

937 һԵՅ 596 դ


CERTIFIED

二三

RETURN RECEIPT REQUESTED

Mr. Clair Fancy P.E.

Chief of the Bureau of Air Mgmt.
Division of Air Resources Mgmt.
Florida Dept of Env. Prot. NO RETURN
111 S. Magnolia, Suite 4
Tallahassee, FL 32301



850

488-1344

Telephone

PER
LE

100% vehicles
and 100%

卷之三

四庫全書

LAKELAND
ELECTRIC