

**Heron, Teresa**

---

**From:** Kosky, Ken [KKosky@GOLDER.com]  
**Sent:** Wednesday, August 27, 2003 1:33 PM  
**To:** Heron, Teresa  
**Cc:** Farzie Shelton (Farzie.Shelton@lakelandelectric.com)  
**Subject:** Larsen Unit 8 - Heat Input Curves

Teresa: Attached are the heat input curves you requested. These contain the same information contained in the application but in graphical form. Let me know if you have any questions. Regards, Ken

-----

Attachments are virus free!


This message has been scanned for viruses at the originating end by

Nemx Anti-Virus for MS Exchange Server/IMC

<http://www.nemx.com/products/antivirus>


9/26/2003

# Larson Unit 8 - Gas Heat Input vs Compressor Inlet Temperature



Note: Curves based on GE data for 60% relative humidity, new and clean condition. Actual performance will vary depending upon turbine inlet conditions (e.g., fogging), NOx injection water and turbine backpressure.

### Larson Unit 8 - Oil Heat Input vs Compressor Inlet Temperature



Note: Curves estimated from GE data for 60% relative humidity, new and clean condition, gas firing. Actual performance will vary depending upon turbine inlet conditions (e.g., fogging), NOx injection water and turbine backpressure. Oil performance estimated based on GE original curves used to adjust heat input for oil firing.

Heron, Teresa

---

**From:** Kosky, Ken [KKosky@GOLDER.com]  
**Sent:** Tuesday, August 12, 2003 9:55 AM  
**To:** Heron, Teresa  
**Cc:** Farzie Shelton (Farzie.Shelton@lakelandelectric.com)  
**Subject:** Lakeland Electric Larsen Unit 8

Teresa: The following changes are requested relative to the previous air construction permit (AC53-190437/PSD-FL-166).

Condition 1:

Table 1 referenced in this condition shall be replaced with the attached Table 1:

- o Change SO2 from 8.6 tons/year to 12.9 tons/year for gas firing.

Condition 6:

From (the heat input condition only):

- o Maximum heat input shall not exceed 1055 MMBtu/hr (gas) or 1040 MMBtu/hr No 2 fuel (oil)

To:

- o Maximum heat input shall not exceed 1075 MMBtu/hr (gas) or 1060 MMBtu/hr No. 2 fuel (oil) on a lower heating value basis for baseload operation and an inlet temperature of 25 degrees F
- o Maximum heat input shall not exceed 1161 MMBtu/hr (gas) or 1149 MMBtu/hr No. 2 fuel (oil) on a lower heating value basis for peak operation and an inlet temperature of 25 degrees F
- o Peak operation is authorized for 2,500 hours/yr when firing natural gas and 500 hour/year when firing No. 2 fuel (oil); if fuel oil is not fired or not used for up to 500 hours in any consecutive 12-month period, peak operation on natural gas is authorized up to an additional 500 hours minus the number of hours when fuel oil was fired during that period

These are the only changes to the AC and PSD permit. Once these are issued we will file a revision of the Title V permit to include these changes as well as several others in the Title V permit. At this time we will include the new heat input curves. Let me know if you have any questions.

Regards, Ken

8/12/2003



**Farzie Shelton, chE; REM**

Manager of Environmental Affairs

July 1, 2003

Ms. Trina Vielhauer, Chief  
Bureau of Air Regulation  
Florida Department of Environmental Protection  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

**Attention: Mr. A. A. Linero, P.E., Administrator New Source Review**

**RE: DEP File No. 105003-008-AC; PSD-FL-166(D)  
Lakeland Electric, Charles Larsen Power Plant  
Combined Cycle Unit 8 – Peak Operation and Turbine Upgrades**

Dear Al:

Thank you for your letter of April 28, 2003 in reference to the above concerning our request to increase heat input for Unit No. 8 at Larsen Power Plant. In response to your letter and request for additional information, Mr. Ken Kosky P.E. of Golder Associate has responded to each request in the same format as your letter. Therefore, please find attached Mr. Kosky's response which has been P.E. signed and sealed.

As always, we appreciate your cooperation in this matter. If you should have any questions, please do not hesitate to call me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Farzie Shelton', with a long horizontal line extending to the right.

Farzie Shelton

Enclosures

cc: Ken Kosky P.E.

**City of Lakeland • Department of Electric Utilities**

---

**501 East Lemon Street • Lakeland, FL 33801-5050 • (863) 834-6603 • Fax (863) 834-8187 • Message System 834-6592**

**farzie.shelton@lakelandgov.net**

**Golder Associates Inc.**

6241 NW 23rd Street, Suite 500  
Gainesville, FL 32653-1500  
Telephone (352) 336-5600  
Fax (352) 336-6603

**RECEIVED**

**JUN 30 2003**



**Environmental Affairs**

June 26, 2003

Ms. Farzie Shelton, Manager of Environmental Affairs  
Lakeland Electric  
501 East Lemon Street  
Lakeland, FL 33801

**RECEIVED** 0237037

**JUL 02 2003**

**BUREAU OF AIR REGULATION**

RE: DEP File No. 105003-008-AC; PSD-FL-166(D)  
City of Lakeland, Charles Larsen Power Plant  
Combined Cycle Unit 8 – Peak Operation and Turbine Upgrades  
Request for Information

Dear Farzie:

This correspondence provides the information requested in the Department's April 28, 2003 letter concerning the request to increase heat input for Larsen Unit 8. The information is being presented in the same format as the letter.


1. **Contemporaneous Creditable Increases in Actual Emissions:** The only contemporaneous increase in emissions at the Larsen Plant was the installation of the inlet foggers as noted in the Department's letter. The Department approved the installation of the foggers in May 2000 (DEP File No. 105003-007-AC; PSD-FL-166C), and the fogger system has been installed and included in the Title V Permit for the facility. Please find attached Table 10a that includes the emissions of the foggers with the potential emission increases resulting from increased heat input. As shown in this table, the emissions for the heat input increase plus the contemporaneous emission increases are less than the PSD review thresholds.
2. **Modes of Operation:** In the air permit application, the emission increases were based on the maximum number of hours anticipated for peak firing. The City of Lakeland requests that the hours of peak operation be limited to 2,500 hours per year when firing gas and 500 hours per year when firing oil.
3. **Technical Upgrades:** As stated in the air permit application, the upgrades involve a GE proprietary enhancement in the design of the high-pressure seals of the compressor discharge. A high-pressure brush seal has been added to the existing Labyrinth seal design to minimize air leakage from the compressor to the combustor (see attached figure). This allows more air into the combustor and exhaust turbine, which slightly increases the performance turbine. This change does not affect the combustion turbine's automatic control system, fuel system logic, or the water injection system for NO<sub>x</sub> control. However, as stated in the air permit application, the increase in performance is theoretical and GE will not guarantee the performance since the turbine has been operated for about 10 years. The existing combustor uses water injection for NO<sub>x</sub> control, and upgrade to the dry low-NO<sub>x</sub> (DLN) combustor cannot be made.
4. **GE Model PG 7111EA Specifications:** The GE performance curves for the PG 7111EA combustion turbine operating in both baseload and peak mode are attached. As noted by the

dates of these curves, Peak Mode operation was included in the original design of Unit 8.  
The heat input limit in the original permit however reflected baseload operation.

Please call me if there are any questions on the information contained herein.

Sincerely,

GOLDER ASSOCIATES INC.



Kennard F. Kosky, P.E.  
Principal  
Professional Engineer Registration No. 14996

SEAL

KFK/nav

Enclosures

P:\Projects\2002-0237637 Lakeland 4-4.1\062603\L062603.doc

Table 10a. Maximum Annual Emissions of the City of Lakeland Larsen Plant Unit 8 - Combustion  
Turbine Peak Operation and Upgrades; includes Inlet Fogger Emissions

Pollutants	Annual Emissions (tons/year) for Upgrades and Peak				Annual Emissions (tons/year) Inlet Foggers <sup>(1)</sup>	Total Annual Emissions (tons/year)	PSD SERs <sup>(2)</sup> (tons/year)
	Peak Operation	Base w/Upgrades	Peak w/Upgrades	Total			
Hours:	3,000	5,760	3,000	8,760	8,760		
PM	1.15	0.64	0.27	2.06	1.32	3.38	15 & 25 <sup>(3)</sup>
NO <sub>x</sub>	13.92	6.40	3.29	23.61	13.21	36.82	40
SO <sub>2</sub>	4.53	3.60	1.08	9.21	7.43	16.64	40
CO	6.92	2.90	1.63	11.46	5.99	17.45	100
VOC	0.37	0.21	0.09	0.67	0.44	1.11	40

<sup>(1)</sup> Inlet Foggers were approved in May 2000 in DEP File No. 1050003-007-AC(PSD-FL166C).

<sup>(2)</sup> PSD = Prevention of Significant Deterioration; SERs - Significant Emission Rates: Rule 62-212.400(2)(e)2.

<sup>(3)</sup> 15 tons/year is for PM<sub>10</sub> and 25 tons/year is for PM.





# ***Frame 7 Advance Technology Uprate***

## **High-Pressure Packing / Inner Barrel**

### **■ Brush Seals**

- Minimize Air Leakage
- Tolerant of Misalignments
- More Durable than Labyrinth Seals

***NOTE: New unit production 71EAs have a honeycomb seal on the inner barrel with labyrinth teeth on the aft stub shaft. For this configuration, a new inner barrel is supplied with a brush seal in addition to the honeycomb seal.***



**GE PERFORMANCE DATA FOR  
PG7111(EA) GAS TURBINE**


**GENERAL ELECTRIC MODEL PG7111 (EA) GAS TURBINE**  
**ESTIMATED PERFORMANCE - CONFIGURATION: NATURAL GAS / DISTILLATE OIL**  
 Compressor Inlet Conditions 59 F (15.0 C), 60% Rel. Humidity  
 Atmospheric Pressure 14.7 psia (1.013 bar)

FUEL			NATURAL GAS		DISTILLATE
DESIGN OUTPUT		kw	83340		81940
DESIGN HEAT RATE (LHV)		Btu (kJ)/kWh	10500 (11080)		10580 (11160)
DESIGN HEAT CONS (LHV)	X10 <sup>-6</sup>	Btu (kJ)/h	875.1 (923.3)		867 (914.6)
DESIGN EXHAUST FLOW	X10 <sup>-3</sup>	lb (kg)/h	2351 (1066)		2358 (1069)
MODE: BASE LOAD					

**NOTES:**

- Altitude correction on curve 416HA622 REV A
- Ambient temperature correction on curve 499HA734
- Air cooled generator
- Humidity correction on curve 498HA697 - all performance calculated with specific humidity of .0064 or less so as not to exceed 100% relative humidity.
- Plant performance is measured at the generator terminals and includes allowances for excitation power, shaft driven auxiliaries, and 2.5 in. H<sub>2</sub>O (6.25 mbar) inlet and 5.5 in. H<sub>2</sub>O (13.75 mbar) exhaust pressure drops.
- Additional pressure drop effects:

	%Effect on Output	%Effect on Heat Rate	Effect on Exhaust Temp.
4.0 in. H <sub>2</sub> O (10.0 mbar) inlet	-1.42	0.45	1.9 F (1.1 C)
4.0 in. H <sub>2</sub> O (10.0 mbar) exhaust	-0.42	0.42	1.9 F (1.1 C)




DATE: 07/08/88  
 C.N. MULLER

499HA733

# GENERAL ELECTRIC MODEL PG7111(EA) GAS TURBINE

EFFECT OF COMPRESSOR INLET TEMPERATURE ON  
OUTPUT, HEAT RATE, HEAT CONSUMPTION, EXHAUST FLOW  
AND EXHAUST TEMPERATURE AT 100% SPEED

FUEL: NATURAL GAS AND DISTILLATE OIL  
MODE: BASE LOAD



DATE 07/06/88


499HA734

C.N. MULLER

CNM

# GENERAL ELECTRIC MODEL PG7111EA GAS TURBINE EFFECT OF WATER INJECTION ON OUTPUT BASE LOAD - Distillate/Natural Gas DESIGN VALUES on curve 499HA733 Rev.A

Based on a constant specific humidity of 0.0064 lbs of water per pound of dry air, except for temperatures below 45 deg F, where fully saturated air results in a lower specific humidity.




5/13/91  
SK DRAPALA 

499HA928 Rev.B  
supersedes 7/13/89

# GENERAL ELECTRIC MODEL PG7111EA GAS TURBINE EFFECT OF WATER INJECTION ON HEAT RATE BASE LOAD - Distillate/Natural Gas DESIGN VALUES on curve 499HA733 Rev.A

Based on a constant specific humidity of 0.0064 lbs of water per pound of dry air, except for temperatures below 45 deg F, where fully saturated air results in a lower specific humidity.



5/13/91  
SK DRAPALA

SK

499HA929 Rev.A  
supersedes 4/12/89

# **GENERAL ELECTRIC MODEL PG7111(EA) GAS TURBINE** **ESTIMATED PERFORMANCE – CONFIGURATION: NATURAL GAS & DISTILLATE**

Compressor Inlet Conditions 59 F (15.0 C), 60% Rel. Humidity


Atmospheric Pressure 14.7 psia (1.013 bar)

FUEL		NATURAL GAS	DISTILLATE
DESIGN OUTPUT	kW	90200	88720
DESIGN HEAT RATE (LHV)	Btu (kJ)/kWh	10450 (11020)	10520 (11100)
DESIGN HEAT CONS (LHV) X10-6	Btu (kJ)/h	942.6 (994.4)	933.3 (984.7)
DESIGN EXHAUST FLOW X10-3	lb/h (kg)/h	2353 (1067)	2359 (1070)
MODE: PEAK LOAD			PPB 040486

## **NOTES:**

- Altitude correction on curve 416HA662 REV A
- Ambient temperature correction on curve 516HA137
- Effect of modulated IGV's on exhaust flow and temp. on curve 516HA129
- Air cooled generator 7A6
- Humidity correction on curve 498HA697 REV B – all performance calculated with specific humidity of .0064 or less so as not to exceed 100% relative humidity.
- Plant performance is measured at the generator terminals and includes allowances for excitation power, shaft driven auxiliaries, and 2.5 in. H<sub>2</sub>O (6.25 mbar) inlet and 5.5 in. H<sub>2</sub>O (13.75 mbar) exhaust pressure drops.
- Additional pressure drop effects:

	%Effect on Output	%Effect on Heat Rate	Effect on Exhaust Temp.
4 in. H <sub>2</sub> O (10.0 mbar) inlet	-1.42	0.45	1.9 F (1.1 C)
4 in. H <sub>2</sub> O (10.0 mbar) exhaust	-0.42	0.42	1.9 F (1.1 C)




DATE: 10/25/89  
 DA JAQUEWAY

516HA136

# GENERAL ELECTRIC MODEL PG7111(EA) GAS TURBINE

Effect of Compressor Inlet Temperature on  
Output, Heat Rate, Heat Consumption, Exhaust Flow  
And Exhaust Temperature at 100% Speed

FUEL: NATURAL GAS & DISTILLATE OIL  
DESIGN VALUES ON CURVE 516HA136  
DESIGN MODE: PEAK LOAD




DATE 10/25/89  
DA JAQUEWAY

516HA137



# GENERAL ELECTRIC MODEL PG7111EA GAS TURBINE EFFECT OF WATER INJECTION ON OUTPUT PEAK LOAD - Distillate/Natural Gas DESIGN VALUES on curve 516HA136

Based on a constant specific humidity of 0.0064 lbs of water per pound of dry air, except for temperatures below 45 deg F, where fully saturated air results in a lower specific humidity.




5/13/91  
SK DRAPALA

499HA930 rev B  
supersedes 7/13/89

# GENERAL ELECTRIC MODEL PG7111EA GAS TURBINE EFFECT OF WATER INJECTION ON HEAT RATE PEAK LOAD - Distillate/Natural Gas DESIGN VALUES on curve 516HA136

Based on a constant specific humidity of 0.0064 lbs of water per pound of dry air, except for temperatures below 45 deg F, where fully saturated air results in a lower specific humidity.



5/13/91  
SK DRAPALA *SK*


499HA931 rev B  
supersedes 7/13/89

# GENERAL ELECTRIC MODEL PG7111EA GAS TURBINE

ESTIMATED WATER SCHEDULE - CITY OF LAKELAND DM-GR0212

Water Injection at 250 psia/70 F to limit NOx to 26 ppmvd

@ 16% O<sub>2</sub> on Natural Gas Fuel.



D. E. Kessler  
1/2/91


516HA585, REVISION A

# GENERAL ELECTRIC MODEL PG7111EA GAS TURBINE

## ESTIMATED WATER SCHEDULE - CITY OF LAKELAND DM-GR0212


Water Injection at 250 psia/70 F to limit NOx to 42 ppmvd

@ 15% O<sub>2</sub> on Distillate Oil Fuel.



D. E. Kessler  
1/2/91

516HA586, REVISION A



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

April 28, 2003

## CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Timothy Bates  
Director of Energy Supplies  
Lakeland Electric  
501 E. Lemon Street  
Lakeland, Florida 33801-5079

Re: DEP File No. PSD-FL-166(D) and 1050003-<sup>012</sup>~~008~~-AC  
Charles Larsen Memorial Power Plant – Combined Cycle Unit 8  
Increase of Heat Input Rate and Peak Mode Operation Request

Dear Mr. Bates:

The Department received your application for the modification to Unit 8 to reflect performance enhancements and peak mode operation. Based on a technical review, the application is incomplete. Please submit the following information, including all assumptions, reference materials and calculations:

1. Please recalculate the net emission increases (sum of all 5 year contemporaneous creditable increases and decreases in the actual emissions of the facility) for all affected PSD pollutants listed in Table 62-212.400-2, F.A.C., to determine PSD applicability. Our records show an increase of emissions (TPY) due to the foggers installation project in the year 2000. Rule 62-212.400 (2)(e), F.A.C.
2. Under what different modes of operation is this unit currently operating? Please recalculate the emission rates under the different scenarios this unit will be operating. It is not clear from the information submitted, if this unit will be operating 3000 hr/yr (Table 10) or few hours per year (page 1 of Part II of application) on peak mode. Would this unit be operating on peak mode during simple or combined cycle operation or both? Natural gas or fuel oil burning? Please explain.
3. Expand the technical information regarding the upgrade of this unit, the information in the application states that the upgrade "involve enhancements to the compressor discharge (high pressure brush seal) that limit the amount of air leakage". Please submit GE technical documents that explain this issue. Is the Low NOx burner (LNB) system being upgraded? Could it be possible to upgrade the LNB system along with the proposed upgrade?
4. Please supply the manufacturer's specifications for the GE Model PG 7111EA.

"More Protection, Less Process"

Printed on recycled paper.

Mr. Timothy Bates  
April 28, 2003

Rule 62-4.050(3), F.A.C. requires that all applications for a Department permit must be certified by a professional engineer registered in the State of Florida. This requirement also applies to responses to Department requests for additional information of an engineering nature. Please note that per Rule 62-4.055(1): *"The applicant shall have ninety days after the Department mails a timely request for additional information to submit that information to the Department.... Failure of an applicant to provide the timely requested information by the applicable date shall result in denial of the application."*

If you have any questions regarding this matter, please call Teresa Heron (Review Engineer) at (850) 921-9529.

Sincerely,

A handwritten signature in black ink, appearing to read 'A. A. Linero', written in a cursive style.

A. A. Linero, P.E. Administrator  
New Source Review Section

AAL/th

Cc: Farzie Shelton, Lakeland Electric  
Ken Kosky P.E., Golder Associates  
Gerry Kissel, DEP SWD  
Gregg Worley, EPA

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. Timothy Bates  
Director of Energy Supplies  
Lakeland Electric  
501 E. Lemon Street  
Lakeland, FL 33801-5079

**COMPLETE THIS SECTION ON DELIVERY**A. Received by (Please Print Clearly) Bonnie Brennan B. Date of Delivery 4-30-03C. Signature Bonnie Brennan ☐ Agent ☐ AddresseeD. Is delivery address different from item 1? ☐ Yes  
If YES, enter delivery address below: ☐ No3. Service Type  
☒ Certified Mail ☐ Express Mail  
☐ Registered ☐ Return Receipt for Merchandise  
☐ Insured Mail ☐ C.O.D.4. Restricted Delivery? (Extra Fee) ☐ Yes7001 0320 0001 3692 6174

PS Form 3811, July 1999

Domestic Return Receipt

102595-99-M-1789

**U.S. Postal Service  
CERTIFIED MAIL RECEIPT**  
(Domestic Mail Only; No Insurance Coverage Provided)

7001 0320 0001 3692 6174

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark  
Here

Sent To Timothy Bates  
Street, Apt. No.,  
or PO Box 501 E. Lemon St.  
City, State, ZIP+4 Lakeland, FL 33801-5079

PS Form 3800, January 2001 See Reverse for Instructions