



Farzie Shelton, chE; REM

Environmental Affairs Manager of Licensing & Permitting

RECEIVED

APR 17 2000

April 12, 2000

BUREAU OF AIR REGULATION

Mr. Scott M. Sheplak, P.E.
Administrator, Title V Section
Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

**Re: Administrative Permit Correction – Title V Permit No.: 1050003-004-AV
Larsen Power Plant Peaking Gas Turbine No. 1 – E.U. ID No. 007 – Deletion from Permit**

Dear Scott:

Pursuant to our telephone discussion of April 7, 2000 in reference to our application for administrative changes to the above referenced permit, we are writing to request the Department to delete all references related to Peaking Gas Turbine No. 1 from Title V Permit for Larsen Power Plant. The reason for our request is because this unit has been dismantled and removed from the Larsen Power Plant facility and therefore is no longer in existence. Accordingly, we are enclosing our Responsible Official's formal certification of this matter. Therefore, enclosed please find this certification signed by Mr. Ronald W. Tomlin our Assistant Managing Director and Responsible Official for our Title V permits.

We look forward to receive our updated Title V permit. As always, we appreciate all the help you have offered us in our permitting endeavors and look forward to hear from you soon.

However, if you should have any questions, please do not hesitate to contact me.

Sincerely,

Farzie Shelton

Enclosure

City of Lakeland ● Department of Electric

Owner/Authorized Representative or Responsible Official

1. Name and Title of Owner/Authorized Representative or Responsible Official:

Ronald W. Tomlin, Assistant Managing Director

2. Owner/Authorized Representative or Responsible Official Mailing Address:

Organization/Firm: **Lakeland Electric**

Street Address: **501 East Lemon Street**

City: **Lakeland**

State: **FL**

Zip Code: **33801-5079**

3. Owner/Authorized Representative or Responsible Official Telephone Numbers:

Telephone: **(863) 834-8474**

Fax: **(863) 834-6373**

4. Owner/Authorized Representative or Responsible Official Statement:

I, the undersigned, am the owner or authorized representative(check here [], if so) or the responsible official (check here [], if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.*

Ronald W. Tomlin

Signature

4-12-00

Date

* Attach letter of authorization if not currently on file.

File/Barbara

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

**NOTICE OF ADMINISTRATIVELY CORRECTED TITLE V OPERATION
PERMIT**

In the Matter of a Request for Administrative Correction:


Mr. Ronald W. Tomlin
Assistant Managing Director
Lakeland Electric and Water Utilities
501 E. Lemon St.
Lakeland, FL 33801-5079

FINAL Permit No.: 1050003-004-AV
Project No.: 1050003-008-AV
Larsen Power Plant

Enclosed is the ADMINISTRATIVELY CORRECTED page to the initial Title V operation permit, 1050003-004-AV for the operation of the Larsen Power Plant located at 2002 East Highway 92, Lakeland, Polk County. This correction is issued pursuant to Rule 62-210.360, Florida Administrative Code and Chapter 403, Florida Statutes (F.S.). This corrective action does not alter the effective dates of the existing permit.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.


C. H. Fancy, P.E.,
Chief
Bureau of Air Regulation

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT (including the corrected page) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 04-03-00 to the persons listed or as otherwise noted:

Ronald Tomlin, Lakeland*
Kennard Kosky, P.E., KBN Engineering and Applied Sciences, Inc.
Farzie Shelton, Lakeland
Bill Thomas, P.E., FDEP, SWD
Gregg Worley, USEPA, Region 4

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Sandra Knight 04-03-00
(Clerk) (Date)

ADMINISTRATIVE PERMIT CORRECTION
FINAL Permit No.: 1050003-004-AV
Larsen Power Plant

Table of Contents on Page i:

D. Emissions Unit -008 Combined or Simple Cycle Combustion Turbine..... 24 - 33

Section III. Emissions Units, Subsection D. on Page 24 of 41 is hereby changed:

E.U. ID No. Brief Description

-008 Combined or Simple Cycle Combustion Turbine

The emission unit is a 120 megawatt combined or simple cycle combustion gas turbine with a heat recovery steam generator (HRSG) designated as Larsen Unit #8.

Section IV, Subsection A. on Page 24 of 41 is hereby changed:

The emissions units listed below are regulated under Acid Rain Part, Phase II.

E.U. ID No. Description

-004 Fossil Fuel Fired Steam Generator #7

-008 Combined or Simple Cycle Combustion Turbine #8

Table 1-1, Summary of Air Pollutant Standards and Terms is hereby changed:

E.U. ID No. Brief Description

-008 Combined or Simple Cycle Combustion Turbine

Table 2-1, Summary of Compliance Requirements is hereby changed:

E.U. ID No. Brief Description

-008 Combined or Simple Cycle Combustion Turbine