

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

**NOTICE OF ADMINISTRATIVELY CORRECTED TITLE V OPERATION PERMIT**

In the Matter of a Request for Administrative Correction:


Mr. Ronald W. Tomlin  
Assistant Managing Director  
Lakeland Electric & Water Utilities  
501 East Lemon Street  
Lakeland, Florida 33801-5079

FINAL Permit No.: 1050003-004-AV  
Charles Larsen Memorial Power Plant

Enclosed is an ADMINISTRATIVELY CORRECTED page to the initial Title V operation permit, 1050003-004-AV for the operation of the Charles Larsen Memorial Power Plant, Polk County. This correction is issued pursuant to Rule 62-210.360, Florida Administrative Code and Chapter 403, Florida Statutes (F.S.). This change is made at the applicant's request dated April 7, 1999, to add a permitting note on capacity. This corrective action does not alter the effective dates of the existing permit.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.

  
C. H. Fancy, P.E.,  
Chief  
Bureau of Air Regulation


**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT (including the corrected page) was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on 4/20/99 to the person(s) listed or as otherwise noted:

Mr. Ronald W. Tomlin, Lakeland Electric & Water Utilities\*  
Mr. Bill Thomas, P.E., FDEP SWD  
Ms. Carla E. Pierce, USEPA, Region 4 (INTERNET E-mail Memorandum)  
Ms. Gracy R. Danois, U.S. EPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

  
(Clerk)

4/20/99  
(Date)

4/20/99 cc: Ed Ivec  
Reading File

ADMINISTRATIVE PERMIT CORRECTION  
FINAL Permit No.: 1050003-004-AV  
Charles Larsen Memorial Power Plant

**Condition B.1. is hereby changed FROM:**

**B.1. Permitted Capacity.** The maximum operation heat input rate is as follows:

<u>Unit No.</u>	<u>MMBtu/hr Heat Input</u>	<u>Fuel Type</u>
7	615.6 (HHV)	Natural Gas
	597.6 (HHV)	No. 6 Fuel Oil

Compliance with the heat input limits shall be determined based on the higher heating value (HHV) of the fuels used and fuel flow meter data.

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.]

**TO:**

**B.1. Permitted Capacity.** The maximum operation heat input rate is as follows:

<u>Unit No.</u>	<u>MMBtu/hr Heat Input</u>	<u>Fuel Type</u>
7	615.6 (HHV)	Natural Gas
	597.6 (HHV)	No. 6 Fuel Oil

Compliance with the heat input limits shall be determined based on the higher heating value (HHV) of the fuels used and fuel flow meter data.

{Permitting note: The heat input limitations have been placed in the permit to identify the capacity of each emissions unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability.}

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.]

Is your RETURN ADDRESS completed on the reverse side?

**SENDER:**

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

1. ☐ Addressee's Address
2. ☐ Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:  
Mr. Ronald W. Tomlin  
Assistant Managing Director  
Lakeland Electric & Water Utilities  
501 East Lemon Street  
Lakeland, Florida 33801-5079

4a. Article Number  
P 263 585 207

4b. Service Type  
☒ Registered ☒ Certified  
☐ Express Mail ☐ Insured  
☐ Return Receipt for Merchandise ☐ COD

7. Date of Delivery  
4-22-99

5. Received By: (Print Name)

8. Addressee's Address (Only if requested and fee is paid)

6. Signature: (Addressee or Agent)

*Ronnie Tomlin*

PS Form 3811, December 1994

102595-97-B-0179

Domestic Return Receipt

Thank you for using Return Receipt Service.

P 263 585 207

US Postal Service

**Receipt for Certified Mail**

No Insurance Coverage Provided.

Do not use for International Mail (See reverse)

Sent to Mr. Ronald W. Tomlin	
Street & Number 501 East Lemon Street	
Post Office, State, & ZIP Code Lakeland, Florida 33801-5079	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date 4/20/99	
Charles Larsen Power Plant Facility ID#1050003-004-AV	

PS Form 3800, April 1995