

Golder Associates Inc.

6241 NW 23rd Street, Suite 500
Gainesville, FL 32653-1500
Telephone (352) 336-5600
Fax (352) 336-6603



June 22, 1998

Mr. Cleve Holladay
Florida Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, FL 32399-2400

RECEIVED

JUN 25 1998

BUREAU OF
AIR REGULATION

RE: City of Lakeland- 501G Combustion Turbine Project
Air Permit Application and Prevention of Significant Deterioration (PSD) Analysis

Dear Mr. Holladay:

As we discussed on Friday, June 19, 1998, the maximum sulfur dioxide (SO₂) emissions of 38.4 tons per year (TPY) proposed for this project will be below the PSD significant emission rate of 40 TPY. The potential increases in pollutant emissions due to this project are presented in Table 3-3 of the application. The maximum SO₂ concentrations for the project, shown in Table 6-4 of the application, are predicted to be well below the PSD significant impact levels. These concentrations were the highest concentrations predicted for the combustion turbine firing either natural gas or distillate fuel oil using 5 years of meteorological data. Because the maximum SO₂ concentrations for the project were below the significant impact levels by more than a factor of 10, even if the project's emissions were to increase slightly, the maximum concentrations would be expected to be well below the significant impact levels.

Please call me or Mr. Ken Kosky at (352) 336-5600 if you have any questions or comments on this analysis.

Sincerely yours,

A handwritten signature in cursive script that reads "Robert C. McCann, Jr.".

Robert C. McCann, Jr.
Manager, Air Resources

RCM/arz

cc: K.F. Kosky, Golder
F. Shelton, City of Lakeland
File (2)

9737594A/2

FACSIMILE TRANSMISSION

GOLDER ASSOCIATES, INC.

6241 NW 23rd Street, Suite 500
Gainesville, FL 32653-1500TELEPHONE NO. (352) 336-5600
FAX NO. (352) 336-6603

Date: 22 June 1998

JOB No.: 9737594

FAX No.: (850) 922-6979

TO: Al Linder / TERRSA HERON

FR: Ken Kosky

RE: CITY OF LAKE LAND - CO calculation

Hard Copy to Follow: Yes NoTotal Number of Pages
(including this cover page): 2

MESSAGE:

AL/TERRSA:

ATTACHED IS THE CO calculation correcting the value to 15% O₂. NOTE that because the O₂-actual dry is lower than 15%, the allowed actual is higher. The adjusted are a little higher than my calc's I gave over the phone since I was rounding off on Friday for speed. CALL if you have questions.

Regards
Ken

City Of Lakeland McIntosh Unit 5

CO Correction to 15% O₂

Equation: $C_{corrected\ to\ 15\% \ O_2} = C_{actual} \cdot 5.9 / (20.9 - \% O_2\ actual\ dry)$ Equation 20-4 EPA Method 20

Natural Gas Firing:

CO	25 ppmvd	Table A-2 adjusted from 50 ppm (i.e., one-half)
	105.5 lb/hr	NOx at 50 ppmvd = 211 lb/hr (vendor); 59° F turbine inlet
O ₂	11.23 % volume	Table A-1
Moisture	12.44 % volume	Table A-1
O ₂	12.83 % vol.-dry	% vol.-dry = % vol. x 1/(1 - % moisture/100);
CO	25 ppmvd @ 15% O ₂	
	34.21 ppmvd	25 ppmvd*(20.9-% O ₂ actual dry)/5.9; Equation 20-4
	144.38 lb/hr	ppmvd/ppmvd @ 15% O x lb/hr @ 25 ppmvd

Fuel Oil Firing:

CO	90 ppmvd	Table A-10; 59° F turbine inlet
	386 lb/hr	Table A-10; 59° F turbine inlet; vendor
O ₂	11.14 % volume	Table A-9
Moisture	12.05 % volume	Table A-9
O ₂	12.67 % vol.-dry	% vol.-dry = % vol. x 1/(1 - % moisture/100);
CO	90 ppmvd @ 15% O ₂	
	125.60 ppmvd	25 ppmvd*(20.9-% O ₂ actual dry)/5.9; Equation 20-4
	538.68 lb/hr	ppmvd/ppmvd @ 15% O x lb/hr @ 25 ppmvd