



Ed Ivec

Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

P.E. Certification Statement

Permittee:
Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

Project type: Title V Air Operation Permit

I HEREBY CERTIFY that the engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including but not limited to the electrical, mechanical, structural, hydrological, and geological features).

Scott M. Sheplak

Scott M. Sheplak, P.E.

Registration Number: 0048866

09/02/98
date

Permitting Authority:

Department of Environmental Protection
Bureau of Air Regulation
111 South Magnolia Drive, Suite 4
Tallahassee, Florida 32301
Telephone: 904/921-9532
Fax: 904/922-6979



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

September 4, 1998

Mr. Ronald W. Tomlin
Assistant Managing Director
Lakeland Electric & Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5079

Re: DRAFT Title V Permit Revision No.: 1050004-005-AV
C. D. McIntosh, Jr. Power Plant

Dear Mr. Tomlin:

One copy of the DRAFT Title V Air Operation Permit revision for the C. D. McIntosh, Jr. Power Plant located at 3030 East Lake Parker Drive, Lakeland, Polk County, is enclosed. The permitting authority's "INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" is also included.

The "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" must be published as soon as possible. This issue is important in order for you to receive your revised Title IV Acid Rain permit by January 1, 1999, for the inclusion of the Phase II NOx limitations pursuant to Rule 62-214.360(6), Florida Administrative Code. Proof of publication, i.e., newspaper affidavit, must be provided to the permitting authority's office within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit.

Please submit any written comments you wish to have considered concerning the permitting authority's proposed action to Scott M. Sheplak, P.E., at the above letterhead address. If you have any other questions, please contact Edward J. Svec at 850/921-8985.

Sincerely,

A handwritten signature in black ink that reads "C. H. Fancy".

C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/s

Enclosures

cc: Ms. Carla E. Pierce, U.S. EPA, Region 4 (INTERNET E-mail Memorandum)
Ms. Gracy Danois, U.S. EPA, Region 4 (INTERNET E-mail Memorandum)

In the Matter of an
Application for Permit Revision by:

Lakeland Electric & Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5079

DRAFT Permit No.: 1050004-005-AV
C. D. McIntosh, Jr. Power Plant
Polk County

INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION

The Department of Environmental Protection (permitting authority) gives notice of its intent to issue a Title V air operation permit revision (copy of DRAFT Permit enclosed) for the Title V source detailed in the application specified above, for the reasons stated below.

The permittee, Lakeland Electric & Water Utilities, submitted the Phase I/II NOx Acid Rain Compliance Plan on December 4, 1997, for the C. D. McIntosh, Jr. Power Plant located at 3030 East Lake Parker Drive, Lakeland, Polk County. The purpose of the revision is to incorporate the Phase I/II NOx standards into the Title IV permit pursuant to Rule 62-214.360(6), Florida Administrative Code (F.A.C.).

The permitting authority has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4, 62-210, 62-213, and 62-214, F.A.C. This source is not exempt from Title V permitting procedures. The permitting authority has determined that a Title V air operation permit is required to commence or continue operations at the described facility.

The permitting authority intends to issue this Title V air operation permit based on the belief that reasonable assurances have been provided to indicate that operation of the source will not adversely impact air quality, and the source will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-256, 62-257, 62-281, 62-296, and 62-297, F.A.C.

Pursuant to Sections 403.815 and 403.087, F.S., and Rules 62-110.106 and 62-210.350(3), F.A.C., you (the applicant) are required to publish at your own expense the enclosed "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT." The notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. Where there is more than one newspaper of general circulation in the county, the newspaper used must be one with significant circulation in the area that may be affected by the permit. If you are uncertain that a newspaper meets these requirements, please contact the permitting authority at the address or telephone number listed below. The applicant shall provide proof of publication to the Department's Bureau of Air Regulation, 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400 (Telephone: 850/488-1344; Fax: 850/922-6979), within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit pursuant to Rule 62-110.106, F.A.C.

The permitting authority will issue the Title V PROPOSED Permit, and subsequent Title V FINAL Permit, in accordance with the conditions of the attached Title V DRAFT Permit unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The permitting authority will accept written comments concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT." Written comments should be provided to the permitting authority office. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this DRAFT Permit, the permitting authority shall issue a Revised DRAFT Permit and require, if applicable, another Public Notice.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 850/488-9730; Fax: 850/487-4938). Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the permitting authority for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the permitting authority's action is based must contain the following information:

(a) The name and address of each agency affected and each agency's file or identification number, if known;

(b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination;

(c) A statement of how and when each petitioner received notice of the agency action or proposed action;

(d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;

(e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief;

(f) A demand for relief.

A petition that does not dispute the material facts upon which the permitting authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation will not be available in this proceeding.

In addition to the above, a person subject to regulation has a right to apply to the Department of Environmental Protection for a variance from or waiver of the requirements of particular rules, on certain conditions, under Section 120.542, F.S. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. The petition must specify the following information:

(a) The name, address, and telephone number of the petitioner;

(b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;

(c) Each rule or portion of a rule from which a variance or waiver is requested;

(d) The citation to the statute underlying (implemented by) the rule identified in (c) above;

(e) The type of action requested;

(f) The specific facts that would justify a variance or waiver for the petitioner;

(g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and,

(h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.


The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in Section 120.542(2), F.S., and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the United States Environmental Protection Agency and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

Finally, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

Executed in Tallahassee, Florida.

**STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION**



C. H. Fancy, P.E.

Chief

Bureau of Air Regulation

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT (including the PUBLIC NOTICE and the DRAFT permit) and all copies were sent by certified mail before the close of business on 9/9/98 to the person(s) listed:

Mr. Ronald W. Tomlin, Lakeland Electric & Water Utilities

In addition, the undersigned duly designated deputy agency clerk hereby certifies that copies of this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT (including the PUBLIC NOTICE and the DRAFT permit) were sent by U.S. mail on the same date to the person(s) listed:

Mr. Kennard Kosky, P.E., Golder Associates, Inc.
Ms. Farzie Shelton, Lakeland Electric & Water Utilities
Mr. Bill Thomas, P.E., FDEP SWD

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

Barbara J. Pontwell 9/9/98
(Clerk) (Date)

PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT REVISION

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

Title V DRAFT Permit No.: 1050004-005-AV
C. D. McIntosh, Jr. Power Plant
Polk County

The Department of Environmental Protection (permitting authority) gives notice of its intent to issue a Title V air operation permit revision to Lakeland Electric & Water Utilities for C. D. McIntosh, Jr. Power Plant located at 3030 East Lake Parker Drive, Lakeland, Polk County. The purpose of the revision is to incorporate the Phase I/II NOx standards in the Title IV permit pursuant to Rule 62-214.360(6), Florida Administrative Code (F.A.C.). The applicant's name and address are: Lakeland Electric & Water Utilities, 501 East Lemon Street, Lakeland, Florida 33801-5079.

The permitting authority will issue the Title V PROPOSED Permit, and subsequent Title V FINAL Permit, in accordance with the conditions of the Title V DRAFT Permit unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The permitting authority will accept written comments concerning the proposed Title V DRAFT Permit issuance action for a period of 30 (thirty) days from the date of publication of this Notice. Written comments should be provided to the Department's Bureau of Air Regulation, 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this DRAFT Permit, the permitting authority shall issue a Revised DRAFT Permit and require, if applicable, another Public Notice.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57 of the Florida Statutes (F.S.). The petition must contain the information set forth below and must be filed (received) in Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 850/488-9730; Fax: 850/487-4938). Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of the notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the permitting authority for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the applicable time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the permitting authority's action is based must contain the following information:

(a) The name and address of each agency affected and each agency's file or identification number, if known;

(b) The name, address and telephone number of the petitioner; name address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how petitioner's substantial rights will be affected by the agency determination;

- (c) A statement of how and when the petitioner received notice of the agency action or proposed action;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so state;
- (e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle petitioner to relief; and
- (f) A demand for relief.

A petition that does not dispute the material facts upon which the permitting authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation is not available for this proceeding.

In addition to the above, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Permitting Authority:

Department of Environmental Protection
Bureau of Air Regulation
111 South Magnolia Drive, Suite 4
Tallahassee, Florida 32301
Telephone: 850/488-1344
Fax: 850/922-6979

Affected District/Local Program:

Department of Environmental Protection
Southwest District Office
4807 Laurel Fair Circle
Tampa, Florida 33619
Telephone: 813/744-6100
Fax: 813/744-6084

The complete project file includes the DRAFT Permit, the application, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact Scott M. Sheplak, P.E., at the above address, or call 850/921-9532, for additional information.

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant
Facility ID No.: 1050004
Polk County

Initial Title V Air Operation Permit
DRAFT Permit No.: 1050004-005-AV

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Title V Section

Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Telephone: 850/488-1344
Fax: 850/922-6979


Compliance Authority:

Department of Environmental Protection
Southwest District Office
3804 Coconut Palm Drive
Tampa, Florida 33619-8218
Telephone: 813/744-6100
Fax: 813/744-6084

Initial Title V Air Operation Permit
DRAFT Permit No.: 1050004-005-AV

Table of Contents

Section	Page Number
Placard Page	1
I. Facility Information	2 - 4
A. Facility Description.	
B. Summary of Emissions Unit ID Nos. and Brief Descriptions.	
C. Relevant Documents.	
II. Facility-wide Conditions	5 - 6
III. Emissions Units and Conditions	
A. Emissions Unit -001 McIntosh Unit 1	7 - 17
B. Emissions Units -002 Diesel Engine Peaking Unit 2	18 - 22
-003 Diesel Engine Peaking Unit 3	
C. Emissions Unit -004 Gas Turbine Peaking Unit 1	23 - 28
D. Emissions Unit -005 McIntosh Unit 2	29 - 42
E. Emissions Unit -006 McIntosh Unit 3	43 - 61
IV. Acid Rain Part	
A. Acid Rain, Phase II	62 - 63
B. Acid Rain, Phase I	64



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

Permittee:

Lakeland Electric & Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5079

DRAFT Permit No.: 1050004-005-AV

Facility ID No.: 1050004

SIC Nos.: 49, 4911

Project: Title V Air Operation Permit Revision

This permit revision is for the inclusion of the Phase I/II NO_x limitations pursuant to Rule 62-214.360(6), Florida Administrative Code (F.A.C.), into the Title IV Acid Rain Part for the C. D. McIntosh, Jr. Power Plant. This facility is located at 3030 East Lake Parker Drive, Lakeland, Polk County; UTM Coordinates: Zone 17, 409.0 km East and 3106.2 km North; Latitude: 28° 04' 50" North and Longitude: 81° 55' 32" West.

STATEMENT OF BASIS: This Title V air operation permit revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix U-1, List of Unregulated Emissions Units and/or Activities
Appendix I-1, List of Insignificant Emissions Units and/or Activities
APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97)
APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)
TABLE 297.310-1, CALIBRATION SCHEDULE (version dated 10/07/96)
FIGURE 1 - SUMMARY REPORT-GASEOUS AND OPACITY EXCESS EMISSION AND
MONITORING SYSTEM PERFORMANCE REPORT (40 CFR 60; July 1996)
Phase II Acid Rain Application/Compliance Plan received 12/18/95
Alternate Sampling Procedure: ASP Number 97-B-01
APPENDIX 40 CFR 60, SUBPART A (40 CFR 60; July 1996)
ORDER EXTENDING PERMIT EXPIRATION DATE dated 02/09/98
Phase I/II NO_x Acid Rain Application/Compliance Plan received December 9, 1997

Effective Date: January 1, 1999

Renewal Application Due Date: July 5, 2003

Expiration Date: December 31, 2003

Howard L. Rhodes, Director
Division of Air Resources
Management

HLR/sms/es

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

Printed on recycled paper.

Section I. Facility Information.

Subsection A. Facility Description.

This facility consists of three fossil fuel fired steam generators, two diesel powered generators, and one gas turbine. Fossil fuel fired steam generators 1 and 2 are fired with No. 6 fuel oil and natural gas with distillate oil used as an ignitor. Fossil fuel fired steam generator 3 is primarily fired with coal, refuse derived fuel and petroleum coke.

Also included in this permit are miscellaneous unregulated/insignificant emissions units and/or activities.

Based on the initial Title V permit application received June 14, 1996, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-001	McIntosh Unit 1 - Fossil Fuel Fired Steam Generator
-002	Diesel Engine Peaking Unit 2
-003	Diesel Engine Peaking Unit 3
-004	Gas Turbine Peaking Unit 1
-005	McIntosh Unit 2 - Fossil Fuel Fired Steam Generator
-006	McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

Unregulated Emissions Units and/or Activities

E.U.

ID No. **Brief Description of Emissions Units and/or Activity**

-007	Tanks with greater than 10,000 gallon capacity installed prior to July 23, 1984
-008	Diesel drive coal tunnel sump engine
-009	Fire water UPS diesel No. 31
-010	Fire water UPS diesel No. 32
-011	CT startup diesel
-012	General purpose diesel engines
-013	Emergency generators
-014	General purpose painting
-015	Parts Cleaning
-016	Sand Blasting (Maintenance only)
-017	Wastewater Treatment Tank
-018	Three Cooling Towers (Unit 2 and 3)
-019	Northside Waste Water Treatment Facility - Wastewater treatment processes and tanks
-020	Northside Waste Water Treatment Facility - Two emergency diesel generators
-021	Northside Waste Water Treatment Facility - Chemical and petroleum storage
-022	Northside Waste Water Treatment Facility - Miscellaneous activities
-023	Coal processing and conveying system
-024	Coal storage system
-025	Coal transfer and loading system
-026	Limestone handling and storage system
-027	Flyash handling and storage system

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit, however, are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History / ID Number Changes

These documents are on file with permitting authority:

Initial Title V Permit Application received June, 14, 1996

Additional Information Request dated January 13, 1997

Additional Information Response received February 10, 1997

Additional Information received May 9, 1997

Letter received July 2, 1997 from Ms. Farzie Shelton

Additional Information received July 8, 1997

Letter received August 7, 1997 from Ms. Farzie Shelton

Letter received September 4, 1997 from Ms. Farzie Shelton

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

1. APPENDIX TV-1, TITLE V CONDITIONS is a part of this permit.
{Permitting note: APPENDIX TV-1, TITLE V CONDITIONS, is distributed to the permittee only.
Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}
2. **Not Federally Enforceable** General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.
[Rule 62-296.320(2), F.A.C.]
3. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.
[Rule 62-296.320(4)(b)1. & 4., F.A.C.]
4. Prevention of Accidental Releases (Section 112(r) of CAA). If required by 40 CFR 68, the permittee shall submit to the implementing agency:
 - a. a risk management plan (RMP) when, and if, such requirement becomes applicable; and
 - b. certification forms and/or RMPs according to the promulgated rule schedule.[40 CFR 68]
5. Unregulated Emissions Units and/or Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.
[Rule 62-213.440(1), F.A.C.]
6. Insignificant Emissions Units and/or Activities. Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit.
[Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]
7. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. Containers shall be kept closed.
[Rule 62-296.320(1)(a), F.A.C.; Proposed by applicant in the initial Title V permit application received June 14, 1996; Revised by a letter received August 7, 1997]

8. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include: maintenance of paved areas; regular mowing of grass and care of vegetation; and limiting access to plant property by unnecessary vehicles.

[Rule 62-296.320(4)(c)2., F.A.C.; Proposed by applicant in the initial Title V permit application received June 14, 1996, as amended in a request received July 8, 1997]

9. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.

[Rule 62-213.440, F.A.C.]

10. The permittee shall submit all compliance related notifications and reports required of this permit to the Department's Southwest District office:

Department of Environmental Protection
Southwest District Office
3804 Coconut Palm Drive
Tampa, Florida 33619-8218
Telephone: 813/744-6100
Fax: 813/744-6084

11. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency
Region 4
Air, Pesticides & Toxics Management Division
Operating Permits Section
61 Forsyth Street
Atlanta, Georgia 30303
Telephone: 404/562-9099
Fax: 404/562-9095

III. Emissions Section Unit.

Subsection A. This section addresses the following emissions unit(s).

E.U.

ID No. Brief Description

-001 McIntosh Unit 1 - Fossil Fuel Fired Steam Generator

McIntosh Unit 1 is a forced draft boiler rated at a nominal load of 90 megawatts. The unit is fired with natural gas at a maximum heat input rate of 985 million Btu per hour (approximately 970 million cubic feet per hour), or No. 6 fuel oil, having a maximum sulfur content of 2.5 percent by weight, at a maximum heat input rate of 950 million Btu per hour (approximately 6,300 gallons per hour). This unit is also permitted to burn "on-specification" used oil generated by the City of Lakeland, at a maximum heat input rate of 950 million Btu per hour. McIntosh Unit 1 began commercial service in February, 1971.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; and Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input.}

The following specific conditions apply to the emissions unit listed above:

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum operation heat input rate is as follows:

<u>Unit No.</u>	<u>MMBtu/hr Heat Input</u>	<u>Fuel Type</u>
1	985	Natural Gas
	950	No. 6 Fuel Oil
	950	Used Oil

When a blend of fuel oil, "on-specification" used oil or natural gas is fired, the heat input is prorated based on the percent heat input of each fuel. The Acid Rain CEM will not be a method of compliance for the determination of the heat input rate.

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.]

A.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **A.23.**

[Rule 62-297.310(2), F.A.C.]

A.3. Methods of Operation. Fuels. The only fuels allowed to be burned are natural gas, propane, No. 6 Fuel Oil, On-Specification Used Oil, No. 2 Fuel Oil and combinations of natural gas, propane, No. 6 Fuel Oil, No. 2 Fuel Oil and/or On-Specification Used Oil. On-Specification used oil containing any quantifiable levels of PCBs can only be fired when the emissions unit is at normal operating temperatures.

[Rule 62-213.410, F.A.C.; and, 40 CFR 271.20(e)(3)]

A.4. Hours of Operation. This emissions unit may operate continuously, i.e., 8,760 hours/year.
[Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.5. Visible Emissions. Visible emissions shall not exceed 20 percent opacity, except for one two-minute period per hour during which opacity shall not exceed 40 percent. Emissions units governed by this visible emissions limit shall compliance test for particulate matter emissions annually and as otherwise required by Chapter 62-297, F.A.C.
[Rule 62-296.405(1)(a), F.A.C.]

A.6. Visible Emissions - Soot Blowing and Load Change. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.

[Rule 62-210.700(3), F.A.C.]

A.7. Particulate Matter. Particulate matter emissions shall not exceed 0.1 pound per million Btu heat input, as measured by applicable compliance methods.

[Rule 62-296.405(1)(b), F.A.C.]

A.8. Particulate Matter - Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

[Rule 62-210.700(3), F.A.C.]

A.9. Sulfur Dioxide. When burning liquid fuel, sulfur dioxide emissions shall not exceed 2.75 pounds per million Btu heat input, as measured by applicable compliance methods.

[Rule 62-296.405(1)(c)1.j., F.A.C.]

A.10. Sulfur Dioxide - Sulfur Content. The No. 6 fuel oil sulfur content shall not exceed 2.5 percent, by weight. See specific condition **A.21**.

[Rule 62-296.405(1)(e)3., F.A.C.; and, AO 53-243945]

A.11. “On-Specification” Used Oil. Only “on-specification” used oil generated by the City of Lakeland shall be fired in this unit. The quantity fired in this unit shall not exceed 1,000 barrels (42,000 gallons) per calendar year. “On-specification” used oil is defined as used oil that meets the 40 CFR 279 (Standards for the Management of Used Oil) specifications listed below. Used oil that does not meet all of the following specifications is considered “off-specification” oil and shall not be fired.

<u>CONSTITUENT / PROPERTY</u> *	<u>ALLOWABLE LEVEL</u>
Arsenic	5 ppm maximum
Cadmium	2 ppm maximum
Chromium	10 ppm maximum
Lead	100 ppm maximum
Total Halogens	1000 ppm maximum
Flash Point	100 °F minimum
PCBs	less than 50 ppm

* As determined by ASTM Standard D140-70, or equivalent
[40 CFR 279.11; and, AO 53-243945]

Excess Emissions

A.12. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

A.13. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

[Rule 62-210.700(2), F.A.C.]

A.14. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

A.15. Sulfur Dioxide. The permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit that will be verified with a fuel analysis provided by the vendor or the permittee upon each fuel delivery. This protocol is allowed because the emissions unit does not have an operating flue gas desulfurization device. See specific conditions **A.10.**, **A.20.** and **A.21.**

[Rule 62-296.405(1)(f)1.b., F.A.C.]

A.16. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.17. Visible emissions. The test method for visible emissions shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. A transmissometer may be used and calibrated according to Rule 62-297.520, F.A.C. See specific condition **A.18.**

[Rule 62-296.405(1)(e)1., F.A.C.]

A.18. DEP Method 9. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:

1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.
2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
 - a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
 - b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value.

[Rule 62-297.401, F.A.C.]

A.19. Particulate Matter. The test methods for particulate emissions shall be EPA Methods 17, 5, 5B, or 5F, incorporated by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. EPA Method 5 may be used with filter temperature no more than 320 degrees Fahrenheit. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. The owner or operator may use EPA Method 5 to demonstrate compliance. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen based F-factor, computed according to EPA Method 19, is used in lieu of heat input. Acetone wash shall be used with EPA Method 5 or 17.

[Rules 62-296.405(1)(e)2. and 62-297.401, F.A.C.]

A.20. Sulfur Dioxide. The test methods for sulfur dioxide emissions shall be EPA Methods 6, 6A, 6B, or 6C, incorporated by reference in Chapter 62-297, F.A.C. Fuel sampling and analysis may be used as an alternate sampling procedure if such a procedure is incorporated into the operation permit for the emissions unit. If the emissions unit obtains an alternate procedure under the provisions of Rule 62-297.620, F.A.C., the procedure shall become a condition of the emissions unit's permit. The Department will retain the authority to require EPA Method 6 or 6C if it has reason to believe that exceedences of the sulfur dioxide emissions limiting standard are occurring. Results of an approved fuel sampling and analysis program shall have the same effect as EPA Method 6 test results for purposes of demonstrating compliance or noncompliance with sulfur dioxide standards. **The permittee may use the EPA test methods, referenced above, to demonstrate compliance; however, as an alternate sampling procedure authorized by permit, the permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit that will be verified with a fuel analysis provided by the vendor or the permittee upon each fuel delivery.** See specific conditions **A.10. and A.21.**

[Rules 62-213.440, 62-296.405(1)(e)3. and 62-297.401, F.A.C.; and, AO 53-243945]

A.21. The fuel sulfur content, percent by weight, for liquid fuels shall be evaluated using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91, or the respective successor ASTM method(s).

[Rules 62-213.440, 62-296.405(1)(e)3., 62-296.405(1)(f)1.b. and 62-297.440, F.A.C.]

A.22. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

A.23. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.
[Rules 62-297.310(2) & (2)(b), F.A.C.]

A.24. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule.
[Rule 62-297.310(3), F.A.C.]

A.25. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. **Opacity Compliance Tests.** When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached as part of this permit.

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.
[Rule 62-297.310(4), F.A.C.]

A.26. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

A.27. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) **General Compliance Testing.**

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid for more than 400 hours other than during startup.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and, SIP approved]

A.28. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

A.29. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

A.30. Compliance with the “on-specification” used oil requirements will be determined as follows:

- (a) Analysis of a sample collected from each batch delivered for firing; or,
- (b) The new batch delivery is from a collection site that has an acceptable analysis already on file with the facility and the analytical results are assumed by the facility for the batch.

For quantification purposes, the highest concentration of each constituent as determined by any analysis is assumed to be the concentration of the constituent of the blended used oil.

See specific condition **A.11.**

[AO 53-243945]

Record keeping and Reporting Requirements

A.31. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department or the appropriate Local Program.
[Rule 62-210.700(6), F.A.C.]

A.32. Submit to the Department a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.
[Rules 62-213.440 and 62-296.405(1)(g), F.A.C.]

A.33. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
 - 1. The type, location, and designation of the emissions unit tested.
 - 2. The facility at which the emissions unit is located.
 - 3. The owner or operator of the emissions unit.
 - 4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
 - 5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
 - 6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
 - 7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.

8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

A.34. Records shall be kept of each delivery of “on-specification” used oil with a statement of the origin of the used oil and the quantity delivered/stored for firing. In addition, monthly records shall be kept of the quantity of “on-specification” used oil fired in this unit. The above records shall be maintained in a form suitable for inspection, retained for a minimum of five years, and be made available upon request. [Rule 62-213.440(1)(b)2.b., F.A.C.; and, AO 53-243945]

A.35. The permittee shall include in the “Annual Operating Report for Air Pollutant Emitting Facility” a summary of the “on-specification” used oil analyses for the calendar year and a statement of the total quantity of “on-specification” used oil fired in Unit 1 during the calendar year. [AO 53-243945]

Section III. Emissions Unit(s) and Conditions.

Subsection B. This section addresses the following emissions unit(s).

E.U.

ID No. Brief Description

-002	Diesel Engine Peaking Unit 2
-003	Diesel Engine Peaking Unit 3

Diesel Engine Peaking Units 2 and 3 are diesel fired internal combustion engines which each drives a generator capable of producing electric power at a maximum rating of 2.5 megawatts. These units are each fired on No. 2 fuel oil, with a maximum sulfur content of 0.5 percent by weight, at a maximum firing rate of 201.6 gallons per hour. This corresponds to a maximum heat input of 28 million Btu per hour. Diesel Engine Peaking Units 2 and 3 began commercial service in 1970.

{Permitting note(s): The emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required. Each diesel engine peaking unit has its own stack.}

The following specific conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

B.1. Permitted Capacity.

- a. The maximum heat input rate of each diesel engine peaking unit is 28 million Btu per hour [Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]
- b. **Not Federally Enforceable** The maximum firing rate of each diesel engine peaking unit is 201.6 gallons per hour firing No. 2 fuel oil. [AO 53-244726]

B.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **B.13.** [Rule 62-297.310(2), F.A.C.]

B.3. Methods of Operation - Fuels. Only distillate (No. 2) fuel oil shall be fired in the diesel engine peaking units. [Rule 62-213.410, F.A.C.]

B.4. Hours of Operation. These emissions units may operate continuously, i.e., 8,760 hours/year. [Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; and, AO 53-244726]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

B.5. Visible Emissions. Visible emissions from each diesel engine peaking unit shall not be equal to or greater than 20 percent opacity.
[Rule 62-296.320(4)(b)1., F.A.C.; and, AO 53-244726]

B.6. Not federally enforceable. Sulfur Dioxide - Sulfur Content. The sulfur content of the No. 2 fuel oil shall not exceed 0.5 percent, by weight.
[AO 53-244726]

Excess Emissions

B. 7. Excess emissions from these emissions units resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

B. 8. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

B.9. The permittee shall demonstrate compliance with the liquid fuel sulfur limit by means of a fuel analysis provided by the vendor or the permittee upon each fuel delivery. See specific condition **B.12.**
[Rule 62-213.440, F.A.C.]

B.10. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

B.11. The test method for visible emissions shall be EPA Method 9, adopted and incorporated by reference in Rule 62-204.800, F.A.C., and referenced in Chapter 62-297, F.A.C.

[Rules 62-204.800, 62-296.320(4)(b)4.a. and 62-297.401, F.A.C.]

B.12. The fuel sulfur content, percent by weight, for liquid fuels shall be evaluated using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91, or the respective successor ASTM method(s).

[Rules 62-213.440 and 62-297.440, F.A.C.; and, AO 53-244726]

B.13. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

B.14. Applicable Test Procedures.

(a) Required Sampling Time.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

- c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

[Rule 62-297.310(4)(a)2.c., F.A.C.]

B.15. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

- a. Did not operate; or
- b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; SIP approved; and, AO 53-244726]

B.16. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

Recordkeeping and Reporting Requirements

B.17. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C.

A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

B.18. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

[Rule 62-297.310(8), F.A.C.]

Section III. Emissions Unit(s) and Conditions.

Subsection C. This section addresses the following emissions unit(s).

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-004	Gas Turbine Peaking Unit 1

Gas Turbine Peaking Unit 1 consists of a gas turbine which drives a generator producing electrical power at a nominal nameplate rating of 20 megawatts. The gas turbine is fired with natural gas, or No. 2 fuel oil with a maximum sulfur content of 0.5 percent by weight. The maximum fuel firing rate is 320 million cubic feet per hour of natural gas (approximately 330 million Btu per hour) or 2,310 gallons per hour of No. 2 fuel oil (approximately 320 million Btu per hour). Gas Turbine Peaking Unit 1 began commercial service in 1973.

{Permitting notes: This emissions unit is regulated under Rule 62-210.300, F.A.C., Permits Required. This unit is not subject to 40 CFR 60, Subpart GG, Standards of Performance for New Stationary Gas Turbines.}

The following specific conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

C.1. Permitted Capacity.

a. The maximum heat input rate of the turbine is 330 million Btu per hour (lower heating value) at 30 degrees F while firing natural gas and 320 million Btu per hour (lower heating value) at 30 degrees F while firing No. 2 fuel oil.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

b. **Not Federally Enforceable** The maximum firing rate of the turbine is 320 million cubic feet per hour when firing natural gas or 2,310 gallons per hour when firing No. 2 fuel oil.

[AO 53-244727]

C.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition C.13.

[Rule 62-297.310(2), F.A.C.]

C.3. Methods of Operation - Fuels. Only natural gas or distillate (No. 2) fuel oil shall be fired in the combustion turbine.

[Rule 62-213.410, F.A.C.]

C.4. Hours of Operation. These emissions unit(s) may operate continuously, i.e., 8,760 hours/year.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; and, AO 53-244727]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

C.5. Visible Emissions. Visible emissions from each turbine shall not be equal to or greater than 20 percent opacity.
[Rule 62-296.320(4)(b)1., F.A.C.; and, AO 53-244727]

C.6. Not federally enforceable. Sulfur Dioxide - Sulfur Content. The sulfur content of the No. 2 fuel oil shall not exceed 0.5 percent, by weight.
[AO 53-244727]

Excess Emissions

C.7. Excess emissions from these emissions units resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

C.8. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

C.9. The permittee shall demonstrate compliance with the liquid fuel sulfur limit by means of a fuel analysis provided by the vendor or the permittee upon each fuel delivery. See specific condition **C.12.**
[Rule 62-213.440, F.A.C.]

C.10. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

C.11. The test method for visible emissions shall be EPA Method 9, adopted and incorporated by reference in Rule 62-204.800, F.A.C., and referenced in Chapter 62-297, F.A.C.

[Rules 62-204.800, 62-296.320(4)(b)4.a. and 62-297.401, F.A.C.]

C.12. The fuel sulfur content, percent by weight, for liquid fuels shall be evaluated using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91, or the respective successor ASTM method(s).

[Rules 62-213.440 and 62-297.440, F.A.C.; and, AO 53-244727]

C.13. Not federally enforceable. Operating Rate During Testing.

Testing of emissions shall be conducted with the emissions unit operating at permitted capacity, which is defined as 95-100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned) air temperature during the test. If it is impracticable to test at capacity, then sources may be tested at less than capacity. In such cases, the entire heat input vs. inlet temperature curve will be adjusted by the increment equal to the difference between the design heat input value and 105 percent of the value reached during the test. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report.

[Requested in initial Title V permit application response for additional information dated February 10, 1997];

C.14. Applicable Test Procedures.

(a) Required Sampling Time.

2. **Opacity Compliance Tests.** When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

- c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

[Rule 62-297.310(4)(a)2.c., F.A.C.]

C.15. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

- a. Did not operate; or
- b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;

8. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; SIP approved; and, AO 53-244727]

C.16. Visible Emissions Testing - Annual. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuels; or
- b. gaseous fuels in combination with any amount of liquid fuels for less than 400 hours per year; or
- c. only liquid fuels for less than 400 hours per year.

[Rules 62-297.310(7)(a)4. & 8., F.A.C.]

Recordkeeping and Reporting Requirements

C.17. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

C.18. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

[Rule 62-297.310(8), F.A.C.]

Section III. Emissions Unit(s) and Conditions.

Subsection D. This section addresses the following emissions unit(s).

E.U.

ID No. Brief Description

-005 McIntosh Unit 2 - Fossil Fuel Fired Steam Generator

McIntosh Unit 2 is a nominal 114.7 megawatt (electric) fossil fuel fired steam generator. The unit is fired on low sulfur No. 6 or No. 2 fuel oil with a maximum heat input of 1,115 million Btu per hour, or natural gas with a maximum heat input of 1,184.5 million Btu per hour. McIntosh Unit 2 began commercial service in June, 1976.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; and NSPS - 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.}

The following conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

D.1. Permitted Capacity. The maximum operation heat input rate is as follows:

<u>Unit No.</u>	<u>MMBtu/hr Heat Input</u>	<u>Fuel Type</u>
2	1,184.5	Natural Gas
	1,115	No. 6 Fuel Oil
	1,115	No. 2 Fuel Oil

When a blend of fuel oil and natural gas is fired, the heat input is prorated based on the percent heat input of each fuel. The Acid Rain CEM will not be a method of compliance for the determination of the heat input rate.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

D.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition D.23.

[Rule 62-297.310(2), F.A.C.]

D.3. Methods of Operation. Fuels. The only fuels allowed to be burned are natural gas, propane, No. 6 Fuel Oil, No. 2 Fuel Oil and combinations of natural gas, propane, No. 6 Fuel Oil and/or No. 2 Fuel Oil.

[Rule 62-213.410, F.A.C.]

D.4. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year.
[Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

Particulate Matter

D.5. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which:

(1) Contain particulate matter in excess of 43 nanograms per joule heat input (0.10 lb per million Btu) derived from fossil fuel or fossil fuel and wood residue.

(2) Exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

[40 CFR 60.42(a)(1) & (2)]

Sulfur Dioxide

D.6. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain sulfur dioxide in excess of:

(1) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel.

[40 CFR 60.43(a)(1)]

D.7. Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

[40 CFR 60.43(c)]

Nitrogen Oxides

D.8. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain nitrogen oxides, expressed as NO₂ in excess of:

- (1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel.
 - (2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel.
- [40 CFR 60.44(a)(1) & (2)]

D.9. When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NO_x} = \frac{w(260)+x(86)+y(130)+z(300)}{w+x+y+z}$$

where:

PS_{NO_x} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;

w = is the percentage of total heat input derived from lignite;

x = is the percentage of total heat input derived from gaseous fossil fuel;

y = is the percentage of total heat input derived from liquid fossil fuel; and,

z = is the percentage of total heat input derived from solid fossil fuel (except lignite).

[40 CFR 60.44(b)]

Excess Emissions

D.10. Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

- (1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

[40 CFR 60.45(b)(2) and 60.45(g)(1)]

D.11. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

D.12. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

D.13. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

D.14. In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in Appendix A of 40 CFR 60 or other methods and procedures as specified in 40 CFR 60.46, except as provided in 40 CFR 60.8(b). Acceptable alternative methods and procedures are given in 40 CFR 60.46(d).

[40 CFR 60.46(a)]

D.15. The owner or operator shall determine compliance with the particulate matter, and NO_x standards in 40 CFR 60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of particulate matter, or NO_x shall be computed for each run using the following equation:

$$E = C F_d (20.9)/(20.9 - \% O_2)$$

E = emission rate of pollutant, ng/J (1b/million Btu).

C = concentration of pollutant, ng/dscm (1b/dscf).

% O₂ = oxygen concentration, percent dry basis.

F_d = factor as determined from Method 19.

(2) Method 5 shall be used to determine the particular matter concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train may be set to provide a gas temperature no greater than 160 ± 14 °C (320 ± 25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O₂ concentration for the run shall be the arithmetic mean of all the individual O₂ sample concentrations at each traverse point.

(iii) If the particulate run has more than 12 traverse points, the O₂ traverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O₂ traverse points.

(3) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.

(5) Method 7 shall be used to determine the NO_x concentration.

(i) The sampling site and location shall be the same as for the SO₂ sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.

(ii) For each NO_x sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The sample shall be taken simultaneously with, and at the same point as, the NO_x sample.

(iii) The NO_x emission rate shall be computed for each pair of NO_x and O₂ samples. The NO_x emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.

[40 CFR 60.46(b)(1), (2), (3), & (5)]

D.16. Compliance with the sulfur dioxide emission standard of specific condition **D.7.** shall be demonstrated using the fuel sampling and analysis procedures of specific condition **D.17.**

[Rule 62-213.440, F.A.C. and Applicant Request dated June 14, 1996]

- D.17.** The following fuel sampling and analysis program shall be used to demonstrate compliance with the sulfur dioxide standard and as the substitute for the sulfur dioxide continuous monitoring system:
- a. Determine and record the as-fired fuel sulfur content, percent by weight, (1) for liquid fuels using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91, or the respective successor ASTM method(s), to analyze a representative sample of the blended fuel following each fuel delivery, (2) for gaseous fuels using ASTM D1072-90, or the respective successor ASTM method.
 - b. Record daily the amount of each fuel fired, the density of each fuel, and the percent sulfur content by weight of each fuel.
 - c. Utilize the information in a. and b., above, to calculate the SO₂ emission rate to ensure compliance at all times.

[Rules 62-213.440, F.A.C.]

D.18. When combinations of fossil fuels are fired, the owner or operator (in order to compute the prorated standard as shown in 40 CFR 60.44(b)) shall determine the percentage (w, x, y, or z) of the total heat input derived from each type of fuel as follows:

- (1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.
- (2) ASTM Methods D 240-76 (liquid fuels), or D 1826-77 (gaseous fuels) (incorporated by reference-see 40 CFR 60.17) shall be used to determine the gross calorific values of the fuels.
- (3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.

[40 CFR 60.46(c)(1), (2), & (3)]

D.19. The owner or operator may use the following as alternatives to the reference methods and procedures in 40 CFR 60.46 or in other sections as specified:

- (1) The emission rate (E) of particulate matter, SO₂ and NO_x may be determined by using the F_c factor, provided that the following procedure is used:

- (i) The emission rate (E) shall be computed using the following equation:

$$E = C F_c (100 / \% \text{ CO}_2)$$

where:

E = emission rate of pollutant, ng/J (lb/million Btu).

C = concentration of pollutant, ng/dscm (lb/dscf).

% CO₂ = carbon dioxide concentration, percent dry basis.

F_c = factor as determined in appropriate sections of Method 19.

(ii) If and only if the average F_c factor in Method 19 is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B shall be used to determine the O_2 and CO_2 concentration according to the procedures in 40 CFR 60.46(b)(2)(ii), (4)(ii), or (5)(ii). Then if F_o (average of three runs), as calculated from the equation in Method 3B, is more than ± 3 percent than the average F_o value, as determined from the average values of F_d and F_c in Method 19, i.e., $F_{oa} = 0.209 (F_{da} / F_{ca})$, then the following procedure shall be followed:

(A) When F_o is less than $0.97 F_{oa}$, then E shall be increased by that proportion under $0.97 F_{oa}$, e.g., if F_o is $0.95 F_{oa}$, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When F_o is less than $0.97 F_{oa}$ and when the average difference (\bar{d}) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under $0.97 F_{oa}$, e.g., if F_o is $0.95 F_{oa}$, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When F_o is greater than $1.03 F_{oa}$ and when \bar{d} is positive, then E shall be decreased by that proportion over $1.03 F_{oa}$, e.g., if F_o is $1.05 F_{oa}$, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B, Method 17 may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of $160^\circ C$ ($320^\circ F$). Method 17 shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

(3) Particulate matter and SO_2 may be determined simultaneously with the Method 5 train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 is used in place of the condenser (section 2.1.7) of Method 5.

(ii) All applicable procedures in Method 8 for the determination of SO_2 (including moisture) are used.

(5) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the O_2 concentration ($\%O_2$) for the emission rate correction factor.

(6) For Method 3, Method 3A or 3B may be used.

(7) For Method 3B, Method 3A may be used.

[40 CFR 60.46(d)(1), (2), (3), (5), (6), & (7)]

D.20. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

D.21. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

D.22. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

D.23. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.

b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached as part of this permit.

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

D.24. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

D.25. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and, SIP approved]

D.26. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

D.27. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

Continuous Monitoring Requirements

D.28. The owner or operator shall install, calibrate, maintain, and operate continuous monitoring systems for measuring the opacity of emissions.

[40 CFR 60.45(a)]

D.29. Sulfur Dioxide. For a fossil fuel fired steam generator that does not use a flue gas desulfurization device, a continuous monitoring system for measuring sulfur dioxide emissions is not required if the owner or operator monitors sulfur dioxide emissions by fuel sampling and analysis under 40 CFR 60.45(d). **The applicant has elected to utilize fuel sampling and analysis in lieu of a continuous monitoring system for sulfur dioxide.** See specific condition **D.19.**

[40 CFR 60.45(b)(2)]

D.30. For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent.

[40 CFR 60.45(c)(3)]

Recordkeeping and Reporting Requirements

D.31. Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c).

[40 CFR 60.45(g)]

D.32. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

Rule 62-210.700(6), F.A.C.]

D.33. Submit to the Department a written report of emissions in excess of emission limiting standards for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.

[Rule 62-213.440, F.A.C.]

D.34. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.

6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

Miscellaneous Requirements.

- D.35.** The permittee shall comply with the requirements contained in Appendix 40 CFR 60, Subpart A, attached to this permit.
[Rule 62-204.800(7)(d), F.A.C.]

Section III. Emissions Unit(s) and Conditions.

Subsection E. This section addresses the following emissions unit(s).

E.U.

<u>ID No.</u>	<u>Brief Description</u>
----------------------	---------------------------------

-006	McIntosh Unit 3 - Fossil Fuel Fired Steam Generator
------	---

McIntosh Unit 3 is a nominal 364 megawatt (electric) dry bottom wall-fired fossil fuel fired steam generator. The unit is fired on coal, residual oil, natural gas and co-fires refuse derived fuel (RDF) and petroleum coke. The maximum heat input rate is 3,640 million Btu per hour. Unit 3 is equipped with an electrostatic precipitator (ESP), a flue gas desulfurization system (FGD), and low-NO_x burners to control emissions. McIntosh Unit 3 began commercial service in September, 1982.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; and NSPS - 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.; Rule 212.400(6), F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination }

The following conditions apply to the emissions unit(s) listed above:

{Permitting note: In addition to the requirements listed below, these emissions units are also subject to the standards and requirements contained in the Acid Rain Part of this permit (see Section IV).}

Essential Potential to Emit (PTE) Parameters

E.1. Capacity. The maximum heat input rate is 3,640 MMBtu per hour. The Acid Rain CEM will not be a method of compliance for the determination of the heat input rate.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

E.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **E.21.**

[Rule 62-297.310(2), F.A.C.]

E.3. Methods of Operation - Fuels. The only fuels allowed to be burned are:

- Coal only
- Low sulfur fuel oil only (≤ 0.5 percent sulfur by weight)
- Coal and up to 10 percent refuse (based on heat input)
- Low sulfur fuel oil and up to 10 percent refuse (based on heat input)
- Coal and up to 20 percent petroleum coke (based on weight)
- Coal and up to 20 percent petroleum coke (based on weight) and 10 percent refuse (based on heat input)
- High sulfur fuel oil (> 0.5 percent sulfur by weight)
- Natural gas or propane only, or in combination with any of the other fuels or fuel combinations listed above

[Rules 62-4.160(2), 62-210.200, and 62-213.440(1), F.A.C.; and, PSD-FL-008(B)]

E.4. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year.
[Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

Particulate Matter

E.5. Particulate matter emitted to the atmosphere from the boiler shall not exceed:

(1) <u>Mode of Firing</u>	<u>Pound / MMBtu Heat Input</u>
Coal	0.044
Coal/Petroleum Coke	0.044
Coal/Refuse	0.050
Coal/Petroleum Coke/Refuse	0.050
Oil	0.070
Oil/Refuse	0.075

(2) Exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

[40 CFR 60.42(a)(2); and, PSD-FL-008(B)]

Sulfur Dioxide

E.6. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain sulfur dioxide in excess of:

(1) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel or liquid fossil fuel and wood residue.

(2) 520 nanograms per joule heat input (1.2 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue, except as provided in 40 CFR 60.43(e).

[40 CFR 60.43(a)(1) and (2)]

E.7. When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the following formula:

$$PS_{SO_2} = [y(340) + z(520)] / (y+z)$$

where:

PS_{SO_2} is the prorated standard for sulfur dioxide when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired,

y is the percentage of total heat input derived from liquid fossil fuel, and

z is the percentage of total heat input derived from solid fossil fuel.

[40 CFR 60.43(b)]

E.8. Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

[40 CFR 60.43(c)]

E.9. A flue gas desulfurization system will be installed to treat exhaust gases and will operate such that whenever coal or blends of coal and petroleum coke or refuse are burned, sulfur dioxide gases discharged to the atmosphere from the boiler shall not exceed 10 percent of the potential combustion concentration (90 percent reduction), or 35 percent of the potential combustion concentration (65 percent reduction), when emissions are less than 0.75 pound per million Btu heat input. Compliance with the percent reduction requirement shall be determined on a 30-day rolling average. This compliance information shall be retained for a period of five years and made available by the City upon request of the Department. Whenever blends of petroleum coke with other fuels are co-fired, sulfur dioxide emissions shall not exceed 0.718 pound per million Btu heat input based on a 30-day rolling average and shall comply with the reduction requirements given above.

[PSD-FL-008(B) and Rule 62-213.440, F.A.C.]

E.10. The burning of high sulfur oil (greater than 0.5 percent sulfur by weight) or a combination of high sulfur oil and municipal refuse as an emergency fuel without the use of the SO₂ scrubber will be allowed only when the flue gas desulfurization system malfunctions to the extent that the burning of coal would cause emission limitations to be exceeded. Sulfur dioxide emitted to the atmosphere from the boiler shall not exceed 0.8 pound per million Btu heat input under this condition.

[PSD-FL-008(B)]

E.11. During malfunctions of equipment which cause an interruption of the coal feed to the boiler, the burning of high sulfur oil (greater than 0.5 percent sulfur by weight) or a combination of high sulfur oil and municipal refuse will be allowed only if all flue gases are fully scrubbed by the SO₂ scrubber. Sulfur dioxide emitted to the atmosphere from the boiler shall not exceed 0.8 pound per million Btu heat input under this condition.

[PSD-FL-008(B)]

E.12. Continuous burning of natural gas, low sulfur fuel oil (less than or equal to 0.5 percent sulfur by weight), or combinations of these two fuels with or without the use of the SO₂ scrubber will be allowed.

[PSD-FL-008(B)]

Nitrogen Oxides

E.13. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain nitrogen oxides, expressed as NO₂ in excess of:

(1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel.

(2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.

(3) 300 nanograms per joule heat input (0.70 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).

[40 CFR 60.44(a)(1), (2), & (3)]

E.14. Except as provided under paragraphs 40 CFR 60.44(c) and (d), when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NOx} = \frac{w(260)+x(86)+y(130)+z(300)}{w+x+y+z}$$

where:

PS_{NOx} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;

w = is the percentage of total heat input derived from lignite;

x = is the percentage of total heat input derived from gaseous fossil fuel;

y = is the percentage of total heat input derived from liquid fossil fuel; and,

z = is the percentage of total heat input derived from solid fossil fuel (except lignite).

[40 CFR 60.44(b)]

Excess Emissions

E.15. Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(2) Sulfur dioxide. Excess emissions for affected facilities are defined as:

(i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under 40 CFR 60.43.

[40 CFR 60.45(g)(1), & (2)]

E.16. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

E.17. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

E.18. In addition to the requirements of 40 CFR 60.7, each excess emissions report shall include the periods of oil consumption due to flue gas desulfurization system malfunction.
[PSD-FL-008]

Monitoring of Operations

E.19. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.
[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

E.20. In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in Appendix A of 40 CFR 60 or other methods and procedures as specified in 40 CFR 60.46, except as provided in 40 CFR 60.8(b). Acceptable alternative methods and procedures are given in 40 CFR 60.46(d).
[40 CFR 60.46(a)]

E.21. The owner or operator shall determine compliance with the particulate matter, SO₂, and NO_x standards in 40 CFR 60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of particulate matter, SO₂, or NO_x shall be computed for each run using the following equation:

$$E = C F_d (20.9)/(20.9 - \% O_2)$$

E = emission rate of pollutant, ng/J (1b/million Btu).

C = concentration of pollutant, ng/dscm (1b/dscf).

% O₂ = oxygen concentration, percent dry basis.

F_d = factor as determined from Method 19.

(2) Method 5 shall be used to determine the particulate matter concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems and Method 5B shall be used to determine the particulate matter concentration (C) after FGD systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train may be set to provide a gas temperature no greater than 160 ± 14 °C (320 ± 25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O₂ concentration for the run shall be the arithmetic mean of all the individual O₂ sample concentrations at each traverse point.

(iii) If the particulate run has more than 12 traverse points, the O₂ traverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O₂ traverse points.

(3) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.

(4) Method 6 shall be used to determine the SO₂ concentration.

(i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.

(ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be taken simultaneously with, and at the same point as, the SO₂ sample. The SO₂ emission rate shall be computed for each pair of SO₂ and O₂ samples. The SO₂ emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.

(5) Method 7 shall be used to determine the NO_x concentration.

(i) The sampling site and location shall be the same as for the SO₂ sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.

(ii) For each NO_x sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The sample shall be taken simultaneously with, and at the same point as, the NO_x sample.

(iii) The NO_x emission rate shall be computed for each pair of NO_x and O₂ samples. The NO_x emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.

[40 CFR 60.46(b)(1), (2), (3), (4), & (5)]

E.22. When combinations of fossil fuels or fossil fuel and wood residue are fired, the owner or operator (in order to compute the prorated standard as shown in 40 CFR 60.43(b) and 60.44(b)) shall determine the percentage (w, x, y, or z) of the total heat input derived from each type of fuel as follows:

- (1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.
- (2) ASTM Methods D 2015-77 (solid fuels), D 240-76 (liquid fuels), or D 1826-77 (gaseous fuels) (incorporated by reference-see 40 CFR 60.17) shall be used to determine the gross calorific values of the fuels. The method used to determine the calorific value of wood residue must be approved by the Administrator.
- (3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.
[40 CFR 60.46(c)(1), (2), & (3)]

E.23. The owner or operator may use the following as alternatives to the reference methods and procedures in 40 CFR 60.46 or in other sections as specified:

(1) The emission rate (E) of particulate matter, SO₂ and NO_x may be determined by using the F_c factor, provided that the following procedure is used:

(i) The emission rate (E) shall be computed using the following equation:

$$E = C F_c (100 / \% \text{CO}_2)$$

where:

E = emission rate of pollutant, ng/J (lb/million Btu).

C = concentration of pollutant, ng/dscm (lb/dscf).

% CO₂ = carbon dioxide concentration, percent dry basis.

F_c = factor as determined in appropriate sections of Method 19.

(ii) If and only if the average F_c factor in Method 19 is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B shall be used to determine the O₂ and CO₂ concentration according to the procedures in 40 CFR 60.46(b)(2)(ii), (4)(ii), or (5)(ii). Then if F_o (average of three runs), as calculated from the equation in Method 3B, is more than ± 3 percent than the average F_o value, as determined from the average values of F_d and F_c in Method 19, i.e., F_{oa} = 0.209 (F_{da} / F_{ca}), then the following procedure shall be followed:

(A) When F_o is less than 0.97 F_{oa}, then E shall be increased by that proportion under 0.97 F_{oa}, e.g., if F_o is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When F_o is less than $0.97 F_{oa}$ and when the average difference (\bar{d}) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under $0.97 F_{oa}$, e.g., if F_o is $0.95 F_{oa}$, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When F_o is greater than $1.03 F_{oa}$ and when \bar{d} is positive, then E shall be decreased by that proportion over $1.03 F_{oa}$, e.g., if F_o is $1.05 F_{oa}$, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B, Method 17 may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of 160°C (320°F). The procedures of sections 2.1 and 2.3 of Method 5B may be used with Method 17 only if it is used after wet FGD systems. Method 17 shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

(3) Particulate matter and SO_2 may be determined simultaneously with the Method 5 train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 is used in place of the condenser (section 2.1.7) of Method 5.

(ii) All applicable procedures in Method 8 for the determination of SO_2 (including moisture) are used.

(4) For Method 6, Method 6C may be used. Method 6A may also be used whenever Methods 6 and 3B data are specified to determine the SO_2 emission rate, under the conditions in 40 CFR 60.46(d)(1).

(5) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the O_2 concentration ($\%\text{O}_2$) for the emission rate correction factor.

(6) For Method 3, Method 3A or 3B may be used.

(7) For Method 3B, Method 3A may be used.

[40 CFR 60.46(d)(1), (2), (3), (4), (5), (6), & (7)]

E.24. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

E.25. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

E.26. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

E.27. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.

b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached as part of this permit.

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

E.28. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

E.29. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid and/or solid fuel for more than 400 hours other than during startup.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the _____ year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

- b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
- c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and, SIP approved]

E.30. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

E.31. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

Continuous Monitoring Requirements

E.32. Each owner or operator shall install, calibrate, maintain, and operate continuous monitoring systems for measuring the opacity of emissions, sulfur dioxide emissions, and either oxygen or carbon dioxide except as provided in 40 CFR 60.45(b).

[40 CFR 60.45(a)]

E.33. Certain of the continuous monitoring system requirements under 40 CFR 60.45(a) do not apply to owners or operators under the following conditions:

- (1) For a fossil fuel-fired steam generator that burns only gaseous fossil fuel, continuous monitoring systems for measuring the opacity of emissions and sulfur dioxide emissions are not required.
- (2) For a fossil fuel-fired steam generator that does not use a flue gas desulfurization device, a continuous monitoring system for measuring sulfur dioxide emissions is not required if the owner or operator monitors sulfur dioxide emissions by fuel sampling and analysis under 40 CFR 60.45(d).
- (3) Notwithstanding 40 CFR 60.13(b), installation of a continuous monitoring system for nitrogen oxides may be delayed until after the initial performance tests under 40 CFR 60.8 have been conducted. If the owner or operator demonstrates during the performance test that emissions of nitrogen oxides are less than 70 percent of the applicable standards in 40 CFR 60.44, a continuous monitoring system for measuring nitrogen oxides emissions is not required. If the initial performance test results show that nitrogen oxide emissions are greater than 70 percent of the applicable standard, the owner or operator shall install a continuous monitoring system for nitrogen oxides within one year after the date of the initial performance tests under 40 CFR 60.8 and comply with all other applicable monitoring requirements under 40 CFR 60.
- (4) If an owner or operator does not install any continuous monitoring systems for sulfur oxides and nitrogen oxides, as provided under 40 CFR 60.45(b)(1) and (b)(3) or (b)(2) and (b)(3), a continuous monitoring system for measuring either oxygen or carbon dioxide is not required.

[40 CFR 60.45(b)(1), (2), (3), & (4)]

E.34. For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:

(1) Methods 6, 7, and 3B, as applicable, shall be used for the performance evaluations of sulfur dioxide and nitrogen oxides continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B are given in 40 CFR 60.46(d).

(2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of Appendix B to 40 CFR 60.

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent and for a continuous monitoring system measuring sulfur oxides or nitrogen oxides the span value shall be determined as follows:

[In parts per million]

Fossil fuel	Span value for sulfur dioxide
Gas.....	{1}
Liquid.....	1,000
Solid.....	1,500
Combinations.....	1,000y+1,500z

{1} Not applicable.

where:

x = the fraction of total heat input derived from gaseous fossil fuel, and

y = the fraction of total heat input derived from liquid fossil fuel, and

z = the fraction of total heat input derived from solid fossil fuel.

(4) All span values computed under 40 CFR 60.45(c)(3) for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm.

(5) For a fossil fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all continuous monitoring systems shall be subject to the Administrator's approval.

[40 CFR 60.45(c)(1), (2), (3), (4), & (5)]

E.35. For any continuous monitoring system installed under 40 CFR 60.45(a), the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/million Btu):

(1) When a continuous monitoring system for measuring oxygen is selected, the measurement of the pollutant concentration and oxygen concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF[20.9/(20.9\text{-percent O}_2)]$$

where:

E, C, F, and % O₂ are determined under 40 CFR 60.45(f).

(2) When a continuous monitoring system for measuring carbon dioxide is selected, the measurement of the pollutant concentration and carbon dioxide concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c [100/\text{percent CO}_2]$$

where:

E, C, F_c and % CO₂ are determined under 40 CFR 60.45(f).
[40 CFR 60.45(e)(1) and (2)]

E.36. The values used in the equations under 40 CFR 60.45(e) (1) and (2) are derived as follows:

(1) E = pollutant emissions, ng/J (lb/million Btu).

(2) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^4 M ng/dscm per ppm (2.59×10^{-9} M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for sulfur dioxide and 46.01 for nitrogen oxides.

(3) % O₂, % CO₂ = oxygen or carbon dioxide volume (expressed as percent), determined with equipment specified under 40 CFR 60.45(a).

(4) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:

(i) For anthracite coal as classified according to ASTM D388-77 (incorporated by reference-see 40 CFR 60.17), $F = 2,723 \times 10^{-17}$ dscm/J (10,140 dscf/million Btu and $F_c = 0.532 \times 10^{-17}$ scm CO₂/J (1,980 scf CO₂/million Btu).

(ii) For subbituminous and bituminous coal as classified according to ASTM D388-77 (incorporated by reference-see 40 CFR 60.17), $F = 2.637 \times 10^{-7}$ dscm/J (9,820 dscf/million Btu) and $F_c = 0.486 \times 10^{-7}$ scm CO₂/J (1,810 scf CO₂/million Btu).

(iii) For liquid fossil fuels including crude, residual, and distillate oils, $F = 2.476 \times 10^{-7}$ dscm/J (9,220 dscf/million Btu) and $F_c = 0.384 \times 10^{-7}$ scm CO₂/J (1,430 scf CO₂/million Btu).

(iv) For gaseous fossil fuels, $F = 2.347 \times 10^{-7}$ dscm/J (8,740 dscf/million Btu). For natural gas, propane, and butane fuels, $F_c = 0.279 \times 10^{-7}$ scm CO₂/J (1,040 scf CO₂/million Btu) for natural gas, 0.322×10^{-7} scm CO₂/J (1,200 scf CO₂/million Btu) for propane, and 0.338×10^{-7} scm CO₂/J (1,260 scf CO₂/million Btu) for butane.

(5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/million Btu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO₂/J, or scf CO₂/million Btu) on either basis in lieu of the F or F_c factors specified in 40 CFR 60.45(f)(4):

$$F = 10^{-6} \frac{[227.2 (\text{pct. H}) + 95.5 (\text{pct. C}) + 35.6 (\text{pct. S}) + 8.7 (\text{pct. N}) - 28.7 (\text{pct. O})]}{\text{GCV}}$$

$$F_c = \frac{2.0 \times 10^{-5} (\text{pct. C})}{\text{GCV}} \\ (\text{SI units})$$

$$F = 10^6 \frac{3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O)}{\text{GCV}} \\ (\text{English units})$$

$$F_c = \frac{20.0(\%C)}{\text{GCV}} \\ (\text{SI units})$$

$$F_c = \frac{321 \times 10^3 (\%C)}{\text{GCV}} \\ (\text{English units})$$

(i) H, C, S, N, and O are content by weight of hydrogen, carbon, sulfur, nitrogen, and oxygen (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM method D3178-74 or D3176 (solid fuels) or computed from results using ASTM method D1137-53(75), D1945-64(76), or D1946-77 (gaseous fuels) as applicable. (These five methods are incorporated by reference-see 40 CFR 60.17.)

(ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015-77 for solid fuels and D1826-77 for gaseous fuels as applicable.

(These two methods are incorporated by reference-see 40 CFR 60.17.)

(iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F_c value shall be subject to the Administrator's approval.

(6) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or F_c factors determined by paragraphs 40 CFR 60.45(f)(4) or (f)(5) shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

where:

X_i = the fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.)

F_i or $(F_c)_i$ = the applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section.

n = the number of fuels being burned in combination.

[40 CFR 60.45(f)(1), (2), (3), (4), (5), & (6)]

E.37. Continuous monitors shall be installed and operated in accordance with 40 CFR 60.45 and 60.13. In addition, an ASTM-certified automatic solid fossil fuel sampler shall be installed which produces a representative daily sample for analysis of sulfur, moisture, heating value and ash. The solid fossil fuel data shall be used in conjunction with emissions factors and the continuous monitoring data to calculate SO_2 reduction.

[PSD-FL-008(B)]

Recordkeeping and Reporting Requirements

E.38. Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c). The summary report form shall contain the information and be in the format shown in figure 1 (attached to this permit) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

[40 CFR 60.7(d) & 60.45(g)]

E.39. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.
[Rule 62-210.700(6), F.A.C.]

E.40. Submit to the Department a written report of emissions in excess of emission limiting for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.
[Rule 62-213.440, F.A.C.]

E.41. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
- (c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:
1. The type, location, and designation of the emissions unit tested.
 2. The facility at which the emissions unit is located.
 3. The owner or operator of the emissions unit.
 4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
 5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
 6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
 7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
 8. The date, starting time and duration of each sampling run.
 9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
 10. The number of points sampled and configuration and location of the sampling plane.
 11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
 12. The type, manufacturer and configuration of the sampling equipment used.

13. Data related to the required calibration of the test equipment.
 14. Data on the identification, processing and weights of all filters used.
 15. Data on the types and amounts of any chemical solutions used.
 16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
 17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
 18. All measured and calculated data required to be determined by each applicable test procedure for each run.
 19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
 20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
 21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.
- [Rule 62-297.310(8), F.A.C.]

Miscellaneous Requirements.

E.42. The permittee shall comply with the requirements contained in Appendix 40 CFR 60, Subpart A, attached to this permit.

[Rule 62-204.800(7)(d), F.A.C.]

E.43. The City shall maintain and submit to the Department on an annual basis for a period of five years from the date that the unit is initially co-fired with petroleum coke, information demonstration in accordance with 40 CFR 52.21(b)(33) and 40 CFR 52.21(b)(21)(v) that the operational changes did not result in emissions increases of carbon monoxide, nitrogen oxides, or sulfuric acid mist.

[PSD-FL-008(B)]

Section IV. This section is the Acid Rain Part.

Operated by: Lakeland Electric & Water Utilities
ORIS code: 676

Subsection A. This subsection addresses Acid Rain, Phase II.

The emissions unit(s) listed below are regulated under Acid Rain, Phase II.

E.U.

ID No.	Brief Description
-001	Boiler - McIntosh Unit 1
-005	Boiler - McIntosh Unit 2
-006	Boiler - McIntosh Unit 3

A.1. The Phase II permit application(s) submitted for this facility, as approved by the Department, are a part of this permit. The owners and operators of these Phase II acid rain unit(s) must comply with the standard requirements and special provisions set forth in the application(s) listed below:

- a. DEP Form No. 62-210.900(1)(a), dated 07/01/95.
 [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

A.2. Sulfur dioxide (SO₂) allowance allocations and nitrogen oxide (NO_x) requirements for each Acid Rain unit is as follows:

E.U. ID No.	EPA ID	Year	2000	2001	2002
-001	No. 01	SO ₂ allowances, under Table 2 or 3 of 40 CFR Part 73	897*	897*	897*
-005	No. 02	SO ₂ allowances, under Table 2 or 3 of 40 CFR Part 73	1019*	1019*	1019*
-006	No. 03	SO ₂ allowances, under Table 2 or 3 of 40 CFR Part 73	9848*	9848*	9848*

* The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 or 3 of 40 CFR 73.]

A.3. Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

1. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.

2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.

3. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]

A.4. Fast-Track Revisions of Acid Rain Parts. Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, F.A.C.

[Rules 62-213.413 and 62-214.370(4), F.A.C.]

A.5. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year.

{See condition No. 52., Appendix TV-1, Title V Conditions.}

[Rule 62-214.420(11), F.A.C.]

A.6. Comments, notes, and justifications: None.

Subsection B. This subsection addresses Acid Rain, Phase I.

{Permitting note: The U.S. EPA issues Acid Rain Phase I permit(s)}

The emissions unit listed below is regulated under Acid Rain Part, Phase I, for Lakeland Electric & Water Utilities, C. D. McIntosh, Jr. Power Plant, **Facility ID No.:** 1050004, **ORIS code:** 676

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-006	Boiler - McIntosh Unit 3

The provisions of the federal Acid Rain, Phase I permit(s), including Early Election Plans for NO_x, govern(s) the above listed emissions unit(s) through December 31, 1999. The provisions of the Phase II permit govern(s) those emissions unit(s) from January 1, 2000 through the expiration date of this Title V permit. The Phase II permit governs all other affected units for the effective period of this permit.

B.1. The owners and operators of these Phase I acid rain unit(s) must comply with the standard requirements and special provisions set forth in the permit(s) listed below:

- a. Phase I permit dated 03/27/97.
 [Chapter 62-213, F.A.C.]

B.2. Nitrogen oxide (NO_x) requirements for each Acid Rain unit is as follows:

<u>E.U. ID No.</u>	<u>EPA ID</u>	<u>NO_x limit*</u>
-006	No. 03	<p>Pursuant to 40 CFR 76.8(d)(2), the Florida Department of Environmental Protection approves a NO_x early election compliance plan for unit U1. The compliance plan is effective for calendar year 2000 through calendar year 2007. Under the compliance plan, this unit's annual average NO_x emission rate for each year, determined in accordance with 40 CFR part 75, shall not exceed the applicable emission limitation, under "40 CFR 76.5(a)(2) of 0.50 lb/mmBtu" for dry bottom wall-fired boilers. If the unit is in compliance with its applicable emission limitation for each year of the plan, then the unit shall not be subject to the applicable emission limitation, under "40 CFR 76.7(a)(2) of 0.46 lb/mmBtu" for dry bottom wall-fired boilers until calendar year 2008.</p> <p>In addition to the described NO_x compliance plan, this unit shall comply with all other applicable requirements of 40 CFR part 76, including the duty to reapply for a NO_x compliance plan and the requirements covering excess emissions.</p>

* Based on the Phase II NO_x Compliance Plan dated December 4, 1997.

B.3. Comments, notes, and justifications: none

Appendix H-1, Permit History/ID Number Changes

City of Lakeland
C. D. McIntosh

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

Permit History (for tracking purposes):

E.U.

<u>ID No</u>	<u>Description</u>	<u>Permit No.</u>	<u>Issue Date</u>	<u>Expiration Date</u>	<u>Extended Date</u> ^{1,2,3}	<u>Revised Date(s)</u>
-001	Boiler Unit #1	AO53-243945	03/23/95	05/27/99		
-002	Peaking Unit 2 (Diesel Engine)	AO53-244726	06/01/94	05/27/99		
-003	Peaking Unit 3 (Diesel Engine)	AO53-244726	06/01/94	05/27/99		
-004	Gas Turbine Peaking Unit 1	AO53-244727	06/01/94	05/27/99		
-005	Unit 2 Electric Generator	AO53-174090	04/17/90	04/13/95	08/14/96	
-006	McIntosh Unit 3 Coal/MSW Fired	PSD-FL-008 PSD-FL-008A PSD-FL-008B PA74-06SR	12/27/78 12/11/95 12/07/78			
ALL	C. D. McIntosh, Jr. Power Plant	1050004-003-AV	04/15/98	12/31/03		

(if applicable) ID Number Changes (for tracking purposes):

From: Facility ID No.: 40TPA530004

To: Facility ID No.: 1050004

Notes:

1 - AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

2 - AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96.

3 - ORDER EXTENDING PERMIT EXPIRATION DATE dated 02/09/98.

{Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
I-001] McIntosh Unit 1 - Fossil Fuel Fired Steam Generator

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
VE	All	8,760	20% w/ 40% for 2 min/hr					62-296.405(1)(a),FAC	III.A.5.
VE	All		60% 3 hrs/24 hrs					62-210.700(3),FAC	III.A.6.
PM	Gas	8,760	0.1 lb/MMBtu			98.5	431.4	62-296.405(1)(b),FAC	III.A.7.
PM	Oil	8,760	0.1 lb/MMBtu			95.0	416.1	62-296.405(1)(b),FAC	III.A.7.
PM	Gas	1,095	0.3 lb/MMBtu			295.5	161.8	62-210.700(3),FAC	III.A.8.
PM	Oil	1,095	0.3 lb/MMBtu			285.0	155.0	62-210.700(3),FAC	III.A.8.
SO ₂	Oil	8,760	2.75 lb/MMBtu			2,612.5	11,442.8	62-296.405(1)(c)1..FAC	III.A.9.
SO ₂	Oil	8,760	2.5% S by weight			2,612.5	11,442.8	AO 53-243945	III.A.10.
Arsenic	Used Oil		5 ppm (42,000 gal/yr)				0.0008	AO 53-243945	III.A.11.
Cadmium	Used Oil		2 ppm (42,000 gal/yr)				0.0003	AO 53-243945	III.A.11.
Chromium	Used Oil		10 ppm (42,000 gal/yr)				0.0017	AO 53-243945	III.A.11.
Lead	Used Oil		100 ppm (42,000 gal/yr)				0.017	AO 53-243945	III.A.11.
Total Halogens	Used Oil		1,000 ppm (42,000 gal/yr)				0.17	AO 53-243945	III.A.11.
PCBs	Used Oil		<50 ppm (42,000 gal/yr)				0.0084	AO 53-243945	III.A.11.

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
[-002]	Diesel Engine Peaking Unit 2
[-003]	Diesel Engine Peaking Unit 3

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
VE	All	8,760	< 20%					62-296.320(4)(b)1., FAC	III.B.5.
SO ₂	Oil	8,760	0.5% S by weight			15.4	67.5	AO 53-244726	III.B.6.

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.

[electronic file name: 10500041.xls]

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-004] Gas Turbine Peaking Unit 1

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
VE	All	8,760	< 20 %					62-296.320(4)(b)1., FAC	III.C.5.
SO ₂	Oil	8,760	0.5% S by weight			176.0	770.9	AO 53-244727	III.C.6.

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-005] McIntosh Unit 2 - Fossil Fuel Fired Steam Generator

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
PM	Gas	8,760	0.10 lb/MMBtu			118.5	518.8	40 CFR 60.42(a)(1)	III.D.5.
PM	Oil	8,760	0.10 lb/MMBtu			111.5	488.4	40 CFR 60.42(a)(1)	III.D.5.
VE	All	8,760	20% w/ 27% for 6 min/hr					40 CFR 60.42(a)(2)	III.D.5.
SO ₂	Oil	8,760	0.80 lb/MMBtu			892.0	3,907.0	40 CFR 60.43(a)(1)	III.D.6.
NO _x	Gas	8,760	0.20 lb/MMBtu			238.9	1,037.8	40 CFR 60.44(a)(1)	III.D.8.
NO _x	Oil	8,760	0.30 lb/MMBtu			355.4	1,556.4	40 CFR 60.44(a)(2)	III.D.8.

Notes:
[electronic file name: 10500041.xls]

[electronic file name: xxxxxxx1.xls]

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-006] McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
PM	Coal	8,760	0.044 lb/MMBtu			160.2	701.5	PSD-FL-008(B)	III.E.5.
PM	Coal/Pet Coke	8,760	0.044 lb/MMBtu			160.2	701.5	PSD-FL-008(B)	III.E.5.
PM	Coal/RDF	8,760	0.050 lb/MMBtu			182.0	701.5	PSD-FL-008(B)	III.E.5.
PM	Coal/Pet Coke/RDF	8,760	0.050 lb/MMBtu			182.0	797.2	PSD-FL-008(B)	III.E.5.
PM	Oil	8,760	0.070 lb/MMBtu			254.8	1,116.0	PSD-FL-008(B)	III.E.5.
PM	Oil/RDF	8,760	0.075 lb/MMBtu			273.0	1,195.7	PSD-FL-008(B)	III.E.5.
VE	All	8,760	20% w/ 27% for 6 min/hr					40 CFR 60.42(a)(2)	III.E.5.
SO ₂	Oil	8,760	0.80 lb/MMBtu			2,912.0	12,754.6	40 CFR 60.43(a)(1)	III.E.6. & 10
SO ₂	Solid	8,760	1.2 lb/MMBtu			4,368.0	19,131.8	40 CFR 60.43(a)(2)	III.E.6.
NO _x	Gas	8,760	0.20 lb/MMBtu			728.0	3,189.6	40 CFR 60.44(a)(1)	III.E.13.
NO _x	Liquid	8,760	0.30 lb/MMBtu			1,092.0	4,783.0	40 CFR 60.44(a)(2)	III.E.13.
NO _x	Solid	8,760	0.70 lb/MMBtu			2,548.0	11,180.2	40 CFR 60.44(a)(3)	III.E.13.

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.

[electronic file name: 10500041.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-001] McIntosh Unit 1 - Fossil Fuel Fired Steam Generator

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS **	See permit condition(s)
VE	Oil	DEP Method 9	Annual	1-Jul	60 minutes		III.A.17. & 18. & 28.
PM	Gas	EPA Method 17, 5, 5B, or 5F	ASP No. 97-B-01	1-Jul	1 hour		III.A.19. & 29.
PM	Oil	EPA Method 17, 5, 5B, or 5F	Annual	1-Jul	1 hour		III.A.19. & 29.
SO ₂	Oil	EPA Method 6, 6A, 6B, or 6C	Annual	1-Jul	1 hour		III.A.15. & 20. & 27.
SO ₂	Oil	2.5% S by weight	Each Delivery				III.A.15. & 20. & 21.
Arsenic	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Cadmium	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Chromium	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Lead	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Total Halogens	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Flash Point	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
PCBs	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.

Notes:
 * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
 ** CMS [=] continuous monitoring system

[electronic file name: 10500042.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
 C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
[-002]	Diesel Engine Peaking Unit 2
[-003]	Diesel Engine Peaking Unit 3

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS **	See permit condition(s)

Notes:
 * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
 **CMS [=] continuous monitoring system

[electronic file name: 10500042.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-004] Gas Turbine Peaking Unit 1

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS **	See permit condition(s)
VE	Oil	EPA Method 9	Annual	1-Aug	30 minutes		III.B.11. & 15. & 16.
SO ₂	Oil	0.5% S by weight	Each Delivery				III.C.6. & 9. & 12.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

[electronic file name: 10500042.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. [005] **Brief Description** McIntosh Unit 2 - Fossil Fuel Fired Steam Generator

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
PM	Oil	EPA Method 17, 5, or 5B	Annual	23-Jun	1 hour		III.D.15., 19., & 27.
VE	Gas	EPA Method 9	Renewal	23-Jun	60 minutes	Yes	III.D.15. & 26.
VE	Oil	EPA Method 9	Annual	23-Jun	60 minutes	Yes	III.D.15. & 26.
SO ₂	Oil	EPA Method 6, 6A, or 6C	Annual	23-Jun	1 hour	Yes	III.D.16., 17., 19., & 29.
NO _x	All	EPA Method 7, 7A, 7C, 7D, or 7E	Annual	23-Jun	1 hour		III.D.15. & 19.

Notes:

- * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
- **CMS [=] continuous monitoring system

[electronic file name: 10500042.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-006] McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	Monitoring	
						CMS**	See permit condition(s)
PM	Gas Only	EPA Method 17, 5, or 5B	ASP No. 97-B-01	23-Jun	1 hour		III.E.21., 23., & 31.
PM	All Other	EPA Method 17, 5, or 5B	Annual	23-Jun	1 hour		III.E.21., 23., & 31.
VE	Gas Only	EPA Method 9	Renewal	23-Jun	60 minutes	Yes	III.D.21. & 30.
VE	All Other	EPA Method 9	Annual	23-Jun	60 minutes	Yes	III.D.21. & 30.
SO ₂	Liquid & Solid	EPA Method 6, 6A, or 6C	Annual	23-Jun	1 hour	Yes	III.E.21. & 23.
NO _x	All	EPA Method 7, 7A, 7C, 7D, or 7E	Annual	23-Jun	1 hour	Yes	III.E.21. & 23.

Notes:
 * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
 **CMS [=] continuous monitoring system

[electronic file name: 10500042.xls]

Appendix U-1, List of Unregulated Emissions Units and/or Activities.

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

Unregulated Emissions Units and/or Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither ‘regulated emissions units’ nor ‘insignificant emissions units’.

E.U.

<u>ID No.</u>	<u>Brief Description of Emissions Units and/or Activity</u>
-007	Tanks with greater than 10,000 gallon capacity installed prior to July 23, 1984
-008	Diesel drive coal tunnel sump engine
-009	Fire water UPS diesel No. 31
-010	Fire water UPS diesel No. 32
-011	CT startup diesel
-012	General purpose diesel engines
-013	Emergency generators
-014	General purpose painting
-015	Parts Cleaning
-016	Sand Blasting (Maintenance only)
-017	Wastewater Treatment Tank
-018	Three Cooling Towers (Unit 2 and 3)
-019	Northside Waste Water Treatment Facility - Wastewater treatment processes and tanks
-020	Northside Waste Water Treatment Facility - Two emergency diesel generators
-021	Northside Waste Water Treatment Facility - Chemical and petroleum storage
-022	Northside Waste Water Treatment Facility - Miscellaneous activities
-023	Coal processing and conveying system
-024	Coal storage system
-025	Coal transfer and loading system
-026	Limestone handling and storage system
-027	Flyash handling and storage system

[electronic file name: 1050004u.doc]

Appendix I-1, List of Insignificant Emissions Units and/or Activities.

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-005-AV
Facility ID No.: 1050004

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62.210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

1. Diesel Storage Tank (T-021)
2. Heavy Oil Tank (T-113)
3. Heavy Oil Tank (T-114)
4. Heavy Oil Tank (T-115)
5. Used Oil Tank (T-116)
6. Comfort Heating <1 MMBtu/hr
7. Non-Industrial Vacuum Cleaning
8. Refrigeration Units
9. Vacuum Pumps for Labs
10. Steam Cleaning Equipment
11. Sanders <5 square feet
12. Space Heating Equipment; non-boilers
13. Bakery Ovens
14. Lab Equipment
15. Brazing, Soldering, or Welding
16. Laundry Dryers
17. Fire and Safety Equipment
18. Surface Coating <5% VOC

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97)

[Note: This attachment includes "canned conditions" developed from the "Title V Core List."]

{Permitting note: APPENDIX TV-1, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}

Chapter 62-4, F.A.C.

1. **Not federally enforceable. General Prohibition.** Any stationary installation which will reasonably be expected to be a source of pollution shall not be operated, maintained, or modified without the appropriate and valid permits issued by the Department, unless the source is exempted by Department rule. The Department may issue a permit only after it receives reasonable assurance that the installation will not cause pollution in violation of any of the provisions of Chapter 403, F.S., or the rules promulgated thereunder. A permitted installation may only be operated, maintained, constructed, expanded or modified in a manner that is consistent with the terms of the permit.

[Rule 62-4.030, Florida Administrative Code (F.A.C.); Section 403.087, Florida Statute (F.S.)]

2. **Not federally enforceable. Procedure to Obtain Permits; Application.**

(1) Any person desiring to obtain a permit from the Department shall apply on forms prescribed by the Department and shall submit such additional information as the Department by law may require.

(2) All applications and supporting documents shall be filed in quadruplicate with the Department.

(3) To ensure protection of public health, safety, and welfare, any construction, modification, or operation of an installation which may be a source of pollution shall be in accordance with sound professional engineering practices pursuant to Chapter 471, F.S. All applications for a Department permit shall be certified by a professional engineer registered in the State of Florida except when the application is for renewal of an air pollution operation permit at a minor facility as defined in Rule 62-210.200, F.A.C., or where professional engineering is not required by Chapter 471, F.S. Where required by Chapter 471 or 492, F.S., applicable portions of permit applications and supporting documents which are submitted to the Department for public record shall be signed and sealed by the professional(s) who prepared or approved them.

(4) Processing fees for air construction permits shall be in accordance with Rule 62-4.050(4), F.A.C.

(5)(a) To be considered by the Department, each application must be accompanied by the proper processing fee. The fee shall be paid by check, payable to the Department of Environmental Protection. The fee is non-refundable except as provided in Section 120.60, F.S., and in this section.

(c) Upon receipt of the proper application fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin.

(d) If the applicant does not submit the required fee within ten days of receipt of written notification, the Department shall either return the unprocessed application or arrange with the applicant for the pick up of the application.

(e) If an applicant submits an application fee in excess of the required fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin upon receipt, and the Department shall refund to the applicant the amount received in excess of the required fee.

(6) Any substantial modification to a complete application shall require an additional processing fee determined pursuant to the schedule set forth in Rule 62-4.050, F.A.C., and shall restart the time requirements of Sections 120.60 and 403.0876, F.S. For purposes of this Subsection, the term "substantial modification" shall mean a modification which is reasonably expected to lead to substantially different environmental impacts which require a detailed review.

(7) Modifications to existing permits proposed by the permittee which require substantial changes in the existing permit or require substantial evaluation by the Department of potential impacts of the proposed modifications shall require the same fee as a new application.

[Rule 62-4.050, F.A.C.]

3. **Standards for Issuing or Denying Permits.** Except as provided at Rule 62-213.460, F.A.C., the issuance of a permit does not relieve any person from complying with the requirements of Chapter 403, F.S., or Department rules.

[Rule 62-4.070(7), F.A.C.]

4. Modification of Permit Conditions.

(1) For good cause and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions and on application of the permittee the Department may grant additional time. For the purpose of this section, good cause shall include, but not be limited to, any of the following:

- (a) A showing that an improvement in effluent or emission quality or quantity can be accomplished because of technological advances without unreasonable hardship.
- (b) A showing that a higher degree of treatment is necessary to effect the intent and purpose of Chapter 403, F.S.
- (c) A showing of any change in the environment or surrounding conditions that requires a modification to conform to applicable air or water quality standards.
- (e) Adoption or revision of Florida Statutes, rules, or standards which require the modification of a permit condition for compliance.

(2) A permittee may request a modification of a permit by applying to the Department.

(3) A permittee may request that a permit be extended as a modification of the permit. Such a request must be submitted to the Department in writing before the expiration of the permit. Upon timely submittal of a request for extension, unless the permit automatically expires by statute or rule, the permit will remain in effect until final agency action is taken on the request. For construction permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that, upon completion, the extended permit will comply with the standards and conditions required by applicable regulation. For all other permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that the extended permit will comply with the standards and conditions applicable to the original permit. A permit for which the permit application fee was prorated in accordance with Rule 62-4.050(4)(1), F.A.C., shall not be extended. In no event shall a permit be extended or remain in effect longer than the time limits established by statute or rule.

[Rule 62-4.080, F.A.C.]

5. Renewals. Prior to one hundred eighty (180) days before the expiration of a permit issued pursuant to Chapter 62-213, F.A.C., the permittee shall apply for a renewal of a permit using forms incorporated by reference in the specific rule chapter for that kind of permit. A renewal application shall be timely and sufficient. If the application is submitted prior to 180 days before expiration of the permit, it will be considered timely and sufficient. If the renewal application is submitted at a later date, it will not be considered timely and sufficient unless it is submitted and made complete prior to the expiration of the operation permit. When the application for renewal is timely and sufficient, the existing permit shall remain in effect until the renewal application has been finally acted upon by the Department or, if there is court review of the Department's final agency action, until a later date is required by Section 120.60, F.S., provided that, for renewal of a permit issued pursuant to Chapter 62-213, F.A.C., the applicant complies with the requirements of Rules 62-213.420(1)(b)3. and 4., F.A.C.

[Rule 62-4.090(1), F.A.C.]

6. Suspension and Revocation.

(1) Permits shall be effective until suspended, revoked, surrendered, or expired and shall be subject to the provisions of Chapter 403, F.S., and rules of the Department.

(2) Failure to comply with pollution control laws and rules shall be grounds for suspension or revocation.

(3) A permit issued pursuant to Chapter 62-4, F.A.C., shall not become a vested property right in the permittee. The Department may revoke any permit issued by it if it finds that the permit holder or the permit holder's agent:

- (a) Submitted false or inaccurate information in application or operational reports.
- (b) Has violated law, Department orders, rules or permit conditions.
- (c) Has failed to submit operational reports or other information required by Department rules.
- (d) Has refused lawful inspection under Section 403.091, F.S.

[Rule 62-4.100, F.A.C.]

7. **Not federally enforceable.** Financial Responsibility. The Department may require an applicant to submit proof of financial responsibility and may require the applicant to post an appropriate bond to guarantee compliance with the law and Department rules.

[Rule 62-4.110, F.A.C.]

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

8. Transfer of Permits.

- (1) Within 30 days after the sale or legal transfer of a permitted facility, an "Application for Transfer of Permit" (DEP Form 62-1.201(1)) must be submitted to the Department. This form must be completed with the notarized signatures of both the permittee and the proposed new permittee.
 - (2) The Department shall approve the transfer of a permit unless it determines that the proposed new permittee cannot provide reasonable assurances that conditions of the permit will be met. The determination shall be limited solely to the ability of the new permittee to comply with the conditions of the existing permit, and it shall not concern the adequacy of these permit conditions. If the Department proposes to deny the transfer, it shall provide both the permittee and the proposed new permittee a written objection to such transfer together with notice of a right to request a Chapter 120, F.S., proceeding on such determination.
 - (3) Within 30 days of receiving a properly completed Application for Transfer of Permit form, the Department shall issue a final determination. The Department may toll the time for making a determination on the transfer by notifying both the permittee and the proposed new permittee that additional information is required to adequately review the transfer request. Such notification shall be served within 30 days of receipt of an Application for Transfer of Permit form, completed pursuant to Rule 62-4.120(1), F.A.C. If the Department fails to take action to approve or deny the transfer within 30 days of receipt of the completed Application for Transfer of Permit form, or within 30 days of receipt of the last item of timely requested additional information, the transfer shall be deemed approved.
 - (4) The permittee is encouraged to apply for a permit transfer prior to the sale or legal transfer of a permitted facility. However, the transfer shall not be effective prior to the sale or legal transfer.
 - (5) Until this transfer is approved by the Department, the permittee and any other person constructing, operating, or maintaining the permitted facility shall be liable for compliance with the terms of the permit. The permittee transferring the permit shall remain liable for corrective actions that may be required as a result of any violations occurring prior to the sale or legal transfer of the facility.
- [Rule 62-4.120, F.A.C.]

9. Plant Operation-Problems. If the permittee is temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by hazard of fire, wind or by other cause, the permittee shall immediately notify the Department. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules.
- [Rule 62-4.130, F.A.C.]

10. For purposes of notification to the Department pursuant to Rule 62-4.130, F.A.C., Plant Operation-Problems, "immediately" shall mean the same day, if during a workday (i.e., 8:00 a.m. - 5:00 p.m.), or the first business day after the incident, excluding weekends and holidays.
- [40 CFR 70.6(a)(3)(iii)(B)]

11. **Not federally enforceable.** Review. Failure to request a hearing within 14 days of receipt of notice of proposed or final agency action on a permit application or as otherwise required in Chapter 62-103, F.A.C., shall be deemed a waiver of the right to an administrative hearing.
- [Rule 62-4.150, F.A.C.]

12. Permit Conditions. All permits issued by the Department shall include the following general conditions:

- (1) The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
- (2) This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
- (3) As provided in subsections 403.087(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

- (4) This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- (5) This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department.
- (6) The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- (7) The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
- (a) Have access to and copy any records that must be kept under conditions of the permit;
 - (b) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and,
 - (c) Sample or monitor any substances or parameters at any location reasonable necessary to assure compliance with this permit or Department rules. Reasonable time may depend on the nature of the concern being investigated.
- (8) If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
- (a) A description of and cause of noncompliance; and,
 - (b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.
- (9) In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the F.S. or Department rules, except where such use is prescribed by Sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- (10) The permittee agrees to comply with changes in Department rules and F.S. after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by F.S. or Department rules.
- (11) This permit is transferable only upon Department approval in accordance with Rule 62-4.120, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- (12) This permit or a copy thereof shall be kept at the work site of the permitted activity.
- (14) The permittee shall comply with the following:
- (a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
 - (b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least five (5) years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
 - (c) Records of monitoring information shall include:
 - 1. the date, exact place, and time of sampling or measurements;
 - 2. the person responsible for performing the sampling or measurements;
 - 3. the dates analyses were performed;
 - 4. the person responsible for performing the analyses;
 - 5. the analytical techniques or methods used; and,
 - 6. the results of such analyses.
- (15) When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.
- [Rules 62-4.160 and 62-213.440(1)(b), F.A.C.]

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

13. Construction Permits.

(1) No person shall construct any installation or facility which will reasonably be expected to be a source of air or water pollution without first applying for and receiving a construction permit from the Department unless exempted by statute or Department rule. In addition to the requirements of Chapter 62-4, F.A.C., applicants for a Department Construction Permit shall submit the following as applicable:

- (a) A completed application on forms furnished by the Department.
- (b) An engineering report covering:
 - 1. plant description and operations,
 - 2. types and quantities of all waste material to be generated whether liquid, gaseous or solid,
 - 3. proposed waste control facilities,
 - 4. the treatment objectives,
 - 5. the design criteria on which the control facilities are based, and,
 - 6. other information deemed relevant.

Design criteria submitted pursuant to Rule 62-4.210(1)(b)5., F.A.C., shall be based on the results of laboratory and pilot-plant scale studies whenever such studies are warranted. The design efficiencies of the proposed waste treatment facilities and the quantities and types of pollutants in the treated effluents or emissions shall be indicated. Work of this nature shall be subject to the requirements of Chapter 471, F.S. Where confidential records are involved, certain information may be kept confidential pursuant to Section 403.111, F.S.

- (c) The owners' written guarantee to meet the design criteria as accepted by the Department and to abide by Chapter 403, F.S. and the rules of the Department as to the quantities and types of materials to be discharged from the installation. The owner may be required to post an appropriate bond or other equivalent evidence of financial responsibility to guarantee compliance with such conditions in instances where the owner's financial resources are inadequate or proposed control facilities are experimental in nature.

(2) The construction permit may contain conditions and an expiration date as determined by the Secretary or the Secretary's designee.

(3) When the Department issues a permit to construct, the permittee shall be allowed a period of time, specified in the permit, to construct, and to operate and test to determine compliance with Chapter 403, F.S., and the rules of the Department and, where applicable, to apply for and receive an operation permit. The Department may require tests and evaluations of the treatment facilities by the permittee at his/her expense.

[Rule 62-4.210, F.A.C.]

14. **Not federally enforceable.** Operation Permit for New Sources. To properly apply for an operation permit for new sources, the applicant shall submit certification that construction was completed noting any deviations from the conditions in the construction permit and test results where appropriate.

[Rule 62-4.220, F.A.C.]

Chapter 62-103, F.A.C.

15. Public Notice, Public Participation, and Proposed Agency Action. The permittee shall comply with all of the requirements for public notice, public participation, and proposed agency action pursuant to Rule 62-103.150 and Rule 62-210.350, F.A.C.

[Rules 62-103.150, 62-210.350 and 62-213.430(1)(b), F.A.C.]

16. Administrative Hearing. The permittee shall comply with all of the requirements for a petition for administrative hearing or waiver of right to administrative proceeding pursuant to Rule 61-103.155, F.A.C.

[Rule 62-103.155, F.A.C.]

Chapter 62-204, F.A.C.

17. Asbestos. This permit does not authorize any demolition or renovation of the facility or its parts or components which involves asbestos removal. This permit does not constitute a waiver of any of the requirements of Chapter 62-257, F.A.C., and 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos, adopted and incorporated by reference in Rule 62-204.800, F.A.C. Compliance with Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, Section 61.145, is required for any asbestos demolition or renovation at the source.

[40 CFR 61; Rule 62-204.800, F.A.C.; and, Chapter 62-257, F.A.C.]

Chapter 62-210, F.A.C.

18. Permits Required. The owner or operator of any emissions unit which emits or can reasonably be expected to emit any air pollutant shall obtain an appropriate permit from the Department prior to beginning construction, modification, or initial or continued operation of the emissions unit unless exempted pursuant to Department rule or statute. All emissions limitations, controls, and other requirements imposed by such permits shall be at least as stringent as any applicable limitations and requirements contained in or enforceable under the State Implementation Plan (SIP) or that are otherwise federally enforceable. Except as provided at Rule 62-213.460, F.A.C., issuance of a permit does not relieve the owner or operator of an emissions unit from complying with any applicable requirements, any emission limiting standards or other requirements of the air pollution rules of the Department or any other such requirements under federal, state, or local law.

(1) Air Construction Permits. An air construction permit shall be obtained by the owner or operator of any proposed new or modified facility or emissions unit prior to the beginning of construction or modification, in accordance with all applicable provisions of Chapters 62-210, 62-212 and 62-4, F.A.C. The construction permit shall be issued for a period of time sufficient to allow construction or modification of the facility or emissions unit and operation while the new or modified facility or emissions unit is conducting tests or otherwise demonstrating initial compliance with the conditions of the construction permit.

(2) Air Operation Permits. Upon expiration of the air operation permit for any existing facility or emissions unit, subsequent to construction or modification and demonstration of initial compliance with the conditions of the construction permit for any new or modified facility or emissions unit, or as otherwise provided in Chapter 62-210 or Chapter 62-213, the owner or operator of such facility or emissions unit shall obtain a renewal air operation permit, an initial air operation permit, or an administrative correction or revision of an existing air operation permit, whichever is appropriate, in accordance with all applicable provisions of Chapter 62-210, Chapter 62-213, and Chapter 62-4, F.A.C.

(a) Minimum Requirements for All Air Operation Permits. At a minimum, a permit issued pursuant to this subsection shall:

1. Specify the manner, nature, volume and frequency of the emissions permitted, and the applicable emission limiting standards or performance standards, if any;
2. Require proper operation and maintenance of any pollution control equipment by qualified personnel, where applicable in accordance with the provisions of any operation and maintenance plan required by the air pollution rules of the Department.
3. Contain an effective date stated in the permit which shall not be earlier than the date final action is taken on the application and be issued for a period, beginning on the effective date, as provided below.
 - a. The operation permit for an emissions unit which is in compliance with all applicable rules and in operational condition, and which the owner or operator intends to continue operating, shall be issued or renewed for a five-year period, except that, for Title V sources subject to Rule 62-213.420(1)(a)1., F.A.C., operation permits shall be extended until 60 days after the due date for submittal of the facility's Title V permit application as specified in Rule 62-213.420(1)(a)1., F.A.C.
 - b. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for six months or more prior to the expiration date of the current operation permit, shall be renewed for a period not to exceed five years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided:
 - (i) the owner or operator of the emissions unit demonstrates to the Department that the emissions unit may need to be reactivated and used, or that it is the owner's or operator's intent to apply to the Department for a permit to construct a new emissions unit at the facility before the end of the extension period; and,
 - (ii) the owner or operator of the emissions unit agrees to and is legally prohibited from providing the allowable emission permitted by the renewed permit as an emissions offset to any other person under Rule 62-212.500, F.A.C.; and,
 - (iii) the emissions unit was operating in compliance with all applicable rules as of the time the source was shut down.
 - c. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for five years or more prior to the expiration date of the current operation permit shall be renewed for a maximum period not to exceed ten years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided the conditions given in Rule 62-210.300(2)(a)3.b., F.A.C., are met and the owner or operator demonstrates to the Department that failure to renew the permit would constitute a hardship, which may include economic hardship.

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

d. The operation permit for an electric utility generating unit on cold standby or long-term reserve shutdown shall be renewed for a five-year period, and additional five-year periods, even if the unit is not maintained in operational condition, provided the conditions given in Rules 62-210.300(2)(a)3.b.(i) through (iii), F.A.C., are met.

4. In the case of an emissions unit permitted pursuant to Rules 62-210.300(2)(a)3.b., c., and d., F.A.C., include reasonable notification and compliance testing requirements for reactivation of such emissions unit and provide that the owner or operator demonstrate to the Department prior to reactivation that such reactivation would not constitute reconstruction pursuant to Rule 62-204.800(7), F.A.C.

[Rules 62-210.300(1) & (2), F.A.C.]

19. **Not federally enforceable. Notification of Startup.** The owner or operator of any emissions unit or facility which has a valid air operation permit and which has been shut down more than one (1) year, shall notify the Department in writing of the intent to start up such emissions unit or facility, a minimum of sixty (60) days prior to the intended startup date.

(a) The notification shall include the planned startup date, anticipated emission rates or pollutants released, changes to processes or control devices which will result in changes to emission rates, and any other conditions which may differ from the valid outstanding operation permit.

(b) If, due to an emergency, a startup date is not known 60 days prior thereto, the owner shall notify the Department as soon as possible after the date of such startup is ascertained.

[Rule 62-210.300(5), F.A.C.]

20. **Emissions Unit Reclassification.**

(a) Any emissions unit whose operation permit has been revoked as provided for in Chapter 62-4, F.A.C., shall be deemed permanently shut down for purposes of Rule 62-212.500, F.A.C. Any emissions unit whose permit to operate has expired without timely renewal or transfer may be deemed permanently shut down, provided, however, that no such emissions unit shall be deemed permanently shut down if, within 20 days after receipt of written notice from the Department, the emissions unit owner or operator demonstrates that the permit expiration resulted from inadvertent failure to comply with the requirements of Rule 62-4.090, F.A.C., and that the owner or operator intends to continue the emissions unit in operation, and either submits an application for an air operation permit or complies with permit transfer requirements, if applicable.

(b) If the owner or operator of an emissions unit which is so permanently shut down, applies to the Department for a permit to reactivate or operate such emissions unit, the emissions unit will be reviewed and permitted as a new emissions unit.

[Rule 62-210.300(6), F.A.C.]

21. **Public Notice and Comment.**

(1) **Public Notice of Proposed Agency Action.**

(a) Notwithstanding any discretionary public notice requirements contained in Rule 62-103.150(2)(a), F.A.C., a notice of proposed agency action on permit application, where the proposed agency action is to issue the permit, shall be published by any applicant for:

1. An air construction permit;
2. An air operation permit, permit renewal or permit revision subject to Rule 62-210.300(2)(b), F.A.C., (i.e., a FESOP), except as provided in Rule 62-210.300(2)(b)1.b., F.A.C.; or
3. An air operation permit, permit renewal, or permit revision subject to Chapter 62-213, F.A.C., except those permit revisions meeting the requirements of Rule 62-213.412(1), F.A.C.

(b) The notice required by Rule 62-210.350(1)(a), F.A.C., shall be published in accordance with all otherwise applicable provisions of Rule 62-103.150, F.A.C.

(2) **Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment-Area Preconstruction Review.**

(a) Before taking final agency action on a construction permit application for any proposed new or modified facility or emissions unit subject to the preconstruction review requirements of Rule 62-212.400 or 62-212.500, F.A.C., the Department shall comply with all applicable provisions of Rule 62-103.150, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:

1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S., and the Department's analysis of the effect of the proposed construction or modification on ambient air quality, including the Department's preliminary determination of whether the permit should be approved or disapproved;
2. A 30-day period for submittal of public comments; and,

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

3. A notice, by advertisement in a newspaper of general circulation in the county affected, specifying the nature and location of the proposed facility or emissions unit, whether BACT or LAER has been determined, the degree of PSD increment consumption expected, if applicable, and the location of the information specified in paragraph 1. above; and notifying the public of the opportunity for submitting comments and requesting a public hearing.
- (b) The notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-103.150, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.
- (c) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall also be sent by the Department to the Regional Office of the U. S. Environmental Protection Agency and to all other state and local officials or agencies having cognizance over the location of such new or modified facility or emissions unit, including local air pollution control agencies, chief executives of city or county government, regional land use planning agencies, and any other state, Federal Land Manager, or Indian Governing Body whose lands may be affected by emissions from the new or modified facility or emissions unit.
- (d) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be displayed in the appropriate district, branch and local program offices.
- (e) An opportunity for public hearing shall be provided in accordance with Chapter 120, F.S., and Rule 62-103.150, F.A.C.
- (f) Any public comments received shall be made available for public inspection in the location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., is available and shall be considered by the Department in making a final determination to approve or deny the permit.
- (g) The final determination shall be made available for public inspection at the same location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., was made available.
- (h) For a proposed new or modified emissions unit which would be located within 100 kilometers of any Federal Class I area or whose emissions may affect any Federal Class I area, and which would be subject to the preconstruction review requirements of Rule 62-212.400, F.A.C., or Rule 62-212.500, F.A.C.:
1. The Department shall mail or transmit to the Administrator a copy of the initial application for an air construction permit and notice of every action related to the consideration of the permit application.
 2. The Department shall mail or transmit to the Federal Land Manager of each affected Class I area a copy of any written notice of intent to apply for an air construction permit; the initial application for an air construction permit, including all required analyses and demonstrations; any subsequently submitted information related to the application; the preliminary determination and notice of proposed agency action on the permit application; and any petition for an administrative hearing regarding the application or the Department's proposed action. Each such document shall be mailed or transmitted to the Federal Land Manager within fourteen (14) days after its receipt by the Department.
- (3) Additional Public Notice Requirements for Facilities Subject to Operation Permits for Title V Sources.
- (a) Before taking final agency action to issue a new, renewed, or revised air operation permit subject to Chapter 62-213, F.A.C., the Department shall comply with all applicable provisions of Rule 62-103.150, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:
1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S.; and,
 2. A 30-day period for submittal of public comments.
- (b) The notice provided for in Rule 62-210.350(3)(a), F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-103.150, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.
- (c) The notice shall identify:
1. The facility;
 2. The name and address of the office at which processing of the permit occurs;
 3. The activity or activities involved in the permit action;
 4. The emissions change involved in any permit revision;
 5. The name, address, and telephone number of a Department representative from whom interested persons may obtain additional information, including copies of the permit draft, the application, and all relevant supporting materials, including any permit application, compliance plan, permit, monitoring report, and compliance statement required pursuant to Chapter 62-213, F.A.C. (except for information entitled to confidential treatment pursuant to Section 403.111, F.S.), and all other materials available to the Department that are relevant to the permit decision;
 6. A brief description of the comment procedures required by Rules 62-103.150 and 62-210.350(3), F.A.C.;
 7. The time and place of any hearing that may be held, including a statement of procedure to request a hearing (unless a hearing has already been scheduled); and,

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

8. The procedures by which persons may petition the Administrator to object to the issuance of the proposed permit after expiration of the Administrator's 45-day review period.

[Rule 62-210.350, F.A.C.]

22. Administrative Permit Corrections.

(1) A facility owner shall notify the Department by letter of minor corrections to information contained in a permit. Such notifications shall include:

- (a) Typographical errors noted in the permit;
- (b) Name, address or phone number change from that in the permit;
- (c) Any other similar minor administrative change at the source; and,
- (d) A change requiring more frequent monitoring or reporting by the permittee.
- (e) Changes listed at 40 CFR 72.83(a)(1), (2), (6), (9) and (10), hereby adopted and incorporated by reference, to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o;
- (f) Changes listed at 40 CFR 72.83(a)(11), hereby adopted and incorporated by reference, to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o, provided the notification is accompanied by a copy of any EPA determination concerning the similarity of the change to those listed at Rule 17-210.360(1)(e).

(2) Upon receipt of such notifications the Department shall within 60 days correct the permit and provide a corrected copy to the owner.

(3) For facilities subject to Chapter 62-213, F.A.C., a copy shall be provided to EPA and any approved local air program in the county where the facility or any part of the facility is located.

(4) The Department shall incorporate requirements resulting from issuance of new or revised construction permits into existing operation permits issued pursuant to Chapter 62-213, F.A.C., if the construction permit revisions incorporate requirements of federally enforceable preconstruction review and if the applicant requests at the time of application that all of the requirements of Rule 62-213.430(1), F.A.C., be complied with in conjunction with the processing of the construction permit application.

[Rule 62-210.360, F.A.C.]

23. Reports.

(3) Annual Operating Report for Air Pollutant Emitting Facility.

- (a) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year.
- (c) The annual operating report shall be submitted to the appropriate Department District or Department approved local air pollution control program office by March 1 of the following year unless otherwise indicated by permit condition or Department request.

[Rule 62-210.370(3), F.A.C.]

24. Circumvention. No person shall circumvent any air pollution control device, or allow the emission of air pollutants without the applicable air pollution control device operating properly.

[Rule 62-210.650, F.A.C.]

25. Forms and Instructions. The forms used by the Department in the stationary source control program are adopted and incorporated by reference in this section. The forms are listed by rule number, which is also the form number, with the subject, title and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resources Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400.

(1) Application for Air Permit - Long Form, Form and Instructions.

- (a) Acid Rain Part (Phase II), Form and Instructions.
 - 1. Repowering Extension Plan, Form and Instructions.
 - 2. New Unit Exemption, Form and Instructions.
 - 3. Retired Unit Exemption, Form and Instructions.

(b) Reserved.

(5) Annual Operating Report (AOR) for Air Pollutant Emitting Facility, Form and Instructions.

[Rule 62-210.900, F.A.C.]

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

Chapter 62-213, F.A.C.

26. Annual Emissions Fee. Each Title V source permitted to operate in Florida must pay between January 15 and March 1 of each year, upon written notice from the Department, an annual emissions fee in accordance with Rule 62-213.205, F.A.C., and the appropriate form and associated instructions.

[Rules 62-213.205 and 62-213.900(1), F.A.C.]

27. Annual Emissions Fee. Failure to pay timely any required annual emissions fee, penalty, or interest constitutes grounds for permit revocation pursuant to Rule 62-4.100, F.A.C.

[Rule 62-213.205(1)(g), F.A.C.]

28. Annual Emissions Fee. Any documentation of actual hours of operation, actual material or heat input, actual production amount, or actual emissions used to calculate the annual emissions fee shall be retained by the owner for a minimum of five (5) years and shall be made available to the Department upon request.

[Rule 62-213.205(1)(j), F.A.C.]

29. Annual Emissions Fee. DEP Form 62-213.900(1), F.A.C., "Major Air Pollution Source Annual Emissions Fee Form", must be completed by the permittee and submitted with the annual emissions fee.

[Rule 62-213.205(4), F.A.C.]

30. Air Operation Permit Fees. After December 31, 1992, no permit application processing fee, renewal fee, modification fee or amendment fee is required for an operation permit for a Title V source.

[Rule 62-213.205(5), F.A.C.]

31. Permits and Permit Revisions Required. All Title V sources are subject to the permit requirements of Chapter 62-213, F.A.C.

[Rule 62-213.400, F.A.C.]

32. No Title V source may operate except in compliance with Chapter 62-213, F.A.C.

[Rule 62-213.400(1), F.A.C.]

33. Changes Without Permit Revision. Title V sources having a valid permit issued pursuant to Chapter 62-213, F.A.C., may make the following changes without permit revision, provided that sources shall maintain source logs or records to verify periods of operation in each alternative method of operation:

(1) Permitted sources may change among those alternative methods of operation allowed by the source's permit as provided by the terms of the permit;

(2) Permitted sources may implement the terms or conditions of a new or revised construction permit if;

(a) The application for construction permit complied with the requirements of Rule 62-213.420(3) and (4), F.A.C.;

(b) The terms or conditions were subject to federally enforceable preconstruction review pursuant to Chapter 62-212, F.A.C.; and,

(c) The new or revised construction permit was issued after the Department and the applicant complied with all the requirements of Rule 62-213.430(1), F.A.C.;

(3) A permitted source may implement operating changes after the source submits any forms required by any applicable requirement and provides the Department and EPA with at least 7 days written notice prior to implementation. The source and the Department shall attach each notice to the relevant permit;

(a) The written notice shall include the date on which the change will occur, and a description of the change within the permitted source, the pollutants emitted and any change in emissions, and any term or condition becoming applicable or no longer applicable as a result of the change;

(b) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes;

(4) Permitted sources may implement changes involving modes of operation only in accordance with Rule 62-213.415, F.A.C.

[Rule 62-213.410, F.A.C.]

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

34. Immediate Implementation Pending Revision Process.

(1) Those permitted Title V sources making any change that constitutes a modification pursuant to paragraph (a) of the definition of modification at Rule 62-210.200, F.A.C., but which would not constitute a modification pursuant to paragraph (b) of the same definition, may implement such change prior to final issuance of a permit revision in accordance with Rule 62-213.412, F.A.C., provided the change:

- (a) Does not violate any applicable requirement;
- (b) Does not contravene any permit term or condition for monitoring, testing, recordkeeping or reporting, or any compliance certification requirement;
- (c) Does not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapter 62-212 or 62-296, F.A.C.;
- (d) Does not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject including any federally enforceable emissions cap or federally enforceable alternative emissions limit.

(2) A Title V source may immediately implement such changes after they have been incorporated into the terms and conditions of a new or revised construction permit issued pursuant to Chapter 62-212, F.A.C., and after the source provides to EPA, the Department, each affected state and any approved local air program having geographic jurisdiction over the source, a copy of the source's application for operation permit revision. The Title V source may conform its application for construction permit to include all information required by Rule 62-213.420, F.A.C., in lieu of submitting separate application forms.

(3) The Department shall process the application for operation permit revision in accordance with the provisions of Chapter 62-213, F.A.C., except that the Department shall issue a draft permit revision or a determination to deny the revision within 60 days of receipt of a complete application for operation permit revision or, if the Title V source has submitted a construction permit application conforming to the requirements of Rule 62-213.420, F.A.C., the Department shall issue a draft permit or a determination to deny the revision at the same time the Department issues its determination on issuance or denial of the construction permit application. The Department shall not take final action until all the requirements of Rule 62-213.430(1)(a), (c), (d), and (e), F.A.C., have been complied with.

(4) Pending final action on the operation permit revision application, the source shall implement the changes in accordance with the terms and conditions of the source's new or revised construction permit.

(5) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes until after the Department takes final action to issue the operation permit revision.

(6) If the Department denies the source's application for operation permit revision, the source shall cease implementation of the proposed changes.

[Rule 62-213.412, F.A.C.]

35. Permit Applications.

(1) Duty to Apply. For each Title V source, the owner or operator shall submit a timely and complete permit application in compliance with the requirements of Rules 62-213.420, 62-4.050(1) & (2), and 62-210.900, F.A.C.

(a) Timely Application.

3. For purposes of permit renewal, a timely application is one that is submitted in accordance with Rule 62-4.090, F.A.C.

(b) Complete Application.

1. Any applicant for a Title V permit, permit revision or permit renewal must submit an application on DEP Form No. 62-210.900(1), which must include all the information specified by Rule 62-213.420(3), F.A.C., except that an application for permit revision must contain only that information related to the proposed change. The applicant shall include information concerning fugitive emissions and stack emissions in the application. Each application for permit, permit revision or permit renewal shall be certified by a responsible official in accordance with Rule 62-213.420(4), F.A.C.

2. For those applicants submitting initial permit applications pursuant to Rule 62-213.420(1)(a)1., F.A.C., a complete application shall be an application that substantially addresses all the information required by the application form number 62-210.900(1), and such applications shall be deemed complete within sixty days of receipt of a signed and certified application unless the Department notifies the applicant of incompleteness within that time. For all other applicants, the applications shall be deemed complete sixty days after receipt, unless the Department, within sixty days after receipt of a signed application for permit, permit revision or permit renewal, requests additional documentation or information needed to process the application. An applicant making timely and complete application for permit, or timely application for permit renewal as described by Rule 62-4.090(1), F.A.C., shall continue to operate the source

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

under the authority and provisions of any existing valid permit or Florida Electrical Power Plant Siting Certification, provided the applicant complies with all the provisions of Rules 62-213.420(1)(b)3. and 4. F.A.C. Failure of the Department to request additional information within sixty days of receipt of a properly signed application shall not impair the Department's ability to request additional information pursuant to Rules 62-213.420(1)(b)3. and 4., F.A.C.

3. For those permit applications submitted pursuant to the provisions of Rule 62-213.420(1)(a)1., F.A.C., the Department shall notify the applicant if the Department becomes aware at any time during processing of the application that the application contains incorrect or incomplete information. The applicant shall submit the corrected or supplementary information to the Department within ninety days unless the applicant has requested and been granted additional time to submit the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days or such additional time as requested and granted shall render the application incomplete.

4. For all applications other than those addressed at Rule 62-213.420(1)(b)3., F.A.C., should the Department become aware, during processing of any application that the application contains incorrect information, or should the Department become aware, as a result of comment from an affected State, an approved local air program, EPA, or the public that additional information is needed to evaluate the application, the Department shall notify the applicant within 30 days. When an applicant becomes aware that an application contains incorrect or incomplete information, the applicant shall submit the corrected or supplementary information to the Department. If the Department notifies an applicant that corrected or supplementary information is necessary to process the permit, and requests a response, the applicant shall provide the information to the Department within ninety days of the Department request unless the applicant has requested and been granted additional time to submit the information or, the applicant shall, within ninety days, submit a written request that the Department process the application without the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days, or such additional time as requested and granted, or to demand in writing within ninety days that the application be processed without the information shall render the application incomplete. Nothing in this section shall limit any other remedies available to the Department.

[Rules 62-213.420(1)(a)3. and 62-213.420(1)(b)1., 2., 3. & 4., F.A.C.]

36. Confidential Information. Whenever an applicant submits information under a claim of confidentiality pursuant to Section 403.111, F.S., the applicant shall also submit a copy of all such information and claim directly to EPA.

[Rule 62-213.420(2), F.A.C.]

37. Standard Application Form and Required Information. Applications shall be submitted under Chapter 62-213, F.A.C., on forms provided by the Department and adopted by reference in Rule 62-210.900(1), F.A.C. The information as described in Rule 62-210.900(1), F.A.C., shall be included for the Title V source and each emissions unit. An application must include information sufficient to determine all applicable requirements for the Title V source and each emissions unit and to evaluate a fee amount pursuant to Rule 62-213.205, F.A.C.

[Rule 62-213.420(3), F.A.C.]

38. Certification by Responsible Official (RO). In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

[Rule 62-213.420(4), F.A.C.]

39. a. Permit Renewal and Expiration. Permits being renewed are subject to the same requirements that apply to permit issuance at the time of application for renewal. Permit renewal applications shall contain that information identified in Rules 62-210.900(1) and 62-213.420(3), F.A.C. Unless a Title V source submits a timely application for permit renewal in accordance with the requirements of Rule 62-4.090(1), F.A.C., the existing permit shall expire and the source's right to operate shall terminate.

b. Permit Revision Procedures. Permit revisions shall meet all requirements of Chapter 62-213, F.A.C., including those for content of applications, public participation, review by approved local programs and affected states, and review by EPA, as they apply to permit issuance and renewal, except that permit revisions for those activities implemented pursuant to Rule 62-213.412, F.A.C., need not meet the requirements of Rule 62-213.430(1)(b), F.A.C. The Department shall require permit revision in accordance with the provisions of Rule 62-4.080, F.A.C., and 40 CFR 70.7(f), whenever any source becomes

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

subject to any condition listed at 40 CFR 70.7(f)(1), hereby adopted and incorporated by reference. The below requirements from 40 CFR 70.7(f) are adopted and incorporated by reference in Rule 62-213.430(4), F.A.C.:

o 40 CFR 70.7(f): Reopening for Cause.

(1) This section contains provisions from 40 CFR 70.7(f) that specify the conditions under which a Title V permit shall be reopened prior to the expiration of the permit. A Title V permit shall be reopened and revised under any of the following circumstances:

- (i) Additional applicable requirements under the Act become applicable to a major Part 70 source with a remaining permit term of 3 or more years. Such a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii).
- (ii) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approved by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
- (iii) The permitting authority or EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- (iv) The Administrator or the permitting authority determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

(2) Proceedings to reopen and issue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable.

(3) Reopenings under 40 CFR 70.7(f)(1) shall not be initiated before a notice of such intent is provided to the Part 70 source by the permitting authority at least 30 days in advance of the date that the permit is to be reopened, except that the permitting authority may provide a shorter time period in the case of an emergency.

[Rules 62-213.430(3) & (4), F.A.C.; and, 40 CFR 70.7(f)]

40. Insignificant Emissions Units or Pollutant-Emitting Activities.

(a) All requests for determination of insignificant emissions units or activities made pursuant to Rule 62-213.420(3)(m), F.A.C., shall be processed in conjunction with the permit, permit renewal or permit revision application submitted pursuant to Chapter 62-213, F.A.C. Insignificant emissions units or activities shall be approved by the Department consistent with the provisions of Rule 62-4.040(1)(b), F.A.C. Emissions units or activities which are added to a Title V source after issuance of a permit under Chapter 62-213, F.A.C., shall be incorporated into the permit at its next renewal, provided such emissions units or activities have been exempted from the requirement to obtain an air construction permit and also qualify as insignificant pursuant to Rule 62-213.430(6), F.A.C.

(b) An emissions unit or activity shall be considered insignificant if:

1. Such unit or activity would be subject to no unit-specific applicable requirement;
2. Such unit or activity, in combination with other units or activities proposed as insignificant, would not cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s); and
3. Such unit or activity would not emit or have the potential to emit:
 - a. 500 pounds per year or more of lead and lead compounds expressed as lead;
 - b. 1,000 pounds per year or more of any hazardous air pollutant;
 - c. 2,500 pounds per year or more of total hazardous air pollutants; or
 - d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C.]

41. Permit Duration. Operation permits for Title V sources may not be extended as provided in Rule 62-4.080(3), F.A.C., if such extension will result in a permit term greater than five (5) years.

[Rule 62-213.440(1)(a), F.A.C.]

42. Monitoring Information. All records of monitoring information shall specify the date, place, and time of sampling or measurement and the operating conditions at the time of sampling or measurement, the date(s) analyses were performed, the company or entity that performed the analyses, the analytical techniques or methods used, and the results of such analyses.

[Rule 62-213.440(1)(b)2.a., F.A.C.]

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

43. Retention of Records. Retention of records of all monitoring data and support information shall be for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

[Rule 62-213.440(1)(b)2.b., F.A.C.]

44. Monitoring Reports. The permittee shall submit reports of any required monitoring at least every six (6) months. All instances of deviations from permit requirements must be clearly identified in such reports.

[Rule 62-213.440(1)(b)3.a., F.A.C.]

45. Deviation from Permit Requirements Reports. The permittee shall report in accordance with the requirements of Rules 62-210.700(6) and 62-4.130, F.A.C., any deviations from permit requirements, including those attributable to upset conditions as defined in the permit. Reports shall include the probable cause of such deviations, and any corrective actions or preventive measures taken.

[Rule 62-213.440(1)(b)3.b., F.A.C.]

46. Reports. All reports shall be accompanied by a certification by a responsible official, pursuant to Rule 62-213.420(4), F.A.C.

[Rule 62-213.440(1)(b)3.c., F.A.C.]

47. If any portion of the final permit is invalidated, the remainder of the permit shall remain in effect.

[Rule 62-213.440(1)(d)1., F.A.C.]

48. It shall not be a defense for a permittee in an enforcement action that maintaining compliance with any permit condition would necessitate halting of or reduction of the source activity.

[Rule 62-213.440(1)(d)3., F.A.C.]

49. A Title V source shall comply with all the terms and conditions of the existing permit until the Department has taken final action on any permit renewal or any requested permit revision, except as provided at Rule 62-213.412(2), F.A.C.

[Rule 62-213.440(1)(d)4., F.A.C.]

50. A situation arising from sudden and unforeseeable events beyond the control of the source which causes an exceedance of a technology-based emissions limitation because of unavoidable increases in emissions attributable to the situation and which requires immediate corrective action to restore normal operation, shall be an affirmative defense to an enforcement action in accordance with the provisions and requirements of 40 CFR 70.6(g)(2) and (3), hereby adopted and incorporated by reference.

[Rule 62-213.440(1)(d)5., F.A.C.]

51. Confidentiality Claims. Any permittee may claim confidentiality of any data or other information by complying with Rule 62-213.420(2), F.A.C.

[Rule 62-213.440(1)(d)6., F.A.C.]

52. Statement of Compliance. The permittee shall submit a statement of compliance with all terms and conditions of the permit. Such statement shall be submitted to the Department and EPA annually, or more frequently if specified by Rule 62-213.440(2), F.A.C., or by any other applicable requirement. The statement of compliance shall include the identity of each term or condition of the permit for which each unit has remained in compliance during the period covered by the statement. The statement shall include identification of all methods used to demonstrate compliance and identification of each term or condition of the permit for which any unit has not remained in compliance during the period covered by the statement. For each term or condition for which the source has not remained in compliance during the period covered by the statement, the statement shall also identify each unit not in compliance and each term and condition with which the unit was not in compliance and state the inclusive dates that the source was not in compliance, the actions taken to achieve compliance and the method used to demonstrate compliance. Such statement shall be accompanied by a certification by a responsible official, in accordance with Rule 62-213.420(4), F.A.C.

[Rule 62-213.440(3), F.A.C.]

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

53. Permit Shield. Except as provided in Chapter 62-213, F.A.C., compliance with the terms and conditions of a permit issued pursuant to Chapter 62-213, F.A.C., shall be deemed compliance with any applicable requirements in effect as of the date of permit issuance, provided that the source included such applicable requirements in the permit application. Nothing in Rule 62-213.460, F.A.C., or in any permit shall alter or affect the ability of EPA or the Department to deal with an emergency, the liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance, or the requirements of the Federal Acid Rain Program.

[Rule 62-213.460, F.A.C.]

54. Forms and Instructions. The forms used by the Department in the Title V source operation program are adopted and incorporated by reference in Rule 62-213.900, F.A.C. The form is listed by rule number, which is also the form number, and with the subject, title, and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resources Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, or by contacting the appropriate permitting authority.

(1) Major Air Pollution Source Annual Emissions Fee (AEF) Form.

[Rule 62-213.900(1), F.A.C.]

Chapter 62-256, F.A.C.

55. **Not federally enforceable.** Open Burning. This permit does not authorize any open burning nor does it constitute any waiver of the requirements of Chapter 62-256, F.A.C. Source shall comply with Chapter 62-256, F.A.C., for any open burning at the source.

[Chapter 62-256, F.A.C.]

Chapter 62-281, F.A.C.

56. Refrigerant Requirements. Any facility having refrigeration equipment, including air conditioning equipment, which uses a Class I or II substance (listed at 40 CFR 82, Subpart A, Appendices A and B), and any facility which maintains, services, or repairs motor vehicles using a Class I or Class II substance as refrigerant must comply with all requirements of 40 CFR 82, Subparts B and F, and with Rule 62-281.100, F.A.C. Those requirements include the following restrictions:

- (1) Any facility having any refrigeration equipment normally containing 50 (fifty) pounds of refrigerant, or more, must keep servicing records documenting the date and type of all service and the quantity of any refrigerant added pursuant to 40 CFR 82.166;
- (2) No person repairing or servicing a motor vehicle may perform any service on a motor vehicle air conditioner (MVAC) involving the refrigerant for such air conditioner unless the person has been properly trained and certified as provided at 40 CFR 82.34 and 40 CFR 82.40, and properly uses equipment approved pursuant to 40 CFR 82.36 and 40 CFR 82.38, and complies with 40 CFR 82.42;
- (3) No person may sell or distribute, or offer for sale or distribution, any substance listed as a Class I or Class II substance at 40 CFR 82, Subpart A, Appendices A and B, except in compliance with Rule 62-281.100, F.A.C., and 40 CFR 82.34(b), 40 CFR 82.42, and/or 40 CFR 82.166;
- (4) No person maintaining, servicing, repairing, or disposing of appliances may knowingly vent or otherwise release into the atmosphere any Class I or Class II substance used as a refrigerant in such equipment and no other person may open appliances (except MVACs as defined at 40 CFR 82.152) for service, maintenance or repair unless the person has been properly trained and certified pursuant to 40 CFR 82.161 and unless the person uses equipment certified for that type of appliance pursuant to 40 CFR 82.158 and unless the person observes the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
- (5) No person may dispose of appliances (except small appliances, as defined at 40 CFR 82.152) without using equipment certified for that type of appliance pursuant to 40 CFR 82.158 and without observing the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
- (6) No person may recover refrigerant from small appliances, MVACs and MVAC-like appliances (as defined at 40 CFR 82.152), except in compliance with the requirements of 40 CFR 82, Subpart F.

[40 CFR 82; and, Chapter 62-281, F.A.C. (Chapter 62-281, F.A.C., is not federally enforceable)]

APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97) (continued)

Chapter 62-296, F.A.C.

57. **Not federally enforceable until SIP approved. Industrial, Commercial, and Municipal Open Burning Prohibited.** Open burning in connection with industrial, commercial, or municipal operations is prohibited, except when:

- (a) Open burning is determined by the Department to be the only feasible method of operation and is authorized by an air permit issued pursuant to Chapter 62-210 or 62-213, F.A.C.; or
- (b) An emergency exists which requires immediate action to protect human health and safety; or
- (c) A county or municipality would use a portable air curtain incinerator to burn yard trash generated by a hurricane, tornado, fire or other disaster and the air curtain incinerator would otherwise be operated in accordance with the permitting exemption criteria of Rule 62-210.300(3), F.A.C.

[Rule 62-296.320(3), F.A.C.]

58. **Unconfined Emissions of Particulate Matter.**

(4)(c)1. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any emissions unit whatsoever, including, but not limited to, vehicular movement, transportation of materials, construction, alteration, demolition or wrecking, or industrially related activities such as loading, unloading, storing or handling, without taking reasonable precautions to prevent such emission.

3. Reasonable precautions may include, but shall not be limited to the following:

- a. Paving and maintenance of roads, parking areas and yards.
- b. Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing.
- c. Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar emissions units.
- d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the emissions unit to prevent reentrainment, and from buildings or work areas to prevent particulate from becoming airborne.
- e. Landscaping or planting of vegetation.
- f. Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter.
- g. Confining abrasive blasting where possible.
- h. Enclosure or covering of conveyor systems.

4. In determining what constitutes reasonable precautions for a particular facility, the Department shall consider the cost of the control technique or work practice, the environmental impacts of the technique or practice, and the degree of reduction of emissions expected from a particular technique or practice.

[Rules 62-296.320(4)(c)1., 3., & 4. F.A.C.]

[electronic file name: tv-1.doc]

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)

Stack Sampling Facilities Provided by the Owner of an Emissions Unit. This section describes the minimum requirements for stack sampling facilities that are necessary to sample point emissions units. Sampling facilities include sampling ports, work platforms, access to work platforms, electrical power, and sampling equipment support. Emissions units must provide these facilities at their expense. All stack sampling facilities must meet any Occupational Safety and Health Administration (OSHA) Safety and Health Standards described in 29 CFR Part 1910, Subparts D and E.

(a) Permanent Test Facilities. The owner or operator of an emissions unit for which a compliance test, other than a visible emissions test, is required on at least an annual basis, shall install and maintain permanent stack sampling facilities.

(b) Temporary Test Facilities. The owner or operator of an emissions unit that is not required to conduct a compliance test on at least an annual basis may use permanent or temporary stack sampling facilities. If the owner chooses to use temporary sampling facilities on an emissions unit, and the Department elects to test the unit, such temporary facilities shall be installed on the emissions unit within 5 days of a request by the Department and remain on the emissions unit until the test is completed.

(c) Sampling Ports.

1. All sampling ports shall have a minimum inside diameter of 3 inches.

2. The ports shall be capable of being sealed when not in use.

3. The sampling ports shall be located in the stack at least 2 stack diameters or equivalent diameters downstream and at least 0.5 stack diameter or equivalent diameter upstream from any fan, bend, constriction or other flow disturbance.

4. For emissions units for which a complete application to construct has been filed prior to December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 15 feet or less. For stacks with a larger diameter, four sampling ports, each 90 degrees apart, shall be installed. For emissions units for which a complete application to construct is filed on or after December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 10 feet or less. For stacks with larger diameters, four sampling ports, each 90 degrees apart, shall be installed. On horizontal circular ducts, the ports shall be located so that the probe can enter the stack vertically, horizontally or at a 45 degree angle.

5. On rectangular ducts, the cross sectional area shall be divided into the number of equal areas in accordance with EPA Method 1. Sampling ports shall be provided which allow access to each sampling point. The ports shall be located so that the probe can be inserted perpendicular to the gas flow.

(d) Work Platforms.

1. Minimum size of the working platform shall be 24 square feet in area. Platforms shall be at least 3 feet wide.

2. On circular stacks with 2 sampling ports, the platform shall extend at least 110 degrees around the stack.

3. On circular stacks with more than two sampling ports, the work platform shall extend 360 degrees around the stack.

4. All platforms shall be equipped with an adequate safety rail (ropes are not acceptable), toeboard, and hinged floor-opening cover if ladder access is used to reach the platform. The safety rail directly in line with the sampling ports shall be removable so that no obstruction exists in an area 14 inches below each sample port and 6 inches on either side of the sampling port.

(e) Access to Work Platform.

APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)
(continued)

1. Ladders to the work platform exceeding 15 feet in length shall have safety cages or fall arresters with a minimum of 3 compatible safety belts available for use by sampling personnel.

2. Walkways over free-fall areas shall be equipped with safety rails and toeboards.

(f) Electrical Power.

1. A minimum of two 120-volt AC, 20-amp outlets shall be provided at the sampling platform within 20 feet of each sampling port.

2. If extension cords are used to provide the electrical power, they shall be kept on the plant's property and be available immediately upon request by sampling personnel.

(g) Sampling Equipment Support.

1. A three-quarter inch eyebolt and an angle bracket shall be attached directly above each port on vertical stacks and above each row of sampling ports on the sides of horizontal ducts.

a. The bracket shall be a standard 3 inch x 3 inch x one-quarter inch equal-legs bracket which is 1 and one-half inches wide. A hole that is one-half inch in diameter shall be drilled through the exact center of the horizontal portion of the bracket. The horizontal portion of the bracket shall be located 14 inches above the centerline of the sampling port.

b. A three-eighth inch bolt which protrudes 2 inches from the stack may be substituted for the required bracket. The bolt shall be located 15 and one-half inches above the centerline of the sampling port.

c. The three-quarter inch eyebolt shall be capable of supporting a 500 pound working load. For stacks that are less than 12 feet in diameter, the eyebolt shall be located 48 inches above the horizontal portion of the angle bracket. For stacks that are greater than or equal to 12 feet in diameter, the eyebolt shall be located 60 inches above the horizontal portion of the angle bracket. If the eyebolt is more than 120 inches above the platform, a length of chain shall be attached to it to bring the free end of the chain to within safe reach from the platform.

2. A complete monorail or dualrail arrangement may be substituted for the eyebolt and bracket.

3. When the sample ports are located in the top of a horizontal duct, a frame shall be provided above the port to allow the sample probe to be secured during the test.

[Rule 62-297.310(6), F.A.C.]

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers (version dated 02/05/97)

Abbreviations and Acronyms:

°F: Degrees Fahrenheit
BACT: Best Available Control Technology
CFR: Code of Federal Regulations
DEP: State of Florida, Department of Environmental Protection
DARM: Division of Air Resource Management
EPA: United States Environmental Protection Agency
F.A.C.: Florida Administrative Code
F.S.: Florida Statute
ISO: International Standards Organization
LAT: Latitude
LONG: Longitude
MMBtu: million British thermal units
MW: Megawatt
ORIS: Office of Regulatory Information Systems
SOA: Specific Operating Agreement
UTM: Universal Transverse Mercator

Citations:

The following examples illustrate the methods used in this permit to abbreviate and cite the references of rules, regulations, guidance memorandums, permit numbers, and ID numbers.

Code of Federal Regulations:

Example: [40 CFR 60.334]

Where:	40	reference to	Title 40
	CFR	reference to	Code of Federal Regulations
	60	reference to	Part 60
	60.334	reference to	Regulation 60.334

Florida Administrative Code (F.A.C.) Rules:

Example: [Rule 62-213, F.A.C.]

Where:	62	reference to	Title 62
	62-213	reference to	Chapter 62-213
	62-213.205	reference to	Rule 62-213.205, F.A.C.

ISO: International Standards Organization refers to those conditions at 288 degrees K, 60 percent relative humidity, and 101.3 kilopascals pressure.

**Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers
(version dated 02/05/97) (continued)**

Identification Numbers:

Facility Identification (ID) Number:

Example: Facility ID No.: 1050221

Where:

105 = 3-digit number code identifying the facility is located in Polk County
0221 = 4-digit number assigned by state database.

Permit Numbers:

Example: 1050221-002-AV, or
1050221-001-AC

Where:

AC = Air Construction Permit
AV = Air Operation Permit (Title V Source)
105 = 3-digit number code identifying the facility is located in Polk County
0221 = 4-digit number assigned by permit tracking database
001 or 002 = 3-digit sequential project number assigned by permit tracking database

Example: PSD-FL-185
PA95-01
AC53-208321

Where:

PSD = Prevention of Significant Deterioration Permit
PA = Power Plant Siting Act Permit
AC = old Air Construction Permit numbering

TABLE 297.310-1 CALIBRATION SCHEDULE
(version dated 10/07/96)

[Note: This table is referenced in Rule 62-297.310, F.A.C.]

ITEM	MINIMUM CALIBRATION FREQUENCY	REFERENCE INSTRUMENT	TOLERANCE
Liquid in glass thermometer	Annually	ASTM Hg in glass ref. thermometer or equivalent, or thermometric points	+/-2%
Bimetallic thermometer	Quarterly	Calib. liq. in glass thermometer	5 degrees F
Thermocouple	Annually	ASTM Hg in glass ref. thermometer, NBS calibrated reference and potentiometer	5 degrees F
Barometer	Monthly	Hg barometer or NOAA station	+/-1% scale
Pitot Tube	When required or when damaged	By construction or measurements in wind tunnel D greater than 16" and standard pitot tube	See EPA Method 2, Fig. 2-2 & 2-3
Probe Nozzles	Before each test or when nicked, dented, or corroded	Micrometer	+/-0.001" mean of at least three readings Max. deviation between readings .004"
Dry Gas Meter and Orifice Meter	1. Full Scale: When received, When 5% change observed, Annually 2. One Point: Semiannually 3. Check after each test series	Spirometer or calibrated wet test or dry gas test meter	2%
		Comparison check	5%

[electronic file name: 297310-1.doc]

FIGURE 1--SUMMARY REPORT--GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE (version dated 7/96)

[Note: This form is referenced in 40 CFR 60.7, Subpart A-General Provisions]

Pollutant (*Circle One*): SO₂ NO_x TRS H₂S CO Opacity

Reporting period dates: From _____ to _____

Company: _____

Emission Limitation: _____

Address: _____

Monitor Manufacturer: _____

Model No.: _____

Date of Latest CMS Certification or Audit: _____

Process Unit(s) Description: _____

Total source operating time in reporting period ¹: _____

Emission data summary ¹	CMS performance summary ¹
1. Duration of excess emissions in reporting period due to:	1. CMS downtime in reporting period due to:
a. Startup/shutdown	a. Monitor equipment malfunctions
b. Control equipment problems	b. Non-Monitor equipment malfunctions
c. Process problems	c. Quality assurance calibration
d. Other known causes	d. Other known causes
e. Unknown causes	e. Unknown causes
2. Total duration of excess emissions	2. Total CMS Downtime
3. Total duration of excess emissions x (100) / [Total source operating time] % ²	3. [Total CMS Downtime] x (100) / [Total source operating time] % ²

¹ For opacity, record all times in minutes. For gases, record all times in hours.

² For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in 40 CFR 60.7(c) shall be submitted.

Note: On a separate page, describe any changes since last quarter in CMS, process or controls.

I certify that the information contained in this report is true, accurate, and complete.

Name: _____

Signature: _____ Date: _____

Title: _____

Phase II Permit Application

For more information, see instructions and refer to 40 CFR 72.30 and 72.31 and Chapter 62-214, F.A.C.

This submission is: New Revised

STEP 1
Identify the source by plant name, State, and ORIS code from NADB

C.D. McIntosh, Jr., FL, 676

STEP 2
Enter the boiler ID# from NADB for each affected unit, and indicate whether a repowering plan is being submitted for the unit by entering "yes" or "no" at column c. For new units, enter the requested information in columns d and e

Compliance Plan				
a	b	c	d	e
Boiler ID#	Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1)	Repowering Plan	New Units Commence Operation Date	New Units Monitor Certification Deadline
1	Yes	No		
2	Yes	No		
3	Yes	No		
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			

STEP 3
Check the box if the response in column c of Step 2 is "Yes" for any unit

For each unit that will be repowered, the Repowering Extension Plan form is included and the Repowering Technology Petition form has been submitted or will be submitted by June 1, 1997.

Plant Name (from Step 1)
C.D. McIntosh, Jr.

STEP 4
Read the standard requirements and certification, enter the name of the designated representative, and sign and date

Standard Requirements

Permit Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Submit a complete Acid Rain part application (including a compliance plan) under 40 CFR part 72, Rules 62-214.320 and 330, F.A.C. in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain part application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain part application or a superseding Acid Rain part issued by the permitting authority; and
 - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
 - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
 - (ii) All emissions monitoring information, in accordance with 40 CFR part 75;
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

Plant Name (from Step 1)
C.D. McIntosh, Jr.

Recordkeeping and Reporting Requirements (cont.)

(iv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability.

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.

(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.

(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

(4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.

(5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.

(6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.

(7) Each violation of a provision of 40 CFR parts 72, 73, 75, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities. No provision of the Acid Rain Program, an Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;

(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,

(5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name <i>Timothy C. Bates, Plant Manager</i>	
Signature <i>Timothy C Bates</i>	Date <i>12/14/95</i>

STEP 5 (optional)
Enter the source AIRS
and FINDS identification
numbers, if known

AIRS
FINDS

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

In the matter of:)

Florida Electric Power Coordinating Group, Inc.,)

ASP No. 97-B-01

Petitioner.)

ORDER ON REQUEST
FOR
ALTERNATE PROCEDURES AND REQUIREMENTS

Pursuant to Rule 62-297.620, Florida Administrative Code (F.A.C.), the Florida Electric Coordinating Group, Incorporated, (FCG) petitioned for approval to: (1) Exempt fossil fuel steam generators which burn liquid and/or solid fuel for less than 400 hours during the federal fiscal year from the requirement to conduct an annual particulate matter compliance test; and, (2) Exempt fossil fuel steam generators which burn liquid and/or solid fuel for less than 400 hours during the federal fiscal year from the requirement to conduct an annual particulate matter compliance test during the year prior to renewal of an operation permit. This Order is intended to clarify particulate testing requirements for those fossil fuel steam generators which primarily burn gaseous fuels including, but not necessarily limited to natural gas.

Having considered the provisions of Rule 62-296.405(1), F.A.C., Rule 62-297.310(7), F.A.C., and all supporting documentation, the following Findings of Fact; Conclusions of Law, and Order are entered:

FINDINGS OF FACT

1. The Florida Electric Power Coordinating Group, Incorporated, petitioned the Department to exempt those fossil fuel steam generators which have a heat input of more than 250 million Btu per hour and burn solid and/or liquid fuel less than 400 hours during the year from the requirement to conduct an annual particulate matter compliance test. [Exhibit 1]

2. Rule 62-296.405(1)(a), F.A.C., applies to those fossil fuel steam generators that are not subject to the federal standards of performance for new stationary sources (NSPS) in 40 CFR 60 and which have a heat input of more than 250 million Btu per hour.

3. Rule 62-296.405(1)(a), F.A.C., limits visible emissions from affected fossil fuel steam generators to, "20 percent opacity except for either one six-minute period per hour during which

Best Available Copy

not exceed 40 percent. The option selected shall be specified in the emissions unit's construction and operation permits. Emissions units governed by this visible emission limit shall test for particulate emission compliance annually and as otherwise required by Rule 62-297, F.A.C."

4. Rule 62-296.405(1)(a), F.A.C., further states, "Emissions units electing to test for particulate matter emission compliance quarterly shall be allowed visible emissions of 40 percent opacity. The results of such tests shall be submitted to the Department. Upon demonstration that the particulate standard has been regularly complied with, the Secretary, upon petition by the applicant, shall reduce the frequency of particulate testing to no less than once annually."

5. Rule 297.310(7)(a)1., F.A.C., states, "The owner or operator of a new or modified emissions unit that is subject to an emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining an operation permit for such emissions unit."

6. Rule 297.310(7)(a)2., F.A.C., states, "The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision."

7. Rule 297.310(7)(a)3., F.A.C., further states, "In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal: a. Did not operate; or, b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours."

8. Rule 297.310(7)(a)4., F.A.C., states, "During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for: a. Visible emissions, if there is an applicable standard; b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant..."

9. Rule 297.310(7)(a)5., F.A.C., states, "An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours."

10. Rule 297.310(7)(a)6., F.A.C., states, "For fossil fuel steam generators on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be

required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup.”

11. Rule 297.310(7)(a)7., F.A.C., states, “For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to Rule 62-296.405(2)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup.” [Note: The reference should be to Rule 62-296.405(1)(a), F.A.C., rather than Rule 62-296.405(2)(a), F.A.C.]

12. The fifth edition of the U. S. Environmental Protection Agency’s Compilation of Air Pollutant Emission Factors, AP-42, that emissions of filterable particulate from gas-fired fossil fuel steam generators with a heat input of more than about 10 million Btu per hour may be expected to range from 0.001 to 0.006 pound per million Btu. [Exhibit 2]

13. Rule 62-296.405(1)(b), F.A.C. and the federal standards of performance for new stationary sources in 40 CFR 60.42, Subpart D, limit particulate emissions from uncontrolled fossil fuel fired steam generators with a heat input of more than 250 million Btu to 0.1 pound per million Btu.

CONCLUSIONS OF LAW

1. The Department has jurisdiction to consider the matter pursuant to Section 403.061, Florida Statutes (F.S.), and Rule 62-297.620, F.A.C.

2. Pursuant to Rule 62-297.310(7), F.A.C., the Department may require Petitioner to conduct compliance tests that identify the nature and quantity of pollutant emissions, if, after investigation, it is believed that any applicable emission standard or condition of the applicable permits is being violated.

3. There is reason to believe that a fossil fuel steam generator which does not burn liquid and/or solid fuel (other than during startup) for a total of more than 400 hours in a federal fiscal year and complies with all other applicable limits and permit conditions is in compliance with the applicable particulate mass emission limiting standard.

ORDER

Having considered the requirements of Rule 62-296.405, F.A.C., Rule 62-297.310, F.A.C., and supporting documentation, it is hereby ordered that:

1. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours;

2. For fossil fuel steam generators on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup;

3. For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to Rule 62-296.405(1)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup;

4. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of particulate matter emission compliance test results for any fossil fuel steam generator emissions unit that burned liquid and/or solid fuel for a total of no more than 400 hours during the year prior to renewal.

5. Pursuant to Rule 62-297.310(7), F.A.C., owners of affected fossil fuel steam generators may be required to conduct compliance tests that identify the nature and quantity of pollutant emissions, if, after investigation, it is believed that any applicable emission standard or condition of the applicable permits is being violated.

6. Pursuant to Rule 62-297.310(8), F.A.C., owners of affected fossil fuel steam generators shall submit the compliance test report to the District Director of the Department district office having jurisdiction over the emissions unit and, where applicable, the Air Program Administrator of the appropriate Department-approved local air program within 45 days of completion of the test.

PETITION FOR ADMINISTRATIVE REVIEW

The Department will take the action described in this Order unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 of the Florida Statutes, or a party requests mediation as an alternative remedy under section 120.573 before the deadline for filing a petition. Choosing mediation will not adversely affect the right to a hearing if mediation does not result in a settlement. The procedures for petitioning for a hearing are set forth below, followed by the procedures for requesting mediation.

A person whose substantial interests are affected by the Department's proposed decision may petition for an administrative hearing in accordance with sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. Petitions must be filed within 21 days of receipt of this Order. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition (or a request for mediation, as discussed below) within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of

the Florida Statutes, or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-5.207 of the Florida Administrative Code.

A petition must contain the following information:

(a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department File Number, and the county in which the project is proposed;

(b) A statement of how and when each petitioner received notice of the Department's action or proposed action;

(c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;

(d) A statement of the material facts disputed by each petitioner, if any;

(e) A statement of facts that the petitioner contends warrant reversal or modification of the Department's action or proposed action;

(f) A statement identifying the rules or statutes each petitioner contends require reversal or modification of the Department's action or proposed action; and,

(g) A statement of the relief sought by each petitioner, stating precisely the action each petitioner wants the Department to take with respect to the Department's action or proposed action in the notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A person whose substantial interests are affected by the Department's proposed decision, may elect to pursue mediation by asking all parties to the proceeding to agree to such mediation and by filing with the Department a request for mediation and the written agreement of all such parties to mediate the dispute. The request and agreement must be filed in (received by) the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000, by the same deadline as set forth above for the filing of a petition.

A request for mediation must contain the following information:

Best Available Copy

(a) The name, address, and telephone number of the person requesting mediation and that person's representative, if any;

(b) A statement of the preliminary agency action;

(c) A statement of the relief sought; and

(d) Either an explanation of how the requester's substantial interests will be affected by the action or proposed action addressed in this notice of intent or a statement clearly identifying the petition for hearing that the requester has already filed, and incorporating it by reference.

The agreement to mediate must include the following:

(a) The names, addresses, and telephone numbers of any persons who may attend the mediation;

(b) The name, address, and telephone number of the mediator selected by the parties, or a provision for selecting a mediator within a specified time;

(c) The agreed allocation of the costs and fees associated with the mediation;

(d) The agreement of the parties on the confidentiality of discussions and documents introduced during mediation;

(e) The date, time, and place of the first mediation session, or a deadline for holding the first session, if no mediator has yet been chosen;

(f) The name of each party's representative who shall have authority to settle or recommend settlement; and

(g) The signatures of all parties or their authorized representatives.

As provided in section 120.573 of the Florida Statutes, the timely agreement of all parties to mediate will toll the time limitations imposed by sections 120.569 and 120.57 for requesting and holding an administrative hearing. Unless otherwise agreed by the parties, the mediation must be concluded within sixty days of the execution of the agreement. If mediation results in settlement of the administrative dispute, the Department must enter a final order incorporating the agreement of the parties. Persons whose substantial interests will be affected by such a modified final decision of the Department have a right to petition for a hearing only in accordance with the requirements for such petitions set forth above. If mediation terminates without settlement of the dispute, the Department shall notify all parties in writing that the administrative hearing processes under sections 120.569 and 120.57 remain available for disposition of the dispute, and the notice will

Best Available Copy

specify the deadlines that then will apply for challenging the agency action and electing remedies under those two statutes.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under section 120.542 of the Florida Statutes. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

The petition must specify the following information:

- (a) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
- (c) Each rule or portion of a rule from which a variance or waiver is requested;
- (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
- (e) The type of action requested;
- (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and
- (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver, when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner. Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully

each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner. Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.


This Order constitutes final agency action unless a petition is filed in accordance with the above paragraphs. Upon timely filing of a petition, this Order will not be effective until further Order of the Department.

RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed with the Clerk of the Department.

DONE AND ORDERED this 17 day of March, 1997 in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



HOWARD L. RHODES, Director
Division of Air Resources Management
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
(904) 488-0114

CERTIFICATE OF SERVICE

The undersigned duly designated deputy clerk hereby certifies that a copy of the foregoing was mailed to Rich Piper, Chair, Florida Power Coordinating Group, Inc., 405 Reo Street, Suite 100, Tampa, Florida 33609-1004, on this 18th day of March 1997.

Clerk Stamp

FILING AND ACKNOWLEDGMENT
FILED, on this date, pursuant to
§120.52(7), Florida Statutes, with the
designated Department Clerk, receipt of
which is hereby acknowledged.

Martha M. Wise 3-18-97
Clerk Date



January 28, 1997

Clair H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
2600 Blair Stone Road, MS 5505
Tallahassee, FL 32301

RECEIVED

JAN 28 1997

BUREAU OF
AIR REGULATION

RE: Comments Regarding Draft Title V Permits

Dear Mr. Fancy:

The Florida Electric Power Coordinating Group, Inc. (FCG), which is made up of 36 utilities owned by investors, municipalities, and cooperatives, has been following the implementation of Title V in Florida and recently submitted comments to you on draft Title V permit conditions by letter dated December 4, 1996. As indicated in that letter, representatives from the FCG would like to meet with you and other members of your air permitting staff to discuss some significant concerns that FCG member companies have regarding conditions that may be included in Title V permits issued by your office. While we will be discussing these issues with you and your staff in greater detail at that meeting, we would like to explain some of our concerns in this letter.

Primarily, the FCG members are concerned that the Title V permits may contain conditions that are much different in important respects than those conditions currently included in existing air permits. During the rulemaking workshops and seminars conducted by the Department to discuss the rules implementing the Title V permitting program, representations were made on several occasions that industry could expect to see permit conditions that were substantively similar to existing permit conditions and that primarily the format was changing. Representations were also made to industry that Title V did not impose additional substantive requirements beyond what was already required under the Department's rules. Based on the first draft Title V permit that we have reviewed, we are concerned that there may be some attempt to change the substantive requirements on existing facilities through the Title V permitting process, and we would like to discuss this with you at the meeting we have scheduled for January 30, 1997.

1. Federal Enforceability--The FCG has long been concerned about the designation of non-federally enforceable permit terms and conditions. We are concerned about this issue because the Department's first draft Title V permits have included language stating that *all* terms and conditions would become federally enforceable once the permit is issued. This approach is consistent with the Department's guidance memorandum dated September 13, 1996 (DARM-PER/V-18), but we understand that the Department may now intend to remove all references to

Best Available Copy

Clair H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
January 28, 1997
Page 2

the federal enforceability of permit terms and conditions. We are also concerned about this approach because a Title V permit is generally federally enforceable and, without any designation of non-federally enforceable terms and conditions, the entire permit could be interpreted to be federally enforceable. As we stated in the December 4 letter as well as our letter dated October 11, 1996, all terms and conditions in a Title V permit do *not* become enforceable by the U.S. Environmental Protection Agency and citizens under the Clean Air Act simply by inclusion in a Title V permit. To make it clear which provisions in a Title V permit are not federally enforceable (which are being included because of state or local requirements only), it is very important to specifically designate those conditions as having no federally enforceable basis. Such a designation is actually required under the federal Title V rules, which provide that permitting agencies are to "specifically designate as not being federally enforceable under the Act any terms and conditions included in the permit that are not required under the Act or under any of its applicable requirements." 40 CFR § 70.6(b). We would like to discuss with you our concerns about this issue and to again specifically request that when Title V permits are issued by the Department, conditions having no federally enforceable basis clearly be identified as such.

2. PM Testing on Gas--The FCG understands that the Department may attempt to require annual particulate matter compliance testing while firing natural gas to determine compliance with the 0.1 lb/mmBtu emission limit established under Rule 62-296.405(1)(b), F.A.C. The FCG member companies feel strongly that compliance testing for particulate matter should not be required while firing natural gas. The Department has not historically required particulate matter compliance testing while firing natural gas, it is not required under the current permits for these units, and it should not be necessary since natural gas is such a clean fuel. Typically only *de minimis* amounts of particulate matter would be expected from the firing of natural gas, so compliance testing would not provide meaningful information to the Department, and the expense to conduct such tests is not justified. We understand that Department representatives suggested that industry could pursue an alternative test procedure under Rule 62-297.620, F.A.C., to allow a visible emissions test to be used in lieu of a stack test for determining compliance with the particulate matter limit. While certainly a visible emissions test would be preferable over a stack test, neither of these tests should be needed to demonstrate compliance with the particulate matter limit of 0.1 lb/mmBtu while burning natural gas. The FCG strongly urges that the Department reconsider its position on this issue and clarify that compliance testing for particulate matter while firing natural gas is not required.

3. Excess Emissions--By letter dated December 5, 1996, the U.S. Environmental Protection Agency (EPA) submitted a letter commenting on a draft Title V permit that had been issued by the Department and indicated some concern regarding excess emission provisions included in conditions that were quoted from Rule 62-210.700, F.A.C. Because the permit conditions cited simply quote the applicable provisions of the Department's rules regarding

Best Available Copy

Clair H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
January 28, 1997
Page 3

excess emissions and because these rules have been approved as part of Florida's State Implementation Plan, the permit conditions are appropriate to be included in the permit. We understand that the Department intends to include as applicable requirements in Title V permit conditions the provisions of Rule 62-210.700, F.A.C. If the Department receives any further adverse comments regarding the excess emissions rule under 62-210.700, F.A.C., we would appreciate your contacting us. Because this issue is so important to us, we would like to discuss it with you in greater detail at our meeting on January 30.

4. Compliance Testing for Combustion Turbines--While the Department's November 22, 1995, guidance regarding the compliance testing requirements for combustion turbines clearly states that the use of heat input curves based on ambient temperatures and humidities is to be included as a permit condition *only* if requested by a permittee, we understand that the Department may intend to include this requirement in Title V permits for all combustion turbines. As we are sure you recall, the FCG worked over a period of several months with the Department on the development of the guidance memorandum and it was clearly understood by FCG members that the heat input curves would not be mandated but would remain voluntary for any existing combustion turbine. It was also understood by FCG members that the requirement to conduct testing at 95 to 100 percent of capacity would be required only if the permit applicant requested the use of heat input curves. We understand that the Department may be interpreting the requirement to use heat input curves and to test at 95 to 100 percent of permitted capacity to be mandatory for all combustion turbines. We would like to clarify this with you during our meeting. Also, we would like to confirm that, regardless of whether a combustion turbine uses heat input curves or tests at 95 to 100 percent of permitted capacity, it is necessary to test at four load points and correct to ISO *only* to determine compliance with the nitrogen oxides (NOx) standard under New Source Performance Standard Subpart GG under 40 CFR § 60.532 and not annually thereafter.

5. Test Methods--The FCG is concerned about the possibility of the Department requiring a full permit revision to authorize the use of an approved test method not specifically identified in a Title V permit, even though the Department may have separately approved the use of the particular test method for a unit (i.e., through a compliance test protocol). It is the FCG's position that language should be included in all Title V permits indicating that other test methods approved by the Department may be used. Further, a full permit revision (including public notice) should *not* be necessary when a test method not previously identified in the permit is approved for use by a unit. The Department's subsequent approval of test methods should simply be included in the next permit renewal cycle. The FCG understands that the Department planned to confirm this approach with the U.S. Environmental Protection Agency Region IV, and we would like to discuss this issue with you at the January 30 meeting to learn of the agency's response.

Best Available Copy

Clair H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
January 28, 1997
Page 4

6. Quarterly Reports--The FCG understands that the Department may be interpreting the quarterly reporting requirements under Rule 62-296.405(1)(g), F.A.C., to apply regardless of whether continuous emissions monitors were required under the preceding Rule 62-296.405(1)(f), F.A.C. It is the FCG's position that quarterly reports are required under Rule 62-296.405(1)(g) only when continuous emissions monitors are required under the preceding paragraph (f). While this may not be entirely clear from the language of the rules, paragraphs (f) and (g) were originally included in a separate rule on "continuous emission monitoring requirements" where it was very clear that the requirements of paragraph (g) applied *only* if continuous emission monitoring was required under paragraph (f). Research indicates that Rule 17-2.710, F.A.C. (copy attached), where these provisions were originally located, was first transferred to Rule 17-297.500, F.A.C. (which later became Rule 62-297.500), later repealed in November of 1994, and ultimately replaced with what is now Rule 62-296.405(1)(f) and (g), F.A.C. To the extent that an emissions unit is not subject to Rule 62-296.405(1)(f) and is not required to install and operate continuous emissions monitors (e.g., oil- and gas-fired units), the quarterly reporting requirements of paragraph (g) should not apply.

7. Trivial Activities--As you may recall, in May of 1996, the FCG submitted to the Department a list of small, *de minimis* emissions units and activities that it considered to be "trivial," consistent with the list developed by EPA as part of the Title V "White Paper" and incorporated by reference by the Department in its March 15, 1996, guidance memorandum (DARM-PER/V-15-Revised). We never received a response from the Department and now understand that the Department may not have made a determination as to whether any of the emission units or activities on the list should qualify as "trivial." This is an important issue to the FCG because only "trivial" activities can be omitted from the Title V permit application and permit, and ultimately omitted from emission estimates in the annual air operation reports under Rule 62-210.370(3), F.A.C. The FCG remains hopeful that the Department will consider its request to determine that most, if not all, of the emission units and activities on the May, 1996, list to be "trivial." We would like to discuss a possible resolution of this issue with you and your staff at the January 30 meeting.

8. Permit Shield--The FCG continues to be concerned about the language in Conditions 5 and 20 of Appendix TV-1, Title V Conditions, which circumvents the permit shield provisions under Section 403.0872(15), Florida Statutes, and Rule 62-215.460, F.A.C. The FCG believes that these conditions should be deleted in their entirety. To the extent that the Department attempt to caveat the applicability of those conditions, the FCG believes that it is important to cite to not only the regulatory citation for the permit shield but the statutory citation as well.

Thank you again for considering the FCG's comments on the draft Title V permits. We very much appreciate the cooperation we have received from the Department throughout the


Best Available Copy

Clair H. Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
January 28, 1997
Page 5

Title V implementation process, and we look forward to our meeting later this week. If you have any questions in the meantime, please call me at 561-625-7661.

Sincerely,

Rich Piper

Rich Piper, Chair 
FCG Air Subcommittee

Enclosures

cc: Howard L. Rhodes, DEP
John Brown, DEP
Pat Comer, DEP OGC
Scott M. Sheplak, DEP
Edward Svec, DEP
FCG Air Subcommittee
Angela Morrison, HGSS

53601

AP-42
FIFTH EDITION
JANUARY 1995

COMPILATION
OF
AIR POLLUTANT
EMISSION FACTORS

VOLUME I:
STATIONARY POINT
AND AREA SOURCES

Office Of Air Quality Planning And Standards
Office Of Air And Radiation
U. S. Environmental Protection Agency
Research Triangle Park, NC 27711

January 1995

Exhibit 2

1.4 Natural Gas Combustion

1.4.1 General¹⁻²

Natural gas is one of the major fuels used throughout the country. It is used mainly for industrial process steam and heat production; for residential and commercial space heating; and for electric power generation. Natural gas consists of a high percentage of methane (generally above 80 percent) and varying amounts of ethane, propane, butane, and inerts (typically nitrogen, carbon dioxide, and helium). Gas processing plants are required for the recovery of liquefiable constituents and removal of hydrogen sulfide before the gas is used (see Section 5.3, Natural Gas Processing). The average gross heating value of natural gas is approximately 8900 kilocalories per standard cubic meter (1000 British thermal units per standard cubic foot), usually varying from 8000 to 9800 kcal scm (900 to 1100 Btu/scf).

1.4.2 Emissions And Controls³⁻⁵

Even though natural gas is considered to be a relatively clean-burning fuel, some emissions can result from combustion. For example, improper operating conditions, including poor air/fuel mixing, insufficient air, etc., may cause large amounts of smoke, carbon monoxide (CO), and organic compound emissions. Moreover, because a sulfur-containing mercaptan is added to natural gas to permit leak detection, small amounts of sulfur oxides will be produced in the combustion process.

Nitrogen oxides (NO_x) are the major pollutants of concern when burning natural gas. Nitrogen oxide emissions depend primarily on the peak temperature within the combustion chamber as well as the furnace-zone oxygen concentration, nitrogen concentration, and time of exposure at peak temperatures. Emission levels vary considerably with the type and size of combustor and with operating conditions (particularly combustion air temperature, load, and excess air level in boilers).

Currently, the two most prevalent NO_x control techniques being applied to natural gas-fired boilers (which result in characteristic changes in emission rates) are low NO_x burners and flue gas recirculation. Low NO_x burners reduce NO_x by accomplishing the combustion process in stages. Staging partially delays the combustion process, resulting in a cooler flame which suppresses NO_x formation. The three most common types of low NO_x burners being applied to natural gas-fired boilers are staged air burners, staged fuel burners, and radiant fiber burners. Nitrogen oxide emission reductions of 40 to 85 percent (relative to uncontrolled emission levels) have been observed with low NO_x burners. Other combustion staging techniques which have been applied to natural gas-fired boilers include low excess air, reduced air preheat, and staged combustion (e. g., burners-out-of-service and overfire air). The degree of staging is a key operating parameter influencing NO_x emission rates for these systems.

In a flue gas recirculation (FGR) system, a portion of the flue gas is recycled from the stack to the burner windbox. Upon entering the windbox, the gas is mixed with combustion air prior to being fed to the burner. The FGR system reduces NO_x emissions by two mechanisms. The recycled flue gas is made up of combustion products which act as inerts during combustion of the fuel/air mixture. This additional mass is heated in the combustion zone, thereby lowering the peak flame temperature and reducing the amount of NO_x formed. To a lesser extent, FGR also reduces NO_x formation by lowering the oxygen concentration in the primary flame zone. The amount of flue gas recirculated is a key operating parameter influencing NO_x emission rates for these systems. Flue gas

Best Available Copy

recirculation is normally used in combination with low NO_x burners. When used in combination, these techniques are capable of reducing uncontrolled NO_x emissions by 60 to 90 percent.

Two post-combustion technologies that may be applied to natural gas-fired boilers to reduce NO_x emissions by further amounts are selective noncatalytic reduction and selective catalytic reduction. These systems inject ammonia (or urea) into combustion flue gases to reduce inlet NO_x emission rates by 40 to 70 percent.

Although not measured, all particulate matter (PM) from natural gas combustion has been estimated to be less than 1 micrometer in size. Particulate matter is composed of filterable and condensable fractions, based on the EPA sampling method. Filterable and condensable emission rates are of the same order of magnitude for boilers; for residential furnaces, most of the PM is in the form of condensable material.

The rates of CO and trace organic emissions from boilers and furnaces depend on the efficiency of natural gas combustion. These emissions are minimized by combustion practices that promote high combustion temperatures, long residence times at those temperatures, and turbulent mixing of fuel and combustion air. In some cases, the addition of NO_x control systems such as FGR and low NO_x burners reduces combustion efficiency (due to lower combustion temperatures), resulting in higher CO and organic emissions relative to uncontrolled boilers.

Emission factors for natural gas combustion in boilers and furnaces are presented in Tables 1.4-1, 1.4-2, and 1.4-3.⁶ For the purposes of developing emission factors, natural gas combustors have been organized into four general categories: utility/large industrial boilers, small industrial boilers, commercial boilers, and residential furnaces. Boilers and furnaces within these categories share the same general design and operating characteristics and hence have similar emission characteristics when combusting natural gas. The primary factor used to demarcate the individual combustor categories is heat input.

Best Available Copy

Table 1.4-1 (Metric and English Units). EMISSION FACTORS FOR PARTICULATE MATTER (PM) FROM NATURAL GAS COMBUSTION^a

Combustor Type (Size, 10 ⁶ Btu/hr Heat Input) (SCC) ^b	Filterable PM ^c			Condensable PM ^d		
	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	RATING	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	RATING
Utility/large industrial boilers (> 100) (1-01-006-01, 1-01-006-04)	16 - 80	1 - 5	B	ND	ND	NA
Small industrial boilers (10 - 100) (1-02-006-02)	99	6.2	B	120	7.5	D
Commercial boilers (0.3 - < 10) (1-03-006-03)	72	4.5	C	120	7.5	C
Residential furnaces (< 0.3) (No SCC)	2.8	0.18	C	180	11	D

^a References 9-14. All factors represent uncontrolled emissions. Units are kg of pollutant/10⁶ cubic meters natural gas fired and lb of pollutant/10⁶ cubic feet natural gas fired. Based on an average natural gas higher heating value of 8270 kcal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. ND = no data. NA = not applicable.

^b SCC = Source Classification Code.

^c Filterable PM is that particulate matter collected on or prior to the filter of an EPA Method 5 (or equivalent) sampling train.

^d Condensable PM is that particulate matter collected using EPA Method 202, (or equivalent). Total PM is the sum of the filterable PM and condensable PM. All PM emissions can be assumed to be less than 10 micrometers in aerodynamic equivalent diameter (PM-10).

Best Available Copy

Table 1.4-2 (Metric And English Units). EMISSION FACTORS FOR SULFUR DIOXIDE (SO₂), NITROGEN OXIDES (NO_x), AND CARBON MONOXIDE (CO) FROM NATURAL GAS COMBUSTION^a

Combustor Type (Size, 10 ⁶ Btu/hr Heat Input) (SCC) ^b	SO ₂ ^c			NO _x ^d			CO ^e		
	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	RATING	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	RATING	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	RATING
Utility/Large Industrial Boilers (>100) (1-01-006-01, 1-01-006-04)									
Uncontrolled	9.6	0.6	A	8800	550 ^f	A	640	40	A
Controlled - Low NO _x burners	9.6	0.6	A	1300	81 ^f	D	ND	ND	NA
Controlled - Flue gas recirculation	9.6	0.6	A	850	53 ^f	D	ND	ND	NA
Small Industrial Boilers (10 - 100) (1-02-006-02)									
Uncontrolled	9.6	0.6	A	2240	140	A	560	35	A
Controlled - Low NO _x burners	9.6	0.6	A	1300	81 ^f	D	980	61	D
Controlled - Flue gas recirculation	9.6	0.6	A	480	30	C	590	37	C
Commercial Boilers (0.3 - <10) (1-03-006-03)									
Uncontrolled	9.6	0.6	A	1600	100	B	330	21	C
Controlled - Low NO _x burners	9.6	0.6	A	270	17	C	425	27	C
Controlled - Flue gas recirculation	9.6	0.6	A	580	36	D	ND	ND	NA
Residential Furnaces (<0.3) (No SCC)									
Uncontrolled	9.6	0.6	A	1500	94	B	640	40	B

^a Units are kg of pollutant/10⁶ cubic meters natural gas fired and lb of pollutant/10⁶ cubic feet natural gas fired. Based on an average natural gas fired higher heating value of 8270 kcal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. ND = no data. NA = not applicable.

^b SCC = Source Classification Code.

^c Reference 7. Based on average sulfur content of natural gas, 4600 g/10⁶ Nm³ (2000 gr/10⁶ scf).

EMISSION FACTORS

1/95

Table 1.4-2 (cont.).

^d References 10, 15-19. Expressed as NO_2 . For tangentially fired units, use $4400 \text{ kg}/10^6 \text{ m}^3$ ($275 \text{ lb}/10^6 \text{ ft}^3$). At reduced loads, multiply factor by load reduction coefficient in Figure 1.4-1. Note that NO_x emissions from controlled boilers will be reduced at low load conditions.

^e References 9-10, 16-18, 20-21.

^f Emission factors apply to packaged boilers only.

Table 1.4.2 (Metric And English Units). EMISSION FACTORS FOR CARBON DIOXIDE (CO₂) AND TOTAL ORGANIC COMPOUNDS (TOC) FROM NATURAL GAS COMBUSTION^a

Combustor Type (Size, 10 ⁶ Btu/hr Heat Input) (SCC) ^b	CO ₂ ^c			TOC ^d		
	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	RATING	kg/10 ⁶ m ³	lb/10 ⁶ ft ³	RATING
Utility/large industrial boilers (> 100) (1-01-006-01, 1-01-006-04)	ND ^e	ND	NA	28 ^f	1.7 ^f	C
Small industrial boilers (10 - 100) (1-02-006-02)	1.9 E+06	1.2 E+05	D	92 ^g	5.8 ^g	C
Commercial boilers (0.3 - < 10) (1-03-006-03)	1.9 E+06	1.2 E+05	C	128 ^h	8.0 ^h	C
Residential furnaces (No SCC)	2.0 E+06	1.3 E+05	D	180 ^h	11 ^h	D

^a All factors represent uncontrolled emissions. Units are kg of pollutant/10⁶ cubic meters and lb of pollutant/10⁶ cubic feet. Based on an average natural gas higher heating value of 8270 kcal/m³ (1000 Btu/scf). The emission factors in this table may be converted to other natural gas heating values by multiplying the given factor by the ratio of the specified heating value to this average heating value. NA = not applicable.

^b SCC = Source Classification Code.

^c References 10,22-23.

^d References 9-10,18.

^e ND = no data.

^f Reference 8: methane comprises 17% of organic compounds.

^g Reference 8: methane comprises 52% of organic compounds.

^h Reference 8: methane comprises 34% of organic compounds.




Figure 1.4-1. Load reduction coefficient as a function of boiler load.
(Used to determine NO_x reductions at reduced loads in large boilers.)

References For Section 1.4

1. *Exhaust Gases From Combustion and Industrial Processes*, EPA Contract No. EHSD 71-36, Engineering Science, Inc., Washington, DC, October 1971.
2. *Chemical Engineers' Handbook, Fourth Edition*, J. H. Perry, Editor, McGraw-Hill Book Company, New York, NY, 1963.
3. *Background Information Document For Industrial Boilers*, EPA-450/3-82-006a, U. S. Environmental Protection Agency, Research Triangle Park, NC, March 1982.
4. *Background Information Document For Small Steam Generating Units*, EPA-450/3-87-000, U. S. Environmental Protection Agency, Research Triangle Park, NC, 1987.
5. *Fine Particulate Emissions From Stationary and Miscellaneous Sources in the South Coast Air Basin*, California Air Resources Board Contract No. A6-191-30, KVB, Inc., Tustin, CA, February 1979.
6. *Emission Factor Documentation for AP-42 Section 1.4 - Natural Gas Combustion (Draft)*, Technical Support Division, Office of Air Quality Planning and Standards, U. S. Environmental Protection Agency, Research Triangle Park, NC, April 1995.
7. *Systematic Field Study of NO_x Emission Control Methods For Utility Boilers*, APTD-1163, U. S. Environmental Protection Agency, Research Triangle Park, NC, December 1971.
8. *Compilation of Air Pollutant Emission Factors, Fourth Edition, AP-42*, U. S. Environmental Protection Agency, Research Triangle Park, NC, September 1985.

Best Available Copy

9. J. L. Muhlbaier, "Particulate and Gaseous Emissions From Natural Gas Furnaces and Water Heaters", *Journal of the Air Pollution Control Association*, December 1981.
10. *Field Investigation of Emissions From Combustion Equipment for Space Heating*, EPA-R2-73-084a, U. S. Environmental Protection Agency, Research Triangle Park, NC, June 1975.
11. N. F. Suprenant, et al., *Emissions Assessment of Conventional Stationary Combustion Systems, Volume I: Gas and Oil Fired Residential Heating Sources*, EPA-600/7-79-029b, U. S. Environmental Protection Agency, Washington, DC, May 1979.
12. C. C. Shih, et al., *Emissions Assessment of Conventional Stationary Combustion Systems, Volume III: External Combustion Sources for Electricity Generation*, EPA Contract No. 68-02-2197, TRW, Inc., Redondo Beach, CA, November 1980.
13. N. F. Suprenant, et al., *Emissions Assessment of Conventional Stationary Combustion Systems, Volume IV: Commercial/Institutional Combustion Sources*, EPA Contract No. 68-02-2197, GCA Corporation, Bedford, MA, October 1980.
14. N. F. Suprenant, et al., *Emissions Assessment of Conventional Stationary Combustion Systems, Volume V: Industrial Combustion Sources*, EPA Contract No. 68-02-2197, GCA Corporation, Bedford, MA, October 1980.
15. *Emissions Test on 200 HP Boiler at Kaiser Hospital in Woodland Hills*, Energy Systems Associates, Tustin, CA, June 1986.
16. *Results From Performance Tests: California Milk Producers Boiler No. 5*, Energy Systems Associates, Tustin, CA, November 1984.
17. *Source Test For Measurement of Nitrogen Oxides and Carbon Monoxide Emissions From Boiler Exhaust at GAF Building Materials*, Pacific Environmental Services, Inc., Baldwin Park, CA, May 1991.
18. J. P. Kesselring and W. V. Krill, "A Low-NO_x Burner For Gas-Fired Firetube Boilers", *Proceedings: 1985 Symposium on Stationary Combustion NO_x Control, Volume 2*, EPRI CS-4360, Electric Power Research Institute, Palo Alto, CA, January 1986.
19. *NO_x Emission Control Technology Update*, EPA Contract No. 68-01-5558, Fudian Corporation, Research Triangle Park, NC, January 1984.
20. *Background Information Document For Small Steam Generating Units*, EPA-450/3-87-009, U. S. Environmental Protection Agency, Research Triangle Park, NC, 1987.
21. *Evaluation of the Pollutant Emissions From Gas-Fired Forced Air Furnaces: Research Report No. 1503*, American Gas Association Laboratories, Cleveland, OH, May 1975.
22. *Thirty-day Field Tests of Industrial Boilers: Site 5 - Gas-fired Low-NO_x Burner*, EPA-600/7-81-095a, U. S. Environmental Protection Agency, Research Triangle Park, NC, May 1981.
23. Private communication from Kim Black (Industrial Combustion) to Ralph Harris (MRI), Independent Third Party Source Tests, February 7, 1992.



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

July 9, 1997

Certified Mail - Return Receipt Requested

Mr. Rich Piper, Chair
Florida Power Coordinating Group, Inc.
405, Reo Street, Suite 100
Tampa, Florida 33609-1004

Dear Mr. Piper:

Enclosed is a copy of a Scrivener's Order correcting an error in the Order concerning particulate matter testing of natural gas fired boilers.

If you have any questions concerning the above, please call Yogesh Manocha at 904/488-6140, or write to me.

Sincerely,

M. D. Harley, P.E., DEE
P.E. Administrator
Emissions Monitoring Section
Bureau of Air Monitoring and
Mobile Sources

MDH:ym

cc: Dotty Diltz, FDEP
Pat Comer, FDEP

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

In the matter of:)

Florida Electric Power Coordinating Group, Inc.,)

ASP No. 97-B-01

Petitioner.)

ORDER CORRECTING SCRIVENER'S ERROR

The Order which authorizes owners of natural gas fired fossil fuel steam generators to forgo particulate matter compliance testing on an annual basis and prior to renewal of an operation permit entered on the 17th day of March, 1997, is hereby corrected on page 4, paragraph number 4, by deleting the words "pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C.":

4. In renewing an air operation permit pursuant to ~~Rule 62-210.300(2)(a)3.b., c., or d., F.A.C.~~, the Department shall not require submission of particulate matter emission compliance test results for any fossil fuel steam generator emissions unit that burned liquid and/or solid fuel for a total of no more than 400 hours during the year prior to renewal.

DONE AND ORDERED this 2 day of July, 1997 in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



HOWARD L. RHODES, Director
Division of Air Resources Management
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
(904) 488-0114

CERTIFICATE OF SERVICE

The undersigned duly designated deputy clerk hereby certifies that a copy of the foregoing was mailed to Rich Piper, Chair, Florida Power Coordinating Group, Inc., 405 Reo Street, Suite 100, Tampa, Florida 33609-1004, on this 10th day of July 1997.

Clerk Stamp

**FILING AND ACKNOWLEDGMENT
FILED**, on this date, pursuant to
§120.52(7), Florida Statutes, with the
designated Department Clerk, receipt of
which is hereby acknowledged.

Martha Jewell Wise 7/10/97
Clerk Date

40 CFR 60 Subpart A-General Provisions (Version dated 07/23/97)

These conditions are based on the July 1996 CFR version.

[Applicability note: These conditions are for an NSPS emissions unit (a.k.a. "federal facility") that has been built and has conducted the initial performance test(s) in accordance with 40 CFR 60.8.]

{Note: Rule 62-204.800(d), F.A.C., did not adopt/incorporate 40 CFR 60.4, 40 CFR 60.16, and 40 CFR 60.17.}

1. **Definitions.** For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.
[40 CFR 60.2; Rule 62-204.800(7)(a), F.A.C.]

40 CFR 60.7 Notification and record keeping.

2. The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:

(4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

[40 CFR 60.7(a)(4)]

3. The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

4. Each owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate).

Written reports of excess emissions shall include the following information:

(1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.

(2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.

(3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.

(4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)(1), (2), (3), and (4)]

5. The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

(1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

(2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

{See attached Figure 1: Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance} (electronic file name: figure1.doc)

[40 CFR 60.7(d)(1) and (2)]

6. (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

(i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;

(ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and

(iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After

demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)(1)]

7. Any owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least **5 (five)** years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

40 CFR 60.8 Performance tests.

8. Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

40 CFR 60.11 Compliance with standards and maintenance requirements.

9. Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.

[40 CFR 60.11(a)]

10. Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in Appendix A of 40 CFR 60, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5).

[40 CFR 60.11(b)]

11. The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.

[40 CFR 60.11(c)]

12. At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

[40 CFR 60.11(d)]

13. The owner or operator of an affected facility subject to an opacity standard may submit, for compliance purposes, continuous opacity monitoring system (COMS) data results produced during any performance test required under 40 CFR 60.8 in lieu of EPA Method 9 observation data. If an owner or operator elects to submit COMS data for compliance with the opacity standard, he or she shall notify the

Administrator of that decision, in writing, at least 30 days before any performance test required under 40 CFR 60.8 is conducted. Once the owner or operator of an affected facility has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent tests required under 40 CFR 60.8 until the owner or operator notifies the Administrator, in writing, to the contrary. For the purpose of determining compliance with the opacity standard during a performance test required under 40 CFR 60.8 using COMS data, the minimum total time of COMS data collection shall be averages of all 6-minute continuous periods within the duration of the mass emission performance test. Results of the COMS opacity determinations shall be submitted along with the results of the performance test required under 60.8. The owner or operator of an affected facility using a COMS for compliance purposes is responsible for demonstrating that the COMS meets the requirements specified in 40 CFR 60.13(c), that the COMS has been properly maintained and operated, and that the resulting data have not been altered in any way. If COMS data results are submitted for compliance with the opacity standard for a period of time during which EPA Method 9 data indicates noncompliance, the EPA Method 9 data will be used to determine opacity compliance.
[40 CFR 60.11(e)(5)]

40 CFR 60.12 Circumvention.

14. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.
[40 CFR 60.12]

40 CFR 60.13 Monitoring requirements.

15. For the purposes of 40 CFR 60.13, all continuous monitoring systems (CMS) required under applicable subparts shall be subject to the provisions of 40 CFR 60.13 upon promulgation of performance specifications for continuous monitoring systems under Appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F of 40 CFR 60, unless otherwise specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.
[40 CFR 60.13(a)]

16. If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, Appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system (CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in Appendix B of 40 CFR 60. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Administrator under section 114 of the Act.

(1) The owner or operator of an affected facility using a COMS to determine opacity compliance during any performance test required under 60.8 and as described in 40 CFR 60.11(e)(5) shall furnish the Administrator two or, upon request, more copies of a written report of the results of the COMS performance evaluation described in 40 CFR 60.13(c) at least 10 days before the performance test required under 60.8 is conducted.

[40 CFR 60.13(c)(1)]

17. (1) Owners and operators of all continuous emission monitoring systems (CEMS) installed in accordance with the provisions of this part shall check the zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For continuous monitoring systems measuring opacity of emissions, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments except that for systems using automatic zero adjustments. The optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.

(2) Unless otherwise approved by the Administrator, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a method for producing a simulated zero opacity condition and an upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly.

[40 CFR 60.13(d)(1) and (2)]

18. Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems (CMS) shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

(1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)(1) and (2)]

19. All continuous monitoring systems (CMS) or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR 60 shall be used.

[40 CFR 60.13(f)]

20. When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems (CMS) on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Administrator. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system.

[40 CFR 60.13(g)]

21. Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally

spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non reduced form (e.g., ppm pollutant and percent O₂ or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).

[40 CFR 60.13(h)]

[electronic file name: 40CFR60a.doc]



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Mr. Ronald W. Tomlin
Assistant Managing Director
Lakeland Electric & Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5079

ORDER EXTENDING PERMIT EXPIRATION DATE C. D. McIntosh, Jr. Power Plant, **Facility ID No.:** 1050004

Section 403.0872(2)(b), Florida Statutes (F.S.), specifies that any facility which submits to the Department of Environmental Protection (Department) a timely and complete application for a Title V permit "is entitled to operate in compliance with its existing air permit pending the conclusion of proceedings associated with its application."

Section 403.0872(6), F.S., provides that a proposed Title V permit which is not objected to by the United States Environmental Protection Agency (EPA) "must become final no later than fifty-five (55) days after the date on which the proposed permit was mailed" to the EPA.

Pursuant to the Federal Acid Rain Program as defined in rule 62-210.200, Florida Administrative Code (F.A.C.), all Acid Rain permitting must become effective on January 1 of a given year.

This facility which will be permitted pursuant to section 403.0872, F.S., (Title V permit) will be required to have a permit effective date subsequent to the final processing date of the facility's Title V permit.

To prevent misunderstanding and to assure that the above identified facility continues to comply with existing permit terms and conditions until its Title V permit becomes effective, it is necessary to extend the expiration date(s) of its existing valid permit(s) until the effective date of its Title V permit. Therefore, under the authority granted to the Department by section 403.061(8), F.S., **IT IS ORDERED:**

1. The expiration date(s) of the existing valid permit(s) under which the above identified facility is currently operating is (are) hereby extended until the effective date of its permit issued pursuant to section 403.0872, F.S., (Title V permit);
2. The facility shall comply with all terms and conditions of its existing valid permit(s) until the effective date of its Title V permit;
3. The facility will continue to comply with the requirements of Chapter 62-214, F.A.C., and the Federal Acid Rain Program, as defined in rule 62-210.200, F.A.C., pending final issuance of its Title V permit.

PETITION FOR ADMINISTRATIVE REVIEW

The Department will take the action described in this Order unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 of the Florida Statutes (F.S.). Mediation under Section 120.573, F.S., will not be available for this proposed action.

A person whose substantial interests are affected by the Department's proposed decision may petition for an administrative hearing in accordance with sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. Petitions must be filed within 21 days of receipt of this Order. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of the Florida Statutes, or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with rule 28-5.207 of the Florida Administrative Code.

A petition must contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department File Number, and the county in which the project is proposed;
- (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
- (d) A statement of the material facts disputed by the petitioner, if any;
- (e) A statement of the facts that the petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement identifying the rules or statutes that the petitioner contends require reversal or modification of the Department's action or proposed action; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the Department to take with respect to the action or proposed action addressed in this notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under section 120.542 of the Florida Statutes. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. The petition must specify the following information:

- (a) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
- (c) Each rule or portion of a rule from which a variance or waiver is requested;
- (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
- (e) The type of action requested;
- (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and
- (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.


This Order constitutes final agency action unless a petition is filed in accordance with the above paragraphs.

RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed with the Clerk of the Department.

DONE AND ORDERED this 12th day of February, 1998 in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



HOWARD L. RHODES, Director
Division of Air Resources Management
Twin Towers Office Building
Mail Station 5500
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
850/488-0114

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this order and all copies were sent by certified mail before the close of business on 2/13/98 to the person(s) listed:

Ms. Farzie Shelton, Lakeland Electric & Water Utilities
Mr. Bill Thomas, PE, FDEP, SWD

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

Barbara J. Boutwell 2/13/98
(Clerk) (Date)

2/13/98 cc: ed [unclear]
Reading File



December 4, 1997

Mr. Scott M. Sheplak, P.E.
Administrator, Title V Section
Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Re: Phase II NO_x Compliance Plans

Dear Scott:

We are in receipt of your communication dated November 10, 1997 in reference to the above. We are baffled as whether or not it is necessary for us to complete the phase II NO_x Compliance Plan as on 12/16/96 we submitted to EPA such form in connection to the "early election" program. From the enclosed documents you will note EPA's acceptance of our participation.

Although we feel this may be unnecessary, nonetheless, to aid you in your recording of such data we have completed the form you have sent to us and we are enclosing same herewith.

If you should have any questions, please do not hesitate to contact me at (941) 499-6603.

Sincerely

Farzie Shelton
Manager of Environmental Permitting & Compliance
Production Division

Enc.

RECEIVED

DEC 09 1997

BUREAU OF
AIR REGULATION

Florida Department of Environmental Protection

Phase II NO_x Compliance Plan

For more information, see instructions and refer to 40 CFR 76.9

This submission is: New Revised

Page of

STEP 1 Indicate plant name, state, and ORIS code from NADB, if applicable.	Plant Name C.D. McIntosh Power Plant	State FL	ORIS Code 000676
STEP 2	Identify each affected Group 1 and Group 2 boiler using the boiler ID# from NADB, if applicable. Indicate boiler type: "CB" for cell burner, "CY" for cyclone, "DBW" for dry bottom wall-fired, "T" for tangentially fired, "V" for vertically fired, and "WB" for wet bottom. Indicate the compliance option selected for each unit.		

ID#	ID#	ID#	ID#	ID#	ID#
1050004					
Type	Type	Type	Type	Type	Type
DBW					
0.51b/mmbtu					

(a) Standard annual average emission limitation of 0.50 lb/mmBtu (for <u>Phase I</u> dry bottom wall-fired boilers)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(b) Standard annual average emission limitation of 0.45 lb/mmBtu (for <u>Phase I</u> tangentially fired boilers)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(c) EPA-approved early election plan under 40 CFR 76.8 through 12/31/07 (also indicate above emission limit specified in plan)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(d) Standard annual average emission limitation of 0.46 lb/mmBtu (for <u>Phase II</u> dry bottom wall-fired boilers)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(e) Standard annual average emission limitation of 0.40 lb/mmBtu (for <u>Phase II</u> tangentially fired boilers)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(f) Standard annual average emission limitation of 0.68 lb/mmBtu (for cell burner boilers)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(g) Standard annual average emission limitation of 0.86 lb/mmBtu (for cyclone boilers)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(h) Standard annual average emission limitation of 0.80 lb/mmBtu (for vertically fired boilers)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(i) Standard annual average emission limitation of 0.84 lb/mmBtu (for wet bottom boilers)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(j) NO _x Averaging Plan (include NO _x Averaging form)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(k) Common stack pursuant to 40 CFR 75.17(a)(2)(i)(A) (check the standard emission limitation box above for most stringent limitation applicable to any unit utilizing stack)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Plant Name (from Step 1) C.D. McIntosh Power Plant

STEP 2, cont'd.

ID#	ID#	ID#	ID#	ID#	ID#
Type	Type	Type	Type	Type	Type

(l) Common stack pursuant to 40 CFR 75.17(a)(2)(i)(B) with NO_x Averaging (check the NO_x Averaging Plan box and include NO_x Averaging Form)

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

(m) EPA-approved common stack apportionment method pursuant to 40 CFR 75.17 (a)(2)(i)(C), (a)(2)(iii)(B), or (b)(2)

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

(n) AEL (include Phase II AEL Demonstration Period, Final AEL Petition, or AEL Renewal form as appropriate)

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

(o) Petition for AEL demonstration period or final AEL under review by U.S. EPA or demonstration period ongoing

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

(p) Repowering extension plan approved or under review

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

STEP 3

Read the standard requirements and certification, enter the name of the designated representative, sign and date.

Standard Requirements
General. This source is subject to the standard requirements in 40 CFR 72.9 (consistent with 40 CFR 76.8(e)(1)(i)). These requirements are listed in this source's Acid Rain Part of its Title V permit.

Special Provisions for Early Election Units
Nitrogen Oxides. A unit that is governed by an approved early election plan shall be subject to an emissions limitation for NO_x as provided under 40 CFR 76.8(a)(2) except as provided under 40 CFR 76.8(e)(3)(iii).

Liability. The owners and operators of a unit governed by an approved early election plan shall be liable for any violation of the plan or 40 CFR 76.8 at that unit. The owners and operators shall be liable, beginning January 1, 2000, for fulfilling the obligations specified in 40 CFR Part 77.

Termination. An approved early election plan shall be in effect only until the earlier of January 1, 2008 or January 1 of the calendar year for which a termination of the plan takes effect. If the designated representative of the unit under an approved early election plan fails to demonstrate compliance with the applicable emissions limitation under 40 CFR 76.5 for any year during the period beginning January 1 of the first year the early election takes effect and ending December 31, 2007, the permitting authority will terminate the plan. The termination will take effect beginning January 1 of the year after the year for which there is a failure to demonstrate compliance, and the designated representative may not submit a new early election plan. The designated representative of the unit under an approved early election plan may terminate the plan any year prior to 2008 but may not submit a new early election plan. In order to terminate the plan, the designated representative must submit a notice under 40 CFR 72.40(d) by January 1 of the year for which the termination is to take effect. If an early election plan is terminated any year prior to 2000, the unit shall meet, beginning January 1, 2000, the applicable emissions limitation for NO_x for Phase II units with Group 1 boilers under 40 CFR 76.7. If an early election plan is terminated on or after 2000, the unit shall meet, beginning on the effective date of the termination, the applicable emissions limitation for NO_x for Phase II units with Group 1 boilers under 40 CFR 76.7.

STEP 3, cont'd.

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name Ronald W. Tomlin	
Signature <i>Ronald W. Tomlin</i>	Date <i>12-01-97</i>



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 4
ATLANTA FEDERAL CENTER
100 ALABAMA STREET, S.W.
ATLANTA, GEORGIA 30303-3104

APR 07 1997

RECEIVED

APR 11 1997

RONALD W. TOMLIN
ASST. MANAGING DIR.

4APT-ARB

Mr. Ronald W. Tomlin
Designated Representative
City of Lakeland
Electric and Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5050

Dear Mr. Tomlin:

Enclosed you will find the draft Phase I Acid Rain permit issued by the U.S. Environmental Protection Agency on March 27, 1997, for the affected sources in your nitrogen oxides early election compliance plan. This permitting action will become final 40 days after a notice is published in the Federal Register or local newspaper, whichever is later, unless adverse comment is received within 30 days after publication. Notice of this permitting action is scheduled for publication on April 11, 1997.

Your cooperation has been appreciated. If you have any questions or comments, please contact Mr. Scott Davis of my staff at (404) 562-9127.

Sincerely,

R. Douglas Neeley

for Chief

Air and Radiation Technology Branch
Air, Pesticides and Toxics
Management Division

Enclosure

cc: Tom Cascio, Florida DEP



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
100 ALABAMA STREET, S.W.
ATLANTA, GEORGIA 30303-3104

PHASE I ACID RAIN PERMIT For NO_x Early Election

Issued to: C.D. McIntosh Power Plant
Operated by: City of Lakeland
Effective: January 1, 1997 through December 31, 1999

This page will be replaced to document new EPA actions each time a new action is taken by the Agency. This is the initial permitting action:


Summary of Previous Actions

None.


Present Action

1. Permit, including the NO_x early election compliance plan, issued as a direct final permit for Unit 3. This action will become final 40 days after notice in the Federal Register or local newspaper, whichever is later, unless adverse comment is received within 30 days after publication.

(See page 1)



Signature



Date

Winston A. Smith
Director, Air, Pesticides and Toxics Management Division
U.S. Environmental Protection Agency, Region 4

61 Forsyth Street, S.W.

Atlanta, Georgia 30303

Telephone: (404) 562-9077

Facsimile: (404) 562-9095



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
100 ALABAMA STREET, S.W.
ATLANTA, GEORGIA 30303-3104

PHASE I ACID RAIN PERMIT For NO_x Early Election

Issued to: C.D. McIntosh Power Plant
Operated by: City of Lakeland
Effective: January 1, 1997 through December 31, 1999

The Acid Rain Permit comprises the following:

1. The statement of basis containing:

Part A, with references to statutory and regulatory authorities, and comments, notes and justifications that apply to the source in general; and

Part B, for each Early Election unit at this source:

- a NO_x compliance plan; and,
- comments, notes and justifications regarding permit decisions and changes made to the permit application forms during the review process, and any additional requirements.

2. The permit application forms that this source submitted, as corrected by EPA. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application.

Statement of Basis. Part A

Page 2

Plant Name: C.D. McIntosh Power Plant

State: Florida

ORIS Code: 0676

Statutory and Regulatory Authorities. In accordance with Title IV of the Clean Air Act Amendments of 1990, the U. S. Environmental Protection Agency issues this permit pursuant to 40 CFR part 72, subparts E and F, and part 76.

For further information contact:


Scott Davis, Acid Rain Contact
U.S. EPA, Region 4
Air, Pesticides and Toxics Management Division
Telephone: (404) 562-9127
Facsimile: (404) 562-9095

Comments, notes and justifications that apply to the source in general:

None.

R. SCOTT DAVIS

Permit Reviewer



Signature

3/24/97

Date

Plant Name: C.D. McIntosh Power Plant

State: Florida

ORIS Code: 0676

Boiler ID#: 3

NO_x Compliance Plan

EPA approves a nitrogen oxides early election plan for this unit for 1997-2007 under which this unit's annual average NO_x emission rate for each year, determined using the methods and procedures specified in 40 CFR part 75, shall not exceed the applicable emission limitation under 40 CFR 76.5(a), of 0.50 lbs/mmBtu for dry bottom wall-fired units. If this unit is in compliance with its applicable emission limitation for each year of the plan, then the unit shall not be subject to any revised NO_x emission limitation for Group 1 boilers that the Administrator may issue pursuant to section 407(b)(2) of the Act, until January 1, 2008.

Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:

None.

R. SCOTT DAVIS

Permit Reviewer



Signature

3/24/97

Date

For further information and a detailed description of the permits and permit modifications, see the information provided in the notice of permits and permit modifications elsewhere in today's **Federal Register**.

Dated: April 10, 1997.

Brian J. McLean,

Director, Acid Rain Division, Office of Atmospheric Programs, Office of Air and Radiation.

[FR Doc. 97-9865 Filed 4-15-97; 8:45 am]

BILLING CODE 6560-50-P

ENVIRONMENTAL PROTECTION AGENCY

[FRL-5812-5]

Acid Rain Program: Permit and Permit Modifications

AGENCY: Environmental Protection Agency (EPA).

ACTION: Notice of permits and permit modifications.

SUMMARY: The U.S. Environmental Protection Agency (EPA) is issuing, as a direct final action, Phase I Acid Rain permits and permit modifications including nitrogen oxides (NO_x) compliance plans in accordance with the Acid Rain Program regulations (40 CFR parts 72 and 76). Because the Agency does not anticipate receiving adverse comments, the exemptions are being issued as a direct final action.

DATES: The permits and permit modifications issued in this direct final action will be final on May 26, 1997 or 40 days after publication of a similar notice in a local publication, whichever is later, unless significant, adverse comments are received by May 16, 1997 or 30 days after publication of a similar notice in a local publication, whichever is later. If significant, adverse comments are timely received on any permit or permit modification in this direct final action, that permit or permit modification will be withdrawn through a notice in the **Federal Register**.

ADDRESSES: *Administrative Records.* The administrative record for the permits, except information protected as confidential, may be viewed during normal operating hours at the following locations: for plants in New York, EPA Region 2, 290 Broadway, New York, NY, 10007-1866; for plants in Alabama, Florida, Georgia, Kentucky, North Carolina, South Carolina and Tennessee, EPA Region 4, 100 Alabama St., NW, Atlanta, GA, 30303; for plants in Illinois, Indiana, Michigan, Minnesota, Ohio, and Wisconsin, EPA Region 5, 77 West Jackson Blvd., Chicago, IL, 60604;

for plants in Colorado, Montana, North Dakota, Utah and Wyoming, EPA Region 8, 999 18th St., Denver, CO, 80202.

Comments. Send comments, requests for public hearings, and requests to receive notice of future actions to: for plants in New York, EPA Region 2, Division of Environmental Planning & Protection, Attn: Gerry DeGaetano (address above); for plants in Alabama, Florida, Georgia, Kentucky, North Carolina, South Carolina and Tennessee, EPA Region 4, Air, Pesticides and Toxics Management Division, Attn: Scott Davis (address above); for plants in Illinois, Indiana, and Ohio, EPA Region 5, Air and Radiation Division, Attn: Cecilia Mijares (address above); for plants in Michigan, Minnesota, and Wisconsin, EPA Region 5, Air and Radiation Division, Attn: Beth Valenziano (address above); for plants in Colorado, Montana, North Dakota, Utah and Wyoming, EPA Region 8, Air and Toxics Division, Attn: Mike Owens (address above). Submit comments in duplicate and identify the permit to which the comments apply, the commenter's name, address, and telephone number, and the commenter's interest in the matter and affiliation, if any, to the owners and operators of all units in the plan. All timely comments will be considered, except those pertaining to standard provisions under 40 CFR 72.9 or issues not relevant to the permit or the permit modification.

Hearings. To request a public hearing, state the issues proposed to be raised in the hearing. EPA may schedule a hearing if EPA finds that it will contribute to the decision-making process by clarifying significant issues affecting a NO_x compliance plan.

FOR FURTHER INFORMATION CONTACT: For plants in New York, call Gerry DeGaetano, 212-637-4020; for plants in Alabama, Florida, Georgia, Kentucky, North Carolina, South Carolina and Tennessee, call Scott Davis, 404-562-9127; for plants in Illinois, Indiana, and Ohio, call Cecilia Mijares, 312-886-0968; for plants in Michigan, Minnesota, and Wisconsin, call Beth Valenziano, 312-886-2703; for plants in Colorado, Montana, North Dakota, Utah and Wyoming, call Mike Owens, 303-312-6440.

SUPPLEMENTARY INFORMATION: Title IV of the Clean Air Act directs EPA to establish a program to reduce the adverse effects of acidic deposition by promulgating rules and issuing permits to emission sources subject to the program. In today's action, EPA is issuing permits and permit modifications that include approval of early election plans for NO_x. The units

that are included in the early election plans will be required to meet an actual annual average emissions rate for NO_x of either 0.45 lbs/MMBtu for tangentially-fired boilers or 0.50 lbs/MMBtu for dry bottom wall-fired boilers beginning on January 1, 1997 through December 31, 2007, after which they will be required to meet the applicable emissions limitation under 40 CFR 76.7(a) of 0.40 lbs/MMBtu for tangentially-fired boilers or 0.46 lbs/MMBtu for dry bottom wall-fired boilers. The following is a list of units included in the permits or permit modifications and the limits that they are required to meet:

S A Carlson units 9, 10, 11, and 12 in New York: 0.50 lbs/MMBtu. The designated representative is R. James Gronquist.

Kintigh unit 1 in New York: 0.50 lbs/MMBtu. The designated representative is James Rettberg. Charles R Lowman units 2 and 3 in Alabama: 0.50 lbs/MMBtu. The designated representative is John Howard.

C D McIntosh unit 3 in Florida: 0.50 lbs/MMBtu. The designated representative is Ronald Tomlin. Crystal River units 2, 4, and 5 in Florida: 0.45 lbs/MMBtu for unit 2; 0.50 lbs/MMBtu for units 4 and 5. The designated representative is W. Jeffrey Pardue.

Deerhaven unit B2 in Florida: 0.50 lbs/MMBtu. The designated representative is John Hancock, Jr. St. Johns River Power Park units 1 and 2 in Florida: 0.50 lbs/MMBtu. The designated representative is Brian Wirz.

Scherer unit 4 in Georgia: 0.45 lbs/MMBtu. The designated representative is R. Haubein, Jr.

D B Wilson unit W1 in Kentucky: 0.50 lbs/MMBtu. The designated representative is Gregory Black.

Cane Run units 4, 5, and 6 in Kentucky: 0.50 lbs/MMBtu for units 4 and 5; 0.45 lbs/MMBtu for unit 6. The designated representative is Chris Herman.

Mill Creek units 1, 2, 3, and 4 in Kentucky: 0.45 lbs/MMBtu for units 1 and 2; 0.50 lbs/MMBtu for units 3 and 4. The designated representative is Chris Herman.

Trimble County unit 1 in Kentucky: 0.45 lbs/MMBtu. The designated representative is Chris Herman.

Buck units 5, 6, 7, 8, and 9 in North Carolina: 0.45 lbs/MMBtu. The designated representative is T. McMeekin.

Cliffside units 1, 2, 3, 4, and 5 in North Carolina: 0.45 lbs/MMBtu. The

For Your Information
Angela R. Morrison



**LAKELAND
ELECTRIC & WATER**

Excellence Is Our Goal, Service Is Our Job

3030 E. Lake Parker Dr.
Lakeland, Florida 33805

PH: (941) 499-6600
FAX: (941) 603-6335

TELECOPY REQUEST/COVER PAGE

Please deliver the following page(s) to:

El Svec

Here's an oldy!

~~Scott Sheplark~~ at Dep

Telecopier Number 1-904-972-6079

From: Fannie Shelton Telefax Number (FAX) (941) 603-6335

Date: 7-17-97 Time: 9:29 AM/PM

Number of Pages (Including Cover Page): 3

For more information or problem assistance, please call your city contact or (941) 499-6600.

Please note the marked area!

Handwritten initials

MAY 27 1976

Best Available Copy



J. A. LIBBY, Supl. of Generation
DEPT. OF ELECTRIC & WATER UTILITIES
TALLAHASSEE, FLORIDA

DEPARTMENT OF ENVIRONMENTAL REGULATION

CENTRAL SUBDISTRICT
P.O. BOX 9205
500 E. CENTRAL AVENUE
WINTER HAVEN, FLORIDA 33880

JOSEPH W. LANDERS
SECRETARY

REUBEN O'D. ASKEW
GOVERNOR

May 25, 1976

Mr. C. D. McIntosh, Jr., Director
Department of Electric & Water Utilities
P. O. Box 368
Lakeland, Florida 33801

POLK CO. AP
DEPT. OF ELECTRIC &
WATER UTILITIES

Dear Mr. McIntosh:

Pursuant to your recent application, please find enclosed a permit (No. AC53-2244) dated 10-9-73 to construct/~~operate~~ the subject pollution source.

This permit will expire on 8-30-76 , and will be subject to the conditions, requirements and restrictions checked or indicated otherwise in the attached sheet "Construction/~~Operation~~ Permit Conditions".

This permit is issued under the authority of Florida Statute 403.061(16). The time limits imposed herein are a condition to this permit and are enforceable under Florida Statute 403.161. You are hereby placed on Notice that the Department will review this permit before the scheduled date of expiry and will seek court action for violation of the conditions and requirements of this permit.

You have ten days from the date of receipt hereof within which to seek a review of the conditions and requirements contained in this permit. Failure to file a written request to review or modify the conditions or requirements contained in this permit shall be deemed a waiver of any objections thereto.

Your continued cooperation in this matter is appreciated and in future communication please refer to your permit number.

Yours very truly,

J. H. Kerns
J. H. Kerns, P.E.
Chief of Permitting

JHK:bat

cc: Central Files

8/75

PS 3

07/17/1997 09:34

9416036335

MCINTOSH POWER PLANT

DEPARTMENT OF ENVIRONMENTAL REGULATION

CONSTRUCTION PERMIT PROVISOS

Best Available Copy

AIR POLLUTION SOURCESPermit No. AC53-2244Date: 10-9-73

- (X) 1. Construction of this installation shall be completed by December 1, 1975. Application for Permit to Operate to be submitted by August 30, 1976.
- (X) 2. This construction permit expires on August 30, 1976 following an initial period of operation for appropriate testing to determine compliance with the Rules of the Florida Department of Environmental Regulation Commission.
- (X) 3. All applicable rules of the Department including design discharge limitations specified in the application shall be adhered to. The permit holder may also need to comply with county, municipal, federal, or other state regulations prior to construction.
- (X) 4. The applicant shall continue the retention of the engineer of record for the inspection of the construction of this project. Upon completion the engineer shall inspect for conformity to construction permit applications and associated documents. A report of such inspection shall be submitted by the engineer to the Department of Environmental Regulation for consideration toward the issuance of an operation permit.
- (X) 5. This Unit #2 steam boiler shall be tested* for particulates, sulfur dioxides, and nitrogen oxides within 30 days after it is placed in operation. These test results are required prior to our issuance of an operation permit and shall be submitted in duplicate to the Florida Department of Environmental Regulation 500 East Central Avenue, Suite 238, Winter Haven, FL 33880.
- * Fuel Analysis May be Submitted for Required Sulfur Dioxide Emission Test.
- (X) 6. The operation of this installation shall be observed for visible emissions in accordance with Method 9-Visible Determination of the Opacity of Emissions from Stationary Sources (36FR24895; Federal Register, December 23, 1971). The observation results are required prior to our issuance of an operation permit, and shall be submitted in duplicate to the Department of Environmental Regulation District Office, 500 East Central Avenue, Suite 238, Winter Haven, Florida 33880.
- X) 7. Satisfactory ladders, platforms, and other safety devices shall be provided/available as well as necessary ports to facilitate the carrying out of an adequate sampling program.
-) 8. There shall be no discharges of liquid effluents or contaminated runoff from the plant site.
-) 9. All fugitive dust generated at this site shall be adequately controlled.
-) 10. Issuance of this permit does not indicate an endorsement or PERM 12-3 approval of any other required permits by this Department.

11/75



CERTIFIED MAIL - RETURN RECEIPT REQUESTED

June 23, 1997

Mr. C.H. Fancy, P.E.
Chief Bureau of Air Regulation
Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

RECEIVED

JUN 25 1997

BUREAU OF
AIR REGULATION

Dear Mr. Fancy:

Re: City of Lakeland C.D. McIntosh, Jr. Power Plant - Public Notice of Intent to Issue Title V Air Operation Permit - Permit No: 1050003-003-AV

We are in receipt of your letter dated June 3, 1997 and attached Proposed Title V Draft Permit, Intent to Issue, Public Notice of Intent to Issue Permit for the above referenced facility.

Pursuant to Section 403.815 and 403.0872, Florida Statutes and Rules 62-103.150 and 62-210.350(3), F.A.C., on June 18, 1997 we published the Public Notice of Intent to Issue Title V Air Operation Permit - Permit No: 1050003-003-AV. Therefore, enclosed please find Affidavit of Publication confirming publication of this notice.

If you should have any questions, please do not hesitate to contact me at (941) 499-6603.

Sincerely

Farzie Shelton
Environmental Division

Enclosure

AFFIDAVIT OF PUBLICATION

Best Available Copy

THE LEDGER

Lakeland, Polk County, Florida

Case No

STATE OF FLORIDA)
COUNTY OF POLK)

Before the undersigned authority personally appeared Nelson Kirkland, who on oath says that he is Classified Advertising Manager of The Ledger, a daily newspaper published at Lakeland in Polk County, Florida; that the attached copy of advertisement, being a

Public Notice

in the matter of

Title V Draft Permit No. 1060004-003-AV

in the

Court, was published in said newspaper in the issues of

June 18;

1997

Affiant further says that said The Ledger is a newspaper published at Lakeland, in said Polk County, Florida, and that the said newspaper has heretofore been continuously published in said Polk County, Florida, daily, and has been entered as second class matter at the post office in Lakeland, in said Polk County, Florida, for a period of one year next preceding the first publication of the attached copy of advertisement; and affiant further says that he has neither paid nor promised any person, firm or corporation any discount, rebate, commission or refund for the purpose of securing this advertisement for publication in the said newspaper.

Signed

Nelson Kirkland

Classified Advertising Manager

By Nelson Kirkland who is personally known to me


18th

Sworn to and subscribed before me this

day of June A.D. 19 97

(Seal)

Notary Public



My Commission Expires

Order#632190
S Jones

A379

PUBLIC

The Department of issue a Title V air operati Power Plant located at Maximum Achievable Ca action. The applicant's n Street, Lakeland, Florida 3

The permitting auth Permit. In accordance w accordance with the fo terms or conditions.

The permitting auth Permit issuance action fo Written comments should Road, Mail Station #5505, available for public insp DRAFT Permit, the permit another Public Notice.

The permitting au hearing is filed, pursuan mediation as an altera petition. Choosing med result in a settlement. Th the procedures for requ

A person whose su petition for an adminis petition must contain the General Counsel of the Mail Station #35, Tallah Petitions must be filed v (fourteen) days of recei copy of the petition to th of any person to file a pe time period shall consti (hearing) under Section as a party to it. Any sub the filing of a motion in

A petition must co (a) The name, ad address, the Permit File (b) A statement of action or proposed action or proposed action authority's action or pro (c) A statement of the permitting authority (d) A statement of modification of the per

(e) A statement of the petitioner wants the pe addressed in this notice (f) Because the adm filling of a petition me position taken by it in such final decision of become a party to the permitting decision, ma to such mediation and mediation and the writ agreement must be fil Environmental Protection 3000, by the same dea A request for med (a) The name, ad person's representative (b) A statement of (c) A statement of (d) Either, an exp action or proposed action for hearing the agreement, (a) The names, mediation (b) The name, d provision for selecting (c) The agreed (d) The agree introduced during med (e) The date, tin session, if no mediator (f) The name of settlement; and (g) The signat

As provided in time limitations imp administrative hearin within 60 (sixty) days administrative disp incorporating the ag F.S. If mediation term parties in writing that remain available for apply for challenging In addition to person may petition Administrator's 45 (f object to issuance o were raised with rea this notice, unless impracticable to-ra objection arose afte not stay the effectv 213, F.A.C. Petitions Section 7661d(b)(2) Washington, D.C. 20 A complete p a.m. to 5:00 p.m.; M

Permitting Authority Department of Env Bureau of Air Regul 111 South Magnolia Tallahassee, Florida Telephone: 904/488 Fax: 904/922-6979

Affected District/Lc Florida Department Southwest District G 8407 Laurel Fair Cir Tampa, Florida 336 Telephone: 813/74 Fax: 813/744-6084

The comple submitted by the interested persons additional inform

A379 - 6-18-1997

- LEVEL/TRANSIT Manufactured by David White, has new tripod. Like new. \$375. Call 858-8275
- LEVEL TRANSIT Mig'd by Topcon, A-T-F7, auto level w/tripod & 14ft. 6" fiberglass collapsing stick. \$325. or best offer. 859-6933
- LEVEL TRANSIT Manufactured by Topcon, A-T-F7, auto level/ tripod & 14ft. 6" fiberglass collapsing stick, \$325 or best offer. 859-6933
- MACHINISTS TOOLS - New/Used Style indicators, combination mikes, combination sets, combination square. \$800. Call 425-3185.
- MACHINISTS TOOLS (Guages) Like new. \$130 or best offer. Call 644-9190
- Matco Work Station All drawers 26" deep. \$2200/or offer/or trade for truck or boat. 941-676-8581
- MIG WELDER Millermatic With Lead. Exc. Cond. \$900/best offer. Call 680-1460
- PANEL SAW Black & Deck er/Dewalt. Heavy duty. 10 ft. \$750 Call 352-923-0781
- PLANER. Thickness 3 hp, 220V, 15". 500lbs. mobile base. exc. \$695/off. 551-9016 W. Haven
- SAW; 12 in. radial Excellent condition \$300. 941-424-2325
- SAW, COMPOUND MITER CRAFTSMAN. \$100. CALL 941-291-058
- SCROLL SAW, RB Industries, never used, also instructions, light & patterns. \$1,000. Call 859-2928
- TRAILER HITCH, heavy duty, for GMC Van or GM products. Complete. Like New! \$100. 665-2367.
- WELDER & GENERATOR Miller Portable. \$600 Call 752-6665
- WOODWORKING TOOLS, \$1,000 negotiable, Call 324-3034 after 1pm
- 8" DELTA BENCH DRILL PRESS Excellent Condition \$85.00. 815-0641



SELL IT!
Or We'll Run It Again
FREE!

3 lines, 7 days, \$10.00
If the item doesn't sell
we'll run it
14 more days FREE!

*Non-commercial - one item per ad, price must appear in the ad.
Applies to Tools!
For Sale category only
Expires 6/30/97

CALL NOW
Lakeland 687-7070
W. Haven 293-6823

The Ledger

477 Items To Trade

- BOAT, 16' center console, 140HP Mercury good cond. Will trade for Pontiac of equal value \$3,000. (941) 678-6210
- CADILLAC 4dr 1988 Sporty style. \$3000 or trade for pickup truck. Call 941-422-1057
- CHRYSLER LANCE '88 Turbo charged, auto. Exc. cond! trade for Honda Goldwing of equal value. 687-2021.
- ELECTRIC GRILL used once. \$100 or trade for computer monitor. Call 683-6990.
- HOLIDAY IMPERIAL '85 33' New engine. All extras. Exc. cond. \$20,000. Will take partial trade for auto, 4x4, or boat. 291-0970
- IBM 386 DX40 4MG Ram, 100MG HD with SVGA monitor, \$300 or trade for 7 859-6676 aft 5pm
- NISSAN 280ZX TURBO, '80 Value \$3,000. Trade for 4-door car of equal value. 299-3561 after 6pm
- SUZUKI, '85 1200 cc motorcycle, 4K mi, needs cosmetics. \$1400 or trade for truck or car. 647-0841



SELL IT!
Or We'll Run It Again
FREE!

3 lines, 7 days, \$10.00
If the item doesn't sell
we'll run it
14 more days FREE!

*Non-commercial - one item per ad, price must appear in the ad.
Applies to Items To Trade.
For Sale category only.
Expires 6/30/97

CALL NOW
Lakeland 687-7070
W. Haven 293-6823

The Ledger



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

June 3, 1997

Mr. Ronald W. Tomlin
Assistant Managing Director
Lakeland Electric & Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5079

Re: DRAFT Title V Permit No.: 1050004-003-AV
C. D. McIntosh, Jr. Power Plant

Dear Mr. Tomlin:

One copy of the DRAFT Title V Air Operation Permit for the C. D. McIntosh, Jr. Power Plant located at 3030 East Lake Parker Drive, Lakeland, Polk County, is enclosed. The permitting authority's "INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" and the "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" are also included.

The "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT" must be published within 30 (thirty) days of receipt of this letter. Proof of publication, i.e., newspaper affidavit, must be provided to the Department's Bureau of Air Regulation office within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit.

Please submit any written comments you wish to have considered concerning the permitting authority's proposed action to Scott M. Sheplak at the above letterhead address. If you have any other questions, please contact Edward Svec at 904/488-1344.

Sincerely,

C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/s
Enclosures

cc: Ms. Gracy R. Danois, U.S. Environmental Protection Agency, Region 4
(INTERNET E-mail Memorandum)

In the Matter of an
Application for Permit by:

Lakeland Electric & Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5079

DRAFT Permit No.: 1060004-003-AV
C. D. McIntosh, Jr. Power Plant
Polk County

INTENT TO ISSUE TITLE V AIR OPERATION PERMIT

The Department of Environmental Protection (permitting authority) gives notice of its intent to issue a Title V air operation permit (copy of DRAFT Permit enclosed) for the Title V source detailed in the application specified above, for the reasons stated below.

The applicant, Lakeland Electric & Water Utilities, applied on June 14, 1996, to the permitting authority for a Title V air operation permit for the C. D. McIntosh, Jr. Power Plant located at 3030 East Lake Parker Drive, Lakeland, Polk County.

The permitting authority has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. This source is not exempt from Title V permitting procedures. The permitting authority has determined that a Title V air operation permit is required to commence or continue operations at the described facility.

The permitting authority intends to issue this Title V air operation permit based on the belief that reasonable assurances have been provided to indicate that operation of the source will not adversely impact air quality, and the source will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-256, 62-257, 62-281, 62-296, and 62-297, F.A.C.

Pursuant to Sections 403.815 and 403.0872, F.S., and Rules 62-103.150 and 62-210.350(3), F.A.C., you (the applicant) are required to publish at your own expense the enclosed "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT." The notice shall be published one time only within 30 (thirty) days in the legal advertisement section of a newspaper of general circulation in the area affected. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. Where there is more than one newspaper of general circulation in the county, the newspaper used must be one with significant circulation in the area that may be affected by the permit. If you are uncertain that a newspaper meets these requirements, please contact the permitting authority at the address or telephone number listed below. The applicant shall provide proof of publication to the Department's Bureau of Air Regulation, 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400 (Telephone: 904/488-1344; Fax: 904/922-6979), within 7 (seven) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit pursuant to Rule 62-103.150(6), F.A.C.

The permitting authority will issue the Title V PROPOSED Permit, and subsequent Title V FINAL Permit, in accordance with the conditions of the enclosed Title V DRAFT Permit unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The permitting authority will accept written comments concerning the proposed permit issuance action for a period of 30 (thirty) days from the date of publication of "PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT." Written comments should be provided to the permitting authority office. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this DRAFT Permit, the permitting authority shall issue a Revised DRAFT Permit and require, if applicable, another Public Notice.

The permitting authority will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57, F.S., or a party requests mediation as an alternative remedy under Section 120.573, before the deadline for filing a petition. Choosing mediation will not adversely affect the right to a hearing if mediation does not result in a settlement. The procedures for petitioning for a hearing are set forth below, followed by the procedures for requesting mediation.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 904/488-9730; Fax: 904/487-4938). Petitions filed by the permit applicant or any of the parties listed below must be filed within 14 (fourteen) days of receipt of this notice of intent. Petitions filed by any other person must be filed within 14 (fourteen) days of publication of the public notice or within 14 (fourteen) days of receipt of this notice of intent, whichever occurs first. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition (or a request for mediation, as discussed below) within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-5.207, F.A.C.

A petition must contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Permit File Number, and the county in which the project is proposed;
- (b) A statement of how and when each petitioner received notice of the permitting authority's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the permitting authority's action or proposed action;
- (d) A statement of the material facts disputed by the petitioner, if any;

(e) A statement of the facts that the petitioner contends warrant reversal or modification of the permitting authority's action or proposed action;

(f) A statement identifying the rules or statutes that the petitioner contends require reversal or modification of the permitting authority's action or proposed action; and,

(g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the permitting authority to take with respect to the action or proposed action addressed in this notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A person whose substantial interests are affected by the permitting authority's proposed permitting decision, may elect to pursue mediation by asking all parties to the proceeding to agree to such mediation and by filing with the Department of Environmental Protection a request for mediation and the written agreement of all such parties to mediate the dispute. The request and agreement must be filed in (received by) the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, FL 32399-3000, by the same deadline as set forth above for the filing of a petition.

A request for mediation must contain the following information:

(a) The name, address, and telephone number of the person requesting mediation and that person's representative, if any;

(b) A statement of the preliminary agency action;

(c) A statement of the relief sought; and,

(d) Either an explanation of how the requester's substantial interests will be affected by the action or proposed action addressed in this notice of intent or a statement clearly identifying the petition for hearing that the requester has already filed, and incorporating it by reference.

The agreement to mediate must include the following:

(a) The names, addresses, and telephone numbers of any persons who may attend the mediation;

(b) The name, address, and telephone number of the mediator selected by the parties, or a provision for selecting a mediator within a specified time;

(c) The agreed allocation of the costs and fees associated with the mediation;

(d) The agreement of the parties on the confidentiality of discussions and documents introduced during mediation;

(e) The date, time, and place of the first mediation session, or a deadline for holding the first session, if no mediator has yet been chosen;

(f) The name of each party's representative who shall have authority to settle or recommend settlement; and,

(g) The signatures of all parties or their authorized representatives.

As provided in Section 120.573, F.S., the timely agreement of all parties to mediate will toll the time limitations imposed by Sections 120.569 and 120.57, F.S., for requesting and holding an administrative hearing. Unless otherwise agreed by the parties, the mediation must be concluded within 60 (sixty) days of the execution of the agreement. If mediation results in settlement of the administrative dispute, the Department of Environmental Protection must enter a Final Order incorporating the agreement of the parties in accordance with the provisions of Section 403.0872(7), F.S. If mediation terminates without settlement of the dispute, the permitting authority shall notify all parties in writing that the administrative hearing processes under Sections 120.569 and 120.57, F.S., remain available for disposition of the dispute, and the notice will specify the deadlines that then will apply for challenging the agency action and electing remedies under those two statutes.

In addition to the above, a person subject to regulation has a right to apply to the Department of Environmental Protection for a variance from or waiver of the requirements of particular rules, on certain conditions, under Section 120.542, F.S. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. The petition must specify the following information:

- (a) The name, address, and telephone number of the petitioner;
- (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;
- (c) Each rule or portion of a rule from which a variance or waiver is requested;
- (d) The citation to the statute underlying (implemented by) the rule identified in (c) above;
- (e) The type of action requested;
- (f) The specific facts that would justify a variance or waiver for the petitioner;
- (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and,
- (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in Section 120.542(2), F.S., and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the United States Environmental Protection Agency and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

Finally, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at 410 M. Street, SW, Washington, D.C. 20460.

Executed in Tallahassee, Florida.

**STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION**



C. H. Fancy, P.E.

Chief

Bureau of Air Regulation

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT (including the PUBLIC NOTICE and the DRAFT permit) and all copies were sent by certified mail before the close of business on 6/4/97 to the person(s) listed:

Mr. Ronald W. Tomlin, Lakeland Electric & Water Utilities

In addition, the undersigned duly designated deputy agency clerk hereby certifies that copies of this INTENT TO ISSUE TITLE V AIR OPERATION PERMIT (including the PUBLIC NOTICE and the DRAFT permit) were sent by U.S. mail on the same date to the person(s) listed:

Mr. Kennard Kosky, P.E., Golder Associates, Inc.
Mr. Bill Thomas, P.E., FDEP SWD

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

Barbara J. Boutwell 6/4/97
(Clerk) (Date)

PUBLIC NOTICE OF INTENT TO ISSUE TITLE V AIR OPERATION PERMIT

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

Title V DRAFT Permit No.: 1060004-003-AV
C. D. McIntosh, Jr. Power Plant
Polk County

The Department of Environmental Protection (permitting authority) gives notice of its intent to issue a Title V air operation permit to Lakeland Electric & Water Utilities for the C. D. McIntosh, Jr. Power Plant located at 3030 East Lake Parker Drive, Lakeland, Polk County. A case-by-case Maximum Achievable Control Technology (MACT) determination was not required in this permitting action. The applicant's name and address are: Lakeland Electric & Water Utilities, 501 East Lemon Street, Lakeland, Florida 33801-5079.

The permitting authority will issue the Title V PROPOSED Permit, and subsequent Title V FINAL Permit, in accordance with the conditions of the Title V DRAFT Permit unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The permitting authority will accept written comments concerning the proposed Title V DRAFT Permit issuance action for a period of 30 (thirty) days from the date of publication of this Notice. Written comments should be provided to the Department's Bureau of Air Regulation, 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this DRAFT Permit, the permitting authority shall issue a Revised DRAFT Permit and require, if applicable, another Public Notice.

The permitting authority will issue the permit unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57, Florida Statutes (F.S.), or a party requests mediation as an alternative remedy under Section 120.573, F.S., before the deadline for filing a petition. Choosing mediation will not adversely affect the right to a hearing if mediation does not result in a settlement. The procedures for petitioning for a hearing are set forth below, followed by the procedures for requesting mediation.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000 (Telephone: 904/488-9730; Fax: 904/487-4938). Petitions must be filed within 14 (fourteen) days of publication of the public notice or within 14 (fourteen) days of receipt of the notice of intent, whichever occurs first. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition (or a request for mediation, as discussed below) within the applicable time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-5.207 of the Florida Administrative Code.

A petition must contain the following information:

(a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Permit File Number, and the county in which the project is proposed;

(b) A statement of how and when each petitioner received notice of the permitting authority's action or proposed action;

(c) A statement of how each petitioner's substantial interests are affected by the permitting authority's action or proposed action;

(d) A statement of the material facts disputed by the petitioner, if any;

(e) A statement of the facts that the petitioner contends warrant reversal or modification of the permitting authority's action or proposed action;

(f) A statement identifying the rules or statutes that the petitioner contends require reversal or modification of the permitting authority's action or proposed action; and,

(g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the permitting authority to take with respect to the action or proposed action addressed in this notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A person whose substantial interests are affected by the permitting authority's proposed permitting decision, may elect to pursue mediation by asking all parties to the proceeding to agree to such mediation and by filing with the Department of Environmental Protection a request for mediation and the written agreement of all such parties to mediate the dispute. The request and agreement must be filed in (received by) the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, FL 32399-3000, by the same deadline as set forth above for the filing of a petition.

A request for mediation must contain the following information:

(a) The name, address, and telephone number of the person requesting mediation and that person's representative, if any;

(b) A statement of the preliminary agency action;

(c) A statement of the relief sought; and,

(d) Either an explanation of how the requester's substantial interests will be affected by the action or proposed action addressed in this notice of intent or a statement clearly identifying the petition for hearing that the requester has already filed, and incorporating it by reference.

The agreement to mediate must include the following:

(a) The names, addresses, and telephone numbers of any persons who may attend the mediation;

(b) The name, address, and telephone number of the mediator selected by the parties, or a provision for selecting a mediator within a specified time;

(c) The agreed allocation of the costs and fees associated with the mediation;

(d) The agreement of the parties on the confidentiality of discussions and documents introduced during mediation;

(e) The date, time, and place of the first mediation session, or a deadline for holding the first session, if no mediator has yet been chosen;

(f) The name of each party's representative who shall have authority to settle or recommend settlement; and,

(g) The signatures of all parties or their authorized representatives.

As provided in Section 120.573, F.S., the timely agreement of all parties to mediate will toll the time limitations imposed by Sections 120.569 and 120.57, F.S., for requesting and holding an administrative hearing. Unless otherwise agreed by the parties, the mediation must be concluded within

60 (sixty) days of the execution of the agreement. If mediation results in settlement of the administrative dispute, the Department of Environmental Protection must enter an order incorporating the agreement of the parties in accordance with the provisions of Section 403.0872(7), F.S. If mediation terminates without settlement of the dispute, the permitting authority shall notify all parties in writing that the administrative hearing processes under Sections 120.569 and 120.57, F.S., remain available for disposition of the dispute, and the notice will specify the deadlines that then will apply for challenging the agency action and electing remedies under those two statutes.

In addition to the above, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at 410 M. Street, SW, Washington, D.C. 20460.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:


Permitting Authority:

Department of Environmental Protection
Bureau of Air Regulation
111 South Magnolia Drive, Suite 4
Tallahassee, Florida 32301
Telephone: 904/488-1344
Fax: 904/922-6979

Affected District/Local Program:

Florida Department of Environmental Protection
Southwest District Office
8407 Laurel Fair Circle
Tampa, Florida 33619
Telephone: 813/744-6100
Fax: 813/744-6084

The complete project file includes the Draft Permit, the application, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact Scott M. Sheplak, P.E., at the above address, or call 904/488-1344, for additional information.



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary


P.E. Certification Statement

Permittee:
Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

Project type: Initial Title V Air Operation Permit

I HEREBY CERTIFY that the engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including but not limited to the electrical, mechanical, structural, hydrological, and geological features).

 06/03/97
Scott M. Sheplak, P.E. date
Registration Number: 0048866

Permitting Authority:
Department of Environmental Protection
Bureau of Air Regulation
111 South Magnolia Drive, Suite 4
Tallahassee, Florida 32301
Telephone: 904/488-1344
Fax: 904/922-6979

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant
Facility ID No.: 1050004
Polk County

Initial Title V Air Operation Permit
DRAFT Permit No.: 1050004-003-AV

Permitting Authority:
State of Florida
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Title V Section

Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Telephone: 904/488-1344
Fax: 904/922-6979

June 3, 1997

Initial Title V Air Operation Permit
DRAFT Permit No.: 1050004-003-AV

Table of Contents

<u>Section</u>	<u>Page Number</u>
Placard Page	1
I. Facility Information	2 - 3
A. Facility Description.	
B. Summary of Emissions Unit ID Nos. and Brief Descriptions.	
C. Relevant Documents.	
II. Facility-wide Conditions	4 - 5
III. Emissions Units and Conditions	
A. Emissions Unit -001 McIntosh Unit 1	6 - 16
B. Emissions Units -002 Diesel Engine Peaking Unit 2	17 - 21
-003 Diesel Engine Peaking Unit 3	
C. Emissions Unit -004 Gas Turbine Peaking Unit 1	22 - 27
D. Emissions Unit -005 McIntosh Unit 2	28 - 44
E. Emissions Unit -006 McIntosh Unit 3	45 - 63
IV. Acid Rain Part	
A. Acid Rain, Phase II	64 - 65
B. Acid Rain, Phase I	66



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

Permittee:
Lakeland Electric & Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5079

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004
SIC Nos.: 49, 4911
Project: Initial Title V Air Operation Permit

This permit is for the operation of the C. D. McIntosh, Jr. Power Plant. This facility is located at 3030 East Lake Parker Drive, Lakeland, Polk County; UTM Coordinates: Zone 17, 409.0 km East and 3106.2 km North; Latitude: 28° 04' 50" North and Longitude: 81° 55' 32" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix U-1, List of Unregulated Emissions Units and/or Activities
Appendix E-1, List of Exempt Emissions Units and/or Activities
APPENDIX TV-1, TITLE V CONDITIONS (version dated 02/27/97)
APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)
TABLE 297.310-1, CALIBRATION SCHEDULE (version dated 10/07/96)
FIGURE 1 - SUMMARY REPORT-GASEOUS AND OPACITY EXCESS EMISSION AND
MONITORING SYSTEM PERFORMANCE REPORT (version dated 07/96)
Phase II Acid Rain Application/Compliance Plan received 12/18/95
Phase I Acid Rain permit dated 03/27/97
Alternate Sampling Procedure: ASP Number 97-B-01

Effective Date: January 1, 1998
Renewal Application Due Date: July 5, 2002
Expiration Date: December 31, 2002

Howard L. Rhodes, Director
Division of Air Resources
Management

HLR/sms/es

Section I. Facility Information.

Subsection A. Facility Description.

This facility consists of three fossil fuel fired steam generators, two diesel powered generators, and one gas turbine. Fossil fuel fired steam generators 1 and 2 are fired with No. 6 fuel oil and natural gas with distillate oil used as an ignitor. Fossil fuel fired steam generator 3 is primarily fired with coal, refuse derived fuel and petroleum coke.

Also included in this permit are miscellaneous unregulated/exempt emissions units and/or activities.

Based on the initial Title V permit application received June 14, 1996, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).

E.U.

ID No.

Brief Description

-001	McIntosh Unit 1 - Fossil Fuel Fired Steam Generator
-002	Diesel Engine Peaking Unit 2
-003	Diesel Engine Peaking Unit 3
-004	Gas Turbine Peaking Unit 1
-005	McIntosh Unit 2 - Fossil Fuel Fired Steam Generator
-006	McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

Unregulated Emissions Units and/or Activities

E.U.

<u>ID No.</u>	<u>Brief Description of Emissions Units and/or Activity</u>
-xxx	Tanks with greater than 10,000 gallon capacity installed prior to July 23, 1984
-xxx	Diesel drive coal tunnel sump engine
-xxx	Fire water UPS diesel No. 31
-xxx	Fire water UPS diesel No. 32
-xxx	CT startup diesel
-xxx	General purpose diesel engines (< 32,000 gal/yr)
-xxx	Emergency generators (< 32,000 gal/yr)
-xxx	General purpose painting (< 6 gal/month average)
-xxx	Parts Cleaning
-xxx	Sand Blasting (Maintenance only)
-xxx	Wastewater Treatment Tank
-xxx	Three Cooling Towers (Unit 2 and 3)
-xxx	Northside Waste Water Treatment Facility - Wastewater treatment processes and tanks
-xxx	Northside Waste Water Treatment Facility - Two emergency diesel generators
-xxx	Northside Waste Water Treatment Facility - Chemical and petroleum storage
-xxx	Northside Waste Water Treatment Facility - Miscellaneous activities

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit, however, are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms
Table 2-1, Summary of Compliance Requirements
Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers
Appendix H-1, Permit History / ID Number Changes

These documents are on file with permitting authority:

Initial Title V Permit Application received June, 14, 1996
Additional Information Request dated January 13, 1997
Additional Information Response received February 10, 1997

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

1. APPENDIX TV-1, TITLE V CONDITIONS (version dated 02/27/97), is a part of this permit. {Permitting note: APPENDIX TV-1, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}

2. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.
[Rule 62-296.320(2), F.A.C.]

3. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity).
[Rule 62-296.320(4)(b)1., F.A.C.]

4. Prevention of Accidental Releases (Section 112(r) of CAA). If required by 40 CFR 68, the permittee shall submit to the implementing agency:
a. a risk management plan (RMP) when, and if, such requirement becomes applicable; and
b. certification forms and/or RMPs according to the promulgated rule schedule.
[40 CFR 68]

5. Unregulated Emissions Units and/or Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.
[Rule 62-213.440(1), F.A.C.]

6. Exempt Emissions Units and/or Activities. Appendix E-1, List of Exempt Emissions Units and/or Activities, is a part of this permit.
[Rules 62-213.440(1), 62-213.430(6), and 62-4.040(1)(b), F.A.C.]

7. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. Containers shall be kept closed and stored in weather-tight buildings.
[Rule 62-296.320(1)(a), F.A.C.; Proposed by applicant in the initial Title V permit application received June 14, 1996]

8. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include: maintenance of paved areas; regular mowing of grass and care of vegetation; limiting access to plant property by unnecessary vehicles; application of water to paved and unpaved roads and open stockpiles where active handling occurs; removal of dust from roads to limit particulate re-entrainment; use of vacuum trucks for ash cleaning when performing plant maintenance; and, enclosing, where practical, areas of paint removal.

[Rule 62-296.320(4)(c)2., F.A.C.; Proposed by applicant in the initial Title V permit application received June 14, 1996]

9. The permittee shall submit all compliance related notifications and reports required of this permit to the Department's Southwest District office.

III. Emissions Section Unit.

Subsection A. This section addresses the following emissions unit(s).

E.U.

ID No. Brief Description

-001 McIntosh Unit 1 - Fossil Fuel Fired Steam Generator

McIntosh Unit 1 is a forced draft boiler rated at a nominal load of 90 megawatts. The unit is fired with natural gas at a maximum heat input rate of 985 million Btu per hour (approximately 970 million cubic feet per hour), or No. 6 fuel oil, having a maximum sulfur content of 2.5 percent by weight, at a maximum heat input rate of 950 million Btu per hour (approximately 6,300 gallons per hour). This unit is also permitted to burn "on-specification" used oil generated by the City of Lakeland, at a maximum heat input rate of 950 million Btu per hour. McIntosh Unit 1 began commercial service in February, 1971.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; and Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with More than 250 million Btu per Hour Heat Input.}

The following specific conditions apply to the emissions unit listed above:

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum operation heat input rate is as follows:

<u>Unit No.</u>	<u>MMBtu/hr Heat Input</u>	<u>Fuel Type</u>
1	985	Natural Gas
	950	No. 6 Fuel Oil
	950	Used Oil

When a blend of fuel oil, "on-specification" used oil or natural gas is fired, the heat input is prorated based on the percent heat input of each fuel.

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.]

A.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **A.23.**

[Rule 62-297.310(2), F.A.C.]

A.3. Methods of Operation. Fuels.

a. Startup: The only fuel allowed to be burned is propane.

b. Normal: The only fuels allowed to be burned are natural gas, No. 6 Fuel Oil, On-Specification Used Oil and combinations of natural gas, No. 6 Fuel Oil and/or On-Specification Used Oil.

[Rule 62-213.410, F.A.C.]

A.4. Hours of Operation. This emissions unit may operate continuously, i.e., 8,760 hours/year.
[Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.5. Visible Emissions. Visible emissions shall not exceed 20 percent opacity, except for one two-minute period per hour during which opacity shall not exceed 40 percent. Emissions units governed by this visible emissions limit shall compliance test for particulate matter emissions annually and as otherwise required by Chapter 62-297, F.A.C.
[Rule 62-296.405(1)(a), F.A.C.]

A.6. Visible Emissions - Soot Blowing and Load Change. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.
[Rule 62-210.700(3), F.A.C.]

A.7. Particulate Matter. Particulate matter emissions shall not exceed 0.1 pound per million Btu heat input, as measured by applicable compliance methods.
[Rule 62-296.405(1)(b), F.A.C.]

A.8. Particulate Matter - Soot Blowing and Load Change. Particulate matter emissions shall not exceed an average of 0.3 pound per million Btu heat input during the 3-hours in any 24-hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.
[Rule 62-210.700(3), F.A.C.]

A.9. Sulfur Dioxide. When burning liquid fuel, sulfur dioxide emissions shall not exceed 2.75 pounds per million Btu heat input, as measured by applicable compliance methods.
[Rule 62-296.405(1) (c)1.j., F.A.C.]

A.10. Sulfur Dioxide - Sulfur Content. The No. 6 fuel oil sulfur content shall not exceed 2.5 percent, by weight. See specific condition **A.21**.
[Rule 62-296.405(1)(e)3., F.A.C.; and, AO 53-243945]

A.11. "On-Specification" Used Oil. Only "on-specification" used oil generated by the City of Lakeland shall be fired in this unit. The quantity fired in this unit shall not exceed 1,000 barrels (42,000 gallons) per calendar year. "On-specification" used oil is defined as used oil that meets the 40 CFR 279 (Standards for the Management of Used Oil) specifications listed below. Used oil that does not meet all of the following specifications is considered "off-specification" oil and shall not be fired.

<u>CONSTITUENT / PROPERTY*</u>	<u>ALLOWABLE LEVEL</u>
Arsenic	5 ppm maximum
Cadmium	2 ppm maximum
Chromium	10 ppm maximum
Lead	100 ppm maximum
Total Halogens	1000 ppm maximum
Flash Point	100 °F minimum
PCBs	less than 50 ppm

* As determined by ASTM Standard D140-70, or equivalent
[40 CFR 279.11; and, AO 53-243945]

Excess Emissions

A.12. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

A.13. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.
[Rule 62-210.700(2), F.A.C.]

A.14. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

A.15. Sulfur Dioxide. The permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit that will be verified with a fuel analysis provided by the vendor upon each fuel delivery. This protocol is allowed because the emissions unit does not have an operating flue gas desulfurization device. See specific conditions **A.10., A.20. and A.21.**

A.16. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.17. Visible emissions. The test method for visible emissions shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. A transmissometer may be used and calibrated according to Rule 62-297.520, F.A.C. See specific condition **A.18.**

[Rule 62-296.405(1)(e)1., F.A.C.]

A.18. DEP Method 9. The provisions of EPA Method 9 (40 CFR 60, Appendix A) are adopted by reference with the following exceptions:

1. EPA Method 9, Section 2.4, Recording Observations. Opacity observations shall be made and recorded by a certified observer at sequential fifteen second intervals during the required period of observation.
2. EPA Method 9, Section 2.5, Data Reduction. For a set of observations to be acceptable, the observer shall have made and recorded, or verified the recording of, at least 90 percent of the possible individual observations during the required observation period. For single-valued opacity standards (e.g., 20 percent opacity), the test result shall be the highest valid six-minute average for the set of observations taken. For multiple-valued opacity standards (e.g., 20 percent opacity, except that an opacity of 40 percent is permissible for not more than two minutes per hour) opacity shall be computed as follows:
 - a. For the basic part of the standard (i.e., 20 percent opacity) the opacity shall be determined as specified above for a single-valued opacity standard.
 - b. For the short-term average part of the standard, opacity shall be the highest valid short-term average (i.e., two-minute, three-minute average) for the set of observations taken.

In order to be valid, any required average (i.e., a six-minute or two-minute average) shall be based on all of the valid observations in the sequential subset of observations selected, and the selected subset shall contain at least 90 percent of the observations possible for the required averaging time. Each required average shall be calculated by summing the opacity value of each of the valid observations in the appropriate subset, dividing this sum by the number of valid observations in the subset, and rounding the result to the nearest whole number. The number of missing observations in the subset shall be indicated in parenthesis after the subset average value.

[Rule 62-297.401, F.A.C.]

A.19. Particulate Matter. The test methods for particulate emissions shall be EPA Methods 17, 5, 5B, or 5F, incorporated by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. EPA Method 5 may be used with filter temperature no more than 320 degrees Fahrenheit. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. The owner or operator may use EPA Method 5 to demonstrate compliance. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen based F-factor, computed according to EPA Method 19, is used in lieu of heat input. Acetone wash shall be used with EPA Method 5 or 17.

[Rules 62-296.405(1)(e)2. and 62-297.401, F.A.C.]

A.20. Sulfur Dioxide. The test methods for sulfur dioxide emissions shall be EPA Methods 6, 6A, 6B, or 6C, incorporated by reference in Chapter 62-297, F.A.C. Fuel sampling and analysis may be used as an alternate sampling procedure if such a procedure is incorporated into the operation permit for the emissions unit. If the emissions unit obtains an alternate procedure under the provisions of Rule 62-297.620, F.A.C., the procedure shall become a condition of the emissions unit's permit. The Department will retain the authority to require EPA Method 6 or 6C if it has reason to believe that exceedences of the sulfur dioxide emissions limiting standard are occurring. Results of an approved fuel sampling and analysis program shall have the same effect as EPA Method 6 test results for purposes of demonstrating compliance or noncompliance with sulfur dioxide standards. **The permittee may use the EPA test methods, referenced above, to demonstrate compliance; however, as an alternate sampling procedure authorized by permit, the permittee elected to demonstrate compliance by accepting a liquid fuel sulfur limit that will be verified with a fuel analysis provided by the vendor upon each fuel delivery.** See specific conditions **A.10. and A.21.**

[Rules 62-213.440, 62-296.405(1)(e)3. and 62-297.401, F.A.C.; and, AO 53-243945]

A.21. The fuel sulfur content, percent by weight, for liquid fuels shall be evaluated using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91.

[Rules 62-213.440, 62-296.405(1)(e)3., 62-296.405(1)(f)1.b. and 62-297.440, F.A.C.]

A.22. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

A.23. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

A.24. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

A.25. Applicable Test Procedures.

(a) **Required Sampling Time.**

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. **Opacity Compliance Tests.** When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) **Minimum Sample Volume.** Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) **Required Flow Rate Range.** For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) **Calibration of Sampling Equipment.** Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached as part of this permit.

(e) **Allowed Modification to EPA Method 5.** When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

A.26. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

A.27. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid for more than 400 hours other than during startup.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.]

A.28. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

A.29. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

A.30. Compliance with the “on-specification” used oil requirements will be determined from a sample collected from each batch (1,000 gallons minimum) delivered for firing. See specific condition **A.11**.

[AO 53-243945]

Record keeping and Reporting Requirements

A.31. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department or the appropriate Local Program.

[Rule 62-210.700(6), F.A.C.]

A.32. Submit to the Department a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.

[Rules 62-213.440 and 62-296.405(1)(g), F.A.C.]

A.33. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.

8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rules 62-213.440 and 62-297.310(8), F.A.C.]

A.34. Records shall be kept of each delivery of “on-specification” used oil with a statement of the origin of the used oil and the quantity delivered/stored for firing. In addition, monthly records shall be kept of the quantity of “on-specification” used oil fired in this unit. The above records shall be maintained in a form suitable for inspection, retained for a minimum of five years, and be made available upon request.

[Rule 62-213.440(1)(b)2.b., F.A.C.; and, AO 53-243945]

A.35. The permittee shall include in the “Annual Operating Report for Air Pollutant Emitting Facility” a summary of the “on-specification” used oil analyses for the calendar year and a statement of the total quantity of “on-specification” used oil fired in Unit 1 during the calendar year.

[AO 53-243945]

Section III. Emissions Unit(s) and Conditions.

Subsection B. This section addresses the following emissions unit(s).

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-002	Diesel Engine Peaking Unit 2
-003	Diesel Engine Peaking Unit 3

Diesel Engine Peaking Units 2 and 3 are diesel fired internal combustion engines which each drives a generator capable of producing electric power at a maximum rating of 2.5 megawatts. These units are each fired on No. 2 fuel oil, with a maximum sulfur content of 0.5 percent by weight, at a maximum firing rate of 201.6 gallons per hour. This corresponds to a maximum heat input of 28 million Btu per hour. Diesel Engine Peaking Units 2 and 3 began commercial service in 1970.

{Permitting note(s): The emissions units are regulated under Rule 62-210.300, F.A.C., Permits Required. Each diesel engine peaking unit has its own stack.}

The following specific conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

B.1. Permitted Capacity. The maximum firing rate of each diesel engine peaking unit is 201.6 gallons per hour firing No. 2 fuel oil.
[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

B.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **B.13.**
[Rule 62-297.310(2), F.A.C.]

B.3. Methods of Operation - Fuels. Only distillate (No. 2) fuel oil shall be fired in the diesel engine peaking units.
[Rule 62-213.410, F.A.C.]

B.4. Hours of Operation. These emissions units may operate continuously, i.e., 8,760 hours/year.
[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; and, AO 53-244726]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

B.5. Visible Emissions. Visible emissions from each diesel engine peaking unit shall not be equal to or greater than 20 percent opacity.
[Rule 62-296.320(4)(b)1., F.A.C.; and, AO 53-244726]

B.6. Not federally enforceable. Sulfur Dioxide - Sulfur Content. The sulfur content of the No. 2 fuel oil shall not exceed 0.5 percent, by weight.
[AO 53-244726]

Excess Emissions

B. 7. Excess emissions from these emissions units resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

B. 8. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

B.9. The permittee shall demonstrate compliance with the liquid fuel sulfur limit by means of a fuel analysis provided by the vendor upon each fuel delivery. See specific condition **B.12.**
[Rule 62-213.440, F.A.C.]

B.10. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

B.11. The test method for visible emissions shall be EPA Method 9, adopted and incorporated by reference in Rule 62-204.800, F.A.C., and referenced in Chapter 62-297, F.A.C.

[Rules 62-204.800, 62-296.320(4)(b)4.a. and 62-297.401, F.A.C.]

B.12. The fuel sulfur content, percent by weight, for liquid fuels shall be evaluated using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91.

[Rules 62-213.440 and 62-297.440, F.A.C.; and, AO 53-244726]

B.13. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

B.14. Applicable Test Procedures.

(a) Required Sampling Time.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

- c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

[Rule 62-297.310(4)(a)2.c., F.A.C.]

B.15. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

- a. Did not operate; or
- b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and, AO 53-244726]

Recordkeeping and Reporting Requirements

B.16. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

B.17. Test Reports

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

[Rule 62-297.310(8), F.A.C.]

Section III. Emissions Unit(s) and Conditions.

Subsection C. This section addresses the following emissions unit(s).

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-004	Gas Turbine Peaking Unit 1

Gas Turbine Peaking Unit 1 consists of a gas turbine which drives a generator producing electrical power at a maximum rated output of 20 megawatts. The gas turbine is fired with natural gas, or No. 2 fuel oil with a maximum sulfur content of 0.5 percent by weight. The maximum fuel firing rate is 320 million cubic feet per hour of natural gas (approximately 330 million Btu per hour) or 2,310 gallons per hour of No. 2 fuel oil (approximately 320 million Btu per hour). Gas Turbine Peaking Unit 1 began commercial service in 1973.

{Permitting notes: This emissions unit is regulated under Rule 62-210.300, F.A.C., Permits Required. This unit is not subject to 40 CFR 60, Subpart GG, Standards of Performance for New Stationary Gas Turbines.}

The following specific conditions apply to the emissions units listed above:

Essential Potential to Emit (PTE) Parameters

C.1. Permitted Capacity. The maximum firing rate of the turbine is 320 million cubic feet per hour when firing natural gas or 2,310 gallons per hour when firing No. 2 fuel oil.
[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.]

C.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **C.13.**
[Rule 62-297.310(2), F.A.C.]

C.3. Methods of Operation - Fuels. Only natural gas or distillate (No. 2) fuel oil shall be fired in the combustion turbine.
[Rule 62-213.410, F.A.C.]

C.4. Hours of Operation. These emissions unit(s) may operate continuously, i.e., 8,760 hours/year.
[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; and, AO 53-244727]

Emission Limitations and Standards

{Permitting Note: The attached Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

C.5. Visible Emissions. Visible emissions from each turbine shall not be equal to or greater than 20 percent opacity.
[Rule 62-296.320(4)(b)1., F.A.C.; and, AO 53-244727]

C.6. Not federally enforceable. Sulfur Dioxide - Sulfur Content. The sulfur content of the No. 2 fuel oil shall not exceed 0.5 percent, by weight.
[AO 53-244727]

Excess Emissions

C.7. Excess emissions from these emissions units resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

C.8. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

C.9. The permittee shall demonstrate compliance with the liquid fuel sulfur limit by means of a fuel analysis provided by the vendor upon each fuel delivery. See specific condition **C.12.**
[Rule 62-213.440, F.A.C.]

C.10. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting Note: The attached Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

C.11. The test method for visible emissions shall be EPA Method 9, adopted and incorporated by reference in Rule 62-204.800, F.A.C., and referenced in Chapter 62-297, F.A.C.

[Rules 62-204.800, 62-296.320(4)(b)4.a. and 62-297.401, F.A.C.]

C.12. The fuel sulfur content, percent by weight, for liquid fuels shall be evaluated using either ASTM D2622-92, ASTM D4294-90, or both ASTM D4057-88 and ASTM D129-91.

[Rules 62-213.440 and 62-297.440, F.A.C.; and, AO 53-244727]

C.13. Not federally enforceable. Operating Rate During Testing.

Testing of emissions shall be conducted with the emissions unit operating at permitted capacity, which is defined as 95-100 percent of the manufacturer's rated heat input achievable for the average ambient (or conditioned) air temperature during the test. If it is impracticable to test at capacity, then sources may be tested at less than capacity. In such cases, the entire heat input vs. inlet temperature curve will be adjusted by the increment equal to the difference between the design heat input value and 105 percent of the value reached during the test. Data, curves, and calculations necessary to demonstrate the heat input rate correction at both design and test conditions shall be submitted to the Department with the compliance test report.

[Requested in initial Title V permit application response for additional information dated February 10, 1997];

C.14. Applicable Test Procedures.

(a) Required Sampling Time.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

- c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

[Rule 62-297.310(4)(a)2.c., F.A.C.]

C.15. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

- a. Did not operate; or
- b. In the case of a fuel burning emissions unit, burned liquid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

- a. Visible emissions, if there is an applicable standard;

8. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; and AO 53-244727]

C.16. Visible Emissions Testing - Annual. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuels; or
- b. gaseous fuels in combination with any amount of liquid fuels for less than 400 hours per year; or
- c. only liquid fuels for less than 400 hours per year.

[Rules 62-297.310(7)(a)4. & 8., F.A.C.]

Recordkeeping and Reporting Requirements

C.17. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.

[Rule 62-210.700(6), F.A.C.]

C.18. Test Reports.

- (a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
- (b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

[Rule 62-297.310(8), F.A.C.]

Section III. Emissions Unit(s) and Conditions.

Subsection D. This section addresses the following emissions unit(s).

E.U.

ID No. Brief Description

-005 McIntosh Unit 2 - Fossil Fuel Fired Steam Generator

McIntosh Unit 2 is a nominal 114.7 megawatt (electric) fossil fuel fired steam generator. The unit is fired on low sulfur No. 6 or No. 2 fuel oil with a maximum heat input of 1,115 million Btu per hour, or natural gas with a maximum heat input of 1,184.5 million Btu per hour. McIntosh Unit 2 began commercial service in June, 1976.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; and NSPS - 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.}

The following conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

D.1. Permitted Capacity. The maximum operation heat input rate is as follows:

<u>Unit No.</u>	<u>MMBtu/hr Heat Input</u>	<u>Fuel Type</u>
2	1,184.5	Natural Gas
	1,115	No. 6 Fuel Oil
	1,115	No. 2 Fuel Oil

When a blend of fuel oil and natural gas is fired, the heat input is prorated based on the percent heat input of each fuel.

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.]

D.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **D.19.**

[Rule 62-297.310(2), F.A.C.]

D.3. Methods of Operation. Fuels.

a. Startup: The only fuel allowed to be burned is propane.

b. Normal: The only fuels allowed to be burned are natural gas, No. 6 Fuel Oil, No. 2 Fuel Oil and combinations of natural gas, No. 6 Fuel Oil and/or No. 2 Fuel Oil.

[Rule 62-213.410, F.A.C.]

D.4. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year.
[Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

Particulate Matter

D.5. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which:

- (1) Contain particulate matter in excess of 43 nanograms per joule heat input (0.10 lb per million Btu) derived from fossil fuel or fossil fuel and wood residue.
- (2) Exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

[40 CFR 60.42(a)(1) & (2)]

D.6. Visible Emissions - Soot Blowing and Load Change. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.
A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.
[Rule 62-210.700(3), F.A.C.]

Sulfur Dioxide

D.7. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain sulfur dioxide in excess of:

- (1) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel.

[40 CFR 60.43(a)(1)]

D.8. Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.
[40 CFR 60.43(c)]

Nitrogen Oxides

D.9. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain nitrogen oxides, expressed as NO₂ in excess of:

- (1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel.
 - (2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel.
- [40 CFR 60.44(a)(1) & (2)]

D.10. When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined

by proration using the following formula:

$$PS_{NO_x} = \frac{w(260)+x(86)+y(130)+z(300)}{w+x+y+z}$$

where:

PS_{NO_x} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;

w = is the percentage of total heat input derived from lignite;

x = is the percentage of total heat input derived from gaseous fossil fuel;

y = is the percentage of total heat input derived from liquid fossil fuel; and,

z = is the percentage of total heat input derived from solid fossil fuel (except lignite).

[40 CFR 60.44(b)]

Excess Emissions

D.11. Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(2) Sulfur dioxide. Excess emissions for affected facilities are defined as:

- (i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under 40 CFR 60.43.

(3) Nitrogen oxides. Excess emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under 40 CFR 60.44.

[40 CFR 60.45(g)(1), (2), & (3)]

D.12. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

D.13. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

[Rule 62-210.700(2), F.A.C.]

D.14. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

D.15. Determination of Process Variables.

(a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

D.16. In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in Appendix A of 40 CFR 60 or other methods and procedures as specified in 40 CFR 60.46, except as provided in 40 CFR 60.8(b). Acceptable alternative methods and procedures are given in 40 CFR 60.46(d).
[40 CFR 60.46(a)]

D.17. The owner or operator shall determine compliance with the particulate matter, SO₂, and NO_x standards in 40 CFR 60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of particulate matter, SO₂, or NO_x shall be computed for each run using the following equation:

$$E = C F_d (20.9)/(20.9 - \% O_2)$$

E = emission rate of pollutant, ng/J (1b/million Btu).

C = concentration of pollutant, ng/dscm (1b/dscf).

% O₂ = oxygen concentration, percent dry basis.

F_d = factor as determined from Method 19.

(2) Method 5 shall be used to determine the particulate matter concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train may be set to provide a gas temperature no greater than 160 ± 14 °C (320 ± 25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O₂ concentration for the run shall be the arithmetic mean of all the individual O₂ sample concentrations at each traverse point.

(iii) If the particulate run has more than 12 traverse points, the O₂ traverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O₂ traverse points.

(3) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.

- (4) Method 6 shall be used to determine the SO₂ concentration.
- (i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.
 - (ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be taken simultaneously with, and at the same point as, the SO₂ sample. The SO₂ emission rate shall be computed for each pair of SO₂ and O₂ samples. The SO₂ emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.
- (5) Method 7 shall be used to determine the NO_x concentration.
- (i) The sampling site and location shall be the same as for the SO₂ sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.
 - (ii) For each NO_x sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The sample shall be taken simultaneously with, and at the same point as, the NO_x sample.
 - (iii) The NO_x emission rate shall be computed for each pair of NO_x and O₂ samples. The NO_x emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.

[40 CFR 60.46(b)(1), (2), (3), (4), & (5)]

D.18. When combinations of fossil fuels are fired, the owner or operator (in order to compute the prorated standard as shown in 40 CFR 60.44(b)) shall determine the percentage (w, x, y, or z) of the total heat input derived from each type of fuel as follows:

- (1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.
- (2) ASTM Methods D 240-76 (liquid fuels), or D 1826-77 (gaseous fuels) (incorporated by reference-see 40 CFR 60.17) shall be used to determine the gross calorific values of the fuels.
- (3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.

[40 CFR 60.46(c)(1), (2), & (3)]

D.19. The owner or operator may use the following as alternatives to the reference methods and procedures in 40 CFR 60.46 or in other sections as specified:

(1) The emission rate (E) of particulate matter, SO₂ and NO_x may be determined by using the F_c factor, provided that the following procedure is used:

(i) The emission rate (E) shall be computed using the following equation:

$$E = C F_c (100 / \% \text{ CO}_2)$$

where:

E = emission rate of pollutant, ng/J (lb/million Btu).

C = concentration of pollutant, ng/dscm (lb/dscf).

% CO₂ = carbon dioxide concentration, percent dry basis.

F_c = factor as determined in appropriate sections of Method 19.

(ii) If and only if the average F_c factor in Method 19 is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B shall be used to determine the O₂ and CO₂ concentration according to the procedures in 40 CFR 60.46(b) (2)(ii), (4)(ii), or (5)(ii). Then if F_o (average of three runs), as calculated from the equation in Method 3B, is more than ± 3 percent than the average F_o value, as determined from the average values of F_d and F_c in Method 19, i.e., $F_{oa} = 0.209 (F_{da} / F_{ca})$, then the following procedure shall be followed:

(A) When F_o is less than 0.97 F_{oa}, then E shall be increased by that proportion under 0.97 F_{oa}, e.g., if F_o is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When F_o is less than 0.97 F_{oa} and when the average difference (\bar{d}) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under 0.97 F_{oa}, e.g., if F_o is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When F_o is greater than 1.03 F_{oa} and when \bar{d} is positive, then E shall be decreased by that proportion over 1.03 F_{oa}, e.g., if F_o is 1.05 F_{oa}, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B, Method 17 may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of 160 °C (320 °F). Method 17 shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

- (3) Particulate matter and SO₂ may be determined simultaneously with the Method 5 train provided that the following changes are made:
- (i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 is used in place of the condenser (section 2.1.7) of Method 5.
 - (ii) All applicable procedures in Method 8 for the determination of SO₂ (including moisture) are used.
- (4) For Method 6, Method 6C may be used. Method 6A may also be used whenever Methods 6 and 3B data are specified to determine the SO₂ emission rate, under the conditions in 40 CFR 60.46(d)(1).
- (5) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the O₂ concentration (%O₂) for the emission rate correction factor.
- (6) For Method 3, Method 3A or 3B may be used.
- (7) For Method 3B, Method 3A may be used.
- [40 CFR 60.46(d)(1), (2), (3), (4), (5), (6), & (7)]

D.20. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

D.21. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

D.22. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.
[Rule 62-297.310(3), F.A.C.]

D.23. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

- a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.
- b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.
- c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached as part of this permit.

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.
[Rule 62-297.310(4), F.A.C.]

D.24. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

D.25. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.
[Rule 62-297.310(7), F.A.C.]

D.26. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

D.27. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

Continuous Monitoring Requirements

D.28. The owner or operator shall install, calibrate, maintain, and operate continuous monitoring systems for measuring the opacity of emissions, ~~sulfur dioxide emissions, and oxygen.~~
[40 CFR 60.45(a) & ~~(b)~~]

~~D.29.~~ For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:

- (1) Methods 6, 7, and 3B, as applicable, shall be used for the performance evaluations of sulfur dioxide continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B are given in 40 CFR 60.46(d).
- (2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of Appendix B to 40 CFR 60.
- (3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent and for a continuous monitoring system measuring sulfur oxides or nitrogen oxides the span value shall be determined as follows:

[In parts per million]

Fossil fuel	Span value for sulfur dioxide	Span value for nitrogen oxides
Gas.....	{1}	500
Liquid.....	1,000	500
Solid.....	1,500	1000
Combinations.....	$1,000y+1,500z$	$500(x+y)+1,000z$

{1} Not applicable.

where:

- x = the fraction of total heat input derived from gaseous fossil fuel, and
- y = the fraction of total heat input derived from liquid fossil fuel, and
- z = the fraction of total heat input derived from solid fossil fuel.

(4) All span values computed under 40 CFR 60.45(c)(3) for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm.

[40 CFR 60.45(c)(1), (2), (3), & (4)]

~~D.30.~~ For any continuous monitoring system installed under 40 CFR 60.45(a), the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/million Btu):

- (1) When a continuous monitoring system for measuring oxygen is selected, the measurement of the pollutant concentration and oxygen concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF[20.9/(20.9 - \text{percent } O_2)]$$

where:

E, C, F, and % O₂ are determined under 40 CFR 60.45(f).

[40 CFR 60.45(e)(1)]

~~D-31.~~ The values used in the equations under 40 CFR 60.45(e) (1) are derived as follows:

- (1) E = pollutant emissions, ng/J (lb/million Btu).
- (2) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^4 M ng/dscm per ppm (2.59×10^{-9} M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for sulfur dioxide and 46.01 for nitrogen oxides.
- (3) % O₂, % CO₂ = oxygen or carbon dioxide volume (expressed as percent), determined with equipment specified under 40 CFR 60.45(a).
- (4) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:
 - (iii) For liquid fossil fuels including crude, residual, and distillate oils, $F = 2.476 \times 10^{-7}$ dscm/J (9,220 dscf/million Btu) and $F_c = 0.384 \times 10^{-7}$ scm CO₂ /J (1,430 scf CO₂ /million Btu).
 - (iv) For gaseous fossil fuels, $F = 2.347 \times 10^{-7}$ dscm/J (8,740 dscf/million Btu). For natural gas, propane, and butane fuels, $F_c = 0.279 \times 10^{-7}$ scm CO₂ /J (1,040 scf CO₂ /million Btu) for natural gas, 0.322×10^{-7} scm CO₂ /J (1,200 scf CO₂ /million Btu) for propane, and 0.338×10^{-7} scm CO₂ /J (1,260 scf CO₂ /million Btu) for butane.
- (5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/million Btu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO₂ /J, or scf CO₂ /million Btu) on either basis in lieu of the F or F_c factors specified in 40 CFR 60.45(f)(4):

$$F = 10^{-6} \frac{[227.2 (\text{pct. H}) + 95.5 (\text{pct. C}) + 35.6 (\text{pct. S}) + 8.7 (\text{pct. N}) - 28.7 (\text{pct. O})]}{\text{GCV}}$$

$$F_c = \frac{2.0 \times 10^{-5} (\text{pct. C})}{\text{GCV}} \\ (\text{SI units})$$

$$F = 10^6 \frac{3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O)}{GCV}$$

(English units)

$$F_c = \frac{20.0(\%C)}{GCV}$$

(SI units)

$$F_c = \frac{321 \times 10^3 (\%C)}{GCV}$$

(English units)

(i) H, C, S, N, and O are content by weight of hydrogen, carbon, sulfur, nitrogen, and oxygen (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM method D3178-74 or D3176 (solid fuels) or computed from results using ASTM method D1137-53(75), D1945-64(76), or D1946-77 (gaseous fuels) as applicable. (These five methods are incorporated by reference-see 40 CFR 60.17.)

(ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015-77 for solid fuels and D1826-77 for gaseous fuels as applicable. (These two methods are incorporated by reference-see 40 CFR 60.17.)

(6) For affected facilities firing combinations of fossil fuels, the F or F_c factors determined by paragraphs 40 CFR 60.45(f)(4) or (f)(5) shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

where:

X_i = the fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.)

F_i or (F_c)_i = the applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section.

n = the number of fuels being burned in combination.

[40 CFR 60.45(f)(1), (2), (3), (4), (5), & (6)]

Recordkeeping and Reporting Requirements

D.32. Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c).
[40 CFR 60.45(g)]

D.33. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.
Rule 62-210.700(6), F.A.C.]

D.34. Submit to the Department a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.
[Rules 62-213.440 and 62-296.405(1) (g), F.A.C.]

D.35. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.

6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

Miscellaneous Requirements.

D.36. Definitions. For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.
[40 CFR 60.2; and, Rule 62-204.800(7)(a), F.A.C.]

D.37. Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.
[40 CFR 60.12]

Section III. Emissions Unit(s) and Conditions.

Subsection E. This section addresses the following emissions unit(s).

E.U.

ID No. **Brief Description**

-006 McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

McIntosh Unit 3 is a nominal 364 megawatt (electric) fossil fuel fired steam generator. The unit is fired on coal, residual oil, natural gas and co-fires refuse derived fuel (RDF) and petroleum coke. The maximum heat input rate is 3,640 million Btu per hour. Unit 3 is equipped with an electrostatic precipitator (ESP), a flue gas desulfurization system (FGD), and low-NO_x burners to control emissions. McIntosh Unit 3 began commercial service in September, 1982.

{Permitting note(s): The emissions unit is regulated under Acid Rain, Phase II; and NSPS - 40 CFR 60, Subpart D, Standards of Performance for Fossil-Fuel Fired Steam Generators for Which Construction is Commenced After August 17, 1971, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.; Rule 212.400(6), F.A.C., Prevention of Significant Deterioration (PSD); Rule 62-212.400(6), F.A.C., Best Available Control Technology (BACT) Determination }

The following conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

E.1. Capacity. The maximum heat input rate is 3,640 MMBtu per hour.
[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.]

E.2. Emissions Unit Operating Rate Limitation After Testing. See specific condition **E.21.**
[Rule 62-297.310(2), F.A.C.]

E.3. Methods of Operation - Fuels. The following fuels may be burned:

a. Startup: The only fuel allowed to be burned is propane.

b. Normal:

Coal only

Low sulfur fuel oil only (≤ 0.5 percent sulfur by weight)

Coal and up to 10 percent refuse (based on heat input)

Low sulfur fuel oil and up to 10 percent refuse (based on heat input)

Coal and up to 20 percent petroleum coke (based on weight)

Coal and up to 20 percent petroleum coke (based on weight) and 10 percent refuse
(based on heat input)

High sulfur fuel oil (> 0.5 percent sulfur by weight)

Natural gas only, or in combination with any of the other fuels or fuel combinations
listed above

[Rules 62-4.160(2), 62-210.200, and 62-213.440(1), F.A.C.; and, PSD-FL-008(B)]

E.4. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year.

[Rule 62-210.200(PTE), F.A.C.]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

Particulate Matter

E.5. Particulate matter emitted to the atmosphere from the boiler shall not exceed:

(1) <u>Mode of Firing</u>	<u>Pound / MMBtu Heat Input</u>
Coal	0.044
Coal/Petroleum Coke	0.044
Coal/Refuse	0.050
Coal/Petroleum Coke/Refuse	0.050
Oil	0.070
Oil/Refuse	0.075

(2) Exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

[40 CFR 60.42(a)(2); and, PSD-FL-008(B)]

E.6. Visible Emissions - Soot Blowing and Load Change. Visible emissions shall not exceed 60 percent opacity during the 3-hours in any 24 hour period of excess emissions allowed for boiler cleaning (soot blowing) and load change.

A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.

[Rule 62-210.700(3), F.A.C.]

Sulfur Dioxide

E.7. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain sulfur dioxide in excess of:

(1) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel or liquid fossil fuel and wood residue.

(2) 520 nanograms per joule heat input (1.2 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue, except as provided in 40 CFR 60.43(e).

[40 CFR 60.43(a)(1) and (2)]

E.8. When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the following formula:

$$PS_{SO_2} = [y(340) + z(520)] / (y+z)$$

where:

PS_{SO_2} is the prorated standard for sulfur dioxide when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired,

y is the percentage of total heat input derived from liquid fossil fuel, and

z is the percentage of total heat input derived from solid fossil fuel.

[40 CFR 60.43(b)]

E.9. Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

[40 CFR 60.43(c)]

Nitrogen Oxides

E.10. On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, no owner or operator subject to the provisions of 40 CFR 60, Subpart D, shall cause to be discharged into the atmosphere from any affected facility any gases which contain nitrogen oxides, expressed as NO₂ in excess of:

- (1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel.
- (2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.
- (3) 300 nanograms per joule heat input (0.70 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).

[40 CFR 60.44(a)(1), (2), & (3)]

E.11. Except as provided under paragraphs 40 CFR 60.44(c) and (d), when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

$$PS_{NOx} = \frac{w(260)+x(86)+y(130)+z(300)}{w+x+y+z}$$

where:

PS_{NOx} = is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired;

w = is the percentage of total heat input derived from lignite;

x = is the percentage of total heat input derived from gaseous fossil fuel;

y = is the percentage of total heat input derived from liquid fossil fuel; and,

z = is the percentage of total heat input derived from solid fossil fuel (except lignite).

[40 CFR 60.44(b)]

Excess Emissions

E.12. Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

- (1) Opacity. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

- (2) Sulfur dioxide. Excess emissions for affected facilities are defined as:
- (i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under 40 CFR 60.43.
- (3) Nitrogen oxides. Excess emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under 40 CFR 60.44.
[40 CFR 60.45(g)(1), (2), & (3)]

E.13. Excess emissions resulting from malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

E.14. Excess emissions resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.
[Rule 62-210.700(2), F.A.C.]

E.15. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

E.16. Determination of Process Variables.

- (a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- (b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.
[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

E.17. In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in Appendix A of 40 CFR 60 or other methods and procedures as specified in 40 CFR 60.46, except as provided in 40 CFR 60.8(b). Acceptable alternative methods and procedures are given in 40 CFR 60.46(d).
[40 CFR 60.46(a)]

E.18. The owner or operator shall determine compliance with the particulate matter, SO₂, and NO_x standards in 40 CFR 60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of particulate matter, SO₂, or NO_x shall be computed for each run using the following equation:

$$E = C F_d (20.9)/(20.9 - \% O_2)$$

E = emission rate of pollutant, ng/J (1b/million Btu).
C = concentration of pollutant, ng/dscm (1b/dscf).
% O₂ = oxygen concentration, percent dry basis.
F_d = factor as determined from Method 19.

(2) Method 5 shall be used to determine the particulate matter concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems and Method 5B shall be used to determine the particulate matter concentration (C) after FGD systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train may be set to provide a gas temperature no greater than 160 ± 14 °C (320 ± 25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O₂ concentration for the run shall be the arithmetic mean of all the individual O₂ sample concentrations at each traverse point.

(iii) If the particulate run has more than 12 traverse points, the O₂ traverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O₂ traverse points.

(3) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.

- (4) Method 6 shall be used to determine the SO₂ concentration.
- (i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.
 - (ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be taken simultaneously with, and at the same point as, the SO₂ sample. The SO₂ emission rate shall be computed for each pair of SO₂ and O₂ samples. The SO₂ emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.
- (5) Method 7 shall be used to determine the NO_x concentration.
- (i) The sampling site and location shall be the same as for the SO₂ sample. Each run shall consist of four grab samples, with each sample taken at about 15-minute intervals.
 - (ii) For each NO_x sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The sample shall be taken simultaneously with, and at the same point as, the NO_x sample.
 - (iii) The NO_x emission rate shall be computed for each pair of NO_x and O₂ samples. The NO_x emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.

[40 CFR 60.46(b)(1), (2), (3), (4), & (5)]

E.19. When combinations of fossil fuels or fossil fuel and wood residue are fired, the owner or operator (in order to compute the prorated standard as shown in 40 CFR 60.43(b) and 60.44(b)) shall determine the percentage (w, x, y, or z) of the total heat input derived from each type of fuel as follows:

- (1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.
- (2) ASTM Methods D 2015-77 (solid fuels), D 240-76 (liquid fuels), or D 1826-77 (gaseous fuels) (incorporated by reference-see 40 CFR 60.17) shall be used to determine the gross calorific values of the fuels. The method used to determine the calorific value of wood residue must be approved by the Administrator.
- (3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.

[40 CFR 60.46(c)(1), (2), & (3)]

E.20. The owner or operator may use the following as alternatives to the reference methods and procedures in 40 CFR 60.46 or in other sections as specified:

- (1) The emission rate (E) of particulate matter, SO₂ and NO_x may be determined by using the Fc factor, provided that the following procedure is used:

(i) The emission rate (E) shall be computed using the following equation:

$$E = C F_c (100 / \% \text{ CO}_2)$$

where:

E = emission rate of pollutant, ng/J (lb/million Btu).

C = concentration of pollutant, ng/dscm (lb/dscf).

% CO₂ = carbon dioxide concentration, percent dry basis.

F_c = factor as determined in appropriate sections of Method 19.

(ii) If and only if the average F_c factor in Method 19 is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B shall be used to determine the O₂ and CO₂ concentration according to the procedures in 40 CFR 60.46(b) (2)(ii), (4)(ii), or (5)(ii). Then if F_o (average of three runs), as calculated from the equation in Method 3B, is more than ± 3 percent than the average F_o value, as determined from the average values of F_d and F_c in Method 19, i.e., $F_{oa} = 0.209 (F_{da} / F_{ca})$, then the following procedure shall be followed:

(A) When F_o is less than 0.97 F_{oa}, then E shall be increased by that proportion under 0.97 F_{oa}, e.g., if F_o is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When F_o is less than 0.97 F_{oa} and when the average difference (\bar{d}) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under 0.97 F_{oa}, e.g., if F_o is 0.95 F_{oa}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When F_o is greater than 1.03 F_{oa} and when \bar{d} is positive, then E shall be decreased by that proportion over 1.03 F_{oa}, e.g., if F_o is 1.05 F_{oa}, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B, Method 17 may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of 160 °C (320 °F). The procedures of sections 2.1 and 2.3 of Method 5B may be used with Method 17 only if it is used after wet FGD systems. Method 17 shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

(3) Particulate matter and SO₂ may be determined simultaneously with the Method 5 train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 is used in place of the condenser (section 2.1.7) of Method 5.

(ii) All applicable procedures in Method 8 for the determination of SO₂ (including moisture) are used.

(4) For Method 6, Method 6C may be used. Method 6A may also be used whenever Methods 6 and 3B data are specified to determine the SO₂ emission rate, under the conditions in 40 CFR 60.46(d)(1).

(5) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the O₂ concentration (%O₂) for the emission rate correction factor.

(6) For Method 3, Method 3A or 3B may be used.

(7) For Method 3B, Method 3A may be used.

[40 CFR 60.46(d)(1), (2), (3), (4), (5), (6), & (7)]

E.21. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

E.22. Operating Rate During Testing. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity, which is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the emissions unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.

[Rules 62-297.310(2) & (2)(b), F.A.C.]

E.23. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.

[Rule 62-297.310(3), F.A.C.]

E.24. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.

b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, attached as part of this permit.

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]

E.25. Required Stack Sampling Facilities. When a mass emissions stack test is required, the permittee shall comply with the requirements contained in Appendix SS-1, Stack Sampling Facilities, attached to this permit.

[Rule 62-297.310(6), F.A.C.]

E.26. Frequency of Compliance Tests. The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required.

(a) General Compliance Testing.

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid and/or solid fuel for more than 400 hours other than during startup.
3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:
 - a. Did not operate; or
 - b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.
4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
 - a. Visible emissions, if there is an applicable standard;
 - b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
 - c. Each NESHAP pollutant, if there is an applicable emission standard.
5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.
9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.
[Rule 62-297.310(7), F.A.C.]

E.27. By this permit, annual emissions compliance testing for visible emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rule 62-297.310(7)(a)4., F.A.C.]

E.28. Annual and permit renewal compliance testing for particulate matter emissions is not required for these emissions units while burning:

- a. only gaseous fuel(s); or
- b. gaseous fuel(s) in combination with any amount of liquid fuel(s) for less than 400 hours per year; or
- c. only liquid fuel(s) for less than 400 hours per year.

[Rules 62-297.310(7)(a)3. & 5., F.A.C.; and, ASP Number 97-B-01.]

Continuous Monitoring Requirements

E.29. Each owner or operator shall install, calibrate, maintain, and operate continuous monitoring systems for measuring the opacity of emissions, sulfur dioxide emissions, nitrogen oxides emissions, and either oxygen or carbon dioxide except as provided in 40 CFR 60.45(b).
[40 CFR 60.45(a)]

E.30. Certain of the continuous monitoring system requirements under 40 CFR 60.45(a) do not apply to owners or operators under the following conditions:

(1) For a fossil fuel-fired steam generator that burns only gaseous fossil fuel, continuous monitoring systems for measuring the opacity of emissions and sulfur dioxide emissions are not required.

(2) For a fossil fuel-fired steam generator that does not use a flue gas desulfurization device, a continuous monitoring system for measuring sulfur dioxide emissions is not required if the owner or operator monitors sulfur dioxide emissions by fuel sampling and analysis under 40 CFR 60.45(d).

(3) Notwithstanding 40 CFR 60.13(b), installation of a continuous monitoring system for nitrogen oxides may be delayed until after the initial performance tests under 40 CFR 60.8 have been conducted. If the owner or operator demonstrates during the performance test that emissions of nitrogen oxides are less than 70 percent of the applicable standards in 40 CFR 60.44, a continuous monitoring system for measuring nitrogen oxides emissions is not required. If the initial performance test results show that nitrogen oxide emissions are greater than 70 percent of the applicable standard, the owner or operator shall install a continuous monitoring system for nitrogen oxides within one year after the date of the initial performance tests under 40 CFR 60.8 and comply with all other applicable monitoring requirements under 40 CFR 60.

(4) If an owner or operator does not install any continuous monitoring systems for sulfur oxides and nitrogen oxides, as provided under 40 CFR 60.45(b)(1) and (b)(3) or (b)(2) and (b)(3), a continuous monitoring system for measuring either oxygen or carbon dioxide is not required. [40 CFR 60.45(b)(1), (2), (3), & (4)]

E.31. For performance evaluations under 40 CFR 60.13(c) and calibration checks under 40 CFR 60.13(d), the following procedures shall be used:

(1) Methods 6, 7, and 3B, as applicable, shall be used for the performance evaluations of sulfur dioxide and nitrogen oxides continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B are given in 40 CFR 60.46(d).

(2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of Appendix B to 40 CFR 60.

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent and for a continuous monitoring system measuring sulfur oxides or nitrogen oxides the span value shall be determined as follows:

[In parts per million]

Fossil fuel	Span value for sulfur dioxide	Span value for nitrogen oxides
Gas.....	{1}	500
Liquid.....	1,000	500
Solid.....	1,500	1000
Combinations.....	1,000y+1,500z	500(x+y)+1,000z

{1} Not applicable.

where:

x = the fraction of total heat input derived from gaseous fossil fuel, and
 y = the fraction of total heat input derived from liquid fossil fuel, and
 z = the fraction of total heat input derived from solid fossil fuel.

(4) All span values computed under 40 CFR 60.45(c)(3) for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm.

(5) For a fossil fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all continuous monitoring systems shall be subject to the Administrator's approval.

[40 CFR 60.45(c)(1), (2), (3), (4), & (5)]

E.32. For any continuous monitoring system installed under 40 CFR 60.45(a), the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/million Btu):

(1) When a continuous monitoring system for measuring oxygen is selected, the measurement of the pollutant concentration and oxygen concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E = CF[20.9/(20.9-\text{percent O}_2)]$$

where:

E, C, F, and % O₂ are determined under 40 CFR 60.45(f).

(2) When a continuous monitoring system for measuring carbon dioxide is selected, the measurement of the pollutant concentration and carbon dioxide concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E = CF_c [100/\text{percent CO}_2]$$

where:

E, C, F_c and % CO_2 are determined under 40 CFR 60.45(f).
[40 CFR 60.45(e)(1) and (2)]

E.33. The values used in the equations under 40 CFR 60.45(e) (1) and (2) are derived as follows:

(1) E = pollutant emissions, ng/J (lb/million Btu).

(2) C = pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15×10^4 M ng/dscm per ppm (2.59×10^{-9} M lb/dscf per ppm) where M = pollutant molecular weight, g/g-mole (lb/lb-mole). M = 64.07 for sulfur dioxide and 46.01 for nitrogen oxides.

(3) % O_2 , % CO_2 = oxygen or carbon dioxide volume (expressed as percent), determined with equipment specified under 40 CFR 60.45(a).

(4) F, F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:

(i) For anthracite coal as classified according to ASTM D388-77 (incorporated by reference-see 40 CFR 60.17), $F = 2,723 \times 10^{-17}$ dscm/J (10,140 dscf/million Btu and $F_c = 0.532 \times 10^{-17}$ scm CO_2 /J (1,980 scf CO_2 /million Btu).

(ii) For subbituminous and bituminous coal as classified according to ASTM D388-77 (incorporated by reference-see 40 CFR 60.17), $F = 2.637 \times 10^{-7}$ dscm/J (9,820 dscf/million Btu) and $F_c = 0.486 \times 10^{-7}$ scm CO_2 /J (1,810 scf CO_2 /million Btu).

(iii) For liquid fossil fuels including crude, residual, and distillate oils, $F = 2.476 \times 10^{-7}$ dscm/J (9,220 dscf/million Btu) and $F_c = 0.384 \times 10^{-7}$ scm CO_2 /J (1,430 scf CO_2 /million Btu).

(iv) For gaseous fossil fuels, $F = 2.347 \times 10^{-7}$ dscm/J (8,740 dscf/million Btu). For natural gas, propane, and butane fuels, $F_c = 0.279 \times 10^{-7}$ scm CO_2 /J (1,040 scf CO_2 /million Btu) for natural gas, 0.322×10^{-7} scm CO_2 /J (1,200 scf CO_2 /million Btu) for propane, and 0.338×10^{-7} scm CO_2 /J (1,260 scf CO_2 /million Btu) for butane.

(5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/million Btu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO₂ /J, or scf CO₂ /million Btu) on either basis in lieu of the F or F_c factors specified in 40 CFR 60.45(f)(4):

$$F = 10^{-6} \frac{[227.2 (\text{pct. H}) + 95.5 (\text{pct. C}) + 35.6 (\text{pct. S}) + 8.7 (\text{pct. N}) - 28.7 (\text{pct. O})]}{\text{GCV}}$$

$$F_c = \frac{2.0 \times 10^{-5} (\text{pct. C})}{\text{GCV}} \\ (\text{SI units})$$

$$F = 10^6 \frac{3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O)}{\text{GCV}} \\ (\text{English units})$$

$$F_c = \frac{20.0(\%C)}{\text{GCV}} \\ (\text{SI units})$$

$$F_c = \frac{321 \times 10^3 (\%C)}{\text{GCV}} \\ (\text{English units})$$

(i) H, C, S, N, and O are content by weight of hydrogen, carbon, sulfur, nitrogen, and oxygen (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM method D3178-74 or D3176 (solid fuels) or computed from results using ASTM method D1137-53(75), D1945-64(76), or D1946-77 (gaseous fuels) as applicable. (These five methods are incorporated by reference-see 40 CFR 60.17.)

(ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015-77 for solid fuels and D1826-77 for gaseous fuels as applicable. (These two methods are incorporated by reference-see 40 CFR 60.17.)

(iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F_c value shall be subject to the Administrator's approval.

(6) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or F_c factors determined by paragraphs 40 CFR 60.45(f)(4) or (f)(5) shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \quad \text{or} \quad F_c = \sum_{i=1}^n X_i (F_c)_i$$

where:

X_i = the fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.)

F_i or $(F_c)_i$ = the applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section.

n = the number of fuels being burned in combination.

[40 CFR 60.45(f)(1), (2), (3), (4), (5), & (6)]

Recordkeeping and Reporting Requirements

E.34. Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in 40 CFR 60.7(c). The summary report form shall contain the information and be in the format shown in figure 1 (attached to this permit) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

[40 CFR 60.7(d) & 60.45(g)]

E.35. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.
Rule 62-210.700(6), F.A.C.]

E.36. Submit to the Department a written report of emissions in excess of emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The nature and cause of the excess emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file by the Source for a period of five years.

[Rules 62-213.440 and 62-296.405(1) (g), F.A.C.]

E.37. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.

21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

Miscellaneous Requirements.

E.38. Definitions. For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.

[40 CFR 60.2; and, Rule 62-204.800(7)(a), F.A.C.]

E.39. Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

Section IV. This section is the Acid Rain Part.

Operated by:

ORIS code: 676

Subsection A. This subsection addresses Acid Rain, Phase II.

The emissions unit(s) listed below are regulated under Acid Rain, Phase II.

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-001	Boiler - McIntosh Unit 1
-005	Boiler - McIntosh Unit 2
-006	Boiler - McIntosh Unit 3

A.1. The Phase II permit application(s) submitted for this facility, as approved by the Department, [is/are] a part of this permit. The owners and operators of these Phase II acid rain unit(s) must comply with the standard requirements and special provisions set forth in the application(s) listed below:

- a. DEP Form No. 62-210.900(1)(a), dated 07/01/95.
[Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

A.2. Sulfur dioxide (SO₂) allowance allocations and nitrogen oxide (NO_x) requirements for each Acid Rain unit is as follows: [insert appropriate table. Table format:

<u>E.U. ID</u> No.	EPA ID	Year	2000	2001	2002
-001	No. 01	SO2 allowances, under Table 2 or 3 of 40 CFR Part 73	897*	897*	897*
		NOx limit	**	**	**
-005	No. 02	SO2 allowances, under Table 2 or 3 of 40 CFR Part 73	1019*	1019*	1019*
		NOx limit	**	**	**
-006	No. 03	SO2 allowances, under Table 2 or 3 of 40 CFR Part 73	9848*	9848*	9848*
		NOx limit	**	**	**

* The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 or 3 of 40 CFR 73.]

** If applicable, by January 1, 1999, this Part will be reopened to add NOx requirements in accordance with the regulations implementing section 407 of the Clean Air Act.

A.3. Comments, notes, and justifications: none

Subsection B. This subsection addresses Acid Rain, Phase I.

{Permitting note: The U.S. EPA issues Acid Rain Phase I permit(s)}

The emissions unit listed below is regulated under Acid Rain Part, Phase I

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-006	Boiler - McIntosh Unit 3

The provisions of the federal Acid Rain, Phase I permit(s), including Early Election Plans for NO_x, govern(s) the above listed emissions unit(s) from the date of issuance of this Title V permit through December 31, 1999. The provisions of the Phase II permit govern(s) those emissions unit(s) from January 1, 2000 through the expiration date of this Title V permit. The Phase II permit governs all other affected units for the effective period of this permit.

B.1. The Phase I permit(s), including Early Election Plans for NO_x, issued by the U.S. EPA, is a part of this permit. The owners and operators of these Phase I acid rain unit(s) must comply with the standard requirements and special provisions set forth in the permit(s) listed below:

- a. Phase I permit dated 03/27/97.
[Chapter 62-213, F.A.C.]

B.2. Comments, notes, and justifications: none

Appendix H-1, Permit History/ID Number Changes

City of Lakeland
C. D. McIntosh

[DRAFT/PROPOSED/FINAL]Permit No.: 1050004-003-AV
Facility ID No.: 1050004

Permit History (for tracking purposes):

E.U.

<u>ID No</u>	<u>Description</u>	<u>Permit No.</u>	<u>Issue Date</u>	<u>Expiration Date</u>	<u>Extended Date</u> ^{1,2}	<u>Revised Date(s)</u>
-001	Boiler Unit #1	AO53-243945	03/23/95	05/27/99		
-002	Peaking Unit 2 (Diesel Engine)	AO53-244726	06/01/94	05/27/99		
-003	Peaking Unit 3 (Diesel Engine)	AO53-244726	06/01/94	05/27/99		
-004	Gas Turbine Peaking Unit 1	AO53-244727	06/01/94	05/27/99		
-005	Unit 2 Electric Generator	AO53-174090	04/17/90	04/13/95	08/14/96	
-006	McIntosh Unit 3 Coal/MSW Fired	PSD-FL-008 PSD-FL-008A PSD-FL-008B PA74-06SR	12/27/78 12/11/95 12/07/78			

(if applicable) ID Number Changes (for tracking purposes):

From: Facility ID No.: 40TPA530004

To: Facility ID No.: 1050004

Notes:

1 - AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

2 - AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96.

{Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. [I-001] **Brief Description** McIntosh Unit 1 - Fossil Fuel Fired Steam Generator

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
VE	All	8,760	20% w/ 40% for 2 min/hr					62-296.405(1)(a),FAC	III.A.5.
VE	All		60% 3 hrs/24 hrs					62-210.700(3),FAC	III.A.5.
PM	Gas	8,760	0.1 lb/MMBtu			98.5	431.4	62-296.405(1)(b),FAC	III.A.7.
PM	Oil	8,760	0.1 lb/MMBtu			95.0	416.1	62-296.405(1)(b),FAC	III.A.7.
PM	Gas	1,095	0.3 lb/MMBtu			295.5	161.8	62-210.700(3),FAC	III.A.8.
PM	Oil	1,095	0.3 lb/MMBtu			285.0	156.0	62-210.700(3),FAC	III.A.8.
SO ₂	Oil	8,760	2.75 lb/MMBtu			2,612.5	11,442.8	62-296.405(1)(c)1.j.,FAC	III.A.9.
SO ₂	Oil	8,760	2.5% S by weight			2,612.5	11,442.8	AO 53-243945	III.A.10.
Arsenic	Used Oil		5 ppm (42,000 gal/yr)				0.0008	AO 53-243945	III.A.11.
Cadmium	Used Oil		2 ppm (42,000 gal/yr)				0.0003	AO 53-243945	III.A.11.
Chromium	Used Oil		10 ppm (42,000 gal/yr)				0.0017	AO 53-243945	III.A.11.
Lead	Used Oil		100 ppm (42,000 gal/yr)				0.017	AO 53-243945	III.A.11.
Total Halogens	Used Oil		1,000 ppm (42,000 gal/yr)				0.17	AO 53-243945	III.A.11.
PCBs	Used Oil		<50 ppm (42,000 gal/yr)				0.0084	AO 53-243945	III.A.11.

Notes:

* The "Equivalent Emissions" listed are for informational purposes only.

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
 C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
 Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
[-002]	Diesel Engine Peaking Unit 2
[-003]	Diesel Engine Peaking Unit 3

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
VE	All	8,760	< 20%					62-296.320(4)(b)1., FAC	III.B.5.
SO ₂	Oil	8,760	0.5% S by weight			15.4	67.5	AO 53-244726	III.B.6.

Notes:

* The "Equivalent Emissions" listed are for informational purposes only.

{electronic file name: 10500041.xls}

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
 C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
 [-004] Gas Turbine Peaking Unit 1

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
VE	All	8,760	< 20%					62-296.320(4)(b)1., FAC AO 53-244727	III.C.5. III.C.6.
SO ₂	Oil	8,760	0.5% S by weight			176.0	770.9		

Notes:
 * The "Equivalent Emissions" listed are for informational purposes only.

[electronic file name: 10500041.xls]

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-005] McIntosh Unit 2 - Fossil Fuel Fired Steam Generator

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
PM	Gas	8,760	0.10 lb/MMBtu			118.5	518.8	40 CFR 60.42(a)(1)	III.D.5.
PM	Oil	8,760	0.10 lb/MMBtu			111.5	488.4	40 CFR 60.42(a)(1)	III.D.5.
VE	All	8,760	20% w/ 27% for 6 min/hr					40 CFR 60.42(a)(2)	III.D.5.
VE	All		60% 3 hrs/24 hrs					62-210.700(3),FAC	III.D.6.
SO ₂	Oil	8,760	0.80 lb/MMBtu			892.0	3,907.0	40 CFR 60.43(a)(1)	III.D.7.
NO _x	Gas	8,760	0.20 lb/MMBtu			236.9	1,037.6	40 CFR 60.44(a)(1)	III.D.9.
NO _x	Oil	8,760	0.30 lb/MMBtu			355.4	1,556.4	40 CFR 60.44(a)(2)	III.D.9.

Notes:
[electronic file name: 10500041.xls]

[electronic file name: xxxxxxx1.xls]

Table 1-1, Summary of Air Pollutant Standards and Terms

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-006] McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

Pollutant Name	Fuel(s)	Hours/Year	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See permit condition(s)
			Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
PM	Coal	8,760	0.044 lb/MMBtu			160.2	701.5	PSD-FL-008(B)	III.E.5.
PM	Coal/Pet Coke	8,760	0.044 lb/MMBtu			160.2	701.5	PSD-FL-008(B)	III.E.5.
PM	Coal/RDF	8,760	0.050 lb/MMBtu			182.0	701.5	PSD-FL-008(B)	III.E.5.
PM	Coal/Pet Coke/RDF	8,760	0.050 lb/MMBtu			182.0	797.2	PSD-FL-008(B)	III.E.5.
PM	Oil	8,760	0.070 lb/MMBtu			254.8	1,116.0	PSD-FL-008(B)	III.E.5.
PM	Oil/RDF	8,760	0.075 lb/MMBtu			273.0	1,195.7	PSD-FL-008(B)	III.E.5.
VE	All	8,760	20% w/ 27% for 6 min/hr					40 CFR 60.42(a)(2)	III.E.5.
VE	All		60% 3 hrs/24 hrs					62-210.700(3),FAC	III.E.6.
SO ₂	Oil	8,760	0.80 lb/MMBtu			2,912.0	12,754.6	40 CFR 60.43(a)(1)	III.E.7.
SO ₂	Solid	8,760	1.2 lb/MMBtu			4,368.0	19,131.8	40 CFR 60.43(a)(2)	III.E.7.
NO _x	Gas	8,760	0.20 lb/MMBtu			728.0	3,188.6	40 CFR 60.44(a)(1)	III.E.10..
NO _x	Liquid	8,760	0.30 lb/MMBtu			1,092.0	4,783.0	40 CFR 60.44(a)(2)	III.E.10..
NO _x	Solid	8,760	0.70 lb/MMBtu			2,548.0	11,160.2	40 CFR 60.44(a)(3)	III.E.10..

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.

[electronic file name: 10500041.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
 C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. [001] **Brief Description** McIntosh Unit 1 - Fossil Fuel Fired Steam Generator

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS **	See permit condition(s)
VE	Gas	DEP Method 9	Renewal	1-Jul	60 minutes		III.A.17. & 18. & 28.
VE	Oil	DEP Method 9	Annual	1-Jul	60 minutes		III.A.17. & 18. & 28.
PM	Gas	EPA Method 17, 5, 5B, or 5F	ASP No. 97-B-01	1-Jul	1 hour		III.A.19. & 29.
PM	Oil	EPA Method 17, 5, 5B, or 5F	Annual	1-Jul	1 hour		III.A.19. & 29.
SO ₂	Oil	EPA Method 6, 6A, 6B, or 6C	Annual	1-Jul	1 hour		III.A.15. & 20. & 27.
SO ₂	Oil	2.5% S by weight	Each Delivery				III.A.15. & 20. & 21.
Arsenic	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Cadmium	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Chromium	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Lead	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Total Halogens	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
Flash Point	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.
PCBs	Used Oil	ASTM Standard D140-70	Each Delivery				III.A.11. & 30. & 34.

Notes:
 * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
 ** CMS [=] continuous monitoring system

[electronic file name: 10500042.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
[-002]	Diesel Engine Peaking Unit 2
[-003]	Diesel Engine Peaking Unit 3

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS ¹ *	See permit condition(s)

Notes:
 * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
 **CMS | = | continuous monitoring system

[electronic file name: 10500042.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-004] Gas Turbine Peaking Unit 1

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
VE	Oil	EPA Method 9	Annual	1-Aug	30 minutes		III.B.11. & 15. & 16.
SO ₂	Oil	0.5% S by weight	Each Delivery				III.C.6. & 9. & 12.

Notes:
 * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
 **CMS [=] continuous monitoring system

[electronic file name: 10500042.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-005] McIntosh Unit 2 - Fossil Fuel Fired Steam Generator

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	See permit condition(s)	
						CMS **	
PM	Gas	EPA Method 17, 5, or 5B	ASP No. 97-B-01	23-Jun	1 hour		III.D.17. & 19. & 27.
PM	Oil	EPA Method 17, 5, or 5B	Annual	23-Jun	1 hour		III.D.17. & 19. & 27.
VE	Gas	EPA Method 9	Renewal	23-Jun	60 minutes	Yes	III.D.17. & 26.
VE	Oil	EPA Method 9	Annual	23-Jun	60 minutes	Yes	III.D.17. & 26.
SO ₂	Oil	EPA Method 6, 6A, or 6C	Annual	23-Jun	1 hour	Yes	III.D.17. & 19.
NO _x	All	EPA Method 7, 7A, 7C, 7D, or 7E	Annual	23-Jun	1 hour		III.D.17. & 19.

Notes:
 * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
 ** CMS [=] continuous monitoring system

[electronic file name: 10500042.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No. **Brief Description**
[-006] McIntosh Unit 3 - Fossil Fuel Fired Steam Generator

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	See permit condition(s)	
						CMS**	
PM	Gas Only	EPA Method 17, 5, or 5B	ASP No. 97-B-01	23-Jun	1 hour		III.E.18. & 20. & 28.
PM	All Other	EPA Method 17, 5, or 5B	Annual	23-Jun	1 hour		III.E.18. & 19. & 20. & 28.
VE	Gas Only	EPA Method 9	Renewal	23-Jun	60 minutes	Yes	III.D.17. & 26.
VE	All Other	EPA Method 9	Annual	23-Jun	60 minutes	Yes	III.D.17. & 26.
SO ₂	Liquid & Solid	EPA Method 6, 6A, or 6C	Annual	23-Jun	1 hour	Yes	III.E.18. & 19. & 20.
NO _x	All	EPA Method 7, 7A, 7C, 7D, or 7E	Annual	23-Jun	1 hour	Yes	III.E.18. & 19. & 20.

Notes:
 * The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
 ** CMS [=] continuous monitoring system

electronic file name: 10500042.xls

Appendix U-1, List of Unregulated Emissions Units and/or Activities.

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

Unregulated Emissions Units and/or Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither ‘regulated emissions units’ nor ‘exempt emissions units’.

E.U. ID

<u>No.</u>	<u>Brief Description of Emissions Units and/or Activity</u>
-xxx	Tanks with greater than 10,000 gallon capacity installed prior to July 23, 1984
-xxx	Diesel drive coal tunnel sump engine
-xxx	Fire water UPS diesel No. 31
-xxx	Fire water UPS diesel No. 32
-xxx	CT startup diesel
-xxx	General purpose diesel engines (< 32,000 gal/yr)
-xxx	Emergency generators (< 32,000 gal/yr)
-xxx	General purpose painting (< 6 gal/month average)
-xxx	Parts Cleaning
-xxx	Sand Blasting (Maintenance only)
-xxx	Wastewater Treatment Tank
-xxx	Three Cooling Towers (Unit 2 and 3)
-xxx	Northside Waste Water Treatment Facility - Wastewater treatment processes and tanks
-xxx	Northside Waste Water Treatment Facility - Two emergency diesel generators
-xxx	Northside Waste Water Treatment Facility - Chemical and petroleum storage
-xxx	Northside Waste Water Treatment Facility - Miscellaneous activities

[electronic file name: 1050004u.doc]

Appendix E-1, List of Exempt Emissions Units and/or Activities.

Lakeland Electric & Water Utilities
C. D. McIntosh, Jr. Power Plant

DRAFT Permit No.: 1050004-003-AV
Facility ID No.: 1050004

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Full Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining whether a facility containing such emissions units or activities would be subject to any applicable requirements. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., are also exempt from the permitting requirements of Chapter 62-213, F.A.C., provided such emissions units and activities also meet the exemption criteria of Rule 62-213.430(6)(b), F.A.C. The below listed emissions units and/or activities are hereby exempt pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities

1. Diesel Storage Tank (T-021)
2. Heavy Oil Tank (T-113)
3. Heavy Oil Tank (T-114)
4. Heavy Oil Tank (T-115)
5. Used Oil Tank (T-116)
6. Comfort Heating <1 MMBtu/hr
7. Mobile Sources
8. Non-Industrial Vacuum Cleaning
9. Refrigeration Units
10. Vacuum Pumps for Labs
11. Steam Cleaning Equipment
12. Sanders <5 square feet
13. Space Heating Equipment; non-boilers
14. Bakery Ovens
15. Lab Equipment
16. Brazing, Soldering, or Welding
17. Laundry Dryers
18. Fire and Safety Equipment
19. Surface Coating <5% VOC



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

January 13, 1997

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Ronald W. Tomlin
Assistant Managing Director
Lakeland Electric & Water Utilities
501 East Lemon Street
Lakeland, Florida 33801-5079

Re: Request for Additional Information Regarding Initial Title V Permit Application
File No. 1050004-003-AV
C. D. McIntosh, Jr. Power Plant, Polk County

Dear Mr. Tomlin:

Your initial Title V permit application for C. D. McIntosh, Jr. Power Plant was "timely and complete" for purposes of the initial Title V application submission (see Rules 62-213.420(1)(a)1. and (b)2., F.A.C.).

However, in order to continue processing your application, the Department will need the below additional information pursuant to Rule 62-213.420(1)(b)3., F.A.C., and Rule 62-4.070(1), F.A.C. The additional information requested is organized by topic.

Should your response to any of the below items require new calculations, please submit the new calculations, assumptions, reference material and appropriate revised pages of the application form.

McIntosh Unit #3


1. McIntosh Unit #3 is permitted to combust coal, refuse derived fuel, petroleum coke, high sulfur fuel oil, low sulfur fuel oil and natural gas. Segment pages (SCC codes) were only submitted for coal, No. 6 fuel oil (0.73 percent sulfur, by weight) and natural gas. Please review the application and submit all of the required segment pages not included in the application. It is not necessary to submit segments for fuel combinations.

Mr. Ronald W. Tomlin
January 13, 1997
Page 2 of 2

The Department must receive a response from you within 90 (ninety) days of receipt of this letter, unless you (the applicant) request additional time under Rule 62-213.420(1)(b)6., F.A.C.

If you should have any questions, please call Edward Svec or me at 904/488-1344.

Sincerely,



John C. Brown, Jr., P.E.

Administrator

Title V Section

JCB/es

copy to:

Bill Thomas, P.E., FDEP, SWD

Kennard Kosky, P.E., KBN Engineering and Applied Sciences, Inc.

Farzie Shelton, Lakeland Electric & Water Utilities

[electronic file name: 10500041.ltr]

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

IN RE: CITY OF LAKELAND;)
C.D. McINTOSH POWER PLANT)
UNIT NO. 3; MODIFICATION OF) OGC NO. 93-3123
CONDITIONS OF CERTIFICATION)
PA-74-06SR-E)
_____)

FINAL ORDER MODIFYING
CONDITIONS OF CERTIFICATION.

On December 7, 1978, the Governor and Cabinet, acting as the Siting Board, issued a final order, pursuant to Chapter 403, Part II, Florida Statutes (F.S.), approving Certification of the City of Lakeland McIntosh Power Plant Unit Number 3 ("McIntosh Unit No. 3"). The Site Certification authorized construction and operation of a coal-refuse, and oil-fired steam electric generating unit, along with various associated facilities. That Site Certification was subsequently modified in 1980, 1988, and 1993.

On December 7, 1994, the City of Lakeland filed a request to modify the conditions of certification for McIntosh Unit No. 3 pursuant to Section 403.516(1)(b), F.S., and Rule 62-17.211, Florida Administrative Code (F.A.C.). On October 26, 1995, the City of Lakeland supplemented the request for modification. The City of Lakeland requested that the conditions be modified to approve use of an alternative fuel, petroleum coke. In addition, the City of Lakeland's requests included minor revisions to:

1) update regulatory references; 2) clarify that the Certification regulates only McIntosh Unit No. 3; 3) reflect the elimination of use of the artificial marsh, and 4) adjust submittal requirements for fuel usage and analysis data.

Copies of the City of Lakeland's modification request were distributed to all parties to the certification proceeding and made available for public review. On January 27, 1995, a Notice of Receipt of Proposed Modification of Power Plant Certification regarding the proposed modifications was published in the Florida Administrative Weekly. The notice specified the Department of Environmental Protection's (Department) intent to modify the conditions of certification. On March 9, 1995, the City of Lakeland responded to the Department's requests for additional information. On December 22, 1995, a Notice of Intent to Issue Proposed Modification of Power Plant Certification was published in the Florida Administrative Weekly. The notice specified that a hearing would be held if requested by the parties on or before 45 days from receipt of the notice of proposed modification or if requested within 30 days of publication of the notice by persons whose substantial interests are affected by the proposed modification. No written objection to the proposed modification was received by the Department.

Accordingly, in the absence of any timely objection, **IT IS ORDERED:**

The proposed changes to the Conditions of Certification for McIntosh Unit No. 3 as described in the December 7, 1994, request for modification and October 26, 1995 supplemental request, as clarified by the City of Lakeland's March 9, 1995 responses to DEP's requests for additional information are **APPROVED**. Pursuant to Section 403.516(1)(b), F.S., the Department hereby **MODIFIES** the conditions of certification for the City of Lakeland McIntosh Unit No. 3 as follows:

GENERAL

1. Change in Discharge

All discharges or emissions authorized herein shall be consistent with the terms and conditions of this certification. The discharge of any regulated pollutant not identified in the application, or any discharge more frequent than, or at a level in excess of that authorized herein, shall constitute a violation of the certification. Any proposed ~~anticipated~~ facility expansions, production increases, or process modifications which will result in new, different or increased discharges or expansion in steam generating capacity of Unit No. 3 will require a submission of a new or supplemental application pursuant to Chapter 403, Florida Statutes.

2. Noncompliance Notification

If, for any reason, the permittee does not comply with or will be unable to comply with any limitation

specified in this certification, the permittee shall notify the Southwest District Manager of the Department by telephone during the working day during which said noncompliance occurs and shall confirm this situation in writing within seventy-two (72) working-day hours of first becoming aware of such conditions, supplying the following information:

- a. A description and cause of noncompliance; and
- b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate and prevent recurrence of the noncomplying event.

3. Unit No. 3 Operation Facilities

The permittee shall at all times maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee to achieve compliance with the terms and conditions of this certification. Such systems are not to be bypassed without prior department approval.

4. Adverse Impact - no change

5. Right of Entry

The permittee shall allow the Secretary of the Florida Department of Environmental Protection Regulation and/or authorized representatives, upon the presentation of credentials: ---- no change

6. - 10. - no change

11. Review of Site Certification

The certification shall be final unless revised, revoked or suspended pursuant to law. At least every five years from the date of issuance of this certification or any National Pollutant Discharge Elimination System Permit issued pursuant to the Federal Water Pollution Control

Act Amendments of 1972, for the plant units, the Department shall review all monitoring data that has been submitted to it during the preceding five-year period, for the purposes of determining the extent of the permittee's compliance with the conditions of this certification and the environmental impact of this facility unit. The Department shall submit the results of its review and recommendations to the permittee. Such review will be repeated at least every five years thereafter.

12. Modification of Conditions

The conditions of this certification may be modified in the following manner:

- a. The Board hereby delegates to the Secretary the authority to modify, after notice and opportunity for hearing, any conditions pertaining to monitoring or sampling.
- b. This certification shall be automatically modified to conform to any subsequent amendments, modifications, or renewals made by DEP under a federally delegated or approved program to any separately issued Prevention of Significant Deterioration (PSD) permit, Title V Air Permit, or National Discharge Elimination System (NPDES) permit for the certified facility. Lakeland or Orlando Utilities Commission (OUC), as appropriate, shall send each party to the certification proceeding (at the party's last known address as shown on the record of such proceeding) copies of notice of requests submitted by Lakeland or OUC for modifications or renewals of the above listed permits if the request involves a relief mechanism (e.g., mixing zone, variance, etc.) From state

standards, a relaxation of conditions included in the permit due to state permitting requirements, or the inclusion of less restrictive air emission limitations in the air permits.

- c. All other modifications shall be made in accordance with Section 403.516, F.S.

CONDITIONS OF CERTIFICATION - SPECIAL

I. Air

The construction and operation of the Unit No. 3 at the McIntosh Plant shall be in accordance with all applicable provisions of the Chapters 62-210 - 62-297 ~~17-2, 17-5, and 17-7~~, Florida Administrative Code. The permittee shall comply with the following conditions of certification:

A. Emission Limitations

1. Stack emissions shall not exceed those specified in Chapter ~~17-2.04(6)(e)~~ 1. 62-296.405, and 62.296.800(2)(a)1., FAC.
2. ~~The permittee shall not burn a fuel oil containing more than an average of 0.7% sulfur unless it can be demonstrated that either, a) heat efficiency is such as to insure compliance with all applicable emission limitations, or b) that a flue gas desulfurization unit is installed that will insure compliance with applicable emission limitations.~~
 - a. Sulfur dioxide emitted to the atmosphere from the boiler shall not exceed 1.2 pounds per million BTU heat input in accordance with 40 CFR 60 Subpart D, Standards of Performance for Fossil-Fuel-Fired Steam Generators for which Construction Started After August 17, 1971.
 - b. A flue gas desulfurization system will be

installed to treat exhaust gases and will operate such that whenever coal or blends of coal and petroleum coke or refuse are burned, sulfur dioxide in gases discharged to the atmosphere from the boiler shall not exceed 10 percent of the potential combustion concentration (90 percent reduction), or 35 percent of the potential combustion concentration (65 percent reduction), when emissions are less than 0.75 pounds per million BTU heat input. Compliance with the percent reduction requirement shall be determined on a 30-day rolling average. This compliance information shall be retained for a period of three years and made available by the City upon request by the Department. Whenever blends of petroleum coke are co-fired with other fuels, sulfur dioxide emissions shall not exceed 0.718 pounds per million BTU heat input based on a 30-day rolling average and shall comply with the reduction requirements given above.

c. Continuous burning of natural gas, low sulfur fuel oil (less than or equal to 0.5 percent sulfur by weight), or combinations of these two fuels with or without the use of the SO₂ scrubber will be allowed.

d. The burning of high sulfur oil (greater than 0.5 percent by weight) or a combination of high sulfur oil and municipal refuse as an emergency fuel without the use of the SO₂ scrubber will be allowed only when the flue gas desulfurization system malfunctions to the extent that the burning of coal would cause emission limitations to be exceeded. Sulfur dioxide emitted to the

atmosphere from the boiler shall not exceed 0.8 pounds per million BTU under this condition.

e. During malfunctions of equipment which cause an interruption of the coal feed to the boiler, the burning of high sulfur oil (greater than 0.5 percent by weight) or a combination of high sulfur oil and municipal refuse will be allowed only if all flue gases are fully scrubbed by the SO₂ scrubber. Sulfur dioxide emitted to the atmosphere from the boiler shall not exceed 0.8 pound per million Btu under this condition.

3. - no change

4. Particulate emissions from the coal handling facilities:

a. The applicant shall not cause to be discharged into the atmosphere from any coal processing or conveying equipment, coal storage system, or coal transfer and loading system ~~processing coal~~, visible emissions which exceed 20 percent opacity.

b. - no change

5. Particulate matter emitted into the atmosphere from the boiler shall not exceed:

<u>Mode of Firing</u>	<u>lb/10⁶ BTU Heat Input</u>
<u>Coal</u>	<u>0.044</u>
<u>Coal/Petcoke</u>	<u>0.044</u>
<u>Coal/Refuse</u>	<u>0.050</u>
<u>Coal/Petcoke/Refuse</u>	<u>0.050</u>
<u>Oil</u>	<u>0.070</u>
<u>Oil/Refuse</u>	<u>0.075</u>

E. Air Monitoring Program

~~1. The permittee shall install and operate continuously monitoring devices for the Unit No. 3 boiler exhaust for sulfur dioxide, nitrogen dioxide and opacity. The~~

~~monitoring devices shall meet the applicable requirements of 17-2.08, FAC~~ Continuous monitors shall be installed and operated in accordance with 40 CFR 60.45 and 60.13. In addition, the ASTM-certified automatic solid fossil fuel sampler shall be installed which produces a representative daily sample for analysis of sulfur, moisture, heating value and ash. The solid fossil fuel analysis data shall be used in conjunction with emission factors and the continuous monitoring data to calculate SO₂ reduction.

2. - 3. - no change

4. The permittee shall provide sampling ports into the stack and shall provide access to the sampling ports, in accordance with ~~Standard Sampling Techniques and Methods of Analysis for The Determination of Air Pollutants from Point Sources, July 1975~~ Rule 62-297, F.A.C.

5. - no change

6. Emission Control Systems:

Prior to operation of the source, the owner or operator shall submit to the Department a standardized plan or procedure that will allow the company to monitor emission control equipment efficiency and enable the company to return malfunctioning equipment to proper operation as expeditiously as possible.

C. Stack Testing:

1. - no change

2. Performance tests shall be conducted and data reduced in accordance with methods and procedures in accordance with EPA or DEP-approved test methods. ~~Standard Sampling Techniques and Methods of the Determination on Air Pollutants from Point Sources, July 1975.~~

3. - 4. - no change

5. Stack tests for particulates, NO_x and SO₂ shall be performed annually in accordance with conditions 2, 3 and 4 above. CEMS and CEM's relative accuracy tests may be used to determine compliance as long as the source and test conditions are consistent with the applicable requirements.

D. Reporting

1. ~~Stack monitoring, fuel usage and fuel analysis data shall be reported to the Department on a quarterly basis in accordance with 40 CFR, Part 60, Section 60.7(c), (d) and in accordance with 62-297.405(1)(g) 17-2-08, FAC.~~ Fuel usage and fuel analysis data shall be reported to the Department on an annual basis.

2. - no change

E. - F. - no change

G. Reporting:

1. Beginning one month after certification the applicant shall submit to the Department a quarterly status report briefly outlining progress made on engineering design and purchase of major pieces of equipment (including control equipment). All reports and information required to be submitted under this condition shall be submitted to Mr. Hamilton S. Owen, Jr., the Administrator, of Power Plant Siting Coordination Office, Department of Environmental Protection Regulation, 2600 Blair Stone Road, MS 48, Tallahassee, Florida 32399-2400.

2. Lakeland shall maintain and submit to the Department on an annual basis for a period of five years from the date the unit is initially in commercial operation, co-fired with petroleum coke, information demonstrating in accordance with 40 CFR 52.21 (b) (33) and 40 CFR 52.21

(b) (21) (v) that the operational changes did not result in emission increases of carbon monoxide, nitrogen oxides, or sulfuric acid mist.

H. Fuels:

The following fuels may be burned:

Coal only;

Low sulfur fuel oil only (≤ 0.5 percent sulfur by weight);

Coal and up to 10 percent refuse (based on heat input)

Low sulfur fuel oil and up to 10 percent refuse (based on heat input);

Coal and up to 20 percent petroleum coke (based on weight);

Coal and up to 20 percent petroleum coke (based on weight) and 10 percent refuse (based on heat input);

High sulfur oil (> 0.5 percent sulfur by weight) consistent with Conditions I.A.2.b. or I.A.2.c.;

Natural gas only or in combination with any of the other fuels or fuel combinations listed above;

II. Water Discharges

Discharges during construction and operation of the Unit No. 3 shall be in accordance with all applicable provisions of Chapter 62-302 17-3, Florida Administrative Code and 40 CFR 423, Effluent Guidelines and Standards for Steam Electric Power Generating Point Source Category. In addition, the permittee shall comply with the following conditions of certification:

A. Pretreatment Standards

Wastewater discharges from Unit No. 3 to the Lakeland wetlands treatment system shall comply with the effluent limitation guidelines contained in 40 CFR § 423.16, ~~Part 423.12~~ and amendments. The specific standards applicable to the

facilities as planned are:

1. Cooling Tower Blowdown

There shall be no detectable amounts of materials added for corrosion inhibition containing zinc and chromium in cooling tower blowdown discharged to the City of Lakeland wetland treatment system. ~~On an emergency basis the on site Marsh Treatment System may be used to treat cooling tower blowdown.~~

2. - 3. - no change

4. Chemical Wastes and Boiler Blowdown

All low volume wastes (demineralizer regeneration, cooling tower basin cleaning wastes, floor drainage, sample drains and similar wastes), metal cleaning wastes (including preheater and fireside wash) and boiler blowdown shall be treated as required for pH adjustment and removal of chemical constituents. These wastewaters will be treated in a process wastewater treatment system capable of complying with 40 CFR, § 423.16 ~~Part 423.12~~ and discharged with the cooling tower blowdown via a return pipeline to the Lakeland wetlands treatment system. The remaining sludge shall be disposed of in the on site FGD stabilized sludge landfill.

5. Sluice Pond Overflow

Sluice pond overflow (coal pile runoff from less than 10-year, 24-hour rainfall and bottom and fly ash transport water) shall be treated if necessary required to meet the requirements of 40 CFR, § 423.16 ~~Part 423.12~~ and discharged with the cooling tower blowdown to the Lakeland wetlands treatment system.

6. Flue Gas Desulfurization Sludge Pond Overflow

The flue gas desulfurization sludge pond overflow shall be treated if required to meet the requirements

of 40 CFR, § 423.16 ~~Part 423.12~~ in a process waste system and discharged with the cooling tower blowdown to the Lakeland wetlands treatment system.

B. In-Plant Water Monitoring Program

A monitoring program shall be undertaken by the City of Lakeland on each effluent stream within the facility to determine compliance by Unit 3 with the applicable effluent guidelines of 40 CFR, § 423.16 ~~Part 423.12~~ for those wastewaters discharged to the Lakeland wetlands treatment system. This monitoring program may be reviewed annually to determine the necessity for its continuance.

III. Groundwater

A. General

The use of groundwater shall be minimized to the greatest extent practicable.

B. Well Criteria

The well locations shall be approved by the Southwest Florida Water Management District. Design and construction of new wells shall be in accordance with the applicable rules of the Department of Environmental Protection Regulation and Southwest Florida Water Management District.

C. Groundwater Use Limitations - No change

IV. Leachate

A. Compliance

Leachate from coal storage piles, settling and treatment ponds, ~~artificial marsh, rapid infiltration beds,~~ secure land fills and flue gas desulfurization sludge ponds (FGD) shall not contaminate waters of the State (including both surface and groundwaters) in excess of the limitations of Chapters 62-302 and 62-520 ~~17-3~~, F.A.C.

B. Monitoring

A monitoring well system shall be used to determine

whether or not leachate from the treatment ponds, ~~artificial marsh~~, secure landfill, ash sluice ponds, and the flue gas desulfurization sludge ponds is reaching the groundwater.

1.-4. - no change

5. A quarterly summary of the results of the monitoring shall be provided by the permittee to the Southwest District of the Department of Environmental Protection Regulation and to the Southwest Florida Water Management District.

6. The permittee shall keep a monthly record of the monitoring results and shall notify the Department's Southwest District Manager and the Southwest Florida Water Management District when said measurements reach 90% of the levels permitted in the water quality standards of Rule 62-520.420 ~~17-3.101~~, F.A.C.

V. Control Measures During Construction

A. Stormwater Runoff

During construction and plant operation, necessary measures shall be used to settle, filter, treat or absorb silt containing or pollutant laden stormwater runoff to limit the suspended solids to 50 mg/l or less during rainfall periods not exceeding the 10-year, 24-hour rainfall, and to prevent an increase in turbidity to 29 NTU's ~~50 Jackson Turbidity Units~~ above background in waters of the State.

Control measures shall consist at the minimum, of filters, sediment traps, barriers, berms or vegetative planting. Exposed or disturbed soil shall be protected as soon as possible to minimize silt and sediment laden runoff. The pH shall be kept within the range of 6.0 to 8.5.

VI. Solid Wastes

Solid Wastes resulting from construction or operation shall be disposed of in accordance with the applicable regulations of Chapter 62-701 ~~17-7~~, FAC.

Open burning in connection with land clearing shall be in accordance with Chapter 62-256 ~~71-5~~, FAC, no additional permits shall be required, but the Division of Forestry shall be notified. Open burning shall not occur if the Division of forestry has issued a ban on burning due to fire hazard conditions.

VIII. Solid Waste Utilization System - no change

The solid waste utilization facility shall be designed and operated in compliance with all applicable regulations of the Department, including but not limited to Chapter 62-701 ~~71-7~~, FAC.

XIII. Transmission Lines

Directly associated transmission lines shall be constructed and maintained in a manner to minimize environmental impacts in accordance with Chapter 403, F.S., and Chapters 27F-6, 27F-7, and 62-312, ~~22~~ FAC.

A. Construction

1. Filling and construction in waters of the State shall be minimized to the extent practicable. No such activities shall take place without obtaining lease or title from the Board of Trustees of the Internal Improvement Trust Fund ~~Department of Natural Resources~~.

2.-9. - no change

10. Any archaeological sites discovered during construction of the transmission line shall be disturbed as little as possible and such discovery shall be communicated to the Department of State, Division of ~~Archive History and Records Management~~ Historical Resources.

XIV. Construction in Waters of the State

No construction in waters of the State shall commence without obtaining lease or title from the ~~Department of Natural~~

Resources Board of Trustees of the Internal Improvement Trust
Fund.

XVI. Sanitary Waste Disposal

Sanitary waste from operating plant facilities shall be disposed of in a septic tank system, as approved by the ~~Health~~ Department of Health & Rehabilitative Services, as long as the average daily flow does not exceed 2,000 gallons per day. If the sanitary waste exceeds 2000 gpd, a properly designed treatment system shall be constructed upon receipt of approval by the Department.

NOTICE OF RIGHTS

Any party to this Order has the right to seek judicial review of this Order pursuant to Section 120.68, Florida Statutes, by filing a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department of Environmental Protection in the Office of the General Counsel, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000; and by filing a copy of the Notice of Appeal accompanied by the appropriate filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Final Order is filed with the Clerk of the Department of Environmental Protection.

DONE AND ORDERED this 15th day of February, 1996, in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION

FILING AND ACKNOWLEDGEMENT
FILED, on this date, pursuant to S120.52
Florida Statutes, with the designated
Department Clerk, receipt of which
is hereby acknowledged.

Roberta B.
Clerk

2/14/96
Date

Virginia B. Wetherell
VIRGINIA B. WETHERELL
SECRETARY

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that copies of the foregoing has been furnished by regular U. S. Mail to the following this 14th day of February, 1996:

James S. Alves, Esquire
Hopping Green Sams & Smith
P.O. Box 6526
Tallahassee, FL 32314-6526

City of Lakeland
2379 Broad Street
Lakeland, FL 33802

Mark Carpanini, Esquire
Office of County Attorney
P.O. Box 60
Bartow, FL 33830-0060

Richard Tschantz, Esquire
Southwest Fla. Water Mgmt. Dist.
2379 Broad Street
Brooksville, FL 34609-6899


Robert V. Elias, Esquire
Division of Legal Services
Florida Public Service Comm.
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

Andrew R. Reilly
East Lake Parker Residents
P.O. Box 2039
Haines City, FL 33844

Tom Tart
Greg DeMuth
Orlando Utilities Commission
500 South Orange Street
Orlando, FL 32801

Farzie Shelton
Dept of Water and Electric
Utilities
501 East Lemon Street
Lakeland, FL 33801-5050

Karen Brodeen, Esquire
Dept. of Community Affairs
2740 Centerview Drive
Tallahassee, FL 32399-2100



CHARLES T. "CHIP" COLLETTE,
Assistant General Counsel
Florida Department of
Environmental Protection
2600 Blair Stone Road
MS 35
Tallahassee, FL 32399-2400

Owner/Authorized Representative or Responsible Official

1. Name and Title of Owner/Authorized Representative or Responsible Official: Ronald W. Tomlin, Assistant Managing Director
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: Lakeland Electric & Water Utilities Street Address: 501 East Lemon Street City: Lakeland State: FL Zip Code: 33801-5079
3. Owner/Authorized Representative or Responsible Official Telephone Numbers: Telephone: (941) 499-6300 Fax: (941) 499-6344
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative* of the non-Title V source addressed in this Application for Air Permit or the responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i> <p><u>Ronald W. Tomlin</u> <u>Feb. 07, 1997</u> Signature Date</p>

* Attach letter of authorization if not currently on file.

4. Professional Engineer's Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [] if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [] if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.


If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [] if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

Kend F. Galy

Date

1/17/97

Attach any exception to certification statement.



ATTACHMENT LMC-EU1-L2

FUEL ANALYSIS
PROPANE ANALYSIS

<u>Parameter</u>	<u>Typical Value</u>
heat content	90,500 Btu/gal
% sulfur	negligible
% nitrogen	0.8% by volume
% ash	negligible

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Residual (No.6) Oil	
2. Source Classification Code (SCC): 1-01-004-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 6.33	5. Maximum Annual Rate: 55,451
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 2.5	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 150	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input for oil firing. Unit can be co-fired with natural gas. No.2 fuel oil can be used.	

Segment Description and Rate: Segment 2 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Natural Gas	
2. Source Classification Code (SCC): 1-01-006-01	
3. SCC Units: Million Cubic Feet	
4. Maximum Hourly Rate: 0.97	5. Maximum Annual Rate: 8,497
6. Estimated Annual Activity Factor: 0	
7. Maximum Percent Sulfur: 0	8. Maximum Percent Ash: 0
9. Million Btu per SCC Unit: 1,024	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input. Propane is used for ignition only (SCC 1-01-010-02).	

Segment Description and Rate: Segment 4 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Propane	
2. Source Classification Code (SCC): 1-01-010-02	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 10.88	5. Maximum Annual Rate: 95,344
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 91	
10. Segment Comment (limit to 200 characters): Million Btu per SCC Unit = 90.5 (rounded to 91). Maximum hourly rate based on maximum heat input of 985 MMBtu/hr. Use as ingitor fuel. Fuel does not increase emissions of any pollutant.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 3 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): On-Specification used oil as defined in 40 CFR 279.11 and generated by City of Lakeland	
2. Source Classification Code (SCC): 1-01-013-02	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 6.33	5. Maximum Annual Rate: 42
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 2.5	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 150	
10. Segment Comment (limit to 200 characters): Sampling of each 1,000 gallons burned is required by operation permit. Maximum hourly rate same as residual oil.	

Emissions Unit Information Section 1 of 7
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: RULE		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 2.75 lb/MMBtu /2.5%S		
4. Equivalent Allowable Emissions:	2,613 lb/hour	11,443 tons/year
5. Method of Compliance (limit to 60 characters): Fuel Analysis; ASTM Methods D-4294-83 and D-240		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Liquid fuel only based on FDEP Rule 62-296.405(1)(c)1. Compliance based on fuel sampling analysis for each shipment to ensure oil sulfur content 2.5% or less (vendor or on-site data).		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

Attachment LMC-EU2-L2

Fuel Analysis

Propane Analysis

<u>Parameter</u>	<u>Typical Value</u>
heat content	90,500 Btu/gal
% sulfur	negligible
% nitrogen	0.8% by volume
% ash	negligible

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Residual (No.6) Oil	
2. Source Classification Code (SCC): 1-01-004-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 7.43	5. Maximum Annual Rate: 65,087
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.7	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 150	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input for oil firing. Unit can be co-fired with natural gas. No.2 fuel oil can be used.	

Segment Description and Rate: Segment 2 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Natural Gas	
2. Source Classification Code (SCC): 1-01-006-01	
3. SCC Units: Million Cubic Feet	
4. Maximum Hourly Rate: 1.16	5. Maximum Annual Rate: 10,133
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1,024	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input. Propane is used for ignition/start-up only (SCC 1-01-010-02)	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 3 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Distillate (No.2) Oil	
2. Source Classification Code (SCC): 1-01-005-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 8.26	5. Maximum Annual Rate: 72,351
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.5	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 135	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input for oil firing. Unit can be co-fired with natural gas. Fuel does not increase emissions of any pollutant.	

Segment Description and Rate: Segment 4 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Propane	
2. Source Classification Code (SCC): 1-01-010-02	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 13.09	5. Maximum Annual Rate: 114,703
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 91.	
10. Segment Comment (limit to 200 characters): Million Btu per SCC Unit = 90.5 (rounded to 91). Maximum hourly rate based on maximum heat input. Propane is used for ignition/start-up. Fuel does not increase emissions of any pollutant.	

Attachment LMC-EU3-L2

Fuel Analysis

Coal

<u>Parameter</u>	<u>Typical Value</u>	<u>Maximum^a, Minimum^b, or Design^c Value</u>
heat content (Btu/lb)	13,000	11,200 ^b - 12,174 ^c
% sulfur	1.0 - 1.5	2.5 ^c - 3.3 ^a
% nitrogen	1.3 - 1.7	1.54% ^c (dry)
% ash	5 - 13	16.3 ^c

Attachment LMC-EU3-L2

Fuel Analysis

RDF

<u>Parameter</u>	<u>Typical Value</u>
heat content (Btu/lb)	4,300 - 6,340
% moisture	5 - 49
% ash	3 - 35
% sulfur	0.1

From laboratory analysis

Attachment LMC-EU3-L2

Fuel Analysis

Petroleum Coke

<u>Parameter</u>	<u>Typical Value</u>
heat content (Btu/lb)	14,000
% sulfur	5
% ash	0.35

From laboratory analysis

Attachment LMC-EU3-L2

Fuel Analysis

Natural Gas Analysis

<u>Parameter</u>	<u>Typical Value</u>	<u>Max Value</u>
Relative density	0.58 (compared to air)	
heat content	950 - 1124 Btu/cu ft. (HHV)	
% sulfur	0.43 grains/CCF ¹	1 grain/100
CF		
% nitrogen	0.8% by volume	
% ash	negligible	

Note: The values listed are "typical" values based upon information supplied by Florida Gas Transmission (FGT). However, analytical results from grab samples of fuel taken at any given point in time may vary from those listed.

¹ Data from laboratory analysis

Attachment LMC-EU3-L2

Fuel Analysis

No. 6 Fuel Oil

<u>Parameter</u>	<u>Typical Value</u>	<u>Max Value</u>
API gravity @ 60 F	8 ¹	-
Relative density	8.2 lb/gal ²	
Heat content	18,300 Btu / lb (HHV)	
% sulfur	0.7 ²	0.725 ³
% nitrogen	0.25 - 0.50	
% ash	negligible	0.01 ¹

Note: The values listed are "typical" values based upon 1) information gathered by laboratory analysis, and 2) fuel purchasing specifications. However, analytical results from grab samples of fuel taken at any given point in time may vary from those listed.

¹ Data taken from the fuel procurement specification

² Data from laboratory analysis

³ Data from current air permit based on 0.8 lb/MMBtu for oil firing only; when using FGD system, or when co-firing with gas, sulfur content can be as high as 2.5 percent.

Attachment LMC-EU3-L2

Fuel Analysis

No. 2 Fuel Oil

<u>Parameter</u>	<u>Typical Value</u>	<u>Max Value</u>
API gravity @ 60 F	30 ¹	-
Relative density	6.92 lb/gal ²	
Heat content	18,400 Btu / lb (LHV)	
% sulfur	<0.5 ²	0.5
% nitrogen	0.025 - 0.030	
% ash	negligible	0.01 ¹

Note: The values listed are "typical" values based upon 1) information gathered by laboratory analysis, and 2) fuel purchasing specifications. However, analytical results from grab samples of fuel taken at any given point in time may vary from those listed.

¹ Data taken from fuel procurement specification

² Data from laboratory analysis

Attachment LMC-EU3-L2

Fuel Analysis

Propane Analysis

<u>Parameter</u>	<u>Typical Value</u>
heat content	90,500 Btu/gal
% sulfur	negligible
% nitrogen	0.8% by volume
% ash	negligible

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Coal	
2. Source Classification Code (SCC): 1-01-001-01	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 159.6	5. Maximum Annual Rate: 1,398,096
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 3.3	8. Maximum Percent Ash: 16
9. Million Btu per SCC Unit: 23	
10. Segment Comment (limit to 200 characters):	

Segment Description and Rate: Segment 2 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Refuse Derived Fuel	
2. Source Classification Code (SCC): 1-01-012-02	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 40.4	5. Maximum Annual Rate: 75,000
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.1	8. Maximum Percent Ash: 35
9. Million Btu per SCC Unit: 9	
10. Segment Comment (limit to 200 characters): See Attachment LMC-EU3-F10; co-fired with other fuels upto 10 percent of heat input.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 3 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Oil	
2. Source Classification Code (SCC): 1-01-004-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 24.268	5. Maximum Annual Rate: 212,584
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.73	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 150	
10. Segment Comment (limit to 200 characters):	

Segment Description and Rate: Segment 4 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Distillate (No.2) Oil	
2. Source Classification Code (SCC): 1-01-005-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 26.96	5. Maximum Annual Rate: 236,196
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.5	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 135	
10. Segment Comment (limit to 200 characters): Used primarily as a start-up fuel.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 5 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Petroleum coke	
2. Source Classification Code (SCC): 1-01-008-01	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 31.9	5. Maximum Annual Rate: 279,619
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 6	8. Maximum Percent Ash: 15
9. Million Btu per SCC Unit: 28	
10. Segment Comment (limit to 200 characters): Co-fired with other primary fuels up to 20 percent by weight.	

Segment Description and Rate: Segment 6 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Natural Gas	
2. Source Classification Code (SCC): 1-01-006-01	
3. SCC Units: Million Cubic Feet	
4. Maximum Hourly Rate: 3.555	5. Maximum Annual Rate: 31,139
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1,024	
10. Segment Comment (limit to 200 characters): Natural gas is proposed as a supplementary fuel. Heat content of mixture based on maximum hourly rate (TPH) and maximum heat input rating for unit of 3,640 MMBtu/hr.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 7 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Propane	
2. Source Classification Code (SCC): 1-01-010-02	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 40.22	5. Maximum Annual Rate: 352,336
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 91	
10. Segment Comment (limit to 200 characters): Million Btu per SCC Unit = 90.5 (rounded to 91). Used as a start-up fuel. Fuel does not increase emissions of any pollutant.	

**C. EMISSIONS UNIT DETAIL INFORMATION
(Regulated Emissions Units Only)**

Emissions Unit Details

1. Initial Startup Date: 1 Jan 1973		
2. Long-term Reserve Shutdown Date:		
3. Package Unit: Manufacturer:	Model Number:	
4. Generator Nameplate Rating:	20 MW	
5. Incinerator Information:		
	Dwell Temperature:	°F
	Dwell Time:	seconds
	Incinerator Afterburner Temperature:	°F

Emissions Unit Operating Capacity

1. Maximum Heat Input Rate:	330	mmBtu/hr
2. Maximum Incineration Rate:	lbs/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Operating Capacity Comment (limit to 200 characters):		
See Attachment LMC-EU5-C5.		

Emissions Unit Operating Schedule

1. Requested Maximum Operating Schedule:		
	hours/day	days/week
	weeks/yr	8,760 hours/yr


ATTACHMENT LMC-EU5-C5
OPERATING CAPACITY COMMENT

**ATTACHMENT LMC-EU5-C5
OPERATING CAPACITY COMMENT**

Maximum heat input shown for natural gas [low heating value (LHV)] for a compressor inlet temperature of 30°F. Maximum heat input for oil is 320 MMBtu/hr (LHV) at 30°F inlet temperature. Heat input as a function of compressor inlet temperature is attached as part of LMC-EU5-C5.

McIntosh Gas Turbine

Heat Input vs Compressor Inlet Temperature




+ Design Input Nat Gas ■ 95% of Design Nat Gas

Peak Reserve Mode

Using LHV of Nat Gas

McIntosh Gas Turbine

Heat Input vs Compressor Inlet Temperature



* Design Input #2 Oil x 95% of Design #2 Oil

Peak Reserve Mode

Using LHV of #2 Oil



February 7, 1997

Mr. John C. Brown, Jr., P.E.
Administrator
Title V Section
Florida Department of Environmental Protection
2600 Blair Stone Road, MS 5505
Tallahassee, FL 32301

RECEIVED

FEB 17 1997

BUREAU OF
AIR REGULATION

RE: Lakeland Electric and Water Utilities
C. D. McIntosh Jr. Power Plant
File No. 1050004-003-AV

Dear John:

We are in receipt of your communication dated January 13, 1997 requesting additional information regarding initial Title V Permit Application for the above referenced facility. Accordingly we have compiled the information you have requested in regards to the Unit No. 3 at this facility. Therefore, enclosed please find four copies of the updated Segment pages (signed and sealed by a P. E. Engineer and Certified by our Responsible Official) covering all different types of fuel burned in this Unit.

If you should have any questions, please do not hesitate to call me at (941) 499-6603.

Sincerely

Farzie Shelton
Environmental Division

Enc.

Edward Svec, DEP
Ronald Tomlin, Lakeland
Angela Morrison, HGSS
Ken Kosky, Golder Associates

City of Lakeland
Dept. of Electric & Water Utilities
3030 E. Lake Parker Drive
Lakeland, FL 33805




Edward Svec
Florida Department of Envir. Protection
2600 Blair Stone Road, MS 5505
Tallahassee, FL 32301



3230175935



TO: Bill Thomas

FROM: Bruce Mitchell 

DATE: October 31, 1996

SUBJECT: Completeness Review of an Application Package for a Title V Operation Permit
C.D. McIntosh, Jr. Power Plant: 1050004-003-AV

The Title V operating permit application package for the referenced facility is being processed in Tallahassee. The application was previously forwarded to your office for your files and future reference. Please have someone review the package for completeness and respond in writing by December 16, 1996, if you have any comments. Otherwise, no response is required. If there are any questions, please call the project engineer, Ed Svec, at 904/488-1344 or SC:278-1344. It is very important to verify the compliance statement regarding the facility. Since we do not have a readily effective means of determining compliance at the time the application was submitted, please advise if you know of any emissions unit(s) that were not in compliance at that time and provide supporting information. Also, do not write on the documents.

If there are any questions regarding this request, please call me or Scott Sheplak at the above number(s).

RBM/bm

Owner/Authorized Representative or Responsible Official

1. Name and Title of Owner/Authorized Representative or Responsible Official: Ronald W. Tomlin, Assistant Managing Director
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: Lakeland Electric & Water Utilities Street Address: 501 East Lemon Street City: Lakeland State: FL Zip Code: 33801-5079
3. Owner/Authorized Representative or Responsible Official Telephone Numbers: Telephone: (941) 499-6300 Fax: (941) 499-6344
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative* of the non-Title V source addressed in this Application for Air Permit or the responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i> <p><u>Ronald W. Tomlin</u> <u>Feb. 07, 1997</u> Signature Date</p>

* Attach letter of authorization if not currently on file.

4. Professional Engineer's Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [] if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [] if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [] if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

[Handwritten Signature]

Signature
(seal)

Date

1/17/97

Attach any exception to certification statement.

ATTACHMENT LMC-EU1-L2

**FUEL ANALYSIS
PROPANE ANALYSIS**

<u>Parameter</u>	<u>Typical Value</u>
heat content	90,500 Btu/gal
% sulfur	negligible
% nitrogen	0.8% by volume
% ash	negligible

**F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)**

Segment Description and Rate: Segment 1 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Residual (No.6) Oil	
2. Source Classification Code (SCC): 1-01-004-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 6.33	5. Maximum Annual Rate: 55,451
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 2.5	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 150	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input for oil firing. Unit can be co-fired with natural gas. No.2 fuel oil can be used.	

Segment Description and Rate: Segment 2 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Natural Gas	
2. Source Classification Code (SCC): 1-01-006-01	
3. SCC Units: Million Cubic Feet	
4. Maximum Hourly Rate: 0.97	5. Maximum Annual Rate: 8,497
6. Estimated Annual Activity Factor: 0	
7. Maximum Percent Sulfur: 0	8. Maximum Percent Ash: 0
9. Million Btu per SCC Unit: 1,024	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input. Propane is used for ignition only (SCC 1-01-010-02).	

Segment Description and Rate: Segment 4 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Propane	
2. Source Classification Code (SCC): 1-01-010-02	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 10.88	5. Maximum Annual Rate: 95,344
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 91	
10. Segment Comment (limit to 200 characters): Million Btu per SCC Unit = 90.5 (rounded to 91). Maximum hourly rate based on maximum heat input of 985 MMBtu/hr. Use as ingitor fuel. Fuel does not increase emissions of any pollutant.	

**F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)**

Segment Description and Rate: Segment 3 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): On-Specification used oil as defined in 40 CFR 279.11 and generated by City of Lakeland	
2. Source Classification Code (SCC): <p style="text-align: center;">1-01-013-02</p>	
3. SCC Units: <p style="text-align: center;">1,000 gallons</p>	
4. Maximum Hourly Rate: <p style="text-align: center;">6.33</p>	5. Maximum Annual Rate: <p style="text-align: center;">42</p>
6. Estimated Annual Activity Factor: 	
7. Maximum Percent Sulfur: <p style="text-align: center;">2.5</p>	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: <p style="text-align: center;">150</p>	
10. Segment Comment (limit to 200 characters): <p style="text-align: center;">Sampling of each 1,000 gallons burned is required by operation permit. Maximum hourly rate same as residual oil.</p>	

Emissions Unit Information Section 1 of 7
Allowable Emissions (Pollutant identified on front page)

A.

1. Basis for Allowable Emissions Code: RULE		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units: 2.75 lb/MMBtu /2.5%S		
4. Equivalent Allowable Emissions:	2,613 lb/hour	11,443 tons/year
5. Method of Compliance (limit to 60 characters): Fuel Analysis; ASTM Methods D-4294-83 and D-240		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters): Liquid fuel only based on FDEP Rule 62-296.405(1)(c)1. Compliance based on fuel sampling analysis for each shipment to ensure oil sulfur content 2.5% or less (vendor or on-site data).		

B.

1. Basis for Allowable Emissions Code:		
2. Future Effective Date of Allowable Emissions:		
3. Requested Allowable Emissions and Units:		
4. Equivalent Allowable Emissions:	lb/hour	tons/year
5. Method of Compliance (limit to 60 characters):		
6. Pollutant Allowable Emissions Comment (Desc. of Related Operating Method/Mode) (limit to 200 characters):		

Attachment LMC-EU2-L2

Fuel Analysis

Propane Analysis

<u>Parameter</u>	<u>Typical Value</u>
heat content	90,500 Btu/gal
% sulfur	negligible
% nitrogen	0.8% by volume
% ash	negligible

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Residual (No.6) Oil	
2. Source Classification Code (SCC): 1-01-004-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 7.43	5. Maximum Annual Rate: 65,087
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.7	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 150	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input for oil firing. Unit can be co-fired with natural gas. No.2 fuel oil can be used.	

Segment Description and Rate: Segment 2 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Natural Gas	
2. Source Classification Code (SCC): 1-01-006-01	
3. SCC Units: Million Cubic Feet	
4. Maximum Hourly Rate: 1.16	5. Maximum Annual Rate: 10,133
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1,024	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input. Propane is used for ignition/start-up only (SCC 1-01-010-02)	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 3 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Distillate (No.2) Oil	
2. Source Classification Code (SCC): 1-01-005-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 8.26	5. Maximum Annual Rate: 72,351
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.5	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 135	
10. Segment Comment (limit to 200 characters): Maximum hourly rate based on maximum heat input for oil firing. Unit can be co-fired with natural gas. Fuel does not increase emissions of any pollutant.	

Segment Description and Rate: Segment 4 of 4

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Propane	
2. Source Classification Code (SCC): 1-01-010-02	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 13.09	5. Maximum Annual Rate: 114,703
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 91	
10. Segment Comment (limit to 200 characters): Million Btu per SCC Unit = 90.5 (rounded to 91). Maximum hourly rate based on maximum heat input. Propane is used for ignition/start-up. Fuel does not increase emissions of any pollutant.	

Attachment LMC-EU3-L2

Fuel Analysis

Coal

<u>Parameter</u>	<u>Typical Value</u>	<u>Maximum^a, Minimum^b, or Design^c Value</u>
heat content (Btu/lb)	13,000	11,200 ^b - 12,174 ^c
% sulfur	1.0 - 1.5	2.5 ^c - 3.3 ^a
% nitrogen	1.3 - 1.7	1.54% ^c (dry)
% ash	5 - 13	16.3 ^c

Attachment LMC-EU3-L2

Fuel Analysis

RDF

<u>Parameter</u>	<u>Typical Value</u>
heat content (Btu/lb)	4,300 - 6,340
% moisture	5 - 49
% ash	3 - 35
% sulfur	0.1

From laboratory analysis

Attachment LMC-EU3-L2

Fuel Analysis

Petroleum Coke

<u>Parameter</u>	<u>Typical Value</u>
heat content (Btu/lb)	14,000
% sulfur	5
% ash	0.35

From laboratory analysis

Attachment LMC-EU3-L2

Fuel Analysis

Natural Gas Analysis

<u>Parameter</u>	<u>Typical Value</u>	<u>Max Value</u>
Relative density	0.58 (compared to air)	
heat content	950 - 1124 Btu/cu ft. (HHV)	
% sulfur	0.43 grains/CCF ¹	1 grain/100
CF		
% nitrogen	0.8% by volume	
% ash	negligible	

Note: The values listed are "typical" values based upon information supplied by Florida Gas Transmission (FGT). However, analytical results from grab samples of fuel taken at any given point in time may vary from those listed.

¹ Data from laboratory analysis

Attachment LMC-EU3-L2

Fuel Analysis

No. 6 Fuel Oil

<u>Parameter</u>	<u>Typical Value</u>	<u>Max Value</u>
API gravity @ 60 F	8 ¹	-
Relative density	8.2 lb/gal ²	
Heat content	18,300 Btu / lb (HHV)	
% sulfur	0.7 ²	0.725 ³
% nitrogen	0.25 - 0.50	
% ash	negligible	0.01 ¹

Note: The values listed are "typical" values based upon 1) information gathered by laboratory analysis, and 2) fuel purchasing specifications. However, analytical results from grab samples of fuel taken at any given point in time may vary from those listed.

¹ Data taken from the fuel procurement specification

² Data from laboratory analysis

³ Data from current air permit based on 0.8 lb/MMBtu for oil firing only; when using FGD system, or when co-firing with gas, sulfur content can be as high as 2.5 percent.

Attachment LMC-EU3-L2

Fuel Analysis

No. 2 Fuel Oil

<u>Parameter</u>	<u>Typical Value</u>	<u>Max Value</u>
API gravity @ 60 F	30 ¹	-
Relative density	6.92 lb/gal ²	
Heat content	18,400 Btu / lb (LHV)	
% sulfur	<0.5 ²	0.5
% nitrogen	0.025 - 0.030	
% ash	negligible	0.01 ¹

Note: The values listed are "typical" values based upon 1) information gathered by laboratory analysis, and 2) fuel purchasing specifications. However, analytical results from grab samples of fuel taken at any given point in time may vary from those listed.

¹ Data taken from fuel procurement specification

² Data from laboratory analysis

Attachment LMC-EU3-L2

Fuel Analysis

Propane Analysis

<u>Parameter</u>	<u>Typical Value</u>
heat content	90,500 Btu/gal
% sulfur	negligible
% nitrogen	0.8% by volume
% ash	negligible

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 1 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Coal	
2. Source Classification Code (SCC): 1-01-001-01	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 159.6	5. Maximum Annual Rate: 1,398,096
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 3.3	8. Maximum Percent Ash: 16
9. Million Btu per SCC Unit: 23	
10. Segment Comment (limit to 200 characters):	

Segment Description and Rate: Segment 2 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Refuse Derived Fuel	
2. Source Classification Code (SCC): 1-01-012-02	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 40.4	5. Maximum Annual Rate: 75,000
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.1	8. Maximum Percent Ash: 35
9. Million Btu per SCC Unit: 9	
10. Segment Comment (limit to 200 characters): See Attachment LMC-EU3-F10; co-fired with other fuels upto 10 percent of heat input.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 3 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Oil	
2. Source Classification Code (SCC): 1-01-004-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 24.268	5. Maximum Annual Rate: 212,584
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.73	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 150	
10. Segment Comment (limit to 200 characters):	

Segment Description and Rate: Segment 4 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Distillate (No.2) Oil	
2. Source Classification Code (SCC): 1-01-005-01	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 26.96	5. Maximum Annual Rate: 236,196
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 0.5	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 135	
10. Segment Comment (limit to 200 characters): Used primarily as a start-up fuel.	

F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)

Segment Description and Rate: Segment 5 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Petroleum coke	
2. Source Classification Code (SCC): 1-01-008-01	
3. SCC Units: Tons	
4. Maximum Hourly Rate: 31.9	5. Maximum Annual Rate: 279,619
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur: 6	8. Maximum Percent Ash: 15
9. Million Btu per SCC Unit: 28	
10. Segment Comment (limit to 200 characters): Co-fired with other primary fuels up to 20 percent by weight.	

Segment Description and Rate: Segment 6 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Natural Gas	
2. Source Classification Code (SCC): 1-01-006-01	
3. SCC Units: Million Cubic Feet	
4. Maximum Hourly Rate: 3.555	5. Maximum Annual Rate: 31,139
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 1,024	
10. Segment Comment (limit to 200 characters): Natural gas is proposed as a supplementary fuel. Heat content of mixture based on maximum hourly rate (TPH) and maximum heat input rating for unit of 3,640 MMBtu/hr.	

**F. SEGMENT (PROCESS/FUEL) INFORMATION
(Regulated and Unregulated Emissions Units)**

Segment Description and Rate: Segment 7 of 7

1. Segment Description (Process/Fuel Type and Associated Operating Method/Mode) (limit to 500 characters): Propane	
2. Source Classification Code (SCC): 1-01-010-02	
3. SCC Units: 1,000 gallons	
4. Maximum Hourly Rate: 40.22	5. Maximum Annual Rate: 352,336
6. Estimated Annual Activity Factor:	
7. Maximum Percent Sulfur:	8. Maximum Percent Ash:
9. Million Btu per SCC Unit: 91	
10. Segment Comment (limit to 200 characters): Million Btu per SCC Unit = 90.5 (rounded to 91). Used as a start-up fuel. Fuel does not increase emissions of any pollutant.	

**C. EMISSIONS UNIT DETAIL INFORMATION
(Regulated Emissions Units Only)**

Emissions Unit Details

1. Initial Startup Date:	1 Jan 1973	
2. Long-term Reserve Shutdown Date:		
3. Package Unit:		
Manufacturer:		Model Number:
4. Generator Nameplate Rating:	20 MW	
5. Incinerator Information:		
	Dwell Temperature:	°F
	Dwell Time:	seconds
	Incinerator Afterburner Temperature:	°F

Emissions Unit Operating Capacity

1. Maximum Heat Input Rate:	330	mmBtu/hr
2. Maximum Incineration Rate:	lbs/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Operating Capacity Comment (limit to 200 characters):	See Attachment LMC-EU5-C5.	

Emissions Unit Operating Schedule

1. Requested Maximum Operating Schedule:		
	hours/day	days/week
	weeks/yr	8,760 hours/yr


ATTACHMENT LMC-EU5-C5
OPERATING CAPACITY COMMENT

**ATTACHMENT LMC-EU5-C5
OPERATING CAPACITY COMMENT**

Maximum heat input shown for natural gas [low heating value (LHV)] for a compressor inlet temperature of 30°F. Maximum heat input for oil is 320 MMBtu/hr (LHV) at 30°F inlet temperature. Heat input as a function of compressor inlet temperature is attached as part of LMC-EU5-C5.

McIntosh Gas Turbine

Heat Input vs Compressor Inlet Temperature




+ Design Input Nat Gas ■ 95% of Design Nat Gas

Peak Reserve Mode

Using LHV of Nat Gas

McIntosh Gas Turbine

Heat Input vs Compressor Inlet Temperature



* Design Input #2 Oil x 95% of Design #2 Oil

Peak Reserve Mode

Using LHV of #2 Oil