

KOOGLER & ASSOCIATES  
ENVIRONMENTAL SERVICES

4014 NW THIRTEENTH STREET  
GAINESVILLE, FLORIDA 32609  
352/377-5822 • FAX/377-7158

KA 124-00-05

August 8, 2002

RECEIVED

AUG 12 2002

BUREAU OF AIR REGULATION

Mr. Syed Arif, P.E.  
Florida Department of  
Environmental Protection  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

Subject: IMC Phosphates MP, Inc. (New Wales)  
Multifos Plant - Kiln C Permit Revision  
No. 1050059-024-AC, PSD-FL-244 A  
*033*

Dear Mr. Arif:

This is in response to FDEP's letter dated May 22, 2002, requesting additional information on the above referenced project. The issues raised in that letter are addressed below.

1. Previously, only a summary of equipment costs was submitted, as presented in Attachment 1. The detailed information requested by FDEP is being submitted under separate cover. The vendor has quoted the cost of installing a venturi scrubber upstream of the cross flow scrubber without the Kimre panels. As previously indicated in our letter dated November 9, 2001, these costs indicated that these alternatives are cost prohibitive. IMC proposes the use of the existing equipment as BACT.
2. The requested summary of all the available emission testing information on Kiln C, has been previously submitted, and is presented in Attachment 2 for the sake of convenience. The fluorides performance tests included 11 scenarios:

- initial compliance test;
- second compliance test;
- test while using dried feed;
- test with caustic flow in SO<sub>2</sub> scrubber;
- test without caustic flow in SO<sub>2</sub> scrubber;
- test with fresh water to demist section;
- test under less erratic operation levels;
- test and vary the source of pond water;
- test and add steam;
- pre-test before use as dryer;
- test while operating as dryer.

Mr. Syed Arif, P.E.  
Florida Department of  
Environmental Protection

August 8, 2002

Please note that the source of pond water was changed; the source of pond water was varied; and, steam was introduced in the scrubber (the scenarios suggested by FDEP). As the test data indicate, it was not possible to achieve the level of emissions expected by FDEP despite IMC's best efforts.


3. Based on all the testing conducted, IMC requests a fluoride emission limit of 0.6 lb/ton P2O5. The summary and calculations are presented in Attachment 3.

The testing for sulfur dioxide emissions from the Multifos A/B Kilns has been scheduled for August 29, 2002.

If you have any questions, please call Pradeep Raval or me.

Very truly yours,

KOOGLER & ASSOCIATES



John B. Koogler, Ph.D., P.E.

JBK:par  
encl.

c: C. Dave Turley, IMC



**ATTACHMENT 1**

**REVISED VENDOR LETTER ON SCRUBBER COST**



# PENN PRO

Engineering & Technical Services

Mr. George Bien  
IMC Phosphates  
P.O. Box 2000  
Mulberry, FL 33860-100

12/17/01

REF: PENN PRO estimate for "C" Kiln Fluorine Scrubber Replacement  
Revision 3

In accordance with your request, I have developed an additional estimate for the scrubber modifications to "C" Kiln.

The scope of this new estimate was to reuse the existing scrubber body and install Kimre panels. Based on the scope from Kimre for the scrubbing requirements, I have estimated new stainless steel support frames to be installed in the existing scrubber. The system allows for changing panels "on the run" and still maintaining scrubbing requirements.

Because the existing scrubber body is carbon steel, rubber-lined, the support frames have been estimated to be installed against the rubber lining (bolted in). Rubber lining repairs are included to prepare the areas where the panel support frames are installed, if it is necessary.

I have also revised the estimate to compress the Kiln downtime.

The estimate of Kiln downtime is 4 weeks on a premium time basis. The job will require 1-2 weeks before to prep and start electrical and piping additions and 1-2 weeks after to install the monorail system to pull the Kimre panels. This is field time only.

The estimated cost for this project is \$ 500,000.00. The cost estimate is attached.

If you have any questions, please call

Sincerely,  


Robert A. Herz, P.E.  
Project Manager



# PENN PRO

CAD Design & Technical Services

Mr. George Bien  
IMC Phosphates  
P.O. Box 2000  
Mulberry, FL 33860-100

12/14/01

REF: PENN PRO estimate for "C" Kiln Fluorine Scrubber Replacement  
Revision 2

After our review of the revised order of magnitude cost estimate for "C" Kiln Fluorine Scrubber replacement with a DR Technology Venturi scrubber on 12/12/01, I am providing these additional comments to clear up the apparent confusion with this estimate.

I apologize for the mix-up between the cost estimate and the letter that was attached. The second page of that memo was from the previous estimate. I have no explanation how that occurred. I have attached the report and cost estimate from 10/11/01, with the proper second page, as it should have been sent. This should clear up part of the confusion.

The addition of the venturi scrubber section resulted in replacing the existing fan with a larger fan. DR Technology had advised us that the existing SO<sub>2</sub> scrubber could withstand the new suction pressure conditions. The packed cross flow scrubber most probably will not as it is rectangular. Because it is carbon steel, rubber lined, adding additional external bracing will required stripping rubber internally, welding bracing and then re-installing the rubber lining, if it is reused. This would have caused extended kiln downtime. To shorten the plant downtime, I estimated a new scrubber body designed based on the new suction pressure.

Also, as stated in the original letter, this design would have reused the existing saddle packing.

I have included the original letter and cost estimate from 10/11/01.

If you have any questions, please call

Sincerely

Robert A. Herz, P.E.  
Project Manager

A handwritten signature in black ink, appearing to read "B Herz".

Mr. George Bien  
IMC Phosphates  
P.O. Box 2000  
Mulberry, FL 33860-100

10/11/01

**REF: PENN PRO estimate for "C" Kiln Fluorine Scrubber Replacement  
Revision 2**

I have completed the revised order of magnitude cost estimate for "C" Kiln Fluorine Scrubber replacement with a DR Technology Venturi scrubber.

The DR Technology Venturi Scrubber data was provided to PENN PRO by IMC and reviewed with Richard Swartz at DR technology by me. Richard advised me that the existing SO<sub>2</sub> scrubber can be used "as is" with the new operating and fan conditions.

This should be verified in writing by DR technology should this project proceed before finalizing the capital cost. I have not included any funds for any SO<sub>2</sub> scrubber modifications.

In addition, the existing pond water supply has been deemed sufficient for the new scrubber conditions by IMC. The existing "hot" system will be converted to a "cold" system as we discussed. PENN PRO has not checked this system. Funds for the piping modifications are included in the estimate.

I faxed the scrubber fan data for the new conditions, provided by you, to Robinson Fan, Pete Beringer. His reply indicates that a new fan will be required with the new conditions. I have attached the revised fan curve proposal provided by Robinson Fan. This is just a preliminary review by Robinson Fan. If the project does become a reality; the local office will have the factory engineers run the calculations for official verification. A new 250 HP motor will be required as well as foundation modifications.

The Cross Flow Scrubber body will need to be replaced to withstand the new suction conditions as well as the modifications for inlet ductwork to the venturi.

I have also assumed that IMC would re-use the existing packing in the new scrubber body.

I have based the revised estimate on a compressed schedule for Kiln downtime.

The estimate of Kiln downtime is 3 weeks on a premium time basis. The job will require 2-3 weeks before to prep and start electrical and piping additions and 1-2 weeks after to install the monorail system to pull the overhead piping. This is field time only.

The estimated cost for this project is \$ 839,000.00

If you have any questions, please call

Sincerely

Robert A. Herz, P.E.  
Project Manager

**ATTACHMENT 2**

**MULTIFOS PLANT – KILN C TEST SUMMARY**

**BEST AVAILABLE COPY**

		Source Sampling Summaries for Particulate and Fluoride Testing done on C Kiln							
Test condition or description:		Initial compliance test				Second Compliance Test			
Parameter	Unit	Run 1	Run 2	Run 3	Average	Run 1	Run 2	Run 3	Average
Date:		07/11/00	07/12/00	07/13/00		08/04/00	08/04/00	08/04/00	
Time Start:		844	853	1020		1224	1430	1555	
Time End:		948	1009	1125		1330	1537	1700	
Barometric Pressure:	Inch Hg	30.10	30.10	30.10		30.11	30.11	30.11	
Static Pressure:	Inch H2O	0.32	0.32	0.32		0.31	0.31	0.31	
Stack Pressure:	Inch Hg	30.124	30.124	30.124		30.133	30.133	30.133	
Average Sqrt Delta P:	Inch HOH 1/2	0.747	0.650	0.635		0.646	0.682	0.690	
Average Delta H:	Inch HOH	1.821	1.413	1.358	1.530	1.363	1.517	1.533	1.471
Maximum Run Vacuum:	Inch Hg	10.0	11.0	10.0		15.0	12.0	10.0	
Meter Box Number:	Unity	3187	3187	3187		3187	3187	3187	
Average Meter Temp:	Degrees F	84.8	81.2	91.7		82.9	83.8	82.2	
Average Stack Temp:	Degrees F	113.8	111.5	110.7	112.0	111.8	112.0	112.7	112.2
Metered Sample Volume:	Cubic Feet	46.51	41.03	40.99		40.02	42.61	43.30	
Standard Meter Volume:	Cubic Feet	45.39	40.27	39.46		39.16	41.65	42.44	
Moisture Measured:	%	0.0894	0.0897	0.0787		0.0886	0.0824	0.0808	
Moisture Saturation:	%	0.0962	0.0900	0.0880		0.0908	0.0912	0.0931	
oisture Used for Calculations:	%	0.0894	0.0897	0.0787	0.0860	0.0886	0.0824	0.0808	0.0839
Pitot Coefficient:	Unity	0.84	0.84	0.84		0.84	0.84	0.84	
Nozzle Diameter:	Inch	0.25	0.25	0.25		0.250	0.250	0.250	
Stack Area:	Square Feet	7.07	7.07	7.07		7.07	7.07	7.07	
Traverse Points:	Unity	24	24	24		24	24	24	
Sampling Time:	Minutes	60	60	60		60	60	60	
Stack Gas Molecular Weight:	lb/lb-mol	27.988	27.985	28.106		27.997	28.066	28.083	
Actual Stack Velocity:	Feet/sec	44.285	38.404	37.416	40.035	38.220	40.275	40.786	39.760
Actual Stack Gas Flow:	ACFM	18772	16279	15861	16971	16201	17072	17289	16854
Dry Standard Stack Gas Flow:	DSCFM	15835	13784	13610	14409	13730	14565	14756	14350
Isokinetic Rate:	%	99.10	101.00	100.23		98.61	98.87	99.44	
Fluoride Emission:	lb/day	7.74	14.05	10.56	10.78	17.54	15.14	8.90	13.86
	lb/hr	0.32	0.59	0.44		0.73	0.63	0.37	
Particulate Emission:	lb/day	13.28	41.58	105.46	53.44	156.02	101.93	65.73	107.89
	lb/hr	0.55	1.73	4.39		6.50	4.25	2.74	
Feed Rate	tph				5.80				7.50
Input P2O5 rate	P2O5 tph				2.05				2.59
Heat input	mmBtu/hr				32.10				40.00
Fluoride allowable	lb/hr				0.078				0.098
Average Fluoride	lb/hr				0.45				0.58
PM allowable	lb/hr				3.08				3.89
Average PM	lb/hr				2.23				4.50

Test condition or description:		Compliance test for authorization for the use of A or B as dryer for mixed feed. C Kiln was using dried feed.				Test for comparison of results with caustic flow on or off in SO2 scrubber. Samples analyzed by Pixe. This test with caustic ON.			
Parameter	Unit	Run 1	Run 2	Run 3	Average	Run 1	Run 2	Run 3	Average
Date:		10/31/00	10/31/00	10/31/00		11/30/00	11/30/00	11/30/00	
Time Start:		1130	1307	1430		1100	1241	1438	
Time End:		1244	1412	1536		1216	1400	1544	
Barometric Pressure:	Inch Hg	30.13	30.13	30.13		30.21	30.21	30.21	
Static Pressure:	Inch H2O	0.35	0.35	0.35		0.46	0.46	0.46	
Stack Pressure:	Inch Hg	30.156	30.156	30.156		30.244	30.244	30.244	
Average Sqrt Delta P:	Inch HOH 1/2	0.568	0.570	0.582		0.594	0.604	0.605	
Average Delta H:	Inch HOH	1.088	1.126	1.118	1.111	1.213	1.260	1.319	1.264
Maximum Run Vacuum:	Inch Hg	9.0	7.0	7.0		10.0	7.0	10.0	
Meter Box Number:	Unity	3187	3187	3187		3187	3187	3187	
Average Meter Temp:	Degrees F	84.2	88.6	79.6		75.9	81.8	82.0	
Average Stack Temp:	Degrees F	102.5	103.8	102.6	103.0	92.8	94.1	92.2	93.0
Metered Sample Volume:	Cubic Feet	35.84	36.65	37.12		37.80	38.93	39.29	
Standard Meter Volume:	Cubic Feet	34.99	35.49	36.55		37.58	38.29	38.64	
Moisture Measured:	%	0.0717	0.0525	0.0583		0.0570	0.0525	0.0525	
Moisture Saturation:	%	0.0692	0.0717	0.0693		0.0513	0.0534	0.0504	
Moisture Used for Calculations:	%	0.0692	0.0525	0.0583	0.0600	0.0513	0.0525	0.0504	0.0514
Pitot Coefficient:	Unity	0.84	0.84	0.84		0.84	0.84	0.84	
Nozzle Diameter:	Inch	0.248	0.248	0.248		0.248	0.248	0.248	
Stack Area:	Square Feet	7.07	7.07	7.07		7.07	7.07	7.07	
Traverse Points:	Unity	24	24	24		24	24	24	
Sampling Time:	Minutes	60	60	60		60	60	60	
Stack Gas Molecular Weight:	lb/lb-mol	28.210	28.393	28.329		28.406	28.393	28.416	
Actual Stack Velocity:	Feet/sec	33.175	33.224	33.931	33.443	34.229	34.822	34.841	34.631
Actual Stack Gas Flow:	ACFM	14063	14084	14383	14177	14510	14761	14769	14680
Dry Standard Stack Gas Flow:	DSCFM	12382	12596	12810	12596	13290	13471	13555	13439
Isokinetic Rate:	%	99.28	99.00	100.23		99.35	99.87	100.14	
Fluoride Emission:	Ib/day	8.76	14.94	21.15	14.95	16.27	9.52	14.59	13.46
	Ib/hr	0.37	0.62	0.88		0.68	0.40	0.61	
Particulate Emission:	Ib/day	42.54	73.95	102.40	72.96	106.90	72.64	108.16	95.90
	Ib/hr	1.77	3.08	4.27		4.45	3.03	4.51	
Feed Rate	tph				10.50				7.00
Input P2O5 rate	P2O5 tph				3.73				2.43
Heat input	mmBtu/hr				45.20				48.89
Fluoride allowable	Ib/hr				0.142				0.092
Average Fluoride	Ib/hr				0.62				0.56
PM allowable	Ib/hr				5.60				3.65
Average PM	Ib/hr				3.04				4.00

Test condition or description:		Test for comparison of results with caustic flow on or off in SO2 scrubber. Samples analyzed by Pixe. This test with caustic OFF.				Test done with fresh water supplied to demist section of packed scrubber before SO2 scrubber.			
Parameter	Unit	Run 1	Run 2	Run 3	Average	Run 1	Run 2	Run 3	Average
Date:		12/01/00	12/01/00	12/01/00		12/08/00	12/08/00	12/08/00	
Time Start:		824	1003	1130		905	1037	1155	
Time End:		930	1107	1234		1011	1149	1305	
Barometric Pressure:	Inch Hg	30.11	30.11	30.11		30.15	30.15	30.15	
Static Pressure:	Inch H2O	0.31	0.31	0.31		0.38	0.38	0.38	
Stack Pressure:	Inch Hg	30.133	30.133	30.133		30.178	30.178	30.178	
Average Sqrt Delta P:	Inch HOH 1/2	0.616	0.616	0.607		0.620	0.632	0.615	
Average Delta H:	Inch HOH	1.355	1.378	1.303	1.345	1.273	1.347	1.275	1.298
Maximum Run Vacuum:	Inch Hg	10.0	7.0	6.0		9.0	10.0	9.0	
Meter Box Number:	Unity	3187	3187	3187		3188	3188	3188	
Average Meter Temp:	Degrees F	66.1	77.8	80.1		73.5	80.8	86.5	
Average Stack Temp:	Degrees F	87.4	88.6	89.9	88.6	86.4	87.9	88.4	87.6
Metered Sample Volume:	Cubic Feet	39.58	39.95	39.70		39.04	40.35	39.95	
Standard Meter Volume:	Cubic Feet	39.97	39.47	39.05		39.90	40.69	39.86	
Moisture Measured:	%	0.0504	0.0552	0.0545		0.0541	0.0498	0.0514	
Moisture Saturation:	%	0.0435	0.0451	0.0470		0.0420	0.0441	0.0448	
Moisture Used for Calculations:	%	0.0435	0.0451	0.0470	0.0452	0.0420	0.0441	0.0448	0.0436
Pitot Coefficient:	Unity	0.84	0.84	0.84		0.84	0.84	0.84	
Nozzle Diameter:	Inch	0.248	0.248	0.248		0.248	0.248	0.248	
Stack Area:	Square Feet	7.07	7.07	7.07		7.07	7.07	7.07	
Traverse Points:	Unity	24	24	24		24	24	24	
Sampling Time:	Minutes	60	60	60		60	60	60	
Stack Gas Molecular Weight:	lb/lb-mol	28.492	28.474	28.453		28.508	28.486	28.477	
Actual Stack Velocity:	Feet/sec	35.325	35.392	34.935	35.217	35.470	36.213	35.305	35.663
Actual Stack Gas Flow:	ACFM	14974	15003	14809	14929	15036	15351	14966	15118
Dry Standard Stack Gas Flow:	DSCFM	13912	13885	13647	13815	14039	14263	13881	14061
Isokinetic Rate:	%	100.94	99.86	100.52		99.84	100.23	100.88	
Fluoride Emission:	lb/day	18.37	10.20	7.26	11.94	13.87	40.26	44.62	32.92
	lb/hr	0.77	0.42	0.30		0.58	1.68	1.86	
Particulate Emission:	lb/day	91.41	56.13	30.60	59.38	115.97	196.90	205.91	172.93
	lb/hr	3.81	2.34	1.27		4.83	8.20	8.58	
Feed Rate	tph				7.00				10.00
Input P2O5 rate	P2O5 tph				2.39				3.45
Heat input	mmBtu/hr				48.89				32.10
Fluoride allowable	lb/hr				0.091				0.131
Average Fluoride	lb/hr				0.50				1.37
PM allowable	lb/hr				3.59				5.18
Average PM	lb/hr				2.47				7.21

Test condition or description:		Test runs done with variations in water used prior to packed scrubber. Flow rate to transition duct was varied.					
			Direct	Direct		Redirect	Redirect
			High	Low	Flow	Low	High
For Calc P205							
Parameter	Unit	%HOH	8.17		Run 1	Run 2	
		%P	16.34				Run 1 Run 2
Date:		12/15/00	12/20/00		01/16/01	01/16/01	01/17/01 01/17/01
Time Start:		10:00	13:50		13:25	1405	10:00 10:51
Time End:		10:30	14:20		1335	1435	10:30 11:21
Barometric Pressure:	Inch Hg	30.32	30.22		30.09	30.09	30.13 30.13
Static Pressure:	Inch H2O	0.33	0.33		0.30	0.30	0.30 0.30
Stack Pressure:	Inch Hg	30.344	30.244		30.112	30.112	30.152 30.152
Average Sqrt Delta P:	Inch HOH 1/2	0.663	0.640		0.615	0.633	0.658 0.652
Average Delta H:	Inch HOH	1.368	1.500		1.298	1.363	1.486 1.464
Maximum Run Vacuum:	Inch Hg	9.0	9.0		6.0	6.0	7.0 8.0
Meter Box Number:	Unity	3188	3188		3188	3188	3188 3188
Average Meter Temp:	Degrees F	77.4	72.2		81.6	83.9	75.2 83.0
Average Stack Temp:	Degrees F	105.4	84.1		96.5	96.9	95.8 97.4
Metered Sample Volume:	Cubic Feet	19.93	20.21		19.46	20.03	20.77 20.92
Standard Meter Volume:	Cubic Feet	20.34	20.76		19.56	20.04	21.15 21.00
Moisture Measured:	%	0.0496	0.0323		0.0668	0.0733	0.0549 0.0614
Moisture Saturation:	%	0.0749	0.0390		0.0577	0.0585	0.0565 0.0593
oisture Used for Calculations:	%	0.0496	0.0323		0.0577	0.0585	0.0549 0.0593
Pitot Coefficient:	Unity	0.84	0.84		0.84	0.84	0.84 0.84
Nozzle Diameter:	Inch	0.248	0.248		0.25	0.25	0.25 0.25
Stack Area:	Square Feet	7.07	7.07		7.07	7.07	7.07 7.07
Traverse Points:	Unity	12	12		12	12	12 12
Sampling Time:	Minutes	30	30		30	30	30 30
Stack Gas Molecular Weight:	lb/lb-mol	28.425	28.615		28.336	28.328	28.367 28.319
Actual Stack Velocity:	Feet/sec	38.558	36.431		35.649	36.742	38.063 37.838
Actual Stack Gas Flow:	ACFM	16345	15443		15112	15575	16135 16039
Dry Standard Stack Gas Flow:	DSCFM	14712	14660		13596	13992	14598 14402
Isokinetic Rate:	%	97.13	99.52		99.45	99.04	100.19 100.83
Fluoride Emission:	lb/day	16.23	29.54		12.83	12.86	27.70 41.29
	lb/hr	0.68	1.23		0.53	0.54	1.15 1.72
Particulate Emission:	lb/day	127.11	150.93		99.24	80.82	137.25 194.89
	lb/hr	5.30	6.29		4.13	3.37	5.72 8.12
Feed Rate	tph	10.5	10.75		10.25	10.25	10.5 10.5
Input P2O5 rate	P2O5 tph	3.61	3.70		3.52	3.52	3.61 3.61
Heat input	mmBtu/hr						
Fluoride allowable	lb/hr	0.137	0.140		0.134	0.134	0.137 0.137
Average Fluoride	lb/hr	0.68	1.23		0.53	0.54	1.15 1.72
PM allowable	lb/hr	5.41	5.54		5.28	5.28	5.41 5.41
Average PM	lb/hr	5.30	6.29		4.13	3.37	5.72 8.12

Test condition or description:		Test runs done with steam addition prior to packed scrubber. Source of pond water to spray tower was varied.						Pre test before use as dryer.			
		Redirect	Redirect	pond water	Direct	Direct		Direct	Direct	Direct	
		Off	On	steam	Off	On					
Parameter	Unit	Run 1	Run 2		Run 1	Run 2		Run 1	Run 2	Run 3	Average
Date:		05/03/01	05/03/01		05/03/01	05/03/01		05/11/01	05/11/01	05/11/01	
Time Start:		840	955		1130	1220		923	1120	1306	
Time End:		910	1025		1200	1250		1026	1222	1408	
Barometric Pressure:	Inch Hg	30.27	30.27		30.27	30.27		30.17	30.17	30.16	
Static Pressure:	Inch H <sub>2</sub> O	0.32	0.32		0.32	0.32		-0.2	-0.18	-0.23	
Stack Pressure:	Inch Hg	30.294	30.294		30.294	30.294		30.16	30.16	30.14	
Average Sqrt Delta P:	Inch HOH 1/2	0.636	0.617		0.612	0.625					
Average Delta H:	Inch HOH	1.433	1.385		1.407	1.373					
Maximum Run Vacuum:	Inch Hg	11.0	10.0		8.0	7.0					
Meter Box Number:	Unity	3187	3187		3187	3187					
Average Meter Temp:	Degrees F	73.4	79.4		82.0	83.0		84.2	91.2	95	
Average Stack Temp:	Degrees F	94.0	96.2		95.0	97.9		101.2	100.5	101.8	101.1667
Metered Sample Volume:	Cubic Feet	20.42	20.02		19.93	20.25		38.298	39.954	39.859	
Standard Meter Volume:	Cubic Feet	20.63	20.00		19.82	20.10		37.488	38.623	38.249	
Moisture Measured:	%	0.0430	0.0411		0.0493	0.0576					
Moisture Saturation:	%	0.0532	0.0568		0.0548	0.0599					
oisture Used for Calculations:	%	0.0430	0.0411		0.0493	0.0576		5.8	5.9	5.7	5.8
Pitot Coefficient:	Unity	0.84	0.84		0.84	0.84		0.84	0.84	0.84	
Nozzle Diameter:	Inch	0.25	0.25		0.25	0.25		0.249	0.249	0.249	
Stack Area:	Square Feet	7.07	7.07		7.07	7.07		7.07	7.07	7.07	
Traverse Points:	Unity	12	12		12	12					
Sampling Time:	Minutes	30	30		30	30		60	60	60	
Stack Gas Molecular Weight:	lb/lb-mol	28.497	28.518		28.429	28.337					
Actual Stack Velocity:	Feet/sec	36.569	35.532		35.283	36.170		34.91	36.13	36.1	
Actual Stack Gas Flow:	ACFM	15501	15062		14956	15332		14806	15323	15311	15146.67
Dry Standard Stack Gas Flow:	DSCFM	14314	13883		13696	13845		13221	13691	13527	13479.67
Isokinetic Rate:	%	99.67	99.62		100.04	100.39		98.8	98.3	98.6	
Fluoride Emission:	lb/day	16.34	15.34		10.26	9.34					
	lb/hr	0.68	0.64		0.43	0.39		0.38	0.59	0.68	0.55
Particulate Emission:	lb/day	67.55	79.25		51.30	52.65					
	lb/hr	2.81	3.30		2.14	2.19	-	2	2.7	1.9	2.2
Feed Rate	tph	8.5	8.5		8.5	8.5					8.4
Input P2O5 rate	P2O5 tph	2.95	2.95		2.95	2.95					2.90
Heat input	mmBtu/hr										43
Fluoride allowable	lb/hr	0.112	0.112		0.112	0.112					0.110
Average Fluoride	lb/hr	0.68	0.64		0.43	0.39					0.54
PM allowable	lb/hr	4.43	4.43		4.43	4.43					4.35
Average PM	lb/hr	2.81	3.30		2.14	2.19					2.20

Test condition or discription:		Used as dryer.			
Parameter	Unit	Run 1	Run 2	Run 3	Average
Date:		05/24/01	05/24/01	05/24/01	
Time Start:		1122	1247	1420	
Time End:		1227	1356	1527	
Barometric Pressure:	Inch Hg	30.27	30.27	30.27	
Static Pressure:	Inch H <sub>2</sub> O	0.11	0.11	0.11	
Stack Pressure:	Inch Hg	30.27809	30.27809	30.27809	
Average Sqrt Delta P:	Inch HOH 1/2	0.337016	0.33067	0.308012	
Average Delta H:	Inch HOH	2.129167	2.083333	1.729167	1.980556
Maximum Run Vacuum:	Inch Hg	15	14	9	
Meter Box Number:	Unity	3188	3188	3188	
Average Meter Temp:	Degrees F	78.58333	84.91667	89.27083	
Average Stack Temp:	Degrees F	94.66667	94.79167	95.08333	94.84722
Metered Sample Volume:	Cubic Feet	48.747	48.689	45.94	
Standard Meter Volume:	Cubic Feet	50.57048	49.91772	46.68599	
Moisture Measured:	%	0.051324	0.052804	0.050381	
Moisture Saturation:	%	0.054287	0.054496	0.054987	
oisture Used for Calculations:	%	0.051324	0.052804	0.050381	0.051503
Pitot Coefficient:	Unity	0.84	0.84	0.84	
Nozzle Diameter:	Inch	0.382	0.382	0.382	
Stack Area:	Square Feet	7.065	7.065	7.065	
Traverse Points:	Unity	24	24	24	
Sampling Time:	Minutes	60	60	60	
Stack Gas Molecular Weight:	lb/lb-mol	28.40603	28.38979	28.41637	
Actual Stack Velocity:	Feet/sec	19.43532	19.07694	17.76613	18.75946
Actual Stack Gas Flow:	ACFM	8238.632	8086.713	7531.061	7952.135
Dry Standard Stack Gas Flow:	DSCFM	7528.826	7376.803	6883.883	7263.171
Isokinetic Rate:	%	99.46086	100.2006	100.4236	
Fluoride Emission:	lb/day	4.02	4.31	4.13	
	lb/hr	0.17	0.18	0.17	
Particulate Emission:	lb/day	47.5	46.4	52.7	
	lb/hr	1.98	1.93	2.20	
Feed Rate	tph				31.5
Input P2O5 rate	P2O5 tph				11.1
Heat input	mmBtu/hr				4.6
Fluoride allowable	lb/hr				0.42
Average Fluoride	lb/hr				0.17
PM allowable	lb/hr				16.65
Average PM	lb/hr				2.04

**NOTE:** (1) Steam rates were between 8 and 10 pounds per hour.

**ATTACHMENT 4**

**P.E. CERTIFICATION**

4. Professional Engineer Statement:

*I, the undersigned, hereby certify, except as particularly noted herein\*, that:*

- (1) *To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and*
- (2) *To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.*

*If the purpose of this application is to obtain a Title V source air operation permit (check here [ ] J, if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.*

*If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [ X ] J, if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.*

*If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [ ] J, if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.*

Signature

(seal)

8/8/02

Date

\* Attach any exception to certification statement.