



Wheelabrator Ridge Energy Inc.

A Wheelabrator Technologies Company
3131 K-ville Avenue
Auburndale, FL 33823

Phone 941.665.2255
Fax 941.665.0400

May 14, 1996

Mr. Clair Fancy, P.E.
Chief, Bureau of Air Regulation
Florida Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Re: Ridge Generating Station
Permit Number AC 53-206244 PSD-FL-183
Comment on Proposed BACT Limits

RECEIVED
MAY 16 1996
BUREAU OF
AIR REGULATION

Dear Mr. Fancy:

This letter provides our comments on the draft revised BACT limits for Ridge Generating Station (RGS) that were sent to us in your letter dated December 12, 1995. We agree with the proposed final BACT limits, test methods and averaging periods for Nitrogen Oxides (Nox), Volatile Organic Compounds (VOC), Hydrogen Chloride (HCL), Mercury (Hg), Lead (Pb), Beryllium (Be) and visual emissions. As discussed below however, we have comments on the proposed limits for Particulate Matter (PM), Carbon Monoxide (CO) and Sulfur Dioxide (SO₂) and we are requesting that these proposed limits be revised.

DISCUSSION

On September 29, 1992, the Florida Department of Environmental Protection (Department) issued a permit to construct RGS. Fuel for the facility consists of wood, tires and landfill gas. Various fuel mixes can be accommodated including wood alone, a mixture of wood and tires, and a mixture of wood, tires and landfill gas. To date, no landfill gas has been combusted, however, it is anticipated that the landfill gas supply will be available in approximately five months.

Specific Condition 5 of the permit specified initial emission limits for PM/PM10, SO₂, Nox, CO, VOC, Hcl, Hg, Pb and Be. Specific Condition 5 also included provisions for revising the initial emission limits or modifying the averaging periods based on the results of the Comprehensive Emissions Test Program.

Specific Condition 8 included the requirements for the Comprehensive Emissions Testing Program. Pursuant to the permit condition, a protocol for the Comprehensive Emissions Testing Program was submitted to the Department on October 29, 1993 and it was approved by the Department on November 23, 1993. The test protocol discussed the specific stack testing procedures and schedule of

boiler operating conditions and fuel mixtures. It also specified the statistical analyses that would be used to develop the revised BACT limits. The Comprehensive Emissions Testing Program included an initial stack test and three additional quarterly stack tests, as well as long term CEM data collection.

The initial permit limited the combustion of tires to 20% of the heat input to the boiler. On February 28, 1995, the Department authorized a test burn to evaluate the potential impacts associated with increasing the tire firing rate. The testing was conducted between March 1 and April 30, 1995. On August 8, 1995, the Department authorized an increase in the tire firing rate to 40% on a heat input basis. The Comprehensive Emission Testing Program addressed the full range of permitted fuel usage, from 100% wood/0% tires to 60% wood/40% tires.

Pursuant to specific Condition 16, the Comprehensive Emissions Testing Program Report was submitted to the Department on June 29, 1995. The report included data from the initial and three quarterly stack tests, which represented a variety of operating conditions. It also included a statistical analysis of the CEM data covering the time period from September 1, 1994 through April 30, 1995. In accordance with the approved protocol, revised permit limits were proposed based on the results of the testing program.

Instead of considering all of the results included in the Comprehensive Testing Program Report, the Department focused on the time period from March 1, 1995 through April 30, 1995 when establishing the proposed final BACT limits because it was assumed that the 60% wood/40% tires would represent worst case emissions for all pollutants. The Department established the proposed revised BACT limits by identifying the highest value (e.g. 30 day rolling average using CEM data or individual stack test result) measured during that time period and adding a margin for compliance. While we generally agree with that approach, we do not believe that 60% wood/40% tires represents the worst case condition for all pollutants. The 60% wood/40% tires will represent the worst case emissions for SO₂, however, as discussed below, it does not represent the worst case operating condition for other pollutants such as PM/PM₁₀ or CO. RGS needs to maintain the operational flexibility to combust the full range of permitted fuels (i.e., 100% wood/0% tires to 60% wood/40% tires). Therefore, the final BACT limits should be based on the worst case conditions for the full range of fuels.

Specific comments related to PM/PM₁₀, CO and SO₂ are provided below.

PM/PM₁₀

The proposed revised BACT limit for PM/PM₁₀ is 4.0 lb/hr (based on EPA Method 5). The Department established this proposed limit based on a measured emission rate of 2.1 lb/hr, which was associated with the highest of 6 individual runs that were

conducted while the facility was combusting 60% wood/40% tires at 100% load. The 2.1 lb/hr measured value was adjusted to provide a margin for compliance. While 2.1 lb/hr was the highest individual run for the 60% wood/40% tire condition, it was not the highest measured value for other fuel conditions.

As described in Appendix A of the Comprehensive Testing Program Report (submitted June 29, 1995), PM/PM10 data were collected during eight operating conditions with 3 test runs per condition for a total of 24 individual runs. While the average of the 24 individual runs equals 2.2 lb/hr, there were eight individual runs that were higher than the 2.1 lb/hr value referenced as the basis for the revised BACT limit. All eight of these occurred when the facility was combusting 80% wood/20% tires. One of these eight runs was at the proposed revised limit of 4.0 lb/hr and two of the individual runs exceeded the proposed revised BACT limit. More importantly, the three run average for Condition 1A (80% wood/20% tires) was 6.1 lb/hr, which is greater than the proposed final limit.

If we applied the same margin for compliance as that applied by the Department, the revised BACT Limit would be 11.6 lb/hr (i.e., $6.1 \times 1.9 = 11.6$). However, since one of the individual runs was measured at the current permit limit of 12.6 lb/hr, we request that the PM/PM10 limit be retained at the current permit limit of 12.6 lb/hr (based on EPA Method 5). This limit reflects an emission factor of 0.011 gr/DSCF corrected to 7% O₂ (0.02 lb/MM Btu) and it is an appropriate BACT limit for this type of facility. The PM limit was not identified as one of the disputed emission limitations in the initial BACT Determination (approved September 29, 1992). The initial Department's proposed BACT limit was the same as the limit proposed by Ridge Generating Station Limited Partnership (RGSLP), and the data illustrate that it is an appropriate emission limitation for this specific facility. The operating permit will require additional stack testing for PM/PM10 if the measured visual emissions (using EPA Method 9) exceed 10% opacity. Therefore, it is not necessary to reduce the limit, nor is it warranted based on the data.

Carbon Monoxide (CO)

The proposed revised BACT limit for CO was based on the highest 30 day rolling average (DRA) calculated by the Department for the time period from 3/30/95 through 4/30/95. The highest 30 DRA calculated by the Department during that time period was 101.6 lb/hr. This value was adjusted to provide a margin for compliance, which resulted in a proposed final BACT limit of 114.0 lb/hr.

It appears that this time period was selected because it was initially assumed that the 60% wood/40% tires condition would represent the worst case emissions with respect to the CO. A more comprehensive evaluation of the CEM data, however, demonstrates that the time period selected by the Department does not represent the worst case emissions for CO. Operating experience has demonstrated that the moisture content of the fuel is a very important factor with regard to CO

emissions. Since the moisture content of the wood is much higher than the moisture content of the tires, higher CO emissions appear to occur when tires represent less than 40% of the heat input to the boiler. Wood fuel with high moisture content will result in higher CO emissions due to its adverse effect on optimum combustion conditions. Compared to dry fuel, wet fuel does not burn as quickly or as efficiently on the grate or in the furnace since the moisture has to be driven off before complete combustion can occur. Optimum combustion conditions also require consistent fuel feed into the furnace and onto the grate. Wet fuel tends to cause unpredictable fuel system pluggages (chutes and hoppers) which can result in fuel flow interruptions and/or uneven fuel distribution into the furnace. When this occurs, operator adjustments can only have a limited effect on combustion until reliable fuel feed is re-established.

Thirty day rolling averages were calculated for the entire CEM data set that was submitted in Volume IV of the Comprehensive Emissions Testing Program Report. To simulate uninterrupted operations, the averages were calculated as 720 hour rolling averages including all hours of operation except those when the boiler was off-line (i.e., less than 5% load). The results of this analysis (see Attachment A) indicate that the average 30 DRA for the period running from September 1, 1994 through April 30, 1995 was 126.2 lbs/hr while the maximum 30 DRA was 191.6 lb/hr.

The CEM data for the period from May 1, 1995 to December 31, 1995 were also reviewed and 30 DRAs have been calculated (see Attachment B). This time period includes several months when the facility was authorized to combust up to 40% tires and also includes periods that are representative of anticipated worst case fuel conditions with respect to high moisture content in the wood. The average 30 DRA during this time period was 138.6 lb/hr with a maximum 30 DRA of 187.4 lb/hr. For this period, daily averages were calculated based on all of the operating hours in a given operating day and a 30 DRA was calculated each steam generating unit operating day by averaging the previous 30 steam generating operating day averages.

These data clearly demonstrate that the RGS cannot consistently meet the final BACT limit proposed by the Department. Using an approach consistent with that used by the Department, RGSLP proposes a revised CO limit of 215 lb/hr based on a 30 DRA. This represents the highest recorded 30 DRA adjusted to provide a margin for compliance (i.e. 191.6 lb/hr x 1.12). This limit would result in a reduction of 438 TPY of CO when compared to the interim permitted level.

Sulfur Dioxide (SO₂)

The final BACT limit proposed by the Department for SO₂ will unnecessarily restrict the operation of the RGS. The Department used a similar approach to develop the proposed final limit for SO₂. The highest 30 DRA for the time period from March

30, 1995 to April 30, 1995 was selected and a margin was added for compliance. The revised BACT determination acknowledges that the proposed limit is below the limit necessary to allow for the continuous operation of the facility at full capacity. However, it erroneously assumes that the facility has the capability of continuously meeting the proposed limit by increasing the lime injection rates to further control SO₂ emissions. As discussed below, the proposed final limit would actually prevent the facility from operating at its full permitted capacity.

The following factors need to be considered when establishing the final BACT limit for SO₂:

- The Department analysis assumed that the facility was combusting 60% wood/40% tires during the 3/30/95 to 4/30/95 time period. As illustrated in Attachment C, tires consistently represented less than 40% of the heat input during that time period. The daily average heat input associated with tires was 23.1%, while the daily heat inputs ranged from 10.3% to 36.7%.
- As described in the initial BACT analysis (Section 5.1.3 of the Permit Application), the SDA was designed to reliably achieve an 80% SO₂ removal efficiency on a long term basis. The original permit limit was based on the expected fuel sulfur content associated with firing 80% wood/20% tires and an 80% SO₂ removal efficiency (see Appendix B in the initial application). This resulted in an initial SO₂ permit limit of 109.4 lbs/hr based on a 24-hour average. On August 8, 1995 the facility was authorized to combust up to 40% tires on a heat input basis, however, the SO₂ limit was reduced to 72 lb/hour on a 30-day rolling average. As illustrated in Attachment D, a removal efficiency in excess of 90% is required to meet the existing interim SO₂ limit of 72 lb/hr when the facility is firing 40% tires. The calculations in Attachment D are based on measured sulfur content of the tires and wood fuels accepted at RGS.
- The SDA design, including vessel size, residence time, SDA outlet temperature, nozzle atomization, and nozzle configuration and spray patterns (number of nozzles) were based on 80% SO₂ removal at the anticipated fuel mix (i.e. 80% wood/20% tires). The lime slaking (slurry preparation) system was also sized based on the 80% removal requirement. Two 1000 lb/hr lime slakers (one operating/one spare) were installed to meet the SDA design requirements.

While the conservative SDA design margins can achieve the 72 lb/hr limit at the elevated SO₂ inlet levels, the associated 90% removal rate is the maximum achievable on a continuous basis. Maintenance and operating costs have increased substantially to maintain the operability and

reliability of the system. To continuously operate at an 90% removal level with the higher SO₂ inlet level (i.e. 40% tires) is beyond the capability of a single slaker. The plant is maintaining the required SO₂ removal level at the maximum tire firing rate by operating both slakers simultaneously. The amount of slurry that can physically be fed is limited by the piping, pump capacity and nozzle configuration of the SDA. The solids content in the slurry is occasionally high enough that it creates problems with the atomization. This results in incomplete drying of the flue gas, which causes significant problems in the ash handling system because that system was designed to handle dry ash. Increasing the required SO₂ removal to continuously maintain an even lower emission level will push the SO₂ removal system further beyond its design limit and present operational levels.

- The SDA vendor was contacted to discuss measures that could be implemented to enhance the performance of the existing system. The installed slurry delivery piping has been replaced with different materials to improve SDA performance. This has resulted in less build-up in the piping and improved slurry delivery to the spray nozzles. The manufacturer is also designing new spray lance heads and nozzles with the objective of improving atomization of the slurry and the drying in the SDA. These measures will improve the operability and reliability of the system, but will not provide for a continuous removal efficiency greater than 90%. Therefore, given the current design of the SO₂ control system, it is not technically feasible to reliably and continuously meet a permit limit that is more stringent than 72 lb/hr.
- With the current interim SO₂ limit, RGS has been forced to periodically reduce the tire feed rate to the boiler in order to ensure compliance with the limit. Any further reduction in the emissions limit will increase the frequency of reduced tire firing.
- The proposed revised BACT limit for SO₂ assumes that the plant will continue to operate at a reduced load. While this has been the pattern to date, it is certainly not the desired long term operating objective. The Department's revised BACT analysis assumes that the proposed revised BACT limit will not limit future plant operations because further control can be achieved by simply increasing the lime injection rates. As discussed above, this is not the case. Further reducing the SO₂ limit will significantly restrict the potential operations of the facility. It will preclude the facility from operating at its permitted design capacity.

In summary, the limited two months of data that the Department relied on when preparing the proposed revised BACT limits were not representative of 60%

wood/40% tire operation. RGS has already accepted a 34% reduction in the SO₂ limit for the facility. The proposed revised BACT limit for SO₂ was based on the erroneous assumption that the current SDA can reliably achieve higher removal efficiencies. However, this is not technically feasible because the SDA is already performing significantly beyond its design capacity. The tire feed rates have to be reduced periodically to ensure compliance with the existing limit. Further reducing the SO₂ limit will prevent the facility from operating at its maximum permitted capacity. Therefore, we request that the current interim SO₂ limit of 72 lb/hour (based on a 30 day rolling average) be retained as the final BACT limit.

CONCLUSION

We understand that you intend to address our earlier request (dated December 26, 1995) for minor permit changes at the same time that you issue the final proposed BACT limits. If you have any questions associated with the minor permit changes or related to our comments on the proposed BACT, please call Chuck Davis at 941-665-2255 or Matt Killeen at 603-929-3420. If you intend to propose final BACT limits that are more stringent than we have requested in this letter, we would like to have an opportunity to meet and discuss the limits before they are issued.

Sincerely,



Rodney Williams
Plant Manager

Attachments

cc: C. Davis
M. Killeen
A. Linero
T. Porter
J. Reynolds

Certification #P 597 437 510

Attachment A

30 Day Rolling Averages
(720 Hour Rolling Averages)

September 1, 1994 through April 30, 1995

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
Average				ERR	ERR	121.8	126.2
Median				ERR	ERR	83.8	125.9
Minimum				ERR	ERR	0.0	90.7
Maximum				ERR	ERR	630.6	191.6
Std Deviation				ERR	ERR	103.0	26.1
Count				0	0	5093	4374
t99				2.326	2.326	2.326	2.326
CI99				ERR	ERR	361.3	186.9
Count > CI99				0	0	240	65
a	b	c	d	c		CO-THR	CO720ROLL
9	1	94	0			40.8	
9	1	94	1			125.0	
9	1	94	2			124.1	
9	1	94	3			81.5	
9	1	94	4			34.6	
9	1	94	5			37.9	
9	1	94	6			52.6	
9	1	94	7			35.4	
9	1	94	8			88.6	
9	1	94	9			63.2	
9	1	94	10			41.3	
9	1	94	11			41.2	
9	1	94	12			53.0	
9	1	94	13			91.9	
9	1	94	14			45.3	
9	1	94	15			41.6	
9	1	94	16			41.8	
9	1	94	17			35.2	
9	1	94	18			46.8	
9	1	94	19			37.4	
9	1	94	20			41.9	
9	1	94	21			41.1	
9	1	94	22			43.8	
9	1	94	23			43.9	
9	2	94	0			41.4	
9	2	94	1			42.8	
9	2	94	2			37.8	
9	2	94	3			38.4	
9	2	94	4			36.3	
9	2	94	5			35.5	
9	2	94	6			43.0	
9	2	94	7			43.0	
9	2	94	8			44.1	
9	2	94	9			54.9	
9	2	94	10			35.6	
9	2	94	11			93.0	
9	2	94	12			46.6	
9	2	94	13			121.5	
9	2	94	14			239.8	
9	2	94	15			113.7	
9	2	94	16			49.6	
9	2	94	17			45.3	
9	2	94	18			58.2	
9	2	94	19			77.7	
9	2	94	20			32.2	
9	2	94	21			63.1	
9	2	94	22			195.1	
9	2	94	23			38.4	
9	3	94	0			32.7	
9	3	94	1			32.9	
9	3	94	2			36.9	
9	3	94	3			39.7	
9	3	94	4			39.2	
9	3	94	5			38.5	
9	3	94	6			35.1	
9	3	94	7			36.8	
9	3	94	8			46.2	
9	3	94	9			61.0	
9	3	94	10			142.5	
9	3	94	11			57.8	
9	3	94	12			95.1	
9	3	94	13			207.9	
9	3	94	14			56.5	
9	3	94	15			16.3	
9	3	94	16			160.1	
9	3	94	17			39.7	
9	3	94	18			64.7	
9	3	94	19			42.6	
9	3	94	20			48.1	
9	3	94	21			51.9	
9	3	94	22			41.4	
9	3	94	23			56.7	
9	4	94	0			50.7	

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging	Interval			1hr	720rolling	1hr	720rolling
9	4	94	1			55.7	
9	4	94	2			50.5	
9	4	94	3			46.5	
9	4	94	4			46.4	
9	4	94	5			57.0	
9	4	94	6			49.0	
9	4	94	7			56.2	
9	4	94	8			70.3	
9	4	94	9			51.6	
9	4	94	10			38.6	
9	4	94	11			46.2	
9	4	94	12			40.2	
9	4	94	13			41.9	
9	4	94	14			46.4	
9	4	94	15			52.8	
9	4	94	16			0.0	
9	4	94	17			88.7	
9	4	94	18			66.3	
9	4	94	19			39.6	
9	4	94	20			45.1	
9	4	94	21			39.9	
9	4	94	22			67.8	
9	4	94	23			48.9	
9	5	94	0			47.6	
9	5	94	1			47.2	
9	5	94	2			48.5	
9	5	94	3			99.4	
9	5	94	4			50.6	
9	5	94	5			54.4	
9	5	94	6			48.3	
9	5	94	7			328.2	
9	5	94	8			190.6	
9	5	94	9			92.1	
9	5	94	10			113.3	
9	5	94	11			66.7	
9	5	94	12			157.2	
9	5	94	13			71.6	
9	5	94	14			52.5	
9	5	94	15			46.9	
9	5	94	16			42.1	
9	5	94	17			52.3	
9	5	94	18			40.9	
9	5	94	19			42.1	
9	5	94	20			47.8	
9	5	94	21			41.3	
9	5	94	22			41.7	
9	5	94	23			45.1	
9	6	94	0			50.3	
9	6	94	1			49.2	
9	6	94	2			43.2	
9	6	94	3			44.3	
9	6	94	4			45.1	
9	6	94	5			43.3	
9	6	94	6			60.7	
9	6	94	7			45.8	
9	6	94	8			213.7	
9	6	94	9			74.0	
9	6	94	10			127.1	
9	6	94	11			98.1	
9	6	94	12			139.8	
9	6	94	13			206.2	
9	6	94	14			58.9	
9	6	94	15			54.7	
9	6	94	16			50.5	
9	6	94	17			44.3	
9	6	94	18			49.4	
9	6	94	19			61.9	
9	6	94	20			56.7	
9	6	94	21			63.6	
9	6	94	22			50.9	
9	6	94	23			74.2	
9	7	94	0			80.4	
9	7	94	1			78.0	
9	7	94	2			70.1	
9	7	94	3			59.8	
9	7	94	4			52.8	
9	7	94	5			64.1	
9	7	94	6			71.8	
9	7	94	7			58.0	
9	7	94	8			42.5	
9	7	94	9			119.3	
9	7	94	10			73.3	
9	7	94	11			54.5	

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
9 7	94 12				64.2	
9 7	94 13				101.5	
9 7	94 14				64.1	
9 7	94 15				91.2	
9 7	94 16				61.4	
9 7	94 17				73.0	
9 7	94 18				76.9	
9 7	94 19				58.1	
9 7	94 20				52.0	
9 7	94 21				47.9	
9 7	94 22				51.7	
9 7	94 23				64.2	
9 8	94 0	NO			59.9	
9 8	94 1	NO			52.2	
9 8	94 2	NO			54.2	
9 8	94 3	NO			56.3	
9 8	94 4	RL			318.9	
9 8	94 5	RL			428.7	
9 8	94 6	RL			67.0	
9 8	94 7	NO			92.9	
9 8	94 8	NO			66.8	
9 8	94 9	NO			93.6	
9 8	94 10	NO			79.3	
9 8	94 11	NO			55.2	
9 8	94 12	NO			63.2	
9 8	94 13	NO			76.8	
9 8	94 14	NO			77.8	
9 8	94 15	RL			147.2	
9 8	94 16	NO			76.8	
9 8	94 17	RL			93.7	
9 8	94 18	NO			83.8	
9 8	94 19	RL			194.4	
9 8	94 20	NO			53.4	
9 8	94 21	NO			70.6	
9 8	94 22	RL			145.3	
9 8	94 23	NO			129.2	
9 9	94 0	NO			84.1	
9 9	94 1	NO			96.4	
9 9	94 2	NO			93.1	
9 9	94 3	NO			74.2	
9 9	94 4	NO			67.5	
9 9	94 5	NO			60.5	
9 9	94 6	NO			66.3	
9 9	94 7	RL/PF			218.2	
9 9	94 8	RL/PF			350.0	
9 9	94 9	NO			109.6	
9 9	94 10	NO			90.7	
9 9	94 11	NO			64.6	
9 9	94 12	NO			127.5	
9 9	94 13	NO			48.7	
9 9	94 14	NO			57.3	
9 9	94 15	NO			66.5	
9 9	94 16	NO			105.5	
9 9	94 17	RL			183.0	
9 9	94 18	NO			53.1	
9 9	94 19	NO			170.9	
9 9	94 20	NO			235.4	
9 9	94 21	NO			56.3	
9 9	94 22	NO			83.5	
9 9	94 23	NO			45.5	
9 10	94 0	NO			49.1	
9 10	94 1	NO			46.8	
9 10	94 2	NO			64.0	
9 10	94 3	RL			49.1	
9 10	94 4	NO			40.4	
9 10	94 5	NO			40.8	
9 10	94 6	NO			44.0	
9 10	94 7	NO			80.0	
9 10	94 8	NO			140.0	
9 10	94 9	RL			81.4	
9 10	94 10	RL			76.7	
9 10	94 11	NO			106.5	
9 10	94 12	NO			106.4	
9 10	94 13	RL			520.3	
9 10	94 14	RL			522.3	
9 10	94 15	RL/PF			347.9	
9 10	94 16	SS			7.3	
9 10	94 17	RL/PF			222.9	
9 10	94 18	RL			92.2	
9 10	94 19	NO			37.0	
9 10	94 20	NO			52.1	
9 10	94 21	NO			87.2	
9 10	94 22	NO			82.1	

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging	Interval			1hr	720rolling	1hr	720rolling
9	10	94	23	NO		87.6	
9	11	94	0	NO		70.0	
9	11	94	1	NO		61.5	
9	11	94	2	NO		56.8	
9	11	94	3	NO		85.6	
9	11	94	4	NO		54.5	
9	11	94	5	NO		57.3	
9	11	94	6	NO		53.0	
9	11	94	7	NO		75.5	
9	11	94	8	NO		53.3	
9	11	94	9	NO		97.5	
9	11	94	10	NO		86.1	
9	11	94	11	NO		114.3	
9	11	94	12	NO		170.9	
9	11	94	13	NO		169.3	
9	11	94	14	NO		97.6	
9	11	94	15	NO		58.4	
9	11	94	16	NO		88.0	
9	11	94	17	NO		88.6	
9	11	94	18	NO		73.0	
9	11	94	19	NO		52.8	
9	11	94	20	NO		49.3	
9	11	94	21	NO		59.1	
9	11	94	22	NO		60.8	
9	11	94	23	NO		49.9	
9	12	94	0	NO		50.6	
9	12	94	1	NO		50.7	
9	12	94	2	NO		55.4	
9	12	94	3	NO		54.8	
9	12	94	4	NO		53.0	
9	12	94	5	NO		53.4	
9	12	94	6	NO		58.8	
9	12	94	7	NO		50.2	
9	12	94	8	NO		103.4	
9	12	94	9	RL		110.6	
9	12	94	10	NO		55.3	
9	12	94	11	NO		47.1	
9	12	94	12	NO		46.7	
9	12	94	13	NO		44.8	
9	12	94	14	NO		39.6	
9	12	94	15	NO		78.4	
9	12	94	16	NO		144.7	
9	12	94	17	NO		68.8	
9	12	94	18	NO		65.6	
9	12	94	19	NO		47.1	
9	12	94	20	NO		53.8	
9	12	94	21	NO		132.3	
9	12	94	22	NO		53.9	
9	12	94	23	NO		51.4	
9	13	94	0	NO		70.6	
9	13	94	1	NO		58.5	
9	13	94	2	NO		63.9	
9	13	94	3	NO		57.8	
9	13	94	4	NO		69.9	
9	13	94	5	NO		64.7	
9	13	94	6	NO		73.1	
9	13	94	7	RL		82.3	
9	13	94	8	RL		98.2	
9	13	94	9	NO		49.7	
9	13	94	10	NO		62.0	
9	13	94	11	NO		63.0	
9	13	94	12	NO		59.7	
9	13	94	13	NO		44.4	
9	13	94	14	NO		42.8	
9	13	94	15	NO		53.2	
9	13	94	16	NO		47.3	
9	13	94	17	NO		63.2	
9	13	94	18	NO		67.1	
9	13	94	19	NO		61.3	
9	13	94	20	NO		66.5	
9	13	94	21	NO		148.7	
9	13	94	22	NO		104.9	
9	13	94	23	NO		66.1	
9	14	94	0	NO		55.3	
9	14	94	1	NO		46.4	
9	14	94	2	NO		49.5	
9	14	94	3	NO		65.5	
9	14	94	4	NO		55.2	
9	14	94	5	NO		47.3	
9	14	94	6	NO		48.9	
9	14	94	7	MF		65.0	
9	14	94	8	RL		272.5	
9	14	94	9	RL		50.4	

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
9	14	94	10	NO		46.9	
9	14	94	11	NO		52.9	
9	14	94	12	NO		64.1	
9	14	94	13	NO		68.3	
9	14	94	14	NO		55.8	
9	14	94	15	NO		67.9	
9	14	94	16	NO		72.4	
9	14	94	17	NO		54.5	
9	14	94	18	NO		56.5	
9	14	94	19	NO		66.1	
9	14	94	20	NO		65.8	
9	14	94	21	NO		184.9	
9	14	94	22	NO		130.2	
9	14	94	23	RL		159.5	
9	15	94	0	RL		235.2	
9	15	94	1	RL		128.1	
9	15	94	2	RL		126.3	
9	15	94	3	RL		134.0	
9	15	94	4	RL		117.1	
9	15	94	5	RL		139.7	
9	15	94	6	RL		123.5	
9	15	94	7	RL		92.4	
9	15	94	8	RL		116.0	
9	15	94	9	RL		77.6	
9	15	94	10	NO		60.5	
9	15	94	11	NO		56.9	
9	15	94	12	NO		72.9	
9	15	94	13	NO		68.7	
9	15	94	14	NO		54.5	
9	15	94	15	NO		55.2	
9	15	94	16	NO		55.0	
9	15	94	17	NO		89.4	
9	15	94	18	RL		464.2	
9	15	94	19	RL/PF		453.2	
9	15	94	20	NO/PF		119.4	
9	15	94	21	NO/PF		107.8	
9	15	94	22	NO/PF		77.2	
9	15	94	23	RL		93.2	
9	16	94	0	RL		250.2	
9	16	94	1	RL		137.2	
9	16	94	2	RL		126.4	
9	16	94	3	RL		70.8	
9	16	94	4	RL		118.3	
9	16	94	5	MF		199.6	
9	16	94	8	SS		0.3	
9	16	94	9	SS		0.1	
9	16	94	10	SS		51.4	
9	16	94	11	RL/PF		248.3	
9	16	94	12	NO/PF		83.6	
9	16	94	13	NO/PF		91.5	
9	16	94	14	NO/PF		68.6	
9	16	94	15	NO		54.3	
9	16	94	16	NO		57.7	
9	16	94	17	NO		88.8	
9	16	94	18	NO		95.8	
9	16	94	19	NO		110.9	
9	16	94	20	NO		67.2	
9	16	94	21	NO		198.7	
9	16	94	22	NO		87.4	
9	16	94	23	RL		92.7	
9	17	94	0	RL		77.1	
9	17	94	1	RL		186.4	
9	17	94	2	RL		84.5	
9	17	94	3	RL		122.7	
9	17	94	4	RL		75.5	
9	17	94	5	RL		112.4	
9	17	94	6	RL		361.2	
9	17	94	7	RL		55.0	
9	17	94	8	RL		100.9	
9	17	94	9	RL		88.0	
9	17	94	10	NO		41.5	
9	17	94	11	NO		37.6	
9	17	94	12	NO		46.5	
9	17	94	13	NO		69.6	
9	17	94	14	NO		165.2	
9	17	94	15	NO		71.8	
9	17	94	16	NO		79.6	
9	17	94	17	NO		105.1	
9	17	94	18	NO		135.7	
9	17	94	19	NO		180.1	
9	17	94	20	NO		123.7	
9	17	94	21	NO		69.6	
9	17	94	22	NO		104.9	

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time		Operating Codes	#/hr	#/hr	CO	
Averaging	Interval	1hr	720rolling				1hr	720rolling
9	17	94	23	NO				108.8
9	18	94	0	RL				74.2
9	18	94	1	RL				57.5
9	18	94	2	RL				142.9
9	18	94	3	RL				366.2
9	18	94	4	RL/PF				20.1
9	18	94	5	RL/PF				226.4
9	18	94	6	RL				57.1
9	18	94	7	RL				89.9
9	18	94	8	RL				141.7
9	18	94	9	RL				97.2
9	18	94	10	NO				148.6
9	18	94	11	NO				354.7
9	18	94	12	NO				143.5
9	18	94	13	NO				61.7
9	18	94	14	NO				219.3
9	18	94	15	RL/PF				369.6
9	18	94	16	RL/PF				338.1
9	18	94	17	RL/PF				239.6
9	18	94	18	RL/PF				352.2
9	18	94	19	RL				29.6
9	18	94	20	SS				18.7
9	18	94	21	SS				81.2
9	18	94	22	SS				110.4
9	18	94	23	SS				57.0
9	19	94	0	SS				184.8
9	19	94	1	RL				187.2
9	19	94	2	RL/PF				53.3
9	19	94	3	RL/PF				314.5
9	19	94	4	RL				208.4
9	19	94	5	RL				219.7
9	19	94	6	MF				101.0
9	19	94	8	SS				454.6
9	19	94	9	RL				302.5
9	19	94	10	NO				44.9
9	19	94	11	NO				133.7
9	19	94	12	NO				49.9
9	19	94	13	NO				47.4
9	19	94	14	NO				47.3
9	19	94	15	NO				108.5
9	19	94	16	NO				135.1
9	19	94	17	NO				52.8
9	20	94	14	NO				313.7
9	20	94	15	NO				61.8
9	20	94	16	NO				56.5
9	20	94	17	NO				42.5
9	20	94	18	NO				138.2
9	20	94	19	NO				70.8
9	20	94	20	NO				113.3
9	20	94	21	NO				83.7
9	20	94	22	NO				67.7
9	20	94	23	RL				100.4
9	21	94	0	RL				77.1
9	21	94	1	RL				77.8
9	21	94	2	RL				74.7
9	21	94	3	RL				145.2
9	21	94	4	RL				508.2
9	21	94	5	RL				260.2
9	21	94	6	RL				345.9
9	21	94	7	RL				209.4
9	21	94	8	RL				234.1
9	21	94	9	RL/PF				288.6
9	21	94	10	RL/PF				89.6
9	21	94	11	RL				136.7
9	21	94	12	NO				74.8
9	21	94	13	RL				105.6
9	21	94	14	RL				142.9
9	21	94	15	RL				69.2
9	21	94	16	NO				49.7
9	21	94	17	NO				50.9
9	21	94	18	NO				39.3
9	21	94	19	NO				42.3
9	21	94	20	RL				76.2
9	21	94	21	RL				64.6
9	21	94	22	RL				67.3
9	21	94	23	RL				66.2
9	22	94	0	RL				76.7
9	22	94	1	RL				106.8
9	22	94	2	RL				81.5
9	22	94	3	RL				146.2
9	22	94	4	RL				119.1
9	22	94	5	RL				128.3
9	22	94	6	RL				128.9

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging	Interval			1hr	720rolling	1hr	720rolling
9	22	94	7	RL		461.0	
9	22	94	8	RL		504.7	
9	22	94	9	MF		105.9	
9	22	94	10	RL		96.4	
9	22	94	11	RL/PF		297.4	
9	22	94	12	MF		10.7	
9	22	94	13	MF		0.0	
9	22	94	14	MF		0.4	
9	22	94	15	MF		0.2	
9	22	94	16	MF		2.1	
9	22	94	17	MF		84.8	
9	22	94	18	RL/PF		498.9	
9	22	94	19	RL/PF		150.0	
9	22	94	20	RL/PF		0.7	
9	22	94	21	RL/PF		0.0	
9	22	94	22	MF		0.0	
9	22	94	23	MF		0.0	
9	23	94	0	MF		0.0	
9	23	94	1	RL/PF		181.7	
9	23	94	2	RL/PF		114.2	
9	23	94	3	RL		103.9	
9	23	94	4	RL		108.1	
9	23	94	5	RL		202.5	
9	23	94	6	RL		166.2	
9	23	94	7	RL		239.2	
9	23	94	8	RL		440.4	
9	23	94	9	RL		246.4	
9	23	94	10	RL		52.2	
9	23	94	11	NO		100.1	
9	23	94	12	RL		83.6	
9	23	94	13	NO		56.6	
9	23	94	14	NO		82.6	
9	23	94	15	NO		46.0	
9	23	94	16	NO		56.6	
9	23	94	17	RL		173.4	
9	23	94	18	RL		106.7	
9	23	94	19	RL		221.1	
9	23	94	20	RL		158.1	
9	23	94	21	RL		195.4	
9	23	94	22	RL		92.5	
9	23	94	23	RL		65.5	
9	24	94	0	RL		118.2	
9	24	94	1	RL		102.0	
9	24	94	2	RL		124.0	
9	24	94	3	RL		175.1	
9	24	94	4	RL		135.5	
9	24	94	5	RL		128.1	
9	24	94	6	RL		76.1	
9	24	94	7	RL		129.2	
9	24	94	8	RL		117.2	
9	24	94	9	RL		261.3	
9	24	94	10	RL		303.4	
9	24	94	11	RL		284.7	
9	24	94	12	RL		88.5	
9	24	94	13	RL		163.9	
9	24	94	14	RL		159.8	
9	24	94	15	RL		85.4	
9	24	94	16	NO		53.3	
9	24	94	17	RL		56.2	
9	24	94	18	NO		49.2	
9	24	94	19	RL		70.3	
9	24	94	20	RL		56.0	
9	24	94	21	NO		40.9	
9	24	94	22	NO		52.1	
9	24	94	23	NO		54.2	
9	25	94	0	RL		79.2	
9	25	94	1	RL		72.6	
9	25	94	2	RL		48.5	
9	25	94	3	RL		83.9	
9	25	94	4	RL		115.0	
9	25	94	5	RL		72.7	
9	25	94	6	RL		89.2	
9	25	94	7	RL		126.8	
9	25	94	8	RL		95.0	
9	25	94	9	RL		232.9	
9	25	94	10	RL		107.2	
9	25	94	11	RL		42.4	
9	25	94	12	RL		121.8	
9	25	94	13	RL		396.5	
9	25	94	14	RL		108.9	
9	25	94	15	RL		106.0	
9	25	94	16	RL		362.3	
9	25	94	17	RL		528.8	

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			thr	720rolling	thr	720rolling
9	25	94	18		RL	487.8
9	25	94	19		RL	495.6
9	25	94	20		RL	125.1
9	25	94	21		RL	251.9
9	25	94	22		RL	308.3
9	25	94	23		RL	533.0
9	26	94	0		RL	489.2
9	26	94	1		RL	303.8
9	26	94	2		RL	48.5
9	26	94	3		RL	80.3
9	26	94	4		RL	126.7
9	26	94	5		RL	148.5
9	26	94	6		RL	86.4
9	26	94	7		RL	75.6
9	26	94	8		RL	54.7
9	26	94	9		RL	42.8
9	26	94	10		RL	314.4
9	26	94	11		RL	507.4
9	26	94	12		RL/PF	430.1
9	26	94	13		RL/PF	89.2
9	26	94	14		RL/PF	15.1
9	26	94	15		RL/PF	262.7
9	26	94	16		RL/PF	179.7
9	26	94	17		RL	128.7
9	26	94	18		RL	303.9
9	26	94	19		RL	319.1
9	26	94	20		RL	252.3
9	26	94	21		RL	448.7
9	26	94	22		RL	216.1
9	26	94	23		RL	99.2
9	27	94	0		RL	232.7
9	27	94	1		RL	65.2
9	27	94	2		RL	69.0
9	27	94	3		NO	71.6
9	27	94	4		RL	87.3
9	27	94	5		RL	115.3
9	27	94	6		RL	200.8
9	27	94	7		RL	396.7
9	27	94	8		RL	377.6
9	27	94	9		RL	119.7
9	27	94	10		NO	44.7
9	27	94	11		RL	308.3
9	27	94	12		RL	331.5
9	27	94	13		RL	190.7
9	27	94	14		RL	159.6
9	27	94	15		RL	155.2
9	27	94	16		RL	172.9
9	27	94	17		RL	148.7
9	27	94	18		RL	58.9
9	27	94	19		RL/PF	183.7
9	27	94	20		MF	66.4
9	27	94	21		MF	157.3
9	27	94	22		RL/PF	210.0
9	27	94	23		RL	79.5
9	28	94	0		RL	59.9
9	28	94	1		RL	75.7
9	28	94	2		RL	258.5
9	28	94	3		RL	226.1
9	28	94	4		RL/PF	212.2
9	28	94	5		RL/PF	331.0
9	28	94	6		RL/PF	268.4
9	28	94	7		RL/PF	216.7
9	28	94	8		RL	255.9
9	28	94	9		RL	154.4
9	28	94	10		RL	110.1
9	28	94	11		RL	180.7
9	28	94	12		RL	131.6
9	28	94	13		RL	116.2
9	28	94	14		RL	117.6
9	28	94	15		NO	125.8
9	28	94	16		NO	49.4
9	28	94	17		NO	54.8
9	28	94	18		RL	262.2
9	28	94	19		RL	129.8
9	28	94	20		RL	172.7
9	28	94	21		RL	91.9
9	28	94	22		RL	107.3
9	28	94	23		NO	95.6
9	29	94	0		RL	101.0
9	29	94	1		RL	92.8
9	29	94	2		RL	123.2
9	29	94	3		RL	159.5
9	29	94	4		RL	181.3

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				lhr	720rolling	lhr	720rolling
9	29	94	5	RL		197.1	
9	29	94	6	RL		96.0	
9	29	94	7	RL		118.7	
9	29	94	8	RL		132.9	
9	29	94	9	RL		53.9	
9	29	94	10	RL		109.0	
9	29	94	11	NO		45.3	
9	29	94	12	RL		127.6	
9	29	94	13	NO		211.1	
9	29	94	14	NO		45.4	
9	29	94	15	NO		58.4	
9	29	94	16	RL		84.7	
9	29	94	17	RL		392.0	
9	29	94	18	NO		90.4	
9	29	94	19	NO		68.3	
9	29	94	20	RL		66.3	
9	29	94	21	RL		111.3	
9	29	94	22	RL		112.3	
9	29	94	23	RL		110.7	
9	30	94	0	RL		153.2	
9	30	94	1	RL		91.1	
9	30	94	2	RL		167.2	
9	30	94	3	RL		143.2	
9	30	94	4	RL		195.9	
9	30	94	5	RL		76.5	
9	30	94	6	RL		77.9	
9	30	94	7	RL		70.1	
9	30	94	8	RL		102.6	
9	30	94	9	NO		55.0	
9	30	94	10	NO		138.8	
9	30	94	11	NO		76.4	
9	30	94	12	NO		63.9	
9	30	94	13	RL		146.2	
9	30	94	14	RL		155.3	
9	30	94	15	NO		66.2	
9	30	94	16	NO		67.1	
9	30	94	17	NO		70.1	
9	30	94	18	NO		44.5	
9	30	94	19	NO		81.6	
9	30	94	20	NO		77.7	
9	30	94	21	NO		120.6	
9	30	94	22	RL		225.4	
9	30	94	23	RL		513.9	
10	1	94	0	RL		273.7	
10	1	94	1	RL		126.0	
10	1	94	2	RL		73.0	
10	1	94	3	RL		90.4	
10	1	94	4	NO		57.5	
10	1	94	5	RL		62.3	
10	1	94	6	RL		49.2	
10	1	94	7	RL		92.5	
10	1	94	8	RL		80.9	
10	1	94	9	RL		92.6	
10	1	94	10	RL		68.2	
10	1	94	11	NO		65.0	
10	1	94	12	RL		92.6	
10	1	94	13	NO		84.9	
10	1	94	14	RL		55.3	
10	1	94	15	RL		192.5	
10	1	94	16	RL		130.4	
10	1	94	17	RL		91.4	
10	1	94	18	NO		41.2	
10	1	94	19	NO		43.3	
10	1	94	20	NO		41.7	
10	1	94	21	RL		49.3	
10	1	94	22	RL		67.9	110.9
10	1	94	23	RL		113.0	111.0
10	2	94	0	RL		73.3	110.9
10	2	94	1	RL		113.7	110.9
10	2	94	2	RL		69.6	110.9
10	2	94	3	RL		62.0	111.0
10	2	94	4	RL		50.4	111.0
10	2	94	5	RL		62.8	111.0
10	2	94	6	RL		38.6	111.0
10	2	94	7	RL		59.1	110.9
10	2	94	8	RL		46.1	110.9
10	2	94	9	RL		56.2	110.9
10	2	94	10	NO/PF		51.9	111.0
10	2	94	11	RL/PF		57.7	111.0
10	2	94	12	RL		60.2	110.9
10	2	94	13	NO		48.7	110.9
10	2	94	14	NO		55.1	110.9
10	2	94	15	NO		60.2	111.0

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
			1hr	720rolling	1hr	720rolling
10	2	94	16	RL	61.4	111.0
10	2	94	17	RL	72.1	111.0
10	2	94	18	RL	58.7	111.1
10	2	94	19	RL	68.8	111.1
10	2	94	20	RL	167.1	111.3
10	2	94	21	RL	114.9	111.4
10	2	94	22	RL	159.3	111.5
10	2	94	23	MF	376.8	112.0
10	3	94	0	RL	122.4	112.1
10	3	94	1	RL	39.0	112.1
10	3	94	2	RL	11.8	112.1
10	3	94	8	RL	85.5	112.2
10	3	94	9	RL	107.7	112.3
10	3	94	10	RL	85.1	112.3
10	3	94	11	RL/PF	189.1	112.5
10	3	94	12	MF	152.5	112.7
10	3	94	13	RL/PF	252.7	112.9
10	3	94	14	RL	149.9	113.1
10	3	94	15	NO	143.1	113.2
10	3	94	16	RL	60.9	113.2
10	3	94	17	RL	63.2	113.1
10	3	94	18	RL	76.5	112.9
10	3	94	19	RL	105.4	112.9
10	3	94	20	RL	85.8	112.9
10	3	94	21	RL	64.2	112.9
10	3	94	22	RL	57.9	112.9
10	3	94	23	RL	60.9	112.9
10	4	94	0	RL	194.3	113.1
10	4	94	1	RL	208.1	113.3
10	4	94	2	MF	441.0	113.7
10	4	94	3	RL	518.7	114.4
10	4	94	4	RL	176.1	114.6
10	4	94	5	RL	85.0	114.6
10	4	94	6	RL/PF	154.4	114.8
10	4	94	7	RL/PF	176.5	115.0
10	4	94	8	RL/PF	174.8	115.2
10	4	94	11	NO	49.2	115.2
10	4	94	12	NO	79.2	115.2
10	4	94	13	RL	226.7	115.5
10	4	94	14	MF	80.3	115.6
10	4	94	15	RL	128.1	115.6
10	4	94	16	NO	217.5	115.8
10	4	94	17	NO	240.4	116.0
10	4	94	18	NO	122.0	116.0
10	4	94	19	NO	55.4	115.8
10	4	94	20	NO	72.9	115.9
10	4	94	21	NO	89.2	116.0
10	4	94	22	NO	123.4	115.9
10	4	94	23	RL	242.6	116.2
10	5	94	0	RL	151.8	116.3
10	5	94	1	RL	77.9	116.4
10	5	94	2	RL	100.6	116.4
10	5	94	3	RL	123.5	116.5
10	5	94	4	RL	158.0	116.7
10	5	94	5	RL	182.5	116.9
10	5	94	6	RL	86.6	116.9
10	5	94	7	NO	53.8	116.9
10	5	94	8	NO	37.1	116.9
10	5	94	9	NO	38.0	116.9
10	5	94	10	RL	69.4	116.9
10	5	94	11	NO	64.3	116.9
10	5	94	12	NO	128.5	117.0
10	5	94	13	NO	69.5	117.1
10	5	94	14	MF	299.8	117.4
10	5	94	15	MF	1.9	117.3
10	5	94	16	RL	102.1	117.4
10	5	94	17	RL	266.8	117.7
10	5	94	18	RL	156.2	117.9
10	5	94	19	NO	164.7	118.0
10	5	94	20	NO	60.9	118.0
10	5	94	21	NO	107.5	118.1
10	5	94	22	NO/PF	93.5	118.3
10	5	94	23	MF	17.0	118.2
10	6	94	0	RL/PF	122.1	118.2
10	6	94	1	RL	105.5	118.3
10	6	94	2	RL	119.9	118.4
10	6	94	3	RL	89.6	118.5
10	6	94	4	RL	96.5	118.5
10	6	94	5	RL	100.2	118.6
10	6	94	6	RL	95.7	118.7
10	6	94	7	RL	70.5	118.7
10	6	94	8	RL	73.8	118.7
10	6	94	9	NO	129.3	118.8

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
			1hr	720rolling	1hr	720rolling
10 6 94	10	RL/PF			109.6	118.9
10 6 94	11	MF			26.8	118.8
10 6 94	12	MF			34.3	118.8
10 6 94	13	RL/PF			188.4	118.6
10 6 94	14	NO			200.7	118.6
10 6 94	15	NO			58.4	118.6
10 6 94	16	RL			426.6	119.0
10 6 94	17	NO			163.6	119.2
10 6 94	18	NO			167.9	119.2
10 6 94	19	RL/PF			192.3	119.3
10 6 94	20	NO			103.3	119.4
10 6 94	21	NO			229.2	119.7
10 6 94	22	MF			83.8	119.7
10 6 94	23	MF			260.6	120.0
10 7 94	0	RL			154.5	120.2
10 7 94	1	RL/PF			47.6	120.2
10 7 94	2	RL/PF			2.3	120.1
10 7 94	3	RL/PF			4.1	120.1
10 7 94	4	RL/PF			0.0	120.0
10 7 94	5	RL/PF			136.6	120.1
10 7 94	6	RL			95.4	120.2
10 7 94	7	NO			60.0	120.2
10 7 94	8	RL			65.7	120.2
10 7 94	9	RL/PF			105.9	120.3
10 7 94	12	NO			117.5	120.4
10 7 94	13	MF			134.3	120.5
10 7 94	14	MF			505.3	121.2
10 7 94	15	RL			467.4	121.7
10 7 94	16	RL			203.1	121.7
10 7 94	17	RL			305.7	122.1
10 7 94	18	NO			197.5	122.2
10 7 94	19	RL			201.5	122.3
10 7 94	20	RL			542.5	122.9
10 7 94	21	RL			530.9	123.3
10 7 94	22	RL			522.3	124.0
10 9 94	7	SS			0.9	123.9
10 9 94	8	RL/PF			89.7	123.9
10 9 94	9	NO			273.4	124.2
10 9 94	11	RL			187.6	124.4
10 9 94	12	RL			254.3	124.7
10 9 94	13	RL			521.1	125.4
10 9 94	14	RL			545.1	126.0
10 9 94	15	RL/PF			74.4	126.1
10 9 94	16	RL/PF			2.5	126.0
10 9 94	17	PF			1.1	125.8
10 9 94	18	PF			0.8	125.7
10 9 94	19	PF			0.9	125.6
10 9 94	20	PF			0.6	125.6
10 9 94	21	PF			0.6	125.5
10 10 94	12	SS			0.1	125.4
10 10 94	13	SS			0.2	125.3
10 10 94	14	SS			0.0	125.2
10 10 94	15	SS			0.2	125.2
10 10 94	16	RL/PF			175.9	125.2
10 10 94	17	RL			75.7	125.2
10 10 94	18	RL			160.7	125.4
10 10 94	19	RL			430.8	125.9
10 14 94	8	SS			10.3	125.8
10 14 94	9	RL/PF			199.4	126.0
10 14 94	10	NO			120.9	126.0
10 14 94	11	RL			129.3	126.1
10 14 94	12	RL			321.7	126.4
10 14 94	13	RL			327.5	126.8
10 14 94	14	RL			159.7	126.9
10 14 94	15	RL			199.3	127.1
10 14 94	16	RL			72.9	127.2
10 14 94	17	RL			170.2	127.3
10 14 94	18	RL			178.8	127.5
10 14 94	19	MF			238.6	127.7
10 14 94	20	NO			301.0	128.1
10 14 94	21	NO			184.0	128.3
10 14 94	22	NO			215.9	128.5
10 14 94	23	RL/PF			387.7	128.6
10 15 94	0	RL/PF			3.4	128.0
10 15 94	1	RL/PF			3.2	127.9
10 15 94	2	RL/PF			342.2	128.3
10 15 94	3	RL			272.1	128.5
10 15 94	4	RL			291.4	128.8
10 15 94	5	NO			143.5	128.9
10 15 94	6	NO			62.9	128.9
10 15 94	7	NO			95.5	129.0
10 15 94	8	NO/PF			111.6	129.0
10 15 94	9	RL/PF			77.3	129.0

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
10	15	94	10	RL/PF		4.1	128.8
10	15	94	11	RL/PF		0.3	128.7
10	15	94	12	RL/PF		0.1	128.6
10	15	94	13	RL/PF		0.0	128.5
10	15	94	14	RL/PF		0.1	128.2
10	15	94	15	RL/PF		0.1	128.1
10	15	94	16	RL/PF		0.1	128.0
10	15	94	17	RL/PF		0.0	127.8
10	15	94	18	RL/PF		0.0	127.6
10	15	94	19	RL/PF		66.1	127.6
10	15	94	20	RL		172.9	127.7
10	15	94	21	RL		55.3	127.7
10	15	94	22	RL		96.5	127.7
10	15	94	23	RL		126.2	127.8
10	16	94	0	RL		182.7	127.9
10	16	94	1	RL		160.8	128.1
10	16	94	2	RL		184.6	128.0
10	16	94	3	RL		132.5	127.7
10	16	94	4	RL		105.3	127.7
10	16	94	5	RL		85.1	127.7
10	16	94	6	RL		59.1	127.7
10	16	94	7	RL/PF		276.0	127.9
10	16	94	8	RL/PF		248.7	128.2
10	16	94	9	RL		143.7	128.3
10	16	94	10	RL		220.3	128.5
10	16	94	11	RL		187.2	128.6
10	16	94	12	RL		39.4	128.4
10	16	94	13	RL		38.0	128.4
10	16	94	14	RL		50.9	128.2
10	16	94	15	RL		97.5	128.1
10	16	94	16	RL		64.6	128.1
10	16	94	17	RL		70.5	128.0
10	16	94	18	RL		68.4	128.1
10	16	94	19	RL		68.8	128.1
10	16	94	20	RL		53.1	128.1
10	16	94	21	NO		182.0	128.3
10	16	94	22	NO		368.2	128.7
10	16	94	23	RL		142.1	128.9
10	17	94	0	RL		59.5	128.9
10	17	94	1	RL		61.8	128.9
10	17	94	2	RL		81.7	128.9
10	17	94	3	RL		108.3	128.9
10	17	94	4	RL		67.4	128.9
10	17	94	5	RL		78.1	128.9
10	17	94	6	RL		125.2	128.9
10	17	94	7	RL		82.7	128.8
10	17	94	8	RL		59.8	128.2
10	17	94	9	MF		139.8	127.7
10	17	94	10	RL		128.0	127.4
10	17	94	16	SS		0.3	127.4
10	17	94	17	RL/PF		63.5	127.1
10	17	94	18	NO		46.3	127.1
10	17	94	19	NO		159.6	127.2
10	17	94	20	NO		117.2	127.3
10	17	94	21	NO		102.5	127.4
10	17	94	22	NO		146.5	127.4
10	17	94	23	RL		145.7	127.5
10	18	94	0	RL		78.8	127.5
10	18	94	1	RL		85.1	127.6
10	18	94	2	MF		343.4	128.0
10	18	94	3	RL		137.2	128.0
10	18	94	4	RL		110.8	128.1
10	18	94	5	RL		136.1	128.2
10	18	94	6	RL		138.8	128.3
10	18	94	7	RL		172.9	128.5
10	18	94	8	RL		137.2	128.6
10	18	94	9	RL		177.3	128.7
10	18	94	10	MF		99.4	128.7
10	18	94	11	RL		322.6	129.0
10	18	94	12	NO		78.2	128.9
10	18	94	13	NO		51.7	128.7
10	18	94	14	NO		55.6	128.7
10	18	94	15	NO		69.7	128.7
10	18	94	16	NO		62.5	128.7
10	18	94	17	NO		59.7	128.6
10	18	94	18	NO		70.1	128.6
10	18	94	19	NO		85.7	128.7
10	18	94	20	NO		102.4	128.7
10	18	94	21	NO		118.9	128.8
10	18	94	22	NO		152.3	128.9
10	18	94	23	RL		198.7	129.1
10	19	94	0	RL		135.9	129.3
10	19	94	1	RL		158.6	129.4

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
10 19 94	2	RL				118.5	129.5
10 19 94	3	RL				182.0	129.7
10 19 94	4	MF				215.8	129.9
10 19 94	5	RL				157.8	130.0
10 19 94	6	RL				154.2	130.2
10 19 94	7	RL				173.0	130.3
10 19 94	8	RL				163.6	130.4
10 19 94	9	MF				184.2	130.5
10 19 94	10	MF				162.6	130.7
10 19 94	11	NO				306.7	131.0
10 19 94	12	NO				363.9	131.5
10 19 94	13	NO				87.7	131.5
10 19 94	14	NO				232.9	131.8
10 19 94	15	NO				140.6	131.9
10 19 94	16	NO				154.6	131.9
10 19 94	17	NO				215.7	132.1
10 19 94	18	NO				145.2	132.2
10 19 94	19	NO				123.7	132.3
10 19 94	20	NO				135.2	132.4
10 19 94	21	NO				149.5	132.5
10 19 94	22	NO				83.9	132.5
10 19 94	23	RL				214.8	132.7
10 20 94	0	RL				118.2	132.8
10 20 94	1	RL				176.3	133.0
10 20 94	2	RL				180.1	133.1
10 20 94	3	RL				84.8	133.2
10 20 94	4	RL				51.2	133.1
10 20 94	5	RL				145.9	133.3
10 20 94	6	RL				149.1	133.4
10 20 94	7	RL				123.9	133.4
10 20 94	8	RL				123.8	133.5
10 20 94	9	RL				125.3	133.6
10 20 94	10	NO				163.3	133.7
10 20 94	11	NO				143.2	133.8
10 20 94	12	NO				131.4	133.9
10 20 94	13	NO				204.5	134.1
10 20 94	14	NO				233.5	134.4
10 20 94	15	NO				208.7	134.6
10 20 94	16	NO				265.1	134.9
10 20 94	17	NO				111.1	135.0
10 20 94	18	NO				212.9	135.2
10 20 94	19	NO				184.2	135.4
10 20 94	20	NO				125.8	135.4
10 20 94	21	NO				110.1	135.4
10 20 94	22	NO				164.1	135.5
10 20 94	23	RL				319.8	135.8
10 21 94	0	RL				209.6	136.0
10 21 94	1	RL				124.0	136.1
10 21 94	2	RL				62.7	136.2
10 21 94	3	RL				82.5	136.2
10 21 94	4	RL				116.9	136.3
10 21 94	5	RL				124.8	136.4
10 21 94	6	RL				75.4	136.4
10 21 94	7	RL				83.7	136.4
10 21 94	8	RL				97.5	136.2
10 21 94	9	RL				104.1	136.3
10 21 94	10	RL				103.1	136.3
10 21 94	11	RL				278.7	136.7
10 21 94	12	NO				168.1	136.8
10 21 94	13	NO				116.5	136.9
10 21 94	14	NO				129.7	137.0
10 21 94	15	NO				139.8	137.1
10 21 94	16	NO				153.0	137.2
10 21 94	17	NO				148.1	137.3
10 21 94	18	NO				104.0	137.4
10 21 94	19	NO				222.2	137.6
10 21 94	20	NO				137.1	137.7
10 21 94	21	NO				134.1	137.6
10 21 94	22	NO				108.6	137.6
10 21 94	23	RL				110.5	137.5
10 22 94	0	RL				123.6	137.4
10 22 94	1	RL				122.1	137.4
10 22 94	2	RL				56.9	137.3
10 22 94	3	RL				51.3	137.2
10 22 94	4	RL				60.4	137.1
10 22 94	5	RL				46.8	136.9
10 22 94	6	RL				42.3	136.8
10 22 94	7	RL				53.1	136.8
10 22 94	8	RL				68.4	136.7
10 22 94	9	RL				135.3	136.8
10 22 94	10	NO				187.8	137.0
10 22 94	11	NO				169.6	137.1
10 22 94	12	NO				101.8	137.2

**RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR**

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
10	22	94	13	NO		76.5	137.2
10	22	94	14	NO		126.5	137.3
10	22	94	15	NO		103.3	137.3
10	22	94	16	NO		95.4	137.4
10	22	94	17	RL		113.9	137.4
10	22	94	18	RL		246.5	137.1
10	22	94	19	NO		90.2	136.6
10	22	94	20	RL		182.9	136.7
10	22	94	21	MF		251.8	136.9
10	22	94	22	NO		125.1	137.0
10	22	94	23	RL		82.0	137.0
10	23	94	0	RL		72.8	136.7
10	23	94	1	RL		83.6	136.6
10	23	94	2	RL		54.3	136.5
10	23	94	3	RL		60.8	136.5
10	23	94	4	RL		62.3	136.5
10	23	94	5	RL/PF		91.2	136.3
10	23	94	6	MF		131.0	136.5
10	23	94	7	SS		38.6	136.5
10	23	94	8	RL/PF		349.5	137.0
10	23	94	9	RL		68.0	136.7
10	23	94	10	NO		104.9	136.7
10	23	94	11	NO		155.6	136.8
10	23	94	12	NO		192.9	137.0
10	23	94	13	NO		142.5	137.1
10	23	94	14	NO		278.7	137.4
10	23	94	15	NO		248.4	137.6
10	23	94	16	NO		261.3	137.9
10	23	94	17	NO		98.2	137.9
10	23	94	18	NO		97.8	137.9
10	23	94	19	NO		66.8	137.7
10	23	94	20	NO		198.0	137.9
10	23	94	21	NO		266.8	138.1
10	23	94	22	NO		330.5	138.5
10	23	94	23	RL		141.7	138.4
10	24	94	0	RL		42.6	138.3
10	24	94	1	RL		37.3	138.2
10	24	94	2	RL		78.7	138.2
10	24	94	3	RL/PF		186.1	138.3
10	24	94	4	RL/PF		79.9	137.9
10	24	94	5	RL		56.4	137.9
10	24	94	6	RL		60.6	137.9
10	24	94	7	RL		74.7	137.9
10	24	94	8	RL		68.5	137.9
10	24	94	9	RL		125.1	138.0
10	24	94	10	NO		79.1	138.1
10	24	94	11	NO		91.9	138.1
10	24	94	12	NO		112.0	138.0
10	24	94	13	NO		125.9	138.1
10	24	94	14	NO		175.1	138.2
10	24	94	15	NO		141.0	138.3
10	24	94	16	NO		213.2	138.4
10	24	94	17	NO		69.4	138.2
10	24	94	18	NO		191.1	138.3
10	24	94	19	NO		122.9	138.4
10	24	94	20	NO		136.0	138.5
10	24	94	21	NO		246.9	138.6
10	24	94	22	NO		350.9	139.0
10	24	94	23	NO		204.6	139.2
10	25	94	0	RL		135.1	139.2
10	25	94	1	RL		124.2	138.9
10	25	94	2	RL		110.6	139.0
10	25	94	3	RL		128.0	138.9
10	25	94	4	RL		109.3	139.0
10	25	94	5	RL		136.7	139.0
10	25	94	6	RL		211.7	139.1
10	25	94	7	RL		56.8	139.1
10	25	94	8	RL		72.3	139.0
10	25	94	9	NO		120.7	138.6
10	25	94	10	NO		184.8	138.7
10	25	94	11	NO		94.9	138.7
10	25	94	12	NO		95.1	138.6
10	25	94	13	NO		112.9	138.2
10	25	94	14	NO		158.0	137.9
10	25	94	15	NO		141.6	137.8
10	25	94	16	NO		298.6	137.7
10	25	94	17	NO		160.8	137.9
10	25	94	18	NO		239.1	138.2
10	25	94	19	NO		180.7	138.4
10	25	94	20	NO		166.4	138.4
10	25	94	21	NO		194.4	138.6
10	25	94	22	NO/PF		93.9	138.5
10	25	94	23	RL/PF		200.9	138.5

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
			1hr	720rolling	1hr	720rolling
10 26 94	0	RL/PF			244.3	138.8
10 26 94	1	RL/PF			168.7	138.6
10 26 94	2	RL			113.6	138.5
10 26 94	3	RL			179.0	138.4
10 26 94	4	RL			136.1	138.5
10 26 94	5	RL			125.6	138.0
10 26 94	6	RL			92.2	137.7
10 26 94	7	RL			80.7	137.8
10 26 94	8	RL			168.2	137.8
10 26 94	9	RL			104.8	137.9
10 26 94	10	NO			123.1	138.0
10 26 94	11	NO			178.3	138.2
10 26 94	12	NO			142.0	138.2
10 26 94	13	NO			175.3	138.3
10 26 94	14	NO			130.2	138.4
10 26 94	15	NO			97.8	138.1
10 26 94	16	NO			97.4	138.1
10 26 94	17	NO			119.5	138.2
10 26 94	18	NO			151.5	138.4
10 26 94	19	NO			77.8	138.3
10 26 94	20	NO			66.2	138.3
10 26 94	21	NO			67.8	138.2
10 26 94	22	NO			63.7	138.2
10 26 94	23	NO			82.5	138.2
10 27 94	0	RL			88.0	138.2
10 27 94	1	RL			107.2	138.2
10 27 94	2	RL			86.6	138.2
10 27 94	3	RL			79.4	138.2
10 27 94	4	RL			90.7	138.2
10 27 94	5	RL			108.4	137.6
10 27 94	6	RL			100.6	137.4
10 27 94	7	RL			75.0	137.0
10 27 94	8	NO			119.2	136.9
10 27 94	9	NO			72.5	136.7
10 27 94	10	NO			68.7	136.4
10 27 94	11	NO			82.4	136.3
10 27 94	12	NO			111.6	136.3
10 27 94	13	NO			89.4	136.3
10 27 94	14	NO			83.8	136.3
10 27 94	15	NO			86.4	136.2
10 27 94	16	NO			87.7	136.3
10 27 94	17	NO			115.4	136.3
10 27 94	18	MF			261.6	136.6
10 27 94	19	RL			310.7	137.0
10 27 94	20	RL			350.6	137.4
10 27 94	21	NO			297.4	137.7
10 27 94	22	MF			152.3	137.9
10 28 94	0	RL			211.6	138.1
10 28 94	1	MF			263.2	138.3
10 28 94	2	RL			112.5	138.4
10 28 94	3	RL			138.7	138.4
10 28 94	4	RL			95.3	138.5
10 28 94	5	RL			100.1	138.4
10 28 94	6	RL			89.3	138.4
10 28 94	7	RL			66.0	138.3
10 28 94	8	RL			51.1	138.2
10 28 94	9	NO			157.7	137.7
10 28 94	10	NO			135.6	137.2
10 28 94	11	NO			107.0	137.2
10 28 94	12	NO			85.4	137.2
10 28 94	13	NO			94.1	136.9
10 28 94	14	MF			99.7	137.1
10 28 94	15	MF			21.3	137.1
10 28 94	16	MF			427.4	137.7
10 28 94	17	RL			337.4	138.1
10 28 94	18	RL			294.9	138.5
10 28 94	19	NO			193.8	138.7
10 28 94	20	NO			165.6	138.2
10 28 94	21	NO			252.5	138.4
10 28 94	22	NO			246.3	138.7
10 28 94	23	RL			126.1	138.9
10 29 94	0	RL			74.5	139.0
10 29 94	1	RL			77.0	139.1
10 29 94	2	RL			81.9	139.2
10 29 94	3	RL			115.8	139.1
10 29 94	4	RL			120.5	139.1
10 29 94	5	RL			92.0	139.1
10 29 94	6	RL			84.0	139.1
10 29 94	7	RL			64.7	138.9
10 29 94	8	NO			172.7	138.9
10 29 94	9	NO			95.1	138.7
10 29 94	10	NO			114.5	138.3
10 29 94	11	NO			210.4	138.2

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set;
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			lhr	720rolling	lhr	720rolling
10 29 94	12	NO			136.9	138.3
10 29 94	13	NO			132.1	138.4
10 29 94	14	NO			117.4	138.4
10 29 94	15	NO			117.1	138.5
10 29 94	16	NO			106.9	138.5
10 29 94	17	NO			106.5	138.6
10 29 94	18	NO			139.2	138.7
10 29 94	19	NO			75.2	138.6
10 29 94	20	NO			93.8	138.6
10 29 94	21	NO			155.8	138.5
10 29 94	22	NO			203.2	138.5
10 29 94	23	NO			184.1	138.5
10 30 94	0	RL			168.3	138.6
10 30 94	1	RL			137.5	138.7
10 30 94	2	RL			43.8	138.6
10 30 94	3	RL			59.7	138.6
10 30 94	4	RL			60.1	138.5
10 30 94	5	RL			78.2	138.3
10 30 94	6	RL			93.5	138.3
10 30 94	7	RL			65.7	138.2
10 30 94	8	RL			33.6	138.1
10 30 94	9	NO			186.0	138.2
10 30 94	10	NO			171.8	138.3
10 30 94	11	NO			151.9	138.1
10 30 94	12	NO			165.1	138.0
10 30 94	13	MF			177.0	137.8
10 30 94	14	MF			331.2	138.1
10 30 94	15	MF			468.4	138.6
10 30 94	16	SS			44.8	138.4
10 30 94	18	RL/PF			41.0	138.3
10 30 94	19	RL/PF			6.9	138.3
10 30 94	20	RL/PF			3.3	138.2
10 30 94	21	RL			221.9	138.4
10 30 94	22	RL			523.5	139.1
10 30 94	23	RL			284.1	139.4
10 31 94	0	RL			55.0	139.4
10 31 94	1	RL			61.3	139.4
10 31 94	2	RL			84.1	139.5
10 31 94	3	RL			63.1	139.4
10 31 94	4	RL			56.8	139.4
10 31 94	5	RL			70.4	139.5
10 31 94	6	RL			47.7	139.4
10 31 94	7	RL/PF			185.3	139.5
10 31 94	8	RL/PF			65.4	139.5
10 31 94	9	RL/PF			14.5	139.4
10 31 94	10	RL/PF			0.8	139.2
10 31 94	11	RL/PF			0.5	139.1
10 31 94	12	RL/PF			0.6	138.8
10 31 94	13	RL/PF			0.6	138.6
10 31 94	14	RL/PF			64.6	138.6
10 31 94	15	RL			108.1	138.6
10 31 94	16	NO			83.7	138.2
10 31 94	17	NO			99.0	138.2
10 31 94	18	NO			286.3	138.4
10 31 94	19	NO			78.1	138.0
10 31 94	20	NO			207.0	137.6
10 31 94	21	NO			274.3	137.3
10 31 94	22	NO			138.2	136.8
10 31 94	23	RL			130.0	136.8
11 1 94	0	RL			84.5	136.6
11 1 94	1	RL			122.8	136.3
11 1 94	2	RL			150.6	135.8
11 1 94	3	RL			87.8	135.2
11 1 94	4	RL			83.9	134.9
11 1 94	5	RL			80.4	135.0
11 1 94	6	RL			116.1	135.0
11 1 94	7	RL/PF			9.4	134.8
11 1 94	8	RL/PF			0.7	134.6
11 1 94	17	RL/PF			45.1	134.6
11 1 94	18	RL			191.6	134.7
11 1 94	19	NO			120.2	134.8
11 1 94	20	NO			71.3	134.9
11 1 94	21	NO			61.2	134.5
11 1 94	22	NO			87.3	133.9
11 1 94	23	RL			103.1	133.5
11 2 94	0	RL			167.7	133.6
11 2 94	1	RL			262.5	133.9
11 2 94	2	MF			181.8	133.8
11 2 94	3	RL			277.2	134.0
11 2 94	4	RL			113.7	133.9
11 2 94	5	NO			115.7	133.7
11 2 94	6	NO			83.2	133.3
11 2 94	7	NO			104.9	133.1

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
11	2	94	8	NO		72.1	132.6
11	2	94	9	RL		183.8	132.6
11	2	94	10	RL		237.1	132.8
11	2	94	11	RL		198.7	132.7
11	2	94	12	RL		123.8	132.8
11	2	94	13	RL		240.8	133.0
11	2	94	14	RL/PF		243.4	133.3
11	2	94	15	RL/PF		67.1	133.3
11	2	94	16	MF		35.7	133.1
11	2	94	17	RL/PF		61.9	132.9
11	2	94	18	RL/PF		100.4	132.5
11	2	94	19	RL		51.8	132.1
11	2	94	20	RL		47.0	132.0
11	2	94	21	RL		58.0	132.0
11	2	94	22	RL		67.5	131.7
11	2	94	23	RL		66.8	131.3
11	3	94	0	RL		63.8	131.1
11	3	94	1	MF		107.7	131.1
11	3	94	2	RL		42.7	130.9
11	3	94	3	RL		39.3	130.7
11	3	94	4	MF		166.9	130.7
11	3	94	5	NO		93.6	130.8
11	3	94	6	NO		100.0	130.7
11	3	94	7	NO		73.6	130.7
11	3	94	8	NO		69.7	130.6
11	3	94	9	NO		67.4	130.4
11	3	94	10	NO		64.0	130.3
11	3	94	11	NO		61.3	130.3
11	3	94	12	NO		52.6	130.3
11	3	94	13	NO		54.6	130.0
11	3	94	14	NO		60.9	129.8
11	3	94	15	NO		54.2	129.6
11	3	94	16	NO		46.7	129.2
11	3	94	17	NO		55.3	128.9
11	3	94	18	NO		54.7	128.7
11	3	94	19	NO		48.5	128.4
11	3	94	20	NO		64.6	128.2
11	3	94	21	NO		107.5	128.2
11	3	94	22	NO		103.9	128.1
11	3	94	23	NO		78.8	128.1
11	4	94	0	RL		34.7	127.9
11	4	94	1	RL		47.6	127.8
11	4	94	2	RL		43.7	127.7
11	4	94	3	RL		43.2	127.7
11	4	94	4	NO		108.7	127.8
11	4	94	5	NO		71.0	127.5
11	4	94	6	NO		112.5	127.5
11	4	94	7	NO		220.0	127.6
11	4	94	8	NO		347.9	127.9
11	4	94	9	NO		135.9	128.0
11	4	94	10	NO		167.8	128.1
11	4	94	11	NO		129.8	128.1
11	4	94	12	NO		166.6	128.2
11	4	94	13	NO		205.9	128.3
11	4	94	14	NO		209.9	128.4
11	4	94	15	NO		293.2	128.6
11	4	94	16	NO		301.7	128.7
11	4	94	17	NO		338.8	129.0
11	4	94	18	NO		189.1	129.1
11	4	94	19	NO		130.6	129.1
11	4	94	20	NO		107.1	129.2
11	4	94	21	NO		147.8	129.3
11	4	94	22	NO		161.3	129.4
11	4	94	23	NO		109.7	129.4
11	5	94	0	NO		47.3	129.2
11	5	94	1	RL		62.7	129.2
11	5	94	2	RL		49.3	129.2
11	5	94	3	RL		54.5	129.1
11	5	94	4	NO		114.1	128.8
11	5	94	5	NO		78.8	128.7
11	5	94	6	NO		87.9	128.8
11	5	94	7	NO		137.9	128.9
11	5	94	8	NO		350.0	129.2
11	5	94	9	NO		135.1	129.2
11	5	94	10	NO		128.5	129.3
11	5	94	11	NO		118.9	129.2
11	5	94	12	NO		125.5	129.3
11	5	94	13	NO		130.0	129.2
11	5	94	14	NO		149.3	129.2
11	5	94	15	NO		118.2	129.1
11	5	94	16	NO		128.8	129.2
11	5	94	17	NO		124.9	129.2
11	5	94	18	SS		196.3	129.4

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100 %
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging	Interval			1hr	720rolling	1hr	720rolling
11	5	94	20	SS		194.7	129.5
11	5	94	21	SS		3.8	129.5
11	5	94	22	RL/PF		175.5	129.5
11	5	94	23	RL		84.7	129.5
11	6	94	0	RL		56.0	129.5
11	6	94	1	NO		55.1	129.4
11	6	94	2	NO		57.4	129.3
11	6	94	3	RL		84.7	129.3
11	6	94	4	NO		139.4	129.4
11	6	94	5	NO		132.6	129.5
11	6	94	6	NO		109.9	129.6
11	6	94	7	NO		149.0	129.7
11	6	94	8	NO		76.8	129.7
11	6	94	9	NO		88.1	129.6
11	6	94	10	NO		129.5	129.5
11	6	94	11	NO		77.9	128.9
11	6	94	12	NO		82.9	128.6
11	6	94	13	NO		77.2	128.5
11	6	94	14	NO		117.1	128.6
11	6	94	15	NO		79.8	128.6
11	6	94	16	NO		83.5	128.6
11	6	94	17	MF		68.6	128.6
11	6	94	20	SS		284.8	129.0
11	6	94	21	NO		195.4	129.1
11	6	94	22	NO		124.2	129.2
11	6	94	23	NO		82.7	129.1
11	7	94	0	RL		40.5	129.1
11	7	94	1	RL		33.2	129.1
11	7	94	2	RL		45.3	129.0
11	7	94	3	RL		84.0	129.0
11	7	94	4	NO		168.9	129.2
11	7	94	5	NO		156.6	129.1
11	7	94	6	NO		78.7	129.0
11	7	94	7	NO		139.7	129.1
11	7	94	8	RL		317.9	129.5
11	7	94	9	NO		73.9	129.5
11	7	94	10	RL		246.5	129.8
11	7	94	11	RL		315.9	130.2
11	7	94	12	RL		255.4	130.4
11	7	94	14	RL		206.6	130.6
11	7	94	15	RL		261.7	130.8
11	7	94	16	RL		217.4	131.0
11	7	94	17	RL		308.4	131.3
11	7	94	18	RL		249.4	131.6
11	7	94	19	RL		117.1	131.7
11	7	94	20	NO		308.6	132.0
11	7	94	21	NO		275.8	132.3
11	7	94	22	NO		103.1	132.4
11	7	94	23	RL		95.3	132.5
11	8	94	0	RL		83.6	132.5
11	8	94	1	RL		52.2	132.5
11	8	94	2	RL		81.3	132.5
11	8	94	3	RL		148.0	132.7
11	8	94	4	RL		68.7	132.7
11	8	94	5	RL		74.5	132.7
11	8	94	6	RL		238.2	133.0
11	8	94	7	RL		409.6	133.4
11	8	94	8	RL/PF		438.1	134.0
11	8	94	9	RL/PF		101.9	134.0
11	8	94	10	RL/PF		44.2	134.0
11	8	94	11	RL/PF		22.8	133.8
11	8	94	12	RL/PF		5.6	133.6
11	8	94	13	RL/PF		3.5	133.4
11	8	94	14	RL/PF		10.4	132.9
11	8	94	15	RL/PF		4.5	132.7
11	8	94	16	RL/PF		9.3	132.7
11	8	94	23	SS		1.2	132.7
11	9	94	-0	RL/PF		74.4	132.7
11	9	94	1	MF		317.4	133.0
11	9	94	2	RL		294.0	133.2
11	9	94	3	RL		137.1	133.2
11	9	94	4	RL		83.0	133.1
11	9	94	5	NO		58.4	132.8
11	9	94	6	NO		73.0	132.7
11	9	94	7	NO		55.0	132.6
11	9	94	8	NO		66.7	132.6
11	9	94	9	NO		101.5	132.6
11	9	94	10	NO		50.4	132.6
11	9	94	11	NO		42.2	132.5
11	9	94	12	NO		47.1	132.5
11	9	94	13	NO		178.2	132.6
11	9	94	14	MF		174.5	132.8
11	9	94	15	RL		164.3	132.9

**RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR**

Description of Data Set:
Load Range = 5-100 %
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date		Time		Operating Codes	#/hr	#/hr	CO	CO
Averaging Interval							1hr	720rolling
11	9	94	16	NO			73.1	132.8
11	9	94	17	NO			71.3	132.6
11	9	94	18	NO			77.9	132.1
11	9	94	19	RL			249.6	131.7
11	9	94	20	NO			91.4	131.6
11	9	94	21	NO			90.9	131.6
11	9	94	22	NO			58.8	131.4
11	9	94	23	RL			78.4	131.3
11	10	94	0	RL			78.3	131.2
11	10	94	1	RL			105.6	131.3
11	10	94	2	RL			76.0	131.3
11	10	94	3	RL			77.1	131.0
11	10	94	4	RL			84.6	131.0
11	10	94	5	RL			63.2	131.0
11	10	94	6	NO			128.1	130.8
11	10	94	7	NO			178.4	130.7
11	10	94	8	NO			166.7	130.8
11	10	94	9	MF			278.1	131.1
11	10	94	10	NO			94.3	131.1
11	10	94	11	NO			130.1	131.2
11	10	94	12	RL/PF			95.0	131.2
11	10	94	13	NO			71.2	130.9
11	10	94	14	NO			103.3	130.9
11	10	94	15	NO			128.8	130.9
11	10	94	16	NO			67.1	130.9
11	10	94	17	NO			156.3	130.9
11	10	94	18	RL			90.8	130.8
11	10	94	19	NO			85.1	130.7
11	10	94	20	NO			57.9	130.7
11	10	94	21	NO			50.6	130.7
11	10	94	22	NO			51.8	130.7
11	10	94	23	RL			89.4	130.7
11	11	94	0	RL			210.1	130.9
11	11	94	1	RL			141.8	131.1
11	11	94	2	RL			106.0	131.0
11	11	94	3	RL			154.2	131.1
11	11	94	4	RL			162.6	130.9
11	11	94	5	RL			75.4	131.1
11	11	94	6	NO			90.7	131.0
11	11	94	7	NO			242.0	131.0
11	11	94	8	NO			106.8	130.9
11	11	94	9	NO			68.9	130.8
11	11	94	10	NO			129.5	130.9
11	11	94	12	NO			193.4	131.0
11	11	94	13	NO			102.0	131.0
11	11	94	14	NO			64.8	131.1
11	11	94	15	NO			116.7	131.1
11	11	94	16	NO			152.8	131.1
11	11	94	17	MF			135.7	131.2
11	12	94	4	SS			1.2	131.0
11	12	94	5	RL/PF			2.0	130.9
11	12	94	6	RL/PF			0.3	130.8
11	12	94	7	RL/PF			97.4	130.8
11	12	94	8	RL			35.7	130.7
11	12	94	9	NO			167.8	130.9
11	12	94	10	NO			139.3	130.9
11	12	94	11	NO			92.5	130.9
11	12	94	12	NO			49.4	130.9
11	12	94	13	NO			81.0	130.9
11	12	94	14	NO			60.7	130.8
11	12	94	15	NO			90.4	130.6
11	12	94	16	NO			50.2	130.6
11	12	94	17	NO			108.7	130.2
11	12	94	18	NO			324.0	130.4
11	12	94	19	NO			221.2	130.5
11	12	94	20	NO			181.0	130.4
11	12	94	21	NO			163.3	130.5
11	12	94	22	RL			165.7	130.4
11	12	94	23	RL			297.1	130.7
11	13	94	0	RL			201.6	130.7
11	13	94	1	RL			216.6	130.7
11	13	94	2	RL			159.4	130.9
11	13	94	3	RL			196.2	131.2
11	13	94	4	RL			272.4	131.5
11	13	94	5	RL			95.6	131.7
11	13	94	6	NO			50.8	131.6
11	13	94	7	NO			72.4	131.5
11	13	94	8	NO			80.6	131.6
11	13	94	9	NO			106.8	131.6
11	13	94	10	RL			316.5	131.9
11	13	94	11	NO			209.8	132.0
11	13	94	12	NO			180.0	132.1
11	13	94	13	NO			296.9	131.8

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval	Interval		1hr	720rolling	1hr	720rolling
11	13	94	14	NO	209.0	131.4
11	13	94	15	NO	89.4	131.3
11	13	94	16	NO	59.0	130.9
11	13	94	17	NO	70.0	130.8
11	13	94	18	NO	154.1	130.7
11	13	94	19	NO	66.7	130.0
11	13	94	20	NO	53.8	129.4
11	13	94	21	NO	125.4	128.8
11	13	94	22	MF	268.3	129.2
11	13	94	23	RL	407.8	129.6
11	14	94	0	RL	0.0	129.3
11	14	94	1	RL	0.0	129.0
11	14	94	5	RL	156.0	128.9
11	14	94	6	NO	80.4	128.2
11	14	94	7	NO	175.1	127.7
11	14	94	10	NO	257.2	128.0
11	14	94	11	NO	207.8	128.3
11	14	94	12	NO	111.4	128.4
11	14	94	13	NO	143.9	128.6
11	14	94	14	NO	265.8	129.0
11	14	94	15	NO	189.2	129.3
11	14	94	16	NO	181.1	129.5
11	14	94	17	NO	159.1	129.7
11	14	94	18	NO	66.8	129.8
11	14	94	19	NO	91.6	129.9
11	14	94	20	NO	114.7	130.1
11	14	94	21	NO	81.8	130.0
11	14	94	22	NO	209.1	130.2
11	14	94	23	RL	417.9	130.5
11	15	94	0	RL	418.5	130.5
11	15	94	1	RL	425.4	131.1
11	15	94	2	RL	419.2	131.4
11	15	94	3	RL	414.2	131.8
11	15	94	4	RL	428.2	132.2
11	15	94	5	RL	147.4	132.0
11	15	94	6	RL	57.5	131.6
11	15	94	7	RL	57.1	131.4
11	15	94	8	MF	272.0	131.5
11	15	94	9	RL	212.2	131.7
11	15	94	10	RL	236.9	131.8
11	15	94	17	RL/PF	280.0	132.0
11	15	94	18	NO	61.6	131.7
11	15	94	19	NO	96.9	131.4
11	15	94	20	NO	37.3	131.2
11	15	94	21	NO	53.2	131.0
11	15	94	22	NO	47.2	130.5
11	15	94	23	RL	344.2	131.0
11	16	94	0	MF	456.1	131.6
11	16	94	12	RL/PF	136.8	131.4
11	16	94	13	RL/PF	192.5	131.2
11	16	94	14	RL/PF	185.8	131.1
11	16	94	15	RL/PF	58.3	131.0
11	16	94	16	RL	61.1	131.0
11	16	94	17	NO	87.7	131.0
11	16	94	18	NO	46.4	130.9
11	16	94	19	NO	144.7	131.0
11	16	94	20	NO	100.4	131.1
11	16	94	21	NO	67.4	131.2
11	16	94	22	NO	74.0	131.3
11	16	94	23	RL	148.6	131.5
11	17	94	0	RL	124.8	131.7
11	17	94	1	RL	180.2	131.9
11	17	94	2	RL	134.4	132.1
11	17	94	3	RL	126.2	132.3
11	17	94	4	RL	156.5	132.5
11	17	94	5	MF	97.8	132.6
11	17	94	8	NO	138.3	132.5
11	17	94	9	NO	79.4	132.5
11	17	94	10	RL	63.0	132.5
11	17	94	11	RL	38.0	132.4
11	17	94	12	NO	61.6	132.2
11	17	94	14	NO	38.9	132.0
11	17	94	15	NO	50.8	131.8
11	17	94	16	NO	53.1	131.7
11	17	94	17	NO	99.8	131.7
11	17	94	18	NO	36.4	131.7
11	17	94	19	NO	78.3	131.7
11	17	94	20	NO	59.3	131.4
11	17	94	21	NO	93.1	131.2
11	17	94	22	NO	83.3	131.1
11	17	94	23	RL	301.9	131.2
11	18	94	0	RL	209.0	131.2
11	18	94	1	RL	155.6	131.4

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging	Interval			1hr	720rolling	1hr	720rolling
11	18	94	2			192.9	131.6
11	18	94	3			178.0	131.8
11	18	94	4			88.3	131.8
11	18	94	5			79.3	131.8
11	18	94	6			170.8	131.9
11	18	94	7			60.1	131.9
11	18	94	8			74.7	131.9
11	18	94	9			42.1	131.9
11	18	94	10			65.0	131.8
11	18	94	11			264.0	131.6
11	18	94	12			236.8	131.7
11	18	94	13			107.7	131.8
11	18	94	14			68.5	131.8
11	18	94	15			51.3	131.8
11	18	94	16			128.9	131.8
11	18	94	17			124.7	131.9
11	18	94	18			61.2	131.9
11	18	94	19			66.8	131.8
11	18	94	20			69.1	131.8
11	18	94	21			92.9	131.8
11	18	94	22			248.7	132.0
11	18	94	23			215.4	132.1
11	19	94	0			206.8	132.4
11	19	94	1			126.6	132.4
11	19	94	2			83.7	132.5
11	19	94	3			228.5	132.6
11	19	94	4			186.6	132.7
11	19	94	5			211.5	132.8
11	19	94	6			630.6	133.5
11	19	94	7			281.8	133.7
11	19	94	8			70.4	133.7
11	19	94	9			335.9	134.0
11	19	94	10			326.8	134.0
11	19	94	11			415.2	134.4
11	19	94	12			70.3	134.3
11	19	94	13			98.7	134.3
11	19	94	14			170.3	134.3
11	19	94	15			50.0	134.2
11	19	94	16			154.9	134.2
11	19	94	17			110.5	134.1
11	19	94	18			73.9	134.1
11	19	94	19			87.9	133.7
11	19	94	20			100.4	133.8
11	19	94	21			52.5	133.8
11	19	94	22			71.1	133.8
11	19	94	23			165.1	133.9
11	20	94	0			227.5	134.2
11	20	94	1			88.2	134.2
11	20	94	2			101.8	134.2
11	20	94	3			252.2	134.5
11	20	94	4			106.7	134.5
11	20	94	5			79.6	134.4
11	20	94	6			92.8	134.3
11	20	94	7			158.9	134.3
11	20	94	8			105.9	134.2
11	20	94	9			250.5	134.4
11	20	94	10			197.2	134.5
11	20	94	11			112.8	134.4
11	20	94	12			119.2	134.3
11	20	94	13			81.4	134.1
11	20	94	14			232.9	134.3
11	20	94	15			92.0	134.1
11	20	94	16			93.8	134.0
11	20	94	17			176.9	134.0
11	20	94	18			130.0	134.0
11	20	94	19			54.6	133.6
11	20	94	20			55.7	133.2
11	20	94	21			58.0	133.2
11	20	94	22			119.9	133.0
11	20	94	23			60.3	132.9
11	21	94	0			79.4	132.8
11	21	94	1			119.3	132.7
11	21	94	2			170.3	132.7
11	21	94	3			130.5	132.7
11	21	94	4			80.3	132.6
11	21	94	5			61.8	132.5
11	21	94	6			79.2	132.5
11	21	94	7			78.0	132.3
11	21	94	8			52.3	132.2
11	21	94	9			49.9	132.0
11	21	94	10			53.3	131.9
11	21	94	11			68.0	131.8
11	21	94	12			56.8	131.9

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
11	21	94	13	NO		59.6	131.7
11	21	94	14	MF		210.9	131.8
11	21	94	15	RL		428.7	132.2
11	21	94	16	NO		88.4	132.2
11	21	94	17	NO		107.1	132.2
11	21	94	18	NO		91.9	132.1
11	21	94	19	NO		88.3	132.0
11	21	94	20	NO		61.5	131.9
11	21	94	21	NO		137.6	131.8
11	21	94	22	RL		104.7	131.6
11	21	94	23	RL		73.3	131.4
11	22	94	0	RL		100.3	131.2
11	22	94	1	RL		162.0	131.3
11	22	94	2	RL		105.8	131.1
11	22	94	3	RL		185.3	131.1
11	22	94	4	RL		89.1	131.1
11	22	94	5	RL		52.0	131.0
11	22	94	6	RL		59.0	130.9
11	22	94	7	RL		59.4	130.5
11	22	94	9	RL		175.1	130.4
11	22	94	10	RL		77.3	130.4
11	22	94	11	RL		56.5	130.4
11	22	94	12	RL		299.7	130.7
11	22	94	13	RL		155.0	130.7
11	22	94	14	RL		100.0	130.7
11	22	94	15	RL		95.0	130.7
11	22	94	16	RL		53.7	130.7
11	22	94	17	RL		80.3	130.7
11	22	94	18	RL		121.9	130.7
11	22	94	19	RL		115.8	130.7
11	22	94	20	RL		84.2	130.4
11	22	94	21	RL		101.9	130.3
11	22	94	22	RL		145.3	130.4
11	22	94	23	RL		259.3	130.6
11	23	94	0	RL		139.9	130.6
11	23	94	1	RL		117.7	130.5
11	23	94	2	RL		93.6	130.4
11	23	94	3	RL		90.1	130.4
11	23	94	4	RL		49.3	130.2
11	23	94	5	NO		31.4	130.0
11	23	94	6	NO		36.3	129.9
11	23	94	7	NO		47.6	129.8
11	23	94	8	NO		56.1	129.7
11	23	94	9	NO		40.7	129.6
11	23	94	10	NO		42.2	129.5
11	23	94	11	NO		38.7	129.5
11	23	94	12	NO		52.7	129.5
11	23	94	13	RL		330.9	129.9
11	23	94	14	RL		272.4	130.2
11	23	94	15	RL		158.7	130.3
11	23	94	16	NO		64.9	130.3
11	23	94	17	NO		29.4	130.3
11	23	94	18	RL		218.6	130.4
11	23	94	19	NO		30.3	130.2
11	23	94	20	NO		40.1	130.0
11	23	94	21	NO		100.4	130.0
11	23	94	22	RL		119.4	130.1
11	23	94	23	RL		348.0	130.4
11	24	94	0	RL		291.7	130.6
11	24	94	1	RL		271.7	130.9
11	24	94	2	RL		279.1	131.1
11	24	94	3	RL		261.8	131.1
11	24	94	4	RL		167.9	131.2
11	24	94	5	NO		41.8	131.0
11	24	94	6	NO		49.8	130.8
11	24	94	7	NO		62.3	130.7
11	24	94	8	NO		74.6	130.7
11	24	94	9	NO		91.8	130.7
11	24	94	10	NO		150.3	130.8
11	24	94	11	RL		113.6	130.9
11	24	94	12	RL		277.5	131.2
11	24	94	13	RL		193.5	131.3
11	24	94	14	RL		115.4	131.4
11	24	94	15	RL		193.0	131.5
11	24	94	16	RL		120.6	131.6
11	24	94	17	NO		72.9	131.2
11	24	94	18	RL		197.1	131.4
11	24	94	19	RL		181.0	131.5
11	24	94	20	RL		75.1	131.4
11	24	94	21	NO		47.3	131.2
11	24	94	22	RL		90.3	131.1
11	24	94	23	RL		205.5	131.0
11	25	94	0	RL		156.4	130.9

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
11	25	94	1	RL		182.9	130.8
11	25	94	2	RL		56.1	130.7
11	25	94	3	RL		76.0	130.7
11	25	94	4	RL		132.3	130.8
11	25	94	5	RL		49.2	130.6
11	25	94	6	NO		73.8	130.3
11	25	94	7	NO		68.0	129.9
11	25	94	8	RL		121.3	129.9
11	25	94	9	RL		167.8	130.1
11	25	94	10	RL		70.1	130.1
11	25	94	11	RL		208.5	130.3
11	25	94	12	RL		266.9	130.4
11	25	94	13	RL		213.3	130.6
11	25	94	14	RL		139.5	130.7
11	25	94	15	NO		91.9	130.7
11	25	94	16	NO		79.3	130.8
11	25	94	17	NO		122.9	130.8
11	25	94	18	RL		127.9	130.8
11	25	94	19	RL		66.5	130.8
11	25	94	20	RL		82.4	130.8
11	25	94	21	RL		77.6	130.8
11	25	94	22	RL		36.3	130.6
11	25	94	23	RL		95.1	130.5
11	26	94	0	RL		198.0	130.6
11	26	94	1	RL		166.2	130.5
11	26	94	2	RL		127.3	130.6
11	26	94	3	RL		52.3	130.4
11	26	94	4	RL		81.6	130.4
11	26	94	5	RL		44.3	130.2
11	26	94	6	NO		105.6	130.0
11	26	94	7	NO		190.2	129.8
11	26	94	8	RL		217.7	129.8
11	26	94	9	NO		98.2	129.8
11	26	94	10	NO		80.4	129.7
11	26	94	11	NO		75.5	129.7
11	26	94	12	NO		83.0	129.6
11	26	94	13	NO		69.0	129.6
11	26	94	14	NO		69.6	129.5
11	26	94	15	NO		74.4	129.3
11	26	94	16	NO		66.7	129.3
11	26	94	17	NO		75.8	129.3
11	26	94	18	NO		60.5	129.2
11	26	94	19	NO		47.6	129.0
11	26	94	20	NO		44.8	128.9
11	26	94	21	NO		99.8	129.0
11	26	94	22	NO		78.4	128.9
11	26	94	23	RL		128.6	128.9
11	27	94	0	RL		35.1	128.7
11	27	94	1	RL		59.9	128.4
11	27	94	2	RL		45.4	128.2
11	27	94	3	RL		52.6	128.0
11	27	94	4	RL		51.5	127.8
11	27	94	5	RL		34.4	127.6
11	27	94	6	NO		94.8	127.5
11	27	94	7	NO		165.5	127.6
11	27	94	8	RL		428.5	127.9
11	27	94	9	NO		104.3	127.7
11	27	94	10	NO		73.4	127.6
11	27	94	11	NO		54.4	127.5
11	27	94	12	NO		49.6	127.3
11	27	94	13	NO		71.5	127.2
11	27	94	14	NO		58.8	127.1
11	27	94	15	NO		74.2	127.1
11	27	94	16	NO		67.5	127.1
11	27	94	17	NO		145.2	127.0
11	27	94	18	NO		57.2	127.0
11	27	94	19	NO		57.5	126.9
11	27	94	20	NO		55.4	126.7
11	27	94	21	NO		56.7	126.6
11	27	94	22	RL		150.5	126.6
11	27	94	23	RL		280.9	126.8
11	28	94	0	RL		361.4	127.1
11	28	94	1	RL		157.4	127.2
11	28	94	2	RL		295.8	127.5
11	28	94	3	RL		190.3	127.5
11	28	94	4	RL		209.3	127.7
11	28	94	5	RL		121.1	127.8
11	28	94	6	MF		281.2	128.1
11	28	94	7	RL		258.8	128.3
11	28	94	8	RL		45.7	128.3
11	28	94	9	RL		89.3	128.3
11	28	94	10	RL		64.9	128.2
11	28	94	11	RL		107.4	128.3

**RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR**

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
11	28	94	12	SS	89.2	128.3
11	28	94	17	RL	296.4	128.6
11	28	94	18	RL	48.4	128.5
11	28	94	19	RL	75.2	128.4
11	28	94	20	NO	103.6	128.5
11	28	94	21	NO	57.1	128.4
11	28	94	22	NO	68.9	128.4
11	28	94	23	RL	93.1	128.4
11	29	94	0	RL	227.7	128.6
11	29	94	1	RL	211.0	128.8
11	29	94	2	RL	234.7	129.0
11	29	94	3	RL	80.9	129.0
11	29	94	4	RL	208.0	129.1
11	29	94	5	RL	162.8	129.2
11	29	94	6	NO	65.9	129.2
11	29	94	7	NO	53.6	128.9
11	29	94	8	NO	104.1	128.6
11	29	94	9	NO	142.4	128.3
11	29	94	10	MF	289.5	128.3
11	29	94	11	RL	277.7	128.5
11	29	94	12	NO	34.1	128.2
11	29	94	13	NO	74.1	128.0
11	29	94	14	NO	59.8	127.9
11	29	94	15	RL	275.5	128.1
11	29	94	16	RL	53.1	128.0
11	29	94	17	NO	44.0	127.9
11	29	94	18	NO	76.0	127.9
11	29	94	19	RL	60.5	127.9
11	29	94	20	NO	38.9	127.9
11	29	94	21	NO	66.3	127.8
11	29	94	22	RL	82.3	127.7
11	29	94	23	RL	90.4	127.7
11	30	94	0	RL	103.7	127.7
11	30	94	1	RL	79.0	127.7
11	30	94	2	RL	65.6	127.6
11	30	94	3	RL	86.5	127.7
11	30	94	4	RL	139.7	127.3
11	30	94	5	RL	87.6	127.0
11	30	94	6	NO	36.4	126.6
11	30	94	7	NO	41.8	126.4
11	30	94	8	NO	179.7	126.4
11	30	94	9	NO	54.8	126.1
11	30	94	10	NO	138.1	126.0
11	30	94	12	NO	84.4	125.9
11	30	94	13	NO	52.9	125.9
11	30	94	14	NO	30.4	125.8
11	30	94	15	NO	29.7	125.8
11	30	94	16	NO	22.5	125.6
11	30	94	17	NO	34.6	125.5
11	30	94	18	NO	39.4	125.4
11	30	94	19	NO	36.9	125.4
11	30	94	20	NO	46.5	125.4
11	30	94	21	NO	51.2	125.2
11	30	94	22	NO	56.1	125.1
11	30	94	23	RL	99.0	125.1
12	1	94	0	RL	69.0	124.9
12	1	94	1	RL	63.7	124.8
12	1	94	2	RL	71.8	124.7
12	1	94	3	RL	69.1	124.7
12	1	94	4	RL	45.3	124.6
12	1	94	5	NO	43.6	124.5
12	1	94	6	NO	52.0	124.4
12	1	94	8	RL	60.7	124.3
12	1	94	9	RL	60.8	124.3
12	1	94	10	NO	68.7	124.2
12	1	94	11	NO	127.9	124.2
12	1	94	12	NO	85.8	124.0
12	1	94	13	RL/PF	264.8	124.1
12	1	94	14	RL	49.5	124.0
12	1	94	15	RL	65.6	123.9
12	1	94	16	RL	64.2	123.9
12	1	94	17	NO	51.3	123.9
12	1	94	18	NO	48.2	123.9
12	1	94	19	NO	44.2	123.8
12	1	94	20	NO	43.1	123.8
12	1	94	21	NO	59.3	123.8
12	1	94	22	RL	62.4	123.8
12	1	94	23	RL	37.1	123.6
12	2	94	0	RL	35.0	123.4
12	2	94	1	RL	60.0	123.3
12	2	94	2	RL	125.5	123.2
12	2	94	3	RL	378.7	123.5
12	2	94	4	RL	412.3	123.6

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
			1hr	720rolling	1hr	720rolling
12	2	94	5	RL	222.3	123.3
12	2	94	6	NO	39.9	123.3
12	2	94	7	RL	364.3	123.7
12	2	94	8	RL/PF	159.2	123.9
12	2	94	9	RL/PF	99.8	124.1
12	2	94	10	RL/PF	102.8	123.9
12	2	94	11	RL/PF	61.8	123.2
12	2	94	12	RL	31.0	122.9
12	2	94	13	NO	28.8	122.9
12	2	94	14	NO	45.6	122.8
12	2	94	15	RL	64.4	122.8
12	2	94	16	NO	79.7	122.8
12	2	94	17	NO	47.9	122.8
12	2	94	18	NO	52.5	122.8
12	2	94	19	NO	82.0	122.8
12	2	94	20	RL	301.9	123.0
12	2	94	21	NO	100.5	123.1
12	2	94	22	NO	108.7	123.2
12	2	94	23	RL	137.6	123.4
12	3	94	0	RL	65.1	123.5
12	3	94	1	RL	113.5	123.6
12	3	94	2	RL	71.5	123.7
12	3	94	3	RL	86.7	123.7
12	3	94	4	RL	60.9	123.7
12	3	94	5	NO	43.9	123.6
12	3	94	6	RL	137.7	123.7
12	3	94	7	RL	100.5	123.4
12	3	94	8	RL/PF	195.5	123.6
12	3	94	9	RL/PF	198.1	123.6
12	3	94	10	RL	63.6	123.3
12	3	94	11	NO	44.3	123.2
12	3	94	12	RL	124.0	123.1
12	3	94	13	RL/PF	170.4	123.3
12	3	94	14	RL/PF	36.0	123.1
12	3	94	15	RL/PF	13.8	123.0
12	3	94	16	SS	1.4	122.8
12	3	94	21	SS	424.6	123.3
12	3	94	22	RL/PF	265.0	123.6
12	3	94	23	RL/PF	94.2	123.5
12	4	94	0	RL	125.3	123.7
12	4	94	1	RL	172.2	123.9
12	4	94	2	RL	160.4	124.1
12	4	94	3	RL	59.5	123.9
12	4	94	4	NO	48.2	123.8
12	4	94	5	NO	71.4	123.8
12	4	94	6	NO	41.6	123.8
12	4	94	7	NO	36.2	123.7
12	4	94	8	NO	35.2	123.6
12	4	94	9	NO	29.4	123.4
12	4	94	10	NO	36.3	123.1
12	4	94	11	NO	30.4	122.9
12	4	94	12	NO	31.2	122.6
12	4	94	13	NO	30.2	122.4
12	4	94	14	NO	35.8	122.3
12	4	94	15	NO	34.5	122.3
12	4	94	16	NO	32.7	122.2
12	4	94	17	RL	37.2	122.1
12	4	94	18	RL	57.2	121.9
12	4	94	19	RL	49.2	121.7
12	4	94	20	RL	105.6	121.5
12	4	94	21	RL	563.2	122.2
12	4	94	22	RL	160.9	122.0
12	4	94	23	RL	26.5	121.7
12	5	94	0	RL	31.8	121.7
12	5	94	1	RL	41.5	121.7
12	5	94	2	RL	51.1	121.7
12	5	94	3	RL	60.2	121.6
12	5	94	4	NO	105.3	121.7
12	5	94	5	NO	47.8	121.7
12	5	94	6	NO	50.9	121.7
12	5	94	7	NO	35.9	121.7
12	5	94	8	NO	41.7	121.6
12	5	94	9	NO	34.7	121.6
12	5	94	10	NO	33.3	121.5
12	5	94	11	NO	34.9	121.5
12	5	94	12	NO	38.8	121.5
12	5	94	13	NO	57.7	121.3
12	5	94	14	NO	35.0	121.2
12	5	94	15	NO	47.5	121.2
12	5	94	16	NO	37.3	121.1
12	5	94	17	NO	50.0	121.1
12	5	94	18	NO	66.1	121.1
12	5	94	19	NO	86.6	121.1

**RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR**

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
12	5	94	20	NO		56.0	121.1
12	5	94	21	NO		50.8	121.1
12	5	94	22	RL		112.6	121.2
12	5	94	23	RL		163.5	121.3
12	6	94	0	RL		105.0	121.4
12	6	94	1	RL		121.6	121.5
12	6	94	2	RL		62.6	121.5
12	6	94	3	RL		99.4	121.6
12	6	94	4	NO		56.5	121.6
12	6	94	5	NO		84.2	121.6
12	6	94	6	NO		150.3	121.7
12	6	94	7	NO		45.6	121.6
12	6	94	8	NO		42.7	121.5
12	6	94	9	NO		37.2	121.5
12	6	94	10	NO		37.0	121.5
12	6	94	11	MF		146.3	121.7
12	6	94	12	RL		387.8	122.1
12	6	94	13	RL		115.3	122.2
12	6	94	14	NO		30.9	122.1
12	6	94	15	NO		70.1	122.0
12	6	94	16	RL		63.0	121.8
12	6	94	17	NO		232.3	121.7
12	6	94	18	NO		26.1	121.5
12	6	94	19	NO		35.7	121.3
12	6	94	20	NO		47.8	121.2
12	6	94	21	NO		82.7	121.1
12	6	94	22	MF		112.9	121.0
12	6	94	23	RL		135.5	120.9
12	7	94	0	RL		52.9	120.5
12	7	94	1	RL		40.5	120.2
12	7	94	2	RL		32.6	119.7
12	7	94	3	RL		62.2	119.6
12	7	94	4	RL		40.4	119.4
12	7	94	5	NO		221.1	119.6
12	7	94	6	MF		118.9	119.6
12	7	94	7	NO		204.4	119.6
12	7	94	8	NO		75.8	119.6
12	7	94	11	RL		100.9	119.6
12	7	94	12	RL		340.1	120.0
12	7	94	13	RL		490.4	120.6
12	7	94	14	MF		147.7	120.8
12	7	94	15	MF		270.9	121.0
12	7	94	16	SS		323.5	121.3
12	7	94	17	RL		318.1	121.6
12	7	94	18	NO		313.4	121.9
12	7	94	19	NO		44.5	121.5
12	7	94	20	NO		29.4	121.3
12	7	94	21	NO		30.1	121.2
12	7	94	22	RL		254.6	121.4
12	7	94	23	RL		176.0	121.4
12	8	94	0	RL		68.3	121.4
12	8	94	1	RL		124.1	121.3
12	8	94	2	RL		189.9	121.4
12	8	94	3	RL		173.9	121.5
12	8	94	4	RL		225.8	121.6
12	8	94	5	NO		42.3	121.4
12	8	94	6	NO		29.4	121.2
12	8	94	7	NO		33.7	121.2
12	8	94	8	NO		46.4	121.0
12	8	94	9	RL		110.7	121.1
12	8	94	10	RL		469.5	121.7
12	8	94	11	RL		459.5	122.2
12	8	94	12	RL		141.4	122.3
12	8	94	13	RL		194.5	122.5
12	8	94	14	RL		78.9	122.4
12	8	94	15	RL		77.2	122.3
12	8	94	16	RL		126.3	122.3
12	8	94	17	RL		59.2	122.2
12	8	94	18	NO		65.6	122.2
12	8	94	19	NO		165.3	122.3
12	8	94	20	NO		40.2	122.2
12	8	94	21	NO		34.8	122.1
12	8	94	22	RL/PF		76.5	122.1
12	8	94	23	RL		56.1	122.1
12	9	94	0	RL		145.0	122.1
12	9	94	1	RL		303.7	122.4
12	9	94	2	RL		207.9	122.6
12	9	94	3	RL		223.0	122.8
12	9	94	4	RL		187.0	122.7
12	9	94	5	NO		43.7	122.5
12	9	94	6	RL		49.5	122.4
12	9	94	7	NO		25.4	122.3
12	9	94	8	RL		29.5	122.3

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
12 9 94	9	RL			33.9	122.3
12 9 94	10	RL			27.7	122.3
12 9 94	11	NO			134.7	122.3
12 9 94	12	RL			18.6	122.1
12 9 94	13	RL			26.0	121.9
12 9 94	14	RL			32.6	121.9
12 9 94	15	RL			96.5	121.8
12 9 94	16	RL			52.5	121.4
12 9 94	17	RL			46.4	121.4
12 9 94	18	RL			56.8	121.1
12 9 94	19	RL			24.0	120.7
12 9 94	20	RL			28.0	120.4
12 9 94	21	RL			31.0	120.2
12 9 94	22	RL			50.0	119.9
12 9 94	23	RL			183.4	119.8
12 10 94	0	RL			219.2	119.7
12 10 94	1	RL			140.3	119.6
12 10 94	2	RL			160.3	119.6
12 10 94	3	RL			247.1	119.5
12 10 94	4	RL			154.2	119.4
12 10 94	5	RL			166.0	119.5
12 10 94	6	RL			35.7	119.4
12 10 94	7	RL			30.7	119.3
12 10 94	8	RL			201.4	119.5
12 10 94	9	RL			93.6	119.5
12 10 94	10	NO			37.3	119.4
12 10 94	11	NO			37.9	119.3
12 10 94	12	NO			34.9	119.3
12 10 94	13	RL			41.7	119.0
12 10 94	14	RL			30.2	118.5
12 10 94	15	RL			31.8	117.9
12 10 94	16	RL			32.6	117.8
12 10 94	17	NO			33.4	117.8
12 10 94	18	MF			58.0	117.8
12 10 94	19	RL			347.3	118.3
12 10 94	20	RL			156.8	118.5
12 10 94	21	RL			15.5	118.5
12 10 94	22	RL			26.6	118.6
12 10 94	23	RL			123.0	118.7
12 11 94	0	RL/PF			138.5	118.9
12 11 94	1	RL/PF			82.0	118.9
12 11 94	2	RL/PF			122.0	118.7
12 11 94	3	RL/PF			185.4	118.5
12 11 94	4	RL/PF			120.8	118.5
12 11 94	5	RL/PF			62.5	118.5
12 11 94	6	NO			21.7	118.4
12 11 94	7	NO			24.8	118.3
12 11 94	8	RL			44.7	118.3
12 11 94	9	RL			58.4	118.3
12 11 94	10	RL			45.0	118.2
12 11 94	11	RL			61.2	118.3
12 11 94	12	RL			42.5	118.3
12 11 94	13	RL			123.5	118.4
12 11 94	14	RL			286.4	118.5
12 11 94	15	RL			86.7	118.4
12 11 94	16	RL			42.9	118.2
12 11 94	17	RL			30.1	118.2
12 11 94	18	RL			38.9	118.1
12 11 94	19	RL			54.8	118.1
12 11 94	20	RL			26.0	117.8
12 11 94	21	RL			22.4	117.7
12 11 94	22	RL			35.4	117.6
12 11 94	23	RL			47.7	117.6
12 12 94	0	RL			88.3	117.6
12 12 94	1	RL			95.8	117.6
12 12 94	2	RL			257.2	117.8
12 12 94	3	RL			247.3	118.1
12 12 94	4	RL			198.9	118.2
12 12 94	5	RL			133.1	118.3
12 12 94	6	RL			32.3	118.3
12 12 94	7	RL			28.1	118.1
12 12 94	8	RL			28.4	117.9
12 12 94	9	RL			40.4	117.7
12 12 94	10	RL			31.7	117.4
12 12 94	11	RL			34.8	117.3
12 12 94	12	RL			43.2	117.2
12 12 94	13	RL			33.2	117.1
12 12 94	14	RL			34.4	117.1
12 12 94	15	RL			85.9	117.0
12 12 94	16	RL			53.2	116.9
12 12 94	17	RL			56.4	116.9
12 12 94	18	RL			79.3	116.8
12 12 94	19	RL			315.0	117.1

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging	Interval			1hr	720rolling	1hr	720rolling
12	12	94	20	RL		81.9	117.1
12	12	94	21	RL		76.0	117.1
12	12	94	22	RL		60.3	117.2
12	12	94	23	RL		80.5	117.2
12	13	94	0	RL		88.2	117.2
12	13	94	1	RL		85.5	117.0
12	13	94	2	RL		71.9	116.9
12	13	94	3	RL		53.3	116.8
12	13	94	4	RL		67.0	116.7
12	13	94	5	RL		53.0	116.6
12	13	94	6	NO		21.0	116.5
12	13	94	7	RL		30.1	116.4
12	13	94	8	RL		36.7	116.1
12	13	94	9	RL		45.5	116.0
12	13	94	10	RL		65.6	116.0
12	13	94	11	RL		54.3	115.9
12	13	94	12	RL		45.1	115.7
12	13	94	13	NO		42.8	115.6
12	13	94	14	NO		41.8	115.6
12	13	94	15	NO		35.6	115.5
12	13	94	16	NO		34.9	115.3
12	13	94	17	NO		48.7	115.2
12	13	94	18	NO		43.9	115.3
12	13	94	19	NO		33.6	115.3
12	13	94	20	NO		31.6	115.4
12	13	94	21	NO		26.8	115.3
12	13	94	22	RL		36.4	115.3
12	13	94	23	RL		109.9	115.2
12	14	94	0	RL		128.4	115.2
12	14	94	1	RL		205.0	115.3
12	14	94	2	RL		203.7	115.5
12	14	94	3	RL		159.4	115.7
12	14	94	4	RL		155.3	115.8
12	14	94	5	RL		67.5	115.8
12	14	94	6	NO		44.3	115.7
12	14	94	7	NO		29.4	115.6
12	14	94	8	NO		30.1	115.2
12	14	94	9	NO		44.2	115.0
12	14	94	10	RL		213.9	115.0
12	14	94	11	RL		433.8	115.4
12	14	94	12	RL		141.6	115.4
12	14	94	13	RL		48.7	115.0
12	14	94	14	RL		42.0	114.8
12	14	94	15	RL		45.8	114.6
12	14	94	16	RL		52.5	114.4
12	14	94	17	RL		175.9	114.4
12	14	94	18	RL		190.4	114.3
12	14	94	19	RL		131.6	114.3
12	14	94	20	RL		116.6	114.4
12	14	94	21	RL		306.2	114.7
12	14	94	22	RL		53.1	114.7
12	14	94	23	RL		130.7	114.7
12	15	94	0	RL		106.9	114.4
12	15	94	1	RL		292.4	114.6
12	15	94	2	RL		208.6	114.6
12	15	94	3	RL		101.4	114.3
12	15	94	4	RL		117.4	114.2
12	15	94	5	RL		24.2	114.1
12	15	94	6	NO		49.0	114.1
12	15	94	7	RL		31.9	114.0
12	15	94	8	RL		58.7	113.9
12	15	94	9	NO		58.0	113.9
12	15	94	10	RL		102.4	114.0
12	15	94	11	RL		77.5	113.9
12	15	94	12	RL		129.9	113.7
12	15	94	13	RL		306.5	113.6
12	15	94	14	RL		391.4	114.1
12	15	94	15	RL		238.6	114.4
12	15	94	16	RL		448.9	114.8
12	15	94	17	RL		452.8	115.4
12	15	94	18	RL		502.5	115.8
12	15	94	19	RL		242.0	115.8
12	15	94	20	MF		375.6	116.0
12	15	94	21	RL		78.1	116.0
12	15	94	22	RL		358.0	116.3
12	15	94	23	RL		411.6	116.5
12	16	94	0	RL		107.8	116.4
12	16	94	1	RL		45.3	116.2
12	16	94	2	RL		51.8	116.0
12	16	94	3	RL		101.4	116.1
12	16	94	4	RL		39.1	116.0
12	16	94	5	RL		145.4	116.1
12	16	94	6	RL		56.1	116.0

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Averaging	Date	Time	Operating Codes	#/hr	#/hr	CO	CO
Interval				1hr	720rolling	1hr	720rolling
12	16	94	7	RL		457.8	116.4
12	16	94	8	RL		508.6	116.5
12	16	94	9	RL		469.6	116.6
12	16	94	10	RL		420.9	116.6
12	16	94	11	RL		443.3	116.6
12	16	94	12	RL		364.9	116.5
12	16	94	13	RL		335.4	116.4
12	16	94	14	RL		29.2	116.2
12	16	94	15	RL		188.5	116.4
12	16	94	16	RL		408.3	116.9
12	16	94	17	RL		496.0	117.2
12	16	94	18	RL		510.6	117.6
12	16	94	19	RL/PF		602.2	118.1
12	16	94	20	RL/PF		222.1	118.0
12	16	94	21	RL/PF		82.9	118.1
12	16	94	22	NO/PF		15.4	118.0
12	16	94	23	NO/PF		26.9	117.9
12	17	94	0	RL		232.7	118.2
12	17	94	1	RL		383.1	118.7
12	17	94	2	RL		421.7	118.8
12	17	94	3	RL		316.7	118.6
12	17	94	4	RL		78.7	118.5
12	17	94	5	RL		107.7	118.4
12	17	94	6	RL		58.5	118.2
12	17	94	7	RL		37.2	118.2
12	17	94	8	RL		80.4	118.2
12	17	94	9	RL		122.0	118.2
12	17	94	10	RL		95.5	118.3
12	17	94	11	RL		120.3	118.3
12	17	94	12	RL		197.5	118.4
12	17	94	13	RL		337.9	118.8
12	17	94	14	RL		225.3	119.0
12	17	94	15	RL		250.3	119.1
12	17	94	16	RL		293.9	119.4
12	17	94	17	RL		188.4	119.4
12	17	94	18	RL		114.3	119.4
12	17	94	19	RL		24.9	119.2
12	17	94	20	RL		23.5	119.0
12	17	94	21	RL		23.1	118.9
12	17	94	22	RL		24.9	118.8
12	17	94	23	RL		179.0	118.9
12	18	94	0	RL		317.9	119.3
12	18	94	1	RL		194.7	119.5
12	18	94	2	RL		374.5	119.9
12	18	94	3	RL		318.3	120.3
12	18	94	4	RL		465.5	120.9
12	18	94	5	RL		421.0	121.4
12	18	94	6	RL		178.8	121.5
12	18	94	7	RL		156.0	121.7
12	18	94	8	RL		117.3	121.7
12	18	94	9	RL		405.6	122.2
12	18	94	10	RL		346.5	122.6
12	18	94	11	RL		125.7	122.6
12	18	94	12	RL		65.6	122.3
12	18	94	13	RL		66.0	122.1
12	18	94	14	RL		66.5	122.0
12	18	94	15	RL		63.2	121.8
12	18	94	16	RL		89.3	121.7
12	18	94	17	RL		84.6	121.7
12	18	94	18	RL		63.2	121.6
12	18	94	19	RL		216.2	121.7
12	18	94	20	RL		393.2	122.2
12	18	94	21	RL		197.8	122.3
12	18	94	22	RL		53.4	122.3
12	18	94	23	SS		156.4	122.5
12	19	94	22	SS		2.0	122.1
12	19	94	23	RL/PF		16.2	121.8
12	20	94	0	RL/PF		14.2	121.7
12	20	94	1	RL		14.3	121.6
12	20	94	2	RL		45.3	121.6
12	20	94	3	RL		202.1	121.7
12	20	94	4	RL		64.9	121.6
12	20	94	5	NO		114.0	121.7
12	20	94	6	NO		42.1	121.6
12	20	94	7	NO		59.7	121.6
12	20	94	8	NO		53.2	121.6
12	20	94	9	NO		107.9	121.4
12	20	94	10	NO		67.7	121.2
12	20	94	11	NO		81.7	121.0
12	20	94	12	NO		75.0	120.9
12	20	94	13	NO		45.8	120.9
12	20	94	14	NO		123.1	120.7
12	20	94	15	NO		63.5	120.6

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
12 20 94	16	MF			141.9	120.5
12 20 94	17	RL			191.0	119.9
12 20 94	18	RL			181.7	119.7
12 20 94	19	NO			194.1	119.9
12 20 94	20	NO			53.6	119.5
12 20 94	21	RL			233.2	119.4
12 20 94	22	RL			183.8	119.0
12 20 94	23	RL			298.1	119.4
12 21 94	0	RL			291.8	119.6
12 21 94	1	RL			348.1	119.9
12 21 94	2	RL			261.5	120.2
12 21 94	3	RL			32.5	120.0
12 21 94	4	RL			94.9	120.0
12 21 94	5	NO			222.2	120.2
12 21 94	6	MF			390.6	120.6
12 21 94	7	RL/PF			68.0	120.6
12 21 94	8	RL/PF			175.7	120.7
12 21 94	9	NO			186.0	120.9
12 21 94	10	NO			149.1	120.9
12 21 94	11	NO			182.8	120.8
12 21 94	12	NO			157.1	120.9
12 21 94	15	NO			160.2	121.0
12 21 94	16	NO			72.2	120.7
12 21 94	17	NO			74.9	120.7
12 21 94	18	NO			67.3	120.7
12 21 94	19	NO			86.0	120.7
12 21 94	20	NO			66.9	120.5
12 21 94	21	NO			80.1	120.5
12 21 94	22	RL			106.6	120.3
12 21 94	23	RL			116.3	120.2
12 22 94	0	RL			47.6	120.1
12 22 94	1	SS			387.4	120.5
12 22 94	10	SS			1.2	120.4
12 22 94	11	RL/PF			66.9	120.1
12 22 94	12	NO			253.4	120.4
12 22 94	13	NO			84.4	120.3
12 22 94	14	NO			159.6	120.3
12 22 94	15	NO			264.3	120.5
12 22 94	16	NO			122.8	120.6
12 22 94	17	NO			380.5	121.0
12 22 94	18	NO			310.2	121.4
12 22 94	19	NO			570.2	122.0
12 22 94	20	MF			280.5	122.3
12 22 94	21	RL			344.9	122.7
12 22 94	22	RL			125.3	122.7
12 22 94	23	RL			166.7	122.7
12 23 94	0	RL			106.2	122.7
12 23 94	1	RL			54.7	122.6
12 23 94	2	RL			46.4	122.6
12 23 94	3	RL			93.0	122.6
12 23 94	4	RL			116.7	122.7
12 23 94	5	RL/PF			231.2	122.9
12 23 94	6	RL/PF			69.4	123.0
12 23 94	7	NO			139.8	123.1
12 23 94	8	NO			59.9	123.1
12 23 94	9	RL			109.5	123.1
12 23 94	10	RL			244.4	123.4
12 23 94	11	NO			194.2	123.4
12 23 94	12	NO			51.3	122.8
12 23 94	13	NO			77.2	122.8
12 23 94	14	NO			81.3	122.8
12 23 94	15	RL			71.3	122.8
12 23 94	16	NO			145.2	122.8
12 23 94	17	RL			155.6	123.0
12 23 94	18	NO			110.7	122.9
12 23 94	19	RL			219.1	123.1
12 23 94	20	NO			230.9	123.3
12 23 94	21	NO			58.5	123.3
12 23 94	22	RL			193.1	123.3
12 23 94	23	RL			91.1	123.3
12 24 94	0	RL			115.5	123.2
12 24 94	1	RL			67.1	123.2
12 24 94	2	RL			82.8	123.2
12 24 94	3	RL			174.0	123.4
12 24 94	4	RL			97.5	123.4
12 24 94	5	RL			260.8	123.5
12 24 94	6	NO			86.3	123.5
12 24 94	7	NO			53.4	123.5
12 24 94	8	NO			51.3	123.2
12 24 94	9	NO			64.3	123.1
12 24 94	10	NO			80.6	123.0
12 24 94	11	NO			466.9	123.6
12 24 94	12	NO			359.1	124.0

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO	CO
Averaging	Interval			1hr	720rolling	1hr	720rolling
12	24	94	13	NO		179.6	124.1
12	24	94	14	NO		142.9	124.1
12	24	94	15	NO		166.9	124.2
12	24	94	16	NO		159.3	124.3
12	24	94	17	NO		62.3	124.3
12	24	94	18	NO		236.6	124.4
12	24	94	19	NO		467.8	124.7
12	24	94	20	NO		246.1	124.8
12	24	94	21	NO		395.8	125.2
12	24	94	22	RL		80.5	125.2
12	24	94	23	RL		51.3	125.1
12	25	94	0	RL		88.6	125.2
12	25	94	1	RL		167.7	125.4
12	25	94	2	RL		516.0	126.1
12	25	94	3	RL/PF		473.0	126.6
12	25	94	4	RL		315.8	127.0
12	25	94	5	NO		86.2	127.1
12	25	94	6	RL		76.8	127.1
12	25	94	7	RL		110.4	127.2
12	25	94	8	RL		47.1	127.2
12	25	94	9	RL		43.6	126.8
12	25	94	10	RL		55.8	126.5
12	25	94	11	RL		62.3	126.4
12	25	94	12	RL		318.2	126.7
12	25	94	13	RL		75.8	126.8
12	25	94	14	RL		113.6	126.6
12	25	94	15	RL		48.8	126.7
12	25	94	16	RL		102.9	126.8
12	25	94	17	NO		176.2	126.9
12	25	94	18	RL		179.0	126.9
12	25	94	19	NO		148.0	126.7
12	25	94	20	RL		241.4	126.6
12	25	94	21	RL		376.5	126.7
12	25	94	22	RL		374.3	126.9
12	25	94	23	RL		302.7	126.9
12	26	94	0	RL		229.2	127.0
12	26	94	1	RL		137.9	127.2
12	26	94	2	RL		131.7	127.3
12	26	94	3	RL		243.0	127.5
12	26	94	4	RL		88.1	127.5
12	26	94	5	NO		332.7	127.9
12	26	94	6	NO		122.4	127.8
12	26	94	7	NO		136.2	127.9
12	26	94	8	NO		89.2	127.6
12	26	94	9	NO		73.6	127.4
12	26	94	10	NO		100.2	127.4
12	26	94	11	RL/PF		249.7	127.5
12	26	94	12	NO		242.0	127.7
12	26	94	13	NO		140.1	127.8
12	26	94	14	NO		70.7	127.6
12	26	94	15	NO		80.8	127.4
12	26	94	16	NO		85.1	127.5
12	26	94	17	NO		111.4	127.5
12	26	94	18	NO		78.7	127.5
12	26	94	19	NO		69.2	127.3
12	26	94	20	NO		126.6	127.3
12	26	94	21	RL		303.3	127.5
12	26	94	22	RL		114.6	127.5
12	26	94	23	RL		215.3	127.7
12	27	94	0	RL		109.4	127.7
12	27	94	1	RL		185.4	127.9
12	27	94	2	RL		250.2	128.1
12	27	94	3	RL		325.9	128.5
12	27	94	4	RL		140.9	128.5
12	27	94	5	RL		48.1	128.4
12	27	94	6	RL		50.7	128.3
12	27	94	7	RL		510.0	128.8
12	27	94	8	RL/PF		365.1	128.9
12	27	94	9	RL/PF		80.4	128.7
12	27	94	10	RL/PF		98.4	128.6
12	27	94	11	NO		45.8	128.6
12	27	94	12	NO		57.2	128.6
12	27	94	13	NO		63.5	128.5
12	27	94	14	NO		51.1	128.4
12	27	94	15	NO		56.0	128.4
12	27	94	16	NO		196.2	128.5
12	27	94	17	NO		375.2	128.9
12	27	94	18	NO		188.4	129.1
12	27	94	19	NO		50.0	129.1
12	27	94	20	NO		120.8	129.0
12	27	94	21	NO		218.6	129.0
12	27	94	22	RL		114.9	129.0
12	27	94	23	RL		199.4	129.2

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
12 28 94	0	RL			141.2	129.3
12 28 94	1	RL			46.5	129.3
12 28 94	2	RL			45.5	129.2
12 28 94	3	RL			28.2	129.0
12 28 94	4	RL			52.6	128.8
12 28 94	5	RL			56.9	128.7
12 28 94	6	NO			393.1	129.1
12 28 94	7	NO			84.2	129.2
12 28 94	8	NO			75.5	129.1
12 28 94	9	NO			84.5	129.2
12 28 94	10	NO			275.1	129.5
12 28 94	11	RL			468.7	130.0
12 28 94	12	RL			175.6	130.2
12 28 94	13	RL			248.7	130.4
12 28 94	14	RL			234.8	130.6
12 28 94	15	RL			536.6	131.3
12 28 94	16	RL			554.9	132.0
12 28 94	17	RL			354.5	132.4
12 28 94	18	RL			326.2	132.7
12 28 94	19	RL			339.2	133.0
12 28 94	20	RL			248.9	133.3
12 28 94	21	NO			259.4	133.6
12 28 94	22	NO			67.5	133.6
12 28 94	23	RL			77.4	133.7
12 29 94	0	RL			324.4	134.0
12 29 94	1	RL			345.4	134.5
12 29 94	2	RL			111.3	134.5
12 29 94	3	RL			413.0	134.8
12 29 94	4	RL			258.1	134.6
12 29 94	5	RL			159.9	134.7
12 29 94	6	RL			117.6	134.7
12 29 94	7	SS			124.9	134.8
12 29 94	16	SS			1.4	134.8
12 29 94	17	RL/PF			120.1	134.8
12 29 94	18	RL			179.7	135.0
12 29 94	19	NO			62.3	135.0
12 29 94	20	RL			62.0	135.0
12 29 94	21	RL			64.3	134.9
12 29 94	22	RL			90.8	134.9
12 29 94	23	RL			51.5	134.9
12 30 94	0	RL			67.8	134.9
12 30 94	1	RL			150.4	135.1
12 30 94	2	RL			294.5	135.3
12 30 94	3	RL			226.4	135.2
12 30 94	4	RL			302.0	135.1
12 30 94	5	RL			86.8	135.0
12 30 94	6	NO			69.2	134.7
12 30 94	7	NO			202.6	134.7
12 30 94	8	NO			338.8	134.9
12 30 94	9	NO			161.5	134.9
12 30 94	10	NO			94.6	134.7
12 30 94	11	NO			78.4	134.4
12 30 94	12	SS			80.9	134.5
12 30 94	18	SS			40.5	134.4
12 30 94	20	RL			408.9	134.9
12 30 94	21	RL			210.4	135.0
12 30 94	22	RL			156.2	135.1
12 30 94	23	MF			200.4	135.0
12 31 94	0	RL			442.8	135.5
12 31 94	1	RL			546.8	136.2
12 31 94	2	SS			478.3	136.7
12 31 94	14	MF			3.4	136.6
12 31 94	15	RL/PF			56.1	136.6
12 31 94	16	NO/PF			94.4	136.6
12 31 94	17	MF			526.4	137.0
12 31 94	18	RL/PF			198.7	137.0
12 31 94	19	RL/PF			110.5	136.8
12 31 94	20	NO/PF			78.6	136.8
12 31 94	21	NO/PF			62.4	136.6
12 31 94	22	RL			131.9	136.6
12 31 94	23	RL			284.3	136.9
1 1 95	0	RL			448.1	137.4
1 1 95	1	RL			445.0	137.9
1 1 95	2	RL			477.1	138.4
1 1 95	3	RL			471.1	138.6
1 1 95	4	RL			261.9	138.6
1 1 95	5	RL			125.7	138.7
1 1 95	6	RL			137.7	138.8
1 1 95	7	RL			109.5	138.9
1 1 95	8	NO			180.8	138.8
1 1 95	9	NO			197.3	139.0
1 1 95	10	NO			139.6	139.1
1 1 95	11	NO			423.0	139.6

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
1	1	95	12	NO	107.4	139.6
1	1	95	13	NO	96.5	139.7
1	1	95	14	NO	118.6	139.8
1	1	95	15	NO	60.0	139.8
1	1	95	16	NO	51.7	139.7
1	1	95	17	NO	78.6	139.7
1	1	95	18	NO	90.5	139.7
1	1	95	19	NO	84.5	139.7
1	1	95	20	NO	114.0	139.8
1	1	95	21	NO	116.9	139.7
1	1	95	22	NO	223.0	139.9
1	1	95	23	RL	377.2	140.4
1	2	95	0	RL	476.1	141.0
1	2	95	1	RL	460.7	141.4
1	2	95	2	RL	456.4	141.9
1	2	95	3	RL	453.2	142.4
1	2	95	4	RL	454.4	142.9
1	2	95	5	RL	451.8	143.4
1	2	95	6	RL	461.1	144.0
1	2	95	7	RL	262.4	144.4
1	2	95	8	NO	312.8	144.8
1	2	95	9	MF	278.3	145.1
1	2	95	10	RL	235.2	145.4
1	2	95	11	NO	266.6	145.7
1	2	95	12	NO	72.8	145.7
1	2	95	13	NO	61.5	145.8
1	2	95	14	NO	110.7	145.8
1	2	95	15	NO	82.0	145.8
1	2	95	16	NO	62.4	145.8
1	2	95	17	NO	49.9	145.8
1	2	95	18	NO	68.7	145.8
1	2	95	19	NO	52.9	145.7
1	2	95	20	NO	231.0	146.0
1	2	95	21	NO	136.2	146.1
1	2	95	22	NO	133.2	146.2
1	2	95	23	RL	242.7	146.5
1	3	95	0	RL	473.6	147.1
1	3	95	1	RL	464.1	147.6
1	3	95	2	RL	465.0	148.1
1	3	95	3	RL	465.3	148.6
1	3	95	4	RL	425.6	148.8
1	3	95	5	NO	247.7	149.1
1	3	95	6	NO	122.2	149.2
1	3	95	7	NO	107.8	149.3
1	3	95	8	NO	57.4	149.3
1	3	95	9	NO	80.2	149.3
1	3	95	10	NO	99.1	149.4
1	3	95	11	NO	41.6	149.4
1	3	95	12	NO	74.9	149.4
1	3	95	13	RL	87.5	149.4
1	3	95	14	NO	172.3	149.6
1	3	95	15	RL	112.8	149.7
1	3	95	16	NO	193.6	149.9
1	3	95	17	NO	189.1	150.0
1	3	95	18	NO	78.9	149.6
1	3	95	19	NO	52.1	149.1
1	3	95	20	NO	213.6	149.1
1	3	95	21	NO	210.9	149.3
1	3	95	22	NO	202.4	149.1
1	3	95	23	RL	258.8	149.2
1	4	95	0	NO	312.8	149.5
1	4	95	1	NO	383.9	149.9
1	4	95	2	NO	355.3	150.3
1	4	95	3	RL/PF	367.3	150.8
1	4	95	4	RL/PF	223.0	151.1
1	4	95	5	NO	82.2	151.1
1	4	95	6	NO	185.2	151.3
1	4	95	7	NO	102.4	151.3
1	4	95	8	NO	145.8	151.4
1	4	95	9	NO	109.0	151.5
1	4	95	10	NO	106.4	151.6
1	4	95	11	NO	308.9	151.6
1	4	95	12	NO	109.9	151.6
1	4	95	13	NO	75.2	151.5
1	4	95	14	NO	116.1	151.5
1	4	95	15	NO	63.0	151.5
1	4	95	16	NO	72.6	151.4
1	4	95	17	RL	71.1	151.4
1	4	95	18	RL	63.0	151.4
1	4	95	19	RL	72.5	151.4
1	4	95	20	NO	75.3	151.5
1	4	95	21	NO	120.4	151.5
1	4	95	22	NO	189.4	151.6

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
1	4	95	23	RL		266.8	151.7
1	5	95	0	RL		486.7	152.1
1	5	95	1	RL		491.9	152.7
1	5	95	2	RL		489.9	153.3
1	5	95	3	RL		482.2	153.8
1	5	95	4	NO		268.1	153.9
1	5	95	5	NO		182.0	154.1
1	5	95	6	NO		273.4	154.5
1	5	95	7	RL		300.6	154.9
1	5	95	8	NO		52.1	154.4
1	5	95	9	NO		81.5	154.1
1	5	95	10	NO		61.2	154.1
1	5	95	11	RL		263.5	154.3
1	5	95	12	NO		63.7	154.1
1	5	95	13	NO		44.0	154.0
1	5	95	14	NO		91.0	154.0
1	5	95	15	NO		72.0	154.0
1	5	95	16	NO		123.0	154.1
1	5	95	17	NO		167.6	154.3
1	5	95	18	NO		161.6	154.5
1	5	95	19	NO		101.7	154.6
1	5	95	20	NO		78.4	154.6
1	5	95	21	NO		137.0	154.8
1	5	95	22	RL		287.3	155.1
1	5	95	23	RL		443.6	155.7
1	6	95	0	MF		299.5	156.1
1	6	95	4	SS		2.6	156.0
1	6	95	5	RL/PF		279.4	156.4
1	6	95	6	RL/PF		330.4	156.8
1	6	95	7	NO		237.6	157.0
1	6	95	8	NO		147.3	157.2
1	6	95	9	MF		127.6	157.3
1	6	95	10	RL/PF		181.6	157.4
1	6	95	11	RL/PF		39.6	156.7
1	6	95	12	RL/PF		88.2	156.6
1	6	95	13	RL/PF		429.2	157.1
1	6	95	14	RL		479.4	157.7
1	6	95	15	RL		432.5	158.3
1	6	95	16	RL		382.2	158.7
1	6	95	17	RL		428.1	159.3
1	6	95	18	RL		465.8	159.8
1	6	95	19	RL		502.5	160.4
1	6	95	20	RL		357.4	160.8
1	6	95	21	NO		117.5	160.9
1	6	95	22	NO		86.4	161.0
1	6	95	23	RL		213.5	161.2
1	7	95	0	RL		196.3	161.5
1	7	95	1	RL		409.9	162.0
1	7	95	2	RL		464.0	162.6
1	7	95	3	RL		476.1	163.2
1	7	95	4	RL		457.1	163.7
1	7	95	5	RL		394.3	164.2
1	7	95	6	RL		83.8	164.3
1	7	95	7	NO		142.1	164.4
1	7	95	8	NO		160.2	164.5
1	7	95	9	NO		382.4	165.0
1	7	95	10	NO		148.9	165.1
1	7	95	11	NO		401.8	165.6
1	7	95	12	NO		112.8	165.6
1	7	95	13	NO		116.2	165.5
1	7	95	14	NO		112.5	165.5
1	7	95	15	NO		149.1	165.6
1	7	95	16	NO		84.9	165.6
1	7	95	17	NO		92.7	165.6
1	7	95	18	NO		192.7	165.8
1	7	95	19	NO		59.8	165.7
1	7	95	20	MF		186.2	165.8
1	7	95	21	NO		75.3	165.8
1	7	95	22	NO		64.8	165.9
1	7	95	23	RL		297.4	166.2
1	8	95	0	RL		553.1	166.9
1	8	95	1	RL		552.9	167.5
1	8	95	2	RL		572.3	167.8
1	8	95	3	MF		253.7	167.9
1	9	95	21	SS		2.5	167.9
1	9	95	22	RL		4.9	167.8
1	9	95	23	MF		460.2	168.4
1	10	95	0	RL		434.5	168.7
1	10	95	1	RL		236.9	168.9
1	10	95	2	RL		259.7	169.3
1	10	95	3	RL		317.6	169.6
1	10	95	4	RL		422.6	170.1
1	10	95	5	RL		188.3	170.2

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
			1hr	720rolling	1hr	720rolling
1	10	95	6	RL	299.2	170.4
1	10	95	7	RL	434.5	171.0
1	10	95	8	RL	525.5	171.6
1	10	95	9	RL	525.5	172.3
1	10	95	10	RL	349.9	172.7
1	10	95	11	RL	41.1	172.7
1	10	95	12	RL	51.8	172.5
1	10	95	13	RL	174.7	172.6
1	10	95	14	RL	198.7	172.6
1	10	95	15	RL	112.4	172.6
1	10	95	16	NO	93.5	172.6
1	10	95	17	NO	88.5	172.2
1	10	95	18	NO	171.9	171.8
1	10	95	19	NO	174.3	171.8
1	10	95	20	NO	197.2	171.7
1	10	95	21	RL	378.2	171.8
1	10	95	22	RL	568.9	172.2
1	10	95	23	RL	303.3	172.1
1	11	95	0	RL	265.6	172.5
1	11	95	1	RL	293.0	172.8
1	11	95	2	RL	507.4	173.5
1	11	95	3	RL	419.1	173.7
1	11	95	4	RL	322.2	173.9
1	11	95	5	RL	68.3	173.9
1	11	95	6	NO	114.0	173.9
1	11	95	7	NO	45.2	173.7
1	11	95	8	NO	103.0	173.6
1	11	95	9	NO	58.5	173.4
1	11	95	10	NO	69.4	173.4
1	11	95	11	NO	48.0	173.4
1	11	95	12	NO	61.4	173.5
1	11	95	13	NO	117.8	173.6
1	11	95	14	RL	180.6	173.7
1	11	95	15	RL	227.6	173.3
1	11	95	16	RL	195.8	173.0
1	11	95	17	NO	94.4	172.9
1	11	95	18	NO	92.1	172.8
1	11	95	19	NO	65.7	172.7
1	11	95	20	NO	55.7	172.7
1	11	95	21	NO	64.2	172.6
1	11	95	22	RL	58.9	172.6
1	11	95	23	RL	162.6	172.8
1	12	95	0	RL	108.1	172.7
1	12	95	1	RL	74.1	172.7
1	12	95	2	RL	124.2	172.9
1	12	95	3	RL	152.9	173.0
1	12	95	4	RL	278.7	173.3
1	12	95	5	RL	113.8	173.2
1	12	95	6	NO	137.8	173.0
1	12	95	7	NO	127.5	172.9
1	12	95	8	NO	52.3	172.6
1	12	95	9	NO	66.7	172.5
1	12	95	10	NO	57.6	172.5
1	12	95	11	NO	64.2	172.5
1	12	95	12	NO	67.7	172.6
1	12	95	13	NO	68.1	172.6
1	12	95	14	NO	57.7	172.7
1	12	95	15	NO	92.9	172.8
1	12	95	16	MF	187.3	172.8
1	12	95	17	NO	88.5	172.9
1	12	95	18	NO	87.7	173.0
1	12	95	19	NO	50.7	173.0
1	12	95	20	NO	54.7	173.0
1	12	95	21	NO	54.1	173.0
1	12	95	22	RL	79.1	173.0
1	12	95	23	RL	165.0	173.2
1	13	95	0	RL	129.9	173.3
1	13	95	1	RL	175.6	173.5
1	13	95	2	RL	239.3	173.8
1	13	95	3	RL	298.2	174.2
1	13	95	4	RL	189.5	174.2
1	13	95	5	RL	42.2	173.9
1	13	95	6	NO	75.2	173.8
1	13	95	7	NO	85.1	173.7
1	13	95	8	NO	110.3	173.5
1	13	95	9	RL	236.6	173.7
1	13	95	10	NO	202.3	173.7
1	13	95	13	NO	66.5	173.7
1	13	95	14	NO	142.3	173.9
1	13	95	15	NO	54.6	173.7
1	13	95	16	NO	54.5	173.6
1	13	95	17	NO	85.0	173.7
1	13	95	18	NO	101.3	173.8

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Averaging	Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
	Interval				1hr	720rolling	1hr	720rolling
1	13	95	19	NO			99.0	173.9
1	13	95	20	NO			69.0	173.9
1	13	95	21	RL			105.4	174.0
1	13	95	22	RL			57.8	174.1
1	13	95	23	RL			50.9	174.1
1	14	95	0	RL			37.0	174.1
1	14	95	1	RL			31.1	174.1
1	14	95	2	RL			99.1	173.7
1	14	95	3	RL			216.4	173.8
1	14	95	4	RL			127.7	174.0
1	14	95	5	RL			273.5	174.3
1	14	95	6	RL			201.4	174.4
1	14	95	7	NO			135.6	174.4
1	14	95	8	NO			59.0	174.4
1	14	95	9	NO			73.4	174.3
1	14	95	10	NO			58.9	174.1
1	14	95	11	NO			100.5	174.1
1	14	95	12	NO			69.5	174.1
1	14	95	13	NO			69.6	174.2
1	14	95	14	NO			61.6	174.2
1	14	95	15	NO			111.7	174.3
1	14	95	16	NO			186.5	174.5
1	14	95	17	NO			117.7	174.6
1	14	95	18	RL			302.9	174.9
1	14	95	19	RL/PF			164.2	175.1
1	14	95	20	NO			127.9	175.1
1	14	95	21	NO			173.4	174.9
1	14	95	22	RL			70.9	174.9
1	14	95	23	RL			121.2	175.0
1	15	95	0	RL			165.5	175.2
1	15	95	1	RL			146.9	175.4
1	15	95	2	RL			185.2	175.6
1	15	95	3	RL			180.9	175.8
1	15	95	4	RL			158.0	176.0
1	15	95	5	RL			129.6	176.1
1	15	95	6	RL			37.3	176.1
1	15	95	7	RL			25.1	176.0
1	15	95	8	RL			88.4	176.0
1	15	95	9	RL			488.3	176.3
1	15	95	10	RL			216.6	176.3
1	15	95	11	RL			155.8	176.2
1	15	95	12	RL			315.2	176.4
1	15	95	13	RL			342.6	176.9
1	15	95	14	RL			58.2	176.9
1	15	95	15	MF			169.9	177.1
1	15	95	16	RL			106.3	177.2
1	15	95	17	RL			190.5	177.4
1	15	95	18	RL			263.6	177.7
1	15	95	19	RL			168.2	177.9
1	15	95	20	RL			126.1	178.0
1	15	95	21	RL			123.2	178.2
1	15	95	22	RL			141.6	178.3
1	15	95	23	RL			242.8	178.5
1	16	95	0	RL			315.0	178.9
1	16	95	1	RL			364.3	179.3
1	16	95	2	RL			258.5	179.2
1	16	95	3	RL			337.4	179.5
1	16	95	4	RL			353.0	179.9
1	16	95	5	RL			320.2	180.3
1	16	95	6	RL			149.3	180.4
1	16	95	7	RL			208.1	180.6
1	16	95	8	RL			113.7	180.6
1	16	95	9	NO			62.6	180.6
1	16	95	10	NO			83.9	180.6
1	16	95	11	NO			203.1	180.8
1	16	95	12	NO			395.3	181.3
1	16	95	13	NO			151.1	181.5
1	16	95	14	NO			257.9	181.8
1	16	95	15	RL			156.7	181.9
1	16	95	16	NO			279.7	182.3
1	16	95	17	NO			500.5	182.9
1	16	95	18	NO			510.9	183.5
1	16	95	19	NO			376.3	184.0
1	16	95	20	NO			236.7	184.2
1	16	95	21	NO			61.7	184.3
1	16	95	22	NO			58.0	184.3
1	16	95	23	RL			333.3	184.7
1	17	95	0	RL			438.3	185.3
1	17	95	1	RL			458.0	185.8
1	17	95	2	RL			471.3	186.4
1	17	95	3	RL			466.0	187.0
1	17	95	4	RL			398.8	187.6
1	17	95	5	MF			221.9	187.8

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Averaging Interval	Date	Time	Operating Codes	#/hr	#/hr	CO	CO
				1hr	720rolling	1hr	720rolling
1	17	95	6	RL		150.3	187.9
1	17	95	7	NO		84.9	187.8
1	17	95	8	NO		85.0	187.6
1	17	95	9	NO		69.1	187.5
1	17	95	10	NO		261.6	187.6
1	17	95	11	NO		69.2	187.5
1	17	95	12	RL		107.2	187.5
1	17	95	13	RL		339.5	187.9
1	17	95	14	RL		348.0	188.4
1	17	95	15	RL		481.3	189.0
1	17	95	16	RL		413.9	189.5
1	17	95	17	RL		254.6	189.6
1	17	95	18	RL		316.2	189.4
1	17	95	19	RL		105.5	189.4
1	17	95	20	RL		119.1	189.5
1	17	95	21	NO		61.7	189.5
1	17	95	22	RL		115.0	189.6
1	17	95	23	RL		225.6	189.8
1	18	95	0	RL		269.6	190.0
1	18	95	1	RL		404.1	190.3
1	18	95	2	RL		407.3	190.6
1	18	95	3	RL		424.9	191.1
1	18	95	4	RL		433.9	191.2
1	18	95	5	RL		138.2	191.4
1	18	95	6	NO		288.5	191.6
1	18	95	7	NO		134.0	191.6
1	18	95	8	NO		100.7	191.4
1	18	95	9	NO		132.6	191.3
1	18	95	10	NO		77.9	191.2
1	18	95	11	NO		52.9	191.1
1	18	95	12	NO		48.8	191.2
1	18	95	13	NO		46.1	191.2
1	18	95	14	NO		56.8	191.2
1	18	95	15	NO		97.7	191.2
1	18	95	16	NO		122.8	191.3
1	18	95	17	NO		133.9	191.4
1	18	95	18	NO		193.2	191.5
1	18	95	19	NO		126.7	191.5
1	18	95	20	NO		69.7	191.2
1	18	95	21	NO		60.7	190.8
1	18	95	22	NO		68.6	190.5
1	18	95	23	RL		317.8	190.3
1	19	95	0	RL		471.7	190.4
1	19	95	1	RL		361.0	190.2
1	19	95	2	RL		383.1	190.4
1	19	95	3	RL		393.8	190.4
1	19	95	4	RL		332.7	190.7
1	19	95	5	NO		73.9	190.3
1	19	95	6	NO		84.1	189.9
1	19	95	7	NO		50.4	189.8
1	19	95	8	RL		153.2	190.0
1	19	95	9	RL		418.9	190.5
1	19	95	10	RL		161.9	190.6
1	19	95	11	NO		22.4	190.5
1	19	95	12	NO		70.0	190.4
1	19	95	13	RL		46.3	190.4
1	19	95	14	RL		43.2	189.8
1	19	95	15	NO		33.5	189.2
1	19	95	16	NO		43.0	188.6
1	19	95	17	NO		39.6	188.1
1	19	95	18	NO		68.4	187.5
1	19	95	19	NO		129.7	187.2
1	19	95	20	NO		50.4	186.8
1	19	95	21	NO		53.1	186.8
1	19	95	22	RL		77.6	186.7
1	19	95	23	RL		112.8	186.3
1	20	95	0	RL		232.6	185.9
1	20	95	1	RL		409.0	185.8
1	20	95	2	RL		497.7	185.6
1	20	95	3	RL		226.3	185.6
1	20	95	4	RL		225.6	185.8
1	20	95	5	NO		142.2	186.0
1	20	95	6	NO		57.8	186.0
1	20	95	7	NO		67.4	185.8
1	20	95	8	NO		42.3	185.3
1	20	95	9	NO		94.0	184.9
1	20	95	10	NO		97.7	184.6
1	20	95	11	NO		37.4	184.5
1	20	95	12	NO		29.1	184.4
1	20	95	13	NO		25.2	184.4
1	20	95	14	RL		137.8	184.5
1	20	95	15	RL		117.6	184.6
1	20	95	16	NO		99.2	184.5

**RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR**

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date		Time		Operating Codes	#/hr	#/hr	CO	CO
Averaging Interval					thr	720rolling	thr	720rolling
1	20	95	17	NO			131.0	184.6
1	20	95	18	NO			58.0	184.5
1	20	95	19	NO			45.6	184.3
1	20	95	20	NO			71.7	183.9
1	20	95	21	NO			56.6	183.7
1	20	95	22	RL			62.3	183.4
1	20	95	23	RL			105.5	183.2
1	21	95	0	RL			177.4	183.1
1	21	95	1	RL			158.7	183.2
1	21	95	2	RL			174.6	183.4
1	21	95	3	RL			279.4	183.8
1	21	95	4	RL			154.2	184.0
1	21	95	5	NO			42.5	184.0
1	21	95	6	NO			51.6	183.8
1	21	95	7	RL			114.4	183.5
1	21	95	8	RL			146.2	183.4
1	21	95	9	RL			94.4	183.1
1	21	95	10	RL			64.8	182.7
1	21	95	11	RL			43.7	182.1
1	21	95	12	RL			47.2	181.6
1	21	95	13	NO			36.8	181.4
1	21	95	14	NO			31.4	181.2
1	21	95	15	NO			33.4	181.1
1	21	95	16	NO			80.9	180.7
1	21	95	17	NO			33.8	180.2
1	21	95	18	NO			29.9	180.1
1	21	95	19	NO			43.4	180.1
1	21	95	20	NO			74.6	180.1
1	21	95	21	NO			63.0	180.1
1	21	95	22	RL			68.7	180.1
1	21	95	23	RL			163.7	180.2
1	22	95	0	RL			152.2	180.3
1	22	95	1	MF			270.4	180.6
1	22	95	2	RL			394.2	180.8
1	22	95	3	RL			407.5	180.8
1	22	95	4	RL			458.4	181.2
1	22	95	5	RL			264.1	181.5
1	22	95	6	RL			130.1	181.5
1	22	95	7	RL			124.3	181.6
1	22	95	8	RL			84.4	181.7
1	22	95	9	RL			136.0	181.9
1	22	95	10	RL			129.6	182.0
1	22	95	11	RL			132.0	182.2
1	22	95	12	RL			37.8	181.9
1	22	95	13	RL			73.8	181.9
1	22	95	14	RL			80.2	181.9
1	22	95	15	RL			129.3	182.0
1	22	95	16	NO			160.2	182.2
1	22	95	17	NO			57.2	182.2
1	22	95	18	NO			41.2	182.1
1	22	95	19	NO			57.4	182.1
1	22	95	20	NO			60.2	182.0
1	22	95	21	NO			77.6	182.0
1	22	95	22	RL			85.5	182.1
1	22	95	23	RL			103.0	182.1
1	23	95	0	RL			137.6	182.2
1	23	95	1	RL			145.9	182.2
1	23	95	2	RL			274.7	182.3
1	23	95	3	RL			470.6	182.7
1	23	95	4	MF			268.6	182.8
1	23	95	5	NO			84.9	182.8
1	23	95	6	NO			84.5	182.6
1	23	95	7	NO			94.1	182.5
1	23	95	8	NO			62.9	182.2
1	23	95	9	NO			45.8	181.8
1	23	95	10	NO			42.5	181.4
1	23	95	11	RL			72.3	181.1
1	23	95	12	NO			51.7	181.2
1	23	95	13	NO			92.5	181.2
1	23	95	14	NO			50.8	180.9
1	23	95	15	RL			85.0	180.5
1	23	95	16	NO			71.6	180.5
1	23	95	17	RL			285.5	180.7
1	23	95	18	RL/PF			307.8	180.8
1	23	95	19	MF			145.3	180.8
1	23	95	20	RL/PF			179.2	180.8
1	23	95	21	RL/PF			96.4	180.7
1	23	95	22	RL			50.2	180.6
1	23	95	23	RL			274.0	180.9
1	24	95	0	RL			467.2	181.4
1	24	95	1	RL			518.8	182.0
1	24	95	2	RL			414.3	182.5
1	24	95	3	RL			318.9	182.8

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Averaging Interval	Date	Time	Operating Codes	#/hr	#/hr	CO	CO
				1hr	720rolling	1hr	720rolling
1	24	95	4	RL		201.1	183.0
1	24	95	5	RL		89.6	183.0
1	24	95	6	RL		104.2	183.0
1	24	95	7	NO		62.7	183.0
1	24	95	8	NO		46.9	182.5
1	24	95	9	NO		47.7	182.6
1	24	95	10	RL		52.2	182.6
1	24	95	11	RL		73.3	182.3
1	24	95	12	RL		198.3	182.5
1	24	95	13	RL		99.0	182.4
1	24	95	14	NO		36.7	182.1
1	24	95	15	RL		177.6	182.2
1	24	95	16	RL		45.8	181.7
1	24	95	17	NO		257.5	181.6
1	24	95	18	NO		38.8	180.9
1	24	95	19	NO		50.7	180.6
1	24	95	20	NO		40.1	180.1
1	24	95	21	NO		38.2	180.0
1	24	95	22	NO		49.6	179.8
1	24	95	23	RL		74.2	179.8
1	25	95	0	RL		65.8	179.8
1	25	95	1	RL		107.5	179.9
1	25	95	2	RL		109.6	179.9
1	25	95	3	RL		131.5	179.9
1	25	95	4	RL		170.2	179.9
1	25	95	5	RL		105.0	179.9
1	25	95	6	NO		52.3	179.8
1	25	95	7	NO		50.5	179.8
1	25	95	8	NO		39.3	179.7
1	25	95	9	NO		41.5	179.4
1	25	95	10	NO		39.4	179.2
1	25	95	11	NO		76.2	179.2
1	25	95	12	NO		40.6	179.2
1	25	95	13	RL		78.6	179.2
1	25	95	14	NO		69.0	179.2
1	25	95	15	NO		69.3	179.1
1	25	95	16	NO		91.7	179.0
1	25	95	17	NO		153.3	179.0
1	25	95	18	NO		109.4	178.9
1	25	95	19	NO		65.3	178.6
1	25	95	20	NO		47.2	178.6
1	25	95	21	NO		65.3	178.5
1	25	95	22	NO		57.0	178.4
1	25	95	23	RL		70.0	178.3
1	26	95	0	RL		78.0	178.4
1	26	95	1	RL		89.0	178.4
1	26	95	2	RL		183.4	178.4
1	26	95	3	RL		156.1	178.5
1	26	95	4	RL		97.4	178.2
1	26	95	5	RL/PF		106.4	178.3
1	26	95	6	RL/PF		131.7	178.4
1	26	95	7	RL/PF		187.8	178.6
1	26	95	8	RL		45.5	178.5
1	26	95	9	RL		122.9	178.6
1	26	95	10	RL		124.1	178.1
1	26	95	11	RL		37.3	177.7
1	26	95	12	RL		58.6	177.5
1	26	95	13	RL		139.2	177.5
1	26	95	14	RL		146.0	177.5
1	26	95	15	RL		84.1	177.4
1	26	95	16	RL		126.7	177.5
1	26	95	17	RL		46.6	177.2
1	26	95	18	RL		59.8	176.6
1	26	95	19	RL		100.6	176.4
1	26	95	20	NO		57.4	175.9
1	26	95	21	NO		63.8	175.9
1	26	95	22	NO		195.8	176.1
1	26	95	23	SS		124.8	176.2
1	28	95	13	SS		1.0	175.9
1	28	95	14	RL/PF		266.8	175.6
1	28	95	15	NO/PF		217.9	175.2
1	28	95	16	NO		41.6	174.9
1	28	95	17	RL		254.1	175.1
1	28	95	18	RL		563.5	175.8
1	28	95	19	RL		549.8	176.4
1	28	95	20	RL		522.7	177.0
1	28	95	21	RL		308.4	177.4
1	28	95	22	RL		134.9	177.5
1	28	95	23	RL		133.7	177.6
1	29	95	0	MF		103.2	177.3
1	29	95	1	RL		166.8	177.4
1	29	95	2	RL		138.9	177.5
1	29	95	3	RL		131.5	177.6

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
					#/hr	#/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
1	29	95	4	RL	483.3	178.1
1	29	95	5	RL	503.4	178.6
1	29	95	6	RL	236.4	178.7
1	29	95	7	RL	124.9	178.6
1	29	95	8	RL	117.4	178.5
1	29	95	9	RL	167.9	178.2
1	29	95	10	RL	110.1	177.8
1	29	95	11	RL	84.0	177.5
1	29	95	12	RL	77.6	177.3
1	29	95	13	RL	93.6	177.2
1	29	95	14	RL	124.8	177.2
1	29	95	15	RL	265.9	177.2
1	29	95	16	RL	317.6	177.6
1	29	95	17	RL	177.5	177.3
1	29	95	18	RL	96.6	177.3
1	29	95	19	RL	56.8	177.2
1	29	95	20	RL	66.2	177.2
1	29	95	21	RL	52.7	177.1
1	29	95	22	RL	40.2	177.1
1	29	95	23	RL	38.8	176.8
1	30	95	0	RL	42.3	176.5
1	30	95	1	RL	94.6	176.4
1	30	95	2	RL	111.0	176.5
1	30	95	3	RL	287.6	176.8
1	30	95	4	RL	111.3	176.8
1	30	95	5	NO	116.6	176.8
1	30	95	6	NO	80.4	176.8
1	30	95	7	NO	60.9	176.8
1	30	95	8	NO	63.3	176.7
1	30	95	9	NO	67.8	176.4
1	30	95	10	NO	60.7	176.3
1	30	95	11	NO	63.0	176.1
1	30	95	12	NO	54.0	176.0
1	30	95	13	NO	53.8	175.8
1	30	95	14	RL	49.0	175.6
1	30	95	15	NO	36.2	175.2
1	30	95	16	NO	35.1	175.0
1	30	95	17	NO	53.7	175.0
1	30	95	18	NO	70.2	175.0
1	30	95	19	NO	51.2	174.4
1	30	95	20	NO	34.3	173.9
1	30	95	21	RL	54.8	173.9
1	30	95	22	RL	136.2	174.0
1	30	95	23	RL	150.4	174.1
1	31	95	0	RL	123.0	174.2
1	31	95	1	RL	180.8	174.4
1	31	95	2	RL	326.6	174.7
1	31	95	3	RL	311.5	175.1
1	31	95	4	MF	230.6	175.2
1	31	95	5	SS	16.3	174.7
1	31	95	6	SS	9.7	174.4
1	31	95	7	RL/PF	43.6	174.4
1	31	95	8	NO	39.9	174.3
1	31	95	9	NO	46.6	174.0
1	31	95	10	NO/PF	80.2	174.0
1	31	95	11	NO	44.7	173.8
1	31	95	12	NO	72.1	173.7
1	31	95	13	NO	62.5	173.7
1	31	95	14	NO	153.2	173.9
1	31	95	15	RL	81.1	173.9
1	31	95	16	NO	46.1	173.9
1	31	95	17	NO	148.3	174.0
1	31	95	18	NO	85.3	173.6
1	31	95	19	NO	76.9	173.6
1	31	95	20	NO	93.2	173.6
1	31	95	21	RL/PF	121.1	173.7
2	1	95	2	SS	427.5	173.9
2	1	95	3	RL	161.9	173.5
2	1	95	4	RL	95.2	173.4
2	1	95	5	NO	133.5	173.2
2	1	95	6	NO	190.7	173.1
2	1	95	7	NO	100.7	172.5
2	1	95	8	NO	104.7	171.9
2	1	95	9	NO	177.1	171.7
2	1	95	10	NO	85.9	171.3
2	1	95	11	NO	41.3	170.9
2	1	95	19	MF	7.3	170.6
2	1	95	20	RL/PF	124.5	170.4
2	1	95	21	RL	130.6	170.5
2	1	95	22	RL	90.7	170.5
2	1	95	23	RL	42.1	170.1
2	2	95	0	RL	38.0	169.7
2	2	95	1	RL	74.9	169.6

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
2	2	95	2			113.0	169.2
2	2	95	3			159.8	169.1
2	2	95	4			157.4	169.1
2	2	95	5			46.2	169.0
2	2	95	6			28.2	168.8
2	2	95	7			86.2	169.0
2	2	95	8			88.9	168.9
2	2	95	9			127.6	168.8
2	2	95	10			168.7	169.0
2	2	95	11			128.0	169.1
2	2	95	12			187.7	169.3
2	2	95	13			256.5	169.5
2	2	95	14			284.7	169.8
2	2	95	15			82.1	169.8
2	2	95	16			470.8	170.3
2	2	95	17			584.9	170.7
2	2	95	18			397.5	170.9
2	2	95	19			109.2	170.6
2	2	95	20			323.6	171.0
2	2	95	21			118.1	171.0
2	2	95	22			54.1	170.8
2	2	95	23			59.0	170.4
2	3	95	0			48.3	170.3
2	3	95	1			75.4	170.3
2	3	95	2			103.5	170.3
2	3	95	3			108.6	170.3
2	3	95	4			53.7	170.4
2	3	95	5			55.1	169.9
2	3	95	6			207.5	169.9
2	3	95	7			98.5	169.8
2	3	95	8			69.4	169.6
2	3	95	9			38.3	169.0
2	3	95	10			39.3	168.3
2	3	95	11			39.6	167.7
2	3	95	12			36.1	167.8
2	3	95	13			31.8	167.7
2	3	95	14			77.8	167.7
2	3	95	15			77.4	167.1
2	3	95	16			74.0	166.9
2	3	95	17			162.5	167.0
2	3	95	18			56.6	167.0
2	3	95	19			79.7	167.0
2	3	95	20			67.7	166.9
2	3	95	21			67.8	166.6
2	3	95	22			54.9	166.0
2	3	95	23			72.9	165.5
2	4	95	0			121.6	165.0
2	4	95	1			255.5	164.7
2	4	95	2			265.3	164.7
2	4	95	3			143.8	164.8
2	4	95	4			116.1	164.7
2	4	95	5			192.9	164.8
2	4	95	6			45.5	164.7
2	4	95	7			43.2	164.4
2	4	95	8			43.2	164.3
2	4	95	9			45.2	163.8
2	4	95	10			42.6	163.7
2	4	95	11			41.4	163.6
2	4	95	12			43.6	163.5
2	4	95	13			43.5	163.5
2	4	95	14			43.0	163.5
2	4	95	15			42.7	163.4
2	4	95	16			45.0	163.4
2	4	95	17			39.7	163.3
2	4	95	18			66.5	163.2
2	4	95	19			60.9	163.2
2	4	95	20			55.7	162.9
2	4	95	21			55.3	162.5
2	4	95	22			59.2	161.9
2	4	95	23			92.3	161.4
2	5	95	0			119.4	160.9
2	5	95	1			224.6	160.6
2	5	95	2			68.6	160.1
2	5	95	3			64.4	159.5
2	5	95	4			76.9	159.0
2	5	95	5			71.5	158.7
2	5	95	6			63.7	158.4
2	5	95	7			59.7	158.1
2	5	95	8			60.9	157.8
2	5	95	9			75.2	157.6
2	5	95	10			54.3	157.5
2	5	95	11			59.3	157.5
2	5	95	12			56.8	157.5

**RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR**

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging	Interval			1hr	720rolling	1hr	720rolling
2	5	95	13	NO		36.7	157.4
2	5	95	14	NO		41.1	157.4
2	5	95	15	NO		41.2	157.4
2	5	95	16	NO		43.1	157.3
2	5	95	17	NO		48.5	157.3
2	5	95	18	NO		49.9	157.1
2	5	95	19	NO		57.1	157.0
2	5	95	20	NO		53.0	156.9
2	5	95	21	NO		61.2	156.6
2	5	95	22	NO		64.1	156.0
2	5	95	23	RL		57.4	155.5
2	6	95	0	RL		77.0	154.9
2	6	95	1	RL		82.8	154.4
2	6	95	2	RL		64.2	153.9
2	6	95	3	RL		45.5	153.6
2	6	95	4	NO		63.4	153.5
2	6	95	5	NO		133.7	153.6
2	6	95	6	NO		58.5	153.6
2	6	95	7	NO		50.3	153.5
2	6	95	8	NO		51.2	153.5
2	6	95	9	NO		57.4	153.5
2	6	95	10	NO		58.9	153.5
2	6	95	11	NO		54.7	153.4
2	6	95	12	NO		40.2	153.2
2	6	95	13	NO		42.1	153.1
2	6	95	14	RL		64.2	153.0
2	6	95	15	RL		53.5	152.8
2	6	95	16	RL		38.8	152.7
2	6	95	17	NO		52.5	152.7
2	6	95	18	NO		62.2	152.5
2	6	95	19	NO		73.4	152.3
2	6	95	20	NO		74.5	152.1
2	6	95	21	NO		70.8	151.9
2	6	95	22	NO		61.6	151.5
2	6	95	23	NO		64.6	151.1
2	7	95	0	NO		34.7	150.6
2	7	95	1	NO		34.2	150.2
2	7	95	2	NO		34.2	149.9
2	7	95	3	NO		36.1	149.8
2	7	95	4	NO		98.8	149.7
2	7	95	5	NO		63.0	149.7
2	7	95	6	NO		59.5	149.5
2	7	95	7	NO		58.2	149.5
2	7	95	8	NO		55.9	149.4
2	7	95	9	NO		53.3	149.1
2	7	95	10	NO		48.7	149.0
2	7	95	11	NO		39.0	148.9
2	7	95	12	NO		28.7	148.8
2	7	95	13	RL		36.0	148.8
2	7	95	14	RL		21.4	148.7
2	7	95	15	NO		29.7	148.6
2	7	95	16	RL		31.9	148.6
2	7	95	17	RL		61.6	148.6
2	7	95	18	RL		59.9	148.6
2	7	95	19	NO		125.9	148.6
2	7	95	20	NO		106.0	148.4
2	7	95	21	NO		167.5	148.3
2	7	95	22	NO		90.3	147.8
2	7	95	23	NO		334.2	147.5
2	8	95	0	NO		106.1	147.0
2	8	95	1	NO		100.7	146.5
2	8	95	2	NO		178.6	146.3
2	8	95	3	NO		62.3	146.2
2	8	95	4	NO		62.7	145.9
2	8	95	5	NO		46.0	145.5
2	8	95	6	NO		58.4	145.5
2	8	95	7	NO		59.1	145.5
2	8	95	8	NO		53.1	145.5
2	8	95	9	NO		51.2	145.2
2	8	95	10	NO		70.2	145.2
2	8	95	11	NO		49.9	145.2
2	8	95	12	NO		49.1	145.2
2	8	95	13	NO		48.2	145.1
2	8	95	14	NO		45.8	145.0
2	8	95	15	NO		43.0	144.9
2	8	95	16	NO		46.6	144.7
2	8	95	17	NO		59.3	144.6
2	8	95	18	NO		74.8	144.6
2	8	95	19	NO		70.2	144.5
2	8	95	20	NO		55.5	144.2
2	8	95	21	NO		87.2	143.7
2	8	95	22	NO		65.9	143.4
2	8	95	23	NO		62.5	143.5
2	9	95	0	NO			

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
2 9 95	1	NO			53.7	143.2
2 9 95	2	NO			73.0	142.8
2 9 95	3	NO			72.0	142.6
2 9 95	4	NO			72.6	142.5
2 9 95	5	NO			64.6	142.4
2 9 95	6	NO			75.0	142.2
2 9 95	7	NO			211.0	142.5
2 9 95	8	NO			112.8	142.5
2 9 95	9	MF			306.6	142.3
2 9 95	12	NO			49.0	141.7
2 9 95	14	NO			53.9	141.2
2 9 95	15	NO			52.6	140.8
2 9 95	17	NO			39.6	140.2
2 9 95	18	NO			44.9	139.6
2 9 95	19	NO			42.2	139.0
2 9 95	20	RL			180.5	138.8
2 9 95	21	RL			297.9	139.0
2 9 95	22	NO			78.6	139.0
2 9 95	23	NO			81.7	138.8
2 10 95	0	MF			120.6	138.7
2 10 95	1	MF			148.1	138.3
2 10 95	2	SS			138.7	137.9
2 10 95	3	RL/PF			105.0	137.4
2 10 95	4	NO			70.2	136.8
2 10 95	5	NO			62.9	136.4
2 10 95	6	MF			122.9	136.4
2 10 95	7	MF			363.5	136.7
2 10 95	8	SS			484.4	137.2
2 10 95	9	RL			159.6	136.9
2 10 95	10	MF			379.7	137.2
2 10 95	11	NO			213.7	136.9
2 10 95	12	NO			72.9	136.9
2 10 95	13	RL			86.1	136.8
2 10 95	14	RL			231.7	137.0
2 10 95	15	RL			86.1	136.9
2 10 95	16	RL			68.2	136.9
2 10 95	17	NO			59.9	136.8
2 10 95	18	NO			54.9	136.7
2 10 95	19	NO			62.4	136.7
2 10 95	20	NO			60.2	136.5
2 10 95	21	NO			65.7	136.5
2 10 95	22	NO			71.7	136.5
2 10 95	23	RL			93.7	136.2
2 11 95	0	RL			171.0	135.7
2 11 95	1	RL			226.9	135.2
2 11 95	2	RL			262.6	134.8
2 11 95	3	RL			307.8	134.9
2 11 95	4	RL/PF			330.6	135.3
2 11 95	5	RL/PF			62.4	135.4
2 11 95	6	RL/PF			6.4	134.8
2 11 95	7	RL/PF			5.5	134.2
2 11 95	8	RL/PF			7.2	133.8
2 11 95	9	RL/PF			16.5	133.5
2 11 95	10	RL/PF			160.6	133.3
2 11 95	11	RL			57.2	132.8
2 11 95	12	MF			205.5	132.8
2 11 95	13	RL			452.8	133.0
2 11 95	14	RL			135.1	132.6
2 11 95	15	RL			27.3	131.9
2 11 95	16	RL			79.3	131.3
2 11 95	17	RL			72.7	130.9
2 11 95	18	RL			324.0	131.3
2 11 95	19	RL			182.6	131.5
2 11 95	20	NO			65.6	131.3
2 11 95	21	NO			55.9	131.1
2 11 95	22	NO			49.3	131.0
2 11 95	23	NO			47.4	131.0
2 12 95	0	RL			96.8	131.0
2 12 95	1	RL			118.9	130.9
2 12 95	2	RL			98.0	130.8
2 12 95	3	RL			87.1	130.7
2 12 95	4	RL			84.5	130.3
2 12 95	5	RL			99.3	129.6
2 12 95	6	RL			97.7	129.3
2 12 95	7	RL			213.6	129.2
2 12 95	8	RL			607.7	129.7
2 12 95	9	NO			253.3	129.3
2 12 95	10	NO			128.0	128.9
2 12 95	11	NO			88.5	128.6
2 12 95	13	NO			60.6	128.6
2 12 95	14	NO			66.7	128.5
2 12 95	15	NO			67.6	128.6
2 12 95	16	NO			25.1	128.4

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Averaging	Date	Time	Interval	Operating Codes	#/hr	#/hr	CO	CO
					1hr	720rolling	1hr	720rolling
2	12	95	17	NO			15.4	128.4
2	12	95	18	NO			13.5	128.3
2	12	95	19	NO			50.4	128.3
2	12	95	20	NO			50.8	128.3
2	12	95	21	NO			47.7	128.2
2	12	95	22	NO			54.9	128.0
2	12	95	23	RL			125.9	127.9
2	13	95	0	RL			59.1	127.7
2	13	95	1	RL			68.0	127.7
2	13	95	2	RL			83.0	127.6
2	13	95	3	RL			77.3	127.7
2	13	95	4	RL			67.8	127.7
2	13	95	5	NO			85.9	127.7
2	13	95	6	NO			79.4	127.7
2	13	95	7	NO			187.0	127.8
2	13	95	8	NO			81.7	127.7
2	13	95	9	NO			57.0	127.7
2	13	95	16	NO			122.4	127.7
2	13	95	17	MF			214.4	127.8
2	13	95	18	NO			157.3	127.6
2	13	95	19	NO			92.2	127.6
2	13	95	20	NO			93.3	127.5
2	13	95	21	NO			126.0	127.5
2	13	95	22	NO			76.6	127.6
2	13	95	23	RL			37.1	127.5
2	14	95	0	RL			54.2	127.5
2	14	95	1	RL			52.6	127.5
2	14	95	2	RL			62.4	127.5
2	14	95	3	RL			64.2	127.5
2	14	95	4	RL			54.8	127.5
2	14	95	5	NO			49.9	127.4
2	14	95	6	NO			69.7	127.3
2	14	95	7	NO			51.1	127.2
2	14	95	8	NO			51.3	127.2
2	14	95	9	NO			52.0	127.2
2	14	95	10	NO			153.7	127.3
2	14	95	11	NO			46.7	127.3
2	14	95	12	NO			63.8	127.3
2	14	95	13	NO			69.0	127.1
2	14	95	14	NO			65.6	127.0
2	14	95	15	NO			76.6	126.9
2	14	95	16	NO			52.7	126.6
2	14	95	17	NO			72.2	126.3
2	14	95	18	NO			75.9	126.2
2	14	95	19	NO			61.6	126.2
2	14	95	20	NO			44.5	126.2
2	14	95	21	NO			77.5	126.2
2	14	95	22	NO			66.2	126.1
2	14	95	23	NO			44.1	125.8
2	15	95	0	RL			51.2	125.6
2	15	95	1	RL			64.5	125.6
2	15	95	2	RL			70.0	125.5
2	15	95	3	RL			81.4	125.5
2	15	95	4	RL			258.8	125.8
2	15	95	5	NO			36.6	125.8
2	15	95	6	NO			112.4	125.8
2	15	95	7	NO			74.9	125.7
2	15	95	8	NO			57.8	125.7
2	15	95	9	NO			120.8	125.8
2	15	95	10	NO			59.3	125.8
2	15	95	11	NO			59.5	125.8
2	15	95	12	NO			55.8	125.8
2	15	95	13	MF			255.7	126.1
2	15	95	14	NO			91.5	126.1
2	15	95	15	NO			67.4	125.9
2	15	95	16	NO			71.3	125.8
2	15	95	17	NO			128.0	125.6
2	15	95	18	NO			92.1	125.5
2	15	95	19	NO			60.5	125.3
2	15	95	20	NO			48.2	125.3
2	15	95	21	NO			95.6	125.4
2	15	95	22	NO			37.2	125.3
2	15	95	23	NO			50.0	125.3
2	16	95	0	RL			51.0	125.2
2	16	95	1	RL			56.9	125.2
2	16	95	2	RL			47.4	125.2
2	16	95	3	RL			50.5	125.1
2	16	95	4	NO			32.6	124.9
2	16	95	5	NO/PF			32.2	124.8
2	16	95	6	NO/PF			68.4	124.5
2	16	95	7	MF			178.2	124.5
2	16	95	8	NO/PF			27.6	124.3
2	16	95	9	NO			32.6	124.1

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
2 16 95	10	NO			37.8	124.1
2 16 95	11	NO			41.3	124.0
2 16 95	12	NO			47.6	123.8
2 16 95	13	NO			36.6	123.7
2 16 95	14	NO			40.8	123.5
2 16 95	15	NO			24.7	123.3
2 16 95	16	NO			30.3	123.1
2 16 95	17	NO			29.8	122.9
2 16 95	18	NO			22.9	122.9
2 16 95	19	NO			24.2	122.9
2 16 95	20	NO			27.8	122.8
2 16 95	21	NO			37.2	122.2
2 16 95	22	NO			36.1	122.0
2 16 95	23	NO			57.0	121.8
2 17 95	0	RL			49.4	121.4
2 17 95	1	RL			59.5	121.1
2 17 95	2	RL			69.4	121.1
2 17 95	3	RL			54.8	120.9
2 17 95	4	RL			49.4	120.8
2 17 95	5	NO/PF			40.2	120.6
2 17 95	6	NO/PF			22.5	120.3
2 17 95	7	NO/PF			33.5	120.1
2 17 95	8	MF			165.4	120.2
2 17 95	9	NO			93.0	120.1
2 17 95	10	NO			36.4	120.0
2 17 95	11	NO			26.1	119.7
2 17 95	12	NO			31.2	119.3
2 17 95	15	NO			44.9	118.8
2 17 95	16	NO/PF			139.0	118.7
2 17 95	17	MF			205.2	118.5
2 17 95	18	NO			235.5	118.3
2 17 95	19	NO			44.3	117.9
2 17 95	20	MF			138.1	117.9
2 17 95	21	NO/PF			92.0	117.8
2 17 95	22	RL/PF			436.7	118.2
2 17 95	23	RL			553.6	118.9
2 18 95	0	RL			308.3	119.2
2 18 95	1	RL			325.1	119.4
2 18 95	2	RL			70.4	118.9
2 18 95	3	MF			285.6	119.1
2 18 95	6	SS			477.1	119.4
2 18 95	7	MF			366.4	119.7
2 18 95	8	NO/PF			51.4	119.4
2 18 95	11	NO/PF			66.4	118.8
2 18 95	19	SS			3.5	118.1
2 18 95	20	RL/PF			133.1	117.7
2 18 95	21	NO/PF			67.3	117.5
2 18 95	22	NO/PF			36.3	117.5
2 18 95	23	NO/PF			35.5	117.4
2 19 95	0	NO			47.8	117.0
2 19 95	1	RL			51.1	116.5
2 19 95	2	RL			51.6	115.9
2 19 95	3	RL			47.8	115.3
2 19 95	4	RL			63.8	114.8
2 19 95	5	NO/PF			45.9	114.3
2 19 95	6	MF			185.4	114.2
2 19 95	7	NO/PF			84.7	114.2
2 19 95	8	NO/PF			31.7	114.1
2 19 95	9	NO/PF			34.4	114.0
2 19 95	10	NO/PF			35.9	114.0
2 19 95	11	NO/PF			31.3	113.6
2 19 95	12	NO/PF			26.8	113.6
2 19 95	13	NO/PF			28.3	113.5
2 19 95	14	NO/PF			35.1	113.1
2 19 95	15	NO/PF			33.3	112.6
2 19 95	16	NO/PF			18.7	112.0
2 19 95	17	NO/PF			39.7	111.5
2 19 95	18	NO/PF			27.0	111.1
2 19 95	19	NO/PF			27.5	110.7
2 19 95	20	NO/PF			25.5	110.6
2 19 95	21	NO/PF			37.7	110.5
2 19 95	22	NO/PF			25.4	110.5
2 19 95	23	NO/PF			32.3	110.3
2 20 95	0	RL			41.4	110.1
2 20 95	1	RL			41.4	109.8
2 20 95	2	RL			41.8	109.3
2 20 95	3	RL			43.0	108.8
2 20 95	4	RL			49.2	108.2
2 20 95	5	NO/PF			29.8	107.7
2 20 95	6	NO/PF			29.2	107.5
2 20 95	7	NO/PF			24.4	107.2
2 20 95	8	NO/PF			21.5	107.0
2 20 95	9	NO/PF			27.3	106.9

**RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR**

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
					#/hr	#/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
2	20	95	10	NO/PF	26.9	106.8
2	20	95	11	NO/PF	30.6	106.7
2	20	95	12	NO/PF	22.2	106.7
2	20	95	13	NO/PF	26.1	106.6
2	20	95	14	NO/PF	22.9	106.6
2	20	95	15	NO/PF	25.1	106.5
2	20	95	16	NO/PF	21.8	106.4
2	20	95	17	NO/PF	30.7	106.3
2	20	95	18	NO/PF	33.9	106.2
2	20	95	19	NO/PF	25.0	105.9
2	20	95	20	NO/PF	25.2	105.8
2	20	95	21	NO/PF	30.2	105.7
2	20	95	22	NO/PF	145.5	105.9
2	20	95	23	RL	56.9	105.8
2	21	95	0	RL	97.4	105.5
2	21	95	1	RL	86.1	105.0
2	21	95	2	RL	126.4	104.7
2	21	95	3	RL	139.8	104.3
2	21	95	4	NO/PF	109.2	103.9
2	21	95	5	NO/PF	9.2	103.5
2	21	95	6	NO/PF	0.0	103.4
2	21	95	8	NO/PF	17.5	103.3
2	21	95	12	NO/PF	40.7	103.3
2	21	95	13	NO/PF	64.6	103.2
2	21	95	14	NO/PF	75.1	102.7
2	21	95	15	NO/PF	133.5	102.6
2	21	95	17	NO/PF	27.1	102.7
2	21	95	18	NO/PF	31.4	102.6
2	21	95	19	NO/PF	23.9	102.6
2	21	95	20	NO/PF	28.7	102.5
2	21	95	21	NO/PF	33.2	102.5
2	21	95	22	NO/PF	57.7	102.6
2	21	95	23	MF	119.5	102.7
2	22	95	0	RL	140.2	102.8
2	22	95	1	RL	29.8	102.6
2	22	95	2	RL	32.7	102.6
2	22	95	3	RL	36.1	102.6
2	22	95	4	NO	82.6	102.6
2	22	95	5	NO	34.8	102.5
2	22	95	6	NO	45.8	102.2
2	22	95	7	NO	32.4	101.7
2	22	95	8	NO	37.8	101.1
2	22	95	9	NO	35.4	100.8
2	22	95	10	NO	64.5	100.6
2	22	95	11	NO	49.3	100.4
2	22	95	12	NO	55.7	100.4
2	22	95	13	NO	57.2	100.4
2	22	95	14	NO	44.3	100.4
2	22	95	15	NO	42.5	100.4
2	22	95	16	NO	39.5	100.3
2	22	95	17	NO	53.5	100.3
2	22	95	18	NO	92.7	100.4
2	22	95	19	NO	52.4	100.4
2	22	95	20	NO	68.1	100.3
2	22	95	21	NO	57.0	100.2
2	22	95	22	NO	43.2	100.2
2	22	95	23	MF	74.5	100.1
2	23	95	6	RL/PF	125.7	100.2
2	23	95	7	RL/PF	203.3	100.4
2	23	95	9	NO	49.7	100.4
2	23	95	11	NO	50.5	100.4
2	23	95	12	SS	67.8	100.4
2	23	95	17	SS/MF	9.1	100.2
2	23	95	18	RL/PF	58.6	100.1
2	23	95	19	RL/PF	311.9	100.3
2	23	95	20	NO	85.8	100.2
2	23	95	21	NO	108.5	99.9
2	23	95	22	RL	584.9	100.5
2	23	95	23	RL	218.2	100.8
2	24	95	0	RL	129.8	100.9
2	24	95	1	RL	92.5	100.8
2	24	95	2	RL	80.7	100.8
2	24	95	3	RL	189.6	100.9
2	24	95	4	NO	146.5	101.0
2	24	95	5	NO	98.6	101.1
2	24	95	6	NO	80.4	101.1
2	24	95	7	NO	86.1	101.2
2	24	95	8	NO	107.1	101.3
2	24	95	9	NO	88.5	101.4
2	24	95	10	NO	127.4	101.4
2	24	95	11	NO	110.5	101.5
2	24	95	12	NO	110.8	101.7
2	24	95	13	NO	130.2	101.8

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
2	24	95	14	NO	84.0	101.8
2	24	95	15	NO	138.9	101.9
2	24	95	16	NO	147.2	102.0
2	24	95	17	NO	176.7	102.0
2	24	95	18	NO	184.8	102.1
2	24	95	19	NO	54.5	101.8
2	24	95	20	NO	53.9	101.3
2	24	95	21	NO	81.5	100.8
2	24	95	22	NO	77.8	100.3
2	24	95	23	NO	61.8	100.0
2	25	95	0	RL	129.9	100.0
2	25	95	1	RL	116.2	100.0
2	25	95	2	RL	118.9	100.1
2	25	95	3	RL	163.0	100.1
2	25	95	4	RL	171.7	100.2
2	25	95	5	NO	105.9	100.1
2	25	95	6	NO	62.5	100.2
2	25	95	7	NO	75.6	100.2
2	25	95	8	NO	65.5	100.1
2	25	95	9	NO	163.4	100.2
2	25	95	10	NO	87.3	100.1
2	25	95	11	NO	78.1	100.1
2	25	95	12	NO	224.9	100.4
2	25	95	13	NO	145.8	100.5
2	25	95	14	NO	76.6	100.5
2	25	95	15	NO	64.8	100.5
2	25	95	16	NO	64.3	100.5
2	25	95	17	NO	61.5	100.4
2	25	95	18	NO	74.8	100.3
2	25	95	19	NO	54.9	100.2
2	25	95	20	NO	44.2	99.9
2	25	95	21	NO	93.1	99.4
2	25	95	22	NO	113.1	99.1
2	25	95	23	NO	113.8	99.2
2	26	95	0	RL	161.2	99.3
2	26	95	1	RL	189.6	99.4
2	26	95	2	RL	158.1	99.6
2	26	95	3	RL	147.4	99.7
2	26	95	4	RL	157.6	99.9
2	26	95	5	NO	108.4	99.9
2	26	95	6	NO	73.2	99.9
2	26	95	7	NO	70.8	99.9
2	26	95	8	NO	63.0	99.9
2	26	95	9	NO	39.7	99.9
2	26	95	10	NO	55.6	99.8
2	26	95	11	NO	44.7	99.5
2	26	95	12	NO	38.3	99.1
2	26	95	13	NO	57.1	99.0
2	26	95	14	RL	87.0	98.9
2	26	95	15	RL	548.3	99.5
2	26	95	16	RL	423.8	100.0
2	26	95	17	NO	56.6	99.7
2	26	95	18	NO	34.9	99.1
2	26	95	19	NO	50.4	98.5
2	26	95	20	NO	62.3	98.0
2	26	95	21	NO	55.2	97.6
2	26	95	22	NO	52.1	97.4
2	26	95	23	RL	172.0	97.5
2	27	95	0	RL	150.8	97.6
2	27	95	1	RL	314.5	97.9
2	27	95	2	RL	205.3	98.2
2	27	95	3	RL	88.3	98.2
2	27	95	4	RL	200.9	98.4
2	27	95	5	NO	215.0	98.6
2	27	95	6	NO/WO	162.7	98.6
2	27	95	7	NO/WO	94.8	98.6
2	27	95	8	NO/WO	99.3	98.7
2	27	95	9	NO/WO	204.0	98.7
2	27	95	10	NO/WO	66.7	98.7
2	27	95	11	NO/WO	52.8	98.4
2	27	95	12	NO/WO	54.9	98.5
2	27	95	13	NO/WO	50.5	98.5
2	27	95	14	NO/WO	84.1	98.5
2	27	95	15	NO/WO	101.2	98.6
2	27	95	16	NO/WO	43.4	98.6
2	27	95	17	NO/WO	51.7	98.6
2	27	95	18	NO/WO	53.7	98.5
2	27	95	19	NO/WO	65.9	98.5
2	27	95	20	NO/WO	44.1	98.4
2	27	95	21	NO/WO	50.2	98.3
2	27	95	22	NO/WO	92.7	98.2
2	27	95	23	NO/WO	93.1	98.2
2	28	95	0	NO	84.5	98.2

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
2	28	95	1	RL	185.4	98.4
2	28	95	2	NO	144.0	98.5
2	28	95	3	RL	218.1	98.8
2	28	95	4	MF	300.6	99.1
2	28	95	5	NO	238.0	99.4
2	28	95	6	NO/WO	184.2	99.6
2	28	95	7	NO/WO	120.4	99.6
2	28	95	8	MF/WO/PF	379.6	100.1
2	28	95	9	MF/WO/PF	215.5	100.3
2	28	95	10	MF/WO/PF	24.5	100.2
2	28	95	11	MF/WO/PF	7.3	100.0
2	28	95	12	MF/WO/PF	183.2	100.1
2	28	95	13	MF/WO/PF	83.1	100.1
2	28	95	14	MF/WO/PF	262.1	100.4
2	28	95	15	MF/WO/PF	201.2	100.6
2	28	95	16	MF/WO/PF	237.9	100.8
2	28	95	17	MF/WO/PF	215.1	101.0
2	28	95	18	NO/WO	127.3	101.1
2	28	95	19	NO/WO	121.9	101.1
2	28	95	20	NO/WO	91.3	101.0
2	28	95	21	NO/WO	153.9	101.0
2	28	95	22	NO/WO	70.0	101.0
2	28	95	23	NO/WO	63.5	100.9
3	1	95	0	NO	63.6	100.8
3	1	95	1	NO	65.9	100.7
3	1	95	2	NO	84.6	100.7
3	1	95	3	RL	87.5	100.7
3	1	95	4	RL	86.0	100.6
3	1	95	5	NO	47.7	100.6
3	1	95	6	NO	95.2	100.7
3	1	95	7	NO	65.9	100.6
3	1	95	8	NO	63.3	100.5
3	1	95	9	NO	92.8	100.5
3	1	95	10	NO	90.2	100.4
3	1	95	11	NO	106.0	100.5
3	1	95	12	NO	60.5	100.5
3	1	95	13	NO	74.9	100.5
3	1	95	14	NO	53.0	100.5
3	1	95	15	NO	37.5	100.4
3	1	95	16	NO	54.8	100.2
3	1	95	17	NO	57.6	100.1
3	1	95	18	NO	60.7	100.2
3	1	95	19	NO	57.3	99.9
3	1	95	20	NO	56.3	99.7
3	1	95	21	NO	53.7	99.7
3	1	95	22	NO	66.4	99.5
3	1	95	23	NO	83.2	98.8
3	2	95	0	RL	75.6	98.1
3	2	95	1	RL	50.6	97.5
3	2	95	2	RL	54.3	97.1
3	2	95	3	RL	44.7	97.0
3	2	95	4	RL	43.5	96.9
3	2	95	5	NO	38.7	96.8
3	2	95	6	NO	42.1	96.6
3	2	95	7	NO	43.0	96.5
3	2	95	8	NO	47.9	96.4
3	2	95	9	NO	51.2	95.8
3	2	95	10	NO	77.8	95.2
3	2	95	11	NO	101.7	95.0
3	2	95	12	NO	72.3	94.9
3	2	95	13	NO	62.5	94.8
3	2	95	14	NO	58.7	94.7
3	2	95	18	NO	179.2	94.8
3	2	95	19	NO	140.2	94.9
3	2	95	20	NO	58.7	94.8
3	2	95	21	NO	88.9	94.8
3	2	95	22	NO	53.2	94.7
3	2	95	23	RL	62.0	94.4
3	3	95	0	RL	56.9	94.1
3	3	95	1	RL	65.8	93.9
3	3	95	2	RL	70.6	93.9
3	3	95	3	RL	48.4	93.9
3	3	95	4	NO	44.3	93.8
3	3	95	5	NO	43.4	93.8
3	3	95	6	NO	48.5	93.8
3	3	95	7	NO	55.2	93.9
3	3	95	8	NO	63.8	93.9
3	3	95	9	NO	84.5	93.9
3	3	95	10	NO	60.3	93.8
3	3	95	11	NO	51.5	93.5
3	3	95	12	NO	50.2	93.4
3	3	95	13	NO	70.9	93.3
3	3	95	14	NO	66.1	93.3

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
Load Range = 5-100%
All codes except Boiler Offline (BO)
Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
			1hr	720rolling	1hr	720rolling
3	3	95	15	NO	89.5	93.4
3	3	95	16	NO	80.8	93.4
3	3	95	17	NO	120.0	93.5
3	3	95	18	NO	86.8	93.5
3	3	95	19	NO	114.9	93.6
3	3	95	20	NO	125.3	93.7
3	3	95	21	NO	197.9	93.9
3	3	95	22	NO	101.6	93.9
3	3	95	23	RL	83.2	94.0
3	4	95	0	RL	75.1	94.1
3	4	95	1	RL	65.8	94.1
3	4	95	2	RL	72.9	94.1
3	4	95	3	MF	185.8	94.3
3	4	95	7	SS	241.1	94.5
3	4	95	8	NO	60.3	94.6
3	4	95	9	NO	94.8	94.5
3	4	95	10	NO	62.3	94.4
3	4	95	11	NO	80.4	94.3
3	4	95	12	MF	193.4	94.3
3	4	95	13	NO	169.0	94.1
3	4	95	14	NO	52.1	93.8
3	4	95	15	NO	66.3	93.5
3	4	95	16	NO	64.3	93.6
3	4	95	17	NO	55.0	93.7
3	4	95	18	NO	55.4	93.7
3	4	95	19	NO	132.5	93.8
3	4	95	20	NO	81.8	93.9
3	4	95	21	NO	84.2	93.9
3	4	95	22	NO	92.3	93.9
3	4	95	23	NO	81.8	93.9
3	5	95	0	RL	60.5	93.9
3	5	95	1	RL	59.1	93.8
3	5	95	2	RL	56.7	93.8
3	5	95	3	RL	78.0	93.8
3	5	95	4	RL	90.6	93.7
3	5	95	5	NO	51.0	93.7
3	5	95	6	NO	74.0	93.7
3	5	95	7	NO	117.7	93.7
3	5	95	8	NO	137.1	93.7
3	5	95	9	NO	60.0	93.2
3	5	95	10	NO	74.1	93.1
3	5	95	11	NO	59.0	93.1
3	5	95	12	NO	60.8	93.0
3	5	95	13	NO	98.7	92.8
3	5	95	14	NO	115.2	92.8
3	5	95	15	NO	77.3	92.8
3	5	95	16	NO	66.8	92.7
3	5	95	17	NO	67.9	92.6
3	5	95	18	NO	64.6	92.7
3	5	95	19	NO	55.7	92.7
3	5	95	20	NO	59.6	92.6
3	5	95	21	NO	56.9	92.5
3	5	95	22	NO	48.8	92.5
3	5	95	23	RL	101.0	92.6
3	6	95	0	RL	119.0	92.7
3	6	95	1	RL	118.6	92.7
3	6	95	2	RL	124.7	92.7
3	6	95	3	RL	113.1	92.7
3	6	95	4	RL	99.6	92.6
3	6	95	5	NO	99.0	92.7
3	6	95	6	NO	68.8	92.7
3	6	95	7	NO	53.6	92.7
3	6	95	8	NO	90.8	92.7
3	6	95	9	NO	47.1	92.6
3	6	95	10	NO	64.9	92.4
3	6	95	11	NO	60.1	92.3
3	6	95	12	RL/WO	208.6	92.4
3	6	95	13	RL/WO	187.6	92.3
3	6	95	14	RL/WO	160.7	92.1
3	6	95	15	RL/WO	397.4	92.5
3	6	95	16	RL/WO/PF	113.0	92.0
3	6	95	17	NO/WO/PF	20.7	91.3
3	6	95	18	NO/WO/PF	24.5	90.7
3	6	95	19	NO/WO/PF	128.3	90.8
3	6	95	20	RL/WO/PF	554.6	91.1
3	6	95	21	RL/WO/PF	532.9	91.7
3	6	95	22	NO/WO/PF	269.0	92.0
3	6	95	23	RL	77.6	92.0
3	7	95	0	RL	83.8	92.0
3	7	95	1	RL	108.3	92.1
3	7	95	2	RL	93.5	92.1
3	7	95	3	RL	109.7	92.1
3	7	95	4	RL	252.0	92.3

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time		Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval					1hr	720rolling	1hr	720rolling
3	7	95	5	NO			71.2	92.4
3	7	95	6	NO			62.8	92.2
3	7	95	7	NO			63.6	92.1
3	7	95	8	NO			77.1	92.1
3	7	95	9	NO			69.8	92.2
3	7	95	10	NO			46.8	92.2
3	7	95	11	NO			52.0	92.2
3	7	95	12	NO			137.3	92.3
3	7	95	13	NO			185.9	92.6
3	7	95	14	NO			103.1	92.6
3	7	95	15	MF			166.5	92.7
3	7	95	16	MF			140.7	92.8
3	7	95	17	NO			76.7	92.7
3	7	95	18	NO			90.3	92.7
3	7	95	19	NO			54.1	92.7
3	7	95	20	NO			44.0	92.7
3	7	95	21	NO			68.3	92.7
3	7	95	22	NO			51.7	92.7
3	7	95	23	NO			185.8	92.8
3	8	95	0	RL			131.4	92.8
3	8	95	1	RL			101.1	92.6
3	8	95	2	RL			108.0	92.4
3	8	95	3	RL			87.5	92.3
3	8	95	4	RL			101.4	92.3
3	8	95	5	NO			74.8	92.1
3	8	95	6	NO			101.9	92.2
3	8	95	7	NO			51.8	92.2
3	8	95	8	NO			47.7	92.2
3	8	95	9	NO			62.7	92.3
3	8	95	10	NO			75.9	92.3
3	8	95	11	NO			58.6	92.3
3	8	95	12	NO			70.6	92.4
3	8	95	13	NO			58.8	92.4
3	8	95	14	NO			54.5	92.4
3	8	95	15	NO			51.9	92.4
3	8	95	16	NO			44.0	92.4
3	8	95	17	NO			80.5	92.5
3	8	95	18	NO			83.3	92.5
3	8	95	19	NO			71.2	92.5
3	8	95	20	NO			54.9	92.5
3	8	95	21	NO			51.9	92.5
3	8	95	22	NO			51.6	92.5
3	8	95	23	RL			61.9	92.5
3	9	95	0	RL			65.2	92.4
3	9	95	1	RL			299.1	92.5
3	9	95	2	RL			281.8	92.8
3	9	95	3	RL			154.4	92.9
3	9	95	4	NO			91.1	92.9
3	9	95	5	NO			77.0	92.9
3	9	95	6	NO			54.3	92.9
3	9	95	7	NO			51.0	92.9
3	9	95	8	NO			54.2	92.9
3	9	95	9	NO			51.8	92.9
3	9	95	10	NO			52.3	92.9
3	9	95	11	NO			52.1	92.8
3	9	95	12	NO			53.5	92.8
3	9	95	13	NO			79.5	92.9
3	9	95	14	NO			42.7	92.9
3	9	95	15	NO			41.6	92.9
3	9	95	16	NO			41.6	92.9
3	9	95	17	NO			46.6	92.9
3	9	95	18	NO			54.6	92.9
3	9	95	19	NO			53.5	92.9
3	9	95	20	NO			76.6	92.9
3	9	95	21	NO			70.7	92.9
3	9	95	22	NO			95.6	93.0
3	9	95	23	RL/PF			377.7	93.4
3	10	95	0	RL/PF			314.4	93.8
3	10	95	1	RL/PF			286.7	94.1
3	10	95	2	RL			133.8	94.1
3	10	95	3	RL			499.6	94.8
3	10	95	4	NO			133.2	94.9
3	10	95	5	NO			40.6	94.7
3	10	95	6	NO			40.7	94.7
3	10	95	7	NO			45.6	94.7
3	10	95	8	NO/PF			143.2	94.8
3	10	95	9	NO/PF			83.0	94.9
3	10	95	10	NO			72.1	94.9
3	10	95	11	NO			55.1	94.9
3	10	95	12	NO			55.2	94.9
3	10	95	13	NO			66.4	95.0
3	10	95	14	NO			67.6	95.0
3	10	95	15	NO			64.8	95.0

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO	
			1hr	720rolling	1hr	720rolling	
3	10	95	16			67.6	95.0
3	10	95	17			63.1	95.0
3	10	95	18			65.9	95.0
3	10	95	19			53.0	95.0
3	10	95	20			58.3	95.0
3	10	95	21			68.6	95.0
3	10	95	22			71.3	95.0
3	10	95	23			132.6	95.1
3	11	95	0			131.9	95.2
3	11	95	1			195.1	95.4
3	11	95	2			266.0	95.8
3	11	95	3			197.8	96.0
3	11	95	4			120.8	96.0
3	11	95	5			72.9	96.0
3	11	95	6			67.7	96.0
3	11	95	7			77.3	96.1
3	11	95	8			54.6	96.1
3	11	95	9			51.8	96.1
3	11	95	10	MF/BO		422.8	96.6
3	11	95	11	SS		73.8	96.6
3	11	95	12	NO		41.6	96.7
3	11	95	13	NO		41.6	96.7
3	11	95	14	NO		35.2	96.7
3	11	95	15	NO		42.7	96.7
3	11	95	16	NO		44.3	96.7
3	11	95	17	NO		42.2	96.7
3	11	95	18	NO		50.9	96.7
3	11	95	19	NO		53.0	96.6
3	11	95	20	NO		74.7	96.5
3	11	95	21	NO		77.1	96.4
3	11	95	22	MF		212.3	96.6
3	11	95	23	RL		331.0	96.6
3	12	95	0	RL		100.4	96.6
3	12	95	1	RL		162.3	96.7
3	12	95	2	RL		337.0	96.9
3	12	95	3	RL		396.5	97.3
3	12	95	4	NO		82.7	97.4
3	12	95	5	NO		57.2	97.4
3	12	95	6	NO		62.9	97.4
3	12	95	7	NO		52.5	97.4
3	12	95	8	NO		57.1	97.4
3	12	95	9	NO		56.0	97.4
3	12	95	10	NO		50.2	97.4
3	12	95	11	NO		56.1	97.4
3	12	95	12	NO		64.8	97.4
3	12	95	13	NO		63.8	97.4
3	12	95	14	NO		59.5	97.4
3	12	95	15	NO		62.9	97.5
3	12	95	16	NO		65.6	97.5
3	12	95	17	NO		69.6	97.5
3	12	95	18	NO		75.2	97.5
3	12	95	19	NO		65.0	97.5
3	12	95	20	NO		57.5	97.5
3	12	95	21	NO		54.0	97.4
3	12	95	22	NO		64.4	97.4
3	12	95	23	RL		379.0	97.9
3	13	95	0	RL		271.7	98.2
3	13	95	1	RL		98.5	98.2
3	13	95	2	RL		141.8	98.3
3	13	95	3	RL		124.0	98.4
3	13	95	4	RL		246.7	98.6
3	13	95	5	RL		104.6	98.7
3	13	95	6	NO		45.5	98.5
3	13	95	7	NO		52.6	98.4
3	13	95	8	NO		51.3	98.0
3	13	95	9	NO		55.2	98.0
3	13	95	10	NO		79.0	98.1
3	13	95	11	NO		68.6	98.1
3	13	95	12	NO		62.8	98.1
3	13	95	13	NO		78.8	98.2
3	13	95	14	NO		82.0	98.2
3	13	95	15	RL		116.9	98.1
3	13	95	16	RL		71.6	97.8
3	13	95	17	RL		35.6	97.8
3	13	95	18	NO		43.8	97.7
3	13	95	19	NO		76.5	97.6
3	13	95	20	NO		78.8	97.5
3	13	95	21	RL		91.7	97.5
3	13	95	22	NO		69.1	97.4
3	13	95	23	NO		67.6	97.4
3	14	95	0	RL		65.6	97.4
3	14	95	1	RL		74.9	97.4
3	14	95	2	RL		109.3	97.0

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
			1hr	720rolling	1hr	720rolling
3	14	95	3	RL	98.7	96.5
3	14	95	4	RL	69.2	96.4
3	14	95	5	RL	46.4	95.9
3	14	95	6	NO	51.1	95.7
3	14	95	7	NO	56.4	95.6
3	14	95	8	NO	61.1	95.6
3	14	95	9	NO	49.1	95.4
3	14	95	10	NO	60.9	95.3
3	14	95	11	NO	59.4	95.3
3	14	95	12	NO	55.8	95.3
3	14	95	13	NO	51.9	95.3
3	14	95	14	NO	51.6	95.3
3	14	95	15	NO	54.0	95.3
3	14	95	16	NO	48.7	95.2
3	14	95	17	NO	41.5	95.2
3	14	95	18	NO	46.9	95.1
3	14	95	19	NO	44.8	95.0
3	14	95	20	NO	50.9	94.7
3	14	95	21	NO	50.1	94.4
3	14	95	22	NO	47.5	94.1
3	14	95	23	RL	60.3	93.7
3	15	95	0	RL	84.3	93.7
3	15	95	1	RL	254.3	94.1
3	15	95	2	RL	354.8	94.5
3	15	95	3	RL	88.9	94.7
3	15	95	4	RL	47.8	94.7
3	15	95	5	RL	73.1	94.6
3	15	95	6	NO	99.8	94.6
3	15	95	7	NO	48.1	94.4
3	15	95	8	NO	52.7	93.9
3	15	95	9	NO	55.1	93.8
3	15	95	10	RL	63.8	93.8
3	15	95	11	RL	53.2	93.8
3	15	95	12	NO	52.2	93.7
3	15	95	13	NO	45.6	93.4
3	15	95	14	NO	39.9	93.2
3	15	95	15	NO	39.9	93.1
3	15	95	16	RL	63.9	93.1
3	15	95	17	NO	52.9	93.1
3	15	95	18	NO	46.8	93.1
3	15	95	19	NO	58.6	93.1
3	15	95	20	NO	58.6	93.0
3	15	95	21	NO	108.7	93.0
3	15	95	22	NO	86.1	93.0
3	15	95	23	NO	99.8	93.0
3	16	95	0	RL	295.3	93.3
3	16	95	1	RL	144.9	93.4
3	16	95	2	RL	185.3	93.3
3	16	95	3	RL	99.0	92.6
3	16	95	4	RL	96.1	92.4
3	16	95	5	NO	99.4	92.4
3	16	95	6	NO	101.3	92.4
3	16	95	7	NO	62.1	92.4
3	16	95	8	NO	46.4	92.4
3	16	95	9	NO	39.6	92.3
3	16	95	10	NO	111.6	92.4
3	16	95	11	NO	50.9	92.5
3	16	95	12	NO	43.5	92.5
3	16	95	13	NO	59.0	92.5
3	16	95	14	NO	79.8	92.6
3	16	95	15	NO	38.9	92.6
3	16	95	16	NO/WO	37.0	92.5
3	16	95	17	NO/WO	37.3	92.4
3	16	95	18	NO/WO	50.6	92.4
3	16	95	19	NO	70.0	92.4
3	16	95	20	NO	50.4	92.4
3	16	95	21	NO	55.6	92.3
3	16	95	22	NO	42.8	92.3
3	16	95	23	NO	45.5	92.3
3	17	95	0	RL	49.8	92.2
3	17	95	1	RL	56.2	92.0
3	17	95	2	RL	56.0	92.0
3	17	95	3	RL	80.2	92.0
3	17	95	4	RL	66.8	91.9
3	17	95	5	NO	48.1	91.7
3	17	95	6	NO	43.6	91.6
3	17	95	7	NO	48.3	91.5
3	17	95	8	NO	40.8	91.4
3	17	95	9	NO	46.2	91.3
3	17	95	10	NO	46.1	91.3
3	17	95	11	NO	44.6	91.3
3	17	95	12	NO	45.8	91.3
3	17	95	13	NO	58.2	91.3

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
3	17	95	14	NO		131.7	91.4
3	17	95	15	NO		52.2	91.4
3	17	95	16	NO		51.8	91.4
3	17	95	17	NO		100.8	91.4
3	17	95	18	NO		59.2	91.4
3	17	95	19	NO		46.6	91.4
3	17	95	20	NO		53.0	91.4
3	17	95	21	NO		51.8	91.4
3	17	95	22	NO		47.5	91.3
3	17	95	23	RL		61.0	91.3
3	18	95	0	RL		66.4	91.3
3	18	95	1	RL		72.4	91.3
3	18	95	2	RL		68.6	91.3
3	18	95	3	RL		94.7	91.3
3	18	95	4	RL		51.1	91.3
3	18	95	5	NO		38.3	91.3
3	18	95	6	NO		47.5	91.2
3	18	95	7	NO		45.8	91.2
3	18	95	8	NO		60.1	91.2
3	18	95	9	NO		54.0	91.2
3	18	95	10	NO		50.6	91.2
3	18	95	11	NO		56.2	91.2
3	18	95	12	NO		69.5	91.2
3	18	95	13	NO		75.5	91.2
3	18	95	14	NO		168.7	91.4
3	18	95	15	MF		209.1	91.5
3	18	95	16	MF		277.5	91.6
3	18	95	17	NO		83.8	91.6
3	18	95	18	NO		116.6	91.6
3	18	95	19	NO		50.2	91.6
3	18	95	20	NO		46.6	91.6
3	18	95	21	NO		53.6	91.5
3	18	95	22	NO		48.5	91.5
3	18	95	23	RL		89.6	91.5
3	19	95	0	RL		93.0	91.6
3	19	95	1	RL		76.2	91.3
3	19	95	2	RL		75.4	91.3
3	19	95	3	SS		97.2	91.3
3	19	95	15	SS		449.7	91.9
3	19	95	16	NO		62.7	91.8
3	19	95	17	NO		53.2	91.7
3	19	95	18	NO		129.7	91.8
3	19	95	19	NO		66.9	91.8
3	19	95	20	NO		55.5	91.8
3	19	95	21	NO		63.9	91.8
3	19	95	22	NO		63.4	91.8
3	19	95	23	NO		71.0	91.9
3	20	95	0	RL		71.2	91.9
3	20	95	1	RL		86.9	92.0
3	20	95	2	RL		73.3	92.0
3	20	95	3	RL		88.1	92.1
3	20	95	4	RL		66.0	92.1
3	20	95	5	NO		61.4	92.1
3	20	95	6	NO		92.5	92.0
3	20	95	7	NO		50.9	92.0
3	20	95	8	NO		70.3	92.1
3	20	95	9	NO		75.5	92.1
3	20	95	10	NO		85.6	92.2
3	20	95	11	NO		99.1	92.2
3	20	95	12	NO		118.4	92.4
3	20	95	13	NO		55.2	92.4
3	20	95	14	NO		59.9	92.4
3	20	95	15	NO		63.1	92.5
3	20	95	16	NO		87.0	92.6
3	20	95	17	NO		67.8	92.6
3	20	95	18	NO		62.4	92.7
3	20	95	19	NO		64.9	92.7
3	20	95	20	NO		77.6	92.8
3	20	95	21	NO		155.6	92.9
3	20	95	22	RL		572.6	93.7
3	20	95	23	RL		456.6	94.2
3	21	95	0	RL		153.2	94.4
3	21	95	1	RL		173.9	94.5
3	21	95	2	RL		101.7	94.6
3	21	95	3	RL		170.8	94.7
3	21	95	4	RL		228.7	95.0
3	21	95	5	RL		293.3	95.4
3	21	95	6	NO		48.9	95.4
3	21	95	7	NO		60.4	95.3
3	21	95	8	NO		50.6	95.2
3	21	95	9	NO		62.5	95.2
3	21	95	10	NO		92.5	95.3
3	21	95	11	NO		75.0	95.4

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
Averaging Interval			1hr	720rolling	1hr	720rolling
3	21	95	12		67.9	95.4
3	21	95	13		91.7	95.3
3	21	95	14		86.9	95.2
3	21	95	15		88.1	95.0
3	21	95	16		118.6	95.1
3	21	95	17		99.9	95.0
3	21	95	18		95.1	95.0
3	21	95	19		98.3	94.6
3	21	95	20		87.2	93.9
3	21	95	21		84.4	93.6
3	21	95	22		104.8	93.3
3	21	95	23		104.5	93.3
3	22	95	0		94.1	93.1
3	22	95	1		92.5	92.5
3	22	95	2		77.9	92.1
3	22	95	3		67.7	92.2
3	22	95	4		77.3	92.2
3	22	95	5		63.8	92.3
3	22	95	6		92.1	92.2
3	22	95	7		104.0	92.3
3	22	95	8		95.1	92.3
3	22	95	9		127.7	92.5
3	22	95	10		77.7	92.5
3	22	95	11		96.7	92.6
3	22	95	12		119.7	92.7
3	22	95	13		104.0	92.7
3	22	95	14		86.6	92.8
3	22	95	15		93.7	92.8
3	22	95	16		82.6	92.7
3	22	95	17		89.1	92.7
3	22	95	18		70.7	92.8
3	22	95	19		65.1	92.8
3	22	95	20		69.5	92.9
3	22	95	21		298.3	93.2
3	22	95	22		296.3	93.6
3	22	95	23		114.2	93.7
3	23	95	0		103.5	93.8
3	23	95	1		182.3	94.0
3	23	95	2		161.0	94.2
3	23	95	3		107.2	94.3
3	23	95	4		88.2	94.4
3	23	95	5		78.1	94.5
3	23	95	6		141.9	94.6
3	23	95	7		175.5	94.8
3	23	95	8		86.3	94.9
3	23	95	9		114.5	95.0
3	23	95	10		82.3	95.1
3	23	95	11		87.1	95.1
3	23	95	12		100.0	95.2
3	23	95	13		53.3	95.2
3	23	95	14		51.2	95.2
3	23	95	15		109.1	95.3
3	23	95	16		82.3	95.4
3	23	95	17		237.2	95.7
3	23	95	18		118.4	95.8
3	23	95	19		191.9	96.1
3	23	95	20		288.4	96.4
3	23	95	21		128.4	96.6
3	23	95	22		160.2	96.8
3	23	95	23		226.3	97.0
3	24	95	0		76.1	97.1
3	24	95	1		85.4	97.2
3	24	95	2		180.8	97.4
3	24	95	3		177.1	97.6
3	24	95	4		80.5	97.7
3	24	95	5		71.7	97.8
3	24	95	6		71.4	97.8
3	24	95	7		52.1	97.9
3	24	95	8		69.8	97.7
3	24	95	9		50.4	97.7
3	24	95	10		81.7	97.7
3	24	95	11		40.7	97.7
3	24	95	12		88.4	97.6
3	24	95	15		3.5	97.4
3	24	95	16		2.6	97.3
3	24	95	17		41.4	97.3
3	24	95	18		193.9	97.6
3	24	95	19		58.7	97.6
3	24	95	20		55.6	97.7
3	24	95	21		54.0	97.6
3	24	95	22		57.5	97.6
3	24	95	23		85.2	97.5
3	25	95	0		170.5	97.7

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO
			1hr	720rolling	1hr	720rolling
3 25 95	1	RL			233.8	98.0
3 25 95	2	RL			133.1	98.2
3 25 95	3	RL			99.8	98.3
3 25 95	4	RL			91.8	98.4
3 25 95	5	NO			93.0	98.4
3 25 95	6	NO			51.2	98.3
3 25 95	7	NO			66.6	98.2
3 25 95	8	NO			121.8	98.3
3 25 95	9	NO			55.5	98.4
3 25 95	10	NO			54.5	98.4
3 25 95	11	NO			54.7	98.4
3 25 95	12	NO			48.8	98.4
3 25 95	13	NO			49.7	98.4
3 25 95	14	NO			82.6	98.5
3 25 95	15	NO			68.8	98.5
3 25 95	16	NO			69.7	98.5
3 25 95	17	NO			54.1	98.5
3 25 95	18	NO			66.3	98.6
3 25 95	19	NO			58.7	98.6
3 25 95	20	NO			52.2	98.5
3 25 95	21	NO			51.7	98.6
3 25 95	22	NO			48.0	98.6
3 25 95	23	RL			89.7	98.6
3 26 95	0	RL			141.9	98.8
3 26 95	1	RL			139.9	98.8
3 26 95	2	RL			163.8	99.0
3 26 95	3	RL			94.5	99.0
3 26 95	4	NO			76.7	99.0
3 26 95	5	NO			63.2	99.1
3 26 95	6	NO			54.5	99.0
3 26 95	7	NO			92.1	99.0
3 26 95	8	NO			45.5	98.8
3 26 95	9	NO			90.0	98.8
3 26 95	10	NO			78.4	98.9
3 26 95	11	NO			60.0	98.9
3 26 95	12	NO			45.2	98.9
3 26 95	13	NO			57.0	98.9
3 26 95	14	NO			91.8	98.6
3 26 95	15	NO			81.4	98.6
3 26 95	16	NO			68.6	98.5
3 26 95	17	NO			109.2	97.9
3 26 95	18	NO			138.3	97.8
3 26 95	19	NO			95.9	97.7
3 26 95	20	NO			56.1	97.7
3 26 95	21	NO			64.2	97.7
3 26 95	22	NO			83.9	97.5
3 26 95	23	RL			124.2	97.5
3 27 95	0	RL			239.6	97.7
3 27 95	1	RL			232.3	97.9
3 27 95	2	RL			71.7	97.9
3 27 95	3	RL			85.1	97.8
3 27 95	4	RL			117.8	97.9
3 27 95	5	NO			101.6	97.8
3 27 95	6	NO			63.8	97.8
3 27 95	7	NO			63.7	97.7
3 27 95	8	NO			49.7	97.6
3 27 95	9	NO			89.0	97.6
3 27 95	10	NO			96.0	97.5
3 27 95	11	NO			148.5	97.5
3 27 95	12	NO			68.4	97.4
3 27 95	13	NO			83.2	97.2
3 27 95	14	RL			66.0	97.3
3 27 95	15	RL			74.7	97.3
3 27 95	16	NO			60.0	97.3
3 27 95	17	NO			50.6	97.2
3 27 95	18	NO			99.0	97.3
3 27 95	19	NO			113.4	97.3
3 27 95	20	NO			75.0	97.2
3 27 95	21	NO			92.6	97.2
3 27 95	22	NO			80.1	97.0
3 27 95	23	RL			313.6	97.2
3 28 95	0	RL			34.2	97.1
3 28 95	1	RL			213.5	97.4
3 28 95	2	RL			475.8	97.9
3 28 95	3	RL			386.0	98.4
3 28 95	4	RL			300.1	98.5
3 28 95	5	NO			78.6	98.5
3 28 95	6	NO			102.5	98.6
3 28 95	7	NO			79.6	98.4
3 28 95	8	NO			69.1	98.3
3 28 95	9	NO			126.1	98.3
3 28 95	10	NO			67.3	98.3
3 28 95	11	MF/PF			221.2	98.5

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time		Operating Codes	#/hr	#/hr	CO	CO
Averaging	Interval	Interval	Interval				#/hr	#/hr
					1hr	720rolling	1hr	720rolling
3	28	95	12	MF/PF			158.3	98.7
3	28	95	13	MF/PF			224.9	98.9
3	28	95	14	NO			263.6	99.2
3	28	95	15	NO			169.1	99.4
3	28	95	16	NO			60.1	99.3
3	28	95	17	NO			48.4	99.2
3	28	95	18	NO			50.2	99.1
3	28	95	19	NO			69.1	99.0
3	28	95	20	NO			140.5	98.9
3	28	95	21	NO			164.1	98.9
3	28	95	22	NO			146.3	98.9
3	28	95	23	NO			88.0	98.8
3	29	95	0	RL			75.9	98.8
3	29	95	1	RL			89.1	98.8
3	29	95	2	MF			207.5	99.0
3	29	95	3	MF			372.6	99.4
3	29	95	4	RL			248.1	99.7
3	29	95	5	NO			119.5	99.8
3	29	95	6	NO			132.3	99.9
3	29	95	7	NO			258.6	100.2
3	29	95	8	NO			447.2	100.8
3	29	95	9	NO			266.3	101.0
3	29	95	10	NO			327.7	100.7
3	29	95	11	NO			157.1	100.4
3	29	95	12	MF/PF			130.7	100.5
3	29	95	13	MF/PF			308.3	100.8
3	29	95	14	MF/PF			250.2	101.1
3	29	95	15	MF/PF			146.2	101.2
3	29	95	16	RL			48.2	101.2
3	29	95	17	NO			67.3	101.2
3	29	95	18	NO			104.6	101.2
3	29	95	19	NO			276.6	101.3
3	29	95	20	NO			218.9	101.2
3	29	95	21	NO			196.0	101.2
3	29	95	22	NO			163.7	101.3
3	29	95	23	NO			82.1	101.1
3	30	95	0	RL			176.4	101.1
3	30	95	1	RL			184.3	101.1
3	30	95	2	RL			255.6	101.3
3	30	95	3	RL			388.9	101.7
3	30	95	4	NO			184.6	101.7
3	30	95	5	NO			135.0	101.8
3	30	95	6	RL			203.9	102.0
3	30	95	7	NO			169.5	102.2
3	30	95	8	NO			81.4	102.2
3	30	95	9	NO			216.1	102.4
3	30	95	10	NO			279.4	102.6
3	30	95	11	NO			200.7	102.9
3	30	95	12	NO			96.3	102.9
3	30	95	13	NO			81.4	103.0
3	30	95	14	NO			58.3	102.9
3	30	95	15	NO			163.4	103.1
3	30	95	16	NO			204.2	103.3
3	30	95	17	NO			63.4	103.3
3	30	95	18	NO			75.3	103.3
3	30	95	19	NO			109.5	103.3
3	30	95	20	NO			127.4	103.2
3	30	95	21	MF/PF			72.2	103.1
3	30	95	22	MF/PF			10.7	102.8
3	30	95	23	MF/PF			48.9	102.5
3	31	95	0	RL			61.4	102.2
3	31	95	1	RL			69.7	102.1
3	31	95	2	RL			75.9	102.0
3	31	95	3	RL			107.9	101.6
3	31	95	4	RL			124.4	101.5
3	31	95	5	NO			113.3	101.6
3	31	95	6	NO			48.7	101.7
3	31	95	7	NO			64.3	101.5
3	31	95	8	NO			174.1	101.6
3	31	95	9	NO			52.1	101.4
3	31	95	10	NO			74.0	101.2
3	31	95	11	NO			82.7	101.0
3	31	95	12	NO			47.2	100.7
3	31	95	13	NO			110.3	100.7
3	31	95	14	NO			38.6	100.6
3	31	95	15	NO			40.5	100.5
3	31	95	16	NO			55.8	100.4
3	31	95	17	NO			84.2	100.4
3	31	95	18	NO			48.8	100.4
3	31	95	19	NO			77.2	100.4
3	31	95	20	NO			114.4	100.5
3	31	95	21	NO			282.7	100.7
3	31	95	22	NO			100.3	100.8

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr		CO #/hr	
			1hr	720rolling	1hr	720rolling
3	31	95	23		65.7	100.7
4	1	95	0		168.0	100.9
4	1	95	1		308.2	101.2
4	1	95	2		216.2	101.4
4	1	95	3		289.5	101.7
4	1	95	4		100.0	101.7
4	1	95	5		114.2	101.8
4	1	95	6		204.0	101.9
4	1	95	7		297.5	102.2
4	1	95	8		74.3	102.2
4	1	95	9		67.1	102.2
4	1	95	10		58.4	102.3
4	1	95	11		53.2	102.3
4	1	95	12		129.2	102.4
4	1	95	13		271.1	102.7
4	1	95	14		53.3	102.7
4	1	95	15		65.5	102.7
4	1	95	16		59.4	102.7
4	1	95	17		62.8	102.7
4	1	95	18		74.2	102.7
4	1	95	19		75.0	102.7
4	1	95	20		50.4	102.7
4	1	95	21		66.8	102.7
4	1	95	22		244.5	103.0
4	1	95	23		174.4	103.1
4	9	95	19		27.4	103.1
4	9	95	20		129.8	103.2
4	9	95	21		32.0	103.2
4	9	95	22		56.3	103.2
4	9	95	23		39.3	103.2
4	10	95	0		12.1	103.1
4	10	95	1		38.1	103.0
4	10	95	2		54.4	103.0
4	10	95	3		204.8	103.2
4	10	95	4		106.8	103.3
4	10	95	5		105.1	103.2
4	10	95	6		78.7	103.1
4	10	95	7		88.3	103.1
4	10	95	12		33.7	103.1
4	10	95	13		34.4	103.0
4	10	95	14		33.4	103.0
4	10	95	15		43.6	103.0
4	10	95	16		29.4	102.9
4	10	95	17		42.0	102.9
4	10	95	18		69.3	102.9
4	10	95	19		46.5	102.9
4	10	95	20		46.1	102.9
4	10	95	21		27.5	102.9
4	10	95	22		96.4	103.0
4	10	95	23		226.4	103.2
4	11	95	0		175.5	103.3
4	11	95	1		254.4	103.6
4	11	95	2		252.7	103.9
4	11	95	3		197.2	104.1
4	11	95	4		210.1	104.3
4	11	95	5		212.1	104.5
4	11	95	6		158.7	104.5
4	11	95	7		112.0	104.6
4	11	95	8		23.2	104.5
4	11	95	13		73.5	104.4
4	11	95	15		39.7	104.3
4	11	95	16		36.8	104.2
4	11	95	17		40.6	104.0
4	11	95	18		31.7	103.9
4	11	95	19		44.5	103.8
4	11	95	20		25.0	103.8
4	11	95	21		29.0	103.7
4	11	95	22		152.2	103.8
4	11	95	23		236.4	103.9
4	12	95	0		89.5	103.7
4	12	95	1		56.8	103.7
4	12	95	2		73.7	103.7
4	12	95	3		44.9	103.6
4	12	95	4		59.3	103.6
4	12	95	5		61.8	103.4
4	12	95	6		77.7	103.3
4	12	95	9		28.1	103.3
4	12	95	10		34.8	103.2
4	12	95	11		61.8	103.2
4	12	95	12		91.7	103.3
4	12	95	13		27.0	103.2
4	12	95	14		33.0	103.1
4	12	95	15		26.1	103.0

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval				1hr	720rolling	1hr	720rolling
4	12	95	16	NO		32.8	102.9
4	12	95	17	NO		28.7	102.9
4	12	95	18	NO		27.5	102.8
4	12	95	19	NO		22.8	102.7
4	12	95	20	NO		70.6	102.7
4	12	95	21	NO		66.0	102.8
4	12	95	22	RL		255.1	103.0
4	12	95	23	RL		120.2	103.0
4	13	95	0	RL		176.1	103.2
4	13	95	1	RL		110.7	103.3
4	13	95	2	RL		90.2	103.2
4	13	95	3	RL		95.4	103.2
4	13	95	4	RL		164.6	103.3
4	13	95	11	RL		54.7	103.3
4	13	95	12	MF		111.9	103.4
4	13	95	16	SS		7.6	103.3
4	13	95	17	RL		248.9	103.5
4	13	95	18	RL		76.2	103.4
4	13	95	19	NO		44.6	103.4
4	13	95	20	NO		29.4	103.3
4	13	95	21	MF		68.8	103.3
4	13	95	22	NO		32.5	103.3
4	13	95	23	RL		34.9	103.3
4	14	95	0	RL		38.0	103.2
4	14	95	1	MF/PF		151.0	103.4
4	14	95	2	MF/PF		97.2	103.4
4	14	95	3	RL		89.3	103.4
4	14	95	4	RL		151.4	103.5
4	14	95	5	RL		82.6	103.4
4	14	95	6	RL		74.0	103.3
4	14	95	7	RL		48.7	103.3
4	14	95	8	RL		43.8	103.2
4	14	95	9	RL		39.4	103.1
4	14	95	10	NO		29.6	103.0
4	14	95	11	NO		32.9	103.0
4	14	95	12	MF		209.7	103.2
4	14	95	13	NO		98.5	103.3
4	14	95	14	NO		45.0	103.2
4	14	95	15	NO		40.6	103.2
4	14	95	16	NO		45.5	103.0
4	14	95	17	NO		46.4	102.8
4	14	95	18	NO		52.0	102.6
4	14	95	19	NO		54.4	102.1
4	14	95	20	NO		59.4	102.1
4	14	95	21	NO		55.5	102.1
4	14	95	22	NO		50.9	102.2
4	14	95	23	RL		88.5	102.1
4	15	95	0	RL		238.5	101.7
4	15	95	1	RL		213.8	101.2
4	15	95	2	RL		170.1	101.1
4	15	95	3	RL		64.9	101.1
4	15	95	4	RL		67.9	101.0
4	15	95	5	RL		151.5	101.1
4	15	95	6	RL		153.6	101.2
4	15	95	7	RL		70.2	101.1
4	15	95	8	RL		145.6	101.0
4	15	95	9	RL		182.3	101.1
4	15	95	10	RL		41.4	101.1
4	15	95	11	NO		51.7	101.1
4	15	95	12	NO		37.8	101.0
4	15	95	13	NO		33.5	101.0
4	15	95	14	NO		32.0	101.0
4	15	95	15	MF		158.4	101.1
4	15	95	16	MF		201.8	101.2
4	15	95	17	NO		107.7	101.1
4	15	95	18	NO		57.8	101.0
4	15	95	19	NO		36.0	100.8
4	15	95	20	NO		30.5	100.7
4	15	95	21	NO		34.8	100.6
4	15	95	22	NO		73.5	100.6
4	15	95	23	MF		229.5	100.9
4	16	95	0	SS		266.1	101.2
4	16	95	1	RL		158.8	101.3
4	16	95	2	RL		68.9	101.3
4	16	95	3	RL		76.2	101.2
4	16	95	4	RL		68.5	101.1
4	16	95	5	RL		73.8	101.0
4	16	95	6	RL		67.9	101.0
4	16	95	7	RL		76.8	101.0
4	16	95	8	RL		114.3	101.0
4	16	95	9	RL		52.9	101.0
4	16	95	10	NO		157.0	101.0
4	16	95	11	NO		162.3	101.2

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			1hr	720rolling	1hr	720rolling
4	16	95	12	NO	108.0	101.3
4	16	95	13	NO	71.4	101.3
4	16	95	14	NO	58.9	101.3
4	16	95	15	NO	78.4	101.3
4	16	95	16	NO	48.9	101.3
4	16	95	17	NO	52.1	101.2
4	16	95	18	NO	45.4	101.2
4	16	95	19	MF	169.6	101.4
4	16	95	20	NO	49.8	101.4
4	16	95	21	NO	32.7	101.3
4	16	95	22	RL	51.2	101.3
4	16	95	23	RL	87.9	101.3
4	17	95	0	RL	94.5	101.4
4	17	95	1	RL	83.5	101.4
4	17	95	2	RL	56.3	101.4
4	17	95	3	RL	59.0	101.4
4	17	95	4	RL	60.7	101.4
4	17	95	5	RL	68.7	101.1
4	17	95	6	RL	64.3	100.8
4	17	95	7	RL	70.5	100.7
4	17	95	8	RL	75.6	100.7
4	17	95	9	RL	56.2	100.6
4	17	95	10	NO	85.8	100.7
4	17	95	11	NO	40.0	100.7
4	17	95	12	NO	36.1	100.6
4	17	95	13	NO	57.7	100.6
4	17	95	14	NO	42.3	100.6
4	17	95	15	NO	26.3	100.6
4	17	95	16	NO	61.4	100.6
4	17	95	17	NO	79.9	100.6
4	17	95	18	NO	39.1	100.6
4	17	95	19	NO	40.0	100.6
4	17	95	20	NO	38.4	100.6
4	17	95	21	NO	41.6	100.6
4	17	95	22	NO	50.5	100.6
4	17	95	23	RL	85.6	100.6
4	18	95	0	RL	55.6	100.6
4	18	95	1	RL	65.1	100.6
4	18	95	2	RL	76.3	100.6
4	18	95	3	RL	69.1	100.1
4	18	95	4	RL	62.3	99.8
4	18	95	5	RL	52.4	99.4
4	18	95	6	NO	36.5	99.3
4	18	95	7	NO	26.3	98.7
4	18	95	8	NO	22.2	98.5
4	18	95	9	NO	26.3	98.5
4	18	95	10	NO	28.9	98.5
4	18	95	11	NO	23.1	98.4
4	18	95	12	NO	0.0	98.2
4	18	95	13	NO	11.9	98.1
4	18	95	14	NO	4.4	98.0
4	18	95	15	NO	45.2	98.0
4	18	95	20	NO	43.0	98.0
4	18	95	21	NO	48.2	98.0
4	18	95	22	RL	72.0	98.0
4	18	95	23	RL	66.2	98.0
4	19	95	0	RL	60.8	98.0
4	19	95	1	RL	77.2	98.0
4	19	95	2	RL	65.9	98.0
4	19	95	3	RL	65.5	98.0
4	19	95	4	RL	67.9	98.0
4	19	95	5	RL	52.5	98.0
4	19	95	6	NO	48.5	98.0
4	19	95	7	NO	60.9	97.9
4	19	95	8	NO	208.9	98.0
4	19	95	9	NO	69.9	97.8
4	19	95	11	NO	54.9	97.5
4	19	95	12	NO	38.5	97.3
4	19	95	13	NO	104.0	97.3
4	19	95	14	NO	79.8	97.3
4	19	95	15	NO	36.8	97.2
4	19	95	16	NO	30.9	97.2
4	19	95	17	NO	37.7	97.2
4	19	95	18	NO	72.1	97.2
4	19	95	19	NO	41.5	96.7
4	19	95	20	NO	37.5	96.6
4	19	95	21	NO	38.1	96.6
4	19	95	22	NO	58.0	96.6
4	19	95	23	RL	65.3	96.7
4	20	95	0	RL	76.4	96.7
4	20	95	1	RL	117.3	96.8
4	20	95	2	RL	94.0	96.9
4	20	95	3	RL	217.8	97.1

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging Interval			thr	720rolling	thr	720rolling
4	20	95	4	SS	7.5	97.1
4	20	95	11	SS	249.4	97.3
4	20	95	12	NO	109.5	97.3
4	20	95	13	NO	67.4	97.1
4	20	95	14	NO	44.6	96.7
4	20	95	15	NO	38.8	96.7
4	20	95	16	NO	35.3	96.5
4	20	95	17	NO	37.5	96.1
4	20	95	18	NO	44.1	95.6
4	20	95	19	NO	39.8	95.5
4	20	95	20	NO	48.2	95.5
4	20	95	21	NO	71.0	95.5
4	20	95	22	RL	127.0	95.6
4	20	95	23	RL	89.6	95.7
4	21	95	0	RL	92.0	95.7
4	21	95	1	RL	85.7	95.8
4	21	95	2	RL	129.4	95.9
4	21	95	3	RL	209.2	96.1
4	21	95	4	RL	203.6	96.3
4	21	95	5	RL	92.9	96.3
4	21	95	6	NO	56.6	96.3
4	21	95	7	NO	52.5	96.3
4	21	95	9	NO	50.3	96.3
4	21	95	10	NO	56.2	96.2
4	21	95	11	NO	48.6	96.2
4	21	95	12	NO	41.2	96.2
4	21	95	13	NO	71.3	96.2
4	21	95	16	NO	57.2	96.2
4	21	95	17	NO	52.9	95.7
4	21	95	18	MF	169.7	95.6
4	21	95	19	NO	199.5	95.7
4	21	95	20	NO	66.7	95.6
4	21	95	21	NO	61.1	95.5
4	21	95	22	RL	91.1	95.3
4	21	95	23	RL	76.5	95.3
4	22	95	0	RL	62.5	95.3
4	22	95	1	RL	82.3	95.4
4	22	95	2	RL	92.5	95.4
4	22	95	3	RL	69.7	95.4
4	22	95	4	RL	60.5	95.4
4	22	95	5	RL	126.4	95.5
4	22	95	6	RL	130.1	95.6
4	22	95	7	RL	204.6	95.8
4	22	95	8	MF	198.6	95.9
4	22	95	9	MF	237.4	96.1
4	22	95	11	NO	52.0	96.1
4	22	95	12	NO	91.2	96.1
4	22	95	13	NO	65.9	96.2
4	22	95	14	NO	204.3	96.3
4	22	95	15	NO	41.3	96.3
4	22	95	16	NO	50.1	96.2
4	22	95	17	NO	57.8	96.2
4	22	95	18	NO	53.5	96.2
4	22	95	19	NO	50.3	96.2
4	22	95	20	NO	46.5	96.1
4	22	95	21	NO	51.1	96.1
4	22	95	22	RL	107.6	96.1
4	22	95	23	RL	146.0	96.2
4	23	95	0	RL	116.2	96.3
4	23	95	1	RL	114.2	96.4
4	23	95	2	RL	104.0	96.4
4	23	95	3	RL	130.5	96.5
4	23	95	4	RL	135.6	96.6
4	23	95	5	RL	90.0	96.7
4	23	95	6	RL	146.2	96.8
4	23	95	7	RL	93.6	96.9
4	23	95	8	RL	76.6	96.9
4	23	95	9	RL	92.0	96.9
4	23	95	10	NO	50.3	96.9
4	23	95	11	NO	52.0	96.9
4	23	95	12	NO	46.3	97.0
4	23	95	13	NO	47.7	97.0
4	23	95	14	NO	43.0	97.0
4	23	95	15	NO	48.9	97.0
4	23	95	16	NO	47.0	96.9
4	23	95	17	NO	46.9	96.9
4	23	95	18	NO	60.7	96.9
4	23	95	19	NO	49.9	96.9
4	23	95	20	NO	60.2	96.6
4	23	95	21	NO	82.8	96.3
4	23	95	22	RL	118.6	96.3
4	23	95	23	RL	209.4	96.5
4	24	95	0	RL	155.0	96.6

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100 %
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date	Time	Operating Codes	#/hr	#/hr	CO	CO	
			1hr	720rolling	1hr	720rolling	
4	24	95	1			213.1	96.8
4	24	95	2			171.7	97.0
4	24	95	3			162.2	97.1
4	24	95	4			411.3	97.6
4	24	95	5			405.4	98.1
4	24	95	6			326.2	98.5
4	24	95	9			62.6	98.5
4	24	95	10			63.1	98.5
4	24	95	11			71.4	98.5
4	24	95	12			59.0	98.6
4	24	95	13			89.2	98.6
4	24	95	14			83.7	98.6
4	24	95	15			61.1	98.7
4	24	95	16			111.9	98.7
4	24	95	17			63.7	98.7
4	24	95	18			58.5	98.7
4	24	95	19			50.0	98.6
4	24	95	20			47.0	98.6
4	24	95	21			86.0	98.3
4	24	95	22			135.6	98.3
4	24	95	23			103.8	98.1
4	25	95	0			117.7	98.2
4	25	95	1			94.8	98.2
4	25	95	2			112.2	98.2
4	25	95	3			123.7	98.2
4	25	95	4			142.0	98.3
4	25	95	5			132.5	98.4
4	25	95	6			82.3	98.5
4	25	95	7			66.1	98.4
4	25	95	8			56.0	98.4
4	25	95	9			98.9	98.5
4	25	95	10			79.0	98.5
4	25	95	11			89.7	98.6
4	25	95	12			86.7	98.6
4	25	95	13			97.5	98.7
4	25	95	14			165.0	98.9
4	25	95	15			88.1	98.9
4	25	95	16			71.7	98.9
4	25	95	17			73.0	99.0
4	25	95	18			77.7	99.0
4	25	95	19			60.2	99.0
4	25	95	20			58.7	99.0
4	25	95	21			53.9	99.1
4	25	95	22			65.5	99.1
4	25	95	23			172.9	99.2
4	26	95	0			244.3	99.5
4	26	95	1			75.9	99.5
4	26	95	2			218.2	99.7
4	26	95	3			45.1	99.7
4	26	95	4			45.8	99.7
4	26	95	5			57.9	99.7
4	26	95	6			62.5	99.8
4	26	95	7			48.6	99.8
4	26	95	8			66.4	99.8
4	26	95	10			82.0	99.8
4	26	95	11			46.5	99.8
4	26	95	12			45.9	99.7
4	26	95	13			51.8	99.7
4	26	95	14			51.8	99.7
4	26	95	15			59.7	99.6
4	26	95	16			55.9	99.6
4	26	95	17			56.0	99.7
4	26	95	18			47.7	99.6
4	26	95	19			48.2	99.6
4	26	95	20			48.3	99.6
4	26	95	21			57.3	99.6
4	26	95	22			52.5	99.6
4	26	95	23			90.0	99.6
4	27	95	0			142.1	99.7
4	27	95	1			207.9	99.9
4	27	95	2			120.6	100.0
4	27	95	3			77.7	100.1
4	27	95	4			81.3	100.1
4	27	95	5			82.1	100.1
4	27	95	6			108.4	100.2
4	27	95	7			58.6	100.2
4	27	95	8			40.0	100.2
4	27	95	9			26.7	100.2
4	27	95	10			34.6	100.1
4	27	95	11			38.6	100.1
4	27	95	12			74.8	99.9
4	27	95	13			65.1	99.7
4	27	95	14			161.5	99.6

RIDGE GENERATING STATION: HOURLY EMISSIONS SUMMARY
CARBON MONOXIDE EMISSIONS IN LB/HR

Description of Data Set:
 Load Range = 5-100%
 All codes except Boiler Offline (BO)
 Data gaps deleted for 720 rolling calc.

Date		Time		Operating Codes	#/hr	#/hr	CO #/hr	CO #/hr
Averaging	Interval				1hr	720rolling	1hr	720rolling
4	27	95	15	NO			50.7	99.5
4	27	95	16	NO			76.0	99.5
4	27	95	17	NO			53.2	99.5
4	27	95	18	NO			68.2	99.5
4	27	95	19	NO			57.3	99.5
4	27	95	20	NO			54.1	99.5
4	27	95	21	NO			54.0	99.5
4	27	95	22	NO			70.8	99.4
4	27	95	23	RL			223.9	99.6
4	28	95	0	RL			136.6	99.7
4	28	95	1	RL			136.0	99.8
4	28	95	2	RL			244.6	99.5
4	28	95	3	RL			322.0	99.9
4	28	95	4	RL			171.4	100.0
4	28	95	5	RL			85.8	100.0
4	28	95	6	SS			415.0	100.4
4	30	95	0	SS			77.5	100.5
4	30	95	1	RL			235.2	100.7
4	30	95	2	RL			157.6	100.8
4	30	95	3	RL			107.5	100.9
4	30	95	4	RL			174.6	101.0
4	30	95	5	RL			285.5	101.3
4	30	95	6	RL			116.3	101.4
4	30	95	7	RL			92.8	101.4
4	30	95	8	RL			81.8	101.4
4	30	95	9	NO			81.3	101.4
4	30	95	10	NO			63.2	101.4
4	30	95	11	NO			74.4	101.4
4	30	95	12	NO			64.8	101.4
4	30	95	13	NO			64.4	101.4
4	30	95	14	NO			75.0	101.4
4	30	95	15	NO			82.7	101.4
4	30	95	16	NO			49.5	101.3
4	30	95	17	NO			40.8	101.2
4	30	95	18	NO			38.4	101.2
4	30	95	19	NO			34.8	101.2
4	30	95	20	NO			54.0	101.1
4	30	95	21	MF/PF			243.5	101.4
4	30	95	22	MF/PF			163.5	101.5
4	30	95	23	MF/PF			141.2	101.6

Attachment B

**30 Day Rolling Averages
(30 Operating Day Rolling Averages)**

May 1, 1995 through December 31, 1995

**RIDGE GENERATING STATION: EMISSIONS SUMMARY
 CARBON MONOXIDE EMISSIONS IN LB/HR AVERAGE
 OPERATING DAY AND 30 OPERATING DAY**

Non-operating days deleted from table for April 1995 only (April 2-8, 29)

	CO DAY #/HR	CO 30 day
3/25/95	81.94	
3/26/95	88.18	
3/27/95	105.64	
3/28/95	155.69	
3/29/95	193.24	
3/30/95	149.45	
3/31/95	88.09	
4/1/95	128.71	
4/9/95	72.70	
4/10/95	70.85	
4/11/95	119.26	
4/12/95	63.18	
4/13/95	95.64	
4/14/95	71.85	
4/15/95	107.70	
4/16/95	83.99	
4/17/95	58.92	
4/18/95	43.95	
4/19/95	64.05	
4/20/95	88.69	
4/21/95	93.53	
4/22/95	99.23	
4/23/95	85.94	
4/24/95	135.98	
4/25/95	94.41	
4/26/95	72.10	
4/27/95	84.51	
4/28/95	182.73	
4/30/95	109.69	
5/1/95	118.96	100.29
5/2/95	133.93	102.03
5/3/95	95.76	102.28
5/4/95	114.77	102.58
5/5/95	89.25	100.37
5/6/95	71.48	96.31
5/7/95	74.18	93.80
5/8/95	81.38	93.58
5/9/95	126.54	93.50
5/10/95	95.76	94.27
5/11/95	73.81	94.37
5/12/95	78.20	93.00
5/13/95	113.69	94.69
5/14/95	72.19	93.90
5/15/95	69.74	93.83
5/16/95	89.66	93.23
5/17/95	107.57	94.02
5/18/95	118.41	96.00
5/19/95	190.47	100.89

5/20/95	214.26	105.89
5/21/95	164.59	108.42
5/22/95	102.74	108.73
5/23/95	81.40	108.14
5/24/95	98.25	108.55
5/25/95	125.50	108.20
5/26/95	144.73	109.87
5/27/95	88.92	110.44
5/28/95	99.23	110.93
5/29/95	72.55	107.25
5/30/95	57.30	105.51
5/31/95	114.09	105.34
6/1/95	137.64	105.47
6/2/95	174.75	108.10
6/3/95	110.18	107.95
6/4/95	97.28	108.22
6/5/95	102.65	109.25
6/6/95	54.22	108.59
6/7/95	105.06	109.38
6/8/95		109.38
6/9/95	10.67	105.52
6/10/95	90.10	105.33
6/11/95	136.88	107.43
6/12/95	99.68	108.15
6/13/95	132.70	108.78
6/14/95	157.42	111.62
6/15/95	131.63	113.68
6/16/95	132.93	115.13
6/17/95	118.48	115.49
6/18/95	117.62	115.46
6/19/95	117.25	113.02
6/20/95	119.59	109.87
6/21/95	145.03	109.22
6/22/95	163.66	111.25
6/23/95	9.94	108.86
6/24/95	144.68	110.41
6/25/95	187.43	112.48
6/26/95	153.36	112.76
6/27/95	127.00	114.03
6/28/95	100.71	114.08
6/29/95	100.15	115.00
6/30/95	113.02	116.86
7/1/95	88.92	116.02
7/2/95	105.75	114.96
7/3/95	129.75	113.46
7/4/95	132.84	114.21
7/5/95	136.63	115.52
7/6/95	113.26	115.88
7/7/95	89.65	117.06
7/8/95	111.94	117.29
7/9/95	103.91	120.40
7/10/95	169.81	123.05
7/11/95	139.41	123.14
7/12/95	136.53	124.37
7/13/95	141.79	124.67
7/14/95	111.67	123.15

7/15/95	102.30	122.17
7/16/95	108.98	121.37
7/17/95	161.50	122.80
7/18/95	123.90	123.01
7/19/95	182.19	125.18
7/20/95	146.31	126.07
7/21/95	164.08	126.70
7/22/95	194.67	127.74
7/23/95	141.09	132.11
7/24/95	131.29	131.66
7/25/95	167.85	131.01
7/26/95	165.64	131.42
7/27/95	179.34	133.16
7/28/95	111.80	133.53
7/29/95	117.59	134.11
7/30/95	110.14	134.02
7/31/95	56.17	132.93
8/1/95	66.97	131.63
8/2/95	159.37	132.62
8/3/95	113.61	131.98
8/4/95	88.80	130.39
8/5/95	180.82	132.64
8/6/95	210.13	136.65
8/7/95	191.33	139.30
8/8/95	182.46	141.92
8/9/95	302.20	146.33
8/10/95	91.32	144.73
8/11/95	158.74	145.47
8/12/95	127.31	144.99
8/13/95	145.56	146.12
8/14/95	143.04	147.47
8/15/95	5.15	144.01
8/16/95	139.49	143.28
8/17/95	130.49	143.50
8/18/95	177.46	143.34
8/19/95	129.32	142.78
8/20/95	141.23	142.01
8/21/95	142.12	140.26
8/22/95	139.50	140.21
8/23/95	109.52	139.48
8/24/95	116.70	137.78
8/25/95	104.29	135.73
8/26/95	182.10	135.82
8/27/95	189.41	138.41
8/28/95	193.13	140.93
8/29/95	172.79	143.02
8/30/95	236.82	149.04
8/31/95	104.19	150.28
9/1/95	1.08	145.00
9/2/95	76.02	143.75
9/3/95	100.80	144.15
9/4/95	107.97	141.72
9/5/95	193.98	141.18
9/6/95	152.08	139.88
9/7/95	230.34	141.47
9/8/95	188.03	137.67

9/9/95	147.89	139.55
9/10/95	169.92	139.92
9/11/95	105.66	139.20
9/12/95	190.42	140.70
9/13/95	260.21	144.60
9/14/95	241.68	152.49
9/15/95	194.70	154.33
9/16/95	158.33	155.26
9/17/95	201.57	156.06
9/18/95	167.36	157.33
9/19/95	102.60	156.04
9/20/95	157.87	156.56
9/21/95	68.58	154.20
9/22/95	272.19	159.62
9/23/95	253.38	164.18
9/24/95	263.96	169.50
9/25/95	172.58	169.18
9/26/95	117.75	166.80
9/27/95	133.09	164.79
9/28/95	275.32	168.21
9/29/95	169.87	165.98
9/30/95	172.72	168.26
10/1/95	179.22	174.20
10/2/95		174.20
10/3/95		174.20
10/4/95		174.20
10/5/95		174.20
10/6/95		174.20
10/7/95	190.86	178.03
10/8/95	115.85	178.53
10/9/95	220.68	182.29
10/10/95	200.32	182.50
10/11/95	126.44	181.65
10/12/95	134.27	178.44
10/13/95	157.53	177.43
10/14/95	172.08	178.23
10/15/95	203.36	179.35
10/16/95	255.96	184.36
10/17/95	282.26	187.42
10/18/95	134.49	183.23
10/19/95	124.37	179.32
10/20/95	131.34	177.21
10/21/95	171.73	177.65
10/22/95	147.88	175.86
10/23/95	123.24	174.39
10/24/95	126.59	175.19
10/25/95	129.00	174.23
10/26/95	139.36	176.59
10/27/95	173.21	173.29
10/28/95	154.20	169.98
10/29/95	88.63	164.14
10/30/95	176.37	164.27
10/31/95	149.57	165.33
11/1/95	153.96	166.02
11/2/95	97.47	160.09
11/3/95	184.59	160.58

11/4/95	142.61	159.58
11/5/95	174.49	159.42
11/6/95	161.59	158.45
11/7/95	149.20	159.56
11/8/95	181.58	158.26
11/9/95	155.29	156.76
11/10/95	129.79	156.87
11/11/95	111.20	156.10
11/12/95	141.51	155.56
11/13/95	144.22	154.64
11/14/95	186.29	154.07
11/15/95	175.69	151.39
11/16/95	137.75	146.57
11/17/95	164.06	147.56
11/18/95	107.35	146.99
11/19/95	135.22	147.12
11/20/95	208.59	148.35
11/21/95	190.16	149.76
11/22/95	188.85	151.95
11/23/95	241.16	155.77
11/24/95	140.85	156.16
11/25/95	227.48	159.10
11/26/95	198.29	159.93
11/27/95	147.98	159.73
11/28/95	141.60	161.49
11/29/95	178.13	161.55
11/30/95	98.30	159.84
12/1/95	109.35	158.35
12/2/95	124.85	159.27
12/3/95	170.54	158.80
12/4/95	136.74	158.60
12/5/95	68.05	155.06
12/6/95	147.79	154.60
12/7/95	124.06	153.76
12/8/95	111.07	151.41
12/9/95	120.09	150.23
12/10/95	127.04	150.14
12/11/95	147.41	151.35
12/12/95	162.03	152.03
12/13/95	95.23	150.40
12/14/95	91.10	147.23
12/15/95	70.11	143.71
12/16/95	114.28	142.93
12/17/95	114.90	141.29
12/18/95	193.10	144.15
12/19/95		144.15
12/20/95	99.20	142.94
12/21/95	170.26	141.67
12/22/95	141.14	140.03
12/23/95	190.99	140.10
12/24/95	184.22	138.21
12/25/95	274.39	142.66
12/26/95	236.12	142.95
12/27/95	117.33	140.25
12/28/95	158.00	140.58
12/29/95	178.38	141.81

12/30/95	150.62	140.89
12/31/95	102.79	141.04
AVG	141.20	138.56
MAX	302.20	187.42

Attachment C

Tire Heat Input

March 1, 1995 through April 30, 1995

BTU/LB	TIRE	13618
	WOOD	3923
	PROPANE	21670

	TIRES MMBTU	WOOD MMBTU	PROPANE MMBTU	TOTAL MMBTU	TIRE % BTU
3 / 1	4,084	8,727	0	12,810	31.88
3 / 2	3,949	8,641	0	12,590	31.37
3 / 3	3,255	9,461	0	12,716	25.60
3 / 4	2,187	8,798	329	11,314	19.33
3 / 5	2,872	10,156	0	13,029	22.05
3 / 6	1,436	8,684	823	10,944	13.13
3 / 7	3,253	8,925	0	12,178	26.71
3 / 8	4,447	8,592	27	13,067	34.03
3 / 9	4,191	8,849	27	13,068	32.07
3 / 10	2,901	8,876	138	11,915	24.35
3 / 11	2,870	8,058	0	10,929	26.26
3 / 12	2,909	8,481	0	11,389	25.54
3 / 13	2,465	9,402	0	11,867	20.77
3 / 14	2,873	9,824	0	12,698	22.63
3 / 15	2,318	9,611	0	11,929	19.43
3 / 16	2,657	10,362	0	13,019	20.41
3 / 17	2,794	8,802	0	11,595	24.09
3 / 18	2,841	8,802	0	11,643	24.40
3 / 19	1,518	3,639	988	6,145	24.70
3 / 20	2,802	9,360	0	12,162	23.04
3 / 21	2,710	9,630	0	12,340	21.96
3 / 22	2,734	8,991	0	11,725	23.32
3 / 23	2,692	8,833	0	11,524	23.36
3 / 24	2,091	6,295	357	8,743	23.92
3 / 25	2,888	8,838	0	11,726	24.63
3 / 26	2,873	9,088	0	11,960	24.02
3 / 27	2,513	8,771	0	11,284	22.27
3 / 28	2,136	8,833	247	11,216	19.04
3 / 29	2,041	8,005	192	10,238	19.94
3 / 30	2,055	8,290	477	10,822	18.99
3 / 31	1,964	10,815	0	12,779	15.37
4 / 1	2,809	7,841	192	10,842	25.90
4 / 2	0	0	219	219	0.00
4 / 3	0	0	0	0	0.00
4 / 4	0	0	0	0	0.00
4 / 5	0	0	0	0	0.00
4 / 6	0	0	0	0	0.00
4 / 7	0	0	0	0	0.00
4 / 8	0	0	0	0	0.00
4 / 9	482	736	933	2,151	22.41
4 / 10	2,013	6,745	182	8,940	22.51

4 / 11	2,240	6,438	82	8,760	25.57
4 / 12	2,929	7,318	27	10,274	28.51
4 / 13	1,284	4,464	549	6,297	20.39
4 / 14	2,460	8,982	27	11,470	21.45
4 / 15	2,301	8,390	0	10,691	21.52
4 / 16	2,827	7,212	0	10,038	28.16
4 / 17	2,702	7,635	0	10,336	26.14
4 / 18	3,365	8,330	0	11,695	28.77
4 / 19	3,174	8,636	0	11,809	26.87
4 / 20	2,317	4,675	302	7,293	31.77
4 / 21	1,628	9,120	110	10,858	14.99
4 / 22	1,382	8,637	55	10,074	13.72
4 / 23	1,184	10,266	0	11,451	10.34
4 / 24	1,934	9,393	0	11,327	17.07
4 / 25	2,430	9,324	27	11,782	20.63
4 / 26	2,739	8,544	0	11,283	24.28
4 / 27	2,474	8,096	0	10,570	23.41
4 / 28	566	921	55	1,542	36.69
4 / 29	0	0	656	656	0.00
4 / 30	2,771	6,307	439	9,517	29.12

Attachment D

Percent SO₂ Removal Calculation based on RGS Fuels Analysis

SO2 REDUCTION CALCULATION

FUEL	LB/HR	%S	LB/HR S	LB/HR SO2
TIRES	16900	0.0144	243.36	486.72
WOOD	101926.03	0.00116	118.23	236.47
TOTAL				723.19
PERMIT LIMIT				-72.00
SO2 REMOVED				651.19
% REDUCTION			REMOVED/TOTAL	90.04%

FUEL CONSUMPTION CALCULATION

	LB/HR	BTU/LB	MMBTU/HR
TIRES	16900	13618	230.14
WOOD	101926.03	3923	399.86
TOTAL			630.00

1. Sulfur content of tires based on the average of 22 samples. The measured sulfur content ranged from 1.17% to 1.84%.
2. Sulfur content of wood based on the average of 76 samples. The measured sulfur content ranged from 0.0% to 0.42%.