



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV  
345 COURTLAND STREET, N.E.  
ATLANTA, GEORGIA 30365

AUG 27 1992

RECEIVED

SEP 8 1992

Division of  
Resources

4APT-AEB

Mr. Clair H. Fancy, P.E., Chief  
Bureau of Air Regulation  
Florida Department of Environmental  
Regulation  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

RE: Ridge Generating Station, L.P. (PSD-FL-183)

Dear Mr. Fancy:

This is to acknowledge receipt of your revised preliminary determination and draft Prevention of Significant Deterioration (PSD) permit for the above referenced facility, by your letter dated July 24, 1992. The applicant proposes to construct a stoker boiler to combust waste wood, scrap tires, and landfill gas, while generating approximately 50 megawatts of electrical power.

Your determination proposes the use of a spray dryer absorber/fabric filter to limit particulate, acid gas, and heavy metal emissions, selective noncatalytic reduction (SNCR) to limit NO<sub>x</sub> emissions, and combustion efficiency to limit CO and VOC emissions.

We have reviewed the package as submitted and have no adverse comments. Thank you for the opportunity to review and comment on this package. If you have any questions or comments, please contact either Mr. Gregg Worley or Mr. Scott Davis of my staff at (404) 347-5014.

Sincerely yours,

Brian L. Beals, Chief  
Source Evaluation Unit  
Air, Pesticides, and Toxics  
Management Division

CHFILK

John Reynolds  
Clare Holladay  
Bill Thomas, SWD  
Linda Novak, Polk Co

} 9-9-92 RBM