



Wheelabrator Ridge Energy Inc.

A Waste Management Company
3131 K-Ville Avenue
Auburndale, FL 33823

Phone 941.665.2255
Fax 941.665.0400

RECEIVED

MAY 18 1999

**BUREAU OF
AIR REGULATION**

Certified Mail Z 075-834-366

May 11, 1999
Mr. John Reynolds
Mail Stop 5505
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
2600 Blair Stone Road
Tallahassee, FL 32399-2400

RE: Correction to Specific Condition 5; Revised Wheelabrator Ridge Energy - PSD
Permit AC53-206244(PSD-FL-183A) Modified March 31, 1999

Dear Mr Reynolds:

While reviewing the Proposed Title V and the March 31, 1999 modification made to the Wheelabrator Ridge Energy PSD permit I noticed an error in Specific Condition 5 of the PSD Permit.

The line for Be in the table of Specific Condition 5 reads:

Be	0.0063	0.028	EPA Method 104 if test required
----	--------	-------	---------------------------------

This line should read:

Be	0.0063	0.028	EPA Method 29 or 104 if test required
----	--------	-------	---------------------------------------

This correction would make this line consistent with the Mercury (Hg) and Lead (Pb) lines of Specific Condition 5.

If you have any additional questions, please call John Neil at (941) 665-2255 Ext. 250.

Sincerely,

George D. Woodward, P.E.
Plant Manager

cc: G. Kissel (DEP Southwest District)
T. Porter (WESI)