

September 10, 2010

Mr. Thomas Cascio
Title V Section
Florida Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, FL 32399-2400

(850-921-9526)

RECEIVED

SEP 13 2010

BUREAU OF
AIR REGULATION

RE: Auburndale Power Partners (APP); Title V Air Operation Permit Renewal No. 1050221-016-AV; Response to the Department's proposed permit package dated August 17, 2010

Dear Mr. Cascio:

We appreciate the opportunity to review and comment on the Department's proposed permit package for the Auburndale Power Partners facility, located in Auburndale, Polk County, Florida (Renewal Permit No. 1050221-016-AV).

Based upon our review we have several minor comments for the Department to consider incorporating into the permit, as well as requesting several points of clarification. These comments are provided below and are also incorporated into an attached "marked-up" copy of the draft permit.

1. Regarding the placard or cover page to be signed by Director Joseph Kahn
 - a. Second line of first paragraph. Remove "sold to the" and insert "retained by", so the sentence now reads as, "... remove portions retained by Calpine Corporation."
 - b. Regarding the effective date of January 1, 2011, the renewal date of May 20, 2015 and Expiration date of December 31, 2015, we just want to confirm these are in place as place holders and will be revised based upon the actual date of permit issuance.
2. Section III, A.12. Delete "and EU 006" on line five of the paragraph.
3. Section III, A.12. Line seven, delete strike-out section
4. Section III, A.14. Line one, insert "for fuel oil" following "the sulfur content..."
5. Section III, A.17. Add Test Method 3A for O2 to the referenced methods. Method 3A is referenced on Table 2, Summary of Compliance Requirements and back references to condition A.17.
6. Section III, A.20. Compliance Tests prior to renewal. For clarity, please confirm that APP will be required to meet this permit requirement as part of the next permit application process, which will occur in 2015.

7. Section III, A.22 and A.24. Please confirm that the recordkeeping and reporting requirements described here are for fuel oil only, and that the reporting deadline described in A.22 is a quarterly requirement, while recordkeeping is monthly.
8. Table 2, Summary of Compliance Requirements. In footnote (2), please add ASTM D5453 as an acceptable fuel sulfur analysis method, as described in condition A.14.

If there are any questions or comments concerning the matters discussed in this letter, please feel free to either call or e-mail me. My telephone number is 917 472-4593 and my e-mail address is tgrace@caithnessenergy.com

For Auburndale Power Partners

Sincerely,

A handwritten signature in black ink, appearing to read "Thomas A. Grace". The signature is fluid and cursive, with the first name "Thomas" and last name "Grace" clearly distinguishable.

Thomas A. Grace

Director – Environmental, Health & Safety

W/attachment (“mark-up” of the 8/17/10 proposed permit))

Cc: K. Collins
W. Lachney
S. Wunderlich

Auburndale Power Partners, L.P.


Auburndale Power Partners Plant

Facility ID No. 1050221

Polk County

Title V Air Operation Permit Renewal

Permit No. 1050221-016-AV



Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resource Management
Bureau of Air Regulation
Title V Section
2600 Blair Stone Road
Mail Station #5505
Tallahassee, Florida 32399-2400
Telephone: (850) 488-0114
Fax: (850) 921-9533

Compliance Authority:

Southwest District Office
13051 N. Telecom Parkway
Temple Terrace, Florida 33637
Telephone: (813) 632-7600
Fax: (813) 632-7665

Title V Air Operation Permit Renewal

Permit No. 1050221-016-AV

Table of Contents

<u>Section</u>	<u>Page Number</u>
Placard Page	1
I. Facility Information.	
A. Facility Description.	2
B. Summary of Emissions Units.	2
C. Applicable Regulations.	2
II. Facility-wide Conditions.	4
III. Emissions Units and Conditions.	
A. Combined Cycle Combustion Turbine (EU-001).	6
IV. Acid Rain Part.	11
Phase II Acid Rain Application/Compliance Plan.	
V. Clean Air Interstate Rule Part.	16
VI. ECONOPAC System Performance Curves.	22
VII. Appendices.	23
Appendix A, Glossary.	
Appendix I, List of Insignificant Emissions Units and/or Activities.	
Appendix ICE, Requirements for Internal Combustion Engines.	
Appendix NESHAP, Subpart A – General Provisions.	
Appendix NESHAP, Subpart ZZZZ – National Emissions Standards For Hazardous Air Pollutants For Stationary Reciprocating Internal Combustion Engines.	
Appendix NSPS, Subpart A – General Provisions.	
Appendix NSPS, Subpart GG – Standards of Performance for Stationary Gas Turbines.	
Appendix RR, Facility-wide Reporting Requirements.	
Appendix TR, Facility-wide Testing Requirements.	
Appendix TV, Title V General Conditions.	
Appendix U, List of Unregulated Emissions Units and/or Activities.	
Referenced Attachments.	At End
Figure 1, Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance (40 CFR 60, July, 1996).	
Table H, Permit History.	
Table 1, Summary of Air Pollutant Standards and Terms.	
Table 2, Compliance Requirements.	

DRAFT/PROPOSED PERMIT

PERMITTEE:

Auburndale Power Partners, L.P.
1501 West Derby Avenue
Auburndale, Florida 33823-4062

Permit No. 1050221-016-AV
Auburndale Power Partners Plant
Facility ID No. 1050221
Title V Air Operation Permit Renewal

The purpose of this ^{retained by} permit is to renew the Title V Air Operation Permit for the above referenced facility and to remove portions ~~sole to~~ the Calpine Corporation. The existing Auburndale Power Partners (AAP) Plant is located at 1501 West Derby Avenue, Auburndale, Florida, in Polk County. The reference Universal Transverse Mercator (UTM) coordinates are: Zone 17, 420.8 km East and 3103.3 km North. Latitude is: 28° 03' 06" North; and, Longitude is: 81° 48' 21" West.

The Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to operate the facility in accordance with the terms and conditions of this permit.

Effective Date: January 1, 2011 *

Renewal Application Due Date: May 20, 2015 *

Expiration Date: December 31, 2015 *

(Draft/Proposed)

Joseph Kahn, Director
Division of Air Resource Management

JK/tlv/jkh/tbc

SECTION I. FACILITY INFORMATION.

Subsection A. Facility Description.

The plant is located in Polk County at 1501 West Derby Avenue, Auburndale, Florida. It is owned and operated by Auburndale Power Partners, L.P. The nominal generating capacity of the plant's combined cycle unit is 156 megawatts (MW). The facility also operates other miscellaneous unregulated and insignificant emissions units and activities.

Subsection B. Summary of Emissions Units.

EU No.	Brief Description
<i>Regulated Emissions Units</i>	
001	This emissions unit is a nominal 156 MW combined cycle unit consisting of a combustion turbine-electrical generator set rated at 121.5 MW, an unfired heat recovery steam generator (HRSG) and a nominal 52 MW steam turbine-electrical generator set.
<i>Unregulated Emissions Units and Activities</i>	
002	Fuel oil storage tanks
003	Emergency generator*
004	Heating units and engines
005	Surface coating operations

*The APP facility, which is a minor (i.e., area) source of hazardous air pollutants (HAP), includes one 265 brake horsepower (bhp) emergency firewater pump compression ignition (CI) diesel engine. On March 3, 2010, following submittal of the APP Title V permit application, EPA promulgated a final rule amending 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. This regulation is applicable to stationary reciprocating internal combustion engines (RICE) located at major or area HAP sources.

In accordance with 40 CFR §63.6603, existing stationary CI RICE of all sizes located at an area source of HAP emissions must comply with the applicable requirements of Table 2b and Table 2d. Table 2b does not contain any requirements that are applicable to the APP emergency firewater pump CI diesel engine. Table 2d contains management and work practice requirements (e.g., change engine oil and filter every 500 hours of operation or annually, whichever comes first, minimize startup operations, etc.) that will be applicable to the APP emergency firewater pump CI diesel engine.

As required by 40 CFR §63.6625(e), existing stationary emergency RICE not subject to any numerical emission standards must operate and maintain the stationary RICE according to the engine manufacturer's emission-related written instructions or must develop a maintenance plan. Engine operating time spent at idle during startup and engine startup duration must be minimized per 40 CFR §63.6625(h). An option to extend the specified oil change requirements in Table 2d utilizing an oil analysis program is provided in 40 CFR §63.6625(i).

In accordance with 40 CFR §63.6595, the existing stationary CI RICE located at this source must comply with the applicable provisions of Subpart ZZZZ no later than May 3, 2013. See Appendix NESHAP, Subpart ZZZZ, attached to this permit.

APP facility management has indicated that it will comply with the above Subpart ZZZZ requirements for the emergency firewater pump diesel engine no later than May 3, 2013.

Subsection C. Applicable Regulations.

Based on the Title V Air Operation Renewal application received on March 2, 2010, this facility is not a major source of hazardous air pollutants (HAP). Because this facility operates stationary reciprocating internal

SECTION I. FACILITY INFORMATION.

combustion engines, it is subject to regulation under 40 CFR 63, Subpart ZZZZ - National Emissions Standards For Hazardous Air Pollutants For Stationary Reciprocating Internal Combustion Engines. However, since the engines being operated meet the Subpart ZZZZ definition of “existing units”, there are no unit specific applicable requirements that must be met pursuant to this rule at this time. The existing facility is a PSD major source of air pollutants in accordance with Rule 62-212.400, F.A.C. A summary of applicable regulations is shown in the following table.

Regulation	EU No(s).
<i>Federal Rule Citations</i>	
40 Code of Federal Regulations (CFR) 60, Subpart A, NSPS General Provisions	001
40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines	
40 CFR 63, Subpart A, General Provisions	003
40 CFR 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines	
40 CFR 75 Acid Rain Monitoring Provisions. The facility operates a unit subject to Phase II of the federal Acid Rain Program	001
<i>State Rule Citations</i>	
Rule 62-4, Florida Administrative Code (F.A.C.) (Permitting Requirements)	001
Rule 62-204, F.A.C. (Ambient Air Quality Requirements, PSD Increments, and Federal Regulations Adopted by Reference)	
Rule 62-210, F.A.C. (Permits Required, Public Notice, Reports, Stack Height Policy, Circumvention, Excess Emissions, and Forms)	
Rule 62-212, F.A.C. (Preconstruction Review, PSD Review and Best Available Control Technology (BACT))	
Rule 62-213, F.A.C. (Title V Air Operation Permits for Major Sources of Air Pollution)	
Rule 62-214, F.A.C. (Requirements For Sources Subject To The Federal Acid Rain Program)	
Rule 62-296, F.A.C. (Emission Limiting Standards)	
Rule 62-297, F.A.C. (Test Methods and Procedures, Continuous Monitoring Specifications, and Alternate Sampling Procedures)	
Rule 62-296.470, F.A.C. (Clean Air Interstate Rule) (CAIR)	

SECTION II. FACILITY-WIDE CONDITIONS.

The following conditions apply facility-wide to all emission units and activities:

FW1. Appendices. The permittee shall comply with all documents identified in Section VII, Appendices, listed in the Table of Contents. Each document is an enforceable part of this permit unless otherwise indicated. [Rule 62-213.440, F.A.C.]

Emissions and Controls

FW2. Not federally Enforceable. Objectionable Odor Prohibited. No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rule 62-296.320(2) and 62-210.200(Definitions), F.A.C.]

FW3. General Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed-necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]

{Permitting Note: Nothing is deemed necessary and ordered at this time.}

FW4. General Visible Emissions. No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b), F.A.C.]

FW5. Unconfined Particulate Matter. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter (PM) at this facility include:

- a. Paving and maintenance of roads, parking areas and yards.
- b. Chemical (dust suppressants) or water application to unpaved roads, unpaved yard areas and open stock piles.
- c. Removal of PM from roads and other paved areas to prevent re-entrainment and from buildings or work areas to prevent airborne PM.
- d. Landscaping or planting of vegetation.
- e. Use of hoods, fans, filters, and similar equipment to contain, capture, and/or vent PM.
- f. Confining abrasive blasting where possible.
- g. Enclosure or covering of conveyor systems.

[Rule 62-296.320(4)(c), F.A.C.; and, proposed by applicant in Title V air operation permit renewal application received March 2, 2010.]

Annual Reports and Fees

See Appendix RR, Facility-wide Reporting Requirements for additional details.

FW6. Annual Operating Report. The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by April 1st of each year. [Rule 62-210.370(3), F.A.C.]

FW7. Annual Emissions Fee Form and Fee. The annual Title V emissions fees are due (postmarked) by March 1st of each year. The completed form and calculated fee shall be submitted to: Major Air Pollution Source Annual Emissions Fee, P.O. Box 3070, Tallahassee, Florida 32315-3070. The forms are available for

SECTION II. FACILITY-WIDE CONDITIONS.

download by accessing the Title V Annual Emissions Fee On-line Information Center at the following Internet web site: <http://www.dep.state.fl.us/air/emission/tvfee.htm>. [Rule 62-213.205, F.A.C.]

FW8. Annual Statement of Compliance. The permittee shall submit an annual statement of compliance to the compliance authority at the address shown on the cover of this permit within 60 days after the end of each calendar year during which the Title V permit was effective. [Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

FW9. Prevention of Accidental Releases (Section 112(r) of CAA). If, and when, the facility becomes subject to 112(r), the permittee shall:

- a. Submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center. Any Risk Management Plans, original submittals, revisions or updates to submittals, should be sent to: RMP Reporting Center, Post Office Box 10162, Fairfax, VA 22038, Telephone: (703) 227-7650.
- b. Submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.

[40 CFR 68]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001

The specific conditions in this section apply to the following emissions unit:

EU No.	Brief Description
001	This emissions unit is a nominal 156 megawatt (MW) combined cycle unit consisting of a Westinghouse model number 501D5 combustion turbine-electrical generator set rated at 121.5 MW, an unfired heat recovery steam generator (HRSG) and a steam turbine-electrical generator set rated at 52 MW.

Nitrogen oxides (NO_x) emissions are controlled by steam injection and selective catalytic reduction (SCR) systems. Compliance assurance monitoring (CAM) does not apply to this emissions unit because a continuous emissions monitoring system (CEMS) is used to demonstrate compliance with the NO_x limits. Stack height is 160 feet, stack exit diameter is 18.0 feet, stack exit temperature is 200 degrees Fahrenheit and flow rate is 839,700 actual cubic feet per minute (acfm). The commercial startup date was July 1, 1994. The combustion turbine is regulated under the NSPS Subpart A (General Provisions) and Subpart GG (Standards of Performance for Stationary Gas Turbines) in 40 CFR 60, and is subject to the Clean Air Interstate Rule (CAIR) set forth in Rule 62-296.470, F.A.C., and is subject to Phase II of the federal Acid Rain Program and Rule 62-212.400(PSD), F.A.C.

Essential Potential to Emit (PTE) Parameters

- A.1. Permitted Capacity. The maximum allowable heat input rates, based on the lower heating value (LHV) of each fuel and International Standards Organization (ISO) conditions, are as follows:

Unit No.	Million British thermal units (MMBtu)/hour	Fuel Type
001	1,214	Natural gas with the wet compression system off
	1,364	Natural gas with the wet compression system in operation
	1,170	Distillate fuel oil

[Rules 62-4.160(2), 62-204.800, 62-210.200(PTE); and, Permit No(s). AC53-208321/PSD-FL-185 and 1050221-012-AC/PSD-FL-185A.]

- A.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

- A.3. Methods of Operation – Fuels.

The fuels that are allowed to be burned in this unit/these units are:

- Natural gas as a primary fuel; and
- New No. 2 fuel oil distillate oil with a maximum sulfur content of 0.05% by weight.

[Rule 62-213.410, F.A.C.; Applicant's request in Title V permit renewal application received March 2, 2010; and Permit No. AC53-208321/PSD-FL-185]

- A.4. Hours of Operation. This emissions unit may operate continuously (8,760 hours/year). The total hours of operation of the combustion turbine while firing distillate fuel oil shall not exceed 400 hours/year. [Rule 62-210.200(PTE), F.A.C. and Permit No. AC53-208321/PSD-FL-185]

Control Technology

- A.5. Wet Compression System. Operation of the wet compression system is approved for use on Unit 1 during any periods at which the ambient temperature is above 60° F. Use of the wet compression system is limited to periods during the firing of natural gas only. [1050221-005-AC]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions A.6.-A.11. are based on the specified averaging time of the applicable test method.

A.6. Visible Emissions (VE). Visible emissions from the combustion turbine shall not exceed 10% opacity at full load (i.e., 156 MW) and 20% opacity at loads other than full load. [Rule 62-212.400(PSD), F.A.C. and PSD-FL-185]

A.7. PM₁₀ Standards. PM₁₀ emissions shall not exceed the following:

- a. *Natural Gas:* 0.0134 lb/MMBtu; 10.5 lb/hour; and 46 tons/year.
 - b. *Distillate Fuel Oil:* 0.0472 lb/MMBtu; 36.8 lb/hour; and 7.4 tons/year.
- [Rule 62-212.400(PSD), F.A.C. and PSD-FL-185]

A.8. SO₂ Standards. SO₂ emissions shall not exceed the following:

- a. *Natural Gas:* 40.0 lb/hour; and 175.2 tons/year.
- b. *Distillate Fuel Oil:* use of distillate oil with a maximum sulfur content of 0.05 % by weight; 70.0 lb/hour; and 14 tons/year.

[Rule 62-212.400(PSD), F.A.C. and PSD-FL-185]

A.9. NO_x Standards. Nitrogen oxides emissions shall not exceed the following:

- a. *Natural Gas:* 15 parts per million by volume dry (ppmvd) corrected to 15% oxygen based on a 24-hour block average as defined below; 9 ppmvd corrected to 15% oxygen based on a 12-month rolling equivalent average as defined below; 78.6 lb/hour; and 177 tons/year based on a 12-month rolling total for the combined total of natural gas and distillate fuel oil firing.
- b. *Distillate Fuel Oil:* 42 ppmvd corrected to 15% oxygen based on a 24-hour block average; 230.0 lb/hour; 46 tons/year; and 177 tons/year based on a 12-month rolling total for the combined total of natural gas and distillate fuel oil firing.
- c. *Calculation of 24-hour Block Averages:* At the same time each day, a 24-hour block average shall be calculated for the monitored operating hours in the previous 24-hour period. The 24-hour block average shall be determined by summing the hourly average NO_x concentrations for all valid monitored operating hours and dividing by the number of hourly average NO_x concentrations in the previous 24-hour period. A monitored operating hour is each hour in which fuel is fired in the combustion turbine and at least two CEMS emission measurements are recorded at least 15 minutes apart. The CEMS data taken during periods of startup, shutdown, or malfunction as defined in Rules 62-210.200 and 62-210.700 F.A.C., when fuel is not fired in the unit, or during CEMS quality assurance checks or when the CEMS is out of control, shall be excluded from the 24-hour block average.
- d. *Calculation of 12-Month Rolling Totals:* For the annual (tons/year) emissions limits of NO_x, measurements shall be in pounds (converted to tons) and be based on a 12-month rolling total starting at the first day of each calendar month. Each monthly total shall be calculated by adding the pounds per day for each valid operating day (all fuels) within the calendar month. This monthly total shall be combined with the emissions from the previous valid 11 calendar months and shall comprise a 12-month rolling total.
- e. *Calculation of the 12-Month Rolling NO_x Average:* To demonstrate compliance with the NO_x limit of 9 ppmvd corrected to 15% oxygen based on a 12-month rolling average, measurements shall be in "ppmvd corrected to 15% oxygen" and be based on a 12-month rolling average starting at the first day of each calendar month. Each monthly average shall be calculated by adding each valid gas firing 24-hour block average (as determined above) from valid operating days within the calendar month. This monthly average shall be combined with the emissions from the previous valid 11 calendar months and shall comprise a 12-month rolling average. In order to convert each 12-month rolling average to an annual equivalent limit, the following formula shall be utilized:

$$\text{ppmvd}_c = (\text{ppmvd}_a) (\text{hours}_g/8760)$$

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001

Where:

ppmvd_c = the equivalent annual NO_x average (ppmvd corrected to 15% oxygen)

ppmvd_a = the measured (CEMS) 12-month rolling NO_x average (ppmvd corrected to 15% oxygen) for firing only natural gas

hours_g = 12-month rolling total valid hours of operation combusting natural gas

[Rule 62-212.400(PSD), F.A.C.; PSD-FL-185, 1050221-004-AC and 1050221-010-AC]

A.10. VOC Standards. Volatile organic compounds emissions shall not exceed the following:

- a. *Natural Gas*: 6.0 lb/hour; and 26.3 tons/year.
- b. *Distillate Fuel Oil*: 10.0 lb/hour; and 2.0 tons/year.

[Rule 62-212.400(PSD), F.A.C. and PSD-FL-185]

A.11. CO Standards. Carbon monoxide emissions shall not exceed the following:

- a. *Natural Gas*: 21 ppmvd at minimum load; 15 ppmvd at base load; 43.5 lb/hour; and 190.5 tons/year.
- b. *Distillate Fuel Oil*: 25 ppmvd; 73.0 lb/hour; and 14.6 tons/year.

[Rule 62-212.400(PSD), F.A.C. and PSD-FL-185]

Excess Emissions

Rule 62-210.700 (Excess Emissions), F.A.C., cannot vary any requirement of an NSPS, NESHAP or Acid Rain program provision.

A.12. Excess Emissions Allowed. Excess emissions from this emissions unit resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. Additionally, the permittee's record keeping for the NO_x emissions caps (TPY) on EU-001 and EU-006 shall be in full agreement with publicly available data on EPA's Acid Rain website which includes all documented exclusions reported to the Department in a quarterly report. However these emissions will be excluded for compliance demonstration. The permittee may exclude startup, shutdown and Part 75 missing data from the ppmvd calculations. However, these data will need to be recorded for the TPY calculations for netting purposes and are required by the Acid Rain website. [Rule 62-210.700(1), F.A.C. and 1050221-010-AC, Specific Condition 18.]

A.13. Excess Emissions Prohibited. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

for fuel oil

Monitoring of Operations

A.14. Fuel Sulfur Monitoring. The permittee shall determine compliance with the sulfur content standard of 0.05% by weight as follows: ASTM D129-91, D1552-90, D2280-71, D2880-96, D2622-92, D4292, D4294-90, D5453, the latest editions or in accordance with approved 40 CFR Part 75 methods. The permittee shall determine compliance with the fuel sulfur content of gaseous fuels as follows: ASTM D1072-80/90/94, D3031-81/86, D3246-81/92, D4084-82/94, D4468-85, D5504-94, the latest editions or in accordance with approved 40 CFR Part 75 methods. The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator. [40 CFR 60.335 and PSD-FL-185]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001

Continuous Monitoring Requirements

A.15. NO_x CEMS. In accordance with Performance Specification 2 in Appendix B of 40 CFR 60, the permittee shall install, calibrate, maintain and operate a CEMS in the stack to measure and record the NO_x emissions from this unit to demonstrate compliance with the applicable emissions standards. Quality assurance procedures must conform to the applicable sections of Appendix F in 40 CFR 60.

- a. For purposes of demonstrating compliance with the NO_x mass emission limits (lb/hr and tons/year), NO_x and diluent concentrations shall be determined by one of the following methods: EPA Method 20 conducted between 90% and 100% of permitted maximum capacity only; continuous monitoring data collected during the relative accuracy test assessment conducted pursuant to Section 7 in Performance Specification 2 of Appendix B, 40 CFR 60; or EPA Method 7E with either EPA Method 3 or 3A in Appendix A of 40 CFR 60.
- b. The NO_x CEMS shall be used to demonstrate continuous compliance with the NO_x emission limit (24-hour block average concentration limit).
- c. CEMS Data Exclusion – Combustor Tuning. CEMS data collected during initial or other major combustor tuning sessions shall be excluded from the CEMS compliance demonstration for short term emission standards provided the tuning session is performed in accordance with the manufacturer's specifications. All valid emissions data shall be used to demonstrate compliance with annual emissions caps. A "major tuning session" would occur after completion of initial construction, a combustor change-out, a major repair or maintenance to a combustor, or other similar circumstances. Prior to performing any major tuning session, the permittee shall provide the Department's Southwest District Compliance Authority with advance notice that details the activity and proposed tuning schedule. The notice shall be by telephone, facsimile transmittal, or electronic mail. [Rules 62-4.070(3), 62-212.400(PSD), F.A.C., 62-210.700(5) F.A.C. and PSD-FL-185A]

[Rule 62-212.400(PSD), F.A.C. and PSD-FL-185]

Test Methods and Procedures

A.16. Testing Requirements. This emissions unit shall operate between 90% and 100% of permitted capacity during the compliance tests as adjusted for compressor inlet temperature (See the W501D5 ECONOPAC SYSTEM PERFORMANCE GRAPH included at the end of this permit.) [Chapter 62-297, F.A.C.]

A.17. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
5	Determination of Particulate Matter Emissions
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources
18	Measurement of Gaseous Organic Compound Emissions (Gas Chromatography) {Note: Optional testing in accordance with EPA Method 18 may be conducted to account for the actual methane fraction of the measured VOC emissions, if specifically requested.}
19	Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates {Optional F-factor method may be used to determine flow rate and gas analysis to calculate mass emissions in lieu of Methods 1-4.}
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines

Add Test Method
3A for O₂ here

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001

Method	Description of Method and Comments
25A	Method for Determining Gaseous Organic Concentrations (Flame Ionization)

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rules 62-204.800, 62-297.100 and 62-297.401, F.A.C.; 40 CFR 60, Appendix A; 40 CFR 60.334; PSD-FL-185; 1050221-004-AC; and 1050221-010-AC]

A.18. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

A.19. Annual Compliance Tests Required. During each federal fiscal year (October 1st to September 30th), each emissions unit (EU) shall be tested to demonstrate compliance with the emissions standards for visible emissions and carbon monoxide. Compliance testing is only required during the combustion of natural gas fuel, which is the primary fuel. [Rule 62-297.310(7), F.A.C.; and Permit Nos. PSD-FL-185, 1050221-004-AC and 1050221-010-AC]

A.20. Compliance Tests Prior To Renewal. Compliance tests shall be performed for nitrogen oxides, carbon monoxide and volatile organic compounds once every 5 years. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. Compliance testing is only required during the combustion of natural gas fuel, which is the primary fuel. The tests shall occur prior to obtaining a renewed operating permit to demonstrate compliance with the emission limits in Specific Conditions **A.9. – A.11.** [Rules 62-210.300(2)(a) and 62-297.310(7)(a), F.A.C., PSD-FL-185, 1050221-004-AC and 1050221-010-AC]

Provide clarity when next required

A.21. Additional Compliance Test Requirements. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once in each 5-year period, coinciding with the term of its air operation permit. [Rule 62-297.310, F.A.C.]

Recordkeeping and Reporting Requirements

A.22. Reporting Schedule. The following reports and notifications shall be submitted to the Compliance Authority:

Report	Reporting Deadline	Related Condition(s)
Notice of Fuel Use	Monthly	A.24.

Please clarify

A.23. Other Reporting Requirements. See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements.

A.24. Specific Reporting Requirement for Fuel Records. Sulfur and lower heating value of the fuel being fired in the combustion turbine shall be based on a weighted 12-month rolling average from fuel delivery receipts. The records of distillate oil usage shall be kept by the permittee for a 5-year period. For SO₂, periods of excess emissions shall be reported if the fuel being fired exceeds 0.05% sulfur by weight. [Rules 62-212.400(PSD) and 62-213.440(1)(b), F.A.C.; and PSD-FL-185]

Please clarify

Other Requirements

A.25. NSPS Provisions. The combustion turbine is also subject to the applicable requirements of Subpart A (General Provisions) and Subpart GG (Stationary Gas Turbine) in 40 CFR 60, attached to this permit. [Rule 62-213.440, F.A.C.]

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

Operated by: Auburndale Power Partners, L.P.
ORIS Code: 54658

The emissions units listed below are regulated under Acid Rain, Phase II.

<u>E.U. ID No.</u>	<u>Brief Description</u>
001	This emissions unit is a nominal 156 MW combined cycle unit consisting of a combustion turbine-electrical generator set rated at 121.5 MW, an unfired heat recovery steam generator (HRSG) and a nominal 52 MW steam turbine-electrical generator set.

A.1. Application. The Phase II Acid Rain Part application is a part of this permit. The owners and operators of the Phase II acid rain units must comply with the standard requirements and special provisions set forth in the following application: DEP Form No. 62-210.900(1)(a), effective 03/16/08, received March 2, 2010. [Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

A.2. Sulfur Dioxide (SO₂) Emission Allowances. SO₂ emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
- b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
- c. Allowances shall be accounted for under the Federal Acid Rain Program.
[Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]

A.3. Comments. Comments, notes, and justifications: None.

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is: ☐ New ☒ Revised ☐ Renewal

STEP 1

Identify the source by plant name, state, and ORIS or plant code.

Auburndale Power Partners <small>Plant name</small>	Florida <small>State</small>	54658 <small>ORIS/Plant Code</small>
---	--	--

STEP 2

Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO₂ Opt-in unit, enter "yes" in column "b".

For new units or SO₂ Opt-in units, enter the requested information in columns "d" and "e."

a	b	c	d	e
Unit ID#	SO ₂ Opt-in Unit? (Yes or No)	Unit will hold allowances in accordance with 40 CFR 72.9(c)(1)	New or SO ₂ Opt-in Units Commence Operation Date	New or SO ₂ Opt-in Units Monitor Certification Deadline
1	No	Yes	N/A	N/A
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

Auburndale Power Partners

Plant Name (from STEP 1)

STEP 3

Read the
standard
requirements.

Acid Rain Part Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part.
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
 - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
- (4) For applications including a SO₂ Opt-in unit, a monitoring plan for each SO₂ Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO₂ Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
 - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
 - (ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

STEP 3,
Continued.

Auburndale Power Partners

Plant Name (from STEP 1)

Recordkeeping and Reporting Requirements (cont)

(iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

Liability

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 75.11 (NO_x averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

STEP 4

For SO₂ Opt-in units only.

In column "f" enter the unit ID# for every SO₂ Opt-in unit identified in column "a" of STEP 2.

For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.

In column "h" enter the hours.

f	g	h (not required for renewal application)
Unit ID#	Description of the combustion unit	Number of hours unit operated in the six months preceding initial application

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

Auburndale Power Partners

STEP 5

For SO₂ Opt-in units only.
(Not required for SO₂ Opt-in renewal applications.)

In column "i" enter the unit ID# for every SO₂ Opt-in unit identified in column "a" (and in column "f").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.

i	j	k	l	m	n
Unit ID#	Baseline or Alternative Baseline under 40 CFR 74.20 (mmBtu)	Actual SO ₂ Emissions Rate under 40 CFR 74.22 (lbs/mmBtu)	Allowable 1985 SO ₂ Emissions Rate under 40 CFR 74.23 (lbs/mmBtu)	Current Allowable SO ₂ Emissions Rate under 40 CFR 74.24 (lbs/mmBtu)	Current Promulgated SO ₂ Emissions Rate under 40 CFR 74.25 (lbs/mmBtu)

STEP 6

For SO₂ Opt-in units only.

Attach additional requirements, certify and sign.

- If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
- A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
- A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
- Attach a complete compliance plan for SO₂ under 40 CFR 72.40.
- The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
- The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."

STEP 7

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

Signature		Date	
Certification (for designated representative or alternate designated representative only)			
I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.			
Walter Lachney Name		Plant Manager Title	
Auburndale Power Partners, LP Owner Company Name			
(863) 965-1561 Phone		wlachney@calithnessenergy.com E-mail address	
Signature <i>Walter Lachney</i>		Date 2-24-10	

DEP Form No. 62-210.900(1)(a) - Form
Effective: 3/16/08

4

Auburndale Power Partners, L.P.
Auburndale Power Partners Plant

Permit No. 1050221-016-AV
Title V Air Operation Permit Renewal

SECTION V. CAIR PART

Clean Air Interstate Rule (CAIR).

Operated by: Auburndale Power Partners, L.P.

Plant Name: Auburndale Power Partners Plant

ORIS Code: 54658

The emissions unit below is regulated under the Clean Air Interstate Rule.

E.U. ID No.	EPA Unit ID#	Brief Description
001	1	This emissions unit is a nominal 156 MW combined cycle unit consisting of a combustion turbine-electrical generator set rated at 121.5 MW, an unfired heat recovery steam generator (HRSG) and a nominal 52 MW steam turbine-electrical generator set.

- Clean Air Interstate Rule Application.** The Clean Air Interstate Rule Part Form submitted for this facility is a part of this permit. The owners and operators of this CAIR unit as identified in this form must comply with the standard requirements and special provisions set forth in the CAIR Part Form (DEP Form No. 62-210.900(1)(b) - Form, Effective: 3/16/08), which is attached at the end of this section. [Chapter 62-213, F.A.C. and Rule 62-210.200, F.A.C.]

Clean Air Interstate Rule (CAIR) Part

This submission is: ☐ New ☒ Revised ☐ Renewal

**Identify the source by
plant name and ORIS
or EIA plant code**

Plant Name: Auburndale Power Partners	State: Florida	ORIS or EIA Plant Code: 54658
--	-----------------------	---

In column "a" enter the unit ID# for every CAIR unit at the CAIR source.

In columns "b," "c," and "d," indicate to which CAIR program(s) each unit is subject by placing an "X" in the column(s).

For new units, enter the requested information in columns "e" and "f."

[illegible]

SECTION V. CAIR PART

STEP 3

Read the
standard
requirements.

Auburndale Power Partners

Plant Name (from STEP 1)

CAIR NO_x ANNUAL TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO_x source and each CAIR NO_x unit at the source shall:
 - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
 - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO_x source and each CAIR NO_x unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO_x source and each CAIR NO_x unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NO_x source with the following CAIR NO_x Emissions Requirements.

NO_x Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x source and each CAIR NO_x unit at the source shall hold, in the source's compliance account, CAIR NO_x allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NO_x emissions for the control period from all CAIR NO_x units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
- (2) A CAIR NO_x unit shall be subject to the requirements under paragraph (1) of the NO_x Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR NO_x allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_x Requirements, for a control period in a calendar year before the year for which the CAIR NO_x allowance was allocated.
- (4) CAIR NO_x allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
- (5) A CAIR NO_x allowance is a limited authorization to emit one ton of NO_x in accordance with the CAIR NO_x Annual Trading Program. No provision of the CAIR NO_x Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO_x allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO_x allowance to or from a CAIR NO_x unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_x unit.

Excess Emissions Requirements.

If a CAIR NO_x source emits NO_x during any control period in excess of the CAIR NO_x emissions limitation, then:

- (1) The owners and operators of the source and each CAIR NO_x unit at the source shall surrender the CAIR NO_x allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NO_x source and each CAIR NO_x unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
 - (i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NO_x unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
 - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Annual Trading Program.
 - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_x Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Annual Trading Program.
- (2) The CAIR designated representative of a CAIR NO_x source and each CAIR NO_x unit at the source shall submit the reports required under the CAIR NO_x Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

SECTION V. CAIR PART

STEP 3, Continued

Auburndale Power Partners

Plant Name (from STEP 1)

Liability.

- (1) Each CAIR NO_x source and each CAIR NO_x unit shall meet the requirements of the CAIR NO_x Annual Trading Program.
- (2) Any provision of the CAIR NO_x Annual Trading Program that applies to a CAIR NO_x source or the CAIR designated representative of a CAIR NO_x source shall also apply to the owners and operators of such source and of the CAIR NO_x units at the source.
- (3) Any provision of the CAIR NO_x Annual Trading Program that applies to a CAIR NO_x unit or the CAIR designated representative of a CAIR NO_x unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_x Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x source or CAIR NO_x unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR SO₂ TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall:
 - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
 - (ii) [Reserved];
- (2) The owners and operators of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR SO₂ source and each SO₂ CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO₂ source with the following CAIR SO₂ Emission Requirements.

SO₂ Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO₂ allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO₂ units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
- (2) A CAIR SO₂ unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR SO₂ allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO₂ Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated.
- (4) CAIR SO₂ allowances shall be held in, deducted from, or transferred into or among CAIR SO₂ Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
- (5) A CAIR SO₂ allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO₂ Trading Program. No provision of the CAIR SO₂ Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR SO₂ allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO₂ allowance to or from a CAIR SO₂ unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO₂ unit.

Excess Emissions Requirements.

If a CAIR SO₂ source emits SO₂ during any control period in excess of the CAIR SO₂ emissions limitation, then:

- (1) The owners and operators of the source and each CAIR SO₂ unit at the source shall surrender the CAIR SO₂ allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

SECTION V. CAIR PART

STEP 3, Continued

Auburndale Power Partners.

Plant Name (from STEP 1)

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR SO₂ source and each CAIR SO₂ unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.
- (i) The certificate of representation under 40 CFR 96.213 for the CAIR designated representative for the source and each CAIR SO₂ unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.213 changing the CAIR designated representative.
- (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
- (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO₂ Trading Program.
- (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR SO₂ Trading Program.
- (2) The CAIR designated representative of a CAIR SO₂ source and each CAIR SO₂ unit at the source shall submit the reports required under the CAIR SO₂ Trading Program, including those under 40 CFR Part 96, Subpart HHH.

Liability.

- (1) Each CAIR SO₂ source and each CAIR SO₂ unit shall meet the requirements of the CAIR SO₂ Trading Program.
- (2) Any provision of the CAIR SO₂ Trading Program that applies to a CAIR SO₂ source or the CAIR designated representative of a CAIR SO₂ source shall also apply to the owners and operators of such source and of the CAIR SO₂ units at the source.
- (3) Any provision of the CAIR SO₂ Trading Program that applies to a CAIR SO₂ unit or the CAIR designated representative of a CAIR SO₂ unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR SO₂ Trading Program, a CAIR Part, or an exemption under 40 CFR 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO₂ source or CAIR SO₂ unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR NO_x OZONE SEASON TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall:
- (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
- (ii) [Reserved].
- (2) The owners and operators of each CAIR NO_x Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO_x Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO_x Ozone Season source with the following CAIR NO_x Ozone Season Emissions Requirements.

NO_x Ozone Season Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_x Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO_x emissions for the control period from all CAIR NO_x Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.
- (2) A CAIR NO_x Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO_x Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1), (2), or (3) and for each control period thereafter.
- (3) A CAIR NO_x Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_x Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO_x Ozone Season allowance was allocated.
- (4) CAIR NO_x Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.
- (5) A CAIR NO_x Ozone Season allowance is a limited authorization to emit one ton of NO_x in accordance with the CAIR NO_x Ozone Season Trading Program. No provision of the CAIR NO_x Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO_x Ozone Season allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO_x Ozone Season allowance to or from a CAIR NO_x Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_x Ozone Season unit.

SECTION V. CAIR PART

**STEP 3,
Continued**

Auburndale Power Partners

Plant Name (from STEP 1)

Excess Emissions Requirements.

If a CAIR NO_x Ozone Season source emits NO_x during any control period in excess of the CAIR NO_x Ozone Season emissions limitation, then:

- (1) The owners and operators of the source and each CAIR NO_x Ozone Season unit at the source shall surrender the CAIR NO_x Ozone Season allowances required for deduction under 40 CFR 96.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.

(i) The certificate of representation under 40 CFR 96.313 for the CAIR designated representative for the source and each CAIR NO_x Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Ozone Season Trading Program.

(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_x Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Ozone Season Trading Program.

(2) The CAIR designated representative of a CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall submit the reports required under the CAIR NO_x Ozone Season Trading Program, including those under 40 CFR Part 96, Subpart HHHH.

Liability.

(1) Each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit shall meet the requirements of the CAIR NO_x Ozone Season Trading Program.

(2) Any provision of the CAIR NO_x Ozone Season Trading Program that applies to a CAIR NO_x Ozone Season source or the CAIR designated representative of a CAIR NO_x Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO_x Ozone Season units at the source.

(3) Any provision of the CAIR NO_x Ozone Season Trading Program that applies to a CAIR NO_x Ozone Season unit or the CAIR designated representative of a CAIR NO_x Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.


No provision of the CAIR NO_x Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x Ozone Season source or CAIR NO_x Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

STEP 4

Certification (for designated representative or alternate designated representative only)

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Walter Lachney Name	Plant Manager Title
Auburndale Power Partners, LP Owner Company Name	
965-1561 Phone	wlachney@caithnessenergy.com E-mail address
Signature 	Date 2-24-10

SECTION VI. ECONOPAC SYSTEM PERFORMANCE CURVES

11/05/96 TUE 16:13 FAX 407 281 5032

(W) SITO

012

W501D5 ECONOPAC SYSTEM PERFORMANCE




FIGURE 2

SECTION VII. APPENDICES.

The Following Appendices Are Enforceable Parts of This Permit:

Appendix A, Glossary.

Appendix I, List of Insignificant Emissions Units and/or Activities.

Appendix ICE, Requirements for Internal Combustion Engines.

Appendix NESHAP, Subpart A – General Provisions.

Appendix NESHAP, Subpart ZZZZ – National Emissions Standards For Hazardous Air Pollutants For
Stationary Reciprocating Internal Combustion Engines.

Appendix NSPS, Subpart A – General Provisions.

Appendix NSPS, Subpart GG – Standards of Performance for Stationary Gas Turbines.

Appendix RR, Facility-wide Reporting Requirements.

Appendix TR, Facility-wide Testing Requirements.

Appendix TV, Title V General Conditions.

Appendix U, List of Unregulated Emissions Units and/or Activities.

REFERENCED ATTACHMENTS.

The Following Attachments Are Included for Applicant Convenience:

Figure 1, Summary Report-Gaseous and Opacity Excess Emission and
Monitoring System Performance (40 CFR 60, July, 1996).

Table H, Permit History.

Table 1, Summary of Air Pollution Standards and Terms.

Table 2, Compliance Requirements.

Permit History

Auburndale Power Partners Plant
Facility ID No: 1050221

EU No.	Description	Permit No.	Issue Date	Expiration Date	Extended Date ^{1,2}	Revised Date(s)
001	Combined Cycle Combustion Turbine	AC53-208321/ PSD-FL-185	12/14/92	10/30/95	11/1/96	6/20/94, 3/18/96, 5/22/97 2/26/02, xx/xx/xx
002	Fuel oil storage tanks (2)					
003	Emergency generators					
004	Heating units and engines					
005	Surface coating operations					
006	Simple Cycle Combustion Turbine	1050221-004-AC	6/26/01	6/26/06		
All	Initial Title V	1050221-002-AV	1/1/98	12/31/02		
001	Wet Compression System	1050221-005-AC	2/26/02	2/26/07		
006	Wet Compression System	1050221-006-AC	4/29/02	4/29/07		
All	Title V Renewal	1050221-007-AV	1/1/03	12/31/07		
All	PSD Modification	1050221-008-AC	11/18/02	11/18/07		
All	Title V Revision	1050221-009-AV	5/4/06	12/31/07		
All	Air Construction Permit Mod	1050221-010-AC	3/10/06	3/10/11		
All	Heat Input Modification	1050221-012-AC	2/7/08	2/7/09		
All	Title V Renewal	1050221-013-AV	1/1/08	12/31/12		
All	Title V Revision (heat input, testing)	1050221-014-AV	4/8/08	12/31/12		
001	CAIR Revision	1050221-015-AV	2/3/09	12/31/12		

Table 1, Summary of Air Pollutant Standards									
Auburndale Power Partners, L.P.				Permit No.: 1050221-016-AV					
Auburndale Power Partners Plant				Facility ID No.: 1050221					
This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.									
E.U. ID No.	Brief Description								
001	Combined Cycle Combustion Turbine								
			Allowable Emissions						
Pollutant Name	Fuel(s)	Hours/Year	Standard(s)	Regulatory Citation(s)	lbs./hour	Regulatory Citation(s)	TPY	Regulatory Citation(s)	See permit condition(s)
VE	Gas/Oil		<10% opacity at full load	see note #3					A.6.
			<20% opacity otherwise	see note #2					A.6.
PM ₁₀	Oil	400	0.0472 lb/mmBtu	see note #2	36.8	see note #1	7.4	see note #2	A.7.
PM ₁₀	Gas	8760	0.0134 lb/mmBtu	see note #2	10.5	see note #1	46.0	see note #2	A.7.
SO ₂	Oil	400	0.05 % sulfur content by weight	see note #1	70.0	see note #1	14.0	see note #2	A.8.
SO ₂	Gas	8760			40.0	see note #1	175.2	see note #2	A.8.
NO _x	Oil	400	42 ppmvd @15% O2, 24 hour block average	see note #1	230.0	see note #2	46.0	see note #2	A.9.
NO _x	Gas	8760	15 ppmvd @15% O2, 24 hour block average	see note #1	78.6	see note #2	177.0	see note #2, 4, and 5	A.9.
NO _x	Gas	8760	9 ppmvd @15% O2, 12 month rolling average					see note #2, 4, and 5	A.9.
VOC	Oil	400			10.0	see note #1	2.0	see note #2	A.10.
VOC	Gas	8760			6.0	see note #1	26.3	see note #2	A.10.
CO	Oil	400	25 ppmvd	see note #2	73.0	see note #1	14.6	see note #2	A.11.
CO	Gas	8760	21 ppmvd (min. load)	see note #2	43.5	see note #1	190.5	see note #2 and 5	A.11.
CO	Gas	8760	15 ppmvd (base load)	see note #2	43.5	see note #1	190.5	see note #2 and 5	A.11.
Notes:									
#1 - from BACT Determination									
#2 - from PSD-FL-185									
#3 - from Rule 62-296.320(4)(b), F.A.C.									
#4 - 1050221-004-AC									
#5 - dual fuel total									

Table 2, Summary of Compliance Requirements							
Auburndale Power Partners, L.P.			Permit No.: 1050221-016-AV				
Auburndale Power Partners Plant			Facility ID No.: 1050221				
This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.							
E.U. ID No.	Brief Description						
001	Combined Cycle Combustion Turbine						
			Testing	Frequency	Min. Compliance		
Pollutant Name		Compliance	Time	Base	Test		
or Parameter	Fuel(s)	Method	Frequency	Date *	Duration	CMS **	See permit condition(s)
VE	Gas	EPA Method 9	annual	June 4	1 hour		A.17.
SO ₂	Oil	(see note 2)	upon receipt of each oil shipment				A.14.
SO ₂	Gas	(see note 3)	bi-monthly				A.14.
NO _x	Gas	EPA Method 20	permit renewal (5 year)	June 4	3 hour	Yes	A.17.
VOC	Gas	EPA Method 25A	permit renewal (5 year)	June 4	3 hour		A.17.
CO	Gas	EPA Method 10	annual and permit renewal (5 year)	June 4	3 hour		A.17.
O ₂	Oil/Gas	EPA Method 3A	permit renewal (5 year)	June 4	3 hour	Yes	A.17.
Notes:							
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.							
**CMS [=] continuous monitoring system							
(2) Sulfur dioxide is indirectly determined by fuel sulfur analysis by ASTM D129-91; D1552-90; D2280-71; D2880-96; D2622-92; D4292; D4294-90; or the latest edition(s) methods specified or any other method approved in writing by the Department pursuant to Rule 62-297.620, F.A.C. or 40 CFR 75, Appendix D.							
(3) Sulfur dioxide is indirectly determined by fuel sulfur analysis by ASTM methods ASTM D1072-80, 90, 94; D3031-81, 86; D3246-81, 92; D4084-82, 94; D4468-85; D5504-94, or any other method approved in writing by the Department pursuant to Rule 62-297.620, F.A.C. or 40 CFR 75, Appendix D.							

Add
 DS453
 per A.14.