

TO: Howard L. Rhodes
FROM: Clair H. Fancy
DATE: December 30, 1997
SUBJECT: **FINAL Permit No.: 1050221-002-AV**
Auburndale Power Partners, Limited Partnership
Auburndale Cogeneration Facility

Issued

This permit is for the initial Title V air operation permit for the subject facility. This facility is a cogeneration plant consisting of a combined cycle combustion turbine cogeneration system rated at 156 total megawatts (MW) output. The combined cycle system is regulated under Acid Rain, Phase II. Also located at this facility are two distillate fuel oil storage tanks, and miscellaneous unregulated/insignificant emissions units and/or activities.

No comments were received from USEPA during their 45 day review period of the PROPOSED permit.

I recommend your signature.

Attachment

CHF/sms

[electronic file name: 1050221f.mem]

STATEMENT OF BASIS

Auburndale Power Partners, Limited Partnership
Auburndale Cogeneration Facility
Facility ID No.: 1050221
Polk County

Initial Title V Air Operation Permit
FINAL Permit No.: 1050221-002-AV

This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

This facility is a cogeneration plant consisting of a combined cycle combustion turbine cogeneration system rated at 156 total megawatts (MW) output. The combined cycle system consists of one combustion turbine (CT), one unfired heat recovery steam generator (HRSG), and one steam turbine-generator. The facility utilizes pipeline natural gas as its primary fuel source and low sulfur (0.05 % by weight) distillate fuel oil as a backup fuel source.

This facility operates a combined cycle combustion turbine (CT) cogeneration system with a combined total output of 156 MW. The combined cycle system consists of one 104 MW Westinghouse 501D5 combustion turbine (CT), one 52 MW steam turbine-generator, and one HRSG. The HRSG is not fuel fired. Water injection (all phases) and good combustion practices are used to control air pollutant emissions. This emissions unit is regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.; Rule 212.400, F.A.C., Prevention of Significant Deterioration (PSD) and Best Available Control Technology (BACT).

Also located at this facility are two distillate fuel oil storage tanks, and miscellaneous unregulated/insignificant emissions units and/or activities.

Based on the initial Title V permit application received October 26, 1995, this facility is not a major source of hazardous air pollutants (HAPs).

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
NOTICE OF FINAL PERMIT

In the Matter of an
Application for Permit by:


Mr. Bruce L. Franco
Executive Director
Auburndale Power Partners, L.P.
12500 Fair Lakes Circle, Suite 200
Fairfax, VA 22033

FINAL Permit No.: 1050221-002-AV
Auburndale Cogeneration Facility

Enclosed is FINAL Permit Number 1050221-002-AV for the operation of the Auburndale Cogeneration Facility located at 1501 Derby Avenue, Auburndale, Polk County, issued pursuant to Chapter 403, Florida Statutes (F.S.).

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the permitting authority in the Legal Office; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the permitting authority.

Executed in Tallahassee, Florida.


C. H. Fancy, P.E.
Chief
Bureau of Air Regulation

CHF/sms

CERTIFICATE OF SERVICE


The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF FINAL PERMIT (including the FINAL permit) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 12/31/97 to the person(s) listed or as otherwise noted:

Mr. Axel Santiago, APP
Mr. Thomas W. Davis, ECT
Mr. Bill Thomas, Southwest District Office
Ms. Carla E. Pierce, USEPA, Region 4 (INTERNET E-mail Memorandum)
Ms. Yolanda Adams, USEPA, Region 4 (INTERNET E-mail Memorandum)

12/31/97 cc: Scott Shepley
Reading Rule

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.


(Clerk) 12/31/97 (Date)

FINAL PERMIT DETERMINATION

FINAL Permit No.: 1050221-002-AV

Page 1 of 1

I. Comment(s).

No comments were received from USEPA during their 45 day review period of the PROPOSED permit.

II. Title V Permitting Formats.

A. CHANGES TO TITLE V PERMITS ISSUED PRIOR TO 12/02/97.

Title V permitting formats were updated due to recent rule changes and after considering comments received from the electric utilities. This permit reflects these changes. A brief summary of the changes is below.

1. Recent rule changes changed "exempt activities" to "insignificant activities." Rules 62-213.430(6), F.A.C. and 62-210, F.A.C., reflecting this change went into effect November 13, 1997.
 - a. The department inserted a condition in Appendix TV-1 clarifying that a Title V source can add an "insignificant activity" at its facility in accordance with the criteria under Rule 62-213.430(6), F.A.C., and include it in the Title V permit's list of "insignificant activities" at the next renewal, in accordance with Rule 62-213.430(6), F.A.C. See condition number 40.
 - b. Appendix E-1 has been changed to Appendix I-1, and the language of this appendix was revised to refer to insignificant emissions units where appropriate.
 - c. Appendix U-1 has been revised to refer to insignificant emissions units instead of exempt emissions units.
2. Several changes were made to Appendix TV-1 to reflect the rule changes discussed above, and to properly identify conditions that are not federally enforceable.
 - a. The following additional rules have been marked as "not federally enforceable":
 - 62-4.030, F.A.C., General Prohibition, (see condition number 1.)
 - 62-4.220, F.A.C., Operation Permit for New Sources, (see condition number 14.)
 - 62-210.300(5), F.A.C., Notification of Startup, (see condition number 19.)
 - b. Appendix TV-1, now carries a version date of "12/02/97".

III. Conclusion.

In conclusion, the changes that have been made are insignificant in nature and do not impose additional noticing requirements. The permitting authority hereby issues the FINAL Title V permit, with any changes noted above.

Is your RETURN ADDRESS completed on the reverse side?

SENDER:

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

1. ☐ Addressee's Address
2. ☐ Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:

Mr. Bruce L. Franco
Executive Director
Auburndale Power Partners, L.P.
12500 Fair Lakes Circle
Suite 200
Fairfax, VA 22033

4a. Article Number

P 263 584 661

4b. Service Type

- | | |
|---|---|
| <input type="checkbox"/> Registered | <input checked="" type="checkbox"/> Certified |
| <input type="checkbox"/> Express Mail | <input type="checkbox"/> Insured |
| <input type="checkbox"/> Return Receipt for Merchandise | <input type="checkbox"/> COD |

7. Date of Delivery

1-5-98

5. Received By: (Print Name)

8. Addressee's Address (Only if requested and fee is paid)

6. Signature: (Addressee or Agent)

X *Mr. J. Clark (CLARK)*

PS Form 3811, December 1994

Domestic Return Receipt

Thank you for using Return Receipt Service.

P 263 584 661

US Postal Service

Receipt for Certified Mail

No Insurance Coverage Provided.

Do not use for International Mail (See reverse)

Sent to	
Mr. Bruce L. Franco	
Street & Number	
12500 Fair Lakes Circle #200	
Post Office, State, & ZIP Code	
Fairfax, VA 22033	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	
12/31/97	
Auburndale Power Partners	
ID#1050221-002-AV	

PS Form 3800, April 1995

Auburndale Power Partners, Limited Partnership
Auburndale Cogeneration Facility
Facility ID No.: 1050221
Polk County

Initial Title V Air Operation Permit
FINAL Permit No.: 1050221-002-AV

Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resources Management
Bureau of Air Regulation
Title V Section
Mail Station #5505
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
Telephone: 850/488-1344
Fax: 850/922-6979

Compliance Authority:

State of Florida
Department of Environmental Protection
Southwest District Office
3804 Coconut Palm Drive
Tampa, Florida 33619-8218
Telephone: 813/744-6100
Fax: 813/744-6084

December 30, 1997

Initial Title V Air Operation Permit
FINAL Permit No.: 1050221-002-AV

Table of Contents

<u>Section</u>	<u>Page Number</u>
Placard Page	1
I. Facility Information	2 - 3
A. Facility Description.	
B. Summary of Emissions Unit ID No(s). and Brief Description(s).	
C. Relevant Documents.	
II. Facility-wide Conditions	4 - 5
III. Emissions Unit(s) and Conditions	
A. Combustion Turbine System	6 - 18
B. Fuel oil storage tanks (2)	19
IV. Acid Rain Part	
A. Acid Rain, Phase II	20



Department of Environmental Protection

Lawton Chiles
Governor

Virginia B. Wetherell
Secretary

Permittee:
Auburndale Power Partners,
Limited Partnership

FINAL Permit No.: 1050221-002-AV
Facility ID No.: 1050221
SIC Nos.: 49, 4911
Project: Initial Title V Air Operation Permit


This permit is for the operation of the Auburndale Cogeneration Facility. This facility is located at 1501 Derby Avenue, Auburndale, Polk County; UTM Coordinates: Zone 17, 420.8 km East and 3103.3 km North; Latitude: 28° 83' 15" North and Longitude: 81° 48' 21" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213, and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:

Appendix I-1, List of Insignificant Emissions Units and/or Activities
Appendix U-1, List of Unregulated Emissions Units and/or Activities
APPENDIX TV-1, TITLE V CONDITIONS (version dated 12/02/97)
APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)
FIGURE 1 - SUMMARY REPORT-GASEOUS AND OPACITY EXCESS EMISSION AND
MONITORING SYSTEM PERFORMANCE (version dated 7/96)
TABLE 297.310-1, CALIBRATION SCHEDULE (version dated 10/07/96)
Phase II Acid Rain Application/Compliance Plan received December 26, 1995
W501D5 ECONOPAC SYSTEM PERFORMANCE GRAPH CURVE LABELED
"POWER" - FIGURE 2
ORDER EXTENDING PERMIT EXPIRATION DATE dated 11/19/97

Effective Date: January 1, 1998
Renewal Application Due Date: July 5, 2002
Expiration Date: December 31, 2002


Howard L. Rhodes, Director
Division of Air Resources
Management

HLR/sms

Section I. Facility Information.

Subsection A. Facility Description.

This facility is a cogeneration plant consisting of a combined cycle combustion turbine cogeneration system rated at 156 total megawatts (MW) output. The combined cycle system consists of one combustion turbine (CT), one unfired heat recovery steam generator (HRSG), and one steam turbine-generator. The facility utilizes pipeline natural gas as its primary fuel source and low sulfur (0.05 % by weight) distillate fuel oil as a backup fuel source.

Also located at this facility are two distillate fuel oil storage tanks, and miscellaneous unregulated/insignificant emissions units and/or activities.

Based on the initial Title V permit application received October 26, 1995, this facility is not a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-001	Combustion Turbine System
-002	Fuel oil storage tanks (2)
-003	Emergency generators
-004	Heating units and engines
-005	Surface coating operations

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit. However, they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Table 1-1, Summary of Air Pollutant Standards and Terms

Table 2-1, Summary of Compliance Requirements

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers

Appendix H-1, Permit History / ID Number Changes

These documents are on file with permitting authority:

Initial Title V Permit Application received October 26, 1995

Letter dated April 26, 1996, changing the Responsible Official

Additional Information Request dated August 12, 1996

Additional Information Response received November 8, 1996

DRAFT Title V Permit issued February 6, 1997

Letter received from Mr. Bruce L. Franco dated March 19, 1997

PROPOSED PERMIT DETERMINATION with PROPOSED Title V Permit
dated November 14, 1997

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

1. APPENDIX TV-1, TITLE V CONDITIONS, is a part of this permit.

{Permitting note: APPENDIX TV-1, TITLE V CONDITIONS, is distributed to the permittee only. Other persons requesting copies of these conditions shall be provided one copy when requested or otherwise appropriate.}

2. **Not federally enforceable.** General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. The permittee shall not cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.
[Rule 62-296.320(2), F.A.C.]

3. Prevention of Accidental Releases (Section 112(r) of CAA). If required by 40 CFR 68, the permittee shall submit to the implementing agency:

- a. a risk management plan (RMP) when, and if, such requirement becomes applicable; and
- b. certification forms and/or RMPs according to the promulgated rule schedule.

[40 CFR 68]

4. Insignificant Emissions Units and/or Activities. Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit.

[Rules 62-213.440(1), 62-213.430(6) and 62-4.040(1)(b), F.A.C.]

5. Unregulated Emissions Units and/or Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.

[Rule 62-213.440(1), F.A.C.]

6. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.

[Rule 62-296.320(1)(a), F.A.C.]

7. General Particulate Emission Limiting Standards. General Visible Emissions Standard.

Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.

[Rule 62-296.320(4)(b)1., F.A.C.]

8. Not federally enforceable. The permittee shall take reasonable precautions, on an as needed basis, to prevent emissions of unconfined particulate matter at this facility to include:

- a. Chemical or water application to unpaved roads and unpaved yard areas;
- b. Paving and maintenance of roads, parking areas and yards;
- c. Landscaping or planting of vegetation;
- d. Confining abrasive blasting where possible; and
- e. Other techniques, as necessary.

[Rule 62-296.320(4)(c)2., F.A.C.; Proposed by applicant in the initial Title V permit application received October 26, 1995]

{Note: This condition implements the requirements of Rules 62-296.320(4)(c)1., 3., & 4. F.A.C., condition 58. of APPENDIX TV-1, TITLE V CONDITIONS.}

9. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.

[Rule 62-213.440, F.A.C.]

10. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year.

{See condition 52., APPENDIX TV-1, TITLE V CONDITIONS}

[Rule 62-214.420(11), F.A.C.]

11. The permittee shall submit all compliance related notifications and reports required of this permit to the Department's Southwest District office:

Department of Environmental Protection
Southwest District Office
3804 Coconut Palm Drive
Tampa, Florida 33619-8218
Telephone: 813/744-6100
Fax: 813/744-6084

12. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency
Region 4
Air, Pesticides & Toxics Management Division
Operating Permits Section
61 Forsyth Street
Atlanta, Georgia 30303
Telephone: 404/562-9099
Fax: 404/562-9095

Section III. Emissions Unit(s).

Subsection A. This section addresses the following emissions unit.

E.U.

<u>ID No.</u>	<u>Brief Description</u>
-001	Combustion Turbine System

This facility operates a combined cycle combustion turbine (CT) cogeneration system with a combined total output of 156 MW. The combined cycle system consists of one 104 MW Westinghouse 501D5 combustion turbine (CT), one 52 MW steam turbine-generator, and one HRSG. The HRSG is not fuel fired. Water injection (all phases) and good combustion practices are used to control air pollutant emissions.

{Permitting note: This emissions unit is regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.; Rule 212.400, F.A.C., Prevention of Significant Deterioration (PSD) and Best Available Control Technology (BACT).}

The following conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum heat input to the combustion turbine (CT) shall not exceed 1214 MMBtu/hr as determined using a lower heating value (LHV) at International Standards Organization (ISO) conditions while firing natural gas and 1170 MMBtu/hr as determined using a LHV at ISO conditions while firing No. 2 distillate fuel oil.
[Rule 62-4.160(2), F.A.C. and Rule 62-210.200, F.A.C., Definitions - (PTE)]

A.2. Methods of Operation - Fuels. Only natural gas or distillate (No. 2) fuel oil having a maximum sulfur content of 0.05 percent by weight shall be fired in the combustion turbine.
[Rules 62-4.160(2), F.A.C. and 62-213.410, F.A.C.]

A.3. Hours of Operation. This emissions unit is allowed to operate continuously, i.e., 8,760 hours/year. The total hours of operation of the combustion turbine while firing distillate fuel oil shall not exceed 400 hours/year.
[Rule 62-4.160(2), F.A.C. and Rule 62-210.200, F.A.C., Definitions - (PTE)]

Emission Limitations and Standards

{Permitting note: Table 1-1, Summary of Air Pollutant Standards and Terms, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.4. Visible emissions (VE) at full load (i.e., 156 MW) shall not exceed 10% opacity.
[Best Available Control Technology (BACT) Determination dated December 14, 1992.]

A.5. Visible emissions (VE) at other than full load shall not be equal to or greater than 20% opacity.
[PSD-FL-185]

A.6. Particulate matter ten (PM10) emissions shall not exceed
a. while firing natural gas:
0.0134 lb/mmBtu (see note #2); 10.5 lbs./hour (see note #1); 46 TPY (see note #2);
and
b. while firing distillate fuel oil:
0.0472 lb/mmBtu (see note #2); 36.8 lbs./hour (see note #1); 7.4 TPY (see note #2).
[Notes: #1 - BACT Determination dated December 14, 1992; #2 - PSD-FL-185]

A.7. Sulfur dioxide (SO2) emissions shall not exceed
a. while firing natural gas:
40.0 lbs./hour (see note #1); 175.2 TPY (see note #2)
b. while firing distillate fuel oil:
0.05 % sulfur content by weight (see note #1); 70.0 lbs./hour (see note #1); 14 TPY
(see note #2).
[Notes: #1 - BACT Determination dated December 14, 1992; #2 - PSD-FL-185]

A.8. Nitrogen oxides (NOx) emissions shall not exceed
a. while firing natural gas:
up to 12/31/98: 25 ppmvd @15% O2, 24-hour block average (see note #1);
131.0 lbs./hour (see note #2); 573.8 TPY (see note #2);
by 12/31/98: 15 ppmvd @15% O2, 24-hour block average (see note #1);
78.6 lbs./hour (see note #2); 344.3 TPY (see note #2);
b. while firing distillate fuel oil:
42 ppmvd @15% O2, 24-hour block average (see note #1);
230.0 lbs./hour (see note #2); 46 TPY (see note #2).

c. 24-hour block averages: 24-hour block averages are calculated as follows:
At the same time each day, a 24-hour block average shall be calculated for the monitored operating hours in the previous 24 hour period. The 24-hour block average shall be determined by summing the hourly average NOx concentrations for all valid monitored operating hours and dividing by the number of hourly average NOx

concentrations in the previous 24 hour period. A monitored operating hour is each hour in which fuel is fired in the combustion turbine and at least two continuous emissions monitoring systems (CEMS) emission measurements are recorded at least 15 minutes apart. CEMS data taken during periods of: startup, shutdown, or malfunction as defined in Rules 62-210.200 and 62-210.700 F.A.C., when fuel is not fired in the unit, or during CEMS quality assurance checks or when the CEMS is out of control shall be excluded from the 24-hour block average.

[Notes: #1 - BACT Determination dated December 14, 1992; #2 - PSD-FL-185]

A.9. Volatile organic compound (VOC) emissions shall not exceed

- a. while firing natural gas: 6.0 lbs./hour (see note #1); 26.3 TPY (see note #2); and
- b. while firing distillate fuel oil: 10.0 lbs./hour (see note #1); 2.0 TPY (see note #2).

[Notes: #1 - BACT Determination dated December 14, 1992; #2 - PSD-FL-185]

A.10. Carbon monoxide (CO) emissions shall not exceed

- a. while firing natural gas: 21 ppmvd @ minimum load (see note #2); 15 ppmvd @ base load (see note #2); 43.5 lbs./hour (see note #1); 190.5 TPY (see note #2). and
- b. while firing distillate fuel oil: 25 ppmvd (see note #2); 73.0 lbs./hour (see note #1); 14.6 TPY (see note #2).

[Notes: #1 - BACT Determination dated December 14, 1992; #2 - PSD-FL-185]

A.11. Sulfuric acid mist emissions shall not exceed

- a. while firing natural gas: 7.5 lbs./hour (see note #1); 32.9 TPY (see note #2); and
- b. while firing distillate fuel oil: 14.0 lbs./hour (see note #1); 2.8 TPY (see note #2).

[Notes: #1 - BACT Determination dated December 14, 1992; #2 - PSD-FL-185]

Excess Emissions

A.12. Excess emissions from this emissions unit resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration.

[Rule 62-210.700(1), F.A.C.]

A.13. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.

[Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

A.14. At all times, including periods of startup, shutdown and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance

procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

[40 CFR 60.11(d)]

A.15. The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG and using water injection to control NO_x emissions shall install and operate a continuous monitoring system (CMS) to monitor and record the fuel consumption and the ratio of water to fuel being fired in the turbine. This system shall be accurate to within ± 5.0 percent and shall be approved by the Administrator. The NO_x CEMS will be used in lieu of the water/fuel monitoring system and fuel bound nitrogen (FBN) monitoring, which are required in 40 CFR 60.334.

[40 CFR 60.334(a); PSD-FL-185]

A.16. The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60, Subpart GG shall monitor sulfur content and nitrogen content of the fuel being fired in the turbine. Pursuant to the custom monitoring schedule provisions of 40 CFR 60.334(b)(2), the frequency of determination of these values shall be as follows:

- (a) Monitoring of the nitrogen content of distillate fuel oil is not required. Sulfur content of distillate fuel oil shall be determined for each shipment of distillate fuel oil received; and
- (b) Monitoring of the nitrogen content of pipeline natural gas is not required. Sulfur content of pipeline natural gas will be based on twice-monthly analyses provided by the natural gas supplier.

[40 CFR 60.334(b)(1) and (2)]

A.17. Determination of Process Variables.

(a) **Required Equipment.** The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) **Accuracy of Equipment.** Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

Test Methods and Procedures

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.18. Visible Emissions (VE). The test method for VE shall be EPA Method 9, incorporated by reference in Chapter 62-297, F.A.C.

[Rules 62-213.440, 62-297.310, and 62-297.401, F.A.C.; and, PSD-FL-185, revised March 18, 1996]

A.19. Particulate Matter Ten (PM10). The test methods for PM10 emissions, for distillate fuel oil-firing only, shall be Methods 5, 17, 201, or 201A, incorporated by reference in Chapter 62-297, F.A.C.

[Rules 62-213.440, 62-297.310, and 62-297.401, F.A.C.; and, PSD-FL-185, revised March 18, 1996]

A.20. To compute the nitrogen oxides emissions, the owner or operator shall use analytical methods and procedures that are accurate to within 5 percent and are approved by the Department to determine the nitrogen content of the fuel being fired.

[40 CFR 60.335(a)]

A.21. For purposes of demonstrating compliance with NSPS - 40 CFR 60, Subpart GG, the monitoring device of 40 CFR 60.334(a) shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with the permitted NO_x standard at 30, 50, 75, and 100 percent of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer.

[40 CFR 60.335(c)(2)]

A.22. a. The owner or operator shall determine compliance with the nitrogen oxides and sulfur dioxide standards in 40 CFR 60.332 as follows: U.S. EPA. Method 20 (40 CFR 60, Appendix A) shall be used to determine the nitrogen oxides, sulfur dioxide, and oxygen concentrations. The span values shall be 300 ppm of nitrogen oxide and 21 percent oxygen. The NO_x emissions shall be determined at each of the load conditions specified in 40 CFR 60.335(c)(2).

b. For purposes of demonstrating compliance with the NO_x emission limits (in lbs/hr and tons/yr) specified in Condition A.8, either EPA Method 20 (at 90 - 100% of permitted maximum capacity load only) or the relative accuracy (RA) test data pursuant to 40 CFR 60 Appendix B Performance Specification 2 Section 7 shall be used. The NO_x CEMS shall be used for the purpose of demonstrating compliance with the NO_x emission limit (24-hour block average concentration limit) specified in Condition A.8.

[40 CFR 60.335(c)(3); PSD-FL-185]

A.23. The owner or operator shall determine compliance with the sulfur content standard of 0.05 percent, by weight, as follows: ASTM D129-91; D1552-90; D2280-71; D2880-96; D2622-92; D4292; D4294-90; or the latest edition(s) shall be used to determine the sulfur content of liquid fuels and ASTM D1072-80, 90, 94; D3031-81, 86; D3246-81, 92; D4084-82, 94; D4468-85; D5504-94; or the latest edition(s) shall be used for the sulfur content of gaseous fuels (incorporated by reference-see 40 CFR 60.17). The applicable ranges of some ASTM methods

mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the approval of the Administrator.

[40 CFR 60.335(d); PSD-FL-185]

A.24. To meet the requirements of 40 CFR 60.334(b), the owner or operator shall use the methods specified in 40 CFR 60.335(a) and 40 CFR 60.335(d) of 40 CFR 60.335 or the latest edition(s) to determine the sulfur contents of the fuel being burned. The analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

[40 CFR 60.335(e); PSD-FL-185]

A.25 Volatile organic compound (VOC). Compliance with the VOC standard shall be demonstrated using EPA Method 25A.

[Rules 62-213.440, 62-297.310, and 62-297.401, F.A.C.; and, PSD-FL-185, revised March 18, 1996]

A.26. Carbon monoxide (CO). Compliance with the CO standard shall be demonstrated using EPA Method 10.

[Rules 62-213.440, 62-297.310, and 62-297.401, F.A.C.; and, PSD-FL-185, revised March 18, 1996]

A.27. Sulfuric Acid Mist. Compliance with the sulfuric acid mist standard shall be demonstrated using EPA Method 8.

[Rules 62-213.440, 62-297.310, and 62-297.401, F.A.C.; and, PSD-FL-185, revised March 18, 1996]

A.28. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards.

[Rule 62-297.310(1), F.A.C.]

A.29. Operating Rate During Testing.

a. This emissions unit shall operate between 90% and 100% of permitted capacity during the compliance test(s) as adjusted for ambient temperature (compressor inlet temperature) (See attached W501D5 ECONOPAC SYSTEM PERFORMANCE GRAPH, CURVE LABELED "POWER" - FIGURE 2.)

b. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.
[PSD-FL-185; and, Rule 62-297.310(2), F.A.C.]

A.30. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.
[Rule 62-297.310(3), F.A.C.]

A.31. Applicable Test Procedures.

(a) Required Sampling Time.

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.

b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) Minimum Sample Volume. Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) Required Flow Rate Range. For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle

and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in TABLE 297.310-1, CALIBRATION SCHEDULE (attached).

(e) Allowed Modification to EPA Method 5. When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube. [Rule 62-297.310(4), F.A.C.]

A.32. The permittee shall comply with the requirements contained in APPENDIX SS-1, Stack Sampling Facilities, attached to this permit.
[Rule 62-297.310(6), F.A.C.]

A.33. Frequency of Compliance Tests. The following provisions apply only to the combustion turbine system and only for the pollutants listed in Conditions A.4 through A.11 for which compliance testing is required.

(a) Compliance Testing.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. A compliance test shall be conducted for nitrogen oxides/oxygen, volatile organic compounds, carbon monoxide, and sulfuric acid mist prior to obtaining a renewed operation permit. Compliance testing is only required during the combustion of natural gas fuel. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 -- September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions (VE);

b. Carbon monoxide (CO); and

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

8. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit.

9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

(b) Special Compliance Tests. When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it may require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.

(c) Waiver of Compliance Test Requirements. If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a baghouse or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.; SIP approved; PSD-FL-185]

A.34. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.

(b) The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends

or other flow disturbances.

8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12. The type, manufacturer and configuration of the sampling equipment used.
13. Data related to the required calibration of the test equipment.
14. Data on the identification, processing and weights of all filters used.
15. Data on the types and amounts of any chemical solutions used.
16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18. All measured and calculated data required to be determined by each applicable test procedure for each run.
19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.
[Rule 62-297.310(8), F.A.C.]

Record Keeping and Reporting Requirements

A.35. For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions that shall be reported are defined as follows:

a. *Nitrogen Oxides.* The NO_x CEMS will be used in lieu of the water/fuel monitoring system and fuel bound nitrogen (FBN) monitoring, which are required in 40 CFR 60.334. The NO_x CEMS shall be used to report excess emissions during periods of startup, shutdown, and malfunction in lieu of FBN monitoring and the water/fuel monitoring system described in 40 CFR 60.334(c)(1).

b. *Sulfur dioxide.* Any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.05 percent.

[40 CFR 60.334(c); PSD-FL-185]

A.36. The owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate). Written reports of excess emissions shall include the following information:

(1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.

(2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.

(3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.

(4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)(1), (2), (3), and (4)]

A.37. The summary report form shall contain the information and be in the format shown in FIGURE 1 - SUMMARY REPORT-GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

(1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

(2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

[40 CFR 60.7(d)(1) and (2)]

A.38. (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

(i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;

(ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and

(iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)]

A.39. Any owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

A.40. Malfunction Reporting. In the case of excess emissions resulting from malfunctions, each owner or operator shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C.. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.
[Rule 62-210.700(6), F.A.C.]

Miscellaneous Requirements

A.41. Definitions. For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.
[40 CFR 60.2; and, Rule 62-204.800(7)(a), F.A.C.]

A.42. Circumvention. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.
[40 CFR 60.12]

A.43. In order to comply with the lower NO_x limit by December 31, 1998, the permittee shall make appropriate combustion technology improvements or install a selective catalytic reduction (SCR) system.
[Revised BACT Determination dated June 20, 1994; PSD-FL-185]

A.44. The following information shall be submitted with the AOR: the sulfur content and lower heating value of the fuel fired, fuel usage, and hours of operation.
[PSD-FL-185, Condition number 27.]

Subsection B. This section addresses the emissions unit(s).

E.U.

ID No. Brief Description

-002 Fuel oil storage tanks (2)

The facility operates two 623,280 gallons distillate (No. 2) fuel oil storage tanks referred to as "STR-001" and "STR-002". Each tank has a fixed cone roof and is equipped with pressure/vacuum conservation vents.

{Permitting note: These emissions units are 'unregulated emissions units.' The tanks are subject to a recordkeeping requirement under NSPS - 40 CFR 60, Subpart Kb, Standards of Performance for Volatile Organic Liquid Storage Vessels; adopted and incorporated by reference in Rule 62-204.800(7), F.A.C.}

The following conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

B.1. Hours of Operation. These emissions units are allowed to operate continuously, i.e., 8,760 hours/year.

[Rule 62-4.160(2), F.A.C. and Rule 62-210.200, F.A.C., Definitions - (PTE)]

Recordkeeping Requirements

B.2. The permittee shall maintain records on site for storage vessels identification numbers STR-001 and STR-002 to include the date of construction, the material storage capacity, and type of material stored for the life of these storage vessels.

[40 CFR 60.116b(b)]

Section IV. This section is the Acid Rain Part.

Operated by: Auburndale Power Partners, Limited Partnership

ORIS code: 54658

The emissions unit(s) listed below is regulated under Acid Rain Part, Phase II.

E.U.

ID No. Brief Description

-001 Combustion Turbine System

A.1. The Phase II Acid Rain Part application submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of this Phase II acid rain unit must comply with the standard requirements and special provisions set forth in the application listed below:

- a. DEP Form No. 62-210.900(1)(a), effective 07/01/95, received December 26, 1995.
[Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

A.2. Sulfur dioxide (SO₂) allowance allocations for each Acid Rain unit is as follows:

<u>E.U. ID</u> <u>No.</u>	<u>EPA ID</u>	<u>Year</u>	2000	2001	2002
-001	1	SO ₂ allowances, under Table 2 or 3 of 40 CFR Part 73	0*	0*	0*

*The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 or 3 of 40 CFR 73.

A.3. Emission Allowances. Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

1. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.

2. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.

3. Allowances shall be accounted for under the Federal Acid Rain Program.
[Rule 62-213.440(1)(c), F.A.C.]

A.4. Fast-Track Revisions of Acid Rain Parts. Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, Fast-Track Revisions of Acid Rain Parts. [Rules 62-213.413 and 62-214.370(4), F.A.C.]

A.5. Comments, notes, and justifications:

a. A superseded version of DEP Form 62.210.900(1)(a), effective 01/02/95, received October 26, 1995, was originally submitted as part of the Title V air operation permit application.

b. The designated representative was changed by letter dated April 29, 1996, with a revised Certificate of Authorization.

Appendix I-1, List of Insignificant Emissions Units and/or Activities.

Auburndale Power Partners,
Limited Partnership
Auburndale Cogeneration Facility

FINAL Permit No.: 1050221-002-AV

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62-210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Emissions Units and/or Activities Description

1. Comfort heating with a gross maximum heat input of less than one million Btu per hour.
2. Vacuum pumps in laboratory operations.
3. Sanders having a total sanding surface of five square feet or less and other equipment used exclusively on woods or plastics or their products having a density of 20 pounds per cubic foot or more.
4. Equipment used exclusively for space heating, other than boilers.
5. Laboratory equipment used exclusively for chemical or physical analyses (including fume hoods and vents).
6. Surface coating operations utilizing only coatings containing 5.0 percent or less VOCs, by volume.
7. Degreasing units using heavier-than-air vapors exclusively, except any unit using or emitting any substance classified as a hazardous air pollutant.
8. No. 2 Fuel Oil Truck Unloading Equipment.
9. Oil/Water Separators.
10. Freshwater cooling towers. The cooling towers do not use chromium-based water treatment chemicals.
11. Refrigeration Units.
12. Lube Oil Vents Associated with Rotating Equipment.
13. Lube Oil Tank Vents.
14. Internal combustion engines used for transportation of passengers and freight.
15. Steam cleaning equipment.
16. Fire and safety equipment.
17. Brazing, soldering, or welding equipment.

Appendix U-1, List of Unregulated Emissions Units and/or Activities.

Auburndale Power Partners,
Limited Partnership
Auburndale Cogeneration Facility

FINAL Permit No.: 1050221-002-AV

Unregulated Emissions Units and/or Activities. An emissions unit which emits no "emissions-limited pollutant" and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither 'regulated emissions units' nor 'insignificant emissions units'.

E.U.

<u>ID No.</u>	<u>Brief Description of Emissions Units and/or Activity</u>
-003	One or more emergency generators which are not subject to the Acid Rain Program and have total fuel consumption, in the aggregate, of 32,000 gallons per year or less of diesel fuel, 4,000 gallons per year or less of gasoline, and 4.4 million cubic feet per year or less of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
-004	One or more heating units and general purpose internal combustion engines which are not subject to the Acid Rain Program and have total fuel consumption, in the aggregate, of 32,000 gallons per year or less of diesel fuel, 4,000 gallons per year or less of gasoline, and 4.4 million cubic feet per year or less of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
-005	Surface coating operations utilizing 6.0 gallons per day or less, averaged monthly, of coatings containing greater than 5.0 percent VOCs, by volume.

United States
Environmental Protection Agency
Acid Rain Program

OMB No. 2060-0221
Expires 6-30-95



Certificate of Representation

Page 1

For more information, see instructions and refer to 40 CFR 72.24

This submission is: ☐ New ☒ Revised

STEP 1
Identify the source by
plant name, State, and
ORIS code from NADB

Plant Name Auburndale Cogeneration Facility	State FL	54658 ORIS Code
--	-----------------	---------------------------

STEP 2
Enter requested
information for the
designated
representative

Name Bruce L. Franco, P.E.	
Address 12500 Fair Lakes Circle Suite 200 Fairfax, VA 22033	
Phone Number (703) 222-0445	Fax Number (703) 227-2760

STEP 3
Enter requested
information for the
alternate designated
representative
(optional)

Name	
Address	
Phone Number	Fax Number

STEP 4
Complete Step 5, read
the certifications and
sign and date

I certify that I was selected as the designated representative or alternate designated representative, as applicable, by an agreement binding on the owners and operators of the affected source and each affected unit at the source.

I certify that I have given notice of the agreement, selecting me as the designated representative or alternate designated representative, as applicable for the affected source and each affected unit at the source identified in this certificate of representation, daily for a period of one week in a newspaper of general circulation in the area where the source is located or in a State publication designed to give general public notice.

I certify that I have all necessary authority to carry out my duties and responsibilities under the Acid Rain Program on behalf of the owners and operators of the affected source and of each affected unit at the source and that each such owner and operator shall be fully bound by my actions, inactions, or submissions.

I certify that I shall abide by any fiduciary responsibilities imposed by the agreement by which I was selected as designated representative or alternate designated representative, as applicable.

I certify that the owners and operators of the affected source and of each affected unit at the source shall be bound by any order issued to me by the Administrator, the permitting authority, or a court regarding the source or unit.

Where there are multiple holders of a legal or equitable title to, or a leasehold interest in, an affected unit, or where a utility or industrial customer purchases power from an affected unit under life-of-the-unit, firm power contractual arrangements, I certify that:

I have given a written notice of my selection as the designated representative or alternate designated representative, as applicable, and of the agreement by which I was selected to each owner and operator of the affected source and of each affected unit at the source; and

Allowances and the proceeds of transactions involving allowances will be deemed to be held or distributed in proportion to each holder's legal, equitable, leasehold, or contractual reservation or entitlement or, if such multiple holders have expressly provided for a different distribution of allowances by contract, that allowances and the proceeds of transactions involving allowances will be deemed to be held or distributed in accordance with the contract.

The agreement by which I was selected as the alternate designated representative includes a procedure for the owners and operators of the source and affected units at the source to authorize the alternate designated representative to act in lieu of the designated representative.

Auburndale Cogeneration Facility
Plant Name (from Step 1)

Certificate Page 2

Page ☐ of ☐

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Signature (designated representative) <i>Burns Law</i>	Date 4/25/96
Signature (alternate)	Date

STEP 5

Provide the name of every owner and operator of the source and each affected unit at the source. Identify the units they own and/or operate by boiler ID# from NADB. For owners only, identify each state or local utility regulatory authority with jurisdiction over each owner

Name Auburndale Power Partners, L.P.						<input checked="" type="checkbox"/> Owner	<input type="checkbox"/> Operator
ID# 1	ID#	ID#	ID#	ID#	ID#	ID#	
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
Regulatory Authorities							

Name Mission Operation & Maintenance, Inc.						<input type="checkbox"/> Owner	<input checked="" type="checkbox"/> Operator
ID# 1	ID#	ID#	ID#	ID#	ID#	ID#	
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
Regulatory Authorities							

Name						<input type="checkbox"/> Owner	<input type="checkbox"/> Operator
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
Regulatory Authorities							

Name						<input type="checkbox"/> Owner	<input type="checkbox"/> Operator
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
Regulatory Authorities							

Phase II Permit Application

Page 1

For more information, see instructions and refer to 40 CFR 72.30 and 72.31 and Chapter 62-214, F.A.C.

This submission is: ☒ New ☐ Revised

STEP 1
Identify the source by
plant name, State, and
ORIS code from NADB

Auburndale Cogeneration Facility Plant Name	FL State	54658 ORIS Code
--	-------------	--------------------

STEP 2
Enter the boiler ID#
from NADB for each affected
unit, and
indicate whether a
repowering plan is
being submitted for
the unit by entering
"yes" or "no" at
column c. For new
units, enter the re-
quested information
in columns d and e

Compliance Plan				
a	b	c	d	e
Boiler ID#	Unit Will Hold Allow- ances in Accordance with 40 CFR 72.9(c)(1)	Repowering Plan	New Units Commence Operation Date	New Units Monitor Certification Deadline
1	Yes	No	7/94	1/1/95 - SO ₂ 1/1/96 - NO _x , CO ₂
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			

STEP 3
Check the box if the
response in column c
of Step 2 is "Yes"
for any unit

☐ For each unit that will be repowered, the Repowering Extension Plan form is included and the Repowering Technology Petition form has been submitted or will be submitted by June 1, 1997.

Auburndale Cogeneration Facility

STEP 4

Read the standard requirements and certification, enter the name of the designated representative, and sign and date

Standard Requirements

Permit Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Submit a complete Acid Rain part application (including a compliance plan) under 40 CFR part 72, Rules 62-214.320, and 330, F.A.C. in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain part application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain part application or a superseding Acid Rain part issued by the permitting authority; and
 - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
 - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
 - (ii) All emissions monitoring information, in accordance with 40 CFR part 75;
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

Auburndale Cogeneration Facility

Recordkeeping and Reporting Requirements (cont.)

(iv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability.


- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 75, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities. No provision of the Acid Rain Program, an Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	Don Fields, Executive Director, Auburndale Power Partners, Limited Partnership	
Signature		Date 12/19/95

STEP 5 (optional)
Enter the source AIRS
and FINDS identification
numbers, if known

AIRS	1050221
FINDS	FL0000361220

W501D5 ECONOPAC SYSTEM PERFORMANCE




FIGURE 2

Table 1-1, Summary of Air Pollutant Standards and Terms											
Auburndale Power Partners, L.P.											
Auburndale Cogeneration Facility			FINAL Permit No.: 1050221-002-AV								
			Facility ID No.: 1050221								
This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.											
E.U. ID No.			Brief Description								
-001			Combustion Turbine System								
			Allowable Emissions								
			Equivalent Emissions*								
Pollutant Name	Fuel(s)	Hours/Year	Standard(s)	Regulatory Citation(s)	lbs./hour	Regulatory Citation(s)	TPY	Regulatory Citation(s)	lbs./hour	TPY	See permit condition(s)
VE	Gas/Oil		<10% opacity at full load	see note #2							III.A.4.
			<20% opacity otherwise	see note #3							III.A.5.
PM10	Oil	400	0.0472 lb/mmBtu	see note #2	36.8	see note #1	7.4	see note #2			III.A.6.
PM10	Gas	8760	0.0134 lb/mmBtu	see note #2	10.5	see note #1	46.0	see note #2			III.A.6.
SO2	Oil	400	0.05 % sulfur content by weight	see note #1	70.0	see note #1	14.0	see note #2			III.A.7.
SO2	Gas	8760			40.0	see note #1	175.2	see note #2			III.A.7.
NOx	Oil	400	42 ppmvd @15% O2, 24 hour block average	see note #1	230.0	see note #2	46.0	see note #2			III.A.8.
NOx	Gas	8760	25 ppmvd @15% O2, 24 hour block average (up to 12/31/98)	see note #1	131.0	see note #2	573.8	see note #2			III.A.8.
NOx	Gas	8760	15 ppmvd @15% O2, 24 hour block average (by 12/31/98)	see note #1	78.6	see note #2	344.3	see note #2			III.A.8.
VOC	Oil	400			10.0	see note #1	2.0	see note #2			III.A.9.
VOC	Gas	8760			6.0	see note #1	26.3	see note #2			III.A.9.
CO	Oil	400	25 ppmvd	see note #2	73.0	see note #1	14.6	see note #2			III.A.10.
CO	Gas	8760	21 ppmvd (min. load)	see note #2	43.5	see note #1	190.5	see note #2			III.A.10.
CO	Gas	8760	15 ppmvd (base load)	see note #2	43.5	see note #1	190.5	see note #2			III.A.10.
Sulfuric Acid Mist	Oil	400			14.0	see note #1	2.8	see note #2			III.A.11.
Sulfuric Acid Mist	Gas	8760			7.5	see note #1	32.9	see note #2			III.A.11.
Notes:											
* The "Equivalent Emissions" listed are for informational purposes only.											
#1 - from BACT Determination											
#2 - from PSD-FL-185											
#3 - from Rule 62-296.320(4)(b), F.A.C.											
[electronic file name: 10502211.xls]											

Table 2-1, Summary of Compliance Requirements							
Auburndale Power Partners, L.P.					FINAL Permit No.: 1050221-002-AV		
Auburndale Cogeneration Facility					Facility ID No.: 1050221		
This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions o							
E.U. ID No.		Brief Description					
-001		Combustion Turbine System					
				Testing	Frequency	Min. Compliance	
Pollutant Name		Compliance		Time	Base	Test	
or parameter		Fuel(s)	Method	Frequency	Date *	Duration	CMS ** See permit condition(s)
VE	Gas	EPA Method 9	annual	June 4	1 hour		III.A.18., 33.
SO2	Oil	(see note 2)	upon receipt of each oil shipment				III.A.22., 23.
SO2	Gas	(see note 2)					III.A.22., 23.
NOx	Gas	EPA Method 20	permit renewal (5 year)	June 4	3 hour	Yes	III.A.22., 33.
VOC	Gas	EPA Method 25A	permit renewal (5 year)	June 4	3 hour		III.A.25., 33.
CO	Gas	EPA Method 10	permit renewal (5 year)	June 4	3 hour		III.A.26., 33.
Sulfuric Acid Mist	Oil	EPA Method 8	permit renewal (5 year)	June 4	3 hour		III.A.27., 33.
O2	Oil/Gas	EPA Method 3A	permit renewal (5 year)	June 4	3 hour	Yes	III.A.22., 33.
Notes:							
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.							
**CMS [=] continuous monitoring system							
(2) Sulfur dioxide is indirectly determined by fuel sulfur analysis by methods specified or any other method approved in writing by the Department pursuant to Rule 62-297.620, F.A.C. or 40 CFR 75, Appendix D.							
[electronic file name: 10502212.xls]							

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers (version dated 02/05/97)

Abbreviations and Acronyms:

°F: Degrees Fahrenheit
BACT: Best Available Control Technology
CFR: Code of Federal Regulations
DEP: State of Florida, Department of Environmental Protection
DARM: Division of Air Resource Management
EPA: United States Environmental Protection Agency
F.A.C.: Florida Administrative Code
F.S.: Florida Statute
ISO: International Standards Organization
LAT: Latitude
LONG: Longitude
MMBtu: million British thermal units
MW: Megawatt
ORIS: Office of Regulatory Information Systems
SOA: Specific Operating Agreement
UTM: Universal Transverse Mercator

Citations:

The following examples illustrate the methods used in this permit to abbreviate and cite the references of rules, regulations, guidance memorandums, permit numbers, and ID numbers.

Code of Federal Regulations:

Example: [40 CFR 60.334]

Where:	40	reference to	Title 40
	CFR	reference to	Code of Federal Regulations
	60	reference to	Part 60
	60.334	reference to	Regulation 60.334

Florida Administrative Code (F.A.C.) Rules:

Example: [Rule 62-213, F.A.C.]

Where:	62	reference to	Title 62
	62-213	reference to	Chapter 62-213
	62-213.205	reference to	Rule 62-213.205, F.A.C.

ISO: International Standards Organization refers to those conditions at 288 degrees K, 60 percent relative humidity, and 101.3 kilopascals pressure.

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers
(version dated 02/05/97) (continued)

Identification Numbers:

Facility Identification (ID) Number:

Example: Facility ID No.: 1050221

Where:

105 = 3-digit number code identifying the facility is located in Polk County
0221 = 4-digit number assigned by state database.

Permit Numbers:

Example: 1050221-002-AV, or
1050221-001-AC

Where:

AC = Air Construction Permit
AV = Air Operation Permit (Title V Source)
105 = 3-digit number code identifying the facility is located in Polk County
0221 = 4-digit number assigned by permit tracking database
001 or 002 = 3-digit sequential project number assigned by permit tracking database

Example: PSD-FL-185
PA95-01
AC53-208321

Where:

PSD = Prevention of Significant Deterioration Permit
PA = Power Plant Siting Act Permit
AC = old Air Construction Permit numbering

Appendix H-1, Permit History/ID Number Changes

Auburndale Power Partners, Limited Partnership
Auburndale Cogeneration Facility

FINAL Permit No.: 1050221-002-AV
Facility ID No.: 1050221

Permit History (for tracking purposes):

<u>E.U.</u> <u>ID No.</u>	<u>Description</u>	<u>Permit No.</u>	<u>Issue Date</u>	<u>Expiration Date</u>	<u>Extended Date</u> ^{1,2}	<u>Revised Date(s)</u>
-001	Combined Cycle Combustion Turbine	AC53-208321/ PSD-FL-185	12/14/92	10/30/95	11/1/96	6/20/94, 3/18/96, 5/22/97

ID Number Changes (for tracking purposes):

From: Facility ID No.: 40TPA530221

To: Facility ID No.: 1050221

Added:

E.U. ID

<u>No.</u>	<u>Brief Description</u>
-002	Fuel oil storage tanks (2)
-003	Emergency generators
-004	Heating units and engines
-005	Surface coating operations

Notes:

1 - AO permit(s) automatic extension(s) in Rule 62-210.300(2)(a)3.a., F.A.C., effective 03/21/96.

2 - AC permit(s) automatic extension(s) in Rule 62-213.420(1)(a)4., F.A.C., effective 03/20/96.

{Rule 62-213.420(1)(b)2., F.A.C., effective 03/20/96, allows Title V Sources to operate under existing valid permits}



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

Mr. Bruce L. Franco
Executive Director
Auburndale Power Partners, L.P.
12500 Fair Lakes Circle, Suite 200
Fairfax, VA 22033

ORDER EXTENDING PERMIT EXPIRATION DATE Auburndale Cogeneration Facility, Facility ID No.: 1050221

Section 403.0872(2)(b), Florida Statutes (F.S.), specifies that any facility which submits to the Department of Environmental Protection (Department) a timely and complete application for a Title V permit "is entitled to operate in compliance with its existing air permit pending the conclusion of proceedings associated with its application."

Section 403.0872(6), F.S., provides that a proposed Title V permit which is not objected to by the United States Environmental Protection Agency (EPA) "must become final no later than fifty-five (55) days after the date on which the proposed permit was mailed" to the EPA.

Pursuant to the Federal Acid Rain Program as defined in rule 62-210.200, Florida Administrative Code (F.A.C.), all Acid Rain permitting must become effective on January 1 of a given year.

This facility which will be permitted pursuant to section 403.0872, F.S., (Title V permit) will be required to have a permit effective date subsequent to the final processing date of the facility's Title V permit.

To prevent misunderstanding and to assure that the above identified facility continues to comply with existing permit terms and conditions until its Title V permit becomes effective, it is necessary to extend the expiration date(s) of its existing valid permit(s) until the effective date of its Title V permit. Therefore, under the authority granted to the Department by section 403.061(8), F.S., **IT IS ORDERED:**

1. The expiration date(s) of the existing valid permit(s) under which the above identified facility is currently operating is (are) hereby extended until the effective date of its permit issued pursuant to section 403.0872, F.S., (Title V permit);
2. The facility shall comply with all terms and conditions of its existing valid permit(s) until the effective date of its Title V permit;
3. The facility will continue to comply with the requirements of Chapter 62-214, F.A.C., and the Federal Acid Rain Program, as defined in rule 62-210.200, F.A.C., pending final issuance of its Title V permit.

PETITION FOR ADMINISTRATIVE REVIEW

The Department will take the action described in this Order unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 of the Florida Statutes (F.S.). Mediation under Section 120.573, F.S., will not be available for this proposed action.

A person whose substantial interests are affected by the Department's proposed decision may petition for an administrative hearing in accordance with sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. Petitions must be filed within 21 days of receipt of this Order. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of the Florida Statutes, or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with rule 28-5.207 of the Florida Administrative Code.

A petition must contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department File Number, and the county in which the project is proposed;
- (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
- (d) A statement of the material facts disputed by the petitioner, if any;
- (e) A statement of the facts that the petitioner contends warrant reversal or modification of the Department's action or proposed action;
- (f) A statement identifying the rules or statutes that the petitioner contends require reversal or modification of the Department's action or proposed action; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the Department to take with respect to the action or proposed action addressed in this notice of intent.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this Order. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under section 120.542 of the Florida Statutes. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. The petition must specify the following information:

- (a) The name, address, and telephone number of the petitioner;

(b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any;

(c) Each rule or portion of a rule from which a variance or waiver is requested;

(d) The citation to the statute underlying (implemented by) the rule identified in (c) above;

(e) The type of action requested;

(f) The specific facts that would justify a variance or waiver for the petitioner;

(g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and

(h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in section 120.542(2) of the Florida Statutes, and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.


This Order constitutes final agency action unless a petition is filed in accordance with the above paragraphs.

RIGHT TO APPEAL

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Notice of Agency Action is filed with the Clerk of the Department.

DONE AND ORDERED this 18 day of Nov, 1997 in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



HOWARD L. RHODES, Director
Division of Air Resources Management
Twin Towers Office Building
Mail Station 5500
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
850/488-0114

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this order and all copies were sent by certified mail before the close of business on 11/19/97 to the person(s) listed:

Mr. Bruce L. Franco, APP

Mr. Bill Thomas, Southwest District Office

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

Barbara J. Boutwell 11/19/97
(Clerk) (Date)

FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
PERMITTING APPLICATION PROJECT EVENT SUMMARY REPORT

04-JUN-01

Facility: AUBURNDALE COGENERATION FACILITY AIRS ID: 1050221
 Owner: CALPINE/AUBURNDALE POWER PARTNERS, LP County: POLK
 Office: SW: TAMPA

----- PROJECT -----

AIR Permit #: 1050221-002-AV Project #: 002 CRA Reference #: 2070
 Permit Office: TAL (HEADQUARTERS) Agency Action: Issued
 Project name: AUBURNDALE COGEN FACILITY Desc: TITLE V PERMIT
 Type/Sub/Req: AV/00 / Air Operate
 Received: 26-OCT-1995 Issued: 31-DEC-1997 Expires: 31-DEC-2002
 Fee: \$000.00 Realized: Dele: Override: NONE

----- PROJECT EVENTS -----

Event	Begin Date	Prd Due Date	Rmn Status	End Date
Receive Request	26-OCT-1995	1 27-OCT-1995	000 Done	26-OCT-1995
Initial Completeness Review	26-OCT-1995	60 25-DEC-1995	000 Complete	25-DEC-1995
Awaiting Detailed Review	25-DEC-1995	365 24-DEC-1996	000 Begin Detailed R	12-AUG-1996
Detailed Completeness Review	12-AUG-1996	60 11-OCT-1996	000 Incomplete	12-AUG-1996
RESET CLOCK	12-AUG-1996	1 13-AUG-1996	000 Done	12-AUG-1996
Awaiting Additional Information	12-AUG-1996	90 10-NOV-1996	000 Received	08-NOV-1996
Completeness Review	08-NOV-1996	30 08-DEC-1996	000 Complete	08-NOV-1996
Determine Agency Action	08-NOV-1996	90 06-FEB-1997	000 Issue	06-FEB-1997
Draft Permit	06-FEB-1997	1 07-FEB-1997	000 Issue	06-FEB-1997
Date of Publication	06-FEB-1997	999 02-NOV-1999	000 Published	18-FEB-1997
Public Comment Period	18-FEB-1997	30 20-MAR-1997	000 Done	20-MAR-1997
Proposed Permit	20-MAR-1997	1 21-MAR-1997	000 Issue	14-NOV-1997
EPA Review	14-NOV-1997	55 08-JAN-1998	000 No Comment	31-DEC-1997
Final Permit	31-DEC-1997	1 01-JAN-1998	000 Issued	31-DEC-1997
ISSUE PERMIT	31-DEC-1997	1 01-JAN-1998	000 Issued	31-DEC-1997
STOP CLOCK	06-FEB-1997	1 07-FEB-1997	000 Done	06-FEB-1997

Date: 1/2/98 2:04:23 PM
From: Mary Fillingim TAL
Subject: New Posting
To: See Below

There is a new posting available on Florida's website.

1050221
AUBURNDALE POWER PARTNERS, LP.

FINAL

Please let me know if you have any questions.

Thanks,
Mary

To: adams yolanda
To: pierce carla
To: Barbara Boutwell TAL
To: Scott Sheplak TAL
To: Terry Knowles TAL
To: danois gracy
To: Elizabeth Walker TAL
CC: Scott Sheplak TAL