



June 30, 1998

Mr. Clair Fancy, P.E., Chief
Bureau of Air Regulation
Florida Department of Environmental Protection
111 S. Magnolia, Suite 4
Tallahassee, Florida 32301

RECEIVED
JUL 01 1998
BUREAU OF
AIR REGULATION

Dear Mr. Fancy:

Re: Hines Energy Complex Air Permit
PSD-FL-195 and Site Certification PA-92-33

Construction on the Hines Energy Complex is nearing completion and startup of the combined cycle units is anticipated in early July 1998. For several months now, I have been working with Mr. Martin Costello, of your staff, on revisions to the above-referenced PSD permit. The revisions were necessary in order to make the permit conditions compatible with the Westinghouse equipment that was ultimately installed, rather than the General Electric equipment that was the basis for our original permit. Our permitting efforts have also been influenced by the development schedule of the dry low NO_x (DLN) combustors proposed for this project and their ability to meet the limits required by the original PSD permit that was issued on February 25, 1994.

Florida Power Corporation (FPC), as recently as April 1998, was pursuing permit revisions that would have allowed the combined cycle units at our Hines Energy Complex to operate at NO_x levels as high as 173 lb/hr (based on 25 ppmvd at 59°F) until the proposed combustors could be developed to the point that they could achieve the original BACT limit of 73 lb/hr (based on 12 ppmvd at 59°F). Draft final permit language was negotiated that would have allowed FPC to operate at these higher NO_x levels until as long as April 1, 2000. At that time, if the original BACT limit could still not be met with DLN technology, the draft negotiated language called for the installation of an SCR system designed to meet a NO_x level of 9 ppmvd. In order to finalize the agreement, the Department requested a firm commitment from FPC management (in a letter to FPC dated April 21, 1998) that the Hines' units would be available to Westinghouse to the extent necessary to achieve the goals of their development schedule.

Subsequent discussions between FPC and Westinghouse have now led to a decision that the prudent course of action is to proceed with the installation of an SCR system designed to control NO_x to the level required in our original PSD permit. Therefore, FPC will not be asking

for relief to emit at higher levels while combustor development occurs, or for any additional time in which to achieve compliance. We will meet our original NO_x commitment with SCR while combustor development concurrently takes place. When the originally proposed DLN combustors are available to meet the current permit limits, FPC will then consider installation of those combustors and the removal of the SCR as an option.

In light of these developments, FPC does not believe that the issues raised in the Department's letter of April 21, 1998 need to be further addressed. Mr. Al Linero, Chief of New Source Review, has informed me that Mr. Costello has taken on a new assignment and that this permitting effort has now been assigned to Mr. Syed Arif. Mr. Arif has indicated that an FPC response to the Department's last correspondence (i.e., the April 21, 1998 letter) was necessary in order for further permit processing to occur. Further, it was requested that FPC submit information pertinent to the SCR system. The requested information is included as an attachment to this letter. Finally, Mr. Arif has indicated that upon receipt of this information, FPC could meet with him and Mr. Linero to finalize revised permit language. A tentative meeting date of June 30, 1998 has been set.

As mentioned earlier, startup at the site is anticipated within several weeks. FPC requests that the revised permit be finalized in a timely manner; to that end I will personally be available to your staff to expedite the permitting process. If you should have any questions, please do not hesitate to contact me at (813) 866-5158.

Sincerely,



Scott H. Osbourn
Senior Environmental Engineer

Attachment

cc: Al Linero, DEP
Syed Arif, DEP

**TECHNICAL SPECIFICATION FOR AN
SCR SYSTEM FOR THE
FPC HINES ENERGY PROJECT**

Written by:	<i>Russel D. Prescott</i> R. D. Prescott, Engineer Thermal Cycle & BOP System Design	12/2/97 Date
Reviewed by:	<i>G. Pyros</i> G. Pyros, Engineer Thermal Cycle & BOP System Design	12/2/97 Date
Reviewed by:	<i>Bruce Rising</i> B. Rising, Engineer Environmental Engineering	12/2/97 Date
Approved by:	<i>Steven J. Knott</i> S. J. Knott, Technical Group Leader Thermal Cycle & BOP System Design	12/2/97 Date
Approved by:	<i>M. S. Briesch</i> M. S. Briesch, Manager Thermal Cycle & BOP System Design	12/3/97 Date

FLORIDA POWER CORPORATION
HINES ENERGY COMPLEX PBI
FPC CONTRACT: G6001079
B & V FILE: 18875.62.1003 GES

ISSUED FOR CONSTRUCTION

Reference: _____
WBS: 255
Review Level: 5

STEAM TURBINE &
AUXILIARIES

(W) GSD



This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97	Page: 1 of 38

TABLE OF CONTENTS

SECTION	PAGE
REVISION SHEET	2
1.0 DOCUMENT SCOPE	4
2.0 SYSTEM APPLICATION AND SCOPE OF SUPPLY	6
3.0 PERFORMANCE AND EQUIPMENT GUARANTEES	7
4.0 DESIGN REQUIREMENTS - GENERAL	9
5.0 DESIGN REQUIREMENTS - CATALYST	10
6.0 DESIGN REQUIREMENTS - CATALYST BED AND HOUSING; MECHANICAL ..	11
7.0 DESIGN REQUIREMENTS - AMMONIA INJECTION SYSTEM	13
8.0 QUALITY, SHOP TEST AND SHIPPING REQUIREMENTS	16
9.0 FIELD ERECTION AND START UP ASSISTANCE	17
10.0 DOCUMENTATION AND INFORMATION REQUIREMENTS	18
FIGURE 1 - SCR SYSTEM LAYOUT : PLAN VIEW	38

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL.	Issue Date: 12/3/97	Page: 3 of 38

1.0 DOCUMENT SCOPE

- 1.1 This specification, together with the contract document and all documents referenced herein, covers the scope of supply and technical design requirements for a Selective Catalytic Reduction (SCR) system to reduce Nitrogen Oxide (NOx) emissions for the 2x1 501F FPC-Hines Energy Combined Cycle Project.
- 1.2 All conflicts between the requirements of this specification, design specification data sheets, related specifications, and standard codes shall be brought to the attention of the Buyer for clarification before proceeding with the design or manufacture of the affected parts.
- 1.3 Reference Documents

The design, fabrication, testing, and inspection of the SCR system shall be in accordance with this document and the documents referenced herein.

1.3.1 Westinghouse Specifications and Documents (latest revisions)

- 21T5673 Supplier Data Requirements for Software Deliverables
- 21T5802 Supplier Quality Requirements
- 21T7360 Paint Specification for FPC-Polk County, Florida
- 21T7397 Specification for a Heat Recovery Steam Generator for FPC-Hines Energy Project
- 21T7525 Acoustical Requirements for FPC-Polk County Project

1.3.2 Codes and Standards (latest editions apply)

1.3.2.1 American Institute of Steel Construction (AISC)

- a. "Specification for the Design, Fabrication, and Erection of Structural Steel for Buildings."

1.3.2.2 American National Standard Institute (ANSI)

- a. ANSI B16.5, "Steel Pipe Flanges and Flanged Fittings."
- b. ANSI B16.11 for Threaded and Socket Welding Fittings.
- c. ANSI B16.9 for Butt Welding Fittings.
- d. ANSI B31.1, "Power Piping."

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2

DOCUMENT NO. 21T8900

DISTRIBUTION CODE: 273-000-604

TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT

TYPE
ESP

REV
001



WESTINGHOUSE POWER GENERATION
POWER GENERATION BUSINESS UNIT - ORLANDO, FL

Issue Date: 12/3/97

Page: 4 of 38

1.3.2.3 American Society of Mechanical Engineers (ASME)

- a. ASME Section II, "Material Specifications."
- b. ASME Section VIII, Division 1, "Rules for the Construction of Pressure Vessels," plus addenda (if applicable to ammonia injection system).
- c. ASME Section IX, "Welding and Brazing Qualifications."

1.3.2.4 American Society for Testing and Materials (ASTM)

In general, all materials of construction not required to be covered by the ASME code shall conform to the latest edition of the applicable ASTM Standard. Other materials may be used provided that they are of a "recognizable quality" as determined by Buyer. Materials conforming to foreign standards (BS, DIM, JIS, etc.) may be used provided that "material equivalency" is proven by the manufacturer to the satisfaction of the Buyer.

1.3.2.5 American Welding Society (AWS)

- a. AWS D1.1, "Structural Welding Code."
- b. Structural welds shall be done in accordance with AWS welding procedures. ASME Code Certified Welders may be used instead of AWS certified welders.

1.3.2.6 Federal Occupational Safety and Health Act (OSHA)


- a. OSHA 2206, "OSHA Safety and Health Standards (29 CFR 1910)."

1.3.2.7 Building Codes

The catalyst and housing shall be designed and constructed in accordance with the building codes indicated in Westinghouse Specification 21T7397, "Heat Recovery Steam Generator (HRSG) for the FPC-Hines Energy Project."

1.3.2.8 Electrical Codes

Electrical equipment supplied shall comply with the latest applicable codes and standards of the NFPA National Electrical Code, the Institute of Electrical and Electronic Engineers (IEEE), the National Electrical Manufacturers Association (NEMA), and the National Electrical Code (NEC). Requirements for electrical equipment certification shall be in accordance with local building codes.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.				
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604		
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP	REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97		Page: 5 of 38	

1.3.2.10 American Standards Association (ASA).

1.3.2.11 American Iron and Steel Institute (AISI).

1.3.2.12 Underwriters Laboratories

All applicable instruments shall be supplied with a UL label.

1.3.2.13 U.S. Environmental Protection Agency (EPA) as applicable to emissions testing.

1.3.3 Other Codes or Standards

The Seller shall list in his proposal any additional codes or standards that he intends to use in the design and manufacture of his equipment. Additional codes or standards are subject to approval by the Buyer.

2.0 SYSTEM APPLICATION AND SCOPE OF SUPPLY

- 2.1 The SCR catalyst shall reduce NOx from the exhaust of a combustion turbine. The system application and design requirements are indicated in Sections 4.0 through 7.0 and the DESIGN SPECIFICATION data sheets. The performance guarantees that shall be met are indicated in Section 3.0 and on the SELLER GUARANTEE data sheet.
- 2.2 The Seller shall supply two (2) complete SCR systems, one for each Heat Recovery Steam Generator (HRSG). The SCR systems shall be opposite hand (skid and piping on outboard side of HRSG), but otherwise identical in design. See Figure 1 at the end of this specification.
- 2.3 The Seller's scope of supply shall be as indicated on the Seller SCOPE OF SUPPLY data sheets.
- 2.4 The following items are specifically excluded from the Seller's scope of supply unless indicated otherwise on the Seller SCOPE OF SUPPLY data sheets:
- 2.4.1 Foundations, anchor bolts, and other embedments required for support of the reactor housing, ammonia injection header, and ammonia injection skid.
- 2.4.2 Heat tracing and/or insulation of hot air piping, miscellaneous drain lines, instrumentation lines, etc. required for freeze or personnel protection which are not on the ammonia injection skid.
- 2.4.3 Nitrogen supply for nitrogen purge of ammonia injection system.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.

DOCUMENT NO. 21T8900

DISTRIBUTION CODE: 273-000-604

TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT

TYPE
ESP

REV
001



WESTINGHOUSE POWER GENERATION
POWER GENERATION BUSINESS UNIT - ORLANDO, FL

Issue Date: 12/3/97

Page: 6 of 38

- 2.4.4 All motor starting equipment and control centers (MCC's) for fan drives, pump drives, or motor operated valves.
- 2.4.5 All control and electrical wiring and conduit external to the ammonia injection skid.
- 2.4.6 Final painting of the reactor housing.
- 2.4.7 Erection and installation of the catalyst reactor, catalyst modules, and ammonia injection skid.
- 2.4.8 Materials for field welding (electrodes, etc.).

3.0 PERFORMANCE AND EQUIPMENT GUARANTEES

The Seller shall meet the following guarantees for each SCR System.. These guarantees shall also be contained in the special Terms and Conditions of the SCR System Contract between Buyer and Seller.


3.1 Emission Guarantees

Emission guarantees shall be made for all operating conditions indicated on the PERFORMANCE INFORMATION and SELLER GUARANTEE data sheets.

The NOx and SO3 concentrations for the guarantees will be measured using EPA Reference Test Methods (40 CFR Part 60, Appendix A). (SO3 emissions will be measured as H2SO4). The inlet concentrations shall be measured using the sampling ports discussed in this specification, upstream of the catalyst bed. The outlet concentrations shall be measured using the stack sampling ports. To preclude the formation of ammonia-sulfur compounds from SO3, the ammonia injection into the gas stream will be interrupted for this test. For the ammonia slip guarantee the outlet concentrations will be measured at the stack sampling ports using an EPA approved method.

3.2 Pressure Drop Guarantee

The maximum pressure drop measured from immediately downstream of the inlet interface with the HRSG to immediately upstream of the outlet interface with the HRSG, shall be guaranteed based on the value indicated in the SELLER GUARANTEE data sheet.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Page: 7 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Issue Date: 12/3/97	

3.3 Catalyst Life Guarantee

3.3.1 The catalyst life guarantee shall be indicated on the SELLER GUARANTEE data sheet.

3.3.2 The "life" is defined as the period of time in which each catalyst can meet all the guarantees stated in paragraphs 3.1 through 3.2, including the operational requirements indicated on the DESIGN SPECIFICATION data sheet.

3.4 Used Catalyst Disposal Guarantee

3.4.1 The Seller shall provide and guarantee disposal of the used catalyst at no additional cost except shipping charges provided that:


a. The used catalyst is not damaged or contaminated in any way with elements/compounds that would substantially alter the disposability of the catalyst.

b. The laws and regulations regarding the handling, transportation, storage, disposal, and/or treatment of the used catalyst are substantially unchanged from those in effect on the date of the sales contract.

3.4.2 It is the responsibility of the Seller to indicate to the Buyer before the sales contract any elements/compounds which could alter the disposability of the catalyst. Also, the Seller shall inform the Buyer of any pending legislation regarding the handling, transportation, storage, disposal, and/or treatment of the used catalyst.

3.5 Acoustical Guarantee

The Seller shall comply with and guarantee the sound level requirements as specified in Westinghouse Specification 21T7525 - "Acoustical Requirements for the FPC-Polk County Project."

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97	Page: 8 of 38	

4.0 DESIGN REQUIREMENTS - GENERAL

4.1 Codes

- 4.1.1 In addition to those specifications, codes, and standards referenced in Section 1.0 of this document, each SCR system shall comply with all state and local codes applicable for the location at which the equipment is to be installed. The responsibility for compliance with these codes rests solely with the Seller.
- 4.1.2 All equipment furnished under this specification shall allow each SCR system to be operated and maintained in accordance with the Federal Occupational Safety and Health Act.

4.2 Catalyst Bed Location

Each catalyst shall be located in the project specific Heat Recovery Steam Generator (HRSG) at the location described on the DESIGN SPECIFICATION data sheets, with the expected temperature range at this location.

4.3 Flow and Temperature Maldistribution


Each catalyst shall be designed for gas flow and temperature maldistribution entering the catalyst as specified on the DESIGN SPECIFICATION data sheets.

4.4 Catalyst Operating Requirements

- 4.4.1 Each catalyst shall be capable of operating in the cyclic duty mode. Start up and shutdown can be on a daily basis.
- 4.4.2 Each catalyst shall be designed to withstand the number of starts indicated on the DESIGN SPECIFICATION data sheets.
- 4.4.3 Each catalyst shall be capable of being operated within specification limits within one hour from a cold HRSG start, provided inlet concentrations are within design values.
- 4.4.4 Start up of each catalyst shall be automatic and initiated from the plant's central control room.

4.5 Catalyst Sampling

- 4.5.1 Two samples of each catalyst shall be retained before shipping the catalyst to the job site. One shall be forwarded to Buyer for storage. The other sample shall be tested by the Seller to ensure the catalyst meets specifications. The results of this test shall be presented to Buyer before shipment of the catalyst.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.				
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604.		
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP	REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97		Page: 9 of 38	

4.5.2 Each catalyst bed shall be equipped with provisions for periodic catalyst sampling. If removable catalyst sections are used to meet sampling requirements, one complete set of spare catalyst sample blocks shall be provided.

4.6 Manufacturing Requirements

4.6.1 All equipment supplied by the Seller shall be manufactured in one complete assembly or in sub-assemblies. All assemblies shall be designed and manufactured to enable the largest pieces possible to be shipped to the plant site.

4.6.2 All equipment shall be designed and constructed to minimize field welding. Where field welding is required, all joints shall be prepared for welding before shipment.

4.7 Welding

4.7.1 All structural welds shall be in accordance with Section IW of Appendix B of 21T7397.

4.7.2 All external welds shall be continuous, full seam welds to prevent rust streaking.

4.8 Surface Preparation


4.8.1 Seller's standard practice for surface preparations of interior surfaces shall be used. For exterior surfaces, the Seller shall conduct surface preparation in accordance with Westinghouse Specification 21T7360, "Paint Specification for FPC Polk County, Florida."

4.8.2 The pipes for the ammonia injection system shall be internally cleaned to remove metal shavings and rust before installation.

4.8.3 All materials shall be cleaned of foreign matter, scale, flux, and weld splatter prior to painting.

5.0 DESIGN REQUIREMENTS - CATALYST

5.1 The design point to be used by the Seller for the design of each catalyst shall be selected from the operating conditions presented in the PERFORMANCE INFORMATION data sheets. The Seller shall design each catalyst to meet all guarantees under the worst case conditions from the data sheets. The design conditions used shall be clearly stated by Seller.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.				
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604		
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP	REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97		Page: 10 of 38	

- 5.2 Each catalyst shall maintain the design removal efficiencies as stated on the PERFORMANCE INFORMATION data sheets as long as the inlet NOx concentrations (ppmvd basis) remain at or below the design values, and that the catalyst operating temperature is maintained within the range given in the SELLER GUARANTEE data sheet.

6.0 DESIGN REQUIREMENTS - CATALYST BED AND HOUSING; MECHANICAL

6.1 Housing Mechanical Design

Each catalyst housing shall be complete with catalyst support structure, inner liner, insulation, and outer casing. Materials of construction for the catalyst housing shall be compatible with the materials used for the HRSG. Seller shall clearly communicate and coordinate with HRSG Seller at interface points.

6.1.1 Outer Casing

6.1.1.1 The outer casing shall be gas tight and shall be a "cold wall" design.

6.1.1.2 The casing shall be manufactured from carbon steel plate, ¼ inch minimum thickness, and reinforced with stiffeners.

6.1.1.3 The internal design pressure of the catalyst housing shall be a minimum of 20 inches of water.

6.1.2 Inner Casing


6.1.2.1 The inner liner shall be constructed of type 409 or 304 stainless steel. Any Type 304 stainless steel exposed to the exhaust gases and which is welded upon, shall be of the low carbon type.

6.1.2.2 Due to the large thermal transients to which the ductwork shall be subjected, the Seller's design shall include adequate provisions for thermal expansion on the inner casing.

6.1.3 Insulation

6.1.3.1 Sufficient insulation shall be installed between the outer and inner casings so that at design conditions the outer casing cold face temperature at any point does not exceed 140 °F with an 80 °F ambient in still air.

6.1.3.2 10 gauge insulation studs and retaining clips shall be installed between liner anchors as required to prevent sagging of the insulation on the ceiling walls.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Issue Date: 12/3/97
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Page: 11 of 38	

6.1.3.3 Insulation shall be fire proof and asbestos free.

6.1.4 Catalyst Housing Doors

6.1.4.1 One access opening shall be provided on the HRSG roof with handrail and ladder access.

6.1.4.2 Access doors shall also be provided upstream and downstream of each catalyst bed.

6.1.4.3 All doors shall be hinged and insulated, and shall be a minimum of 18 in. by 24 in.

6.1.5 Interface with HRSG

6.1.5.1 The HRSG interface dimensions for each catalyst are to be worked out between the catalyst Seller and the HRSG Seller. Transitions from the catalyst housing to the HRSG duct may be used to interface the two systems and allow a larger section for each catalyst.

6.1.5.2 The catalyst housing interface, supports, and piping shall be designed so that expansion joints are not required.

6.1.5.3 The scope of supply for the interfacing between the catalyst Seller and HRSG Seller shall be as indicated on the SCOPE OF SUPPLY data sheets.


6.1.6 Housing Drains

Each catalyst housing shall be equipped with drains located at the lowest point of the housing. The drains shall be sized based on the washing requirements of the catalyst if washing is part of the potential maintenance. If washing is not necessary or is performed outside the housing, drains shall be sized based on HRSG draining requirements.

6.2 Catalyst Support Structure

6.2.1 Each catalyst module shall be supported with minimum clearance, and seals should be made to prevent gas by-pass.

6.2.2 In some housing designs it may be required to provide space for additional catalyst or provide additional support structure for addition of catalyst after plant has been in operation. These requirements shall be indicated on the Seller SCOPE OF SUPPLY data sheets.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.				
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604		
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP	REV 001
	WESTINGHOUSE POWER GENERATION		Issue Date: 12/3/97	
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		Page: 12 of 38	

6.3 Catalyst Housing Structural Loads

6.3.1 Live loads shall be taken as 100 lbs/ft².

6.3.2 Wind loading and seismic loading shall be as defined by the applicable building code referenced in Specification 21T7397.

6.3.3 Thermal loadings shall be calculated by the Seller for submission to the HRSG Seller.

6.3.4 Each catalyst housing shall accept all loads imposed on it by the HRSG.

6.4 Catalyst Housing Sampling Ports

6.4.1 All sampling ports and monitoring equipment shall be in compliance with EPA requirements.

6.4.2 Seller shall supply a minimum of 7 equally spaced ports along the vertical dimension of the housing for the measurement of temperature and flow distributions, inlet NO_x, and ammonia injection distributions. Sampling ports shall be provided upstream and downstream of each catalyst bed. The ports upstream of the catalyst shall be downstream of the ammonia injection grid.

6.4.3 A permanent gas side thermocouple shall be installed upstream of each catalyst bed to monitor inlet temperature.


7.0 DESIGN REQUIREMENTS - AMMONIA INJECTION SYSTEM

An aqueous ammonia injection system shall be supplied by the Seller that will take aqueous ammonia forwarded from a storage vessel (by others), vaporize the ammonia, mix it with a dilution medium, and inject it into the exhaust gas stream at the proper location and in the proper proportions. Scope of supply requirements for the injection system are given in the Seller SCOPE OF SUPPLY data sheets. Detailed design requirements are given in this section.

7.1 Ammonia Injection System - General

7.1.1 All ammonia injection system components supplied by the Seller shall be free of ammonia leaks. The detectable limit shall be determined by odor such that no ammonia shall be detectable by sense of smell in any area.

7.1.2 A solenoid operated emergency shut-off valve shall be provided for any ammonia supply line or steam supply line to the injection system.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.				
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604		
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP	REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97		Page: 13 of 38	

Ammonia/dilution medium mixer shall be provided to obtain proper dilute concentrations of ammonia. The Seller shall measure both dilution medium and ammonia flow rates such that dilute concentrations can be continuously monitored. The ammonia concentration after mixing with the dilution medium shall be a maximum of 5% by volume.

7.3 Ammonia Injection Grid (AIG)


- 7.3.1 Because temperature and flow maldistribution are more likely to occur vertically in the HRSG, the AIG shall be designed with horizontal injection pipes to allow for adjusting ammonia flow along the entire height of the catalyst bed. Also, provisions shall be provided for vertical injection pipes at areas where flow maldistribution is expected side to side (i.e., against wall where bypassing is possible between tubes and inner liner).
- 7.3.2 The ammonia injection header, adjustable trim valves, and flow indicators shall be shop assembled and shall be accessible from grade.
- 7.3.3 The AIG shall be located upstream of the catalyst in a location which shall prevent the possibility of conversion of NH₃ to NO.

7.4 Ammonia Injection System Control

- 7.4.1 The start-up and control of the ammonia injection system shall be accomplished in the plant distributed control system. The injection system shall also have the capability to be controlled manually.
- 7.4.2 The control system shall ensure that if the ammonia injection is shut down for any reason while the combustion turbine is in operation, the dilution air is continuously injected into the injection nozzles to prevent back flow of the flue gas into the ammonia injection line.
- 7.4.3 The control system shall also monitor inlet temperature to the catalyst so that ammonia is not injected into the gas stream at any time when the temperature is below the formation temperatures for ammonia salts.

7.5 Instrumentation and Valve Requirements

- 7.5.1 Design requirements for all instrumentation and valves shall be in accordance with Section 5.2 of Specification 21T7397 (including referenced subsections).
- 7.5.2 The scope of supply for specific SCR instrumentation is indicated in the Seller SCOPE OF SUPPLY data sheets.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Page: 15 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Issue Date: 12/3/97	

- 7.5.3 The pressure drop across each catalyst shall be measured. Local differential pressure measurement devices shall be provided by the catalyst Seller.
- 7.5.4 All valve limit switches and position transmitters shall be rigidly mounted on the valve, and they shall have water tight enclosures. The position switch shall be an integral part of the valve and actuator design (not an "add-on").
- 7.5.5 To the extent that it is economically feasible, remotely operated ON-OFF valves shall be pneumatically actuated.
- 7.5.6 All Seller supplied equipment shall be supplied with provisions for freeze protection.

8.0 QUALITY, SHOP TEST AND SHIPPING REQUIREMENTS

8.1 Quality Assurance Requirements


- 8.1.1 Suppliers of Materials, Equipment and Services in support of this specification shall meet the requirements of the Westinghouse Supplier Quality Program as described in Westinghouse Document 21T5802, "Supplier Quality Requirements". This document shall be reviewed concurrently with this specification.
- 8.1.2 It is the Seller's responsibility to obtain copies of all documents referenced in this specification. Unless specific exception is requested formally by the Seller, and formally granted by the Buyer, these referenced documents shall be binding.

8.2 Shop Test Requirements

- 8.2.1 Catalyst testing shall be as indicated in paragraph 4.6.1.
- 8.2.2 The Seller shall leak test all ammonia injection piping assemblies before shipment to the site.
- 8.2.3 The Seller shall perform a functional test of the ammonia injection system including sequencing of all valves.

8.3 Preparation for Shipment

- 8.3.1 During in-transit time and while pending assembly, the catalyst components will be subject to outdoor exposure in a wide range of ambient conditions. All items shall be preserved, sealed, and packed adequately to keep moisture, dirt and other contaminants out for a minimum of 6 months of field storage and with a preservation durability of one year preferred.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Page: 16 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Issue Date: 12/3/97	

- 8.3.2 For shipment and storage any flanged connections shall be suitably protected with steel plate, gaskets, and bolts.
- 8.3.3 A permanently attached corrosion resistant nameplate shall be affixed at a prominent location on the catalyst housing and shall include the following information as a minimum:
 - 8.3.3.1 Name of Manufacturer.
 - 8.3.3.2 Equipment Type (Name).
 - 8.3.3.3 Manufacturer's Model No.
 - 8.3.3.4 Buyer Purchase order No.
 - 8.3.3.5 Design Removal Efficiency.
- 8.3.4 The Seller shall be responsible for any damage to equipment resulting from improper shipment or storage instructions.

9.0 FIELD ERECTION AND START UP ASSISTANCE

9.1 Field Erection


The Seller's proposal shall include sufficient information to allow evaluation of the erection requirements (see Section 10.1).

9.2 Field Supervision

- 9.2.1 The Seller shall make available a competent engineer to supervise erection and start up of all equipment in his scope.
- 9.2.2 The requirements shall be indicated on the SELLER SCOPE OF SUPPLY data sheets. The Seller should recommend the number of hours required for erection and start-up separately.
- 9.2.3 The Seller shall supply, at no cost to the Buyer, personnel to witness the performance testing of the catalyst, if desired by the Buyer.

9.3 Erection Equipment

- 9.3.1 The Seller shall supply special tools, fixtures, wrenches, or other equipment required for erection and list additional equipment which may be required but is not furnished.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Issue Date: 12/3/97
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Page: 17 of 38	

9.3.2 The Seller shall supply all lifting beams, spreader bars, and other devices required for unloading and installation purposes. Any special slings or cables required shall be provided.

9.4 Erection Instructions

9.4.1 The Seller shall furnish a complete written description of the erection and start up procedure to supplement his erection drawings.

9.4.2 The Seller shall furnish instructions for the preservation and storage of equipment in his scope at the job site during construction.

10.0 DOCUMENTATION AND INFORMATION REQUIREMENTS

The following drawings and information shall be furnished by the Seller in accordance with Westinghouse Document 21T5673, "Supplier Data Requirements for Software Deliverables." More specific information required is given in this section to be used in conjunction with 21T5673. All documents shall contain the following information as a minimum:

Customer:	Westinghouse Electric Corporation
Project Name:	Hines Energy Complex PB1
P.A. No.:	
Service:	Selective Catalytic Reduction
Tag No.:	
Specification :	21T8900
Sequence No.:	
WBS No.:	255


10.1 Proposal Information Requirements

The Seller shall submit three (3) copies of a technical proposal containing the following requirements, at a minimum. Drawings and details of the proposed system shall give enough detail for evaluation of the system with regard to performance, structural integrity, installation labor and conformance with all major requirements of this specification.

10.1.1 General arrangement drawings showing outline dimensions, foundation requirements and accessories.

10.1.2 Preliminary foundation footprint, including estimated plot space and flooded weights and foundation loadings.

10.1.3 Ammonia injection system piping and instrumentation diagram.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL		Issue Date: 12/3/97
			Page: 18 of 38

- 10.1.4 Expected performance curves for NOx conversion versus temperature, and ammonia slip versus temperature.
- 10.1.5 All filled-in data sheets in this specification
- 10.1.6 Clearly identified design conditions used for the design point.
- 10.1.7 List of any specific contaminants which could alter the catalyst performance (e.g. air, fuel, water, steam, lubricating oil contaminants).
- 10.1.8 Expected gas side pressure drop.
- 10.1.9 Buyer and HRSG Seller Interface List:

The Seller shall furnish a list of all major interface points where the Seller terminates their supply with the Buyer and with the HRSG Seller. Seller shall provide information as necessary to properly interface the catalyst housing with the HRSG and the housing foundation.


- 10.1.10 Catalyst disposal/replacement information.
- 10.1.11 List of shipping components including dimensions and weights.
- 10.1.12 Any special storage requirements for equipment supplied.
- 10.1.13 Field Erection Information

A typical erection procedure shall be submitted for equipment substantially similar to the equipment being proposed by the Seller, including typical erection drawings of how the unit is to be erected. The Seller shall also provide lifting requirements for the specific catalyst components being proposed including required lifting capacity and length of time that each crane is required. A detailed erection schedule shall also be supplied specific to the proposed equipment, which includes craft man-hour estimates for each major step in the erection procedure.

- 10.1.14 Proposed engineering, purchasing and fabrication schedule.
- 10.1.15 List of exceptions (with reasoning) to all requirements of referenced specifications.

10.2 Buyer Approval Drawings and Information

The following certified drawings and information shall be furnished by the Seller in accordance with Westinghouse Document 21T5673.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL		Issue Date: 12/3/97	Page: 19 of 38

10.2.1 General Arrangement Drawing

This shall show the arrangement and location of all major components within the Seller's scope, and shall feature side elevations, plan, and frontal views.

10.2.2 Ammonia Injection P&I Diagram

This shall show all components of ammonia injection system including control valves and flow meters.

10.2.3 Catalyst Housing Layout Drawings

This shall show all layout and interface details with the HRSG duct. The layout shall show the location of all Buyer interface points including piping connections, structural supports to grade, and other structural supports which interface with the HRSG duct. This shall also show layout of loading and access doors.

10.2.4 Catalyst Housing Foundation Loading Diagram

This shall show locations of baseplates, plate and anchor bolt details, and list the dead, wind, thermal, and seismic forces transmitted to the foundations for the catalyst support duct.

10.2.5 Ammonia Injection Control System Drawings

The following control system drawings shall be supplied by the Seller:

10.2.5.1 Control Logic drawings.

10.2.5.2 Instrumentation Input and Output List.

10.2.5.3 Instrument Specification Data Sheets.


10.2.5.4 Instrument Installation Details.

10.2.5.5 Instrument Control Setting List.

10.2.5.6 All Control Valve Data Sheets.

10.2.6 Maintenance Layout Drawing

This shall show the location of all stairs, ladders, and platforms as well as the location of all instruments, valves, and other equipment that requires access for maintenance.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.				
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604		
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP	REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97	Page: 20 of 38		

10.2.7 Detail Drawings

Details of the following components shall be provided for Buyer approval:

- (a) Module sealing details
- (b) Ammonia injection skid details
- (c) Ammonia injection grid/piping details
- (d) All equipment on ammonia injection skid

10.2.8 Performance Curves

- (a) NOx conversion versus temperature.
- (b) Ammonia slip versus temperature.
- (c) Ammonia slip as a function of inlet NOx and NH3 injection rate.
- (d) SO2 to SO3 conversion versus temperature.
- (e) Formation of ammonia sulfur compounds versus SO3 concentration upstream of AIG and temperature assuming constant NH3 slip.
- (f) Estimated removal efficiencies for Non-Methane and Non-Ethane Hydrocarbons versus temperature.
- (g) NOx conversion versus hours of operation.

10.2.9 Catalyst Replacement Details

10.2.9.1 A detailed cost analysis should be submitted regarding the replacement of each used catalyst, including cost of new catalyst, installation cost, and reclaim value of used catalyst.

10.2.9.2 A detailed description of removal and disposal procedures should be submitted.

10.2.10 Piping Layout Drawings


This shall show the layout and routing of all piping within the Seller's scope.

10.2.11 Erection Drawings

Drawings and instructions shall be furnished sufficient to allow erection of the equipment in the field by others (See Section 9.0).

10.2.12 Design, Engineering, and Manufacturing Schedule

The Seller shall submit a schedule showing specific milestones for all design, engineering, drafting, purchasing, and manufacturing functions. This schedule shall include specific shipping dates.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.				
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604		
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP	REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97	Page: 21 of 38		

LIST OF ATTACHMENTS DATASHEET

JOB NO./SHOP NO. _____
 JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
 SPECIFICATION NO. 21T8900

THE SCR CATALYST SYSTEM SHALL BE DESIGNED IN COMPLIANCE WITH THE ATTACHMENTS LISTED BELOW ACCORDING TO THE FOLLOWING KEY (THIS KEY SHALL APPLY TO ALL DATA SHEETS):

X= SCR SELLER, H = HRSG SELLER, W = OTHERS, NR = NOT REQUIRED, OPT = OPTION


SPECIFICATIONS (LATEST REVISIONS):

- X SPECIFICATION 21T7397, SPECIFICATION FOR A HEAT RECOVERY STEAM GENERATOR (HRSG) FOR THE FPC-HINES ENERGY PROJECT
- X SPECIFICATION 21T8900, SPECIFICATION FOR AN SCR CATALYST FOR THE FPC-HINES ENERGY PROJECT
- X SPECIFICATION 21T7525, ACOUSTICAL REQUIREMENTS FOR THE FPC-POLK COUNTY PROJECT
- X SPECIFICATION 21T7360, PAINT SPECIFICATION FOR FPC POLK COUNTY, FLORIDA
- X SPECIFICATION 21T5802, SUPPLIER QUALITY REQUIREMENTS
- X SPECIFICATION 21T5673, SUPPLIER DATA REQUIREMENTS FOR SOFTWARE DELIVERABLES

DATASHEETS:

- X SELLER SCOPE OF SUPPLY DATASHEET - GENERAL (1 PAGE)
- X SELLER SCOPE OF SUPPLY DATASHEET - SCR AQUEOUS AMMONIA (2 PAGES)
- NR SELLER SCOPE OF SUPPLY DATASHEET - SCR/ANHYDROUS AMMONIA (2 PAGES)
- NR SELLER SCOPE OF SUPPLY DATASHEET - CO INSTRUMENTATION (1 PAGE)
- X PERFORMANCE INFORMATION DATASHEET (8 PAGES)
- X DESIGN SPECIFICATION DATASHEET - GENERAL(1 PAGE)
- X DESIGN SPECIFICATION DATASHEET - AMMONIA INJECTION SYSTEM (1 PAGE)
- X SELLER GUARANTEE DATASHEET (1 PAGE)

THE SELLER SHALL REVIEW THE ABOVE LIST TO ENSURE THAT ALL ATTACHMENTS INDICATED HAVE BEEN INCLUDED WITH THE TRANSMITTAL. SELLER SHALL NOTIFY BUYER IF ANY DOCUMENTS ARE MISSING.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Page: 23 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Issue Date: 12/3/97	

JOB NO./SHOP NO. _____
 JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
 SPECIFICATION NO. 21T8900

THE ITEMS LISTED BELOW SHALL INDICATE THE SELLER'S SCOPE OF SUPPLY:

- X _____ SCR CATALYST IN MODULES
- NR _____ CO CATALYST IN MODULES
- X _____ AQUEOUS AMMONIA INJECTION SYSTEM
- NR _____ ANHYDROUS AMMONIA INJECTION SYSTEM

CATALYST REACTOR HOUSING:

- X _____ CATALYST HOUSING WITH INTERNAL INSULATION AND LINER
- X _____ CATALYST MODULE SUPPORT STRUCTURE
- NR _____ SPACE IN REACTOR FOR ADDITION OF CATALYST AT LATER DATE (TO ACHIEVE 90% REDUCTION IN NO_x)
- NR _____ CATALYST SUPPORT STRUCTURE FOR ADDITION OF CATALYST AT LATER DATE (TO ACHIEVE 90% REDUCTION IN NO_x)

CATALYST HANDLING/MAINTENANCE FACILITIES:


- X _____ CATALYST LOADING DOORS
- X _____ ACCESS DOORS (UPSTREAM AND DOWNSTREAM OF CATALYST BED)
- NR _____ MONORAIL AND HOIST WITH SUPPORT STEEL FOR CATALYST LOADING
- II _____ PLATFORMS, LADDERS, AND STAIRWAYS

ACCESSORIES AND FIELD WORK:

- X _____ HOUSING SAMPLING PORTS (7 UPSTREAM AND DOWNSTREAM OF EACH CATALYST BED)
- NR _____ CATALYST FOR SAMPLING CELLS
- X _____ SAMPLE EXTRACTION TOOLS
- W _____ FOUNDATIONS
- W _____ SLIDE PLATES FOR FOUNDATIONS (EMBEDDED)
- W _____ FOUNDATION BOLTS
- X _____ STRUCTURAL STEEL FOR SUPPORT OF ALL ITEMS WITHIN SELLERS SCOPE OF SUPPLY
- X _____ SURFACE PREPARATION PER THE SPECIFICATION
- X _____ SHIPMENT OF ALL EQUIPMENT TO SITE
- W _____ ERECTION OF CATALYST HOUSING
- W _____ INSTALLATION OF CATALYST MODULES
- W _____ INSTALLATION OF AMMONIA INJECTION SKID
- X _____ ALL CONSTRUCTION, START-UP, AND COMMISSIONING SPARES

TECHINICAL FIELD ASSISTANCE:

- X _____ TFA FOR ERECTION AND INSTALLATION
- NR _____ TFA FOR START-UP OF CATALYST
- NR _____ TFA FOR PERFORMANCE TESTS

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Issue Date: 12/3/97
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Page: 24 of 38	

**SELLER SCOPE OF SUPPLY DATASHEET -
AQUEOUS AMMONIA INJECTION SYSTEM**

JOB NO./SHOP NO. _____
JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
SPECIFICATION NO. 21T8900

THE ITEMS LISTED BELOW SHALL INDICATE THE SELLER'S SCOPE OF SUPPLY:

AMMONIA INJECTION HEADER ASSEMBLY (MOUNTED AT GRADE):

- X AMMONIA INJECTION HEADER WITH CONNECTING PIPES
- X MANUAL TRIM VALVES
- X FLOW INDICATORS
- X MANUAL SHUT-OFF VALVES
- W SUPPORT OF INJECTION HEADER, IF REQUIRED (FOUNDATIONS)

AQUEOUS AMMONIA EVAPORATION AND FLOW CONTROL SKID:

- X DILUTION AIR FANS WITH MOTOR (QTY. 2)
- X PROVISIONS FOR RECIRCULATING HOT GAS FROM HRSG
- NR ELECTRIC AIR HEATERS
- X AMMONIA VAPORIZER WITH AIR OR STEAM ATOMIZING NOZZLE
- X AMMONIA/AIR MIXER
- X ALL AMMONIA/STEAM AIR PIPING AND VALVES ON SKID
- X ALL CONTROL INSTRUMENTATION (SEE CONTROL AND INSTRUMENTATION DATASHEET)
- X TUBING AND WIRING ON SKID
- X INSULATION ON SKID
- X PROVISIONS FOR NITROGEN PURGE OF AMMONIA INJECTION SYSTEM


AQUEOUS AMMONIA STORAGE AND FORWARDING EQUIPMENT:

- W AQUEOUS AMMONIA STORAGE TANK
- W AQUEOUS AMMONIA FORWARDING PUMPS
- W AQUEOUS AMMONIA STRAINER

EXTERNAL PIPING:

- W PIPING FROM FORWARDING SYSTEM TO AMMONIA INJECTION SKID
- X/H* PIPING FROM AMMONIA INJECTION SKID TO AMMONIA INJECTION HEADER
- X/H* PIPING FROM HRSG DUCT TO INLET OF DILUTION AIR FANS
- X/H* PIPING FROM AMMONIA INJECTION HEADER TO HRSG DUCT (INJECTION GRID)
- X AMMONIA FLOW CONTROL VALVE
- X AMMONIA SHUT-OFF VALVE (SOLENOID OPERATED)
- X AMMONIA FLOW TRANSMITTER
- X DILUTION AIR FLOW TRANSMITTER
- X ATOMIZING STEAM/AIR FLOW CONTROL VALVE
- X ATOMIZING STEAM/AIR PRESSURE REGULATING VALVE
- X ATOMIZING STEAM/AIR SHUT-OFF VALVE (SOLENOID OPERATED)

* TO BE WORKED OUT BETWEEN HRSG SELLER AND CATALYST SELLER

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Page: 25 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Issue Date: 12/3/97	

**SELLER SCOPE OF SUPPLY DATASHEET -
AQUEOUS AMMONIA INJECTION SYSTEM**

JOB NO./SHOP NO. _____
JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
SPECIFICATION NO. 21T8900

EXTERNAL PIPING:


- X _____ PRESSURE/TEMPERATURE TRANSMITTERS FOR CONTROL
- X _____ LOCAL PRESSURE/TEMPERATURE INDICATORS
- X _____ ALL INSTRUMENTATION AND VALVES FOR CONTROL OF EQUIPMENT ON INJECTION SKID
- X _____ FLUE GAS INLET TEMPERATURE TRANSMITTER - CONNECTION ONLY
- NR _____ CATALYST PRESSURE DROP TRANSMITTER
- X _____ LOCAL CATALYST PRESSURE DROP INDICATOR
- X _____ CONTROL LOGIC
- W _____ CONTROL SYSTEM HARDWARE

FLUE GAS ANALYZERS:

- W _____ SCR INLET NO_x/O₂ ANALYZER WITH PROBE AND SAMPLING LINE
- W _____ SCR OUTLET NO_x/O₂ ANALYZER WITH PROBE AND SAMPLING LINE
- W _____ SCR OUTLET NH₃ ANALYZER WITH PROBE AND SAMPLING LINE

GAS SAMPLING PORTS:

- H _____ INLET NO_x/O₂ PORT
- H _____ STACK SAMPLING PORTS

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL		Page: 26 of 38
	Issue Date: 12/3/97		

PERFORMANCE INFORMATION DATASHEET

JOB NO./SHOP NO. _____
 JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
 SPECIFICATION NO. 21T8900

PERFORMANCE CASE DESCRIPTION: CASE #1, 20°F AMB, N.G., BASE LOAD


	UNITS	COMBUSTION TURBINE	DUCT BURNER	TOTAL
FUEL	NONE	<u>N.G.</u>	_____	_____
DUCT BURNER HEAT INPUT (HHV)	MMBTU/HR	<u>N/A</u>	_____	_____
EXHAUST FLOW	LB/HR	<u>3554,960</u>	_____	_____
EXHAUST TEMPERATURE	DEG. F	<u>1112</u>	_____	_____
TEMP. ENTERING SCR CATALYST	DEG. F	<u>.</u>	_____	_____
TEMP. ENTERING CO CATALYST	DEG. F	<u>NR</u>	_____	_____

EXHAUST COMPOSITION:

	UNITS	COMBUSTION TURBINE	DUCT BURNER	TOTAL
OXYGEN	VOL. %	<u>12.43</u>	_____	_____
CARBON DIOXIDE	VOL. %	<u>3.90</u>	_____	_____
WATER	VOL. %	<u>7.89</u>	_____	_____
NITROGEN	VOL. %	<u>74.82</u>	_____	_____
ARGON	VOL. %	<u>0.94</u>	_____	_____
EXHAUST MOLECULAR WEIGHT	LBS/LBMOLE	<u>28.45</u>	_____	_____

EXHAUST EMISSIONS		COMBUSTION TURBINE	DUCT BURNER	TOTAL	DOWNSTREAM CO	SCR
	UNITS					
NOx	(ppmvd @ 15% O2)	<u>45</u>	<u>N/A</u>	<u>45</u>	_____	<u>12</u>
NOx	(lbs/hour)	<u>311</u>	_____	_____	_____	<u>73</u>
NOx	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____
CO	(ppmvd)	<u>25</u>	_____	_____	_____	<u>**</u>
CO	(lbs/hour)	<u>85</u>	_____	_____	_____	_____
CO	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____
S02	(ppmvd)	<u>1</u>	_____	_____	_____	<u>**</u>
S02	(lbs/hour)	<u>2</u>	_____	_____	_____	_____
S02	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____
VOC***	(ppmvd)	<u>3</u>	_____	_____	_____	<u>**</u>
VOC	(lbs/hour)	<u>6</u>	_____	_____	_____	_____
VOC	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____
Particulates	(lbs/hour)	<u>16.2</u>	_____	_____	_____	<u>**</u>
Particulates	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____

*HRSG SELLER TO CALCULATE AND USE ± 20°F MARGIN FOR SCR DESIGN (AVERAGE TEMP.)
 **CATALYST SELLER TO DETERMINE
 ***VOC DEFINED AS NON-METHANE AND NON-ETHANE HC'S

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Page: 27 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Issue Date: 12/3/97	

PERFORMANCE INFORMATION DATASHEET

JOB NO./SHOP NO. _____
 JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
 SPECIFICATION NO. 21T8900

PERFORMANCE CASE DESCRIPTION: CASE #2, 59°F AMB, N.G., BASE LOAD

	UNITS	COMBUSTION TURBINE	DUCT BURNER	TOTAL
FUEL	NONE	N.G.		
DUCT BURNER HEAT INPUT (HHV)	MMBTU/HR	N/A		
EXHAUST FLOW	LB/HR	3,519,210		
EXHAUST TEMPERATURE	DEG. F	1140		
TEMP. ENTERING SCR CATALYST	DEG. F	*		
TEMP. ENTERING CO CATALYST	DEG. F	NR		

EXHAUST COMPOSITION:

OXYGEN	VOL. %	12.60		
CARBON DIOXIDE	VOL. %	3.76		
WATER	VOL. %	8.31		
NITROGEN	VOL. %	74.38		
ARGON	VOL. %	0.93		
EXHAUST MOLECULAR WEIGHT	LBS/LBMOLE	28.39		


EXHAUST EMISSIONS

	UNITS	COMBUSTION TURBINE	DUCT BURNER	TOTAL	DOWNSTREAM CO	SCR
NOx	(ppmvd @ 15% O2)	45	N/A	45		12
NOx	(lbs/hour)	298				73
NOx	(lbs/MMBtu), HHV					
CO	(ppmvd)	25				**
CO	(lbs/hour)	81				
CO	(lbs/MMBtu), HHV					
S02	(ppmvd)	1				**
S02	(lbs/hour)	2				
S02	(lbs/MMBtu), HHV					
VOC***	(ppmvd)	3				**
VOC	(lbs/hour)	6				
VOC	(lbs/MMBtu), HHV					
Particulates	(lbs/hour)	15.6				**
Particulates	(lbs/MMBtu), HHV					

*HRSG SELLER TO CALCULATE AND USE ± 20°F MARGIN FOR SCR DESIGN (AVERAGE TEMP.)

**CATALYST SELLER TO DETERMINE

***VOC DEFINED AS NON-METHANE AND NON-ETHANE HC'S

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Page: 28 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Issue Date: 12/3/97	

PERFORMANCE INFORMATION DATASHEET

JOB NO./SHOP NO. _____
 JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
 SPECIFICATION NO. 21T8900

PERFORMANCE CASE DESCRIPTION: CASE #4, 105°F AMB, N.G., 57% LOAD

	UNITS	COMBUSTION TURBINE	DUCT BURNER	TOTAL
FUEL	NONE	<u>N.G.</u>	_____	_____
DUCT BURNER HEAT INPUT (HHV)	MMBTU/HR	<u>N/A</u>	_____	_____
EXHAUST FLOW	LB/HR	<u>2,335,500</u>	_____	_____
EXHAUST TEMPERATURE	DEG. F	<u>1160</u>	_____	_____
TEMP. ENTERING SCR CATALYST	DEG. F	<u>.</u>	_____	_____
TEMP. ENTERING CO CATALYST	DEG. F	<u>NR</u>	_____	_____

EXHAUST COMPOSITION:


OXYGEN	VOL. %	<u>12.66</u>	_____	_____
CARBON DIOXIDE	VOL. %	<u>3.40</u>	_____	_____
WATER	VOL. %	<u>11.02</u>	_____	_____
NITROGEN	VOL. %	<u>72.00</u>	_____	_____
ARGON	VOL. %	<u>0.90</u>	_____	_____
EXHAUST MOLECULAR WEIGHT	LBS/LBMOLE	<u>28.07</u>	_____	_____

EXHAUST EMISSIONS		COMBUSTION TURBINE	DUCT BURNER	TOTAL	DOWNSTREAM CO	SCR
UNITS						
NOx	(ppmvd @ 15% O2)	<u>45</u>	<u>N/A</u>	<u>45</u>	_____	<u>**</u>
NOx	(lbs/hour)	<u>179</u>	_____	_____	_____	<u>70</u>
NOx	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____
CO	(ppmvd)	<u>75</u>	_____	_____	_____	<u>**</u>
CO	(lbs/hour)	<u>165</u>	_____	_____	_____	_____
CO	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____
S02	(ppmvd)	<u>1</u>	_____	_____	_____	<u>**</u>
S02	(lbs/hour)	<u>1</u>	_____	_____	_____	_____
S02	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____
VOC***	(ppmvd)	<u>8</u>	_____	_____	_____	<u>**</u>
VOC	(lbs/hour)	<u>10</u>	_____	_____	_____	_____
VOC	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____
Particulates	(lbs/hour)	<u>10.3</u>	_____	_____	_____	<u>**</u>
Particulates	(lbs/MMBtu), HHV	_____	_____	_____	_____	_____

*HRSG SELLER TO CALCULATE AND USE ± 20°F MARGIN FOR SCR DESIGN (AVERAGE TEMP.)

**CATALYST SELLER TO DETERMINE

***VOC DEFINED AS NON-METHANE AND NON-ETHANE HC'S

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Page: 30 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Issue Date: 12/3/97	

PERFORMANCE INFORMATION DATASHEET

JOB NO./SHOP NO. _____
 JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
 SPECIFICATION NO. 21T8900

PERFORMANCE CASE DESCRIPTION: CASE #5, 59°F AMB, N.G., 50% LOAD

	UNITS	COMBUSTION TURBINE	DUCT BURNER	TOTAL
FUEL	NONE	N.G.		
DUCT BURNER HEAT INPUT (HHV)	MMBTU/HR	N/A		
EXHAUST FLOW	LB/HR	2,552,500		
EXHAUST TEMPERATURE	DEG. F	1043		
TEMP. ENTERING SCR CATALYST	DEG. F	.		
TEMP. ENTERING CO CATALYST	DEG. F	NR		

EXHAUST COMPOSITION:

	UNITS	COMBUSTION TURBINE	DUCT BURNER	TOTAL
OXYGEN	VOL.%	14.09		
CARBON DIOXIDE	VOL.%	3.08		
WATER	VOL.%	6.99		
NITROGEN	VOL.%	74.90		
ARGON	VOL.%	0.94		
EXHAUST MOLECULAR WEIGHT	LBS/LBMOLE	28.48		


EXHAUST EMISSIONS

	UNITS	COMBUSTION TURBINE	DUCT BURNER	TOTAL	DOWNSTREAM CO	SCR
NOx	(ppmvd @ 15% O2)	45	N/A	45		**
NOx	(lbs/hour)	179				70
NOx	(lbs/MMBtu), HHV					
CO	(ppmvd)	200				**
CO	(lbs/hour)	474				
CO	(lbs/MMBtu), HHV					
S02	(ppmvd)	1				**
S02	(lbs/hour)	1				
S02	(lbs/MMBtu), HHV					
VOC***	(ppmvd)	20				**
VOC	(lbs/hour)	27				
VOC	(lbs/MMBtu), HHV					
Particulates	(lbs/hour)	11.4				**
Particulates	(lbs/MMBtu), HHV					

*HRSG SELLER TO CALCULATE AND USE ± 20°F MARGIN FOR SCR DESIGN (AVERAGE TEMP.)

**CATALYST SELLER TO DETERMINE

***VOC DEFINED AS NON-METHANE AND NON-ETHANE HC'S

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.				
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604		
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP	REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL	Issue Date: 12/3/97		Page: 31 of 38	

DESIGN SPECIFICATION DATASHEET - GENERAL

JOB NO./SHOP NO. _____
 JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
 SPECIFICATION NO. 21T8900

SCR/CO CATALYST OPERATION

<u>7500</u>	CONTINUOUS DUTY EST. HOURS PER YEAR	<u>X</u>	<u>120</u>	CYCLIC DUTY HOT STARTS PER YEAR	<u>30 YRS</u>	<u>30</u>	DESIGN LIFE COLD STARTS PER YEAR
-------------	--	----------	------------	------------------------------------	---------------	-----------	-------------------------------------

COMBUSTION TURBINE OPERATION

<u>X</u>	NATURAL GAS	<u>X</u>	NO. 2 FUEL OIL	OTHER:	
<u>7350</u>	HOURS OPER. PER YEAR	<u>150</u>	HOURS OPER. PER YEAR		HOURS OPER./YR
<u>X</u>	UNFIRED DESIGN		FIRED DESIGN		

SCR CATALYST BED LOCATION

	SPLIT HP EVAP		DESIGN FLOW MALDSTRIB		DESIGN TEMP MALDSTRIB
<u>X</u>	DOWNSTREAM OF HP EVAP	<u>H</u>	DESIGN FLOW MALDSTRIB	<u>H</u>	DESIGN TEMP MALDSTRIB
	DOWNSTREAM OF HP ECON		DESIGN FLOW MALDSTRIB		DESIGN TEMP MALDSTRIB

CO CATALYST BED LOCATION


<u>N/A</u>	UPSTREAM OF HP SUPHTR	<u>N/A</u>	DESIGN FLOW MALDSTRIB	<u>N/A</u>	DESIGN TEMP MALDSTRIB
<u>N/A</u>	DWNSTRM OF HP SUPHTR	<u>N/A</u>	DESIGN FLOW MALDSTRIB	<u>N/A</u>	DESIGN TEMP MALDSTRIB
<u>N/A</u>	SPLIT HP EVAP	<u>N/A</u>	DESIGN FLOW MALDSTRIB	<u>N/A</u>	DESIGN TEMP MALDSTRIB
<u>N/A</u>	DWNSTRM OF HP SUPHTR	<u>N/A</u>	DESIGN FLOW MALDSTRIB	<u>N/A</u>	DESIGN TEMP MALDSTRIB
<u>N/A</u>	DWNSTRM OF HP SUPHTR	<u>N/A</u>	DESIGN FLOW MALDSTRIB	<u>N/A</u>	DESIGN TEMP MALDSTRIB

CATALYST DESIGN

H APPROX. HRSG DIM. H MAX INNER LINER DIMENSIONS

SPECIAL DESIGN CONSIDERATIONS:

HRSG SELLER TO COORDINATE WITH CATALYST SELLER CATALYST DESIGN LOCATION AND DIMENSIONS, AND MALDISTRIBUTIONS.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
 WESTINGHOUSE POWER GENERATION POWER GENERATION BUSINESS UNIT - ORLANDO, FL		Issue Date: 12/3/97	Page: 35 of 38

**DESIGN SPECIFICATION DATASHEET -
AMMONIA INJECTION SYSTEM**

JOB NO./SHOP NO. _____
JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
SPECIFICATION NO. 21T8900

AMMONIA INJECTION SYSTEM

DILUTION MEDIUM (ANHYDROUS AMMONIA INJECTION SYSTEM): N/A

_____ STEAM _____ AMBIENT AIR _____ HEATED AIR

DILUTION MEDIUM (AQUEOUS AMMONIA INJECTION SYSTEM):

_____ STEAM X RECIRCULATED HRSG GAS _____ HEATED AIR

VAPORIZATION MEDIUM (AQUEOUS AMMONIA INJECTION SYSTEM):

H STEAM H HOT AIR (HIGH PRESSURE)


AVAILABLE STEAM PROPS:	<u>H</u>	PRESSURE (PSIG)	<u>H</u>	TEMPERATURE (DEG. F)
STEAM PIPING DESIGN:	<u>H</u>	PRESSURE (PSIG)	<u>H</u>	TEMPERATURE (DEG. F)
AVAILABLE AIR PROPS:	<u>H</u>	PRESSURE (PSIG)	<u>H</u>	TEMPERATURE (DEG. F)
AIR PIPING DESIGN:	<u>H</u>	PRESSURE (PSIG)	<u>H</u>	TEMPERATURE (DEG. F)

SELLER TO FILL IN FOLLOWING DATA:

_____	AQUEOUS AMMONIA WT %	_____	DISTANCE BETWEEN NOZZLES/ORIFICES ON INJECTION GRID
_____	AQUEOUS NH3 CONSP. RATE	_____	DESIGN PRESSURE DROP ACROSS NOZZLES/ORIFICES
<u>N/A</u>	ANHYDROUS NH3 CONSP. RATE	_____	DIRECTION OF NH3 INJECTION (UPSTREAM OR DOWNSTREAM)
_____	# AIG HORIZONTAL RUNNERS	_____	DIRECTION BETWEEN AIG AND SCR CATALYST
_____	# AIG VERTICAL RUNNERS		

SPECIAL DESIGN CONSIDERATIONS:

SELLER TO SPECIFY ANY SPECIAL DESIGN CONSIDERATIONS IN THE PROPOSAL.
HRSG SELLER TO DETERMINE VAPORIZATION MEDIUM.

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION	Issue Date: 12/3/97	Page: 36 of 38
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		

SELLER GUARANTEE DATASHEET

JOB NO./SHOP NO. _____
 JOB TITLE FPC-HINES ENERGY PROJECT

RFQ NO. _____
 SPECIFICATION NO. 21T8900

THE SCR CATALYST SHALL MEET THE GUARANTEES LISTED BELOW AND AS EXPLAINED IN SECTION 3.0 OF SPEC 21T8900

REFERENCE CATALYST INLET CONDITIONS*

EXHAUST GAS FLOW	UNITS: LB/HR	<u>SEE PERFORMANCE DATA SHEETS</u>
TEMPERATURE RANGE ENTERING SCR CATALYST**	DEG. F	<u>H</u>
TEMPERATURE RANGE ENTERING CO CATALYST**	DEG. F	<u>N/A</u>
TOTAL EMISSIONS: (WORST CASE FROM PERFORMANCE DATASHEETS)		<u>SEE PERFORMANCE DATA SHEETS</u>

SCR CONVERSION GUARANTEES:

NOx REDUCTION	UNITS: (%)	<u>WORST CASE FROM PERF. DATA SHTS</u>
AMMONIA SLIP	(ppmvd @ 15% O2)	<u>10 MAX</u>
S02-S03 CONVERSION	(%)	<u>3 MAX</u>


OTHER GUARANTEES

CATALYST LIFE GUARANTEE	UNITS	
FROM DELIVERY	MONTHS	<u>N/A</u>
FROM FIRST EXHAUST GAS IN	MONTHS	<u>36</u>
EQUIPMENT GUARANTEE		
FROM DELIVERY	MONTHS	<u>NA</u>
FROM PLANT ACCEPTANCE	MONTHS	<u>24</u>
GAS SIDE PRESSURE DROP		
SCR CATALYST	INCHES H2O	<u>3.0 MAX</u>
CO CATALYST	INCHES H2O	<u>N/A</u>
TOTAL	INCHES H2O	<u>N/A</u>
DISPOSAL GUARANTEE	NONE	<u>YES</u>
ACOUSTICAL GUARANTEE		
3 FEET FROM SOURCE, ALL EQUIPMENT	dB(A)	<u>SEE 21T7525</u>

*ALL GUARANTEES SHOULD BE MADE AT THESE CONDITIONS UNLESS NOTED OTHERWISE

** TEMPERATURE RANGE DENOTES AVERAGE TEMPERATURES

H-HRSG SELLER TO DETERMINE FROM PERFORMANCE INFORMATION DATA SHEETS

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.			
DOCUMENT NO. 21T8900		DISTRIBUTION CODE: 273-000-604	
TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT			TYPE ESP
			REV 001
	WESTINGHOUSE POWER GENERATION		Issue Date: 12/3/97
	POWER GENERATION BUSINESS UNIT - ORLANDO, FL		
		Page: 37 of 38	




FIGURE 1 - SCR SYSTEM LAYOUT : PLAN VIEW

This drawing contains information proprietary to Westinghouse Electric Corporation. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned upon request. This drawing and such information is not to be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Westinghouse Electric Corporation. Proprietary Class No. 2.

DOCUMENT NO. 21T8900

DISTRIBUTION CODE: 273-000-604


TITLE: SCR SYSTEM FOR THE FPC-HINES ENERGY PROJECT

TYPE ESP	REV 001
--------------------	-------------------

 **WESTINGHOUSE POWER GENERATION**
POWER GENERATION BUSINESS UNIT - ORLANDO, FL

Issue Date: 12/3/97

Page: 38 of 38



**Florida
Power**
CORPORATION

RECEIVED

AUG 9 1995

Bureau of
Air Regulation

August 2, 1995

Mr. William C. Thomas
District Air Program Administrator
Florida Department of Environmental Protection
Southwest District
3804 Coconut Palm Dr.
Tampa, Florida 33619

Dear Mr. Thomas:

Re: Notification of the Commencement of Construction of FPC's Polk County Project
Permit Nos. PA-92-33 and PSD-FL-195

As required by 40 CFR 60.7(a)(1), Florida Power Corporation (FPC) is providing the Florida Department of Environmental Protection (DEP) notification of commencement of construction at FPC's above-referenced facility.

If you should have any questions or concerns, please do not hesitate to contact me at (813) 866-4387.

Sincerely,

W. Jeffrey Pardue, C.E.P.
Director, Environmental Services

cc: John Brown, DEP- Tallahassee
Jewell Harper, EPA Reg. IV


ENVIRONMENTAL SERVICES DEPARTMENT

H2G • 3201 Thirty-fourth Street South • P.O. Box 14042 • St. Petersburg, Florida 33733 • (813) 866-5151



Printed on recycled paper

A Florida Progress Company



**Florida
Power**
CORPORATION

May 5, 1998

Mr. Hamilton S. Oven, Jr.
Florida Department of Environmental Protection
Douglas Bldg., Room 953AA
3900 Commonwealth Blvd., MS48
Tallahassee, FL 32399-3000

Dear Mr. Oven:

Re: Florida Power Corporation
Hines Energy Complex (formerly the Polk County Site)
Site Certification No. PA-92-33; Condition No. XIII.E.3.a.
PSD Permit No. FL-195; Specific Condition E.3.a.

In fulfillment of the above-referenced conditions of Florida Power Corporation's (FPC) Site Certification and Prevention of Significant Deterioration (PSD) permit, this letter serves to notify the Department that the auxiliary boiler to be used in support of Power Block 1 has been selected. The boiler is a Universal Energy Corporation (UEC) Model BF 500C-PF-V-G-I.

If you should have any questions concerning this submittal, please do not hesitate to contact me at (813) 866-5158 or Randall Melton at (813) 866-4290.

Sincerely,

Scott H. Osbourn
Senior Environmental Engineer

cc: Clair Fancy, DEP Tallahassee

cc: M. Costello

RECEIVED
MAY 08 1998
BUREAU OF
AIR REGULATION

RECEIVED
MAY 08 1998
BUREAU OF
AIR REGULATION

PSD-FL-195 PERMITTING HISTORY

Florida Power Corporation
Hines Energy Complex

Facility ID No.: 1050234

PSD Permit History (for tracking purposes):

	Issue	PERMITTING ACTION DESCRIPTION
Permit No.	Date	
PSD-FL-195	3/01/94	PPSC No. PA-92-33. PSD permit issued for the construction of two 235 MW combined cycle combustion units using GE technology and with NO _x limits of 12 ppmvd.
PSD-FI-195A	9/29/98	Permit modification to install SCR system and to reflect the specifications of the actual (Westinghouse 501FC) combustion turbines installed. Other changes included higher input & power rates and emissions increases.
PSD-FL-195B 1050234-002AC	5/27/99	Modification to allow the facility to utilize the fully installed capacity of the combined cycle units by modifying the maximum heat input and megawatts rating. Additional time for warm and cold start. Refer to changes in specific conditions.

Permit #:	PATS:	Issue:	Expire:
Project #/Name	Owner/Company	Type/Sub	Receive
001/FPC HINES ENERGY COMPLEX	FLORIDA POWER CORPORATION	AV /00	20-JAN-1999
002/FPC HINES PSD-FL195A, PA9	FLORIDA POWER CORPORATION	AC /M1	04-MAY-1999
/		/	
/		/	
/		/	
/		/	
/		/	
/		/	
/		/	
/		/	
/		/	

Your query has retrieved 2 records.
 Count: *2

<Replace>

In the folder labeled as follows there are documents, listed below, which were not reproduced in this electronic file. That folder can be found in one of the file drawers labeled Supplementary Documents Drawer. Folders in that drawer are arranged alphabetically, then by permit number.

Folder Name: Florida Power Corporation

Permit(s) Numbered:

AC	53	-	217434
PSD	FL	-	195
PA	92	-	33

Period during
which document
was received:

Detailed Description

APPLICATION 14 OCT 1992	1.	PAMPHLET DESCRIBING A NEBRASKA BOILER
	2.	PAMPHLET DESCRIBING VOGT HEAT RECOVERY STEAM GENERATORS

Check Sheet

Company Name: FLORIDA POWER CORPORATION Hinds Energy
Permit Number: AC 53-217434 Complex
PSD Number: 199
Permit Engineer: _____

Application:

- Initial Application
- Incompleteness Letters
- Responses
- Waiver of Department Action
- Department Response
- Other

Cross References:

-
-
-

Intent:

- Intent to Issue
- Notice of Intent to Issue
- Technical Evaluation
- BACT Determination
- Unsigned Permit
- Correspondence with:
 - EPA
 - Park Services
 - Other
- Proof of Publication
 - Petitions - (Related to extensions, hearings, etc.)
 - Waiver of Department Action
 - Other

Final Determination:

- Final Determination
- Signed Permit
- BACT Determination
- Other

Post Permit Correspondence:

- Extensions/Amendments/Modifications
- Other