

Florida Department of
Environmental Protection

Memorandum

TO: Jeffery F. Koerner, P.E., Program Administrator
THROUGH: Jonathan Holtom, P.E., Section Administrator *JH.*
FROM: Kris Lanh, Engineering Specialist II *KL*
DATE: November 2, 2011
SUBJECT: Draft/Proposed Permit No. 1050234-019-AV
Progress Energy Florida, Inc., Hines Energy Complex
Title V Air Operation Permit Renewal

Attached for your review are the following items:

- Written Notice of Intent to Issue Air Permit;
- Public Notice of Intent to Issue Air Permit;
- Statement of Basis;
- Draft/Proposed permit; and,
- P.E. Certification.

The draft/proposed permit renews the Title V permit for the Hines Energy Complex, which is located in Polk County, Florida. The Statement of Basis provides a summary of the project and the rationale for issuance. The P.E. certification briefly summarizes the proposed project.

The application was received on May 20, 2011 and deemed complete on October 11, 2011. Day 90 is January 9, 2012. There is no ongoing/open enforcement case for this facility, according to Southwest District Office.

I recommend your approval of the attached draft/proposed permit.

Attachments



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

Electronic Mail – Received Receipt Requested

Martin J. Drango, Plant Manager
Progress Energy Florida, Inc.
7700 County Road 555
Bartow, Florida 33830

Re: Permit No. 1050234-019-AV
Hines Energy Complex
Title V Permit Renewal


Dear Mr. Martin J. Drango:

Enclosed is the draft/proposed permit package to renew the Title V air operation permit for the Hines Energy Complex. This facility is located in Polk County at 7700 County Road 555, Bartow, Florida. The permit package includes the following documents:

- The Statement of Basis, which summarizes the facility, the equipment, the primary rule applicability, and the changes since the last Title V renewal.
- The draft/proposed Title V air operation permit renewal, which includes the specific permit conditions that regulate the emissions units covered by the proposed project.
- The Written Notice of Intent to Issue Air Permit provides important information regarding: the Permitting Authority's intent to issue an air permit for the proposed project; the requirements for publishing a Public Notice of the Permitting Authority's intent to issue an air permit; the procedures for submitting comments on the draft/proposed permit; the process for filing a petition for an administrative hearing; and the availability of mediation.
- The Public Notice of Intent to Issue Air Permit is the actual notice that you must have published in the legal advertisement section of a newspaper of general circulation in the area affected by this project. The Public Notice of Intent to Issue Title V Air Permit must be published as soon as possible and the proof of publication must be provided to the Department within seven days of the date of publication. Because this permit is being processed as a combined draft/proposed permit in order to reduce processing time, a duplicate copy of the proof of publication must also be transmitted by electronic mail within seven days of the date of publication to Ms. Ana Oquendo at EPA Region 4 at the following address: oquendo.ana@epa.gov.

If you have any questions, please contact the Project Engineer, Kris Lanh, by telephone at (850) 717-9094 or by email at kris.lanh@dep.state.fl.us.

Sincerely,


Jeffrey F. Koerner, Program Administrator
Office of Permitting and Compliance
Division of Air Resource Management

11-10-11
Date

Enclosures
JFK/jh/kl

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

*In the Matter of an Application for
Title V Air Operation Permit Renewal by:*

Progress Energy Florida, Inc.
7700 County Road 555
Bartow, Florida 33830

Permit No. 1050234-019-AV
Facility ID No. 1050234
Hines Energy Complex
Title V Operation Permit Renewal
Polk County, Florida

Responsible Official:

Martin J. Drango, Plant Manager

Facility Location: Progress Energy Florida, Inc. operates the existing Hines Energy Complex, which is located in Polk County at 7700 County Road 555, Bartow, Florida.

Project: The purpose of this project is to renew Title V air operation permit No. 1050234-014-AV. Details of the project are provided in the application and the enclosed Statement of Basis.

Permitting Authority: Applications for Title V air operation permits for facilities that contain Acid Rain units are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, 62-213 and 62-214 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and a Title V air operation permit is required to operate the facility. The Division of Air Resource Management is the Permitting Authority responsible for making a permit determination for this project. The Permitting Authority's physical address is: 111 South Magnolia Drive, Suite #4, Tallahassee, Florida. The Permitting Authority's mailing address is: 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Permitting Authority's telephone number is 850/717-9000.

Project File: A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at the address indicated above for the Permitting Authority. The complete project file includes the draft/proposed permit, the Statement of Basis, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may view the draft/proposed permit by visiting the following website: <http://www.dep.state.fl.us/air/emission/apds/default.asp> and entering the permit number shown above. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address or phone number listed above.

Notice of Intent to Issue Permit: The Permitting Authority gives notice of its intent to issue a Title V air operation permit renewal to the applicant for the project described above. The applicant has provided reasonable assurance that continued operation of the existing equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a final permit in accordance with the conditions of the draft/proposed permit unless a response received in accordance with the following procedures results in a different decision or a significant change of terms or conditions.

Public Notice: Pursuant to Section 403.815, F.S. and Rules 62-110.106 and 62-210.350, F.A.C., you (the applicant) are required to publish at your own expense the enclosed Public Notice of Intent to Issue Air Permit (Public Notice). The Public Notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected by this project. The newspaper used must meet the requirements of Sections 50.011 and 50.031, F.S. in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the Permitting Authority at the above address or phone number. Pursuant to Rule 62-110.106(5) and (9), F.A.C., the applicant shall provide proof of publication to the Permitting Authority at the above address within 7 days of publication. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rule 62-110.106(11), F.A.C.

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

Comments: The Permitting Authority will accept written comments concerning the draft/proposed Title V air operation permit for a period of 30 days from the date of publication of the Public Notice. Written comments must be received by the close of business (5:00 p.m.), on or before the end of this 30-day period by the Permitting Authority at the above address. As part of his or her comments, any person may also request that the Permitting Authority hold a public meeting on this permitting action. If the Permitting Authority determines there is sufficient interest for a public meeting, it will publish notice of the time, date, and location in the Florida Administrative Weekly (FAW). If a public meeting is requested within the 30-day comment period and conducted by the Permitting Authority, any oral and written comments received during the public meeting will also be considered by the Permitting Authority. If timely received written comments or comments received at a public meeting result in a significant change to the draft/proposed permit, the Permitting Authority shall issue a revised draft/proposed permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection. For additional information, contact the Permitting Authority at the above address or phone number.

Petitions: A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by the applicant or any of the parties listed below must be filed within 14 days of receipt of this Written Notice of Intent to Issue Air Permit. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within 14 days of publication of the attached Public Notice or within 14 days of receipt of this Written Notice of Intent to Issue Air Permit, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of when and how each petitioner received notice of the agency action or proposed decision; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Written Notice of Intent to Issue Air Permit. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.


WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT

Mediation: Mediation is not available in this proceeding.

EPA Review: EPA has agreed to treat the draft/proposed Title V air operation permit as a proposed Title V air operation permit and to perform its 45-day review provided by the law and regulations concurrently with the public comment period, provided that the applicant also transmits an electronic copy of the required proof of publication directly to EPA at the following email address: oquendo.ana@epa.gov. Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day review period is performed after the public comment period has ended. The final Title V air operation permit will be issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that result in a different decision or significant change of terms or conditions. The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following website address: <http://www.epa.gov/region4/air/permits/Florida.htm>.

Objections: Pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 days of the expiration of the Administrator's 45-day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to the issuance of any Title V air operation permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30-day public comment period provided in the Public Notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460. For more information regarding EPA review and objections, visit EPA's Region 4 web site at <http://www.epa.gov/region4/air/permits/Florida.htm>.

Executed in Tallahassee, Florida.



Jeffery F. Koerner, Program Administrator
Office of Permitting and Compliance
Division of Air Resource Management

5

WRITTEN NOTICE OF INTENT TO ISSUE AIR PERMIT


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Written Notice of Intent to Issue Title V Air Operation Permit Renewal (including the Public Notice, the Statement of Basis, and the draft/proposed permit), or a link to these documents available electronically on a publicly accessible server, was sent by electronic mail with received receipt requested before the close of business on 11/10/11 to the persons listed below.

- Mr. Martin J. Drango, Progress Energy Florida, Inc.: martin.drango@pgnmail.com
- Mr. Anthony Salvarezza, Progress Energy Florida, Inc.: another.salvarezza@pgnmail.com
- Mr. Chris Bradley, Progress Energy Florida, Inc.: chris.bradley@pgnmail.com
- Mr. Thomas W. Davis, Environmental Consulting and Technology, Inc.: tdavis@ectinc.com
- Ms. Cindy Zhang-Torres, DEP – SWD: cindy.zhang-torres@dep.state.fl.us
- Ms. Cindy Mulkey, DEP Siting: cindy.mulkey@dep.state.fl.us
- Ms. Katy Forney, U.S. EPA Region 4: forney.kathleen@epa.gov
- Ms. Ana Oquendo, EPA Region 4: oquendo.ana@epa.gov
- Ms. Barbara Friday, DEP OPC: barbara.friday@dep.state.fl.us (for posting with U.S. EPA, Region 4)
- Ms. Lynn Scarce, DEP OPC: lynn.scarce@dep.state.fl.us (for reading file)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.


(Clerk) _____ (Date) 11/10/11

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

Florida Department of Environmental Protection
Division of Air Resource Management
Draft/Proposed Permit No. 1050234-019-AV
Progress Energy Florida Inc., Hines Energy Complex
Polk County, Florida

Applicant: The applicant for this project is Progress Energy Florida, Inc. The applicant's responsible official and mailing address are: Martin J. Drango, Plant Manager, Progress Energy Florida, Inc., Hines Energy Complex, 7700 County Road 555, Bartow, Florida 33830.

Facility Location: The applicant operates the existing Hines Energy Complex which is located in Polk County at 7700 County Road 555 in Bartow, Florida.

Project: The applicant applied on May 20, 2011 to the Department for a Title V air operation permit renewal. This is a renewal of Title V air operation permit No. 1050234-014-AV. This facility consists of: four power blocks (1, 2, 3 and 4), each with two combined cycle combustion turbines (CT) with unfired heat recovery steam generators (HRSG); a 99 million British thermal unit per hour (MMBtu/hr) auxiliary boiler; two fuel oil storage tanks; and a diesel-fired emergency fire pump engine. Emissions from each CT and HRSG combination are vented through a single stack. The combustion turbines may fire fuel oil or natural gas. Emissions are monitored by continuous emissions monitors (CEMS) for each power block

Permitting Authority: Applications for Title V air operation permits for facilities that contain Acid Rain units are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210, 62-213 and 62-214 of the Florida Administrative Code (F.A.C.). The proposed project is not exempt from air permitting requirements and a Title V air operation permit is required to operate the facility. The Division of Air Resource Management is the Permitting Authority responsible for making a permit determination for this project. The Permitting Authority's physical address is: 111 South Magnolia Drive, Suite #4, Tallahassee, Florida. The Permitting Authority's mailing address is: 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Permitting Authority's telephone number is 850/717-9000.

Project File: A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at the address indicated above for the Permitting Authority. The complete project file includes the draft/proposed permit, the Statement of Basis, the application, and the information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may view the draft/proposed permit by visiting the following website: <http://www.dep.state.fl.us/air/emission/apds/default.asp> and entering the permit number shown above. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address or phone number listed above.

Notice of Intent to Issue Permit: The Permitting Authority gives notice of its intent to issue a renewed Title V air operation permit to the applicant for the project described above. The applicant has provided reasonable assurance that continued operation of the existing equipment will not adversely impact air quality and that the project will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296 and 62-297, F.A.C. The Permitting Authority will issue a final permit in accordance with the conditions of the draft/proposed permit unless a response received in accordance with the following procedures results in a different decision or a significant change of terms or conditions.

Comments: The Permitting Authority will accept written comments concerning the draft/proposed Title V air operation permit for a period of 30 days from the date of publication of the Public Notice. Written comments must be received by the close of business (5:00 p.m.), on or before the end of this 30-day period by the Permitting Authority at the above address. As part of his or her comments, any person may also request that the Permitting Authority hold a public meeting on this permitting action. If the Permitting Authority determines there is sufficient interest for a public meeting, it will publish notice of the time, date, and location in the Florida Administrative Weekly (FAW). If a public meeting is requested within the 30-day comment period and

(Public Notice to be Published in the Newspaper)

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

conducted by the Permitting Authority, any oral and written comments received during the public meeting will also be considered by the Permitting Authority. If timely received written comments or comments received at a public meeting result in a significant change to the draft/proposed permit, the Permitting Authority shall issue a revised draft/proposed permit and require, if applicable, another Public Notice. All comments filed will be made available for public inspection. For additional information, contact the Permitting Authority at the above address or phone number.

Petitions: A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed with (received by) the Department's Agency Clerk in the Office of General Counsel of the Department of Environmental Protection at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S. must be filed within 14 days of publication of the Public Notice or receipt of a written notice, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the Permitting Authority for notice of agency action may file a petition within 14 days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address and telephone number of the petitioner; the name address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial rights will be affected by the agency determination; (c) A statement of when and how the petitioner received notice of the agency action or proposed decision; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action. A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this Public Notice of Intent to Issue Air Permit. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation: Mediation is not available for this proceeding.

EPA Review: EPA has agreed to treat the draft/proposed Title V air operation permit as a proposed Title V air operation permit and to perform its 45-day review provided by the law and regulations concurrently with the public comment period, provided that the applicant also transmits an electronic copy of the required proof of publication directly to EPA at the following email address: ouquendo.ana@epamail.epa.gov. Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day review period is performed after the public comment period has ended. The final Title V air operation permit will be

(Public Notice to be Published in the Newspaper)

PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMIT

issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that result in a different decision or significant change of terms or conditions. The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following website address: <http://www.epa.gov/region4/air/permits/Florida.htm>.

Objections: Pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 days of the expiration of the Administrator's 45-day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to the issuance of any Title V air operation permit. Any petition shall be based only on objections to the permit that were raised with reasonable specificity during the 30-day public comment period provided in the Public Notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460. For more information regarding EPA review and objections, visit EPA's Region 4 web site at <http://www.epa.gov/region4/air/permits/Florida.htm>.

STATEMENT OF BASIS

Title V Air Operation Permit Renewal
Permit No. 1050234-019-AV

APPLICANT

The applicant for this project is Florida Power Corporation D/B/A Progress Energy Florida, Inc. (PEF) The applicant's responsible official and mailing address are: Martin J. Drango, Plant Manager, Hines Energy Complex, 7700 County Road 555, Bartow, Florida 33830.

FACILITY DESCRIPTION

The applicant operates the existing Hines Energy Complex, which is located in Polk County at 7700 County Road 555, Bartow, Florida.

This facility has a total generating capacity of approximately 2,090 megawatts (MW) and is a major source of hazardous air pollutants (HAP). This facility consists of: four blocks (1, 2, 3 and 4), each with two combined cycle combustion turbines (CT) with unfired heat recovery steam generators (HRSG); a 99 million British thermal unit per hour (MMBtu/hr) auxiliary boiler; two fuel oil storage tanks; and, an emergency diesel fire pump. Emissions from each CT and HRSG combination are vented through a single stack. The combustion turbines may fire fuel oil or natural gas. Emissions are monitored by continuous emissions monitors (CEMS) for each power block.

This facility also includes miscellaneous unregulated/insignificant emissions units and/or activities.

PROJECT DESCRIPTION

The purpose of this permitting project is to renew the existing Title V permit for the above referenced facility.

PROCESSING SCHEDULE AND RELATED DOCUMENTS

Application for a Title V Air Operation Permit Renewal received May 20, 2011.

Requested for Additional Information sent July 19, 2011.

Additional Information response received October 11, 2011.

Draft/proposed permit issued MM/DD/YYYY.

Final Renewed permit effective January 1, 2012.

PRIMARY REGULATORY REQUIREMENTS

Title III: The facility is identified as a major source of hazardous air pollutants (HAP).

Title IV: The facility operates units subject to the acid rain provisions of the Clean Air Act.

Title V: The facility is a Title V major source of air pollution in accordance with Chapter 62-213, Florida Administrative Code (F.A.C.).

PSD: The facility is a Prevention of Significant Deterioration (PSD)-major source of air pollution in accordance with Rule 62-212.400, F.A.C.

NSPS: The facility operates units subject to the New Source Performance Standards (NSPS) of 40 Code of Federal Regulations (CFR) 60.

NESHAP: The facility operates units subject to the National Emissions Standards for Hazardous Air Pollutants (NESHAP) of 40 CFR 6.

CAIR: The facility is subject to the Clean Air Interstate Rule (CAIR) set forth in Rule 62-296.470, F.A.C.

Siting: This plant is subject to certain requirements of Chapter 403, Part II, Florida Statutes, Electric Power Plant and Transmission Line Siting, including a modification of the conditions Site Certification PA 92-33.

STATEMENT OF BASIS

PROJECT REVIEW

Changes made in this permitting renewal project include the follows:

- Remove Emissions Unit 001 (Facility 7775047), Relocatable Diesel Generator(s). This facility is no longer subjected to Permit No. AC09-202080.
- Include Emissions Unit 004, Diesel Fuel Fire Pump. This engine is regulated under NESHAP Subpart ZZZZ.
- Include Rental Non-road Emergency Diesel Generator(s) in the List of Insignificant Emissions Unit and/or Activities. This/these generator(s) is/are defined as Non-road Engines under 40 CFR 1068.30,(1)(iii).
- Incorporate new Title V formatting as adoptable by the Division of Air Resource Management as of November 1, 2010. These formatting changes include replacing the previous Appendix TV-6 with new Appendices RR, TR and TV.
- Minor administrative type clarifications as requested in Appendix H of Title V permit renewal application submitted on May 20, 2011.

CONCLUSION

This project renews Title V air operation permit No. 1050234-014-AV, which was effective on January 1, 2007. This Title V air operation permit renewal is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4, 62-210, 62-213 and 62-214, F.A.C.

P.E. CERTIFICATION STATEMENT

PERMITTEE

Progress Energy Florida, Inc.
Hines Energy Complex
7700 County Road 555
Bartow, Florida 33830


Permit No. 1050234-019-AV
Facility ID No. 1050234
Hines Energy Complex
Title V Air Operation Permit Renewal
Polk County, Florida


PROJECT DESCRIPTION

This project is for the renewal of Title V permit No. 1050234-014-AV for the above referenced facility. Minor revisions were requested by the applicant as part of this project. Some of the requested changes were made, but others will be addressed through a future air construction permit to be processed concurrently with a Title V permit revision. The renewed permit has been reformatted to reflect the current permit style.

I HEREBY CERTIFY that the air pollution control engineering features described in the above referenced application and subject to the proposed permit conditions provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-4 and 62-204 through 62-297. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including, but not limited to, the electrical, mechanical, structural, hydrological, geological, and meteorological features).

This review was conducted by Kris Lanh, Engineering Specialist II under my responsible supervision.


Jonathan K. Holtom, P.E.
Registration Number: 0052664




Progress Energy Florida, Inc.
Hines Energy Complex
Facility ID No. 1050234
Polk County

Title V Air Operation Permit Renewal

Permit No. 1050234-019-AV

(Renewal of Title V Air Operation Permit No. 1050234-014-AV)



Permitting Authority:

State of Florida
Department of Environmental Protection
Division of Air Resource Management
Bureau of Air Regulation
Title V Section
2600 Blair Stone Road
Mail Station #5505
Tallahassee, Florida 32399-2400
Telephone: (850) 717-9000
Fax: (850) 717-9097

Compliance Authority:

Department of Environmental Protection
Southwest District Office
13051 N. Telecom Parkway
Temple Terrace, FL 33637-0926
Telephone: 813/632-7600
Fax: 813/744-6084

Title V Air Operation Permit Renewal

Permit No. 1050234-019-AV

Table of Contents

<u>Section</u>	<u>Page Number</u>
Placard Page	1
I. Facility Information.	
A. Facility Description.	2
B. Summary of Emissions Units.	2
C. Applicable Regulations.	3
II. Facility-wide Conditions.	4
III. Emissions Units and Conditions.	
A. Emission Units 001 & 002, Westinghouse 501FC Combined Cycle Combustion.	6
Turbines (CCCT): Power Block 1 (PB 1)	
B. Emission Unit 003, Auxiliary Steam Boiler.	14
C. Emissions Unit 004, Clarke Diesel Fuel Fire Pump.	16
D. Emission Units 014 & 015, Westinghouse 501FD CCCT: (PB 2).	19
E. Emission Units 016 & 017, Westinghouse 501FD CCCT: (PB 3).	30
F. Emission Units 018 & 019, General Electric 7FA CCCT: (PB 4).	41
IV. Acid Rain Part.	51
V. Clean Air Interstate Rule Part.	56
VI. Appendices.	62
Appendix A, Abbreviations, Acronyms, Citations and Identification Numbers.	
Appendix G, Combustion Turbine Heat Input Curves.	
Appendix I, List of Insignificant Emissions Units and/or Activities.	
Appendix NESHAP, Subpart A - General Provisions.	
Appendix NESHAP, Subpart YYYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.	
Appendix NSPS, Subpart A - General Provisions.	
Appendix NSPS, Subpart Dc - Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units	
Appendix NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines.	
Appendix RR, Facility-wide Reporting Requirements.	
Appendix TR, Facility-wide Testing Requirements.	
Appendix TV, Title V General Conditions.	
Attachments.	At End
Figure 1, Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance (40 CFR 60, July, 1996).	
Table H, Permit History.	

DRAFT/PROPOSED PERMIT

PERMITTEE:

Progress Energy Florida, Inc.
100 Central Avenue, HE44
St. Petersburg, Florida 33701-5511

Permit No. 1050234-019-AV
Hines Energy Complex
Facility ID No. 1050234
Title V Air Operation Permit Renewal

The purpose of this permit is to renew the Title V air operation permit for the above referenced facility. The existing Hines Energy Complex is located in Polk County at 7700 County Road 555, Bartow, Florida. UTM Coordinates are: Zone 17, 414.4 km East and 3073.9 km North. Latitude is: 27° 47' 19" North; and, Longitude is: 81° 52' 10" West.

The Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to operate the facility in accordance with the terms and conditions of this permit.

Effective Date: January 1, 2012
Renewal Application Due Date: May 20, 2016
Expiration Date: December 31, 2016

(Draft/Proposed)

Jeffery F. Koerner, Program Administrator
Office of Permitting and Compliance
Division of Air Resource Management

JFK/jkh/kl

SECTION I. FACILITY INFORMATION.

Subsection A. Facility Description

Power Block 1 consists of two combined cycle combustion turbines (CT) with unfired heat recovery steam generators (HRSG), for a nominal total of 500 megawatts (MW), a 99 million British thermal unit per hour (MMBtu/hr) auxiliary boiler, and a 97,570 barrel fuel oil storage tank. Emissions from each CT and HRSG combination are vented through a single stack.

Power Block 2 consists of two combined cycle combustion turbines with unfired HRSG, and an associated single steam-turbine electrical generator, for a nominal total of 530 MW. Emissions from each CT and HRSG combination are vented through a single stack.

Power Block 3 consists of two combined cycle combustion turbines with unfired HRSG, and an associated single steam-turbine electrical generator, for a nominal total of 530 MW. Emissions from each CT and HRSG combination are vented through a single stack.

Power Block 4 consists of two combined cycle combustion turbines with unfired HRSG, and an associated single steam-turbine electrical generator, for a nominal total of 530 MW. Emissions from each CT and HRSG combination are vented through a single stack.

The entire facility (inclusive of all Power Blocks 1, 2, 3 and 4) has a total generating capacity of approximately 2,090 MW.

Subsection B. Summary of Emissions Units

E.U. ID No.	Brief Description
<i>Regulated Emissions Units</i>	
001	170 MW Westinghouse 501FC CT1A with unfired HRSG
002	170 MW Westinghouse 501FC CT1B with unfired HRSG
014	170 MW Westinghouse 501FD CT2A with unfired HRSG
015	170 MW Westinghouse 501FD CT2B with unfired HRSG
016	170 MW Westinghouse 501FD CT3A with unfired HRSG
017	170 MW Westinghouse 501FD CT3B with unfired HRSG
018	170 MW General Electric Model 7FA CT4A with unfired HRSG
019	170 MW General Electric Model 7FA CT4B with unfired HRSG
003	Auxiliary Steam Boiler
004	Clarke Diesel Fire Pump

Also included in this permit are miscellaneous unregulated/insignificant emissions units and/or activities (see Appendix I - List of Insignificant Emissions Units and/or Activities).

SECTION I. FACILITY INFORMATION.

Subsection C. Applicable Regulations

Based on the Title V Air Operation Renewal application received May 20, 2011, this facility is a major source of hazardous air pollutants (HAPs). The existing facility is a PSD major source of air pollutants in accordance with Rule 62-212.400, F.A.C. A summary of applicable regulations is shown in the following table.

Regulation	EU ID
<i>Federal Rule Citations</i>	
NSPS – 40 CFR 60, Subpart A – General Provisions.	001, 002, 014, 015, 016, 017, 018, 019
NSPS - 40 CFR 60, Subpart GG - Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800, F.A.C.	
NSPS – 40 CFR 72 – 80 - Federal Acid Rain Program, Phase II.	
NESHAP – 40 CFR 63, Subpart A – General Provisions.	001, 002, 004 014, 015, 016, 017, 018, 019
NESHAP – 40 CFR 63, Subpart YYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.	
NESHAP – 40 CFR 63, Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.	004
<i>State Rule Citations</i>	
Rule 62-4, F.A.C. (Permitting Requirements).	001, 002, 003 014, 015, 016 017, 018, 019
Rule 62-204, F.A.C. (Ambient Air Quality Requirements, PSD Increments, and Federal Regulations Adopted by Reference).	
Rule 62-210, F.A.C. (Permits Required, Public Notice, Reports, Stack Height Policy, Circumvention, Excess Emissions, and Forms).	
Rule 62-212, F.A.C. (Preconstruction Review, PSD Review and BACT).	
Rule 62-213, F.A.C. (Title V Air Operation Permits for Major Sources of Air Pollution).	
Rule 62-214, F.A.C. (Requirements For Sources Subject To The Federal Acid Rain Program).	
Rule 62-296, F.A.C. (Emission Limiting Standards).	
Rule 62-297, F.A.C. (Test Methods and Procedures, Continuous Monitoring Specifications, and Alternate Sampling Procedures).	
PSD-FL-195 and revisions (A, B & C); PPSA: PA 92-33.	
PSD-FL-296 and revisions (A & B).	
PSD-FL-330 and revision (A).	001, 002
PSD-FL-342; Power Plant Siting Case No. PA 92-33	014, 015
	016, 017
	018, 019

SECTION II. FACILITY-WIDE CONDITIONS.

The following conditions apply facility-wide to all emission units and activities.

FW1. Appendices. The permittee shall comply with all documents identified in Section VI, Appendices, listed in the Table of Contents. Each document is an enforceable part of this permit unless otherwise indicated. [Rule 62-213.440(1), F.A.C.]

Emissions and Controls

FW2. Not federally Enforceable. Objectionable Odor Prohibited. No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rule 62-296.320(2) and 62-210.200(Definitions), F.A.C.]

{Permitting Note: Nothing is deemed necessary and ordered at this time.}

FW3. General Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed-necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]

FW4. General Visible Emissions. No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20% opacity. EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. This regulation does not impose a specific testing requirement. [Rule 62-296.320(4)(b), F.A.C.]

FW5. Unconfined Particulate Matter. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions. Reasonable precautions to prevent emissions of unconfined particulate matter at this facility include:

- a. Maintenance of paved areas as needed;
- b. Regular mowing of grass and care of vegetation;
- c. Limiting access to plant property by unnecessary vehicles; and,
- d. Fugitive dust emissions during the construction period shall be minimized by covering or watering dust generation areas.

[Rule 62-296.320(4)(c), F.A.C.; and, proposed by applicant in Title V air operation permit renewal application received May 20, 2011]

Annual Reports and Fees

See Appendix RR, Facility-wide Reporting Requirements for additional details.

FW6. Annual Operating Report. The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by April 1st of each year. [Rule 62-210.370(3), F.A.C.]

FW7. Annual Emissions Fee Form and Fee. The annual Title V emissions fees are due (postmarked) by March 1st of each year. The completed form and calculated fee shall be submitted to: Major Air Pollution Source Annual Emissions Fee, P.O. Box 3070, Tallahassee, Florida 32315-3070. The forms are available for download by accessing the Title V Annual Emissions Fee On-line Information Center at the following Internet web site: <http://www.dep.state.fl.us/air/emission/tvfee.htm>. [Rule 62-213.205, F.A.C.]

SECTION II. FACILITY-WIDE CONDITIONS.

FW8. Annual Statement of Compliance. The permittee shall submit an annual statement of compliance to the compliance authority at the address shown on the cover of this permit within 60 days after the end of each calendar year during which the Title V permit was effective. [Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

FW9. Prevention of Accidental Releases (Section 112(r) of CAA).

- a. As required by Section 112(r)(7)(B)(iii) of the CAA and 40 CFR 68, the owner or operator shall submit an updated Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center. (See paragraph e., below.)
- b. As required under Section 252.941(1)(c), F.S., the owner or operator shall report to the appropriate representative of the Division of Emergency Management, as established by department rule, within one working day of discovery of an accidental release of a regulated substance from the stationary source, if the owner or operator is required to report the release to the United States Environmental Protection Agency under Section 112(r)(6) of the CAA.
- c. The owner or operator shall submit the required annual registration fee to the Division of Emergency Management on or before April 1, in accordance with Part IV, Chapter 252, F.S., and Rule 9G-21, F.A.C.
- d. Any required written reports, notifications, certifications, and data required to be sent to the Division of Emergency Management, should be sent to: Division of Emergency Management, 2555 Shumard Oak Boulevard, Tallahassee, FL 32399-2100, Telephone: (850) 413-9970, Fax: (850) 488-1739.
- e. Any Risk Management Plans, original submittals, revisions, or updates to submittals, should be sent to: RMP Reporting Center, Post Office Box 10162, Fairfax, VA 22038, Telephone: (703) 227-7650.
- f. Any required reports to be sent to the National Response Center, should be sent to: National Response Center, EPA Office of Solid Waste and Emergency Response, USEPA (5305 W), 401 M Street SW, Washington, D.C. 20460, Telephone: (800) 424-8802.
- g. Send the required annual registration fee using approved forms made payable to: Cashier, Division of Emergency Management, State Emergency Response Commission, 2555 Shumard Oak Boulevard, Tallahassee, FL 32399-2149

[Part IV, Chapter 252, F.S.; and, Rule 9G-21, F.A.C.]

FW10. Other Requirements.

- a. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one. [Rule 62-213.440, F.A.C.]
- b. The permittee shall submit all compliance related notifications and reports required of this permit to the Department's Southwest District office at the address shown on the cover page to this permit.
- c. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to: United States Environmental Protection Agency, Region 4: Air, Pesticides & Toxics Management Division, Air and EPCRA Enforcement Branch, Air Enforcement Section, 61 Forsyth Street, Atlanta, Georgia 30303, Telephone: 404/562-9155, Fax: 404/562-9164

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001 and 002

The specific conditions in this section apply to the following emissions units:

EU No.	Brief Description
001	170 MW Westinghouse 501FC CT1A with unfired HRSG
002	170 MW Westinghouse 501FC CT1B with unfired HRSG

Emission units 001 and 002 each consist of a combined cycle Westinghouse 501FC Combustion Turbine, each with a nominal generator rating of 170 MW and each with a maximum heat input rating of 1,915 MMBtu/hr (HHV), while firing natural gas, and 2,020 MMBtu/hr (HHV), while firing fuel oil, based on a compressor inlet air temperature of 59°F, the HHV of each fuel, and 100% load. NO_x emissions are controlled with dry low NO_x burners (DLN) and/or Selective Catalytic Reduction (SCR) for natural gas firing and wet injection for fuel oil firing. Each combustion turbine incorporates an unfired heat recovery steam generator (HRSG). Steam from both HRSGs is delivered to a single steam turbine-electrical generator, which has a generating capacity of 160 MW. The total generating capacity of the "2-on-1" combined cycle unit is approximately 500 MW.

{Permitting notes: These emissions units are regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; Rule 212.400(5), F.A.C., Prevention of Significant Deterioration (PSD); PSD-FL-195 and revisions (A, B & C); PPSA: PA 92-33; and, Rule 62-212.400, F.A.C. Stack Parameters: height = 125ft, exit diameter = 19.0 ft, exit temperature = 190°F., and flow rate = 1,009,500 acfm.}

Essential Potential to Emit (PTE) Parameters

A.1. Permitted Capacity. The maximum allowable heat input rates at an ambient temperature of 59 degrees Fahrenheit are as follows:

EU No.	MMBtu/hr Heat Input	Fuel Type
001 & 002	1,915	Natural Gas
	2,020	Fuel Oil

Heat input may vary depending on ambient conditions and the CT characteristics. The manufacturer's curves shall be used to establish the heat input rates over a range of temperatures for the purpose of compliance determination. See Appendix G, Combustion Turbine Heat Input Curves. [Permit No. 1050234-003-AC/PSD-FL-195B), Specific Condition A.1.]

A.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

A.3. Methods of Operation - Fuels. The only fuels that are allowed to be burned in these units are:

- a. *Natural Gas* - having a maximum sulfur content of 1 grain per 100 cf of natural gas, or shall be fired in each combustion turbine at all times.
- b. *Fuel Oil* - having a maximum sulfur content of 0.05%, by weight. The maximum allowable consumption of fuel oil for the two turbines is 13,762,806 gallons per year, which is equivalent to an aggregate of 1,000 hours per year of operation at full load.

[1050234-003-AC/PSD-FL-195B, Specific Conditions A.3. & A.5.]

A.4. Hours of Operation. Each of the combustion turbines in Power Block 1 may operate continuously, i.e., 8,760 hours/year. [1050234-003-AC/PSD-FL-195B, Specific Condition A.2.]

Control Technology

A.5. Control of Nitrogen Oxides (NO_x). Control of nitrogen oxides from each CT while firing natural gas shall be accomplished using dry low NO_x burners (DLN) and SCR. [Permit Nos. PSD-FL-195A/PA-92-33 and 105234-003-AC/PSD-FL-195B, Specific Condition B.1.i.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001 and 002

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions A.6. – A.12. are based on the specified averaging time of the applicable test method.

A.6. Visible Emissions (VE). As determined by stack tests, visible emissions shall not exceed:

- a. *When firing natural gas:* 10 percent opacity.
- b. *When firing fuel oil:* 20 percent opacity.

[40 CFR 60.334(i)(1) and 1050234-003-AC/PSD-FL-195B, Specific Condition B.1.]

A.7. Nitrogen Oxides (NO_x). As determined by CEMS and adjusted to a reference temperature of 59°F, except during periods of startup, shutdown, malfunction, NO_x emissions shall not exceed:

a. *Pursuant to PSD:*

(1) When firing natural gas:

- (a) 73 pounds per hour (lbs/hr) per CT, 24-hour block average midnight-to-midnight (for informational purposes, lbs/hr limit is based on 12 ppmvd at 15% O₂, not ISO corrected).
- (b) 639 tons per year (tpy) (total from both CTs).

(2) When firing fuel oil:

- (a) 305 pounds lbs/hr per CT, 24-hour block average midnight-to-midnight (for informational purposes, lbs/hr limit is based on 42 ppmvd at 15% O₂ at full load operation, not ISO corrected).
- (b) 153 tpy (total from both CTs).

(3) Pollutant emission rates may vary depending on ambient conditions (compressor inlet temperatures) and the CT characteristics. Manufacturer's curves for the NO_x emission rate correction to other temperatures at different loads were provided to the DEP for review and are now a part of this permit (see Appendix G-1). The manufacturer's curves shall be used to establish pollutant emission rates over a range of temperatures for the purpose of compliance determination. Emission limitations in lbs/hr/CT of NO_x are blocked 24-hour averages (midnight-to-midnight) and are determined continuously by a Continuous Emissions Monitoring System (CEMS).

b. *Pursuant to NSPS:* For fuel oil firing, NO_x levels of 42 ppm @ 15% are based on a fuel bound nitrogen content of 0.015 percent or less. The emission limit for NO_x is adjusted as follows for higher nitrogen contents up to a maximum of 0.030 percent by weight:

Fuel Bound Nitrogen (% by weight)	NO _x Levels (ppmvd @ 15% O ₂)	NO _x Emissions	
		lb/hr/CT	TPY (both CTs)
0.015 or less	42	305	153
0.020	44	320	160
0.025	46	334	167
0.030	48	349	175

Using the formula $STD = 0.0042 + F$, where:

STD = allowable NO_x emissions (percent by volume at 15 percent O₂ and on a dry basis)

F = NO_x emission allowance for fuel-bound nitrogen defined by the following table:

Fuel-Bound Nitrogen (% by weight)	F (NO _x % by volume)
0 < N < 0.015	0
0.015 < N < 0.03	0.04(N-0.015)

where: N = the nitrogen content of the fuel (% by weight).

[40 CFR 60.334(i)(1) and 1050234-003-AC/PSD-FL-195(B), Specific Condition B.1.]

A.8. Particulate Material/Particulate Matter less than 10 Microns (PM/PM₁₀). As determined by stack tests, particulate matter emissions shall not exceed:

a. *While firing natural gas:*

- (1) 15.6 lbs/hour per CT, and
- (2) 79 tpy (total from both CT).

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001 and 002

b. *While firing fuel oil:*

- (1) 44.8 lbs/hour per CT, and
- (2) 21 tpy (total from both CT).

PM/PM₁₀ emission limitations include sulfuric acid mist. [40 CFR 60.334(i)(1) and 1050234-003-AC/PSD-FL-195B, Specific Condition B.1.]

A.9. Carbon Monoxide (CO). As determined by stack tests, carbon monoxide emissions shall not exceed:

a. *While firing natural gas:*

- (1) 77 lbs/hour per CT, 24-hour block average midnight-to-midnight (for informational purposes, lbs per hour limit is based on 25 ppmvd at 15% O₂, not ISO corrected), and
- (2) 675 tpy (total from both CT).

b. *While firing fuel oil:*

- (1) 93 lbs/hour per CT, 24-hour block average midnight-to-midnight (for informational purposes, lbs per hour limit is based on 30 ppmvd at 15% O₂, not ISO corrected), and
- (2) 47 tpy (total from both CT).

[40 CFR 60.334(i)(1) and 1050234-002-AC/ PSD-FL-195B, Specific Condition B.1.]

A.10. Sulfur Dioxide(SO₂). As determined by fuel analysis, sulfur dioxide emissions shall not exceed:

a. *While firing natural gas:*

- (1) 4.7 lbs/hour per CT, and
- (2) 44 tpy (total from both CT).

b. *While firing fuel oil:*

- (1) 94 lbs/hour per CT, and
- (2) 47 tpy (total from both CT).

SO₂ emissions are based on a maximum of 1 grain of S/100 cf of natural gas and 0.05 percent sulfur, by weight, in the fuel oil. [40 CFR 60.334(i)(1) and 1050234-002-AC/ PSD-FL-195B, Specific Condition B.1.]

A.11. Volatile Organic Compound (VOC). As determined by stack tests, VOC emissions shall not exceed:

a. *While firing natural gas:*

- (1) 10.4 lbs/hour per CT (for informational purposes, lbs per hour limit is based on 7 ppmvd), and
- (2) 91 tpy (total from both CT).

b. *While firing fuel oil:*

- (1) 19.0 lbs/hour per CT (for informational purposes, lbs per hour limit is based on 10 ppmvd), and
- (2) 5.6 tpy (tpy total is from both CT).

[40 CFR 60.334(i)(1) and 1050234-002-AC/ PSD-FL-195B, Specific Condition B.1.]

A.12. Ammonia. Ammonia slip shall not exceed 10 ppm. [40 CFR 60.334(i)(1) and 1050234-002-AC/ PSD-FL-195B, Specific Condition B.1.]

Excess Emissions

Rule 62-210.700 (Excess Emissions), F.A.C. cannot vary any requirement of an NSPS, NESHAP or Acid Rain program provision.

A.13. Excess Emissions Allowed. Excess emissions resulting from startup, shutdown, or malfunction, shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized. Excess emissions occurrences shall in no case exceed two hours in any 24-hour period except in the event that the steam turbine has been shut down for 8 hours or more, in which case, the following provisions apply:

- a. During a cold start-up to combined cycle operation, up to four hours of excess emissions are allowed in a 24-hour period. Cold start-up is defined as a start-up to combined cycle operation following a steam turbine shutdown lasting at least 48 hours.

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001 and 002

- b. During a warm start up to combined cycle operation, up to three hours of excess emissions are allowed in a 24-hour period. Warm start-up is defined as a startup to combined cycle operation following a steam turbine shutdown lasting at least 8 hours.
- c. During fuel switches (oil-to-gas or gas-to-oil), up to two hours of excess emissions per fuel switch per emissions unit are allowed.
- d. Allowable Excess Emissions Convenience Summary:

Method of Operation	Excess Emissions Conditions	Period Authorized for Excess Emissions
Hot Start-up	Complete shutdown of CT-HRSG lasting ≤ 8 hours	≤ 2 hours/start-up/unit
Cold STG Start-up	STG shutdown lasting ≥ 48 hours	≤ 4 hours /start-up/unit
Warm CT-HRSG Start-up	Complete shutdown of CT-HRSG lasting ≥ 8 hours	≤ 3 hours/start-up/unit
Shutdown	Shutdown	≤ 2 hours/shutdown/unit
Fuel Switches	Oil-to-Gas or Gas-to-Oil	≤ 2 hours/fuel-switch/unit
Documented Malfunctions	Malfunctions	≤ 2 hours in any 24-hour block

[Rules 62-210.700(1), 62-210.700(5) & 62-213.440(1), F.A.C.; and, Permit No. 1050234-015-AC/PSD-FL-195D, Specific Condition B.3.]

A.14. Excess Emissions Prohibited. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Monitoring of Operations

A.15. Proper Operation. At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source. [40 CFR 60.11(d)].

A.16. Fuel Monitoring. The permittee shall monitor sulfur content and nitrogen content of the new No. 2 distillate fuel oil and sulfur content of natural gas. These values may be provided by the vendor and the frequency of determinations of these values shall be as follows:

- a. *New No. 2 Distillate Fuel Oil:* The values (sulfur and nitrogen content) shall be determined on each occasion that fuel is transferred to the storage tanks from any other source. Records of these values shall be kept by the facility for a five year period for regulatory agency inspection purposes.
- b. *Natural Gas:* Pursuant to 40 CFR 60, Subpart GG, a custom fuel monitoring schedule for the determination of these values shall be followed for the natural gas fired at this facility and shall be as follows (See Appendix GG, NSPS Subpart GG Requirements for Gas Turbines):

Custom Fuel Monitoring Schedule for Natural Gas (NG)

- (1) Monitoring of fuel nitrogen content shall not be required if NG is the only fuel being fired in the gas turbines.
- (2) Sulfur Monitoring:

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001 and 002

- (a) Analysis for fuel sulfur content of the natural gas shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternative method. These methods are referenced in 40 CFR 60, Subpart GG. The permittee can use these methods or their latest editions.
 - (b) This custom fuel monitoring schedule shall become effective on May 3, 2001, the date the Initial Title V Permit was issued. Effective the date of this custom schedule, sulfur monitoring shall be conducted twice monthly for six months. If this monitoring shows little variability in the fuel sulfur content, and indicates consistent compliance with 40 CFR 60.333 and the conditions of this permit, then sulfur monitoring shall be conducted once per quarter for six quarters. If monitoring data is provided by the applicant which demonstrates consistent compliance with the requirements herein the applicant may begin monitoring as per the requirements of 2(c).
 - (c) If after the monitoring required in item 2(b) above, or herein, the sulfur content of the fuel shows little variability and, calculated as sulfur dioxide, represents consistent compliance with the sulfur dioxide emission limits specified under 40 CFR 60.333 and the conditions of this permit, sample analysis shall be conducted twice per annum. This monitoring shall be conducted during the first and third quarters of each calendar year.
 - (d) Should any sulfur analysis as required in items 2(b) or 2(c) above indicate noncompliance with 40 CFR 60.333 and the conditions of this permit, the owner or operator shall notify the Department of such excess emissions and the custom schedule shall be reexamined. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
- (3) If there is a change in fuel supply, the owner or operator must notify the Department of such change for re-examination of this custom schedule. A substantial change in natural gas quality (i.e., sulfur content varying by more than 1 grain/100 standard cubic feet of gas) shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
 - (4) Records of sample analysis and fuel supply pertinent to this custom schedule shall be retained for a period of five years, and be available for inspection by personnel of federal, state, and local air pollution control agencies.

[40 CFR 60.334 & 40 CFR 60.335; Custom Fuel Monitoring Schedule Approved on June 1, 2000; and, Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition E.2.h.]

A.17. Water Injection Monitoring Requirements. In accordance with the manufacturer's specifications, the permittee shall operate and maintain a monitoring system to continuously measure and record the water-to-fuel ratio when firing distillate oil. The permittee shall document the water-to-fuel ratio required to meet permitted emissions levels over the range of load conditions allowed by this permit. The NO_x CEMS is used to demonstrate compliance with the NO_x emissions standards. During NO_x CEMS downtimes or malfunctions, the permittee shall monitor the water-to-fuel ratio and operate at a level that is consistent with the documented flow rate for the gas turbine load condition. [Rule 62-213.440(1)(b), F.A.C.]

A.18. Ammonia Monitoring Requirements. In accordance with the manufacturer's specifications, the permittee shall operate and maintain an ammonia flow meter to measure and record the ammonia injection rate to the SCR system. The permittee shall document the general range of ammonia flow rates required to meet permitted emissions levels over the range of load conditions allowed by this permit by comparing NO_x emissions recorded by the CEM system with ammonia flow rates recorded using the ammonia flow meter. During NO_x monitor downtimes or malfunctions, the permittee shall operate at the ammonia flow rate that is consistent with the documented flow rate for the combustion turbine load condition. [Rule 62-213.440(1)(b), F.A.C.]

Continuous Monitoring Requirements

A.19. Oxides of Nitrogen. NO_x emissions shall be determined continuously by a Continuous Emissions Monitoring System (CEMS). A CEMS operated and maintained in accordance with 40 CFR 75 shall be used.

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001 and 002

Compliance with the NO_x emissions standards shall be demonstrated with this CEMS based on a 24-hour block average. Based on CEMS data at the end of each operating day, new 24-hour average emission rates, both actual and allowable (based on compressor inlet temperatures) are calculated from the arithmetic average of all valid hourly emission rates during the previous 24 operating hours. Valid hourly emission rates shall not include periods of startup (including fuel switching), shutdown, or malfunction as defined in Rule 62-210.200(Definitions), F.A.C., where emissions exceed the NO_x standard. These excess emission periods shall be reported as required by 40 CFR 60.7(b) (see Appendix NSPS, Subpart A - General Provisions). A valid hourly emission rate shall be calculated for each hour in which two NO_x and carbon dioxide (or oxygen) concentrations are obtained at least 15 minutes apart. When monitoring data is not available, substitution for missing data shall be handled as required by Title IV (40 CFR 75) to calculate the 24-hour block average. [1050234-003-AC/PSD-FL-195B, Specific Condition B.1.a.]

- A.20. Continuous Emission Monitoring System (CEMS).** For each combined cycle unit, the permittee shall install, operate, and maintain a continuous emission monitoring system (CEMS) (in accordance with 40 CFR 60, Appendix F, or 40 CFR 75, whichever is more stringent) or use other DEP approved alternate methods to monitor nitrogen oxides and, if necessary, a diluent gas (CO₂ or O₂).
- Each CEMS shall meet performance specifications of 40 CFR 60, Appendix B, or 40 CFR 75, whichever is more stringent.
 - CEMS data shall be recorded and reported in accordance with 40 CFR 60, Appendix A and Subpart GG, or 40 CFR 75, whichever is more stringent. The record shall include periods of start up, shutdown, and malfunction. Compliance with Specific Condition A.7. for NO_x shall be determined by CEMS on a mass emission rate basis (lbs/hr) using EPA Method 19 and hourly averaged heat inputs (MMBtu/hr).
 - A malfunction means any sudden and unavoidable failure of air pollution control equipment or process equipment to operate in a normal or usual manner. Failures that are caused entirely or in part by poor maintenance, careless operation or any other preventable upset condition or preventable equipment breakdown shall not be considered malfunctions.
 - The procedures under 40 CFR 60.13 or 40 CFR 75, whichever is more stringent, shall be followed for installation, evaluation, and operation of all CEMS.
 - For purposes of the reports required under this permit, excess emissions are defined as any calculated average emission rate, as determined pursuant to Specific Condition A.13. which exceeds the applicable emission limits in Specific Condition A.7.

[Permit No. 1050234-003-AC/PSD-FL-195B, Specific Conditions D.1 – D.5.]

Test Methods and Procedures

- A.21. Test Methods.** When required, tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
5 or 17	Method for Determining Particulate Matter Emissions (All PM is assumed to be PM ₁₀ .)
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources {Note: The method shall be based on a continuous sampling train.}
18	Measurement of Gaseous Organic Compound Emissions by Gas Chromatography

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001 and 002

Method	Description of Method and Comments
19	Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates (Optional F-factor method may be used to determine flow rate and gas analysis to calculate mass emissions in lieu of Methods 1-4.)
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines
25A	Method for Determining Gaseous Organic Concentrations (Flame Ionization)
ASTM D4294	Method for Determining Sulfur Content of Distillate Oil.
ASTM D1072-80, ASTM D3031-81, ASTM D4084-82, ASTM D3246-81 (or equivalent)	Methods for Determining Sulfur Content of Natural Gas.
CTM-027	Conditional EPA Test Method 027, Measurement of Ammonia Slip (or equivalent method)

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rules 62-297.401 & 62-297.440, F.A.C.; and, Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition C.1.]

A.22. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

A.23. Annual Compliance Tests Required. During each federal fiscal year (October 1st to September 30th), each CT shall be tested to demonstrate compliance with the applicable emissions standards for the following pollutants with the fuel(s) listed below:

- a. *PM.* Only for oil and only if oil is fired for more than 400 hours for the CT in the previous federal fiscal year.
- b. *VE.* Only for oil and only if oil is fired for more than 400 hours for the CT in the previous federal fiscal year.
- c. *CO:*
 - (1) For gas, and
 - (2) For oil if oil is fired for more than 400 hours for the CT in the previous federal fiscal year.
- d. *Fuel Sulfur Content.* For oil.

[Rules 62-213.440(1) & 62-297.310(7), F.A.C.; and, Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition C.1.]

A.24. Critical Fuel Parameters. The maximum sulfur content of the low sulfur fuel oil shall not exceed 0.05 percent, by weight. Compliance shall be demonstrated in accordance with the requirements of 40 CFR 60, Subpart GG, or their latest editions, testing for sulfur content of the fuel oil in the storage tanks on each occasion that fuel is transferred to the storage tanks from any other source. Testing for fuel bound nitrogen content per 40 CFR 60, Subpart GG, or their latest editions, and for fuel oil higher heating value, shall also be conducted on the same schedule. See Appendix GG - NSPS Subpart GG Requirements for Gas Turbines. [40 CFR 60.334 and Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition C.2.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection A. Emissions Unit 001 and 002

- A.25. Sulfur Dioxide - NSPS.** The permittee shall determine compliance with the sulfur standards for distillate oil by using the ASTM reference methods specified in 40 CFR 60, Subpart GG, or their latest editions. The analysis may be performed by the permittee, a service contractor retained by the permittee, the fuel vendor, or any other qualified agency. See Appendix GG - NSPS Subpart GG Requirements for Gas Turbines. [40 CFR 60.334; 40 CFR 60.335; Rules 62-213.440(1), 62-297.440 & 62-297.620(2)(d), F.A.C.; and, Permit No. 1050234-015-AC/PSD-FL-195D, Specific Condition C.1.]
- A.26. Compliance Tests Prior To Renewal.** Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit. [Rule 62-297.310(7), F.A.C.]

Recordkeeping and Reporting Requirements

- A.27. Other Reporting Requirements.** See Appendix RR, Facility-Wide Reporting Requirements, for reporting requirements. [Rule 62-213.440(1)(b), F.A.C.]
- A.28. Daily Fuel Records.** To determine compliance with the natural gas and fuel oil firing heat input limitation, the permittee shall maintain daily records of natural gas and fuel oil consumption for each turbine, as well as recent records of the heating value for each fuel. All records shall be maintained for a minimum of five years after the date of each record and shall be made available to representatives of the Department upon request. [Rule 62-4.070(3), F.A.C.; and, Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition E.1.]

Miscellaneous Conditions

- A.29. Future Addition of Control Devices.** The permittee shall have the option of installing duct module(s) suitable for possible future installation of an oxidation catalyst and/or SCR equipment on each combined cycle generating unit. In the event that the module(s) are not installed in the HRSG, the retrofit costs associated with not making provisions for such technology (initially) shall not be considered in any future economic evaluation to justify not installing SCR or an oxidation catalyst. [Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition A.4.]
- {Permitting Note: SCR was installed between 1999 - 2000 under the authority of Permit No. PSD-FL-195A/PA-92-33, which was subsequently replaced by Permit No. 1050234-003-AC/PSD-FL-195B on August 16, 2000.}*
- A.30. Federal Requirements.** In addition to the above conditions, these units shall also comply with all the applicable requirements of 40 CFR 60, Subparts A and GG. See Appendices NSPS, Subpart A - General Provisions and NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines. [Permit Nos. 1050234-003-AC/PSD-FL-195B, Specific Condition E.1. & 1050234-015-AC/PSD-FL-195D]
- A.31. National Emission Standards for Hazardous Air Pollutants (NESHAP).** The Department determines that compliance with the stationary combustion turbine requirements of 40 CFR 63, Subpart YYYYY, National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines (currently stayed) is required. See Appendix NESHAP, Subpart YYYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines of this permit. Compliance shall be required when the final rule is promulgated. [Rule 62-213.440(1), F.A.C. and 40 CFR 63.6085]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection B. Emissions Unit 003

The specific conditions in this section apply to the following emissions unit:

EU No.	Brief Description
003	Auxiliary Steam Boiler

Emission unit 003 is a fossil fuel steam boiler rated at 99 MMBtu at 1,050 Btu/cf natural gas (HHV). The boiler provides steam for periods of combustion turbine startup or quick startup out of a short-term shutdown. The boiler has no add-on pollution control equipment. Air pollution emissions are controlled by efficient combustion and firing natural gas.

{Permitting note: The emissions unit is regulated under NSPS - 40 CFR 60, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, adopted and incorporated by reference in Rule 62-204.800, F.A.C.}

Essential Potential to Emit (PTE) Parameters

B.1. Permitted Capacity. The maximum operation heat input rate for the boiler is as follows:

Unit No.	MMBtu/hr Heat Input	Fuel Type
003	99	Natural Gas

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; and, 1050234-003-AC/PSD-FL-195B, Specific Condition A.4.]

B.2. Methods of Operation. Only natural gas shall be fired in the auxiliary steam boiler at all times. [Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition B.4.b.]

B.3. Hours of Operation. The operation of the auxiliary steam boiler shall be limited to a maximum of 1,000 hours per year and only during periods of cold CT startup or quick startup out of a short-term shutdown mode, when no other source of steam is available or during periodic testing. [Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition B.4.]

B.4. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

Emission Limitations and Standards

B.5. Nitrogen Oxides (NO_x). Based on vendor-certified stack test data for this model of auxiliary boiler, NO_x emissions shall not exceed 0.1 lb/MMBtu while firing natural gas. [Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition B.4.a.]

B.6. Sulfur Dioxide. Emissions shall be limited by firing natural gas. [Rule 62-296.406(2), F.A.C.; and, Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition B.4.b.]

B.7. Visible Emissions. Visible emissions shall not exceed 10 percent opacity while burning natural gas. [Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition B.4.c.]

Excess Emissions

Rule 62-210.700 (Excess Emissions), F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.

B.8. Excess Emissions Allowed. Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection B. Emissions Unit 003

B.9. Excess Emissions Prohibited. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

Test Methods and Procedures

B.10. Test Methods. When required, tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
9	Visual Determination of the Opacity of Emissions from Stationary Sources

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rule 62-297.401, F.A.C. and Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition C.1.b.]

B.11. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

B.12. Waiver of Annual Compliance Test. By this permit, annual visible emissions compliance testing not required for the emissions unit. [Rule 62-297.310(7)(a)4., F.A.C.]

B.13. Compliance Test Prior To Renewal. A visible emissions compliance test shall be performed prior to obtaining a renewed operation permit to demonstrate compliance with the emission limit in Specific Condition B.7. [Rules 62-210.300(2)(a) and 62-297.310(7)(a), F.A.C.]

Recordkeeping and Reporting Requirements

B.14. Reporting Requirements. See Appendix RR, Facility-Wide Reporting Requirements, for reporting requirements. [Rule 62-213.440(1)(b), F.A.C.]

Miscellaneous Conditions

B.15. Federal Requirements. In addition to the above conditions, these units shall also comply with all the applicable requirements of 40 CFR 60, Subparts A – General Provisions and Dc - Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units. See Appendices NSPS, Subpart A - General Provisions and 40 CFR 60, Subpart Dc - Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units. [Permit No. 1050234-003-AC/PSD-FL-195B, Specific Condition E.2.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection C. Emissions Unit 004

The specific conditions in this section apply to the following emissions units:

EU No.	Brief Description
004	Emergency Diesel-Fired Fire Pump Engine

This emissions unit is a diesel-fired reciprocating internal combustion engine (RICE), Clarke, Model No. DDFP – L6FA 8393V, used to drive an emergency fire pump. The emergency fire pump engine uses low sulfur fuel oil only.

This unit includes one 265 horse power (HP) stationary reciprocating internal combustion engine (RICE). This engine is a diesel-fired, six cylinder, 2-cycle engine and is associated with the emergency fire pump. This engine is regulated under NESHAP Subpart ZZZZ. This engine was installed in 1998. Emissions from this engine are uncontrolled.

The following table contains details for this emissions unit:

Engine Brake HP	Date of Construction	Primary Fuel	Displacement liters/cylinder(l/c)	Serial Number	Applicable Requirements for Compression Ignition Type Engines
265	10/1997	Diesel	9.1 L/V6 (1.5 L per cylinder)	6VF - 218618	40 CFR 63, Subparts A and ZZZZ This engine is an 'existing' unit.

{Permitting Note: This compression ignition (CI) engine used to drive an emergency fire pump is regulated under 40 CFR 63, Subpart ZZZZ, NESHAP for Stationary RICE adopted in Rule 62.204.800(11)(b), F.A.C. Because this engine qualifies as an existing stationary RICE less than 500 HP operating at a major source of HAP, it is not subject to regulation under NSPS 40 CFR 60, Subpart IIII.}

C.0. Duty to Comply. The permittee shall comply with the following operating limitations no later than October 19, 2013. [40 CFR 63.6595(a)]

Essential Potential to Emit (PTE) Parameters

C.1. Hours of Operation.

- a. *Emergency Situations.* There is no time limit on the use of this fire pump engine in emergency situations. [40 CFR 63.6640(f)(1)(i)]
- b. *Maintenance and Readiness Testing.* This engine is authorized to operate for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Operation for maintenance checks and readiness testing is limited to 100 hours per year. [40 CFR 63.6640(f)(1)(ii)]
- c. *Non-emergency Situations.* This engine is authorized to operate up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. [40 CFR 63.6640(f)(1)]
- d. *Engine Startup.* During periods of startup the owner or operator must minimize the engine's time spent at idle and minimize the engine's startup time to a period needed for the appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)]

Emission Limitations and Operating Requirements

C.2. Work or Management Practice Standards.

- a. *Oil.* Change oil and filter every 500 hours of operation or annually, whichever comes first or use an oil analysis program to extend this interval, as provided in e., below. [40 CFR 63 Table 2c(1)(a) and footnote 2]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection C. Emissions Unit 004

- b. *Air Cleaner*. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first. [40 CFR 63 Table 2c(1)(b)]
- c. *Hoses and Belts*. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. [40 CFR 63 Table 2c(1)(c)]
- d. *Operation and Maintenance*. Operate and maintain the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions or develop and follow your own maintenance plan which must provide, to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR 63.6625(e) & 40 CFR 63.6640(a)]
- e. *Oil Analysis*. The owner or operator has the option of using oil analysis to extend the oil change requirement. The oil analysis must be performed at the same frequency specified for changing the oil in paragraph a., of this condition. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. [40 CFR 63.6625(i)]
[40 CFR 63.6602]

Monitoring of Operations

- C.3. *Hour Meter*. The owner or operator must install a non-resettable hour meter if one is not already installed. [40 CFR 63.6625(f)]

Compliance

- C.4. *Continuous Compliance*. Each unit shall be in compliance with the emission limitations and operating standards in this section at all times. [40 CFR 63.6605(a)]
- C.5. *Operation and Maintenance of Equipment*. At all times the owner or operator must operate and maintain, any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the compliance authority which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR 63.6605(b)]

Recordkeeping Requirements

- C.6. *Compliance Records*. The owner or operator must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The records must document how many hours are spent for emergency operation; including what classified the operation as emergency and how many hours are spent for non-emergency operation. [40 CFR 63.6655(f)]

Reporting Requirements

- C.10. *Emergency Situation*. If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Specific

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection C. Emissions Unit 004

Condition C.2. of this section, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable. [40 CFR 63 Table 2c, footnote 1]

Other Federal Requirements

C.11. 40 CFR 63, Subpart A. In addition to the above requirements, this emissions unit shall also comply with the applicable requirements listed below, which are contained in the attached Appendix NESHAP A: 40 CFR 63, Subpart A - General Provisions.

General Provisions Citation	Subject of Citation
§63.1	General applicability of the General Provisions
§63.2	Definitions. Additional terms defined in §63.6675.
§63.3	Units and abbreviations
§63.4	Prohibited activities and circumvention
§63.5	Construction and reconstruction
§63.6(a)	Applicability
§63.6(b)(1)–(4)	Compliance dates for new and reconstructed sources
§63.6(j)	Presidential compliance exemption
§63.7(a)(3)	CAA section 114 authority
§63.7(e)(4)	Administrator may require other testing under section 114 of the CAA
§63.9(i)	Adjustment of submittal deadlines
§63.9(j)	Change in previous information
§63.10(a)	Administrative provisions for recordkeeping/reporting
§63.10(b)(1)	Record retention
§63.10(b)(2)(vi)–(xi)	Records
§63.10(b)(2)(xii)	Records when under waiver
§63.10(b)(2)(xiv)	Records of supporting documentation
§63.10(b)(3)	Records of applicability determination
§63.10(d)(1)	General reporting requirements
§63.10(d)(4)	Progress reports
§63.10(f)	Waiver for recordkeeping/reporting
§63.12	State authority and delegations
§63.13	Addresses
§63.14	Incorporation by reference
§63.15	Availability of information

[40 CFR 63.6665]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

The specific conditions in this section apply to the following emissions units:

E.U. No.	Brief Description of Power Block 2
014	170 MW Westinghouse 501FD CT2A with unfired HRSG
015	170 MW Westinghouse 501FD CT2B with unfired HRSG

Emission units 014 and 015 each consist of a combined cycle Westinghouse 501FD Combustion Turbine, each with a nominal generator rating of 170 MW and each with a maximum heat input rating of 2,048 MMBtu/hr (HHV), while firing natural gas, and 2,155 MMBtu/hr (HHV), while firing fuel oil, based on a compressor inlet air temperature of 59°F, the HHV of each fuel, and 100% load. NO_x emissions are controlled with dry low NO_x burners (DLN) for natural gas firing and wet injection for fuel oil firing, complete with Selective Catalytic Reduction (SCR). Each combustion turbine incorporates an unfired heat recovery steam generator (HRSG). Steam from both HRSGs is delivered to a single steam turbine-electrical generator, which has a generating capacity of 190 MW. The total generating capacity of the “2-on-1” combined cycle unit is approximately 530 MW.

The efficient combustion of natural gas and restricted firing of low sulfur distillate oil minimizes the emissions of CO, PM/PM₁₀, SAM, SO₂ and VOC. Dry low-NO_x (DLN) combustion technology for gas firing and water injection for oil firing reduce NO_x emissions. A selective catalytic reduction (SCR) system – in combination with DLN combustion technology for gas firing and a water injection system for oil firing – reduces NO_x emissions. The HRSGs are designed and constructed such that an oxidation catalyst can be readily installed if necessary to achieve compliance with CO emission limitations.

Each HRSG has a stack that is 125 feet tall and 19 feet in diameter. Each stack is equipped with continuous emissions monitoring systems (CEMS) to measure and record CO and NO_x emissions as well as flue gas oxygen or carbon dioxide content. The following table summarizes the exhaust characteristics for the combined cycle systems. Heat input rate is based on the higher heating value (HHV) of the fuel, assuming 1,030 British thermal units (Btu) per standard cubic feet of natural gas and 19,892 Btu/lb of fuel oil.

Fuel	Heat Input Rate (HHV)	Compressor Inlet Temp	Exhaust Temperature	Exit Velocity	Flow Rate
Natural Gas	2,048 MMBtu/hour	59°F	190°F	59.2 ft/sec	1,009,487 acfm
Oil	2,155 MMBtu/hour	59°F	270°F	67.0 ft/sec	1,139,394 acfm

{Permitting notes: These emissions units are regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; Rule 212.400(5), F.A.C., Prevention of Significant Deterioration (PSD); PSD-FL-296 and revisions (A & B); PPSA: PA 92-33; and, Rule 62-212.400, F.A.C.}

Essential Potential to Emit (PTE) Parameters

D.1. Permitted Capacity. The maximum allowable heat input rates are as follows:

EU No.	MMBtu/hr Heat Input	Fuel Type
014	2,048	Natural Gas
015	2,155	Fuel Oil

Maximum heat input rate is based on a compressor inlet air temperature of 59°F, the HHV of each fuel, and 100% load. Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate fuels, and evaporative cooling. The permittee shall provide updated manufacturer’s performance curves (or equations) that correct for site conditions to the Compliance Authority within 45 days of completing a maintenance activity, tuning session or compliance testing that results in the need to reestablish the curves. Operating data may be adjusted for the appropriate site conditions in accordance with the

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

performance curves and/or equations on file with the Department. [Rules 62-210.200(PTE) & 62-213.440(1), F.A.C.; and Permit Nos. 1050234-007-AC/PSD-FL-296A, Specific Condition III.7. & 1050234-011-AC/PSD-FL-296B]

D.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

D.3. Methods of Operation.

a. *Fuels.* The fuels that are allowed to be burned in this unit/these units are:

(1) Natural gas shall be the primary fuel and shall contain no more than 1.0 grains of sulfur per 100 standard cubic feet of natural gas.

(2) No. 2 distillate oil (or a superior grade) shall be the restricted alternative fuel and shall contain no more than 0.05% sulfur, by weight. Distillate fuel oil consumption of both emissions units shall not exceed 19,703,000 gallons in any consecutive 12-month period. *{Permitting note: This condition limits annual average fuel oil consumption to the equivalent of approximately 720 hours of operation per year per turbine, based on 59 F annual average temperature. Fuel oil consumption is not limited per turbine, and the allowable fuel may be used in a single turbine.}*

b. *Combined Cycle Operation.* Each gas turbine/HRSG system may operate to produce direct, shaft-driven electrical power and steam-generated electrical power from the steam turbine-electrical generator as a “2-on-1” combined cycle unit subject to the restrictions of this permit. In accordance with the specifications of the SCR and HRSG manufacturers, the SCR system shall be on line and functioning properly during combined cycle operation or when the HRSG is producing steam.

c. *Ammonia Injection.* Ammonia injection shall begin as soon as operation of the gas turbine/HRSG system achieves the operating parameters specified by the manufacturer.

[Rules 62-210.200(PTE) & 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.8.]

{Permitting Note: The fuel specifications listed in Specific Condition D.3. combined with the efficient combustion design and operation of each gas turbine represents the BACT determination for PM/PM₁₀ emissions.

Compliance with the fuel specifications, CO standards, and visible emissions standards shall serve as indicators of good combustion. The fuel sulfur specifications also effectively limit the potential emissions of SAM and SO₂ from the gas turbines and represent the BACT determination for these pollutants. Compliance with the fuel sulfur specifications shall be determined by the requirements in Specific Condition D.33.}

D.4. Hours of Operation. Subject to the other operational restrictions of this permit, the gas turbines may operate throughout the year (8,760 hours per year). [Rules 62-210.200(PTE) & 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.8.]

Control Technology and Operating Procedures

D.5. Equipment and Controls - Gas Turbines. The permittee is authorized to tune, operate, and maintain two Siemens Westinghouse Model 501 FD gas turbine-electrical generator sets each with a generating capacity of 170 MW. Each gas turbine includes the Siemens TXP automated gas turbine control system and has dual-fuel capability. The gas turbines utilize DLN combustors.

a. *Gas Turbine NO_x Controls.*

(1) DLN Combustion. The permittee shall operate and maintain the DLN combustion system to control NO_x emissions from each gas turbine when firing natural gas. Each system shall be maintained and tuned in accordance with the manufacturer’s recommendations.

(2) Water Injection. The permittee shall operate and maintain the water injection system to reduce NO_x emissions from each gas turbine when firing distillate oil. Each system shall be maintained and tuned in accordance with the manufacturer’s recommendations.

(3) SCR System. The permittee shall operate and maintain the SCR system to control NO_x emissions from each gas turbine when firing either natural gas or distillate oil. The SCR system consists of an

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

ammonia injection grid, catalyst, ammonia storage, monitoring and control system, electrical, piping and other ancillary equipment. The SCR system shall be tuned, maintained and operated to achieve the permitted levels for NO_x emissions and ammonia slip.

{Permitting note: In accordance with 40 CFR 60.130, the storage of ammonia shall comply with all applicable requirements of the Chemical Accident Prevention Provisions in 40 CFR 68.}

- b. *Heat Recovery Steam Generators (HRSG).* The permittee is authorized to operate and maintain two unfired HRSGs. Each HRSG shall be maintained to recover heat energy from one of the two gas turbines (CT 2A or CT 2B) and deliver steam to the steam turbine-electrical generator through a common manifold.

{Permitting note: The two HRSGs deliver steam to a single steam turbine-electrical generator with a generating capacity of 190 MW.}

- c. *CO Controls.* The permittee shall have designed and constructed the HRSGs such that an oxidation catalyst can be readily installed if necessary to achieve compliance with the CO emission limitations.

[Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.4.]

- D.6. Operating Procedures. The BACT determinations established by this permit rely on "good operating practices" to reduce emissions. Therefore, all operators and supervisors shall be properly trained to operate and maintain the gas turbines, HRSGs, and pollution control systems in accordance with the guidelines and procedures established by each manufacturer. The training shall include good operating practices as well as methods of minimizing excess emissions. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.10.]

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions D.7. – D.11. are based on the specified averaging time of the applicable test method.

- D.7. Carbon Monoxide (CO). Based on continuous emissions monitoring systems (CEMS), CO emissions shall not exceed:

- a. *While firing Natural Gas:* 16 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
b. *While firing Fuel Oil:* 30 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.

Compliance with the 24-hour block CO CEMS standards shall be determined separately based on the hours of operation for each alternative fuel. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.9.]

{Permitting note: A 24-hour block compliance average may be based on as little as 1-hour of CEMS data or as much as 24-hours of CEMS data.}

- D.8. Nitrogen Oxides (NO_x). Based on CEMS, NO_x emissions shall not exceed:

- a. *While firing Natural Gas:* 3.5 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
b. *While firing Fuel Oil:* 12 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.

NO_x mass emission rates are defined as oxides of nitrogen expressed as NO₂. Compliance with the 24-hour block NO_x CEMS standards shall be determined separately based on the hours of operation for each alternative fuel. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.9.]

{Permitting Note: A 24-hour block (midnight-to-midnight) compliance average may be based on as little as 1-hour of CEMS data or as much as 24-hours of CEMS data, depending upon how many hours the unit actually ran during a given block. Compliance averages shall only include actual run hours during each 24-hour block.}

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

D.9. Volatile Organic Compound (VOC). Based on stack testing, VOC emissions shall not exceed:

- While firing Natural Gas:* 2 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
- While firing Fuel Oil:* 10 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.

Compliance with the VOC standards shall be demonstrated by conducting tests in accordance with EPA Method 25A. Optionally, EPA Method 18 may also be performed to deduct emissions of methane and ethane. The emission standards are based on VOC measured as propane. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.9.]

D.10. Ammonia. Based on stack testing, ammonia emissions shall not exceed:

- While firing Natural Gas:* 5 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
- While firing Fuel Oil:* 9 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.

Subject to the requirements of Specific Condition **D.24.**, each SCR system shall be maintained and operated to meet the designed ammonia slip target of less than 5 ppmvd corrected to 15% oxygen when firing natural gas based on the average of three test runs. Compliance with the ammonia slip standard shall be demonstrated by conducting tests in accordance with EPA Method CTM-027 or EPA Method 320. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.9.]

D.11. Visible Emissions (VE). As determined by stack testing, Visible emissions shall not exceed 10% opacity for each 6-minute block average. [Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.9.]

{Permitting Note: The concentration limits and fuel specifications for the control of the above pollutants are equivalent to the following mass emission rates (at 20°F):

- *CO = 78.7 lbs/hr for natural gas firing and 119.5 lbs/hr for distillate fuel oil firing,*
- *NO_x = 27.0 lbs/hr for natural gas firing and 99.7 lbs/hr for distillate fuel oil firing,*
- *VOC = 5.0 lbs/hr for natural gas firing and 23.5 lbs/hr for distillate fuel oil firing,*
- *PM₁₀ = 7.3 lbs/hr for natural gas firing and 64.8 lbs/hr for distillate fuel oil firing, and*
- *SO₂ = 5.6 lbs/hour for natural gas firing and 105.6 lbs/hr for distillate fuel oil firing.*

SAM emissions are estimated to be less than 10% of the SO₂ emissions.}

Excessive Emissions

The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.

D.12. Excess Emissions Allowed. Except as provided in Specific Conditions **D.15.** and **D.16.**, excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]

D.13. Excess Emissions Prohibited. Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.11.]

D.14. Alternate Visible Emissions Standard. Visible emissions due to startups, shutdowns, and malfunctions shall not exceed 10% opacity except for up to ten, 6-minute averaging periods during a calendar day, which shall not exceed 20% opacity. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.12.]

D.15. CEMS Data Exclusion. As provided in this paragraph, NO_x and CO emissions data recorded during periods of startup, shutdown, fuel switches (oil-to-gas or gas-to-oil), and documented malfunctions may be

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

excluded from the block average calculated to demonstrate compliance with the emission limits of this permit. (See specific conditions **D.7. - D.11.**)

- a. *Startup.* Periods of excess emissions excluded due to startup shall not exceed two hours per startup per unit except for the following cold startups. A “cold STG startup” is defined as a startup following a complete steam turbine generator (STG) shutdown lasting a minimum of 48 hours. Periods of excess emissions excluded due to cold STG startup shall not exceed six hours per startup per unit. A “cold CT-HRSG startup” is defined as startup following a complete shutdown of the combustion turbine-heat recovery steam generator (CT-HRSG) lasting a minimum of 8 hours. Periods of excess emissions excluded due to cold CT-HRSG startup shall not exceed three hours per startup per unit.
- b. *Shutdown.* Periods of data excluded for shutdown shall not exceed two hours per shutdown per unit.
- c. *Fuel Switching.* Periods of data excluded for fuel switches shall not exceed two hours per fuel switch per unit.
- d. *Malfunctions.* Periods of data excluded for documented malfunctions shall not exceed two hours per unit in any 24-hour block. A “documented malfunction” means a malfunction that meets the notification requirements specified in Specific Condition **D.28.**
- e. *All Periods.* All periods of data excluded for any startup, shutdown, fuel switches or documented malfunction shall be consecutive for each episode.
- f. *Duration.* The permittee shall minimize the duration of data excluded to the extent practicable. Data shall not be excluded if the startup, shutdown, or documented malfunction was caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably have been prevented. Best operating practices shall be used to minimize hourly emissions that occur during episodes of startup, shutdown, fuel switching, or documented malfunction.
- g. *Summary.* Allowable Excess Emissions Convenience Summary:

Method of Operation	Excess Emissions Conditions	Period Authorized for Excess Emissions
Hot Start-up	Complete shutdown of CT-HRSG lasting ≤ 8 hours	≤ 2 hours/start-up/unit
Cold STG Start-up	STG shutdown lasting ≥ 48 hours	≤ 6 hours /start-up/unit
Cold CT-HRSG Start-up	Complete shutdown of CT-HRSG lasting ≥ 8 hours	≤ 3 hours/start-up/unit
Shutdown	Shutdown	≤ 2 hours/shutdown/unit
Fuel Switches	Oil-to-Gas or Gas-to-Oil	≤ 2 hours/fuel-switch/unit
Documented Malfunctions	Malfunctions	≤ 2 hours in any 24-hour block

[Rules 62-212.400(BACT), 62-210.700 & 62-213.440(1), F.A.C.; and, Permit No. 1050234-015-AC/PSD-FL-296C, Specific Condition 13.]

D.16. CEMS Data Exclusion – DLN Tuning. CEMS data collected during major DLN tuning sessions shall be excluded from the CEMS compliance demonstration provided the tuning session is performed in accordance with the manufacturer’s specifications. A “major tuning session” would occur after completion of a combustor change-out, a major repair or maintenance to a combustor, or other similar circumstances. Prior to performing any major tuning session, the permittee shall provide the Department’s Southwest District Compliance Authority with an advance notice that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.14.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

Monitoring of Operations

- D.17. Water Injection Monitoring Requirements.** In accordance with the manufacturer's specifications, the permittee shall operate and maintain a monitoring system to continuously measure and record the water-to-fuel ratio when firing distillate oil. The permittee shall document the water-to-fuel ratio required to meet permitted emissions levels over the range of load conditions allowed by this permit. The NO_x CEMS is used to demonstrate compliance with the NO_x emissions standards. During NO_x CEMS downtimes or malfunctions, the permittee shall monitor the water-to-fuel ratio and operate at a level that is consistent with the documented flow rate for the gas turbine load condition. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.21.]
- D.18. Ammonia Monitoring Requirements.** In accordance with the manufacturer's specifications, the permittee shall operate and maintain an ammonia flow meter to measure and record the ammonia injection rate to the SCR system. The permittee shall document the general range of ammonia flow rates required to meet permitted emissions levels over the range of load conditions allowed by this permit by comparing NO_x emissions recorded by the CEM system with ammonia flow rates recorded using the ammonia flow meter. During NO_x monitor downtimes or malfunctions, the permittee shall operate at the ammonia flow rate that is consistent with the documented flow rate for the combustion turbine load condition. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.22.]

Continuous Monitoring Requirements

- D.19. CO and NO_x CEMS.** The permittee shall maintain and operate CEMS to measure and record the emissions of CO and NO_x from the combined cycle gas turbine. The CEMS shall be used to demonstrate continuous compliance with the CEMS emission standards specified in this permit. Upon request by the Department's Southwest District Compliance Authority, the CEMS emission rates shall be corrected to ISO conditions to demonstrate compliance with the applicable standards of 40 CFR 60.332. Within one working day of discovering emissions in excess of a CO or NO_x standard (and subject to the specified averaging period), the permittee shall notify the Department's Southwest District Compliance Authority.
- CO Monitors.*** Except as otherwise specified by this condition, the CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, and reported semiannually to the Department's Southwest District Compliance Authority. The RATA tests required for the CO monitor shall be performed using EPA Method 10 in Appendix A, 40 CFR 60. The Method 10 analysis shall be based on a continuous sampling train, and the ascarite trap may be omitted or the interference trap of Section 10.1 may be used in lieu of the silica gel and ascarite traps. The CO monitor shall be a dual range monitor. The span for the lower range shall not be greater than 50 ppm. The span for the upper range shall be set at a level that provides for accurate measurement during startups and shutdowns.
 - NO_x Monitors.*** Except as otherwise specified by this condition, the NO_x monitor shall be certified pursuant to 40 CFR 75, and shall be operated and maintained in accordance with the applicable requirements of 40 CFR 75, Subparts B and C. Record keeping and reporting shall be conducted pursuant to 40 CFR 75, Subparts F and G. The RATA tests required for the NO_x monitor shall be performed using EPA Method 20 or 7E in Appendix A, 40 CFR 60. The NO_x monitor shall be a dual range monitor. The span for the lower range shall not be greater than 10 ppm. The span for the upper range shall be set at a level that provides for accurate measurement during startups and shutdowns.
 - Diluent Monitors.*** The oxygen or carbon dioxide (CO₂) content of the flue gas shall be monitored at the location where CO and NO_x are monitored to correct the measured emissions rates to 15% oxygen. If a CO₂ monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

- d. *Moisture Correction.* Final results of the CEMS shall be expressed as ppmvd corrected to 15% oxygen. If the CEMS measures concentration on a wet basis, the CEMS shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the permittee may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load for each allowable fuel, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). If the CEMS measures concentration on a wet basis and the diluent monitor measures CO₂ on a wet basis, then the permittee may develop an algorithm to enable correction of the CEMS results to a dry basis (0% moisture) without determining the corresponding moisture content.
- e. *1-Hour Block Averages.* Hourly average values shall begin at the top of each hour. Each hourly average value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). If less than two such data points are available, the hourly average value is not valid. An hour in which any oil is fired is attributed towards compliance with the permit standards for oil firing. The permittee shall use all valid measurements or data points collected during an hour to calculate the hourly average values. The CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over an hour.
- f. *24-hour Block Average.* A 24-hour block shall begin at midnight of each operating day and shall be calculated from 24 consecutive hourly average emission rate values. If a unit operates less than 24 hours during the block, the 24-hour block average shall be the average of available valid hourly average emission rate values for the 24-hour block. For purposes of determining compliance with the 24-hour CEMS emissions standards of this permit, missing (or excluded) data shall not be substituted. Instead, the 24-hour block average shall be determined using the remaining hourly data in the 24-hour block.

{Permitting Note: There may be more than one 24-hour compliance demonstration required for CO and NO_x emissions depending on the use of alternate fuels.}

- g. *Data Exclusion.* Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, fuel switches, and DLN tuning. CEMS emissions data recorded during some of these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of specific conditions **D.15.** and **D.16.**
- h. *Availability.* Monitor availability for the CEMS shall be 95% or greater in any calendar quarter. The quarterly permit excess emissions report shall be used to demonstrate monitor availability. In the event 95% availability is not achieved, the permittee shall provide the Department's Southwest District Compliance Authority with a report identifying the problems in achieving 95% availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Southwest District Compliance Authority.

[Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.20.]

{Permitting Note: Compliance with these requirements assures compliance with the other applicable CEM system requirements such as: NSPS Subpart GG: Rule 62-297.520, F.A.C.; 40 CFR 60.7(a)(5) and 40 CFR 60.13; 40 CFR 60, Appendix B - Performance Specifications; and, 40 CFR 60, Appendix F - Quality Assurance Procedures.}

Test Methods and Procedures

D.20. Test Methods. Required tests shall be performed in accordance with the following reference methods:

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

<u>Method</u>	<u>Description of Method and Comments</u>
1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
CTM-027 or EPA Method 320	<i>Procedure for Collection and Analysis of Ammonia in Stationary Sources</i> This is an EPA conditional test method. The minimum detection limit shall be 1 ppm.
7E	<i>Determination of Nitrogen Oxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)</i>
9	<i>Visual Determination of the Opacity of Emissions from Stationary Sources</i> The test shall be conducted for a minimum of 30 minutes.
10	<i>Determination of Carbon Monoxide Emissions from Stationary Sources</i> This method shall be based on a continuous sampling train.
18	<i>Measurement of Gaseous Organic Compound Emissions by Gas Chromatography</i> (Optional) EPA Method 18 may be used concurrently with EPA Method 25A to deduct emissions of methane and ethane from the measured VOC emissions.
20	<i>Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions from Stationary Gas Turbines</i>
25A	<i>Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer</i>

Note: Method CTM-027 is published on EPA's Technology Transfer Network Web Site at <http://www.epa.gov/ttn/emc/ctm.html>. The above methods are described in Appendix A, 40 CFR 60, adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rules 62-204.800 & 62-297.401, F.A.C.; 40 CFR 60, Appendix A; and, Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.15.]

- D.21. Common Testing Requirements.** Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]
- D.22. Continuous Compliance.** The permittee shall demonstrate continuous compliance with the CO and NO_x emissions standards based on data collected by the certified CEMS. Within 45 days of conducting any RATA on a CEMS, the permittee shall submit a report to the Department's Southwest District Compliance Authority summarizing results of the RATA. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.17.]
{Permitting note: Compliance with the CO emission standards also serves as an indicator of efficient fuel combustion, which reduces emissions of PM/PM₁₀ and VOC.}
- D.23. Annual Compliance Tests.** During each federal fiscal year (October 1st to September 30th), each gas turbine shall be tested to demonstrate compliance with the emission standards for visible emissions and ammonia.
- a. *Visible Emissions.* Each unit shall be tested for visible emissions when firing natural gas and when firing distillate fuel oil. Annual emissions testing while firing fuel oil is not required during any federal fiscal year in which less than 5,473,000 gallons of distillate fuel oil is fired in both emission units combined. CO emissions recorded by the CEMS shall be reported for the visible emissions observation period.

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

{Permitting Note: The fuel limitation for waiving testing while firing distillate fuel oil corresponds to the equivalent of approximately 200 hours of operation per year per turbine.}

- b. **Ammonia.** Annual testing to determine the ammonia slip shall be conducted while firing natural gas. NO_x emissions recorded by the CEMS shall be reported for each ammonia slip test run.
- c. **VOC.** Annual compliance tests for VOC emissions are not required. Compliance with the continuously monitored CO standards shall indicate efficient combustion and low VOC emissions. A monitored exceedance of the CO standard does not necessarily indicate an exceedance of the VOC emissions limitation; however, it may constitute good reason to require compliance testing pursuant to Rule 62-297.310(7)(b), F.A.C.

[Rules 62-212.400(BACT), 62-213.440(1) & 62-297.310(7)(a)4., F.A.C.; and, Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.18.]

D.24. Additional Compliance Determinations. The Department may require the permittee to conduct additional tests following a major replacement or major repair of any air pollution control equipment, such as the SCR catalyst, DLN combustors, etc. If required, each gas turbine shall be stack tested to demonstrate compliance with the emission standards for CO, NO_x, VOC, visible emissions, and ammonia slip. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the unit is restarted. Each unit shall be tested when firing natural gas and when firing distillate fuel oil. CEMS data collected during the required Relative Accuracy Test Assessments (RATA) may be used to demonstrate compliance with the CO and NO_x standards. CO and NO_x emissions recorded by the CEMS shall also be reported for each run during tests for visible emissions, VOC and ammonia slip. [40 CFR 60.8 and Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.16.]

D.25. Additional Ammonia Slip Testing. If the tested ammonia slip rate for a gas turbine exceeds 5 ppmvd corrected to 15% oxygen when firing natural gas during the annual test, the permittee shall:

- a. Begin testing and reporting the ammonia slip for each subsequent calendar quarter;
- b. Before the ammonia slip exceeds 7 ppmvd corrected to 15% oxygen, take corrective actions that result in lowering the ammonia slip to less than 5 ppmvd corrected to 15% oxygen; and,
- c. Test and demonstrate that the ammonia slip is no more than 5 ppmvd corrected to 15% oxygen within 15 days after completing the corrective actions.

Corrective actions may include, but are not limited to, adding catalyst, replacing catalyst, or other SCR system maintenance or repair. After demonstrating that the ammonia slip level is no more than 5 ppmvd corrected to 15% oxygen, testing and reporting shall resume on an annual basis. [Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.19.]

Recordkeeping and Reporting Requirements

D.26. Reporting Schedule. The following reports and notifications shall be submitted to the Compliance Authority:

Report	Reporting Deadline	Related Condition
Malfunction Notification	Within One Working Day	D.28.
Data Exclusion Report	Quarterly	D.29.
NSPS Excess Emissions Report	Semi-annually	D.30.

[Rule 62-213.440(1)(b), F.A.C.]

D.27. Other Reporting Requirements. See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements. [Rule 62-213.440(1)(b), F.A.C.]

D.28. Malfunction Notification. Within one working day of a malfunction for which CEMS data is excluded pursuant to Specific Condition **D.15.**, the permittee shall notify the Department's Southwest District Compliance Authority by telephone, facsimile transmittal, or electronic mail. The notification shall include a preliminary report of: the nature, extent, and duration of the emissions; the probable cause of the emissions;

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

and the actions taken to correct the problem. If requested by the Department's Southwest District Compliance Authority, the permittee shall submit written quarterly reports summarizing the malfunctions in lieu of the individual malfunction notifications otherwise required. [Rule 62-210.700, F.A.C.; and, Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.26.]

- D.29. Quarterly Data Exclusion and Monitor Availability Report.** The permittee shall quarterly submit a report to the Department's Southwest District Compliance Authority summarizing all periods of valid hourly CO and NO_x emissions data excluded from the 24-hour block average compliance determinations pursuant to Specific Conditions **D.15.** and **D.16.** In addition, the quarterly report shall summarize the CEMS availability for the previous quarter. All reports shall be postmarked by the 30th day following the end of each calendar quarter. An example of an acceptable report format for monitoring systems availability is provided in Figure 1 - Summary Report-Gaseous And Opacity Excess Emissions and Monitoring System Performance. [Rules 62-4.130, 62-204.800 and 62-210.700(6), F.A.C.; 40 CFR 60.7(c) and (d); and, Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.28.]
- D.30. Semiannual NSPS Excess Emissions Report.** In accordance with 40 CFR 60.7(c), the permittee shall semiannually submit a report to the Department's Southwest District Compliance Authority summarizing any emissions in excess of the NSPS standards. All reports shall be postmarked by the 30th day following the end of each six-month period. Written reports of excess emissions shall include the information specified in 40 CFR 60.7(c)(1) through (c)(4). For purposes of reporting emissions in excess of 40 CFR 60, Subpart GG, excess emissions from the gas turbine are defined as: any CEMS hourly average value exceeding the NSPS NO_x emission standard identified in Appendix GG - NSPS Subpart GG Requirements for Gas Turbines (i.e., 112.5 ppmvd corrected to 15% oxygen for both natural gas and fuel oil); and any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds the NSPS standard identified in Appendix GG - NSPS Subpart GG Requirements for Gas Turbines (i.e., sulfur in excess of 0.8% by weight). An example of an acceptable report format is provided in Figure 1 - Summary Report-Gaseous And Opacity Excess Emissions and Monitoring System Performance. [40 CFR 60.7(c) and Permit No.1050234-007-AC/PSD-FL-296A, Specific Condition III.27.]
- D.31. Monitoring of Operation.** To demonstrate compliance with the fuel consumption limits of this permit, the permittee shall record the distillate fuel oil consumption on a rolling 12-month basis. [Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.23.]
- D.32. Frequency of Recordkeeping.** Specific Condition **D.19.** requires the calculation of one or more 24-hour block average emission rates for each operating day. Within 24 hours of the conclusion of each operating day, the permittee shall complete the calculations and record the results for that operating day. [Permit No. 1050234-007-AC/PSD-FL-296A, Specific Condition III.24.]
- D.33. Fuel Sulfur Records.** The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.
- Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be in accordance with 40 CFR 60, Subpart GG. (See Appendix NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines.)
 - Sampling and analysis for the fuel oil sulfur content shall be conducted in accordance with the methods in 40 CFR 60, Subpart GG, or their latest editions. For each subsequent fuel delivery, the permittee shall either (1) maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor, or (2) take and analyze a sample according to the above procedures and maintain a permanent file of the results of the analysis. At the request of a Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content. (See Appendix NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines.)

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection D. Emissions Unit 014 and 015

- c. The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75, Appendix D.
[Rule 62-4.160(15), F.A.C.; 40 CFR 75, Appendix D; and, Permit No. 1050234-015-AC/PSD-FL-296C, Specific Condition 25.]

Other Requirements

D.34. Federal Requirements. In addition to the above conditions, these units shall also comply with all the applicable requirements of 40 CFR 60, Subparts A and GG. See Appendices NSPS, Subpart A - General Provisions and NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines. [Permit No. 1050234-015-AC/PSD-FL-296C]

D.35. National Emission Standards for Hazardous Air Pollutants (NESHAP). The Department determines that compliance with the stationary combustion turbine requirements of 40 CFR 63, Subpart YYYYY, National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines (currently stayed) is required. See Appendix NESHAP, Subpart YYYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines of this permit. Compliance shall be required when the final rule is promulgated. [Rule 62-213.440(1), F.A.C. and 40 CFR 63.6085]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

The specific conditions in this section apply to the following emissions units:

E.U. No.	Brief Description of Power Block 3
016	170 MW Westinghouse 501FD CT3A with unfired HRSG
017	170 MW Westinghouse 501FD CT3B with unfired HRSG

Emission units (EU) 016 and 017 are each a Siemens Westinghouse 501 FD gas turbine-electrical generator set with an automated gas turbine control system and an unfired heat recovery steam generator (HRSG). Each of the gas turbine-electrical generator sets has a generating capacity of 170 MW for gas firing. Each gas turbine fires natural gas as the primary fuel and distillate oil as a restricted alternate fuel. Steam from both HRSGs is delivered to a single steam turbine-electrical generator, which has a generating capacity of 190 MW. The total generating capacity of the “2-on-1” combined cycle unit is approximately 530 MW. The maximum heat input rate is based on the higher heating value (HHV) of the fuel, which is 2,048 MMBtu/hr, while firing natural gas, and 2,155 MMBtu/hr, while firing fuel oil, based on a compressor inlet air temperature of 59°F, and 100% load.

The efficient combustion of natural gas and restricted firing of low sulfur distillate oil minimizes the emissions of CO, PM/PM₁₀, SAM, SO₂ and VOC. Dry low-NO_x (DLN) combustion technology for gas firing and water injection for oil firing reduce NO_x emissions. A selective catalytic reduction (SCR) system – in combination with DLN combustion technology for gas firing and a water injection system for oil firing – reduces NO_x emissions. The HRSGs are designed and constructed such that an oxidation catalyst can be readily installed if necessary to achieve compliance with CO emission limitations.

Each HRSG has a stack that is 125 feet tall and 19 feet in diameter. Each stack is equipped with continuous emissions monitoring systems (CEMS) to measure and record CO and NO_x emissions as well as flue gas oxygen or carbon dioxide content. The following table summarizes the exhaust characteristics for the combined cycle systems. Heat input rate is based on the higher heating value (HHV) of the fuel, assuming 1,030 British thermal units (Btu) per standard cubic feet of natural gas and 19,892 Btu/lb of fuel oil.

Fuel	Heat Input Rate (HHV)	Compressor Inlet Temp	Exhaust Temperature	Exit Velocity	Flow Rate
Natural Gas	2,048 MMBtu/hour	59°F	190°F	59.2 ft/sec	1,009,487 acfm
Oil	2,155 MMBtu/hour	59°F	270°F	67.0 ft/sec	1,139,394 acfm

{Permitting Notes: These emissions unit are regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; Rule 212.400(5), F.A.C., Prevention of Significant Deterioration (PSD); PSD-FL-330 and revision No. PSD-FL-330A; and, Rule 62-212.400, F.A.C.}

Essential Potential to Emit (PTE) Parameters

E.1. Permitted Capacity. The maximum allowable heat input rates are as follows:

EU No.	MMBtu/hr Heat Input	Fuel Type
016	2,048	Natural Gas
017	2,155	Fuel Oil

Maximum heat input rate is based on a compressor inlet air temperature of 59°F, the HHV of each fuel, and 100% load. Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate fuels, and evaporative cooling. The permittee shall provide updated manufacturer’s performance curves (or equations) that correct for site conditions to the Compliance Authority within 45 days of completing a maintenance activity, tuning session or compliance testing that results in the need to reestablish the curves. Operating data may be adjusted for the appropriate site conditions in accordance with the

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

performance curves and/or equations on file with the Department. [Rule 62-210.200(Definitions-PTE), F.A.C.; and, Permit Nos. 1050234-006-AC/PSD-FL-330, Specific Condition III.7. & 1050234-013-AC/PSD-FL-330A]

E.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

E.3. Methods of Operation.

a. *Fuels.* The fuels that are allowed to be burned in this unit/these units are:

- (1) Natural gas shall be the primary fuel and shall contain no more than 1.0 grains of sulfur per 100 standard cubic feet of natural gas.
- (2) No. 2 distillate oil (or a superior grade) shall be the restricted alternative fuel and shall contain no more than 0.05% sulfur, by weight. Distillate fuel oil consumption of both emissions units shall not exceed 19,703,000 gallons in any consecutive 12-month period. *{Permitting note: This condition limits annual average fuel oil consumption to the equivalent of approximately 720 hours of operation per year per turbine, based on 59 F annual average temperature. Fuel oil consumption is not limited per turbine, and the allowable fuel may be used in a single turbine.}*

b. *Combined Cycle Operation.* Each gas turbine/HRSG system may operate to produce direct, shaft-driven electrical power and steam-generated electrical power from the steam turbine-electrical generator as a “2-on-1” combined cycle unit subject to the restrictions of this permit. In accordance with the specifications of the SCR and HRSG manufacturers, the SCR system shall be on line and functioning properly during combined cycle operation or when the HRSG is producing steam.

c. *Ammonia Injection.* Ammonia injection shall begin as soon as operation of the gas turbine/HRSG system achieves the operating parameters specified by the manufacturer.

[Rules 62-210.200(PTE) and 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.8.]

{Permitting Note: The fuel specifications listed in Specific Condition E.3. combined with the efficient combustion design and operation of each gas turbine represents the BACT determination for PM/PM₁₀ emissions.

Compliance with the fuel specifications, CO standards, and visible emissions standards shall serve as indicators of good combustion. The fuel sulfur specifications also effectively limit the potential emissions of SAM and SO₂ from the gas turbines and represent the BACT determination for these pollutants. Compliance with the fuel sulfur specifications shall be determined by the requirements in Specific Condition E.33.}

E.4. Hours of Operation. Subject to the other operational restrictions of this permit, the gas turbines may operate throughout the year (8,760 hours per year). [Rules 62-210.200(PTE) and 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.8.]

Control Technology

E.5. Equipment and Controls - Gas Turbines. The permittee is authorized to tune, operate, and maintain two Siemens Westinghouse Model 501FD gas turbine-electrical generator sets each with a generating capacity of 170 MW. Each gas turbine includes the Siemens TXP automated gas turbine control system and has dual-fuel capability. The gas turbines utilize DLN combustors.

a. *Gas Turbine NO_x Controls.*

- (1) DLN Combustion. The permittee shall operate and maintain the DLN combustion system to control NO_x emissions from each gas turbine when firing natural gas. Each system shall be maintained and tuned in accordance with the manufacturer’s recommendations.
- (2) Water Injection. The permittee shall operate and maintain the water injection system to reduce NO_x emissions from each gas turbine when firing distillate oil. Each system shall be maintained and tuned in accordance with the manufacturer’s recommendations.

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

(3) SCR System. The permittee shall operate and maintain the SCR system to control NO_x emissions from each gas turbine when firing either natural gas or distillate oil. The SCR system consists of an ammonia injection grid, catalyst, ammonia storage, monitoring and control system, electrical, piping and other ancillary equipment. The SCR system shall be tuned, maintained and operated to achieve the permitted levels for NO_x emissions and ammonia slip. *{Permitting note: In accordance with 40 CFR 60.130, the storage of ammonia shall comply with all applicable requirements of the Chemical Accident Prevention Provisions in 40 CFR 68.}*

- b. *Heat Recovery Steam Generators (HRSG)*. The permittee is authorized to operate and maintain two unfired HRSGs. Each HRSG shall be maintained to recover heat energy from one of the two gas turbines (CT 3A or CT 3B) and deliver steam to the steam turbine-electrical generator through a common manifold. *{Permitting note: The two HRSGs deliver steam to a single steam turbine-electrical generator with a generating capacity of 190 MW.}*
- c. *CO Controls*. The permittee shall have designed and constructed the HRSGs such that an oxidation catalyst can be readily installed if necessary to achieve compliance with the CO emission limitations. The oxidation catalyst, should it be installed, shall be designed and operated to achieve a maximum outlet concentration of 3.5 ppmvd corrected to 15% oxygen when natural gas is fired and 7.0 ppmvd corrected to 15% oxygen when distillate oil is fired.

[Permit No. 1050234-006-AC/PSD-FL-330, Specific Conditions III.3. – 6.]

- E.6. Operating Procedures. The BACT determinations established by this permit rely on “good operating practices” to reduce emissions. Therefore, all operators and supervisors shall be properly trained to operate and maintain the gas turbines, HRSGs, and pollution control systems in accordance with the guidelines and procedures established by each manufacturer. The training shall include good operating practices as well as methods of minimizing excess emissions. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.10.]

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions E.7. – E.11. are based on the specified averaging time of the applicable test method.

- E.7. Carbon Monoxide (CO). Based on continuous emissions monitoring systems (CEMS), CO emissions shall not exceed:

- a. *While firing Natural Gas*: 10 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
- b. *While firing Fuel Oil*: 20 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
- Compliance with the 24-hour block CO CEMS standards shall be determined separately based on the hours of operation for each alternative fuel. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.9.]

{Permitting note: A 24-hour block compliance average may be based on as little as 1-hour of CEMS data or as much as 24-hours of CEMS data. The Department shall revise the CO emissions standards following any future installation of an oxidation catalyst pursuant to Specific Condition E.5.c.}

- E.8. Nitrogen Oxides (NO_x). Based on CEMS, NO_x emissions shall not exceed:
- a. *While firing Natural Gas*: 2.5 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
- b. *While firing Fuel Oil*: 10 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
- NO_x mass emission rates are defined as oxides of nitrogen expressed as NO₂. Compliance with the 24-hour block NO_x CEMS standards shall be determined separately based on the hours of operation for each alternative fuel. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.9.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

{Permitting Note: A 24-hour block (midnight-to-midnight) compliance average may be based on as little as 1-hour of CEMS data or as much as 24-hours of CEMS data, depending upon how many hours the unit actually ran during a given block. Compliance averages shall only include actual run hours during each 24-hour block.}

- E.9. Volatile Organic Compound (VOC).** Based on stack testing, VOC emissions shall not exceed:
- While firing Natural Gas:* 2 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
 - While firing Fuel Oil:* 10 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
- Compliance with the VOC standards shall be demonstrated by conducting tests in accordance with EPA Method 25A. Optionally, EPA Method 18 may also be performed to deduct emissions of methane and ethane. The emission standards are based on VOC measured as propane. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.9.]
- E.10. Ammonia.** Based on stack testing, ammonia emissions shall not exceed:
- While firing Natural Gas:* 5 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
 - While firing Fuel Oil:* 5 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
- Subject to the requirements of Specific Condition E.24., each SCR system shall be maintained and operated to meet the designed ammonia slip target of less than 5 ppmvd corrected to 15% oxygen when firing natural gas based on the average of three test runs. Compliance with the ammonia slip standard shall be demonstrated by conducting tests in accordance with EPA Method CTM-027 or EPA Method 320. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.9.]
- E.11. Visible Emissions (VE).** As determined by stack testing, visible emissions shall not exceed 10% opacity for each 6-minute block average. [Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.9.]

{Permitting Note: The concentration limits and fuel specifications for the control of the above pollutants are equivalent to the following mass emission rates (at 20°F):

- CO = 49.2 lbs/hr for natural gas firing and 80.0 lbs/hr for distillate fuel oil firing,*
- NO_x = 19.1 lbs/hr for natural gas firing and 82.0 lbs/hr for distillate fuel oil firing,*
- VOC = 5.7 lbs/hr for natural gas firing and 23.5 lbs/hr for distillate fuel oil firing,*
- PM₁₀ = 8.5 lbs/hr for natural gas firing and 64.8 lbs/hr for distillate fuel oil firing, and*
- SO₂ = 5.6 lbs/hour for natural gas firing and 105.6 lbs/hr for distillate fuel oil firing.*

SAM emissions are estimated to be less than 10% of the SO₂ emissions.}

Excessive Emissions

The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.

- E.12. Excess Emissions Allowed.** Except as provided in Specific Conditions E.15. and E.16., excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]
- E.13. Excess Emissions Prohibited.** Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.11.]
- E.14. Alternate Visible Emissions Standard.** Visible emissions due to startups, shutdowns, and malfunctions shall not exceed 10% opacity except for up to ten, 6-minute averaging periods during a calendar day, which

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

shall not exceed 20% opacity. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.12.]

E.15. CEMS Data Exclusion. As provided in this paragraph, NO_x and CO emissions data recorded during periods of startup, shutdown, fuel switches (oil-to-gas or gas-to-oil), and documented malfunctions may be excluded from the block average calculated to demonstrate compliance with the emission limits of this permit. (See specific conditions E.7. - E.11.)

- a. *Startup.* Periods of excess emissions excluded due to startup shall not exceed two hours per startup per unit except for the following cold startups. A “cold STG startup” is defined as a startup following a complete steam turbine generator (STG) shutdown lasting a minimum of 48 hours. Periods of excess emissions excluded due to cold STG startup shall not exceed six hours per startup per unit. A “cold CT-HRSG startup” is defined as startup following a complete shutdown of the combustion turbine-heat recovery steam generator (CT-HRSG) lasting a minimum of 8 hours. Periods of excess emissions excluded due to cold CT-HRSG startup shall not exceed three hours per startup per unit.
- b. *Shutdown.* Periods of data excluded for shutdown shall not exceed two hours per shutdown per unit.
- c. *Fuel Switching.* Periods of data excluded for fuel switches shall not exceed two hours per fuel switch per unit.
- d. *Malfunctions.* Periods of data excluded for documented malfunctions shall not exceed two hours per unit in any 24-hour block. A “documented malfunction” means a malfunction that meets the notification requirements specified in Specific Condition E.28.
- e. *All Periods.* All periods of data excluded for any startup, shutdown, fuel switches or documented malfunction shall be consecutive for each episode.
- f. *Duration.* The permittee shall minimize the duration of data excluded to the extent practicable. Data shall not be excluded if the startup, shutdown, or documented malfunction was caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably have been prevented. Best operating practices shall be used to minimize hourly emissions that occur during episodes of startup, shutdown, fuel switching, or documented malfunction.
- g. *Summary.* Allowable Excess Emissions Convenience Summary:

Method of Operation	Excess Emissions Conditions	Period Authorized for Excess Emissions
Hot Start-up	Complete shutdown of CT-HRSG lasting ≤ 8 hours	≤ 2 hours/start-up/unit
Cold STG Start-up	STG shutdown lasting ≥ 48 hours	≤ 6 hours /start-up/unit
Cold CT-HRSG Start-up	Complete shutdown of CT-HRSG lasting ≥ 8 hours	≤ 3 hours/start-up/unit
Shutdown	Shutdown	≤ 2 hours/shutdown/unit
Fuel Switches	Oil-to-Gas or Gas-to-Oil	≤ 2 hours/fuel-switch/unit
Documented Malfunctions	Malfunctions	≤ 2 hours in any 24-hour block

[Rules 62-212.400(BACT), 62-210.700 & 62-213.440(1), F.A.C.; and, Permit No. 1050234-015-AC/PSD-FL-330B, Specific Condition 13.]

E.16. CEMS Data Exclusion – DLN Tuning. CEMS data collected during major DLN tuning sessions shall be excluded from the CEMS compliance demonstration provided the tuning session is performed in accordance with the manufacturer’s specifications. A “major tuning session” would occur after completion of a combustor change-out, a major repair or maintenance to a combustor, or other similar circumstances. Prior to

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

performing any major tuning session, the permittee shall provide the Department's Southwest District Compliance Authority with an advance notice that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.14.]

Monitoring of Operations

- E.17. Water Injection Monitoring Requirements.** In accordance with the manufacturer's specifications, the permittee shall operate and maintain a monitoring system to continuously measure and record the water-to-fuel ratio when firing distillate oil. The permittee shall document the water-to-fuel ratio required to meet permitted emissions levels over the range of load conditions allowed by this permit. The NO_x CEMS is used to demonstrate compliance with the NO_x emissions standards. During NO_x CEMS downtimes or malfunctions, the permittee shall monitor the water-to-fuel ratio and operate at a level that is consistent with the documented flow rate for the gas turbine load condition. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.21.]
- E.18. Ammonia Monitoring Requirements.** In accordance with the manufacturer's specifications, the permittee shall operate and maintain an ammonia flow meter to measure and record the ammonia injection rate to the SCR system. The permittee shall document the general range of ammonia flow rates required to meet permitted emissions levels over the range of load conditions allowed by this permit by comparing NO_x emissions recorded by the CEM system with ammonia flow rates recorded using the ammonia flow meter. During NO_x monitor downtimes or malfunctions, the permittee shall operate at the ammonia flow rate that is consistent with the documented flow rate for the combustion turbine load condition. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.22.]

Continuous Monitoring Requirements

- E.19. CO and NO_x CEMS.** The permittee shall maintain and operate CEMS to measure and record the emissions of CO and NO_x from the combined cycle gas turbine. The CEMS shall be used to demonstrate continuous compliance with the CEMS emission standards specified in this permit. Upon request by the Department's Southwest District Compliance Authority, the CEMS emission rates shall be corrected to ISO conditions to demonstrate compliance with the applicable standards of 40 CFR 60.332. Within one working day of discovering emissions in excess of a CO or NO_x standard (and subject to the specified averaging period), the permittee shall notify the Department's Southwest District Compliance Authority.
- a. *CO Monitors.* Except as otherwise specified by this condition, the CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, and reported semiannually to the Department's Southwest District Compliance Authority. The RATA tests required for the CO monitor shall be performed using EPA Method 10 in Appendix A, 40 CFR 60. The Method 10 analysis shall be based on a continuous sampling train, and the ascarite trap may be omitted or the interference trap of Section 10.1 may be used in lieu of the silica gel and ascarite traps. The CO monitor shall be a dual range monitor. The span for the lower range shall not be greater than 50 ppm. The span for the upper range shall be set at a level that provides for accurate measurement during startups and shutdowns.
 - b. *NO_x Monitors.* Except as otherwise specified by this condition, the NO_x monitor shall be certified pursuant to 40 CFR 75, and shall be operated and maintained in accordance with the applicable requirements of 40 CFR 75, Subparts B and C. Record keeping and reporting shall be conducted pursuant to 40 CFR 75, Subparts F and G. The RATA tests required for the NO_x monitor shall be performed using EPA Method 20 or 7E in Appendix A, 40 CFR 60. The NO_x monitor shall be a dual range monitor. The span for the lower range shall not be greater than 10 ppm. The span for the upper range shall be set at a level that provides for accurate measurement during startups and shutdowns.

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

- c. *Diluent Monitors.* The oxygen or carbon dioxide (CO₂) content of the flue gas shall be monitored at the location where CO and NO_x are monitored to correct the measured emissions rates to 15% oxygen. If a CO₂ monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.
- d. *Moisture Correction.* Final results of the CEMS shall be expressed as ppmvd corrected to 15% oxygen. If the CEMS measures concentration on a wet basis, the CEMS shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the permittee may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load for each allowable fuel, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). If the CEMS measures concentration on a wet basis and the diluent monitor measures CO₂ on a wet basis, then the permittee may develop an algorithm to enable correction of the CEMS results to a dry basis (0% moisture) without determining the corresponding moisture content.
- e. *1-Hour Block Averages.* Hourly average values shall begin at the top of each hour. Each hourly average value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). If less than two such data points are available, the hourly average value is not valid. An hour in which any oil is fired is attributed towards compliance with the permit standards for oil firing. The permittee shall use all valid measurements or data points collected during an hour to calculate the hourly average values. The CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over an hour.
- f. *24-hour Block Average.* A 24-hour block shall begin at midnight of each operating day and shall be calculated from 24 consecutive hourly average emission rate values. If a unit operates less than 24 hours during the block, the 24-hour block average shall be the average of available valid hourly average emission rate values for the 24-hour block. For purposes of determining compliance with the 24-hour block CEMS emissions standards of this permit, missing (or excluded) data shall not be substituted. Instead, the 24-hour block average shall be determined using the remaining hourly data in the 24-hour block. *{Permitting note: There may be more than one 24-hour block compliance demonstration required for CO and NO_x emissions depending on the use of alternate fuels.}*
- g. *Data Exclusion.* Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, fuel switches, and DLN tuning. CEMS emissions data recorded during some of these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of specific conditions **E.15.** and **E.16.**
- h. *Availability.* Monitor availability for the CEMS shall be 95% or greater in any calendar quarter. The quarterly permit excess emissions report shall be used to demonstrate monitor availability. In the event 95% availability is not achieved, the permittee shall provide the Department's Southwest District Compliance Authority with a report identifying the problems in achieving 95% availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Southwest District Compliance Authority.

[Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.20.]

{Permitting note: Compliance with these requirements assures compliance with the other applicable CEM system requirements such as: NSPS Subpart GG; Rule 62-297.520, F.A.C.; 40 CFR 60.7(a)(5) and 40 CFR 60.13; 40 CFR 60, Appendix B - Performance Specifications; and, 40 CFR 60, Appendix F - Quality Assurance Procedures.}

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

Test Methods and Procedures

E.20. Test Methods. Required tests shall be performed in accordance with the following reference methods:

<u>Method</u>	<u>Description of Method and Comments</u>
1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
CTM-027 or EPA Method 320	<i>Procedure for Collection and Analysis of Ammonia in Stationary Sources</i> This is an EPA conditional test method. The minimum detection limit shall be 1 ppm.
7E	<i>Determination of Nitrogen Oxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)</i>
9	<i>Visual Determination of the Opacity of Emissions from Stationary Sources</i> The test shall be conducted for a minimum of 30 minutes.
10	<i>Determination of Carbon Monoxide Emissions from Stationary Sources</i> This method shall be based on a continuous sampling train.
18	<i>Measurement of Gaseous Organic Compound Emissions by Gas Chromatography</i> (Optional) EPA Method 18 may be used concurrently with EPA Method 25A to deduct emissions of methane and ethane from the measured VOC emissions.
20	<i>Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions from Stationary Gas Turbines</i>
25A	<i>Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer</i>

Note: Method CTM-027 is published on EPA's Technology Transfer Network Web Site at <http://www.epa.gov/ttn/emc/ctm.html>. The above methods are described in Appendix A, 40 CFR 60, adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rules 62-204.800 & 62-297.401, F.A.C.; 40 CFR 60, Appendix A; and, Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.15.]

E.21. Common Testing Requirements. Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]

E.22. Continuous Compliance. The permittee shall demonstrate continuous compliance with the CO and NO_x emissions standards based on data collected by the certified CEMS. Within 45 days of conducting any RATA on a CEMS, the permittee shall submit a report to the Department's Southwest District Compliance Authority summarizing results of the RATA. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.17.]

{Permitting note: Compliance with the CO emission standards also serves as an indicator of efficient fuel combustion, which reduces emissions of PM/PM₁₀ and VOC.}

E.23. Annual Compliance Tests. During each federal fiscal year (October 1st to September 30th), each gas turbine shall be tested to demonstrate compliance with the emission standards for visible emissions and ammonia.

a. *Visible Emissions.* Each unit shall be tested for visible emissions when firing natural gas and when firing distillate fuel oil. Annual emissions testing while firing fuel oil is not required during any federal fiscal

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

year in which less than 5,473,000 gallons of distillate fuel oil is fired in both emission units combined. CO emissions recorded by the CEMS shall be reported for the visible emissions observation period. *{Permitting note: The fuel limitation for waiving testing while firing distillate fuel oil corresponds to the equivalent of approximately 200 hours of operation per year per turbine.}*

- b. *Ammonia.* Annual testing to determine the ammonia slip shall be conducted while firing natural gas. NO_x emissions recorded by the CEMS shall be reported for each ammonia slip test run.
- c. *VOC.* Annual compliance tests for VOC emissions are not required. Compliance with the continuously monitored CO standards shall indicate efficient combustion and low VOC emissions. A monitored exceedance of the CO standard does not necessarily indicate an exceedance of the VOC emissions limitation; however, it may constitute good reason to require compliance testing pursuant to Rule 62-297.310(7)(b), F.A.C.

[Rules 62-212.400(BACT), 62-213.440(1) & 62-297.310(7)(a)4., F.A.C.; and, Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.18.]

E.24. Additional Compliance Determinations. The Department may require the permittee to conduct additional tests following a major replacement or major repair of any air pollution control equipment, such as the SCR catalyst, DLN combustors, etc. If required, each gas turbine shall be stack tested to demonstrate compliance with the emission standards for CO, NO_x, VOC, visible emissions, and ammonia slip. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the unit is restarted. Each unit shall be tested when firing natural gas and when firing distillate fuel oil. CEMS data collected during the required Relative Accuracy Test Assessments (RATA) may be used to demonstrate compliance with the CO and NO_x standards. CO and NO_x emissions recorded by the CEMS shall also be reported for each run during tests for visible emissions, VOC and ammonia slip. [40 CFR 60.8 and Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.16.]

E.25. Additional Ammonia Slip Testing. If the tested ammonia slip rate for a gas turbine exceeds 5 ppmvd corrected to 15% oxygen when firing natural gas during the annual test, the permittee shall:

- a. Begin testing and reporting the ammonia slip for each subsequent calendar quarter;
- b. Before the ammonia slip exceeds 7 ppmvd corrected to 15% oxygen, take corrective actions that result in lowering the ammonia slip to less than 5 ppmvd corrected to 15% oxygen; and,
- c. Test and demonstrate that the ammonia slip is no more than 5 ppmvd corrected to 15% oxygen within 15 days after completing the corrective actions.

Corrective actions may include, but are not limited to, adding catalyst, replacing catalyst, or other SCR system maintenance or repair. After demonstrating that the ammonia slip level is no more than 5 ppmvd corrected to 15% oxygen, testing and reporting shall resume on an annual basis. [Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.19.]

Recordkeeping and Reporting Requirements

E.26. Reporting Schedule. The following reports and notifications shall be submitted to the Compliance Authority:

Report	Reporting Deadline	Related Condition
Malfunction Notification	Within One Working Day	E.28.
Data Exclusion Report	Quarterly	E.29.
NSPS Excess Emissions Report	Semi-annually	E.30.

[Rule 62-213.440(1)(b), F.A.C.]

E.27. Other Reporting Requirements. See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements. [Rule 62-213.440(1)(b), F.A.C.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

- E.28. Malfunction Notification.** Within one working day of a malfunction for which CEMS data is excluded pursuant to Specific Condition E.15., the permittee shall notify the Department's Southwest District Compliance Authority by telephone, facsimile transmittal, or electronic mail. The notification shall include a preliminary report of: the nature, extent, and duration of the emissions; the probable cause of the emissions; and the actions taken to correct the problem. If requested by the Department's Southwest District Compliance Authority, the permittee shall submit written quarterly reports summarizing the malfunctions in lieu of the individual malfunction notifications otherwise required. [Rule 62-210.700, F.A.C.; and, Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.26.]
- E.29. Quarterly Data Exclusion and Monitor Availability Report.** The permittee shall quarterly submit a report to the Department's Southwest District Compliance Authority summarizing all periods of valid hourly CO and NO_x emissions data excluded from the 24-hour block average compliance determinations pursuant to Specific Conditions E.15. and E.16. In addition, the quarterly report shall summarize the CEMS availability for the previous quarter. All reports shall be postmarked by the 30th day following the end of each calendar quarter. An example of an acceptable report format for monitoring systems availability is provided in Figure 1 - Summary Report-Gaseous And Opacity Excess Emissions and Monitoring System Performance. [Rules 62-4.130, 62-204.800 and 62-210.700(6), F.A.C.; 40 CFR 60.7(c) and (d); and, Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.28.]
- E.30. Semiannual NSPS Excess Emissions Report.** In accordance with 40 CFR 60.7(c), the permittee shall semiannually submit a report to the Department's Southwest District Compliance Authority summarizing any emissions in excess of the NSPS standards. All reports shall be postmarked by the 30th day following the end of each six-month period. Written reports of excess emissions shall include the information specified in 40 CFR 60.7(c)(1) through (c)(4). For purposes of reporting emissions in excess of 40 CFR 60, Subpart GG, excess emissions from the gas turbine are defined as: any CEMS hourly average value exceeding the NSPS NO_x emission standard identified in Appendix GG - NSPS Subpart GG Requirements for Gas Turbines (i.e., 112.5 ppmvd corrected to 15% oxygen for both natural gas and fuel oil); and any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds the NSPS standard identified in Appendix GG - NSPS Subpart GG Requirements for Gas Turbines (i.e., sulfur in excess of 0.8% by weight). An example of an acceptable report format is provided in Figure 1 - Summary Report-Gaseous And Opacity Excess Emissions and Monitoring System Performance. [40 CFR 60.7(c) and Permit No.1050234-006-AC/PSD-FL-330, Specific Condition III.27.]
- E.31. Monitoring of Operation.** To demonstrate compliance with the fuel consumption limits of this permit, the permittee shall record the distillate fuel oil consumption on a rolling 12-month basis. [Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.23.]
- E.32. Frequency of Recordkeeping.** Specific Condition E.19. requires the calculation of one or more 24-hour block average emission rates for each operating day. Within 24 hours of the conclusion of each operating day, the permittee shall complete the calculations and record the results for that operating day. [Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.24.]
- E.33. Fuel Sulfur Records.** The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.
- Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be in accordance with 40 CFR 60, Subpart GG. (See Appendix NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines.)
 - Sampling and analysis for the fuel oil sulfur content shall be conducted in accordance with the methods in 40 CFR 60, Subpart GG, or their latest editions. For each subsequent fuel delivery, the permittee shall

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection E. Emissions Unit 016 and 017

either (1) maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor, or (2) take and analyze a sample according to the above procedures and maintain a permanent file of the results of the analysis. At the request of a Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content. (See Appendix NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines.)

- c. The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75, Appendix D.

[Rule 62-4.160(15), F.A.C.; 40 CFR 75, Appendix D; and, Permit No. 1050234-015-AC/PSD-FL-330B, Specific Condition 25.]

Other Requirements

E.34. Federal Requirement. In addition to the above conditions, these units shall also comply with all the applicable requirements of 40 CFR 60, Subparts A and GG. See Appendices NSPS, Subpart A - General Provisions and NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines. [Permit No. 1050234-015-AC/PSD-FL-330B]

E.35. National Emission Standards for Hazardous Air Pollutants (NESHAP). The Department determines that compliance with the stationary combustion turbine requirements of 40 CFR 63, Subpart YYYYY, National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines (currently stayed) is required. See Appendix NESHAP, Subpart YYYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines of this permit. Compliance shall be required when the final rule is promulgated. [Rule 62-213.440(1), F.A.C. and 40 CFR 63.6085]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

The specific conditions in this section apply to the following emissions units:

E.U. No.	Brief Description of Power Block 4
018	170 MW General Electric Model 7FA CT4A with unfired HRSG
019	170 MW General Electric Model 7FA CT4B with unfired HRSG

Emission units 018 and 019 each consist of a General Electric Model 7FA gas turbine-electrical generator set, an automated gas turbine control system, and an unfired heat recovery steam generator (HRSG). In addition, Power Block 4 also includes a single steam turbine-electrical generator that serves both gas turbine/HRSG systems. Each gas turbine fires natural gas as the primary fuel and distillate oil as a restricted alternate fuel. Each of the gas turbine-electrical generator sets have a generating capacity of 170 megawatt (MW) for gas firing. Exhaust from each gas turbine passes through a separate HRSG unit. Steam from both HRSG units is delivered to the single steam turbine-electrical generator, which has a generating capacity of 190 MW. The total generating capacity of the “2-on-1” combined cycle unit is approximately 530 MW.

The efficient combustion of natural gas and restricted firing of low sulfur distillate oil minimizes the emissions of carbon monoxide (CO), particulate matter (PM/PM₁₀), sulfuric acid mist (SAM), sulfur dioxide (SO₂) and volatile organic compounds (VOC). Dry low-NO_x (DLN) combustion technology for gas firing and water injection for oil firing reduce NO_x emissions. A selective catalytic reduction (SCR) system – in combination with DLN combustion technology for gas firing and a water injection system for oil firing – reduces NO_x emissions. The HRSG units are designed and constructed such that an oxidation catalyst can be readily installed if necessary to achieve compliance with CO emission limitations.

Each HRSG has a stack that is 125 feet tall and 18 feet in diameter. The following table summarizes the exhaust characteristics for the combined cycle systems. Nominal heat input values are based on the higher heating value (HHV) of the fuel, assuming 1,021 British thermal units (Btu) per standard cubic feet of natural gas and 19,075 Btu/lb of fuel oil.

Fuel	Nominal Heat Input (HHV)	Compressor Inlet Temp	Exhaust Temperature	Exit Velocity	Flow Rate
Gas	1,915 MMBtu/hour	59°F	202°F	67.9 ft/sec	1,036,271 acfm
Oil	2,122 MMBtu/hour	59°F	295°F	80.0 ft/sec	1,220,938 acfm

Each stack is equipped with continuous emissions monitoring systems (CEMS) to measure and record CO and NO_x emissions as well as flue gas oxygen or carbon dioxide content.

{Permitting Notes: These emissions unit are regulated under Acid Rain, Phase II; NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; Rule 212.400(5), F.A.C., Prevention of Significant Deterioration (PSD); PSD-FL-342; 1050234-010-AC; and, Rule 62-212.400, F.A.C.}

Essential Potential to Emit (PTE) Parameters

F.1. Permitted Capacity. The maximum allowable heat input rates are as follows:

EU No.	MMBtu/hr Heat Input	Fuel Type
016	1,915	Natural Gas
017	2,122	Fuel Oil

Maximum heat input rate is based on a compressor inlet air temperature of 59°F, the HHV of each fuel, and 100% load. Heat input rates will vary depending upon gas turbine characteristics, ambient conditions, alternate fuels, and evaporative cooling. The permittee shall provide updated manufacturer’s performance curves (or equations) that correct for site conditions to the Compliance Authority within 45 days of completing a maintenance activity, tuning session or compliance testing that results in the need to reestablish

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

the curves. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department. [Rule 62-210.200(Definitions-PTE), F.A.C.; and, Permit Nos. 1050234-010-AC/PSD-FL-342, Specific Condition III.8.]

F.2. Emissions Unit Operating Rate Limitation After Testing. See the related testing provisions in Appendix TR, Facility-wide Testing Requirements. [Rule 62-297.310(2), F.A.C.]

F.3. Methods of Operation.

a. *Fuels.* The fuels that are allowed to be burned in this unit/these units are:

(1) Natural gas shall be the primary fuel and shall contain no more than 1.0 grains of sulfur per 100 standard cubic feet of natural gas.

(2) No. 2 distillate oil (or a superior grade) shall be the restricted alternative fuel and shall contain no more than 0.05% sulfur, by weight. Distillate fuel oil consumption of both emissions units shall not exceed 30,700,000 gallons in any consecutive 12-month period. *{Permitting note: This condition limits annual average fuel oil consumption to the equivalent of approximately 1,000 hours of operation per year per turbine, based on 59 F annual average temperature. Fuel oil consumption is not limited per turbine, and the allowable fuel may be used in a single turbine.}*

b. *Combined Cycle Operation.* Each gas turbine/HRSG system may operate to produce direct, shaft-driven electrical power and steam-generated electrical power from the steam turbine-electrical generator as a "2-on-1" combined cycle unit subject to the restrictions of this permit. In accordance with the specifications of the SCR and HRSG manufacturers, the SCR system shall be on line and functioning properly during combined cycle operation or when the HRSG is producing steam.

c. *Ammonia Injection.* Ammonia injection shall begin as soon as operation of the gas turbine/HRSG system achieves the operating parameters specified by the manufacturer.

[Rules 62-210.200(PTE) and 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.9.]

{Permitting Note: The fuel specifications listed in Specific Condition F.3. combined with the efficient combustion design and operation of each gas turbine represents the BACT determination for PM/PM₁₀ emissions.

Compliance with the fuel specifications, CO standards, and visible emissions standards shall serve as indicators of good combustion. The fuel sulfur specifications also effectively limit the potential emissions of SAM and SO₂ from the gas turbines and represent the BACT determination for these pollutants. Compliance with the fuel sulfur specifications shall be determined by the requirements in Specific Condition F.33.}

F.4. Hours of Operation. Subject to the other operational restrictions of this permit, the gas turbines may operate throughout the year (8,760 hours per year). [Rules 62-210.200(PTE) and 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.9.]

Control Technology

F.5. Equipment and Controls - Gas Turbines. The permittee is authorized to tune, operate, and maintain two General Electric Model 7FA gas turbine-electrical generator sets each with a generating capacity of 170 MW. Each gas turbine has dual-fuel capability. The gas turbines utilize DLN combustors.

a. *Gas Turbine NO_x Controls.*

(1) DLN Combustion. The permittee shall operate and maintain the DLN combustion system to control NO_x emissions from each gas turbine when firing natural gas. Each system shall be maintained and tuned in accordance with the manufacturer's recommendations.

(2) Water Injection. The permittee shall operate and maintain the water injection system to reduce NO_x emissions from each gas turbine when firing distillate oil. Each system shall be maintained and tuned in accordance with the manufacturer's recommendations.

(3) SCR System. The permittee shall operate and maintain the SCR system to control NO_x emissions from each gas turbine when firing either natural gas or distillate oil. The SCR system consists of an ammonia injection grid, catalyst, ammonia storage, monitoring and control system, electrical, piping

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

and other ancillary equipment. The SCR system shall be tuned, maintained and operated to achieve the permitted levels for NO_x emissions and ammonia slip. *{Permitting note: In accordance with 40 CFR 60.130, the storage of ammonia shall comply with all applicable requirements of the Chemical Accident Prevention Provisions in 40 CFR 68.}*

- b. *Heat Recovery Steam Generators (HRSG).* The permittee is authorized to operate and maintain two unfired HRSGs. Each HRSG shall be maintained to recover heat energy from one of the two gas turbines (CT 4A or CT 4B) and deliver steam to the steam turbine-electrical generator through a common manifold. *{Permitting note: The two HRSGs deliver steam to a single steam turbine-electrical generator with a generating capacity of 190 MW.}*
- c. *CO Controls.* The permittee shall have designed and constructed the HRSGs such that an oxidation catalyst can be readily installed if necessary to achieve compliance with the CO emission limitations. The oxidation catalyst, should it be installed, shall be designed and operated to achieve a maximum outlet concentration of 2.5 ppmvd corrected to 15% oxygen when natural gas is fired and 5.0 ppmvd corrected to 15% oxygen when distillate oil is fired.

[Permit No. 1050234-010-AC/PSD-FL-342, Specific Conditions III.4. – 7.]

- F.6. Operating Procedures.** The BACT determinations established by this permit rely on “good operating practices” to reduce emissions. Therefore, all operators and supervisors shall be properly trained to operate and maintain the gas turbines, HRSGs, and pollution control systems in accordance with the guidelines and procedures established by each manufacturer. The training shall include good operating practices as well as methods of minimizing excess emissions. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.11.]

Emission Limitations and Standards

Unless otherwise specified, the averaging times for Specific Conditions **F.7. – F.11.** are based on the specified averaging time of the applicable test method.

- F.7. Carbon Monoxide (CO).** Based on continuous emissions monitoring systems (CEMS), CO emissions shall not exceed:
- a. *While firing Natural Gas:* 8.0 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
 - b. *While firing Fuel Oil:* 12.0 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
- Compliance with the 24-hour block CO CEMS standards shall be determined separately based on the hours of operation for each alternative fuel. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.10.]

{Permitting Note: A 24-hour block (midnight-to-midnight) compliance average may be based on as little as 1-hour of CEMS data or as much as 24-hours of CEMS data, depending upon how many hours the unit actually ran during a given block. Compliance averages shall only include actual run hours during each 24-hour block. The Department shall revise the CO emissions standards following any future installation of an oxidation catalyst pursuant to Specific Condition F.5.c.}

- F.8. Nitrogen Oxides (NO_x).** Based on CEMS, NO_x emissions shall not exceed:
- a. *While firing Natural Gas:* 2.5 ppmvd corrected to 15 percent oxygen on a 24- hour block averaging time.
 - b. *While firing Fuel Oil:* 10.0 ppmvd corrected to 15 percent oxygen on a 24-hour block averaging time.
- NO_x mass emission rates are defined as oxides of nitrogen expressed as NO₂. Compliance with the 24-hour block NO_x CEMS standards shall be determined separately based on the hours of operation for each alternative fuel. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.10.]

{Permitting note: A 24-hour block compliance average may be based on as little as 1-hour of CEMS data or as much as 24-hours of CEMS data.}

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

- F.9. Volatile Organic Compound (VOC).** Based on stack testing, VOC emissions shall not exceed:
- While firing Natural Gas:* 1.3 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
 - While firing Fuel Oil:* 3.0 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
- Compliance with the VOC standards shall be demonstrated by conducting tests in accordance with EPA Method 25A. Optionally, EPA Method 18 may also be performed to deduct emissions of methane and ethane. The emission standards are based on VOC measured as propane. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.10.] *{Permitting Note: Compliance with this standard is adequate to avoid a PSD/BACT review.}*
- F.10. Ammonia.** Based on stack testing, ammonia emissions shall not exceed:
- While firing Natural Gas:* 5.0 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
 - While firing Fuel Oil:* 5.0 ppmvd corrected to 15 percent oxygen on a 3-hour averaging time.
- Each SCR system shall be maintained and operated with an ammonia slip of less than 5 ppmvd corrected to 15% oxygen when firing natural gas based on the average of three test runs. Compliance with the ammonia slip standard shall be demonstrated by conducting tests in accordance with EPA Method CTM-027 or EPA Method 320. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.10.d.]
- F.11. Visible Emissions (VE).** As determined by stack testing, visible emissions shall not exceed 10% opacity for each 6-minute block average. [Permit No. 1050234-006-AC/PSD-FL-330, Specific Condition III.9.]

{Permitting Note: The concentration limits and fuel specifications for the control of the above pollutants are equivalent to the following mass emission rates (at 20°F):}

- CO = 32.1 lbs/hr for natural gas firing and 57.2 lbs/hr for distillate fuel oil firing,*
- NO_x = 17.7 lbs/hr for natural gas firing and 82.4 lbs/hr for distillate fuel oil firing,*
- VOC = 3.1 lbs/hr for natural gas firing and 8.1 lbs/hr for distillate fuel oil firing,*
- PM₁₀ = 10.1 lbs/hr for natural gas firing and 39.1 lbs/hr for distillate fuel oil firing, and*
- SO₂ = 5.4 lbs/hour for natural gas firing and 109.2 lbs/hr for distillate fuel oil firing.*

SAM emissions are estimated to be less than 10% of the SO₂ emissions.}

Excessive Emissions

The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of a NSPS, NESHAP, or Acid Rain program provision.

- F.12. Excess Emissions Allowed.** Excess emissions resulting from startup, shutdown or malfunction shall be permitted provided that best operational practices are adhered to and the duration of excess emissions shall be minimized. Best operating practices shall be used to minimize hourly emissions that occur during episodes of startup, shutdown, fuel switching or documented malfunction. Except as provided in Specific Conditions **F.14. - F.17.**, excess emissions shall in no case exceed two hours in any 24 hour period. [Rule 62-210.700(1), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.15.]
- F.13. Excess Emissions Prohibited.** Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.12.]
- F.14. Alternate Visible Emissions Standard.** Visible emissions due to startups, shutdowns, and malfunctions shall not exceed 10% opacity except for up to ten, 6-minute averaging periods during a calendar day, which shall not exceed 20% opacity. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.13.]

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

- F.15. Alternate CO and NO_x Emissions Standard.** During any 24 hour period, in which at least one hour of startup or shutdown operation has occurred, the following alternative emission limits shall apply:
- An alternative NO_x limit of 3,000 lb shall apply if natural gas is the exclusively fired fuel;
 - An alternative NO_x limit of 8,880 lb shall apply if any fuel oil is fired; and
 - An alternative CO limit of 4,200 lb shall apply when firing either natural gas or fuel oil.
- [Permit No. 1050234-010-AC/PAD-FL-342, Specific Condition III.14.]
- F.16. CEMS Data Exclusion.** As provided in this paragraph, NO_x and CO emissions data recorded during periods of startup, shutdown, fuel switches (oil-to-gas or gas-to-oil), and documented malfunctions may be excluded from the block average calculated to demonstrate compliance with the emission limits of this permit. (See specific conditions F.7. - F.11.)
- Periods of data excluded for fuel switches shall not exceed two hours in any 24-hour block.
 - Periods of data excluded for documented malfunctions shall not exceed two hours in any 24-hour block. A “documented malfunction” means a malfunction that meets the notification requirements specified in Specific Condition F.27. The permittee shall minimize the duration of data excluded to the extent practicable. Data shall not be excluded if the documented malfunction was caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably have been prevented.
 - Data collected during periods covered by the alternate emissions standard provisions of Specific Condition F.15. may be excluded from the compliance determination calculation requirements of Specific Conditions F.7. - F.11.
- [Rules 62-212.400(BACT) & 62-210.700, F.A.C.; and, Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.16.]
- F.17. CEMS Data Exclusion – DLN Tuning.** CEMS data collected during major DLN tuning sessions shall be excluded from the CEMS compliance demonstration provided the tuning session is performed in accordance with the manufacturer’s specifications. A “major tuning session” would occur after completion of a combustor change-out, a major repair or maintenance to a combustor, or other similar circumstances. Prior to performing any major tuning session, the permittee shall provide the Department’s Southwest District Compliance Authority with an advance notice that details the activity and proposed tuning schedule. The notice may be by telephone, facsimile transmittal, or electronic mail. [Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.17.]

Monitoring of Operations

- F.18. Ammonia Monitoring Requirements.** In accordance with the manufacturer’s specifications, the permittee shall operate and maintain an ammonia flow meter to measure and record the ammonia injection rate to the SCR system. The permittee shall document the general range of ammonia flow rates required to meet permitted emissions levels over the range of load conditions allowed by this permit by comparing NO_x emissions recorded by the CEM system with ammonia flow rates recorded using the ammonia flow meter. During NO_x monitor downtimes or malfunctions, the permittee shall operate at the ammonia flow rate that is consistent with the documented flow rate for the combustion turbine load condition. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.; and, Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.23.]

Continuous Monitoring Requirements

- F.19. CO and NO_x CEMS.** The permittee shall maintain and operate CEMS to measure and record the emissions of CO and NO_x from the combined cycle gas turbine. The CEMS shall be used to demonstrate continuous compliance with the CEMS emission standards specified in this permit. Upon request by the Department’s Southwest District Compliance Authority, the CEMS emission rates shall be corrected to ISO conditions to demonstrate compliance with the applicable standards of 40 CFR 60.332. Within one working day of discovering emissions in excess of a CO or NO_x standard (and subject to the specified averaging period), the permittee shall notify the Department’s Southwest District Compliance Authority.

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

- a. *CO Monitors.* Except as otherwise specified by this condition, the CO monitor shall be certified pursuant to 40 CFR 60, Appendix B, Performance Specification 4 or 4A. Quality assurance procedures shall conform to the requirements of 40 CFR 60, Appendix F, and the Data Assessment Report of Section 7 shall be made each calendar quarter, and reported semiannually to the Department's Southwest District Compliance Authority. The RATA tests required for the CO monitor shall be performed using EPA Method 10 in Appendix A, 40 CFR 60. The Method 10 analysis shall be based on a continuous sampling train, and the ascarite trap may be omitted or the interference trap of Section 10.1 may be used in lieu of the silica gel and ascarite traps. The CO monitor shall be a dual range monitor. The span for the lower range shall not be greater than 50 ppm. The span for the upper range shall be set at a level that provides for accurate measurement during startups and shutdowns.
- b. *NO_x Monitors.* Except as otherwise specified by this condition, the NO_x monitor shall be certified pursuant to 40 CFR 75, and shall be operated and maintained in accordance with the applicable requirements of 40 CFR 75, Subparts B and C. Record keeping and reporting shall be conducted pursuant to 40 CFR 75, Subparts F and G. The RATA tests required for the NO_x monitor shall be performed using EPA Method 20 or 7E in Appendix A, 40 CFR 60. The NO_x monitor shall be a dual range monitor. The span for the lower range shall not be greater than 10 ppm. The span for the upper range shall be set at a level that provides for accurate measurement during startups and shutdowns.
- c. *Diluent Monitors.* The oxygen or carbon dioxide (CO₂) content of the flue gas shall be monitored at the location where CO and NO_x are monitored to correct the measured emissions rates to 15% oxygen. If a CO₂ monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75.
- d. *Moisture Correction.* Final results of the CEMS shall be expressed as ppmvd corrected to 15% oxygen. If the CEMS measures concentration on a wet basis, the CEMS shall include provisions to determine the moisture content of the exhaust gas and an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). Alternatively, the permittee may develop through manual stack test measurements a curve of moisture contents in the exhaust gas versus load for each allowable fuel, and use these typical values in an algorithm to enable correction of the monitoring results to a dry basis (0% moisture). If the CEMS measures concentration on a wet basis and the diluent monitor measures CO₂ on a wet basis, then the permittee may develop an algorithm to enable correction of the CEMS results to a dry basis (0% moisture) without determining the corresponding moisture content.
- e. *1-Hour Block Averages.* Hourly average values shall begin at the top of each hour. Each hourly average value shall be computed using at least one data point in each fifteen-minute quadrant of an hour, where the unit combusted fuel during that quadrant of an hour. Notwithstanding this requirement, an hourly value shall be computed from at least two data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour). If less than two such data points are available, the hourly average value is not valid. An hour in which any oil is fired is attributed towards compliance with the permit standards for oil firing. The permittee shall use all valid measurements or data points collected during an hour to calculate the hourly average values. The CEMS shall be designed and operated to sample, analyze, and record data evenly spaced over an hour.
- f. *24-hour Block Averages.* A 24-hour block shall begin at midnight of each operating day and shall be calculated from 24 consecutive hourly average emission rate values. If a unit operates less than 24 hours during the block, the 24-hour block average shall be the average of available valid hourly average emission rate values for the 24-hour block. For purposes of determining compliance with the 24-hour CEMS emissions standards of this permit, missing (or excluded) data shall not be substituted. Instead, the 24-hour block average shall be determined using the remaining hourly data in the 24-hour block.
{Permitting note: There may be more than one 24-hour compliance demonstration required for CO and NO_x emissions depending on the use of alternate fuels}.
- g. *Data Exclusion.* Each CEMS shall monitor and record emissions during all operations including episodes of startup, shutdown, malfunction, fuel switches, and DLN tuning. CEMS emissions data recorded during

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

some of these episodes may be excluded from the corresponding CEMS compliance demonstration subject to the provisions of Specific Conditions **F.16.** and **F.17.**

- h. *Availability.* Monitor availability for the CEMS shall be 95% or greater in any calendar quarter. The quarterly permit excess emissions report shall be used to demonstrate monitor availability. In the event 95% availability is not achieved, the permittee shall provide the Department's Southwest District Compliance Authority with a report identifying the problems in achieving 95% availability and a plan of corrective actions that will be taken to achieve 95% availability. The permittee shall implement the reported corrective actions within the next calendar quarter. Failure to take corrective actions or continued failure to achieve the minimum monitor availability shall be violations of this permit, except as otherwise authorized by the Department's Southwest District Compliance Authority.

[Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.22.]

{Permitting note: Compliance with these requirements assures compliance with the other applicable CEM system requirements such as: NSPS Subpart GG; Rule 62-297.520, F.A.C.; 40 CFR 60.7(a)(5) and 40 CFR 60.13; 40 CFR 60, Appendix B - Performance Specifications; and, 40 CFR 60, Appendix F - Quality Assurance Procedures. Water injection monitoring is no longer necessary due to the NSPS, Subpart GG revisions.}

Test Methods and Procedures

F.20. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
CTM-027 or EPA Method 320	<i>Procedure for Collection and Analysis of Ammonia in Stationary Sources</i> This is an EPA conditional test method. The minimum detection limit shall be 1 ppm.
7E	<i>Determination of Nitrogen Oxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)</i>
9	<i>Visual Determination of the Opacity of Emissions from Stationary Sources</i> The test shall be conducted for a minimum of 30 minutes.
10	<i>Determination of Carbon Monoxide Emissions from Stationary Sources</i> This method shall be based on a continuous sampling train.
18	<i>Measurement of Gaseous Organic Compound Emissions by Gas Chromatography</i> (Optional) EPA Method 18 may be used concurrently with EPA Method 25A to deduct emissions of methane and ethane from the measured VOC emissions.
20	<i>Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions from Stationary Gas Turbines</i>
25A	<i>Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer</i>

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

Method CTM-027 is published on EPA's Technology Transfer Network Web Site at <http://www.epa.gov/ttn/emc/ctm.html>. The above methods are described in Appendix A, 40 CFR 60, adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rules 62-204.800 & 62-297.401, F.A.C.; 40 CFR 60, Appendix A; and, Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.18.]

- F.21. Common Testing Requirements.** Unless otherwise specified, tests shall be conducted in accordance with the requirements and procedures specified in Appendix TR, Facility-Wide Testing Requirements, of this permit. [Rule 62-297.310, F.A.C.]
- F.22. Continuous Compliance.** The permittee shall demonstrate continuous compliance with the CO and NO_x emissions standards based on data collected by the certified CEMS. Within 45 days of conducting any RATA on a CEMS, the permittee shall submit a report to the Department's Southwest District Compliance Authority summarizing results of the RATA. [Rule 62-212.400(BACT), F.A.C. and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.20.]

{Permitting note: Compliance with the CO emission standards also serves as an indicator of efficient fuel combustion, which reduces emissions of PM/PM₁₀ and VOC.}

- F.23. Annual Compliance Tests.** During each federal fiscal year (October 1st to September 30th), each gas turbine shall be tested to demonstrate compliance with the emission standards for visible emissions and ammonia.
- a. *Visible Emissions.* Each unit shall be tested for visible emissions when firing natural gas and when firing distillate fuel oil. Annual emissions testing while firing fuel oil is not required during any federal fiscal year in which less than 6,140,000 gallons of distillate fuel oil is fired in both emission units combined. CO emissions recorded by the CEMS shall be reported for the visible emissions observation period.
{Permitting note: The fuel limitation for waiving testing while firing distillate fuel oil corresponds to the equivalent of approximately 200 hours of operation per year per turbine.}
- b. *Ammonia.* Annual testing to determine the ammonia slip shall be conducted while firing natural gas. NO_x emissions recorded by the CEMS shall be reported for each ammonia slip test run.
- c. *VOC.* Annual compliance tests for VOC emissions are not required. Compliance with the continuously monitored CO standards shall indicate efficient combustion and low VOC emissions. A monitored exceedance of the CO standard does not necessarily indicate an exceedance of the VOC emissions limitation; however, it may constitute good reason to require compliance testing pursuant to Rule 62-297.310(7)(b), F.A.C.
- [Rules 62-212.400(BACT), 62-213.440(1) & 62-297.310(7)(a)4., F.A.C.; and, Permit No. 1050234-010-AC/PSD-FL-342 Specific Condition III.21.]

- F.24. Additional Compliance Determinations.** The Department may require the permittee to conduct additional tests following a major replacement or major repair of any air pollution control equipment, such as the SCR catalyst, DLN combustors, etc. If required, each gas turbine shall be stack tested to demonstrate compliance with the emission standards for CO, NO_x, VOC, visible emissions, and ammonia slip. The tests shall be conducted within 60 days after achieving the maximum production rate at which the unit will be operated, but not later than 180 days after the unit is restarted. Each unit shall be tested when firing natural gas and when firing distillate fuel oil. CEMS data collected during the required Relative Accuracy Test Assessments (RATA) may be used to demonstrate compliance with the CO and NO_x standards. CO and NO_x emissions recorded by the CEMS shall also be reported for each run during tests for visible emissions, VOC and ammonia slip. [40 CFR 60.8 and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.19.]

Recordkeeping and Reporting Requirements

- F.25. Reporting Schedule.** The following reports and notifications shall be submitted to the Compliance Authority:

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

Report	Reporting Deadline	Related Condition
Malfunction Notification	Within One Working Day	F.27.
Data Exclusion Report	Quarterly	F.28.
NSPS Excess Emissions Report	Semi-annually	F.29.

[Rule 62-213.440(1)(b), F.A.C.]

F.26. Other Reporting Requirements. See Appendix RR, Facility-Wide Reporting Requirements, for additional reporting requirements. [Rule 62-213.440(1)(b), F.A.C.]

F.27. Malfunction Notification. Within one working day of a malfunction for which CEMS data is excluded pursuant to Specific Condition F.16., the permittee shall notify the Department's Southwest District Compliance Authority by telephone, facsimile transmittal, or electronic mail. The notification shall include a preliminary report of: the nature, extent, and duration of the emissions; the probable cause of the emissions; and the actions taken to correct the problem. If requested by the Department's Southwest District Compliance Authority, the permittee shall submit written quarterly reports summarizing the malfunctions in lieu of the individual malfunction notifications otherwise required. [Rule 62-210.700, F.A.C.; and, Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.27.]

F.28. Quarterly Data Exclusion and Monitor Availability Report. The permittee shall quarterly submit a report to the Department's Southwest District Compliance Authority summarizing all periods of valid hourly CO and NO_x emissions data excluded from the 24-hour block average compliance determinations pursuant to Specific Conditions F.16. and F.17. In addition, the quarterly report shall summarize the CEMS availability for the previous quarter. All reports shall be postmarked by the 30th day following the end of each calendar quarter. An example of an acceptable report format for monitoring systems availability is provided in Figure 1 - Summary Report-Gaseous and Opacity Excess Emissions and Monitoring System Performance. [Rules 62-4.130, 62-204.800 and 62-210.700(6), F.A.C.; 40 CFR 60.7(c) & (d); and, Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.29.]

F.29. Semiannual NSPS Excess Emissions Report. In accordance with 40 CFR 60.7(c), the permittee shall semiannually submit a report to the Department's Southwest District Compliance Authority summarizing any emissions in excess of the NSPS standards. All reports shall be postmarked by the 30th day following the end of each six-month period. Written reports of excess emissions shall include the information specified in 40 CFR 60.7(c)(1) through (c)(4). For purposes of reporting emissions in excess of 40 CFR 60, Subpart GG, excess emissions from the gas turbine are defined as: any CEMS hourly average value exceeding the NSPS NO_x emission standard identified in Appendix GG - NSPS Subpart GG Requirements for Gas Turbines (i.e., 112.5 ppmvd corrected to 15% oxygen for both natural gas and fuel oil); and any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds the NSPS standard identified in Appendix GG - NSPS Subpart GG Requirements for Gas Turbines (i.e., sulfur in excess of 0.8% by weight). An example of an acceptable report format is provided in Figure 1 - Summary Report-Gaseous And Opacity Excess Emissions and Monitoring System Performance. [40 CFR 60.7(c) and Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.28.]

F.30. Monitoring of Operation. To demonstrate compliance with the fuel consumption limits of this permit, the permittee shall record the distillate fuel oil consumption on a rolling 12-month basis. [Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.24.]

F.31. Frequency of Recordkeeping. Specific Condition F.19. requires the calculation of one or more 24-hour block average emission rates for each operating day. Within 24 hours of the conclusion of each operating day, the permittee shall complete the calculations and record the results for that operating day. [Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.25.]

F.32. Fuel Sulfur Records. The permittee shall demonstrate compliance with the fuel sulfur limits specified in this permit by maintaining the following records of the sulfur contents.

SECTION III. EMISSIONS UNITS AND SPECIFIC CONDITIONS.

Subsection F. Emissions Unit 018 and 019

- a. Compliance with the fuel sulfur limit for natural gas shall be demonstrated by keeping reports obtained from the vendor indicating the average sulfur content of the natural gas being supplied from the pipeline for each month of operation. Methods for determining the sulfur content of the natural gas shall be ASTM methods D4084-82, D3246-81 or more recent versions.
- b. Compliance with the distillate oil sulfur limit shall be demonstrated by sampling the fuel oil sulfur content in accordance with ASTM D4057-88, Standard Practice for Manual Sampling of Petroleum and Petroleum Products, and one of the following test methods for sulfur in petroleum products: ASTM D129-91, ASTM D1552-90, ASTM D2622-94, or ASTM D4294-90. More recent versions of these methods may be used. For each subsequent fuel delivery, the permittee shall either (1) maintain a permanent file of the certified fuel sulfur analysis from the fuel vendor, or (2) take and analyze a sample according to the above procedures and maintain a permanent file of the results of the analysis. At the request of a Compliance Authority, the permittee shall perform additional sampling and analysis for the fuel sulfur content.

The above methods shall be used to determine the fuel sulfur content in conjunction with the provisions of 40 CFR 75, Appendix D. [Rule 62-4.160(15), F.A.C.; 40 CFR 75, Appendix D; and, Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.26.]

Other Requirements

- F.33. Federal Requirement.** The Department determines that compliance with the BACT emissions performance and monitoring requirements also assures compliance with the NSPS for gas turbines at 40 CFR 60, subpart GG. In addition to the above conditions, these units shall also comply with all the applicable requirements of 40 CFR 60, Subparts A and GG. See Appendices NSPS, Subpart A - General Provisions and NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines. [Permit No. 1050234-010-AC/PSD-FL-342, Specific Condition III.2.]
- F.34. National Emission Standards for Hazardous Air Pollutants (NESHAP).** The Department determines that compliance with the stationary combustion turbine requirements of 40 CFR 63, Subpart YYYYY, National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines (currently stayed) is required. See Appendix NESHAP, Subpart YYYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines of this permit. Compliance shall be required when the final rule is promulgated. [40 CFR 63.6085 and Permit No. 1050234-010-AC, Specific Condition III.3.]

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

Operated By: Progress Energy Florida, Inc.

Plant: Hines Energy Complex

ORIS Code: 7302

The emissions units listed below are regulated under Acid Rain, Phase II.

<u>E.U. No.</u>	<u>Brief Description</u>
001	170 MW Combined Cycle Westinghouse Model 501FC CT1A with unfired HRSG
002	170 MW Combined Cycle Westinghouse Model 501FC CT1B with unfired HRSG
014	170 MW Combined Cycle Westinghouse Model 501FD CT2A with unfired HRSG
015	170 MW Combined Cycle Westinghouse Model 501FD CT2B with unfired HRSG
016	170 MW Combined Cycle Westinghouse Model 501FD CT3A with unfired HRSG
017	170 MW Combined Cycle Westinghouse Model 501FD CT3B with unfired HRSG
018	170 MW Combined Cycle General Electric Model 7FA CT4A with unfired HRSG
019	170 MW Combined Cycle General Electric Model 7FA CT4B with unfired HRSG

A.1. Sulfur dioxide (SO₂) Emission Allowances. SO₂ emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
- b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
- c. Allowances shall be accounted for under the Federal Acid Rain Program. [Rule 62-213.440(1)(c)1., 2. & 3., F.A.C.]

A.2. Fast-Track Revisions of Acid Rain Parts. Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, F.A.C., Fast-Track Revisions of Acid Rain Parts. [Rules 62-213.413 and 62-214.370(4), F.A.C.]

A.3. Comments, notes, and justifications: None.

A.4. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be incorporated into the permit and shall be enforceable by the Administrator. [40 CFR 70.6(a)(1)(ii); and, Rule 62-210.200(Definitions-Applicable Requirements), F.A.C.]

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is: New Revised Renewal

STEP 1

Identify the source by plant name, state, and ORIS or plant code.

Hines Energy Complex	Florida	7302
Plant name	State	ORIS/Plant Code

STEP 2

Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO₂ Opt-in unit, enter "yes" in column "b".

For new units or SO₂ Opt-in units, enter the requested information in columns "d" and "e."

a	b	c	d	e
Unit ID#	SO ₂ Opt-in Unit? (Yes or No)	Unit will hold allowances in accordance with 40 CFR 72.9(c)(1)	New or SO ₂ Opt-in Units Commence Operation Date	New or SO ₂ Opt-in Units Monitor Certification Deadline
1A	No	Yes	N/A	N/A
1B	No	Yes	N/A	N/A
2A	No	Yes	N/A	N/A
2B	No	Yes	N/A	N/A
3A	No	Yes	N/A	N/A
3B	No	Yes	N/A	N/A
4A	No	Yes	N/A	N/A
4B	No	Yes	N/A	N/A

SECTION IV. ACID RAIN PART.
Federal Acid Rain Provisions

Hines Energy Complex

Plant Name (from STEP 1)

STEP 3

Read the standard requirements.

Acid Rain Part Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
 - (ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
 - (ii) Have an Acid Rain Part.

Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
- (4) For applications including a SO₂ Opt-in unit, a monitoring plan for each SO₂ Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO₂ Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
 - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
 - (ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

SECTION IV. ACID RAIN PART.

Federal Acid Rain Provisions

STEP 3,
Continued.

Hines Energy Complex
Plant Name (from STEP 1)

Recordkeeping and Reporting Requirements (cont)

(iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

Liability.

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO_x averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities.

- No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:
- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
 - (2) Limiting the number of allowances a unit can hold; *provided*, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
 - (3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
 - (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
 - (5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

STEP 4
For SO₂ Opt-in units only.

In column "f" enter the unit ID# for every SO₂ Opt-in unit identified in column "a" of STEP 2.

For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.

In column "h" enter the hours.

f	g	h (not required for renewal application)
Unit ID#	Description of the combustion unit	Number of hours unit operated in the six months preceding initial application

SECTION V. CAIR PART.
CLEAN AIR INTERSTATE RULE PROVISIONS

Operated by: Progress Energy Florida, Inc.
Plant: Hines Energy Complex
ORIS Code: 7302

The emissions units listed below are regulated under the Clean Air Interstate Rule (CAIR).

<u>E.U. No.</u>	<u>Brief Description</u>
001	170 MW Combined Cycle Westinghouse Model 501FC CT1A with unfired HRSG
002	170 MW Combined Cycle Westinghouse Model 501FC CT1B with unfired HRSG
014	170 MW Combined Cycle Westinghouse Model 501FD CT2A with unfired HRSG
015	170 MW Combined Cycle Westinghouse Model 501FD CT2B with unfired HRSG
016	170 MW Combined Cycle Westinghouse Model 501FD CT3A with unfired HRSG
017	170 MW Combined Cycle Westinghouse Model 501FD CT3B with unfired HRSG
018	170 MW Combined Cycle General Electric Model 7FA CT4A with unfired HRSG
019	170 MW Combined Cycle General Electric Model 7FA CT4B with unfired HRSG

A.1. Clean Air Interstate Rule Application. The Clean Air Interstate Rule Part Form submitted for this facility is a part of this permit. The owners and operators of these CAIR units as identified in this form must comply with the standard requirements and special provisions set forth in the CAIR Part Form (DEP Form No. 62-210.900(1)(b) - Form, Effective: 3/16/08), which is attached at the end of this subsection. [Chapter 62-213, F.A.C. and Rule 62-210.200, F.A.C.]

A.2. Comments, Notes, and Justifications. None.

SECTION V. CAIR PART.
CLEAN AIR INTERSTATE RULE PROVISIONS

Hines Energy Complex

Plant Name (from STEP 1)

STEP 3

**Read the
standard
requirements.**

CAIR NO_x ANNUAL TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO_x source and each CAIR NO_x unit at the source shall:
 - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
 - (ii) [Reserved];
- (2) The owners and operators of each CAIR NO_x source and each CAIR NO_x unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO_x source and each CAIR NO_x unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NO_x source with the following CAIR NO_x Emissions Requirements.

NO_x Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x source and each CAIR NO_x unit at the source shall hold, in the source's compliance account, CAIR NO_x allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NO_x emissions for the control period from all CAIR NO_x units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
- (2) A CAIR NO_x unit shall be subject to the requirements under paragraph (1) of the NO_x Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR NO_x allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_x Requirements, for a control period in a calendar year before the year for which the CAIR NO_x allowance was allocated.
- (4) CAIR NO_x allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
- (5) A CAIR NO_x allowance is a limited authorization to emit one ton of NO_x in accordance with the CAIR NO_x Annual Trading Program. No provision of the CAIR NO_x Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO_x allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NO_x allowance to or from a CAIR NO_x unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_x unit.

Excess Emissions Requirements.

If a CAIR NO_x source emits NO_x during any control period in excess of the CAIR NO_x emissions limitation, then:

- (1) The owners and operators of the source and each CAIR NO_x unit at the source shall surrender the CAIR NO_x allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NO_x source and each CAIR NO_x unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
 - (i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NO_x unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
 - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Annual Trading Program.
 - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_x Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Annual Trading Program.
- (2) The CAIR designated representative of a CAIR NO_x source and each CAIR NO_x unit at the source shall submit the reports required under the CAIR NO_x Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

SECTION V. CAIR PART.
CLEAN AIR INTERSTATE RULE PROVISIONS

Hines Energy Complex

Plant Name (from STEP 1)

**STEP 3,
Continued**

Liability.

- (1) Each CAIR NO_x source and each CAIR NO_x unit shall meet the requirements of the CAIR NO_x Annual Trading Program.
- (2) Any provision of the CAIR NO_x Annual Trading Program that applies to a CAIR NO_x source or the CAIR designated representative of a CAIR NO_x source shall also apply to the owners and operators of such source and of the CAIR NO_x units at the source.
- (3) Any provision of the CAIR NO_x Annual Trading Program that applies to a CAIR NO_x unit or the CAIR designated representative of a CAIR NO_x unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_x Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x source or CAIR NO_x unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR SO₂ TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall:
 - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
 - (ii) [Reserved];
- (2) The owners and operators of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR SO₂ source and each SO₂ CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO₂ source with the following CAIR SO₂ Emission Requirements.

SO₂ Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO₂ source and each CAIR SO₂ unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO₂ allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO₂ units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
- (2) A CAIR SO₂ unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR SO₂ allowance shall not be deducted for compliance with the requirements under paragraph (1) of the SO₂ Emission Requirements for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated.
- (4) CAIR SO₂ allowances shall be held in, deducted from, or transferred into or among CAIR SO₂ Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
- (5) A CAIR SO₂ allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO₂ Trading Program. No provision of the CAIR SO₂ Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR SO₂ allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO₂ allowance to or from a CAIR SO₂ unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO₂ unit.

Excess Emissions Requirements.

If a CAIR SO₂ source emits SO₂ during any control period in excess of the CAIR SO₂ emissions limitation, then:

- (1) The owners and operators of the source and each CAIR SO₂ unit at the source shall surrender the CAIR SO₂ allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

SECTION V. CAIR PART.
CLEAN AIR INTERSTATE RULE PROVISIONS

Hines Energy Complex

Plant Name (from STEP 1)

**STEP 3,
Continued**

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR SO₂ source and each CAIR SO₂ unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.

(i) The certificate of representation under 40 CFR 96.213 for the CAIR designated representative for the source and each CAIR SO₂ unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.213 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO₂ Trading Program.

(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR SO₂ Trading Program.

(2) The CAIR designated representative of a CAIR SO₂ source and each CAIR SO₂ unit at the source shall submit the reports required under the CAIR SO₂ Trading Program, including those under 40 CFR Part 96, Subpart HHH.

Liability.

(1) Each CAIR SO₂ source and each CAIR SO₂ unit shall meet the requirements of the CAIR SO₂ Trading Program.

(2) Any provision of the CAIR SO₂ Trading Program that applies to a CAIR SO₂ source or the CAIR designated representative of a CAIR SO₂ source shall also apply to the owners and operators of such source and of the CAIR SO₂ units at the source.

(3) Any provision of the CAIR SO₂ Trading Program that applies to a CAIR SO₂ unit or the CAIR designated representative of a CAIR SO₂ unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR SO₂ Trading Program, a CAIR Part, or an exemption under 40 CFR 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO₂ source or CAIR SO₂ unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

CAIR NO_x OZONE SEASON TRADING PROGRAM

CAIR Part Requirements.

(1) The CAIR designated representative of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall:

- (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C., and
- (ii) [Reserved];

(2) The owners and operators of each CAIR NO_x Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO_x Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

(1) The owners and operators, and the CAIR designated representative, of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.

(2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO_x Ozone Season source with the following CAIR NO_x Ozone Season Emissions Requirements.

NO_x Ozone Season Emission Requirements.

(1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_x Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO_x emissions for the control period from all CAIR NO_x Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.

(2) A CAIR NO_x Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO_x Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1),(2), or (3) and for each control period thereafter.

(3) A CAIR NO_x Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO_x Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO_x Ozone Season allowance was allocated.

(4) CAIR NO_x Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.

(5) A CAIR NO_x Ozone Season allowance is a limited authorization to emit one ton of NO_x in accordance with the CAIR NO_x Ozone Season Trading Program. No provision of the CAIR NO_x Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.

(6) A CAIR NO_x Ozone Season allowance does not constitute a property right.

(7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO_x Ozone Season allowance to or from a CAIR NO_x Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO_x Ozone Season unit.

**SECTION V. CAIR PART.
CLEAN AIR INTERSTATE RULE PROVISIONS**

Hines Energy Complex

Plant Name (from STEP 1)

**STEP 3,
Continued**

Excess Emissions Requirements.

If a CAIR NO_x Ozone Season source emits NO_x during any control period in excess of the CAIR NO_x Ozone Season emissions limitation, then:
 (1) The owners and operators of the source and each CAIR NO_x Ozone Season unit at the source shall surrender the CAIR NO_x Ozone Season allowances required for deduction under 40 CFR 98.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law, and
 (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 98, Subpart AAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

(1) Unless otherwise provided, the owners and operators of the CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.

(i) The certificate of representation under 40 CFR 98.313 for the CAIR designated representative for the source and each CAIR NO_x Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 98.113 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 40 CFR Part 98, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 98, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Ozone Season Trading Program.

(iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO_x Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Ozone Season Trading Program.

(2) The CAIR designated representative of a CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall submit the reports required under the CAIR NO_x Ozone Season Trading Program, including those under 40 CFR Part 98, Subpart HHHH.

Liability.

(1) Each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit shall meet the requirements of the CAIR NO_x Ozone Season Trading Program.

(2) Any provision of the CAIR NO_x Ozone Season Trading Program that applies to a CAIR NO_x Ozone Season source or the CAIR designated representative of a CAIR NO_x Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO_x Ozone Season units at the source.

(3) Any provision of the CAIR NO_x Ozone Season Trading Program that applies to a CAIR NO_x Ozone Season unit or the CAIR designated representative of a CAIR NO_x Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.

No provision of the CAIR NO_x Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 98.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x Ozone Season source or CAIR NO_x Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

STEP 4

Certification (for designated representative or alternate designated representative only)

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information, are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Patricia Q. West Name	Manager, Environmental Services, Energy Supply Florida Title
Progress Energy Florida Owner Company Name	
(727) 820-5739 Phone	Patricia.West@pgnmail.com E-mail address
Signature <i>Patricia Q. West</i>	Date <i>7/13/2011</i>

SECTION VI. APPENDICES.

The Following Appendices Are Enforceable Parts of This Permit:

Appendix A, Abbreviations, Acronyms, Citations and Identification Numbers.

Appendix G, Combustion Turbine Heat Input Curves.

Appendix I, List of Insignificant Emissions Units and/or Activities.

Appendix NESHAP, Subpart A - General Provisions.

Appendix NESHAP, Subpart YYYY - National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines.

Appendix NSPS, Subpart A - General Provisions.

Appendix NSPS, Subpart Dc - Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units

Appendix NSPS, Subpart GG - Standards of Performance for Stationary Gas Turbines.

Appendix RR, Facility-wide Reporting Requirements.

Appendix TR, Facility-wide Testing Requirements.

Appendix TV, Title V General Conditions.

Attachments (at end of Appendices Section).

Figure 1, Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance (40 CFR 60, July, 1996).

Table H, Permit History.

Friday, Barbara

From: Friday, Barbara
Sent: Thursday, November 10, 2011 2:17 PM
To: 'martin.drango@pgnmail.com'
Cc: 'anthony.salvarrezza@pgnmail.com'; 'chris.bradley@pgnmail.com'; 'tdavis@ectinc.com'; Zhang-Torres; Mulkey, Cindy; 'forney.kathleen@epamail.epa.gov'; 'oquendo.ana@epa.gov'; Lanh, Kris; Holtom, Jonathan
Subject: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV
Attachments: 1050234-019-AV Signed Written Notice of Intent.pdf

Tracking:	Recipient	Delivery	Read
	'martin.drango@pgnmail.com'		
✓	'anthony.salvarrezza@pgnmail.com'		
✓	'chris.bradley@pgnmail.com'		
✓	'tdavis@ectinc.com'		
✓	Zhang-Torres	Delivered: 11/10/2011 2:17 PM	
✓	Mulkey, Cindy	Delivered: 11/10/2011 2:17 PM	
	'forney.kathleen@epamail.epa.gov'		
	'oquendo.ana@epa.gov'		
	Lanh, Kris	Delivered: 11/10/2011 2:17 PM	Read: 11/10/2011 2:20 PM
✓	Holtom, Jonathan	Delivered: 11/10/2011 2:17 PM	

Dear Mr. Drango:

Attached is the official **Notice of Draft/Proposed Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).

Attention: Kris Lahn

Owner/Company Name: FLORIDA POWER CORPORATION DBA PROGRESS ENERGY FLORIDA, INC.
Facility Name: HINES ENERGY COMPLEX
Project Number: 1050234-019-AV
Permit Status: DRAFT/PROPOSED
Permit Activity: PERMIT RENEWAL
Facility County: POLK

Click on the following link to access the permit project documents:

http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/1050234.019.AV.D_pdf.zip

The Office of Permitting and Compliance is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "Air Permit Documents Search" website at <http://www.dep.state.fl.us/air/emission/apds/default.asp>.

Permit project documents addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Office of Permitting and Compliance.

Note: The attached document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <<http://www.adobe.com/products/acrobat/readstep.html>> .

Regards,

Barbara Friday

Office of Permitting and Compliance (OPC)

Division of Air Resources Management

850-717-9095

Please take a few minutes to share your comments on the service you received from the department by clicking on this link. [DEP Customer Survey](#).

Friday, Barbara

From: Microsoft Exchange
To: 'martin.drango@pgnmail.com'; 'chris.bradley@pgnmail.com'
Sent: Thursday, November 10, 2011 2:17 PM
Subject: Relayed: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX;
1050234-019-AV

Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:

'martin.drango@pgnmail.com'

'chris.bradley@pgnmail.com'

Subject: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Sent by Microsoft Exchange Server 2007

Friday, Barbara

From: Bradley, Chris [Chris.Bradley@pgnmail.com]
To: Friday, Barbara
Sent: Thursday, November 10, 2011 2:34 PM
Subject: Read: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Your message was read on Thursday, November 10, 2011 2:34:26 PM (GMT-05:00) Eastern Time (US & Canada).

Friday, Barbara

From: Microsoft Exchange
To: 'anthony.salvarezza@pgnmail.com'
Sent: Thursday, November 10, 2011 2:26 PM
Subject: Relayed: FW: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX;
1050234-019-AV

Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:

'anthony.salvarezza@pgnmail.com'

Subject: FW: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Sent by Microsoft Exchange Server 2007

Friday, Barbara

From: Salvarezza, Anthony [Anthony.Salvarezza@pgnmail.com]
To: Friday, Barbara
Sent: Thursday, November 10, 2011 2:36 PM
Subject: Read: FW: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX;
1050234-019-AV

Your message was read on Thursday, November 10, 2011 2:36:13 PM (GMT-05:00) Eastern Time (US & Canada).

Friday, Barbara

From: Microsoft Exchange
To: 'tdavis@ectinc.com'
Sent: Thursday, November 10, 2011 2:17 PM
Subject: Relayed: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX;
1050234-019-AV

Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:

'tdavis@ectinc.com'

Subject: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Sent by Microsoft Exchange Server 2007

Friday, Barbara

From: Tom Davis [tdavis@ectinc.com]
Sent: Thursday, November 10, 2011 2:22 PM
To: Friday, Barbara
Subject: RE: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Dear Ms. Friday,

I have received and can access the documents referenced in your email below.

Thanks.

From: Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]
Sent: Thursday, November 10, 2011 2:17 PM
To: 'martin.drango@pgnmail.com'
Cc: 'anthony.salvarrezza@pgnmail.com'; 'chris.bradley@pgnmail.com'; 'tdavis@ectinc.com'; Zhang-Torres; Mulkey, Cindy; 'forney.kathleen@epamail.epa.gov'; 'oquendo.ana@epa.gov'; Lanh, Kris; Holtom, Jonathan
Subject: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Dear Mr. Drango:

Attached is the official **Notice of Draft/Proposed Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).

Attention: Kris Lahn

Owner/Company Name: FLORIDA POWER CORPORATION DBA PROGRESS ENERGY FLORIDA, INC.
Facility Name: HINES ENERGY COMPLEX
Project Number: 1050234-019-AV
Permit Status: DRAFT/PROPOSED
Permit Activity: PERMIT RENEWAL
Facility County: POLK

Click on the following link to access the permit project documents:

http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/1050234.019.AV.D_pdf.zip

The Office of Permitting and Compliance is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "Air Permit Documents Search" website at <http://www.dep.state.fl.us/air/emission/apds/default.asp>.

Permit project documents addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems

opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Office of Permitting and Compliance.

Note: The attached document is in Adobe Portable Document Format (pdf). Adobe Acrobat Reader can be downloaded for free at the following internet site: <<http://www.adobe.com/products/acrobat/readstep.html>> .

Regards,

Barbara Friday

Office of Permitting and Compliance (OPC)

Division of Air Resources Management

850-717-9095

Please take a few minutes to share your comments on the service you received from the department by clicking on this link. [DEP Customer Survey](#).

Friday, Barbara

From: Microsoft Exchange
To: Zhang-Torres; Mulkey, Cindy; Holtom, Jonathan; Lanh, Kris
Sent: Thursday, November 10, 2011 2:17 PM
Subject: Delivered: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX;
1050234-019-AV

Your message has been delivered to the following recipients:

Zhang-Torres

Mulkey, Cindy

Holtom, Jonathan

Lanh, Kris

Subject: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Sent by Microsoft Exchange Server 2007

Friday, Barbara

From: Zhang-Torres
To: Friday, Barbara
Sent: Thursday, November 10, 2011 2:30 PM
Subject: Read: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Your message was read on Thursday, November 10, 2011 2:29:40 PM (GMT-05:00) Eastern Time (US & Canada).

Friday, Barbara

From: Mulkey, Cindy
To: Friday, Barbara
Sent: Thursday, November 10, 2011 2:29 PM
Subject: Read: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Your message was read on Thursday, November 10, 2011 2:28:43 PM (GMT-05:00) Eastern Time (US & Canada).

Friday, Barbara

From: Holtom, Jonathan
To: Friday, Barbara
Sent: Thursday, November 10, 2011 2:41 PM
Subject: Read: PROGRESS ENERGY FLORIDA, INC. - HINES ENERGY COMPLEX; 1050234-019-AV

Your message was read on Thursday, November 10, 2011 2:40:48 PM (GMT-05:00) Eastern Time (US & Canada).