

Golder Associates Inc.

6241 NW 23rd Street, Suite 500
Gainesville, FL 32653-1500
Telephone (352) 336-5600
Fax (352) 336-6603

RECEIVED

SEP 08 2000



BUREAU OF AIR REGULATION

September 5, 2000

9939570

Administrator, New Source Review Section
Florida Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Attention: Mr. A.A. Linero, P.E.

RE: CALPINE CONSTRUCTION FINANCE COMPANY, LP
OSPREY ENERGY CENTER
COMMENTS ON DRAFT AIR CONSTRUCTION PERMIT; RESPONSES TO EPA
COMMENTS ON APPLICATION FOR PERMIT TO CONSTRUCT

Dear Mr. Linero:

The following information provides comments to the draft air construction permit for the proposed Osprey Energy Center in Auburndale, Polk County, Florida prepared by the Florida Department of Environmental Protection (DEP). In addition, responses have been prepared that address the comments made by the U.S. Environmental Protection Agency (EPA) dated June 21, 2000 regarding the air construction permit application.

COMMENTS TO THE DRAFT AIR CONSTRUCTION PERMIT

Comments to the draft air construction permit were discussed in a meeting held with DEP on June 29, 2000. A summary of these comments is presented in Attachment 1 to this letter.

EPA COMMENTS AND RESPONSES

Comment 1

1. In November 1999, ABB ALSTOM POWER announced the availability of SCONOX_x systems for any size combustion turbines. Region 4 therefore considers this control method technically feasible for Osprey's combined cycle CTs. Accordingly, FDEP should require the Osprey Energy Center to provide a project-specific BACT analysis for SCONOX_x (economics, environmental impacts, and energy use) before issuing a final permit.

Response: Although SCONOX_xTM is theoretically technically feasible, it has not been demonstrated on an "F" Class combustion turbine. Performance data on future applications on "F" Class turbines considering SCONOX_xTM will only likely be available after 2002, well after the Osprey Energy Center is scheduled for construction. The SCONOX_xTM system has only been operated on a 32 MW facility in California since 1996 and a 5 MW unit in Massachusetts since 1999. The scale up of this complicated technology should not be underestimated. The SCONOX_xTM technology installed on an "F" Class turbine would involve about a dozen or more different catalyst chambers for absorption and regeneration. Every 15 to 30 minutes, dampers would be operated to isolate a particular catalyst chamber for regeneration. Each regeneration cycle must isolate the chamber so that oxygen is not introduced and regeneration gas (hydrogen) is introduced. There is concern that damper seal leaks would be significant as applied to the large volume flows associated with an "F" Class CT. While ammonia is not required for the SCONOX_xTM system, the turbine backpressure with SCONOX_xTM is greater than SCR (about 60%) and SCONOX_xTM requires natural gas and steam for regeneration of the

catalyst beds. In contrast, SCR is a proven and demonstrated technology that can achieve the same NO_x reduction performance.

While ammonia is not used or emitted from a SCONO_xTM system, there are substantial natural gas and energy requirements for the system that would directly produce air pollutants. The natural gas required to produce the steam needed for SCONO_xTM is equivalent to 27 mmBtu/hr or 235,200 mmBtu/year. In contrast, the natural gas requirement needed for SCR is equivalent to 1.8 mmBtu/hr or 15,600 mmBtu/year. These energy requirements, combined with the turbine backpressure and electrical usage would increase emissions of carbon dioxide by about 23,800 ton/year. When all the energy requirements for SCONO_xTM are considered, it is about 2.3 percent of the combustion turbine heat input. SCR results in an additional 0.3 percent of the combustion turbine heat input.

The estimated capital cost for SCONO_xTM developed for one turbine/HRSG unit for the proposed Osprey Energy Center is \$30 million. This capital cost estimate is based on information supplied by ABB Alstrom and the procedures in the EPA Cost Control Manual. In contrast, the capital costs for SCR is about \$3.0 million, which clearly is about one-tenth the cost of a SCONO_xTM system. The annualized cost of SCONO_xTM is estimated at \$6.2 million, while the annualized cost for SCR is \$1.6 million. Tables B-3a and B-4a present the capital and annualized costs of SCR and SCONO_xTM. The cost effectiveness of SCONO_xTM is \$9,300 per ton of NO_x removed. In contrast, the cost effectiveness of SCR is \$2,400 per ton of NO_x removed. The cost per ton of NO_x removed is nearly 4 times higher for the SCONO_xTM system than for SCR and incurs the uncertainty in its lack of demonstrated feasibility on large turbines.

Comment 2

2. We suggest you verify the emission factor used by Golder Associates to estimate potential formaldehyde emissions. The emission factor cited by Golder is only one-fifth of the emission factor cited for formaldehyde from natural gas turbines in the recently revised section 3.1 of AP-42.

Response: Golder Associates has revised the emission factors for hazardous air pollutants (HAPs) to reflect the availability of additional data. The revised HAP emissions are based on emission factors from the April 2000 revision of EPA's AP-42 emission factor database. A summary of the emission factors and emissions for gas firing is presented in Tables A-2, A-3, A-5, A-6, A-8, and A-9.

Except for formaldehyde, the emission factors are those presented in Tables 3.1-4 and 3.1-5 of the revised AP-42 section for combustion turbines. For formaldehyde, a review of EPA's database was conducted and an emission factor was estimated based on comparisons of the turbines and emission characteristics from EPA's database to those proposed for this project. A discussion regarding this review and estimation of the formaldehyde emission factor is presented here.

The original emission factor for formaldehyde used in the application was from the Electric Power Research Institute (EPRI)- sponsored Electric Utility Trace Substances Synthesis Report. This report was submitted to EPA as part the requirements of the 1990 Clean Air Act Amendments to study potentially toxic air pollutants from utility sources. These data were the most technically accurate and complete data available on emission from utility sources. The emission factor used for the proposed CTs for this Project was 34 lb/10¹² Btu. It should be recognized that there are still limited data on formaldehyde emissions from large (i.e., > 100 MW) gas turbines.

The recent EPA emission factor suggests formaldehyde emissions from gas turbines of 780 lb/10¹² Btu when firing natural gas at loads greater than 80 percent. The EPA suggested emission factor for all loads is 3,100 lb/10¹² Btu. These emission factors for formaldehyde when firing natural gas are not appropriate for the proposed CTs for several reasons. First, and most importantly, the data used to develop the AP-42 emission factors are not representative of the Siemens Westinghouse combustion

turbine. Second, an evaluation of the data in the EPA Combustion Turbine Emissions Database clearly suggests a much lower emission factor for formaldehyde. Some of the important aspects of the EPA Gas Turbine Database related to formaldehyde emission are as follows.

- The formaldehyde emissions listed in the database are from small (< 30 MW) gas turbines. The available data are from an average capacity of about 28 MW. More importantly, the median capacity, or the turbine size where an equal number of turbines are above and below that size, is about 15 MW. Data from only 8 large turbines (>30 MW) are included in the EPA database, with a maximum size of 88 MW.
- In contrast to the AP-42 emission factors for formaldehyde, which are based on an average value, the median value in the database is substantially lower. For all loads, the median formaldehyde emission factor is about 320 lb/10¹² Btu; for turbine loads greater than 50 percent, the median emission factor is about 110 lb/10¹² Btu. The median emission factor is about 8 to ten times lower than the average factor which demonstrates the wide range in formaldehyde emissions and how individual turbine combustion characteristics can influence the results. The median is a measure of the middle of the distribution and, in distributions where there is symmetry about the mean, the mean and median coincide. However, in highly skewed distributions, as that observed for formaldehyde emissions, the median is more representative of a "truer average" since the median is not influenced by extreme values.
- There is a strong relationship between formaldehyde and CO emissions, as noted by EPA in the support document and, as observed in the data. Gas turbines with higher CO emissions had higher observed formaldehyde emissions. An evaluation of the coincident CO and formaldehyde data indicates that formaldehyde emissions were 150 lb/10¹² Btu with CO emissions less than 0.1 lb/mmBtu. The CO emissions from the Siemens Westinghouse 501F turbine are about 0.02 lb/mmBtu under base load conditions and 0.06 lb/mmBtu with power augmentation.

The California Air Resource Board sponsored a program to develop emission factors for toxic air pollutants. These factors, referred to as California Air Toxic Emission Factors (CATEF), included an emission factor for formaldehyde. The suggested factor is 108 lb/10¹² Btu.

Based on the available data, formaldehyde emissions would be in the range between 100 and 150 lb/10¹² Btu. An emission factor of 150 lb/10¹² Btu is considered appropriate for the Osprey Energy Center as a conservative factor for formaldehyde emissions.

Preliminary test data from a Calpine facility in Pasadena indicate formaldehyde emissions of about 150 lb/10¹² Btu. Therefore, the emissions factor for formaldehyde developed from the EPA database is similar to the preliminary test data. The AP-42 emission factor for acetaldehyde is 40 lb/10¹² Btu, which is also similar to the preliminary test data.

EPA developed the emission factors for many of the other HAPs in a manner similar to formaldehyde. For these HAPs, fewer data are available and are also considered not representative of state-of-the-art DLN combustion systems. The use of AP-42 emission factors for these HAPs are considered to provide conservative estimates of emissions.

An evaluation of the HAP emissions from the project indicates that emissions are less than 25 tons/year for all HAPs and less than 10 tons/year for any single HAP. As shown in Table 2-4, the maximum total emissions of HAPs are estimated to be 8 tons/year with maximum emissions of any single HAPs at 2.6 tons/year (i.e., for formaldehyde). Therefore, the requirements of 40 CFR 63.43 for a maximum achievable control technology are not applicable to the project.

Comment 3


3. The "Public Notice of Intent to Issue PSD Permit" indicates that the combustion turbines for this project will be General Electric PG7241FA units. It is our understanding, as indicated in the preliminary determination and draft PSD permit, that the Osprey Energy Center will be installing Siemens Westinghouse 501FD combustion turbines. If possible, please clarify this inconsistency before the public notice is published.

Response: As a point of clarification, the Siemens Westinghouse 501FD combustion turbines are proposed for the Osprey Energy Center.


We appreciate your timely review of these responses. If you have any additional questions, please contact Mr. Benjamin Borsch of Calpine at (813) 637-3515 or me at (352) 363-5600.

Sincerely,

GOLDER ASSOCIATES INC.



Kennard F. Kosky, P.E.
Principal



RCM/jkw

cc: Benjamin Borsch, Calpine, Corporation
R.C. McCann, Golder
R. Douglas Neeley, EPA Region
David S. Dee, Landers & Parsons
M. Halpin
C. Holladay
NPS
B. Owens
SWD

ATTACHMENT 1

Comments On Osprey Draft Permit

Permit Ref.	Sec.	Para.	Line	Comment
Intent to Issue PSD Permit	N/A	2	5	Delete "121 foot" or change to "135 foot"
Public Notice to Issue	N/A	1	4	Change "nitrous" to "nitrogen"
Public Notice to Issue	N/A	2	1	Change "General Electric PG7241FA" to "Siemens Westinghouse 501FD"
Public Notice to Issue	N/A	2	4	Change "...relatively short stacks ..." to "... stacks..."
Public Notice to Issue	N/A	4	Table	NO _x emissions should be reduced from 258 to 227 TPY in order to reflect the reduction of emission concentration from 4.0 to 3.5 ppmvd corrected to 15% O ₂ . The 227 TPY reflects 3.5 ppmvd (corrected) limit and the emergency gas generator and diesel fire pump.
Technical Evaluation and Preliminary Determination (TEPD)	1.1	1	1	Change "Calpine Construction Finance Company" to "Calpine Construction Finance Company, LP"
TEPD	3	2	1	Change "Calpine Construction & Finance Company, LP" to "Calpine Construction Finance Company, LP"
TEPD	4	3	4&5	Delete "Steam cooling of key components of the 501 F minimizes the need for less efficient air-cooling." F turbines do not employ this technology; G turbines do.
TEPD	6.2	1	NO _x	The NO _x emissions of the 2 CT/DB with duct firing are 218 TPY; the total is 227 TPY. This reflects the 3.5 ppmvd (corrected) limit.
TEPD	6.4.4	2	2	Change "Because no add-on-on control equipment and no reagents are required, there will be no steam plum or tendency to form ammoniated particulate species" to "There will be no steam plume."
Draft Permit	I(pg1)	1	1	Change "Calpine Construction & Finance Co., LP" to "Calpine Construction Finance Company, LP"
Draft Permit	I(pg2)	1	6	Change "230 KV transmission line" to "transmission line"
Draft Permit	III(pg6)	9	2&3	Add "without power augmentation" at end of first sentence since 1,669 MMBtu/hour is based

Permit Ref.	Sec.	Para.	Line	Comment
				on base load conditions. Also, the 1,669 million Btu per hour at ISO conditions is based on Siemens/Westinghouse guarantees but could change depending on the final installation and testing of the 501F units. Calpine understands that, based on the language of the condition, this could be modified based on "as built" performance curves.
Draft Permit	III(pg7)	10	2	The 250 MMBtu/hour is lower heating value (LHV); Change "(HHV)" to "(LHV)".
Draft Permit	III(pg7)	16	1	Change "simple cycle mode" to "without the use of the SCR system except during periods of startup and shut down." It is possible that the unit could operate in simple cycle mode during steam turbine failure or overhaul or during startup. For example, a dump condenser could be installed to manage the steam generated by the HRSG. With such operation, the SCR system would still be operated to meet emission limits but the unit would be in simple cycle mode.
Draft Permit	III(pg7)	19	1	Change "A certification..." to "A manufacturer's certification..."
Draft Permit	III(pg8)	20	2	Change "3-hr block average" to "24-hour block average" to be consistent with DEP's BACT Determination
Draft Permit	III(pg8)	20	6	Add after "27.5 lb/hr" the following "...at 95°F ambient temperature with power augmentation and duct firing)". The 27.5 lb/hr reflects NO _x emissions when duct firing and power augmentation at 95 °F ambient conditions. This mode is more likely during the summer conditions, under cold weather conditions the emissions are 30.7 lb/hr. This is the maximum mass emission and is based on data from Siemens Westinghouse for that ambient temperature. Data sheets are attached.
Draft Permit	III(pg8)	21	2	Change "10 ppm" to "10 ppmvd"
Draft Permit	III(pg8)	21	5	Change "10 ppm" to "10 ppmvd @ 15% O ₂ "
Draft Permit	III(pg8)	21	5	Change "45 lb/hr" to "45 lb/hr per unit"
Draft Permit	III(pg8)	21	6	Change "with the duct burner off" to "with the duct burner off and no steam injection for

Permit Ref.	Sec.	Para.	Line	Comment
				power augmentation"
Draft Permit	III(pg8)	21	6	Add "...to be demonstrated by annual stack test using EPA Method <u>10</u> or through annual <u>RATA testing</u> ." Calpine will have a certified CEMS that will demonstrate compliance continuously.
Draft Permit	III(pg8)	22	2 and 3	Change "ppmvd" to "ppmvd @ 15% O ₂ " and "lb/hr" to "lb/hr per unit"
Draft Permit	III(pg8)	22	5	Add emission limit of 4.2 ppmvd @ 15% O ₂ during operations between 60 and 70 percent load per DEPs BACT Determination.
Draft Permit	III(pg8)	23	2	Change "less" to "not greater than"
Draft Permit	III(pg8)	23	5 and 6	Convert the last sentence to a note, since this statement is not relevant to limiting emissions of SO ₂ .
Draft Permit	III(pg8)	24	2	Change "the combustion turbine" to "each combustion turbine and HRSG train"
Draft Permit	III(pg9)	25	8	This condition would prohibit operation at or below 60 percent load even if the unit can meet the emission limits for CO. Add the following at the end of the condition: "...unless the permittee can demonstrate that the emission limits in Specific Condition III. 21. can be met." The plant will have CEMs and compliance will have to be demonstrated except for the periods outlined in the condition.
Draft Permit	III(pg9)	26	3	Change "3-hr" to "24-hr"
Draft Permit	III(pg9)	27	8	Change "No. 20 through 24" to "No. 20 through 21." Calpine has no way of knowing excess emissions for VOC, SO ₂ and PM during startups and shutdowns.
Draft Permit	III(pg9)	29	1-4	Delete "Initial tests shall ... or change of combustors." What constitutes a "substantial modification" is very subjective in this context and any work performed on the units will likely affect only CO and NO _x , which are subject to CEMS. In addition, annual compliance tests were performed during every federal fiscal year. Replace with "Any replacement of the major components of the air pollution control equipment or the combustors (e.g., catalyst change-out or combustor replacement) must demonstrate

Permit Ref.	Sec.	Para.	Line	Comment
				compliance with the CEM based emission limits after the replacement is made. This activity must be identified in the quarterly report. If compliance with the CO emission limit is demonstrated through the CEM after the replacement, then no testing of VOCs is required."
Draft Permit	III(pg9)	29	Bul. 4	Delete the last sentence. The BACT standard should not have any relationship to the "ISO" correction and methods used in EPA Method 20. For annual tests, add that compliance with the BACT standard can be demonstrated during the RATA testing required under 40 CFR Part 75
Draft Permit	III(pg10)	30	8	Change "These excess emission periods..." to "Excess emission periods..."
Draft Permit	III(pg12)	44	All	Calpine understands that the language is taken from the Department's rules and that the appropriate process variables are based on the permit and the test methods prescribed in the permit. Add "No later than 90 days prior to operation, the permittee shall submit for the Department's approval a list of process variables that will be measured to comply with this permit condition."
Draft Permit	III(pg12)	46	Bul. 2	Delete the last sentence of the bullet. The wording presents both interpretation and enforcement difficulties. It is clear that the NO _x emission limit is CEM based and Calpine will operate the SCR system as required by both the emission limit and the manufacturer's requirements to insure the NO _x limit is achieved. See also comments to Bullet 5.
Draft Permit	III(pg12)	46	Bul. 3, ln 8&9	Delete the last two sentences. As discussed in our comments to Bullets 5 and 6 of this paragraph, Calpine proposes continuous monitoring, notification and corrective action planning that renders these two sentences unnecessary.
Draft Permit	III(pg13)	46	Bul. 4	Delete the word "minimum" in reference to the ammonia flow rate in the first sentence. Replace "at a minimum of 100% of the ammonia injection rate determined during the test." with "at an ammonia flow rate

Permit Ref.	Sec.	Para.	Line	Comment
				immediately prior to the NO _x CEM disruption." The system will be operated according to the manufacturer's requirements and information on the flow rate will be provided and the annual tests will include the ammonia emissions. Using an ammonia flow rate just prior to a NO _x CEM failure would reflect the current state of the catalyst while minimizing ammonia emissions. See also comments to Bullet 5.
Draft Permit	III(pg13)	46	Bul. 5	Calpine offers the following as a condition to monitor ammonia emissions. "Ammonia emissions shall be calculated using inlet and outlet NO _x concentrations from the SCR system and ammonia flow supplied to the SCR system. The calculation procedure shall be provided with the CEM monitoring plan required by 40 CFR Part 75." There are several procedures, which can be used to calculate ammonia emissions based on the final CEM design. Examples are attached.
Draft Permit	III(pg13)	46	Bul. 6	Delete. This provision is inappropriate since it assumes that ammonia slip will exceed the 9-ppm limit within a year from the time that the ammonia slip is over 7. Indeed, ammonia testing will occur each year to determine compliance. Moreover, ammonia is not a regulated pollutant under the Clean Air Act except for 112 r provisions. The prior provisions to this paragraph provide the DEP with adequate assurances of continuous compliance. Per our discussion with the Department, replace this condition with: "The permittee shall notify the Department within 2 business days if the calculated ammonia emissions exceed 9 ppmvd corrected to 15% O ₂ over a 24-hour block average. The notification shall include a corrective action plan to reduce ammonia emissions to below 9 ppmvd corrected to 15% O ₂ over a 24-hour block average."
Draft Permit	III(pg13)	46	Bul. 7	Delete. This provision assumes that the cause of an ammonia slip or NO _x exceedence is saturated catalyst when in fact it could be

Permit Ref.	Sec.	Para.	Line	Comment
				another cause (plugged nozzles, pump malfunctions, etc.). The prior provisions provide DEP with adequate assurances of continuous compliance. Calpine has offered language in Bullet 6 that provides notification and corrective actions to limit ammonia emissions.
Draft Permit	III(pg13)	46	Bul. 8	Delete. Calpine is not aware of any data that suggests maintaining a catalyst age of less than 24 months is necessary to ensure compliance with our NO _x or ammonia limits. In addition, each unit will have continuous monitoring of NO _x and ammonia usage (via ammonia flow monitoring), which will provide an indication of the need to replace catalyst. Calpine has offered continuous monitoring and notification procedures (see Bullets 5 and 6) that provide reasonable assurance that the SCR system will comply with ammonia and NO _x emission limits.
Appendix BD	PgBD-3	Tab.1		The Calpine Sutter and Delta Projects were LAER limits, not BACT limits
Appendix BD	PgBD-7	3	4	The SCONO _x unit in Massachusetts is operational; however, it has not provided consistently low NO _x emissions.
Appendix BD	PgBD-8	2	1 and 2	Most of the recent LAER determinations have specified the combination of dry-low NO _x combustors and SCR, not SCONO _x .
Appendix BD	PgBD-11	Table	NO _x	Request that EPA Method 7e be added to the compliance procedures for NO _x .

Table 2-1. Stack, Operating, and Emission Data for the Combustion Turbines/HRSG and Duct Burners
Osprey Energy Center Project

Parameter	Operating and Emission Data ^a for Ambient Temperature				
	Combustion Turbine/ HRSG			CT/ HRSG/ Duct Burner	
	32 °F	59 °F	95 °F	Power Augmentation 95 °F	Power Augmentation 95 °F
<u>Stack Data (ft)</u>					
Height	135	135	135	135	135
Diameter	19	19	19	19	19
<u>100 Percent Load</u>					
Operating Data					
Temperature (°F)	200	200	200	200	200
Velocity (ft/sec)	62.9	60.0	55.2	59.7	60.0
Maximum Hourly Emissions per Unit ^b					
SO ₂ lb/hr	11.0	10.4	9.4	10.4	12.0
PM/PM ₁₀ lb/hr	22.3	21.1	19.0	19.8	22.8
NO _x lb/hr	25.8	24.3	22.1	24.4	27.5
CO lb/hr	45.0	43.0	39.0	106.0	139.3
VOC (as methane) lb/hr	5.8	5.4	4.9	5.5	12.4
Sulfuric Acid Mist lb/hr	1.69	1.59	1.44	1.59	1.83
Mercury lb/hr	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
<u>75 Percent Load</u>					
Operating Data					
Temperature (°F)	200	200	200	-	-
Velocity (ft/sec)	54.8	52.8	50.2	-	-
Maximum Hourly Emissions per Unit ^b					
SO ₂ lb/hr	8.6	8.1	7.6	-	-
PM/PM ₁₀ lb/hr	19.0	18.2	16.9	-	-
NO _x lb/hr	20.1	19.0	17.7	-	-
CO lb/hr	35.0	33.0	31.0	-	-
VOC (as methane) lb/hr	8.4	7.9	7.4	-	-
Sulfuric Acid Mist lb/hr	1.31	1.25	1.16	-	-
Mercury lb/hr	0.00E+00	0.00E+00	0.00E+00	-	-
<u>60 Percent Load</u>					
Operating Data					
Temperature (°F)	200	200	200	-	-
Velocity (ft/sec)	45.9	44.5	42.5	-	-
Maximum Hourly Emissions per Unit ^b					
SO ₂ lb/hr	7.4	7.2	6.5	-	-
PM/PM ₁₀ lb/hr	16.0	15.4	14.3	-	-
NO _x lb/hr	17.4	16.8	15.2	-	-
CO lb/hr	152.0	146.0	133.0	-	-
VOC (as methane) lb/hr	7.3	7.0	6.3	-	-
Sulfuric Acid Mist lb/hr	1.14	1.10	1.00	-	-
Mercury lb/hr	0.00E+00	0.00E+00	0.00E+00	-	-

^a Refer to Appendix A for detailed information. Data at 100% load and duct firing for 95 °F are based on power augmentation with evaporative cooler on and operating at 95 percent efficiency. With evaporative cooler not operating, emissions are lower. Duct firing is assumed for 100% operating load. No duct firing is assumed for loads less than 100%.

^b Other regulated pollutants are assumed to have negligible emissions. These pollutants include lead, reduced sulfur compounds, hydrogen sulfide, fluorides, beryllium, arsenic, asbestos, vinyl chloride, and radionuclides.

See Appendix A for basis of pollutant emission rates and operating data.

Table 2-4 Summary of Maximum Potential Annual Emissions for the CT/HRSG, Duct Burner, and Cooling Tower

Pollutant	Load: Hours	Annual Emissions (tons/year) ^a					Maximum Emissions (tons/year) ^b				
		100%	75%	60%	Power Augmentation 100%	Duct Burner/ Power Augmentation 100%	Case A	Case B	Case C	Case D	Overall
		8,760	8,760	8,760	8,760	8,760 (@95 Deg. F)					
One Combustion Turbine- Combined Cycle											
SO _x	45.4	35.6	31.4	45.6	52.4	45.4	47.7	43.0	45.3	47.7	
PM/PM ₁₀	92.4	79.7	67.6	86.6	99.8	92.4	94.8	87.1	90.6	94.8	
NO _x	106	83	73	107	115	106.3	109.1	100.8	103.5	109.1	
CO	188	145	129	164	186	188.3	219.0	314.7	396.2	396.2	
VOC (as methane)	23.8	34.8	30.6	23.9	53.0	23.8	33.4	25.0	34.6	34.6	
Sulfuric Acid Mist	7.0	5.5	4.8	7.0	8.0	7.0	7.3	6.6	6.9	7.3	
Mercury	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
1,3-Butadiene	3.49E-03	2.74E-03	2.41E-03	3.50E-03	4.03E-03	3.49E-03	3.67E-03	3.31E-03	3.48E-03	3.67E-03	
Acetaldehyde	3.25E-01	2.55E-01	2.24E-01	3.26E-01	3.75E-01	3.25E-01	3.41E-01	3.06E-01	3.24E-01	3.41E-01	
Acrolein	5.19E-02	4.08E-02	3.59E-02	5.21E-02	5.99E-02	5.19E-02	5.46E-02	4.92E-02	5.18E-02	5.46E-02	
Benzene	9.74E-02	7.64E-02	6.73E-02	9.78E-02	1.12E-01	9.74E-02	1.02E-01	9.22E-02	9.72E-02	1.02E-01	
Ethylbenzene	2.60E-01	2.04E-01	1.79E-01	2.61E-01	3.00E-01	2.60E-01	2.73E-01	2.46E-01	2.59E-01	2.73E-01	
Formaldehyde	1.22E+00	9.56E-01	8.41E-01	1.22E+00	1.40E+00	1.22E+00	1.28E+00	1.15E+00	1.21E+00	1.28E+00	
Naphthalene	1.06E-02	8.28E-03	7.29E-03	1.06E-02	1.22E-02	1.06E-02	1.11E-02	1.00E-02	1.05E-02	1.11E-02	
Polycyclic Aromatic Hydrocarbons (PAH)	1.79E-02	1.40E-02	1.23E-02	1.79E-02	2.06E-02	1.79E-02	1.88E-02	1.69E-02	1.78E-02	1.88E-02	
Propylene Oxide	2.35E-01	1.85E-01	1.63E-01	2.36E-01	2.72E-01	2.35E-01	2.47E-01	2.23E-01	2.35E-01	2.47E-01	
Toluene	1.06E+00	8.28E-01	7.29E-01	1.06E+00	1.22E+00	1.06E+00	1.11E+00	1.00E+00	1.05E+00	1.11E+00	
Xylene	5.19E-01	4.08E-01	3.59E-01	5.21E-01	5.99E-01	5.19E-01	5.46E-01	4.92E-01	5.18E-01	5.46E-01	
Total HAPs	3.79E+00	2.98E+00	2.62E+00	3.81E+00	4.38E+00	3.79E+00	3.98E+00	3.59E+00	3.78E+00	3.98E+00	
Cooling Tower											
PM	4.3	4.3	4.3	4.3	4.3	4.3	4.3	4.3	4.3	4.3	
PM ₁₀	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	
Two Combustion Turbines- Combined Cycle											
SO _x	90.8	71.3	62.7	91.1	104.7	90.8	95.4	86.1	90.6	95.4	
PM/PM ₁₀	185	159	135	173	199.7	185	190	174	181	189.7	
NO _x	213	167	147	214	229.6	213	218	202	207	218.2	
CO	377	289	1,279	929	1,171.4	377	638	629	792	792.5	
VOC (as methane)	47.6	69.6	61.2	47.8	106.0	47.6	66.8	49.9	69.1	69.1	
Sulfuric Acid Mist	13.9	10.91	9.60	13.96	16.0	13.91	14.61	13.18	13.87	14.6	
Mercury	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	
1,3-Butadiene	6.98E-03	5.48E-03	4.82E-03	7.01E-03	8.05E-03	6.98E-03	7.33E-03	6.62E-03	6.96E-03	7.33E-03	
Acetaldehyde	6.49E-01	5.10E-01	4.49E-01	6.52E-01	7.49E-01	6.49E-01	6.82E-01	6.15E-01	6.48E-01	6.82E-01	
Acrolein	1.04E-01	8.15E-02	7.18E-02	1.04E-01	1.20E-01	1.04E-01	1.09E-01	9.85E-02	1.04E-01	1.09E-01	
Benzene	1.96E-01	1.53E-01	1.35E-01	1.96E-01	2.25E-01	1.96E-01	2.05E-01	1.85E-01	1.94E-01	2.05E-01	
Ethylbenzene	5.19E-01	4.08E-01	3.59E-01	5.21E-01	5.99E-01	5.19E-01	5.46E-01	4.92E-01	5.18E-01	5.46E-01	
Formaldehyde	2.43E+00	1.91E+00	1.68E+00	2.44E+00	2.81E+00	2.43E+00	2.56E+00	2.31E+00	2.43E+00	2.56E+00	
Naphthalene	2.11E-02	1.66E-02	1.46E-02	2.12E-02	2.43E-02	2.11E-02	2.22E-02	2.00E-02	2.11E-02	2.22E-02	
Polycyclic Aromatic Hydrocarbons (PAH)	3.57E-02	2.80E-02	2.47E-02	3.58E-02	4.12E-02	3.57E-02	3.75E-02	3.38E-02	3.56E-02	3.75E-02	
Propylene Oxide	4.71E-01	3.69E-01	3.25E-01	4.73E-01	5.43E-01	4.71E-01	4.95E-01	4.46E-01	4.70E-01	4.95E-01	
Toluene	2.11E+00	1.66E+00	1.46E+00	2.12E+00	2.43E+00	2.11E+00	2.22E+00	2.00E+00	2.11E+00	2.22E+00	
Xylene	1.04E+00	8.15E-01	7.18E-01	1.04E+00	1.20E+00	1.04E+00	1.09E+00	9.85E-01	1.04E+00	1.09E+00	
Total HAPs	7.59E+00	5.95E+00	5.24E+00	7.61E+00	8.75E+00	7.59E+00	7.97E+00	7.19E+00	7.57E+00	7.97E+00	
Two Combustion Turbines- Combined Cycle with Cooling Tower											
PM	193	168	144	182	208	193	198	183	190	198.3	
PM ₁₀	189	164	139	177	204	189	194	179	185	194.0	

^a Based on 59 °F ambient inlet air temperature except for power augmentation.

Power augmentation and duct firing will be used with CTs operating at 100 percent load, 95 °F ambient inlet air temperature, and evaporative cooler at 95% efficiency. With evaporative cooler not operating, emissions are lower.

^b Maximum emission cases:

Operation	Number of Hours for Operation			
	Case A	Case B	Case C	Case D
100 % Load	8,760	5,680	5,700	4,380
100 % Load with PA	0	0	1,560	0
100% Load with PA & Duct firing)	0	2,880	0	2,880
60% Load	0	0	1,500	1,500
Total hours	8,760	8,760	8,760	8,760

Table 2-5 Summary of Maximum Potential Annual Emissions for the Osprey Energy Center Power Project

Pollutant	Annual Emissions (tons/year)				TOTAL	PSD Significant Emission Rate (tons/year)
	2 CT/HRSG with Duct Burners	Cooling Tower	Emergency Gas-Fired Generator	Diesel Fire Pump		
SO ₂	95	--	0.006	0.056	95	40
PM	190	8.6	0.03	0.34	199	25
PM ₁₀	190	4.3	0.03	0.34	194	15
NO _x	218	--	3.8	4.8	227	40
CO	792	--	3.79	1.04	797	100
VOC (as methane)	69.1	--	0.09	0.38	70	40
Sulfuric Acid Mist	14.6	--	Neg.	Neg.	15	7
Mercury	0.0	--	Neg.	Neg.	0.0	0.1

Table A-2. Maximum Emissions for Criteria and Other Regulated Pollutants for the Osprey Energy Center Project
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 100 % Load including Power Augmentation (PA) and Duct Burner (DB)

Parameter	Ambient/Compressor Inlet Temperature						DUCT BURNER (Ambient Temperature)				
	32 °F Case 9	50 °F PA	59 °F Case 6	95 °F Case 3	95 °F Case 2	95 °F Case 1 (PA)	32 °F PA	59 °F Case 6 (DB)	95 °F Case 3 (DB)	95 °F Case 2 (DB)	95 °F Case 1 (DB&PA)
Hours of Operation	8,760	8,760	8,760	8,760	8,760	8,760	8,760	8,760	8,760	8,760	8,760
Particulate from CT and SCR											
Particulate from CT = Emission rate (lb/hr) from CT manufacturer (front- and back-burn)											
Basic, lb/hr - provided (a)	16.6	16.6	15.8	14.1	14.4	14.4	16.6	18.0	16.4	16.7	16.6
Particulate from SCR = Sulfur trioxide (formed from conversion of SO₂) converts to ammonium sulfate (=PM₁₀)											
Particulate from conversion of SO ₂ = SO ₂ emissions (lb/hr) × Conversion SO ₂ to SO ₃ × lb SO ₃ /lb SO ₂ × Conversion of SO ₃ to lb SO ₃ to (NH ₄) ₂ SO ₄ × (NH ₄) ₂ SO ₄ to lb SO ₃											
SO ₂ emission rate (lb/hr)-calculated	11.0	11.8	10.4	9.4	9.8	10.4	11.8	11.9	11.0	11.3	12.0
Conversion (%) from SO ₂ to SO ₃	25	25	25	25	25	25	25	25	25	25	25
MW SO ₂ /SO ₃ (88/66)	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3
Conversion (%) from SO ₃ to (NH ₄) ₂ SO ₄	100	100	100	100	100	100	100	100	100	100	100
MW (NH ₄) ₂ SO ₄ /SO ₃ (132/80)	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
Particulate (lb/hr)-calculated	5.68	6.08	5.35	4.86	5.03	5.36	6.08	6.15	5.66	5.86	6.17
Particulate (lb/hr) from CT + SCR (TPY)	22.3	22.7	21.1	19.0	19.5	19.8	22.7	24.1	22.0	22.5	22.8
SO ₂ Dioxide (lb/hr) = Natural gas (cf/hr) × sulfur content (gr/100 cf) × 1 lb SO ₂ /lb S /100											
Fuel use (cf/hr)	1,924,007	2,063,043	1,814,130	1,648,913	1,708,696	1,820,652	2,063,043	2,085,870	1,920,652	1,980,435	2,092,391
Sulfur content (grains/100 cf) - assumed (b)	2	2	2	2	2	2	2	2	2	2	2
lb SO ₂ /lb S (64/32)	2	2	2	2	2	2	2	2	2	2	2
Emission rate (lb/hr)-calculated	11.0	11.8	10.4	9.4	9.8	10.4	11.8	11.9	11.0	11.3	12.0
(lb/hr)-provided (0.2 gr/100 cf (not used) (TPY)	1.3	1.2	1.1	1.0	1.1	1.1	1.2	1.1	1.0	1.1	1.1
	48.3	51.6	45.4	41.3	42.8	45.6	51.6	52.3	48.1	49.6	52.4
Nitrogen Oxides (lb/hr) = NO_x(ppm) × [(20.9 × (1 - Moisture(%)/100) - Oxygen(%)) × 2116.8 × Volume flow (acfm) × 60 (min/hr) × 60 (min/hr) / (1545 × (CT temp.(°F) + 460°F) × 5.9 × 1,000,000 (adj. for ppm)]											
Basic, ppmvd @ 15% O ₂ (a) (d)	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5
Moisture (%)	7.92	13.11	8.44	10.62	11.08	15.81	13.96	9.40	11.45	12.08	16.73
Oxygen (%)	12.53	11.29	12.51	12.13	11.97	10.90	10.33	11.45	10.97	10.85	9.85
Volume Flow (acfm)	2,509,194	2,661,219	2,417,049	2,264,224	2,317,426	2,438,907	2,673,585	2,429,103	2,276,513	2,329,668	2,451,160
Temperature (°F)	1,088	1,108	1,102	1,133	1,126	1,125	1,108	1,102	1,133	1,126	1,125
Emission rate (lb/hr)-calculated	24.4	26.2	23.0	20.9	21.7	23.1	29.3	26.1	24.0	24.8	26.2
(lb/hr)-provided	25.8	27.6	24.3	22.1	22.9	24.4	30.7	27.4	25.2	26.0	27.5
(TPY)	112.9	120.8	106.3	96.6	100.2	106.8	134.5	114.4	105.2	108.5	114.8
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056	1.056	1.056	1.056	1.049	1.049	1.049	1.049	1.049
Carbon Monoxide (lb/hr) = CO(ppm) × [(20.9 × (1 - Moisture(%)/100) - Oxygen(%)) × 2116.8 × Volume flow (acfm) × 60 (min/hr) × 60 (min/hr) / (1545 × (CT temp.(°F) + 460°F) × 5.9 × 1,000,000 (adj. for ppm)]											
Basic, ppmvd -calculated	12.4	33.5	12.3	12.4	12.6	42	37.7	22.6	24.0	23.9	45.1
Basic, ppmvd @ 15% O ₂ -calculated	10	25	10	10	10	31	25	16	17	16	29
- provided (a)	10	25	10	10	10	25	25				
Moisture (%)	7.92	13.11	8.44	10.62	11.08	15.81	13.96	9.40	11.45	12.08	16.73
Oxygen (%)	12.53	11.29	12.51	12.13	11.97	10.90	10.33	11.45	10.97	10.85	9.85
Volume Flow (acfm)	2,509,194	2,661,219	2,417,049	2,264,224	2,317,426	2,438,907	2,673,585	2,429,103	2,276,513	2,329,668	2,451,160
Temperature (°F)	1,088	1,108	1,102	1,133	1,126	1,125	1,108	1,102	1,133	1,126	1,125
Emission rate (lb/hr)-calculated from given ppmvd	42.4	113.7	40.0	36.3	37.7	100.4	127.3	73.3	69.7	71.0	133.7
(lb/hr)-provided	45.0	120.0	43.0	39.0	40.0	106.0	120.0	76.3	72.3	73.3	139.3
(TPY)	197.1	525.6	182.3	170.8	175.2	444.3	525.6	321.0	305.1	310.9	585.7
[Ratio lb/hr provided/calculated]	1.060	1.055	1.076	1.073	1.082	1.056	0.942	1.041	1.038	1.033	1.062
VOCs (lb/hr) = VOC(ppm) × [(1 - Moisture(%)/100) × 2116.8 × Volume flow (acfm) × 60 (min/hr) × 60 (min/hr) / (1545 × (CT temp.(°F) + 460°F) × 5.9 × 1,000,000 (adj. for ppm)]											
Basic, ppmvd (as CH ₄)-calculated	2.8	3.0	2.8	2.8	2.8	3.0	3.4	6.5	7.0	6.9	7.1
Basic, ppmvd @ 15% O ₂ -calculated	2.3	2.3	2.3	2.3	2.3	2.3	2.3	4.7	4.9	4.8	4.6
- provided (a)	2.3	2.3	2.3	2.3	2.3	2.3	2.3				
Moisture (%)	7.92	13.11	8.44	10.62	11.08	15.81	13.96	9.40	11.45	12.08	16.73
Oxygen (%)	12.53	11.29	12.51	12.13	11.97	10.90	10.33	11.45	10.97	10.85	9.85
Volume Flow (acfm)	2,509,194	2,661,219	2,417,049	2,264,224	2,317,426	2,438,907	2,673,585	2,429,103	2,276,513	2,329,668	2,451,160
Temperature (°F)	1,088	1,108	1,102	1,133	1,126	1,125	1,108	1,102	1,133	1,126	1,125
Emission rate (lb/hr)-calculated	5.5	5.8	5.1	4.7	4.8	5.2	6.5	12.1	11.6	11.8	12.1
(lb/hr)-provided	5.8	6.2	5.4	4.9	5.1	5.5	6.2	12.4	11.9	12.1	12.4
(TPY)	25.2	26.9	23.8	21.6	22.4	23.9	26.9	52.9	50.9	51.6	53.0
[Ratio lb/hr provided/calculated]	1.056	1.052	1.056	1.056	1.056	1.056	0.939	1.024	1.023	1.023	1.024
Lead (lb/hr) = NA											
Emission Rate Basic (a)	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Emission rate (lb/hr) (TPY)	0	0	0	0	0	0	0	0	0	0	0
Mercury (lb/hr) = NA											
Emission Rate Basic (a)	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Emission Rate (lb/hr) (TPY)	0	0	0	0	0	0	0	0	0	0	0
Sulfuric Acid Mist = SO₂ emission rate (lb/hr) × conversion rate of SO₂ to H₂SO₄ (%) × MW H₂SO₄/MW SO₂ (98/66)											
SO ₂ emission rate (lb/hr)	11.0	11.8	10.4	9.4	9.8	10.4	11.8	11.9	11.0	11.3	12.0
lb H ₂ SO ₄ /lb SO ₂ (98/66)	1.53	1.53	1.53	1.53	1.53	1.53	1.53	1.53	1.53	1.53	1.53
Conversion to H ₂ SO ₄ (%) (b)	10	10	10	10	10	10	10	10	10	10	10
Emission Rate (lb/hr) (TPY)	1.69	1.81	1.59	1.44	1.50	1.59	1.81	1.83	1.66	1.73	1.83
	7.38	7.91	6.95	6.32	6.55	6.98	7.91	7.99	7.36	7.59	8.02

Source: (a) Siemens-Westinghouse 1998.

(b) Colburn Associates Inc. 1999.

(c) EPA 2003, AP-42.

(d) For NO_x emissions, data originally provided at 25 ppmvd at 15% oxygen.

(e) For VOC emissions, data originally provided at 1.5 ppmvd at 15% oxygen.

Note: ppmvd = parts per million, volume dry; O₂ = oxygen.

Table A-3. Maximum Emissions for Hazardous Air Pollutants for the Osprey Energy Center Project
Stations: Wastehouse 501F, Dry Low NOx Combustor, Natural Gas, 100 % Load including Power Augmentation (PA) and Duct Burner (DB)

Parameter	32 °F Case 9	Ambient/Compressor Inlet Temperature				DUCT BURNER (Ambient Temperature)			
		59 °F Case 6	95 °F Case 3	95 °F Case 2	95 °F Case 1 (PA)	59 °F Case 6 (DB)	95 °F Case 3 (DB)	95 °F Case 2 (DB)	95 °F Case 1 (DB&PA)
Hours of Operation	8,760	8,760	8,760	8,760	8,760	8,760	8,760	8,760	8,760
Heat Input Rate (MMBtu/hr), DBIV: CT	1,968	1,853	1,684	1,746	1,860	1,853	1,684	1,746	1,860
Duct burner	0	0	0	0	0	278	278	278	278
Total	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
$\text{Ammonia (lb/hr)} = \text{Ammonia (ppm)} \times (20.9 \times (1 - \text{Moisture (\%)/100}) \cdot \text{Oxygen (K)} \times 2116.8 \times \text{Volume flow (acfm)} \times 17 \text{ (mole wt ammonia)} \times 60 \text{ min/hr} / (1545 \times (\text{CT temp (°F)} + 460\text{°F})) \times 5.9 \times 1,000,000 \text{ (adj. for ppm)}$									
Basis, ppmvd @ 15% O ₂ (a) (d)	9	9	9	9	9	9	9	9	9
Moisture (%)	7.92	8.44	10.62	11.08	15.81	9.40	11.45	12.08	16.73
Oxygen (%)	12.53	12.51	12.13	11.97	10.90	11.45	10.97	10.85	9.85
Volume Flow (acfm)	2,509,194	2,417,049	2,264,224	2,317,426	2,438,907	2,429,103	2,276,513	2,329,668	2,451,140
Temperature (°F)	1,088	1,102	1,133	1,126	1,125	1,102	1,133	1,124	1,125
Emission rate (lb/hr)	23.2	21.8	19.9	20.6	21.9	24.8	23.8	23.6	24.9
(TPY)	102	96	87	90	96	109	100	100	109
$1,3\text{-Butadiene (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	4.30E-01	4.30E-01	4.30E-01	4.30E-01	4.30E-01	4.30E-01	4.30E-01	4.30E-01	4.30E-01
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	8.46E-04	7.97E-04	7.24E-04	7.51E-04	8.00E-04	9.16E-04	8.43E-04	8.70E-04	9.19E-04
(TPY)	3.71E-03	3.49E-03	3.17E-03	3.29E-03	3.50E-03	4.01E-03	3.69E-03	3.81E-03	4.03E-03
$\text{Acetaldehyde (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01	4.00E-01
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	7.87E-02	7.41E-02	6.74E-02	6.98E-02	7.44E-02	8.52E-02	7.85E-02	8.09E-02	8.55E-02
(TPY)	3.45E-01	3.25E-01	2.95E-01	3.06E-01	3.26E-01	3.73E-01	3.44E-01	3.55E-01	3.75E-01
$\text{Acrolein (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	6.40E+00	6.40E+00	6.40E+00	6.40E+00	6.40E+00	6.40E+00	6.40E+00	6.40E+00	6.40E+00
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	1.26E-02	1.19E-02	1.08E-02	1.12E-02	1.19E-02	1.36E-02	1.26E-02	1.30E-02	1.37E-02
(TPY)	5.52E-02	5.19E-02	4.72E-02	4.89E-02	5.21E-02	5.97E-02	5.50E-02	5.67E-02	5.99E-02
$\text{Benzene (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	1.20E+01	1.20E+01	1.20E+01	1.20E+01	1.20E+01	1.20E+01	1.20E+01	1.20E+01	1.20E+01
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	2.36E-02	2.22E-02	2.02E-02	2.10E-02	2.23E-02	2.56E-02	2.35E-02	2.43E-02	2.57E-02
(TPY)	1.03E-01	9.74E-02	8.85E-02	9.18E-02	9.78E-02	1.12E-01	1.03E-01	1.06E-01	1.12E-01
$\text{Ethylbenzene (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	3.20E+01	3.20E+01	3.20E+01	3.20E+01	3.20E+01	3.20E+01	3.20E+01	3.20E+01	3.20E+01
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	6.30E-02	5.93E-02	5.39E-02	5.59E-02	5.95E-02	6.82E-02	6.38E-02	6.64E-02	6.94E-02
(TPY)	2.76E-01	2.60E-01	2.36E-01	2.45E-01	2.61E-01	2.99E-01	2.75E-01	2.84E-01	3.00E-01
$\text{Formaldehyde (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	1.50E+02	1.50E+02	1.50E+02	1.50E+02	1.50E+02	1.50E+02	1.50E+02	1.50E+02	1.50E+02
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	2.95E-01	2.78E-01	2.53E-01	2.62E-01	2.79E-01	3.20E-01	2.94E-01	3.04E-01	3.21E-01
(TPY)	1.29E+00	1.22E+00	1.11E+00	1.15E+00	1.22E+00	1.40E+00	1.29E+00	1.33E+00	1.40E+00
$\text{Naphthalene (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	1.30E+00	1.30E+00	1.30E+00	1.30E+00	1.30E+00	1.30E+00	1.30E+00	1.30E+00	1.30E+00
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	2.54E-03	2.41E-03	2.19E-03	2.27E-03	2.42E-03	2.77E-03	2.56E-03	2.63E-03	2.78E-03
(TPY)	1.12E-02	1.06E-02	9.59E-03	9.94E-03	1.06E-02	1.21E-02	1.12E-02	1.15E-02	1.22E-02
$\text{Polycyclic Aromatic Hydrocarbons (PAH) (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	2.20E+00	2.20E+00	2.20E+00	2.20E+00	2.20E+00	2.20E+00	2.20E+00	2.20E+00	2.20E+00
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	4.33E-03	4.08E-03	3.70E-03	3.84E-03	4.09E-03	4.69E-03	4.32E-03	4.45E-03	4.70E-03
(TPY)	1.90E-02	1.79E-02	1.62E-02	1.68E-02	1.79E-02	2.05E-02	1.89E-02	1.95E-02	2.06E-02
$\text{Propylene Oxide (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	2.90E+01	2.90E+01	2.90E+01	2.90E+01	2.90E+01	2.90E+01	2.90E+01	2.90E+01	2.90E+01
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	5.71E-02	5.37E-02	4.88E-02	5.06E-02	5.39E-02	6.18E-02	5.69E-02	5.87E-02	6.20E-02
(TPY)	2.50E-01	2.35E-01	2.14E-01	2.22E-01	2.36E-01	2.71E-01	2.49E-01	2.57E-01	2.72E-01
$\text{Toluene (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	1.30E+02	1.30E+02	1.30E+02	1.30E+02	1.30E+02	1.30E+02	1.30E+02	1.30E+02	1.30E+02
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	2.56E-01	2.41E-01	2.19E-01	2.27E-01	2.42E-01	2.77E-01	2.56E-01	2.63E-01	2.78E-01
(TPY)	1.12E+00	1.06E+00	9.59E-01	9.94E-01	1.06E+00	1.21E+00	1.12E+00	1.15E+00	1.22E+00
$\text{Xylenes (lb/hr)} = \text{Basis (lb/10}^3 \text{ Btu)} \times \text{Heat Input (MMBtu/hr)} / 1,000,000 \text{ MMBtu/10}^3 \text{ Btu}$									
Basis, lb/10 ³ Btu	6.40E+01	6.40E+01	6.40E+01	6.40E+01	6.40E+01	6.40E+01	6.40E+01	6.40E+01	6.40E+01
Heat Input Rate (MMBtu/hr)	1,968	1,853	1,684	1,746	1,860	2,131	1,962	2,024	2,138
Emission Rate (lb/hr)	1.26E-01	1.19E-01	1.08E-01	1.12E-01	1.19E-01	1.36E-01	1.26E-01	1.30E-01	1.37E-01
(TPY)	5.52E-01	5.19E-01	4.72E-01	4.89E-01	5.21E-01	5.97E-01	5.50E-01	5.67E-01	5.99E-01

Source: EPA, 2002, AP-42.

Table A-5. Maximum Emissions for Criteria and Other Regulated Pollutants for the Oprey Energy Center Project
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 75 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 10	59 °F Case 7	95 °F Case 4
Hours of Operation	8,760	8,760	8,760
Particulate from CT and SCR			
Particulate (lb/hr) = Emission rate (lb/hr) from manufacturer (front- and back-half)			
Basin lb/hr - provided (a)	14.6	14.0	13.0
Particulate from SCR = Sulfur trioxide (formed from conversion of SO ₂) converts to ammonium sulfate (=PM10)			
Particulate from conversion of SO ₂ = SO ₂ emissions (lb/hr) × Conversion SO ₂ to SO ₃ × lb SO ₃ /lb SO ₂ × Conversion of SO ₃ × lb SO ₃ to (NH ₄) ₂ SO ₄ × (NH ₄) ₂ SO ₄ / lb SO ₃			
SO ₂ emission rate (lb/hr) - calculated	8.6	8.1	7.6
Conversion (%) from SO ₂ to SO ₃	25	25	25
MW SO ₂ /SO ₃ (80/64)	1.3	1.3	1.3
Conversion (%) from SO ₃ to (NH ₄) ₂ SO ₄	100	100	100
MW (NH ₄) ₂ SO ₄ /SO ₃ (132/80)	1.7	1.7	1.7
Particulate (lb/hr) - calculated	4.42	4.19	3.89
Particulate (lb/hr) from CT + SCR	19.0	18.2	16.9
(TPY)	83.3	79.7	73.9
Sulfur Dioxide (lb/hr) = Natural gas (cf/hr) × sulfur content (gr/100 cf) × 1 lb/7000 gr × (lb SO ₂ /lb S) / 100			
Fuel use (cf/hr)	1,501,214	1,423,626	1,321,928
Sulfur content (grains/ 100 cf) - assumed (b)	2	2	2
lb SO ₂ /lb S (64/32)	2	2	2
Emission rate (lb/hr) - calculated	8.6	8.1	7.6
(lb/hr) - provided (0.2 gr/100 cf) (not used)	0.93	0.89	0.82
(TPY)	37.6	35.6	33.1
Nitrogen Oxide (lb/hr) = NOx(ppm) × [(20.9 × (1 - Moisture(%) / 100) - Oxygen(%)) × 2116.8 × Volume flow (acfm) × 46 (mole. wt. NOx) × 60 min/hr / (1545 × (CT temp.(°F) + 460°F) × 5.9 × 1,000,000 (adj. for ppm))]			
Basin ppmvd @ 15% O ₂ (a) (d)	3.5	3.5	3.5
Moisture (%)	7.12	7.64	9.76
Oxygen (%)	13.42	13.41	13.10
Volume Flow (acfm)	2,058,955	2,005,603	1,947,155
Temperature (°F)	998	1,013	1,045
Emission rate (lb/hr) - calculated	19.0	18.0	16.7
(lb/hr) - provided	20.1	19.0	17.7
(TPY)	87.9	83.3	77.4
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056
Carbon Monoxide (lb/hr) = CO(ppm) × [(20.9 × (1 - Moisture(%) / 100) - Oxygen(%)) × 2116.8 lb/lb × Volume flow (acfm) × 28 (mole. wt. CO) × 60 min/hr / (1545 × (CT temp.(°F) + 460°F) × 1,000,000 (adj. for ppm))]			
Basin ppmvd - calculated	10.9	10.8	10.8
Basin ppmvd @ 15% O ₂ - calculated	10	10	10
- provided (a)	10	10	10
Moisture (%)	7.12	7.64	9.76
Oxygen (%)	13.42	13.41	13.10
Volume Flow (acfm)	2,058,955	2,005,603	1,947,155
Temperature (°F)	998	1,013	1,045
Emission rate (lb/hr) - calculated from given ppmv	33.0	31.3	29.1
(lb/hr) - provided	35.0	33.0	31.0
(TPY)	153.3	144.5	135.8
[Ratio lb/hr provided/calculated]	1.059	1.053	1.065
VOCs (lb/hr) = VOC(ppm) × [(1 - Moisture(%) / 100) × 2116.8 lb/lb × Volume flow (acfm) × 16 (mole. wt. as methane) × 60 min/hr / (1545 × (CT temp.(°F) + 460°F) × 1,000,000 (adj. for ppm))]			
Basin ppmvd (as CH ₄) - calculated	4.6	4.5	4.5
Basin ppmvd @ 15% O ₂ - calculated	4.2	4.2	4.2
- provided (a) (e)	4.2	4.2	4.2
Moisture (%)	7.12	7.64	9.76
Oxygen (%)	13.42	13.41	13.10
Volume Flow (acfm)	2,058,955	2,005,603	1,947,155
Temperature (°F)	998	1,013	1,045
Emission rate (lb/hr) - calculated	7.9	7.5	7.0
(lb/hr) - provided	8.4	7.9	7.4
(TPY)	36.7	34.8	32.3
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056
Lead (lb/hr) = NA			
Emission Rate Basin (c)	NA	NA	NA
Emission rate (lb/hr)	0	0	0
(TPY)	0	0	0
Mercury (lb/hr) = NA			
Emission Rate Basin (c)	NA	NA	NA
Emission rate (lb/hr)	0	0	0
(TPY)	0	0	0
Sulfuric Acid Mist = SO ₂ emission rate (lb/hr) × conversion rate of SO ₂ to H ₂ SO ₄ (%) × MW H ₂ SO ₄ /MW SO ₂ (98/64)			
SO ₂ emission rate (lb/hr)	8.6	8.1	7.6
lb H ₂ SO ₄ /lb SO ₂ (98/64)	1.53	1.53	1.53
Conversion to H ₂ SO ₄ (%) (b)	10	10	10
Emission Rate (lb/hr)	1.31	1.25	1.16
(TPY)	5.75	5.46	5.07

Source: (a) Siemens-Westinghouse 1999.

(b) Golder Associates Inc. 1999.

(c) EPA 2000, AP-42.

(d) For NOx emissions, data originally provided at 25 ppmvd at 15% oxygen.

(e) For VOC emissions, data originally provided at 2.6 ppmvd at 15% oxygen.

Note: ppmvd = parts per million, volume dry; O₂ = oxygen.

Table A-6. Maximum Emissions for Hazardous Air Pollutants for the Osprey Energy Center Project
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 75 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 10	59 °F Case 7	96 °F Case 4
Hours of Operation	8,760	8,760	8,760
Heat Input Rate (MMBtu/hr), HHV- CT	1,534	1,454	1,351
Duct burner	0	0	0
Total	1,534	1,454	1,351
Ammonia (lb/hr) = Ammonia (ppm) x ([20.9 x (1 - Moisture(%)/100)] - Oxygen(%)) x 2116.8 x Volume flow (acfm) x 17 (mole. wgt ammonia) x 60 min/hr / [1545 x (CT temp (°F) + 460°F) x 5.9 x 1,000,000 (adj. for ppm)]			
Basis, ppmvd @15% O ₂ (a) (d)	9	9	9
Moisture (%)	7.12	7.64	9.76
Oxygen (%)	13.42	13.41	13.10
Volume Flow (acfm)	2,054,956	2,005,603	1,947,155
Temperature (°F)	998	1,013	1,045
Emission rate (lb/hr)	18.1	17.1	15.9
(TPY)	79	75	70
1,3- Butadiene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	4.30E-01	4.30E-01	4.30E-01
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	6.59E-04	6.25E-04	5.81E-04
(TPY)	2.89E-03	2.74E-03	2.54E-03
Acetaldehyde (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	4.00E+01	4.00E+01	4.00E+01
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	6.13E-02	5.82E-02	5.40E-02
(TPY)	2.69E-01	2.55E-01	2.37E-01
Acrolein (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	6.40E+00	6.40E+00	6.40E+00
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	9.82E-03	9.31E-03	8.64E-03
(TPY)	4.30E-02	4.08E-02	3.79E-02
Benzene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	1.20E+01	1.20E+01	1.20E+01
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	1.84E-02	1.75E-02	1.62E-02
(TPY)	8.06E-02	7.64E-02	7.10E-02
Ethylbenzene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	3.20E+01	3.20E+01	3.20E+01
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	4.91E-02	4.65E-02	4.32E-02
(TPY)	2.15E-01	2.04E-01	1.89E-01
Formaldehyde (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	1.50E+02	1.50E+02	1.50E+02
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	2.30E-01	2.18E-01	2.03E-01
(TPY)	1.01E+00	9.56E-01	8.87E-01
Naphthalene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	1.30E+00	1.30E+00	1.30E+00
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	1.99E-03	1.89E-03	1.76E-03
(TPY)	8.73E-03	8.28E-03	7.69E-03
Polycyclic Aromatic Hydrocarbons (PAH) (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	2.20E+00	2.20E+00	2.20E+00
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	3.37E-03	3.20E-03	2.97E-03
(TPY)	1.48E-02	1.40E-02	1.30E-02
Propylene Oxide (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	2.90E+01	2.90E+01	2.90E+01
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	4.45E-02	4.22E-02	3.92E-02
(TPY)	1.95E-01	1.85E-01	1.72E-01
Toluene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	1.30E+02	1.30E+02	1.30E+02
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	1.99E-01	1.89E-01	1.76E-01
(TPY)	8.73E-01	8.28E-01	7.69E-01
Xylene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	6.40E+01	6.40E+01	6.40E+01
Heat Input Rate (MMBtu/hr)	1,534	1,454	1,351
Emission Rate (lb/hr)	9.82E-02	9.31E-02	8.64E-02
(TPY)	4.30E-01	4.08E-01	3.79E-01

Source: EPA, 2000, AP-42.

Table A-8. Maximum Emissions for Criteria and Other Regulated Pollutants for the Osprey Energy Center Project
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 60 % Load

Parameter	Ambient/Compressor Inlet Temperature		
	32 °F Case 11	59 °F Case 8	95 °F Case 5
Hours of Operation	8,760	8,760	8,760
Particulate from CT and SCR			
Particulate (lb/hr) - Emission rate (lb/hr) from manufacturer (front- and back-hall)			
Basic, lb/hr (a)	13.2	11.7	11.0
Particulate from SCR - Sulfur trioxide (formed from conversion of SO ₂) converts to ammonium sulfate (=PM10)			
Particulate from conversion of SO ₂ = SO ₂ emissions (lb/hr) x Conversion SO ₂ to SO ₃ x lb SO ₃ /lb SO ₂ x Conversion of SO ₂ x lb SO ₃ to (NH ₄) ₂ SO ₄ x (NH ₄) ₂ SO ₄ /lb SO ₃			
SO ₂ emission rate (lb/hr) - calculated	7.4	7.2	6.5
Conversion (%) from SO ₂ to SO ₃	25	25	25
lb SO ₃ /lb SO ₂ (80/64)	1.3	1.3	1.3
lb (NH ₄) ₂ SO ₄ /lb SO ₃ (132/68)	100	100	100
Particulate (lb/hr) - calculated	3.84	3.69	3.35
Particulate (lb/hr) from CT + SCR	14.0	15.4	14.3
(TPV)	70.2	67.6	62.8
Sulfur Dioxide (lb/hr) = Natural gas (cf/hr) x sulfur content (gr/100 cf) x 1 lb/7000 gr x (lb SO ₂ /lb S) / 100			
Fuel use (cf/hr)	1,303,411	1,252,999	1,137,756
Sulfur content (grains/100 cf) - assumed (b)	2	2	2
lb SO ₂ /lb S (64/32)	2	2	2
Emission rate (lb/hr) - calculated	7.4	7.2	6.5
(lb/hr) - provided (0.2 gr/100 cf) (not used)	0.81	0.78	0.71
(TPV)	32.6	31.4	28.5
Nitrogen Oxides (lb/hr) = NOx(ppm) x [(20.9 x (1 - Moisture(%)/100)) - Oxygen(%)] x 2116.8 x Volume flow (acfm) x 46 (mole. wt. NOx) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 5.9 x 1,000,000 (adj. for ppm)]			
Basic, ppmvd @ 15% O ₂ (a) (d)	3.5	3.5	3.5
Moisture (%)	7.36	7.94	9.86
Oxygen (%)	13.15	13.07	12.99
Volume flow (acfm)	1,817,013	1,795,882	1,703,893
Temperature (°F)	1,076	1,107	1,094
Emission rate (lb/hr) - calculated	16.5	15.9	14.4
(lb/hr) - provided	17.4	16.8	15.2
(TPV)	74.3	73.4	66.6
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056
Carbon Monoxide (lb/hr) = CO(ppm) x [(20.9 x (1 - Moisture(%)/100)) - Oxygen(%)] x 2116.8 lb/ft ³ x Volume flow (acfm) x 28 (mole. wt. CO) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 5.9 x 1,000,000 (adj. for ppm)]			
Basic, ppmvd - calculated	56.8	56.8	55.0
Basic, ppmvd @ 15% O ₂ - calculated	50	50	50
- provided (a)	50	50	50
Moisture (%)	7.36	7.94	9.86
Oxygen (%)	13.15	13.07	12.99
Volume flow (acfm)	1,817,013	1,795,882	1,703,893
Temperature (°F)	1,076	1,107	1,094
Emission rate (lb/hr) - calculated from given ppmvd	143.4	137.9	125.2
(lb/hr) - provided	152.0	146.0	133.0
(TPV)	665.8	639.5	582.5
[Ratio lb/hr provided/calculated]	1.060	1.058	1.062
VOCs (lb/hr) = VOC(ppm) x [1 - Moisture(%)/100] x 2116.8 lb/ft ³ x Volume flow (acfm) x 16 (mole. wt. as methane) x 60 min/hr / [1545 x (CT temp.(°F) + 460°F) x 5.9 x 1,000,000 (adj. for ppm)]			
Basic, ppmvd (as CH ₄) - calculated	4.8	4.8	4.6
Basic, ppmvd @ 15% O ₂ - calculated	4.2	4.2	4.2
- provided (a) (e)	4.2	4.2	4.2
Moisture (%)	7.36	7.94	9.86
Oxygen (%)	13.15	13.07	12.99
Volume flow (acfm)	1,817,013	1,795,882	1,703,893
Temperature (°F)	1,076	1,107	1,094
Emission rate (lb/hr) - calculated	6.9	6.6	6.0
(lb/hr) - provided	7.3	7.0	6.3
(TPV)	31.8	30.6	27.8
[Ratio lb/hr provided/calculated]	1.056	1.056	1.056
Lead (lb/hr) = NA			
Emission Rate Basis (g)	NA	NA	NA
Emission rate (lb/hr)	0	0	0
(TPV)	0	0	0
Mercury (lb/hr) = NA			
Emission Rate Basis (g)	NA	NA	NA
Emission rate (lb/hr)	0	0	0
(TPV)	0	0	0
Sulfuric Acid Mist = SO ₂ emission rate (lb/hr) x conversion rate of SO ₂ to H ₂ SO ₄ (%) x MW H ₂ SO ₄ /MW SO ₂ (98/64)			
SO ₂ emission rate (lb/hr)	7.4	7.2	6.5
lb H ₂ SO ₄ /lb SO ₂ (98/64)	1.53	1.53	1.53
Conversion to H ₂ SO ₄ (%) (b)	10	10	10
Emission rate (lb/hr)	1.14	1.10	1.00
(TPV)	5.00	4.80	4.36

Source: (a) Siemens-Westinghouse 1999.

(b) Golden Associates Inc. 1999.

(c) EPA 2003, AP-42.

(d) For NOx emissions, data originally provided at 25 ppmvd at 15% oxygen.

(e) For VOC emissions, data originally provided at 2.8 ppmvd at 15% oxygen.

Note: ppmvd = parts per million, volume dry; O₂ = oxygen.

Table A-9 Maximum Emissions for Hazardous Air Pollutants for the Osprey Energy Center Project
Siemens-Westinghouse 501F, Dry Low NOx Combustor, Natural Gas, 60 % Load

Parameter	Ambient/Compressor Inlet Temperature		95 °F Case 5
	32 °F Case 11	59 °F Case 8	
Hours of Operation	8,760	8,760	8,760
Heat Input Rate (MMBtu/hr), HHV- CT	1,332	1,280	1,162
Duct burner	0	0	0
Total	1,332	1,280	1,162
$\text{Ammonia (lb/hr)} = \text{Ammonia (ppm)} \times \left(\frac{20.9 \times (1 - \text{Moisture}(\%)/100)}{100} - \text{Oxygen}(\%) \right) \times 2116.8 \times \text{Volume flow (acfm)} \times 17 \text{ (mole. wgt ammonia)} \times 60 \text{ min/hr} / (1545 \times (\text{CT temp.}(\text{°F}) + 460\text{°F}) \times 5.9 \times 1,000,000 \text{ (adj. for ppm)})$			
Basis, ppmvd @15% O ₂ (a) (d)	9	9	9
Moisture (%)	7.36	7.94	9.86
Oxygen (%)	13.15	13.07	12.99
Volume Flow (acfm)	1,817,013	1,795,882	1,703,893
Temperature (°F)	1,076	1,107	1,094
Emission rate (lb/hr) (TPY)	15.7 69	15.1 66	13.7 60
1,3- Butadiene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	4.30E-01	4.30E-01	4.30E-01
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	5.73E-04 2.51E-03	5.50E-04 2.41E-03	5.00E-04 2.19E-03
Acetaldehyde (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	4.00E+01	4.00E+01	4.00E+01
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	5.33E-02 2.33E-01	5.12E-02 2.24E-01	4.65E-02 2.04E-01
Acrolein (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	6.40E+00	6.40E+00	6.40E+00
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	8.52E-03 3.73E-02	8.19E-03 3.59E-02	7.44E-03 3.26E-02
Benzene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	1.20E+01	1.20E+01	1.20E+01
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	1.60E-02 7.00E-02	1.54E-02 6.73E-02	1.39E-02 6.11E-02
Ethylbenzene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	3.20E+01	3.20E+01	3.20E+01
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	4.26E-02 1.87E-01	4.10E-02 1.79E-01	3.72E-02 1.63E-01
Formaldehyde (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	1.50E+02	1.50E+02	1.50E+02
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	2.00E-01 8.75E-01	1.92E-01 8.41E-01	1.74E-01 7.64E-01
Naphthalene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	1.30E+00	1.30E+00	1.30E+00
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	1.73E-03 7.58E-03	1.66E-03 7.29E-03	1.51E-03 6.62E-03
Polycyclic Aromatic Hydrocarbons (PAH) (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	2.20E+00	2.20E+00	2.20E+00
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	2.93E-03 1.28E-02	2.82E-03 1.23E-02	2.56E-03 1.12E-02
Propylene Oxide (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	2.90E+01	2.90E+01	2.90E+01
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	3.86E-02 1.69E-01	3.71E-02 1.63E-01	3.37E-02 1.48E-01
Toluene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	1.30E+02	1.30E+02	1.30E+02
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	1.73E-01 7.58E-01	1.66E-01 7.29E-01	1.51E-01 6.62E-01
Xylene (lb/hr) = Basis (lb/10 ¹² Btu) x Heat Input (MMBtu/hr) / 1,000,000 MMBtu/10 ¹² Btu			
Basis, lb/10 ¹² Btu	6.40E+01	6.40E+01	6.40E+01
Heat Input Rate (MMBtu/hr)	1,332	1,280	1,162
Emission Rate (lb/hr) (TPY)	8.52E-02 3.73E-01	8.19E-02 3.59E-01	7.44E-02 3.26E-01

Source: EPA, 2000, AP-42.

Table B-3a. Capital Cost for Selective Catalytic Reduction and SCONOXTM for the Siemens Westinghouse 501FD Combined Cycle Combustion Turbine

Cost Component	Costs for SCR	Costs for SCONOX TM	Basis of Cost Component
<u>Direct Capital Costs</u>			
Pollution Control Equipment	\$1,418,000	\$16,712,000	Vendor Estimates
Ammonia Storage Tank	\$137,529	\$0	\$35 per 1,000 lb mass flow developed from vendor quotes
Flue Gas Ductwork	\$44,505	\$69,725	Vatavauk, 1990
Instrumentation	\$50,000	\$50,000	Additional NO _x Monitor and System
Taxes	\$85,080	\$1,002,720	6% of SCR Associated Equipment and Catalyst
Freight	\$70,900	\$835,600	5% of SCR Associated Equipment
Total Direct Capital Costs (TDCC)	\$1,806,014	\$18,670,045	
<u>Direct Installation Costs</u>			
Foundation and supports	\$144,481	1,493,604	8% of TDCC and RCC; OAQPS Cost Control Manual
Handling & Erection	\$252,842	2,613,806	14% of TDCC and RCC; OAQPS Cost Control Manual
Electrical	\$72,241	746,802	4% of TDCC and RCC; OAQPS Cost Control Manual
Piping	\$36,120	373,401	2% of TDCC and RCC; OAQPS Cost Control Manual
Insulation for ductwork	\$18,060	186,700	1% of TDCC and RCC; OAQPS Cost Control Manual
Painting	\$18,060	186,700	1% of TDCC and RCC; OAQPS Cost Control Manual
Site Preparation	\$5,000	\$5,000	Engineering Estimate
Buildings	\$15,000	\$15,000	Engineering Estimate
Total Direct Installation Costs (TDIC)	\$561,804	\$5,621,014	
Total Capital Costs (TCC)	\$2,367,819	\$24,291,059	Sum of TDCC, TDIC and RCC
<u>Indirect Costs</u>			
Engineering	\$180,601	\$1,867,005	10% of Total Direct Capital Costs; OAQPS Cost Control Manual
PSM/RMP Plan	\$50,000	\$0	Engineering Estimate
Construction and Field Expense	\$90,301	\$933,502	5% of TDCC; OAQPS Cost Control Manual
Contractor Fees	\$180,601	\$1,867,005	10% of TDCC; OAQPS Cost Control Manual
Start-up	\$36,120	\$373,401	2% of TDCC; OAQPS Cost Control Manual
Performance Tests	\$18,060	\$186,700	1% of TDCC; OAQPS Cost Control Manual
Contingencies	\$54,180	\$560,101	3% of TDCC; OAQPS Cost Control Manual
Total Indirect Capital Cost (TInCC)	\$609,864	\$5,787,714	
Total Direct, Indirect and Capital Costs (TDICC)	\$2,977,683	\$30,078,773	Sum of TCC and TInCC

Table B-4a. Annualized Cost for Selective Catalytic Reduction and SCONOX™ for the Siemens-Westinghouse 501FD Combined Cycle Operation

Cost Component	Costs for SCR	Costs for SCONOX™	Basis of Cost Component
Direct Annual Costs			
Operating Personnel	\$18,720	\$37,440	24 hours/week at \$15/hr for SCR; SCONOX 2 times SCR costs
Supervision	\$2,808	\$5,616	15% of Operating Personnel; OAQPS Cost Control Manual
Ammonia	\$291,393	\$0	\$300 per ton for Aqueous NH ₃
PSM/RMP Update	\$15,000	\$0	Engineering Estimate
Inventory Cost	\$34,404	\$68,808	Capital Recovery (10.98%) for 1/3 catalyst for SCR; SCONOX 2 times SCR
Catalyst Cost	\$313,333	\$470,000	3 years catalyst life; Based on Vendor Budget Estimate
Contingency	\$20,270	\$17,456	3% of Direct Annual Costs
Total Direct Annual Costs (TDAC)	\$695,928	\$599,320	
Energy Costs			
Electrical	\$28,032	\$70,080	80kW/h for SCR @ \$0.04/kWh times Capacity Factor; 200 kW for SCONOX
MW Loss and Heat Rate Penalty	\$336,358	\$840,894	0.3% or 0.54 MW output for SCR; 0.75% or 1.35 MW for SCONOX; EPA, 1993
Steam Costs for SCONOX	\$0	\$705,663	18,184 lb/hr 600 °F, 85 psig, steam (1,329 Btu/lb steam); 90% boiler eff.; \$3/mmBtu
Natural Gas for SCONOX	\$0	\$49,347	81 lb/hr; 0.044 lb/scf; 1,020 Btu/scf; \$3/mmBtu
Total Energy Costs (TEC)	\$364,390	\$1,665,984	
Indirect Annual Costs			
Overhead	187,752	25,834	60% of Operating/Supervision Labor and Ammonia
Property Taxes	29,777	300,788	1% of Total Capital Costs
Insurance	29,777	300,788	1% of Total Capital Costs
Annualized Total Direct Capital	326,950	3,302,649	10.98% Capital Recovery Factor of 7% over 15 years times sum of TDACC
Total Indirect Annual Costs (TIAC)	\$574,256	\$3,930,058	
Total Annualized Costs	\$1,634,573	\$6,195,362	Sum of TDAC, TEC and TIAC
Cost Effectiveness	\$2,443	\$9,261	per ton of NO _x Removed
	669.01	669.01	tons NO _x removed /year; 3.5 ppmvd corrected to 15% oxygen

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

RECEIVED

JUL 13 2000

BUREAU OF AIR REGULATION

CALPINE CONSTRUCTION FINANCE
COMPANY, L.P.,

Petitioner,

vs.

DEP Draft Permit No.
PA 00-41 (PSD-FL-287)

DEPARTMENT OF ENVIRONMENTAL
PROTECTION,

Respondent.

CALPINE'S SECOND REQUEST FOR EXTENSION
OF TIME TO FILE PETITION

Petitioner, Calpine Construction Finance Company, L.P.
("Calpine"), pursuant to Rule 28-106.011(3), Florida
Administrative Code, respectfully requests the Department of
Environmental Protection ("Department") to grant Calpine an
additional extension of time to file a petition for a formal
administrative hearing concerning the Department's draft permit
for Calpine's Osprey Energy Center (DEP Draft Permit No. PA 00-
41 (PSD-FL-287)) (the "Draft Permit"). In support of this
request, Calpine says:

1. On March 16, 2000 Calpine filed an application with the
Department for a prevention of significant deterioration ("PSD")
permit for Calpine's Osprey Energy Center, a 527 MW electrical
power plant to be located at 1501 Derby Avenue, Auburndale,
Florida.

2. On May 11, 2000, the Department distributed its "Public

Notice of Intent to Issue PSD Permit", Draft Permit, Technical Evaluation and Preliminary Determination, and Draft BACT Determination for the Osprey Energy Center. As the applicant for the Draft Permit, Calpine is affected by the Department's proposed action.

3. On May 23, 2000, Calpine requested a 45-day extension of time to file its petition. The Department has not yet issued an order concerning Calpine's request for extension of time.

4. The Draft Permit is lengthy and complex. Calpine's preliminary review of the Draft Permit indicated that some provisions of the Draft Permit are not consistent with Calpine's application. On June 29, 2000, representatives of Calpine met with Department staff to discuss modifications to the Draft Permit. Based on those discussions with Department staff, Calpine will submit written comments concerning the Draft Permit to the Department.

5. Although Calpine does not expect to file a petition for a formal administrative hearing concerning the Draft Permit, Calpine requests a 60-day extension of time to finalize its comments concerning the Draft Permit, and to conduct additional meetings with the Department, before Calpine waives its right to a hearing.

6. Petitioner's counsel has discussed this request with Department's counsel, Mr. Scott Goorland. Mr. Goorland indicated that the Department has not yet formulated a position concerning

this request.

WHEREFORE, Calpine requests the Department to grant a 60-day extension of time to file a petition for a formal administrative hearing concerning the Draft Permit.

Respectfully submitted this 7th day of July, 2000.

LANDERS & PARSONS




DAVID S. DEE
Fla. Bar No. 281999
JOHN T. LaVIA, III
Fla. Bar No. 853666
310 West College Avenue (32301)
P.O. Box 271
Tallahassee, Florida 32302
850/681-0311
850/224-5595 (fax)

COUNSEL FOR CALPINE CONSTRUCTION
FINANCE COMPANY, L.P.

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that an original and one copy of the foregoing was furnished by hand-delivery to the CLERK'S OFFICE, Department of Environmental Protection, Office of General Counsel, 3900 Commonwealth Blvd., Room 659E, Tallahassee, Florida 32399; and a copy by U.S. Mail to Scott Goorland, Department of Environmental Protection, Office of General Counsel, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399, on this 7th day of July, 2000.


ATTORNEY

STATE OF FLORIDA
DIVISION OF ADMINISTRATIVE HEARINGS

IN RE: CALPINE CONSTRUCTION
FINANCE COMPANY, L.P.
(OSPREY ENERGY CENTER);
POWER PLANT SITING
APPLICATION NO. PA00-41

DOAH CASE NO. 00-1288EPP
OGC CASE NO. 00-0740

CALPINE'S SUPPLEMENTAL RESPONSE TO
DEP'S NOTICE OF INSUFFICIENCY

Calpine Construction Finance Company, L.P. (Calpine), submits this supplemental response to the notice of insufficiency (Notice) served by the Florida Department of Environmental Protection (Department or DEP) and says:

1. On March 20, 2000, Calpine filed an application for certification of an electrical power plant (the Osprey Energy Center) pursuant to the Florida Electrical Power Plant Siting Act (Act), Section 403.501, et seq. On May 22, 2000, the Department issued its Notice, which indicates that Calpine's application is "insufficient" because the application does not contain all of the information needed by the Southwest Florida Water Management District (SWFWMD) for the SWFWMD's evaluation of the Osprey Energy Center.

2. The Department's Notice indicates that Calpine may pursue several different options under the Act. Under one option, Calpine may submit additional information to the Department within 40 days to make the application sufficient. Under another option, Calpine may advise the Department and the

Administrative Law Judge that Calpine cannot submit the additional information needed to make the application sufficient within 40 days.


3. On May 26, 2000, Calpine filed a response to DEP's Notice stating that Calpine intended to submit additional information to make its application sufficient within 40 days.

4. Since filing its response to DEP's Notice, Calpine has diligently worked on assembling the additional information requested by the Department and the SWFWMD. On June 13, 2000, Calpine's consultants met with the SWFWMD staff to discuss the issues raised in DEP's Notice. In light of the discussions with SWFWMD staff, Calpine has determined that it requires more time to submit the additional information requested in DEP's Notice.

4. Accordingly, pursuant to Section 403.5067(1)(b), Florida Statutes, Calpine hereby advises the Department and the Administrative Law Judge that Calpine requires more time to submit the additional information requested in DEP's Notice. Calpine anticipates that it will submit the additional information within 45 days of this response.

Respectfully submitted this 7th day of July, 2000.

LANDERS & PARSONS



DAVID S. DEE
Florida Bar No. 281999
JOHN T. LaVIA, III
Florida Bar No. 853666
P.O. Box 271
310 West College Avenue (32301)
Tallahassee, Florida 32302
Phone: 850/681-0311
Fax: 850/224-5595

CERTIFICATE OF SERVICE

I CERTIFY that a true and correct copy of the foregoing has been sent by U.S. Mail to the following this 7th day of July, 2000.

Steven Palmer, P.E.
Office of Siting Coordination
Department of Environmental
Protection
2600 Blair Stone Road, MS 48
Tallahassee, FL 32399-3000

Scott Goorland
Senior Assistant General
Counsel
Office of General Counsel
Department of Environmental
Protection
3900 Commonwealth Blvd., MS 35
Tallahassee, FL 32399-3000

James V. Antista, General Counsel
Florida Fish and Wildlife
Conservation Commission
620 South Meridian Street
Tallahassee, FL 32399-1600

Sheauching Yu
Assistant General Counsel
Department of Transportation
605 Suwannee Street, MS 58
Tallahassee, FL 32399-0458

Cathy Bedell
Acting General Counsel
Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399

Cari Roth, General Counsel
Andrew Grayson, Asst. Gen. Coun.
Office of General Counsel
Department of Community Affairs
2555 Shumard Oak Blvd.
Tallahassee, FL 32399


Frank Anderson, Asst. Gen. Coun.
Office of General Counsel
Southwest Florida Water
Management District
2379 Broad Street
Brooksville, FL 34609

R. Douglas Leonard
Executive Director
Central Florida Regional
Planning Council
P.O. Box 2089
Bartow, FL 33831

Norman White
General Counsel
Central Florida Regional
Planning Council
c/o Bradley Johnson Law Firm
P.O. Box 1260
Lake Wales, FL 33859-1260

Mark Carpanini
County Attorney
Polk County
P.O. Box 9005 Drawer CA01
Bartow, FL 33831-9005

Patton Kee
City Attorney
City of Auburndale
P.O. Box 186
Auburndale, FL 33823


ATTORNEY



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

JUN 21 2000

RECEIVED

JUN 26 2000

4APT-ARB

BUREAU OF AIR REGULATION

Mr. A. A. Linero, P.E.
Florida Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

SUBJ: Preliminary Determination and draft PSD Permit for Calpine Construction & Finance Company, L.P. - Osprey Energy Center in Polk County located near Auburndale, FL

Dear Mr. Linero:

Thank you for sending the preliminary determination and draft prevention of significant deterioration (PSD) permit for the Osprey Energy Center dated May 10, 2000. The draft PSD permit is for the proposed construction and operation of two combined cycle combustion turbines (CTs) and two natural gas-fired heat recovery steam generating units with a total nominal generating capacity of 527 megawatts (MW). The combustion turbines proposed for the facility are Siemens Westinghouse 501FD units. The CTs will combust pipeline quality natural gas only. Total emissions from the proposed project are above the thresholds requiring PSD review for nitrogen oxides (NO_x), carbon monoxide (CO), volatile organic compounds (VOC), sulfur dioxide (SO₂) and particulate matter (PM/PM₁₀).

Based on our review of the preliminary determination and draft PSD permit, we have the following comments:

1. In November 1999, ABB ALSTOM POWER announced the availability of SCONOX™ systems for any size combustion turbine. Region 4 therefore considers this control method technically feasible for Osprey's combined cycle CTs. Accordingly, FDEP should require the Osprey Energy Center to provide a project-specific BACT analysis for SCONOX™ (economics, environmental impacts, and energy use) before issuing a final permit.
2. We suggest you verify the emission rate used by Golder Associates to estimate potential formaldehyde emissions. The emission factor cited by Golder is only one-fifth of the emission factor cited for formaldehyde from natural gas turbines in the recently revised section 3.1 of AP-42.
3. The "Public Notice of Intent to Issue PSD Permit" indicates that the combustion turbines for this project will be General Electric PG7241FA units. It is our understanding, as

indicated elsewhere in the preliminary determination and draft PSD permit, that the Osprey Energy Center will be installing Siemens Westinghouse 501FD combustion turbines. If possible, clarify this inconsistency before the public notice is published.

Thank you for the opportunity to comment on the preliminary determination and draft PSD permit for Calpine's Osprey Energy Center. If you have any questions or concerns, please direct them to either Katy Forney at 404-562-9130 or Jim Little at 404-562-9118.

Sincerely,



R. Douglas Neeley
Chief
Air and Radiation Technology Branch
Air, Pesticides and Toxics
Management Division

cc: M. Halpin
C. Halladay
NPS
B. Owen
SWD