



CPV Pierce Power Generating Facility Application for Air Permit Document ID: CPV-PI

**Florida Department of Environmental Protection
Division of Air Resources Management**

Prepared for:


CPV Pierce, Ltd.

Prepared by:

TRC Environmental Corporation

Windsor, Connecticut

April 2001



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

April 20, 2001

Mr. Gregg Worley, Chief
Air, Radiation Technology Branch
Preconstruction/HAP Section
U.S. EPA, Region 4
61 Forsyth Street
Atlanta, Georgia 30303

RE: Facility ID No. 1050349-001-AC, PSD-FL-319
CPV Pierce Power Generating Facility

Dear Mr. Worley:

Enclosed for your review and comment is an application for CPV Pierce, Ltd. to construct and operate a new electric power generating plant in Polk County, Florida.

Your comments may be forwarded to my attention at the letterhead address or faxed to the Bureau of Air Regulation at 850/922-6979. If you have any questions, please contact Teresa Heron, review engineer, at 850/921-9529.

Sincerely,

Patricia Adams

AL

Al Linero, P.E.
Administrator
New Source Review Section

AAL/pa

Enclosure

cc: Teresa Heron

RECEIVED

APR 18 2001

BUREAU OF AIR REGULATION

**CPV Pierce Power Generating Facility
Application for Air Permit
Document ID: CPV-PI**

Florida Department of Environmental
Protection
Division of Air Resources Management

Prepared For:

CPV Pierce, Ltd.

Prepared By:

TRC Environmental Corporation
5 Waterside Crossing
Windsor, Connecticut

April 2001

TABLE OF CONTENTS

Section	Page
1.0 INTRODUCTION.....	1-1
2.0 PROJECT DESCRIPTION	2-1
2.1 Site Description	2-1
2.2 Equipment Description.....	2-1
2.2.1 Combined-Cycle Combustion Turbine Generator	2-2
2.2.2 Heat Recovery Steam Generator	2-3
2.2.3 Emission Control Equipment	2-3
2.2.4 Cooling Towers	2-4
2.2.5 Proposed Fuel Use.....	2-5
2.3 Project Physical Layout and Design.....	2-5
2.4 Equipment Operation	2-6
2.5 Construction Schedule.....	2-8
3.0 APPLICABLE REGULATORY REQUIREMENTS	3-1
3.1 Ambient Air Quality Standards.....	3-2
3.2 Non-attainment New Source Review	3-4
3.3 Prevention of Significant Deterioration (PSD)	3-4
3.4 New Source Performance Standards (NSPS).....	3-5
3.5 National Emission Standards for Hazardous Air Pollutants	3-6
3.6 Acid Rain Program.....	3-7
3.7 Operating Permit	3-7
3.8 Risk Management Plan (RMP)	3-8
3.9 Florida Air Permit Application	3-8
4.0 ASSESSMENT OF IMPACTS	4-1
4.1 Emission and Stack Parameters	4-1
4.2 Good Engineering Practice (GEP) Stack Height Calculation	4-4
4.3 Land Use Determination	4-5
4.4 Background Air Quality	4-5
4.5 Meteorological Data	4-8
4.6 Receptors.....	4-8
4.7 Modeling Approach.....	4-9
4.8 Predicted Impacts	4-10
4.8.1 Sulfur Dioxide (SO ₂).....	4-10
4.8.2 Nitrogen Dioxide (NO ₂).....	4-11
4.8.3 Carbon Monoxide (CO)	4-11
4.8.4 Particulate Matter (PM ₁₀).....	4-11
4.9 Class I Area Analyses	4-12
4.9.1 PSD Class I Increments.....	4-13
4.9.2 Regional Haze	4-14
4.9.3 Model Selection.....	4-14

4.9.4	CALPUFF Modeling.....	4-15
4.9.4.1	Meteorology	4-16
4.9.4.2	Receptors	4-16
4.9.4.3	Source Emissions and Dispersion Characteristics	4-16
4.9.5	CALPUFF Level I Modeling Procedures.....	4-17
4.9.5.1	CALPOST Processing.....	4-18
4.9.6	PSD Class I Increment Modeling Results	4-18
4.9.7	Regional Haze Modeling Results	4-19
4.10	Summary of Project Impacts	4-20
5.0	CONTROL TECHNOLOGY ANALYSIS	5-1
5.1	Applicability of Control Technology Requirements	5-1
5.1.1	PSD Contaminants Subject To BACT Under PSD Review	5-2
5.1.2	Non-Attainment Pollutants Subject To LAER	5-2
5.2	Approach Used in BACT Analysis	5-2
5.2.1	Identification of Technically Feasible Control Options	5-3
5.2.2	Economic (Cost-Effectiveness) Analysis	5-3
5.2.3	Energy Impact Analysis	5-5
5.2.4	Environmental Impact Analysis	5-5
5.2.5	BACT Proposal	5-6
5.3	BACT Analysis for Carbon Monoxide	5-6
5.3.1	Identification of Technically Feasible Control Options	5-6
5.3.2	Environmental Impacts of Technically Feasible CO Controls	5-7
5.3.3	Energy Impact of Oxidation Catalyst	5-8
5.3.4	Economic Impact of Oxidation Catalyst	5-8
5.3.5	BACT Proposal	5-9
5.4	BACT Analysis for Sulfur Dioxide.....	5-9
5.5	BACT Analysis for Particulate Matter	5-10
5.5.1	Combustion Turbine.....	5-10
5.5.2	Cooling and Waste Water Towers	5-10
5.6	BACT Analysis for Nitrogen Oxides	5-11
5.6.1	Identification of Technically Feasible Control Options	5-12
5.6.2	Environmental Impacts of a SCR Control System	5-13
5.6.3	Energy Impacts of a SCR Control System	5-14
5.6.4	Economic Impact of SCR Control System	5-15
5.6.5	BACT Proposal	5-16
5.7	BACT Summary.....	5-16

APPENDICES

- A Air Permit Application Forms
- B Engineering Drawings
- C Air Pollutant Emissions
- D Air Quality Modeling
- E Control Technology Review

LIST OF FIGURES

Page

Figure 1-1	Illustration of CPV Pierce Site Location.....	1-2
Figure 1-2	Location of CPV Pierce Property Boundary and Fence line.....	1-3
Figure 4-1	Land Use Analysis – 3 Km Radius	4-6

LIST OF TABLES

Table 3-1	New Power Generation Equipment Criteria Pollutant Emissions CPV Pierce.....	3-2
Table 3-2	Ambient Air Quality Standards and Thresholds	3-3
Table 3-3	PSD Significant Emissions Increase Level and CPV Pierce Project, Net Emission Rates (Pursuant to 40 CFR 52.21 (b) (23) (i))	3-5
Table 4-1	Stack Exhaust Parameters CPV Pierce Project	4-2
Table 4-2	Power Generation Equipment Projected Criteria Pollutant Emissions for the CPV Pierce Project	4-3
Table 4-3	Air Quality Monitoring Stations	4-7
Table 4-4	Existing Air Quality	4-7
Table 4-5	PSD Class I Increments and Significance Levels in $\mu\text{g}/\text{m}^3$	4-13
Table 4-6	Gas Turbine Particle Size Distribution.....	4-18
Table 4-7	Maximum Predicted Concentrations at Chassahowitzka NWR.....	4-19
Table 4-8	Background Extinction Data and Relative Humidity Factors for Chassahowitzka NWR.....	4-20
Table 4-9	CPV Pierce Project Summary of Applicable Limits and Predicted Impacts	4-22
Table 5-1	Energy Impacts of SCR Controls.....	5-15
Table 5-2	Summary of Proposed BACT Limits for the CPV Pierce Project	5-17

Section 1

Introduction


1.0 INTRODUCTION

The purpose of this document is to provide the regulatory forms and technical information required to secure approval pursuant to Florida environmental regulations for construction and operation of a new electric power generation facility.

CPV Pierce, Ltd. (CPV) is proposing to construct a power generation facility capable of generating a nominal net electrical output of approximately 245 megawatts (MW). The proposed facility, referred to as the CPV Pierce Power Generating Facility (The Facility or Project), will be located in Polk County. The proposed Facility will be sited on a leased parcel of land currently owned by IMC Phosphates Company (IMC). The size of the leased parcel is approximately 75 acres. The Project equipment will be contained within a fenced portion of the parcel expected to be approximately 13 acres. The location of the site is shown on a USGS topographical map of the area given as Figure 1-1. An illustration of the proposed site showing the approximate Project boundary and fenced portion is presented as Figure 1-2.

CPV is proposing to install an electrical generating unit consisting of a combined-cycle generating system. The combined-cycle system will be comprised of an energy efficient combustion turbine (CT), a heat recovery steam generator (HRSG) and a steam turbine. The gas turbine will provide approximately 170 MW of electrical power. The HRSG recovers otherwise lost heat from the gas turbine exhaust and provides steam energy to drive the steam turbine to provide a controlled maximum 74.9 MW of electric energy. The new power generation equipment will be designed to meet federal Best Available Control Technology (BACT) standards, as appropriate, for emissions control. The new power generation Facility includes a 175-foot stack, a 5 cell cooling tower and a water treatment system that will result in zero waste water discharge.

The following sections of this document will provide the requisite information describing the proposed Project. Section 2.0 provides a detailed description of the proposed Facility. Section 3.0 describes the applicability of specific regulatory requirements to the CPV Project. Section 4.0 documents the air quality modeling study conducted to demonstrate compliance with ambient air quality standards and increments. Section 5.0 presents the emissions control technology



TRC Environmental Corporation

5 Waterside Crossing
Windsor, CT 06095
(860) 289-8631


CPV Pierce

FIGURE 1-1

Illustration of CPV Pierce
Site Location

Date: April 10, 2001

Project No. 31325



assessment. The application forms are contained in Appendix A. Other appendices provide drawings, technical specifications, and data supporting the studies conducted to demonstrate compliance with applicable regulatory requirements.



IMC Phosphates Company
P.O. Box 2000
Mulberry, Florida 33860-1100
863.428.2500

April 11, 2001

Authorization for Proposed Power Plant in the Pebbledale area, Polk County by
Competitive Power Ventures

The undersigned hereby certifies that as an Authorized Representative of **IMC PHOSPHATES COMPANY**, owner of the seventy-three (73) acres within Parcel Nos.: 243031000000012010 and 243030000000021040, that the **IMC PHOSPHATES COMPANY** is authorizing **CPV Pierce, Limited** to apply for necessary State and Federal permits for a proposed power plant on the above described property.

IMC PHOSPHATES COMPANY, by
IMC PHOSPHATES MP, INC., its
Managing General Partner

Richard Krakowski
Authorized Representative (Typed)


Richard Krakowski
Authorized Representative (Signature)

Vice President, General Manager Operations,
Phosphates & Feed
Officer of IMC Phosphates MP, Inc.
TITLE

April 16, 2001
DATE

STATE OF FLORIDA
COUNTY OF POLK

The foregoing instrument was acknowledged before me this 16th day of April, 2001, by Richard Krakowski on behalf of IMC PHOSPHATES COMPANY, who is personally known by me or has produced _____ as identification.



Diane W. Smith
Notary Public
Name of Notary Public DIANE W. SMITH
My Commission Expires _____

Section 2

Project Description

2.0 PROJECT DESCRIPTION

CPV proposes to construct a power generation facility in Polk County using state-of-the-art combined-cycle power generation technology and air pollution control systems. The major components of the Project include a combustion turbine generator, one heat recovery steam generator, one steam turbine, and state-of-the-art air pollution controls. Natural gas will be used as the primary source of fuel. To enhance overall reliability, the proposed system will also be capable of burning very low sulfur content distillate oil as backup fuel for up to an equivalent of 30 days at full load each year.

2.1 Site Description

The CPV power generation facility will be located in southwestern Polk County, Florida. CPV identified a tract of land owned by IMC that will be secured for the Project. The Project parcel is approximately 75 acres in size. The Project equipment will be contained within a fenced portion of the parcel with an area of approximately 13 acres. Figures 1-1 and 1-2 illustrate the proposed Project location.

2.2 Equipment Description

To maximize efficiency and energy conservation, the proposed Project will include both combustion and steam cycles. In the combustion cycle, the combustion turbine will fire natural gas as its primary fuel to produce approximately 170 MW. The system will also have a steam cycle system consisting of a HRSG and steam turbine generator. This system provides exceptional efficiency by employing the HRSG to recover otherwise lost heat from the gas turbine exhaust and using it to create steam and drive the steam turbine generator to produce an additional maximum 74.9 MW. The steam that exhausts from the steam turbine generator is cooled and condensed for re-use in the steam cycle.

The combined-cycle technology design achieves an operational efficiency on a unit of energy output per unit of energy input basis greater than operational efficiency for peaker type simple-cycle system or older power plants.

Ancillary equipment for the Project will include:

- One diesel fired 250 hp fire water pump,
- One 500 kW emergency generator for safe shutdown, and
- Cooling Towers

A description of each major Project component is provided below.

2.2.1 Combined-Cycle Combustion Turbine Generator

The Project will use an advanced natural gas and distillate oil fired combustion turbine generator. The combustion turbine generator to be supplied by General Electric (GE) will be equipped with GE's two-stage, lean pre-mix dry low-nitrogen oxides (NO_x) combustor.

The nominal 170 MW turbine generator is GE's Model 7241FA. Basic elements include a compressor, a dry low NO_x combustor, a power turbine, and a generator. Within the combustor, injected fuel (in this case, natural gas or distillate oil) mixes with compressed air from the compressor and burns, producing hot exhaust that drives the shaft-mounted turbine blades. Some of the rotational energy of the shaft compresses the incoming combustion air. The greater portion of the shaft's rotational energy drives the generator to produce the nominal 170 MW.

The power produced by the combustion turbine generator decreases as the ambient temperature rises. This is because the density of the air decreases with increasing temperature. Because the turbine section produces power based on mass flow, increases in ambient air temperature result in a decrease in ambient air density that reduces the mass flow rate available for power generation by the turbine. In the proposed unit, power augmentation will be employed to minimize the effect of decreasing output with increasing temperature.

During warmer ambient temperatures, the combustion turbine is power augmented to make-up electrical output that is lost due to the increasing temperatures. Power augmentation involves using steam generated in the HRSG. The steam is injected into the turbine section of the combustion turbine generator. The injected steam increases the density of the air entering the turbine, thereby increasing power output. Power augmentation can only be used, however, when the ambient air temperature is above 59°F.

2.2.2 Heat Recovery Steam Generator

Exhaust gases leaving the combustion turbine retain considerable recoverable heat energy. The HRSG transfers the heat from this high temperature exhaust gas (about 1,100°F) to water in order to generate useful steam for additional generating capacity. The temperature of the exhaust gas leaving the HRSG is approximately 190°F when firing natural gas.

The major sections of the HRSG include a super heater, an evaporator, and an economizer. The HRSG will not include duct burners and it will not be supplementally fired. Other HRSG components include a Selective Catalytic Reduction (SCR) NO_x control system (with associated ammonia injection and control systems) and an exhaust stack.

2.2.3 Emission Control Equipment

The exhaust flow from the combustion turbine will pass through an SCR system before venting through a 175-foot stack. This stack height has been designed to provide sufficient emission dispersion while minimizing the potential for aerodynamic downwash of stack emissions, and limiting the effect upon visual aesthetics. The SCR control system will be capable of reducing NO_x emissions to 3.5 (ppmvd @15% O₂) when firing natural gas and 10 ppmvd @15% O₂ when firing distillate oil. The ammonia slip will be limited to 5 ppmvd @ 15% O₂.

2.2.4 Cooling Towers

Wet cooling towers are employed to cool and condense steam in combined-cycle electric generation facilities. The cooling tower reduces the temperature of cooling water by air-water contact. The Facility will include a five-cell mechanical draft cooling tower to cool the steam/water from the HRSG.

Water flows down through each cooling tower cell while air flows upward. Some of the cooling water evaporates and exits with the air as water vapor. The surface area of the water is increased as it flows or trickles through the fill section, which optimizes the heat transfer capability prior to it being collected in a basin at the bottom of the tower. Airflow, induced through the tower by fans, passes upward through the fill section, where heat transfers from the water and a small fraction of the water evaporates, thus cooling the remaining water. The cooled water, which is collected in the basin, is then re-circulated back to the condenser. All of this occurs in a continuous fashion. A small percentage of the water is trapped in the air as small droplets. These entrained water droplets are referred to as cooling tower drift. Most of the water trapped in the air is removed using high-efficiency drift eliminators. However, some droplets remain airborne and are released with the plume exiting the tower.

The water that is lost through the tower to the atmosphere must be replaced. In addition, as water is evaporated from the system, the dissolved solids concentration of the water remaining in circulation increases. To prevent dissolved solids from reaching levels where they would collect as scale on the exposed surfaces of the tower and condenser, some of the basin water is continuously bled off from the system. This is known as cooling tower blowdown. As with the evaporative losses, this blowdown must be replaced. The flow required to compensate for evaporative and blowdown losses are known as cooling tower makeup.

Air quality impacts are expected from the mechanical draft cooling tower system due to the dissolved solids contained in the cooling tower drift, even when high efficiency drift eliminators are employed to limit the quantity of droplets in the plume. The cooling tower will be designed to achieve a drift rate of 0.0005 percent of the circulating water flow rate, which represents the

state of the art in drift elimination technology. Some of the solids (particulate matter) are less than 10 microns in size and constitute PM₁₀ emissions. These cooling tower emissions will be in addition to combustion emissions associated with the proposed Project stacks.

The proposed Facility design includes a zero liquid discharge system from the cooling tower process. Cooling tower blow-down will be processed through a separate waste water tower. This tower is similar in design and operates as the 5-cell cooling tower and will also be a source of particulate emissions. These emissions have been calculated based on expected system design and are included in the Facility evaluations.

2.2.5 Proposed Fuel Use

The equipment will be designed to generate electricity and steam using natural gas as the primary fuel source. During periods of natural gas interruption or when market conditions warrant, very low sulfur (0.05 percent) distillate oil will be used. The annual quantity of distillate oil use is limited to the equivalent of 100 percent load operation for no more than 30 days, i.e. 720 hours. The distillate oil will be delivered to the site by truck, and stored in an above ground tank.

2.3 Project Physical Layout and Design

The new equipment associated with the Project will occupy an approximate 13-acre area footprint on the approximately 75-acre site. A Site plan illustrating the Facility arrangement is contained in Appendix B.

Power Generation Equipment: The electrical generating equipment, including the gas turbine, steam turbine, HRSG and associated mechanical and electrical equipment will be located outdoors.

Support Buildings: There will be several small ancillary buildings as shown on the site plan in Appendix B, including a combination administration/warehouse building, a combination electric room/control room, a cooling tower electric room, water treatment area and a pump house.

Security: All operational areas of the site will be enclosed by a security fence. The electrical switchyard and the gas metering area will each be separately fenced. There will be one main plant entrance with a gate adjacent to the administration building.

Storage Tanks: Several storage tanks will be constructed, all of which will be above ground and will meet all applicable Florida Department of Environmental Protection (FDEP) standards. One distillate oil storage tank with a capacity of 975,000 gallons will be installed. The tank will have double-wall construction with leak detection. Two water storage tanks will also be constructed: one 1.0 million gallon de-mineralized water tank and one 0.5 million gallon raw firewater storage tank. A 12,000-gallon aqueous ammonia storage tank will be constructed for the nitrogen oxide emission control system. A concrete containment dike will be built around this tank. Finally, a 20,000-gallon neutralizer tank will be installed.

2.4 Equipment Operation

The proposed design consists of a combined-cycle power generating unit based on a GE 7FA utilizing a single PG7241 (FA) combustion turbine (CT), a 3-pressure heat recovery steam generator (HRSG) and a steam turbine generator (STG) designed in conjunction with the HRSG steam conditions. The steam turbine generator output will be limited to less than 75 MW. Control of STG output will be monitored and controlled via an automatic digital control system (DCS) to ensure the 75 MW output limit is not exceeded. A number of control options have been investigated and the most probable are described below.

When ambient temperature is at 59 degrees Fahrenheit (°F) or greater, excess steam generated in the HRSG can be extracted from the HRSG, bypassing the steam turbine, and injected into the CT. This mode of operation is referred to as power augmentation. Since there is a limit on the quantity of steam that may be injected into the CT, it may be necessary to further reduce steam flow to the STG to limit output or to reduce steam turbine output by other means.

Bypass of a portion of heat exchange surface in the HRSG can be an effective method of reducing steam production by reducing the heat recovered from the combustion turbine flue gas. The proposed design will make use of a low temperature economizer bypass to limit steam production by allowing more of the heat generated by the combustion turbine to be discharged to the atmosphere with the flue gas. This will limit STG output.

In many cases, application of both of these control modes will reduce steam output of the turbine to the required quantity. If additional reduction in STG output is required, raising the STG discharge pressure by raising the condenser operating temperature will reduce turbine efficiency, reducing electrical output. Output of the STG may be tuned to the desired value by turning cooling tower cells on and off as necessary.

When the ambient temperature falls below 59 °F, the manufacturer does not recommend injection of steam into the combustion turbine. If the low temperature economizer bypass, combined with an increase in cooling water temperature does not reduce STG output sufficiently, excess steam may bypass the steam turbine and be sent directly to the condenser.

Output of the STG will be controlled automatically utilizing the methods described above through a DCS designed to ensure that the electrical power produced from steam does not exceed 74.9 MW. The DCS will be programmed by the Engineering Procurement Construction (EPC) engineer to limit the steam turbine output to 74.9 MW. The necessary logic to automatically control steam injection to the gas turbine, cooling tower fan speed, HRSG economizer bypass control, steam bypass control, or reduce gas turbine load will be incorporated in the DCS. The plant operator can manually lower the steam turbine output value but cannot raise the number beyond the programmed set point limit or alter the DCS logic. Depending on the DCS platform purchased, the logic and set point will either be protected by password or keylock. If the logic or set point must be changed after the plant is in commercial operation, only an authorized DCS representative or a qualified DCS engineer can make the modifications. These modifications can be made using the DCS engineering work station, which will be located in the plant control room. A shutdown of the facility is not required since the changes can be made while the plant is on-line.

2.5 Construction Schedule

The development schedule for the Project calls for obtaining all required pre-construction approvals by the fourth quarter of 2001. Upon financial closing, groundbreaking for the Facility would be initiated by the EPC contractor. Construction of the Project would require approximately 22 to 24 months and is scheduled to be completed in the fourth quarter of 2003. Start-up/testing activities would be ongoing during the later phases of construction. Commercial acceptance of the Facility by CPV would occur approximately six weeks after completion of the construction activities.

Section 3

Applicable Regulatory Requirements

3.0 APPLICABLE REGULATORY REQUIREMENTS

The proposed CPV Project must comply with air pollution control regulations administered by the Florida Department of Environmental Protection (FDEP), Division of Air Resources Management (DARM). Essential to understanding the regulatory requirements to which the Project must comply are the new power generation equipment air pollutant emission rates.

The Project will produce approximately 245 MW of electrical power. The Project's primary power generation equipment includes a new combustion turbine, HRSG, and steam turbine, operated as a combined-cycle system.

Major pollutants of interest emitted include: sulfur dioxide (SO_2), nitrogen oxides (NO_x), particulate matter less than 10 microns (PM_{10}), carbon monoxide (CO), and volatile organic compounds (VOC). Other pollutants including lead and regulated non-criteria air contaminants are not of concern because the new power generation equipment will fire natural gas as the primary fuel and very low-sulfur distillate oil (0.05 percent sulfur content) as the back-up fuel. The distillate oil firing will be limited to the equivalent of 30-day operation at 100 percent load.

The annual emission rates that determine regulatory applicability are the potential annual emissions of the new power generation equipment. Design data provided by the equipment manufacturer for the new power generation equipment specifies air pollutant emissions as a function of operating load and ambient temperature for both natural gas and distillate oil firing (see Appendix C). The annual potential emissions were calculated assuming 335 days of natural gas firing and 30 days of low sulfur distillate oil firing, and assuming the maximum pollutant emission rate over the range of operating conditions contained in the equipment design data. Table 3-1 shows the new power generation equipment's potential annual emissions.

Table 3-1 New Power Generation Equipment Criteria Pollutant Emissions CPV Pierce¹	
Pollutant	Potential Emissions² (Tons/Year)
NO _x	125
SO ₂	76
CO	226
PM/PM ₁₀ ³	100
VOC	15
¹ Source: GE performance data in Appendix C. ² Annual emission estimates based on combustion turbine operating 8760 hours at maximum hourly emission rate. ³ PM/PM ₁₀ value includes combustion turbines, cooling tower drift and waste water tower drift.	

The U.S. Environmental Protection Agency (EPA) regulations establish air quality standards and air contaminant emission limits with which all new sources must comply. These regulations affect the design and operation of the new power generation equipment. This section describes the regulations and their impact on the Project.

3.1 Ambient Air Quality Standards

EPA has developed National Ambient Air Quality Standards (NAAQS) for six pollutants, referred to as criteria pollutants, for the protection of the public health and welfare. The criteria pollutants are SO₂, NO₂, CO, PM₁₀, ozone (O₃), and lead (Pb). FDEP enforces the NAAQS as state air quality standards. FDEP has also established primary SO₂ State Ambient Air Quality Standards (SAAQS), which are more restrictive than the NAAQS. Table 3-2 shows the NAAQS and SAAQS.

Primary standards protect human health with an adequate margin of safety, and secondary standards protect public welfare (e.g., avoid damage to property or vegetation). Different averaging periods are established for the criteria pollutants based on their potential environmental effects.

Attaining and maintaining compliance with the state and national ambient air quality standards is the primary goal of all air regulations evolving from the original Clean Air Act and its subsequently enacted amendments. All areas of the nation have been classified as to their status with regard to attaining the standards. The Project site area is classified as "unclassified" or "attainment" for all criteria pollutants.

Table 3-2 Ambient Air Quality Standards and Thresholds					
Pollutant	Averaging Period	NAAQS ($\mu\text{g}/\text{m}^3$)^h		PSD Increments ($\mu\text{g}/\text{m}^3$)	Significant Impact Levels ($\mu\text{g}/\text{m}^3$)
		Primary	Secondary		
Sulfur Dioxide (SO_2)	3-hour	NA	1300 ^a	512 ^a	25
	24-hour	365 ^a (260)	NA	91 ^a	5
	Annual	80 ^g (60)	NA	20 ^g	1
Nitrogen Dioxide (NO_2)	Annual	100 ^g	100 ^g	25 ^g	1
Carbon Monoxide (CO)	1-hour ^a	40,000	NA	NA	2000
	8-hour ^a	10,000	NA	NA	500
Particulate Matter (PM_{10})	24-hour	150 ^d	NA	30 ^a	5
	Annual	50 ^g	NA	17 ^g	1
Particulate Matter ($\text{PM}_{2.5}$)	24-hour	65 ^f	NA	NA	NA
	Annual	15 ^{e,g}	NA	NA	NA
Ozone (O_3)	1-hour	235 ^b	235 ^b	NA	NA
	8-hour	157 ^c	157 ^c	NA	NA
Lead (Pb)	Quarterly	1.5 ^g	NA	NA	NA
a Not to be exceeded more than once per year. b Not to be exceeded more than once per year on average. c 3-year average of annual 4th highest concentration. d The pre-existing form is exceedance-based. The revised form is the 99th percentile. e Spatially averaged over designated monitors. f The form is the 98 th percentile. g Never to be exceeded. h $\mu\text{g}/\text{m}^3$, micrograms per cubic meter. () SAAQS Concentration.					

It is important to note that implementation of some proposed NAAQS, the $\text{PM}_{2.5}$ standards, and the 8-hour ozone standard have been delayed. The delay is due to recent court decisions and the need to develop additional ambient air quality data and compliance assessment procedures.

3.2 Non-attainment New Source Review

Because Polk County is currently designated as “unclassifiable” or “attainment” for all criteria pollutants, the Project is not subject to non-attainment new source review.

3.3 Prevention of Significant Deterioration (PSD)

The federal PSD regulations affect areas classified as “unclassifiable” or “attainment” with respect to the NAAQS. Polk County is classified as such for all criteria pollutants.

As part of an ambient air quality impact analysis, a facility classified as a new major source or major modification must demonstrate compliance with the NAAQS, and with the PSD increments shown in Table 3-2. The PSD regulations require assessments of potential impacts to soils and vegetation and to growth and visibility in the area surrounding the proposed plant.

Additionally, facilities within 100 kilometers (km) of a Class I (wilderness) area must also perform an assessment of potential impacts to Class I area(s). The Class I area closest to the Project is the Chassahowitzka National Wildlife Refuge (NWR). This Class I area is located approximately 108 km northwest of the Facility site, and therefore is beyond the distance for which an impact analysis is required under the PSD Rules. However, the Federal Land Manager for this area has asked that an analysis be performed and included with this application (Section 4.9).

A new major source in “unclassifiable” or “attainment” areas that will result in net emissions increases greater than the significant emissions increase levels presented in Table 3-3 is subject to PSD review. Other pollutants for which EPA promulgated annual emission thresholds are not listed because the new equipment will burn natural gas as the primary fuel producing negligible emissions of these pollutants. The annual emission thresholds shown in Table 3-3 are exceeded for NO_x, SO₂, CO, and PM/PM₁₀. Accordingly, the proposed project's new power generation equipment is subject to PSD permitting requirements for these air pollutants.

**Table 3-3 PSD Significant Emissions Increase Level and CPV Pierce Project,
Net Emission Rates (Pursuant to 40 CFR 52.21 (b) (23) (i))**

Pollutant	Significant Emissions Increase Level (TPY)	Annual Net Emissions Increases (TPY)
NO _x	40	125
SO ₂	40	76
CO	100	226
PM	25	100
PM ₁₀	15	100
VOC	40	15

3.4 New Source Performance Standards (NSPS)

Combustion Turbine

The new combustion turbine associated with the Project is subject to the provisions of 40 CFR Part 60 Subpart GG (New Source Performance Standards for Combustion Turbines). NSPS Subpart GG affects combustion turbines having a maximum firing capacity greater than 10 million Btu per hour and constructed after October 1977. The emission standards contained in the NSPS rule, limit flue gas concentrations of NO_x and SO₂.

The NO_x limit is 75 parts per million (ppm) (based on the turbine heat rate and the fuel bound nitrogen). The SO₂ limit is 150 ppm (or 0.8 percent sulfur in fuel). Additionally, the provisions of this subpart require the installation of a Continuous Emission Monitoring System (CEMS) to monitor fuel consumption and water to fuel ratio. Subpart GG also requires monitoring of fuel sulfur and nitrogen content and allows for the development of a custom schedule to monitor these parameters.

The new power generation equipment will combust natural gas and 0.05 percent sulfur content distillate oil. The proposed fuels contain less than 0.8 percent sulfur, complying with the NSPS requirements for SO₂.

The combined-cycle combustion turbine will generate no more than 9 ppm of NO_x prior to the addition of SCR controls and no more than 3.5 ppmvd@15% O₂ after the SCR controls when

firing natural gas. Backup distillate firing will generate no more than 10 ppmvd@15% O₂ of NO_x. Therefore, the combustion turbine will comply with the requirements of NSPS Subpart GG for NO_x.

Fuel Oil Storage Tank

The Facility plans to install and operate a 975,000 gallon above ground fuel oil storage tank. Due to its size this tank is subject to the provisions of 40 CFR 60, Subpart Kb, Standards of Performance for Volatile Organic Liquid Storage Vessels for which Construction Commenced after July 23, 1984. Specifically, this Subpart requires record keeping as stated in Section 60.116b, which includes the dimensions of the tank, and an analysis showing the capacity of the vessel.

3.5 National Emission Standards for Hazardous Air Pollutants

New stationary combustion turbines are subject to 40 CFR Part 63, Subpart B – Requirements for the Control Technology Determinations for Major Sources in Accordance with Clean Air Act Sections 112(g) and 112(j). This regulation requires a case-by-case determination of the Maximum Achievable Control Technology (MACT) for major sources that exceed the annual emission thresholds of 10 tons per year for an individual Hazardous Air Pollutant (HAP) or 25 tons per year for total HAP emissions.

Because the Project is using clean fuels (natural gas and distillate oil), total Project HAP emissions do not exceed the regulatory thresholds. Emission calculations for HAPs are provided in Appendix C and are based on AP-42 emission factors, Fifth Edition, April 2000 for all HAPs. Total Project emissions of each HAP are less than 10 tons per year and less than 25 total tons; therefore, the Project is not subject to this regulation.

3.6 Acid Rain Program

Title IV of the 1990 Clean Air Act amendments required EPA to establish a program to reduce emissions of acid rain-forming pollutants, called the Acid Rain Program. The overall goal of the Acid Rain Program is to achieve significant environmental benefits through reductions in SO₂ and NO_x emissions. To achieve this goal, the program employs both traditional and market-based approaches for controlling air pollution.

Under the federal program, EPA allocates existing units SO₂ allowances. The affected facilities may use their allowances to cover emissions, or may trade their allowances to other units under a market-trading program. In addition, subject facilities are required to implement continuous emissions monitoring systems (CEMS) for affected units. The CEMS requirements of the Acid Rain Program include: an SO₂ concentration monitor; a NO_x concentration monitor; a volumetric flow monitor; an opacity monitor; a diluent gas (O₂ or CO₂) monitor; and a computer-based data acquisition and handling system for recording and performing calculations.

Beginning in 2000, the Federal Acid Rain Program's annual emission limitations became effective. The new combustion turbine will not be given an annual emissions budget under the Federal Acid Rain Program. The new combustion turbine will obtain SO₂ allowances through the market-trading program. The new power generation equipment incorporates the appropriate CEMS equipment in its design.

3.7 Operating Permit

The CPV Facility is subject to the Federal Clean Air Act (CAA) Title V operating permit program. The Florida DARM regulations implementing the CAA Title V program are contained in Rule 62-213. The operating permit specifies the applicable regulatory requirements with which the CPV Facility must comply and the methods used to demonstrate compliance. CPV will comply with the rule requirements as necessary.

3.8 Risk Management Plan (RMP)

In the case of a new facility, compliance with the RMP rule requires that the plan be submitted before the regulated substance is present at the facility above the applicable regulatory threshold. Because the SCR control technology proposed for the Project will utilize aqueous ammonia with a concentration of less than 20 percent, a RMP will not be required for the Project.

3.9 Florida Air Permit Application

The purpose of the new source permitting process is to ensure that a proposed facility will be in compliance with all applicable federal and state regulatory requirements.

The Project requires the submittal of an Air Permit Application under the Florida permitting rules. Based on the regulatory applicability review presented in the previous sections, the application for the new power generation equipment is expected to include the following analyses:

- Air quality modeling study demonstrating compliance with state and federal ambient air quality standards and increments; and
- Federal PSD review for SO₂, NO_x, PM/PM₁₀, and CO.

The Application is submitted to DARM for review and approval. The initial step in the agency review of the application is a completeness determination. Once the application is deemed complete, DARM conducts its review and issues a proposed permit for public review. A public hearing may be held and any comments addressed before issuing final approval.

Section 4

Assessment Of Impacts

4.0 ASSESSMENT OF IMPACTS

Due to limitations in the spatial and temporal coverage of air quality measurements, monitoring data normally are not sufficient to demonstrate the adequacy of emission limits for existing sources. Also, the impacts of new sources that do not yet exist can only be determined through modeling. Thus, dispersion models have become the primary analytical tools in most air quality impact assessments.

The following subsections describe the evaluation of the Project ambient air quality impacts. The air quality modeling study was conducted using data, assumptions, and procedures consistent with FDEP modeling guidelines and was based on discussions with FDEP modeling staff to determine specific model input requirements and compliance criteria.

4.1 Emission and Stack Parameters

The new power generation equipment will operate over a range of load conditions typically from 50 to 100 percent. Operation below 50 percent load will only occur briefly during startup or shutdown. The equipment vendor developed emissions and representative stack parameters for the combined-cycle system. Expected emissions for combinations of representative local ambient temperature range and load conditions for natural gas and distillate oil firing were provided to represent the range of operating conditions. These data are summarized in the following tables.

Table 4-1 contains the expected stack parameters for each of the operating conditions evaluated for the proposed power generation equipment. Table 4-2 contains the estimated emission rates for all operating scenarios modeled for the proposed power generation equipment based on vendor data currently available.

For demonstration of compliance purposes, if the maximum predicted air quality impact of the new power generation equipment for a specific pollutant and averaging time is below the

modeling significance impact levels shown in Table 3-2, no additional air quality modeling is required.

Table 4-1 Stack Exhaust Parameters CPV Pierce Project		
Stack Height: 175 feet		
Stack Diameter: 18.5 feet		
Case ID	Temperature	Velocity
Temperature (°F)/% Load	(°F)	(feet/second)
Natural Gas		
25/50	166	40.5
25/75	172	50.4
25/100	184	65.2
59/50	173	40.0
59/75	177	48.5
59/100	186	61.5
59/100PA	181	64.4
72/50	168	39.2
72/75	172	47.2
72/100	181	59.2
72/100PA	187	63.0
97/50	175	38.3
97/75	179	45.9
97/100	188	55.8
97/100PA	183	58.3
Low Sulfur Distillate Oil		
25/50	255	46.8
25/75	258	58.0
25/100	285	78.6
59/50	255	45.8
59/75	265	56.4
59/100	284	73.8
72/50	255	45.4
72/75	265	55.4
72/100	284	71.4
97/50	259	44.1
97/75	270	53.2
97/100	284	66.0

Table 4-2 Power Generation Equipment Projected Criteria Pollutant Emissions for the CPV Pierce Project (lb/hr)

Load Condition (%)	50	75	100	50	75	100	100PA	50	75	100	100PA	50	75	100	100PA
Ambient Temperature (°F)	25	25	25	59	59	59	59	72	72	72	72	97	97	97	97
Combined-Cycle Unit with Emission Controls															
Natural Gas															
SO ₂	6	8	10	6	8	9	10	6	7	9	9	6	7	8	9
NO _x	15	19	24	14	18	23	23	14	18	22	23	13	17	20	21
CO	20	25	31	19	23	29	50	19	23	28	49	18	21	26	45
PM	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19
Distillate Oil															
SO ₂	62	79	99	59	75	93		58	73	91		53	68	83	
NO _x	49	63	80	47	60	75		46	58	73		42	54	67	
CO	53	65	70	52	62	66		51	60	63		49	57	57	
PM	41	42	44	40	42	44		40	42	44		40	41	43	

PA=Power Augmentation Operating Scenario

4.2 Good Engineering Practice (GEP) Stack Height Calculation

The Project site is located in a rural setting with no existing nearby buildings that have the potential to affect plume dispersion from the combustion turbine stacks. The HRSG, associated with the combined-cycle unit, is the only structure with physical dimensions that could potentially affect plume dispersion. The HRSG height is 88 feet above grade and is connected to the stack. Appendix B contains a site drawing showing structure location and dimensions.

A mechanical draft cooling tower will be constructed at the site consisting of five cells. The combined dimensions of the five contiguous cells will be approximately 250 feet long, 50 feet wide, and 31 feet in height with fan top height of 45 feet. The fan opening at the top of each cell is approximately 32.8 feet in diameter. The cooling tower is to be located to the west of the power production equipment (see Site Plan in Appendix B) with the long axis oriented northeast to southwest. A two cell waste water cooling tower will also be used for waste water treatment to achieve zero liquid discharge. The combined dimensions of the two contiguous cells will be 40 feet long by 30 feet wide by 18 feet height, with fan top heights of 45 feet. The entire structure will be elevated 20 feet above ground level such that the release height is 45 feet. The fan opening is approximately 14 feet in diameter. The location of the waste water tower (15 feet to the southwest of the five-cell tower) is shown on the site plan drawing included in Appendix B. As the cooling towers are sources of PM_{10} , they were included in the GEP analysis.

The GEP stack height analysis was done following the procedures outlined in the Guideline for Determination of Good Engineering Practice Stack Height (Technical Support Document For the Stack Height Regulations, Revised, EPA-450/4-80-023R, June 1985).

Direction specific building downwash dimensions were determined using the EPA's BPIP software for the combustion turbine stack assuming a height of 175 feet. Each building's location and dimensions and the location of the proposed stack and cooling towers were input to calculate the maximum building downwash height and projected width for each 10-degree sector surrounding the stack or emission point. Version 3 of the Industrial Source Complex Short Term model (ISCST3) was used to predict air quality impacts. Input files for ISCST3 included the 36

pairs of effective building height and projected width values for the stack and the cooling tower cells generated by BPIP.

The GEP height regulations allow stack heights up to 65 meters without any need for a demonstration. The height of the stacks for this Project will be below 65 meters, therefore, they will comply with the GEP regulations.

Appendix D-1 includes the input and output files from the GEP program and a graphic showing the location of the stacks and buildings.


4.3 Land Use Determination

The ISCST3 model allows the option to include atmospheric dispersion coefficients characteristic of urban or rural land use. The determination of which set of dispersion coefficients to use is based on the land use within a three-kilometer (3km) radius circle centered on the project site, referred to as the Auer method. Figure 4-1 illustrates the area within a 3 km radius considered in the land use determination.

The Project site is located near the town of Pierce, Florida on land owned by IMC in southwestern Polk County. The site is characterized as previously mined and reclaimed land. The land use within three kilometers of the station is predominately rural residential and agricultural. Based on the EPA-recommended Auer technique, the land use within the 3 km circle is considered rural.

4.4 Background Air Quality

FDEP maintains a network of ambient air monitors to evaluate existing air quality throughout the state. The existing air quality in the area of the Project site is described using data available from the EPA AIRS database monitoring network.



**TRC Environmental
Corporation**

5 Waterside Crossing
Windsor, CT 06095
(860) 289-8631

CPV Pierce

FIGURE 4-1

Land Use Analysis
3 km Radius

Date: April 10, 2001

Project No. 31325

The most recent three years (1998 to 2000) of available data from nearby monitoring locations were analyzed to determine representative ambient concentrations of criteria pollutants of interest. The highest annual average and highest second-high short-term concentrations were identified, as appropriate, for each air contaminant. Table 4-3 lists the monitoring stations, and the classifications of their associated land uses, selected to determine existing ambient levels in the vicinity of the Project site.

The air contaminant measurements are summarized in Table 4-4. The short-term levels, e.g., 24-hours or less, are the second highest average values for each year. As can be seen from Table 4-4, existing ambient levels of all pollutants are well below their respective NAAQS and SAAQS.

Table 4-3 Air Quality Monitoring Stations

Monitor Address	Land Use	Location Type	Monitor ID
E.G.Simmons County Park, Tampa, (NO ₂)	NA	NA	12-057-0081-1
Anderson & Pinecrest Rd., Mulberry, (PM ₁₀ & SO ₂)	Industrial	Rural	12-105-0010-1
One Raider Place, Plant City, (CO)	Residential	Suburban	12-057-4004-1

Table 4-4 Existing Air Quality

Pollutant	Station	Averaging Time	Units	Concentration			
				NAAQS (SAAQS)	1998	1999	2000
NO ₂	Tampa	Annual	ppm	0.053	0.006	0.007	0.007
SO ₂	Mulberry	3-hour	ppm	0.5	0.069	0.052	0.062
		24-hour	ppm	0.14 (0.1)	0.027	0.019	0.018
		Annual	ppm	0.03 (0.02)	0.006	0.006	0.005
PM ₁₀	Mulberry	24-hour	µg/m ³	150	48	38	30
		Annual	µg/m ³	50	24.0	26.9	21.8
CO	Plant City	1-hour	ppm	35	2.6	2.4	2.2
		8-hour	ppm	9.0	1.5	1.3	1.3

4.5 Meteorological Data

Five years of hourly surface meteorological data (1987 to 1991) from Tampa International Airport were used to model the emission impacts for the proposed Facility. This observation station is located approximately 40 miles to the west-northwest of the Project site. The meteorological data sets consist of hourly values of wind speed and direction, temperature, stability class, and mixing height.

Wind roses for the years 1987 through 1991, individually and cumulatively, are contained in Appendix D-2. The predominant winds are from the east, east-northeast, and northeast, occurring approximately 30 percent of the time for the three compass directions combined for the five years of data used in the modeling. Calm winds occur on an average of about 6 percent each year.

4.6 Receptors

A polar receptor grid was developed to assess the air quality impacts in the Project vicinity. Receptor rings were located at 100-meter intervals from the combustion turbine stack location (polar grid center at $x=0.0$, $y=0.0$) out to a distance of 2.0 kilometers. Receptor rings were also placed at 200-meter increments out to a distance of 5 km. From 5 km to 10 km the rings were placed at 500-meter intervals and at 1 km intervals out to 20 km distance. A total of 1980 polar receptors were used.

Receptors were also placed around the plant and fence-line at approximately 50-meter intervals for a total of 26 receptors. Polar receptors located within the fence line were then deleted, leaving a total of 1974 receptors.

A more refined receptor grid was used in the PM_{10} impact analysis to insure capture of the maximum impact from the low level cooling tower emission points. A 10 meter refined grid was generated beyond the fence line out to 200 meters in all directions.

Receptor terrain elevations were set to zero along with the stack base elevation as recommended by FDEP.

4.7 Modeling Approach

TRC conducted the modeling study after consultation with FDEP, and consistent with the preceding discussions using EPA and FDEP approved methods.

Refined modeling was conducted using the ISCST3 model to demonstrate compliance with ambient air quality standards and/or significant impact levels (SILs). ISCST3 is preferred by EPA and other agencies for refined modeling because ISCST3 can simulate atmospheric dispersion associated with multiple stacks, simple, intermediate and complex terrain, and building wake effects. Rural dispersion coefficients were used, as more than 50 percent of the land use within a three-kilometer radius circle centered on the Project site is classified as rural.

ISCST3 was run to predict concentrations using the regulatory default option, which includes:

- Stack-tip downwash;
- Buoyancy-induced dispersion;
- Final plume rise;
- Calm wind processing;
- Default wind profile exponents;
- Default vertical potential temperature gradients; and
- Use of upper bounds for super-squat buildings having an influence in the lateral dispersion of the plume.

The ISCST3 model was run with the simple terrain processing option selected as recommended by FDEP.

The modeling was conducted for each air contaminant and for the proposed power generation equipment operating scenarios using the five years of Tampa International Airport meteorological data. If the maximum predicted impact is less than the SIL for a particular pollutant and averaging time, then no further assessment is required.

4.8 Predicted Impacts

Impacts predicted by the ISCST3 model are presented for each criteria pollutant and averaging time for the Project's emissions. The short-term air quality impacts are documented for natural gas and backup low-sulfur distillate oil firing. The annual impacts are conservatively reported as the annual maximum average concentration predicted for all operating scenarios and fuel burned.

In assessing the impacts of the proposed new combustion turbines, the ISCST3 model was run for all operating cases using case-specific emission rates. The predicted impacts were then compared to the appropriate pollutant and averaging period SILs. PM_{10} combined impacts from the combustion stack and the cooling towers were also evaluated using the ISCST3 model with appropriate model input parameters for each source. The model input and output files for each scenario modeled are provided on a CD included in Appendix D-3. A summary of the scenarios modeled and results is provided in Appendix D-4.

4.8.1 Sulfur Dioxide (SO_2)

The maximum predicted 3-hour average impact for the five years of meteorological data modeled for the stack emissions is $9.6 \mu\text{g}/\text{m}^3$ (distillate) and $1.6 \mu\text{g}/\text{m}^3$ (natural gas). For the 24-hour average, the model predicted maximum impacts of $2.5 \mu\text{g}/\text{m}^3$ (distillate) and $0.5 \mu\text{g}/\text{m}^3$ (natural gas). These impacts are well below the 3-hour and 24-hour SO_2 SILs of 25.0 and 5.0 $\mu\text{g}/\text{m}^3$, respectively.

The maximum annual average SO_2 impact is predicted to be $0.06 \mu\text{g}/\text{m}^3$. This maximum impact is well below the annual SIL of $1.0 \mu\text{g}/\text{m}^3$.

4.8.2 Nitrogen Dioxide (NO_2)

The modeled maximum annual average impact of the oil-fired and gas-fired scenarios was predicted to be $0.05 \mu\text{g}/\text{m}^3$, which is well below the annual SIL of $1.0 \mu\text{g}/\text{m}^3$.

4.8.3 Carbon Monoxide (CO)

The modeled CO impacts for low-sulfur distillate oil firing are $23 \mu\text{g}/\text{m}^3$ and $4.4 \mu\text{g}/\text{m}^3$ for the 1-hour and 8-hour averaging periods, respectively. The predicted CO impacts for natural gas firing are $13.5 \mu\text{g}/\text{m}^3$ and $2.8 \mu\text{g}/\text{m}^3$ for the 1-hour and 8-hour averaging periods, respectively. With SILs for one-hour of $2,000 \mu\text{g}/\text{m}^3$ and for 8-hours of $500 \mu\text{g}/\text{m}^3$, the predicted CO impacts from the proposed project are well below the SILs.

4.8.4 Particulate Matter (PM_{10})

The maximum predicted PM_{10} impacts for the combustion turbines for the 24-hour averaging period when firing low sulfur distillate oil is $2.1 \mu\text{g}/\text{m}^3$ ($1.7 \mu\text{g}/\text{m}^3$ firing natural gas) and for the maximum annual average is $0.04 \mu\text{g}/\text{m}^3$. The 24-hour and annual SILs for PM_{10} are 5.0 and $1.0 \mu\text{g}/\text{m}^3$, respectively.

The cooling towers are sources of PM_{10} emissions as dissolved solids and suspended particles in the cooling water will become airborne particles once the water from the drift droplets evaporates. A table of parameters used to develop the PM_{10} emission rates from the cooling towers is provided in Appendix C.

In addressing impacts from the cooling tower, it was assumed that the five cells operate continuously. This is a conservative assumption as the combustion turbine may not always be operating at maximum load and/or atmospheric conditions of temperature and dew point may not always require operation of all cells even when the combustion turbine is operating at full load.

Due to the location of the cooling tower on the project property, the maximum impacts are close to the property line. With the assumptions listed above, the maximum 24-hour impact due to the combustion turbine stack, waste water and cooling towers is $4.7 \mu\text{g}/\text{m}^3$ at a receptor located to the southwest of the cooling tower, approximately 60 meters south of the proposed fenced area. At the location and date on which the cooling tower is predicted to have a maximum impact, the combustion turbine contributes approximately one $\mu\text{g}/\text{m}^3$. The combined maximum annual impact from all particulate matter sources is predicted to be $0.2 \mu\text{g}/\text{m}^3$. Comparing these results with the applicable 24-hour and annual SILs, e.g. 5.0 and $1.0 \mu\text{g}/\text{m}^3$, respectively, the predicted maximum impacts are below PSD significance levels.

4.9 Class I Area Analyses

The PSD regulations provide special protection from adverse air quality impacts to national parks and wilderness areas designated as Class I areas. These areas are considered to be of special national or regional value due to their natural, scenic, recreational or historic significance, and as such, increases of pollutants in these areas are strictly limited. The regulations require any PSD permit applicant proposing to construct a source within 100 kilometers of a PSD Class I area to demonstrate through air quality modeling that the emissions from the proposed source will not cause or contribute significantly to any violation of established allowable increments, i.e., PSD Class I increments, or degradation of Air Quality Related Values, (AQRVs). In addition, if the proposed source is of such size and is located at a distance greater than 100 kilometers from a PSD Class I area, the reviewing agency or Federal Land Manager (FLM) can require the applicant to perform an analysis of the source's potential impact on the Class I area.

The Chassahowitzka National Wildlife Refuge (NWR) is located approximately 108 kilometers to the northwest of the proposed Facility. However, consistent with previous submittals and preliminary conferences with the FDEP and Fish and Wildlife Service (FWS) it was determined that, due to the proximity to the NWR and the potential emissions from the proposed Facility, modeling analyses should be performed to estimate pollutant impacts at the NWR. The analyses that were recommended during our preliminary discussions to demonstrate the impacts of the proposed Facility to Chassahowitzka NWR are as follows:

- Demonstration of compliance with the applicable PSD Class I area increments, and
- Analyses of impacts of the Project emissions to regional haze.

Recent guidance has been issued on the methods and procedures to follow in performing the above analyses. It was the intent of CPV and TRC to perform all necessary analyses in accordance with the following major sources of guidance:

- Direct guidance provided by representatives of FDEP, and FWS during project conferences,
- Interagency Work Group on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts; EPA-454/R-98-019, OAQPS, December, 1998 (herein referred to as the IWAQM guidance), and
- Federal Land Managers' Air Quality Related Values Work Group (FLAG); Phase I Report (December, 2000); USDA/FS, NPS and FWS (herein referred to as the FLAG guidance).

4.9.1 PSD Class I Increments

The primary means of limiting air quality degradation in Class I areas is by stringent limits imposed on the allowable increments, or increases above base line values of SO₂, PM₁₀ and NO₂. Table 4-5 provides a summary of the PSD Class I increments and the proposed "significance level" values.

Table 4-5 PSD Class I Increments and Significance Levels in $\mu\text{g}/\text{m}^3$			
Pollutant	Averaging Period	Class I Increment	Significance Level
SO ₂	Annual	2	0.1
	24-Hour	5	0.2
	3-Hour	25	1.0
PM ₁₀	Annual	4	0.2
	24-Hour	8	0.3
NO ₂	Annual	2.5	0.1

If it can be demonstrated through dispersion modeling that the proposed source does not contribute to an increase in any concentration above the proposed significance levels at the Class I area, the source is deemed “insignificant” and no additional increment analyses are required. If modeled concentrations are predicted to be above significance levels then further analyses are required to demonstrate that the source does not contribute to adverse air quality conditions.

4.9.2 Regional Haze

Class I areas that are greater than 50 kilometers from a source are evaluated for uniform or regional haze impairment. Regional haze is a general alteration in the appearance of landscape features or the sky, changing the color or contrast between landscape features or causing features of a view to disappear. As plumes are transported over large distances they become well mixed in the atmosphere and may contribute to regional haze.

Regional haze calculations involve estimating the change in atmospheric light extinction relative to natural conditions. Changes in light extinction are measured in deciview units. The level of concern for visibility impairment is whether or not it is perceptible to an observer. The level of concern currently adopted by FLMs is a 5 percent change in extinction (FLAG, 2000). If the predicted change in extinction from new source emissions is less than 5 percent as compared against natural conditions, the FLMs will generally approve of the project. For visibility impairment predicted to be above 5 percent, more refined analyses are required to demonstrate that the proposed Facility’s emissions do not contribute significantly to unacceptable regional haze conditions.

4.9.3 Model Selection

Air quality modeling analyses performed to demonstrate compliance with SAAQS/NAAQS and PSD increments generally follow guidance provided by EPA in the Guideline on Air Quality Models (EPA Guidance), i.e., Appendix W to 40 CFR 51, and/or in guidance provided by FDEQ. Both of these guidelines recognize that the range of the preferred models recommended is 50 km. Beyond 50 km, there are currently no preferred models recommended. EPA, however,

is currently reviewing two newly proposed models for inclusion in the guideline. These are the AERMOD model and the CALMET/CALPUFF modeling system.

Based on discussions with the FDEP and FWS it was agreed that the most appropriate method for evaluating the impacts of the facility emissions on the Chassahowitzka NWR Class I area is the application of the CALPUFF model for increment and regional haze analyses. The underlying basis of the recommendation is reliance on the IWAQM recommendation and modeling guidance for long-range pollutant transport. The IWAQM modeling recommendations for long-range pollutant transport and evaluation of impacts on visibility impairment, deposition and pollutant transformation is the CALPUFF modeling system. Consistent with other modeling guidance, IWAQM also recommends two levels of modeling sophistication, a screening level analysis which relies on simplified meteorological and default model inputs, and a refined analysis which requires a much more rigorous treatment of meteorological transport parameters. Screening level analyses are designed to provide conservatively high results, therefore a demonstration of compliance with appropriate significance levels based on these analyses will not require further modeling.

4.9.4 CALPUFF Modeling

Table 1 of the IWAQM Phase 2 Summary Report outlines a methodology for performing a PSD Class I area screening analysis using the CALPUFF model. The screening analysis makes use of CALPUFF in a simple "screening mode" whereby a single station meteorology file is used instead of a wind field. The CALPUFF model is run with 5 years of a single station meteorology file to estimate concentration impacts, pollutant deposition and visibility impacts at the PSD Class I areas. If the model results indicate that the proposed source impacts are below specific thresholds, then no further analyses are required.

A PSD Class I area screening analysis was performed for the proposed CPV Facility using the CALPUFF model (Version 5.4 Level 000602-1). The data used for this analysis and the procedures for performing the analysis are described below.

4.9.4.1 Meteorology

For the CALPUFF screening analysis, surface meteorological data and upper air (mixing height) data for Tampa, Florida for the 5-year period 1986-1990 were used. These data were obtained from available sources in the Solar and Meteorological Surface Observation Network (SAMSON) format, and processed using the Meteorological Processor for Regulatory Models (MPRM) to produce a data set for CALPUFF. Since MPRM does not process the relative humidity and solar radiation data needed for CALPUFF chemistry mechanisms, it was necessary to post-process the MPRM data to include these parameters. (Note that for the Class I area analysis the period of data (1986-1990) differs from the period used for the Class II area analysis (1987-1991) due to the availability of data in the SAMSON format).

4.9.4.2 Receptors

The CALPUFF screening analysis requires receptors placed at least every two degrees on rings that encircle the source and pass through the Class I area boundaries of interest. For Chassahowitzka NWR, modeling receptors were placed at one-degree increments along three rings spaced at 108, 118 and 128 kilometers, to represent the closest, mid-point and furthest extent of the NWR from the CPV Facility. Flat terrain was assumed at each receptor point.

4.9.4.3 Source Emissions and Dispersion Characteristics

The major sources of emissions of criteria pollutants of interest will be emitted from fuel combustion. The emissions will vary as a function of fuel, load and ambient temperature. The equipment manufacturer has provided emission and stack parameter data for various representative scenarios of load, ambient temperature and humidity, and for natural gas and distillate oil fuels. These scenarios are summarized in Tables 4-1 and 4-2. For the Class I analysis, since the Chassahowitzka NWR is over 100 kilometers from the proposed Facility, it can be assumed that the conditions that result in the highest emissions rates lead to the worst-case, i.e., highest impacts, at the NWR. Therefore for the Class I area analyses the maximum

emissions rates and the associated stack parameters were used. The conditions associated with this criterion occur during the combustion of distillate oil.

4.9.5 CALPUFF Level I Modeling Procedures

A CALPUFF input control file was developed for a 400 x 400 kilometer modeling domain that extends to 5000 meters in the vertical. Default CALPUFF switch settings along with MESOPUFF II chemistry were used. CALPUFF default values for background ozone concentrations (80 ppb) and background ammonia (10 ppb) were used for this analysis. The modeling domain was set for rural dispersion. Both wet and dry deposition switches were invoked.

The MESOPUFF II chemistry algorithm requires the pollutant species SO_2 , sulfate (SO_4), NO_x , nitrate (NO_3), and nitric acid (HNO_3) to be included for a model run. SO_2 and NO_x are the primary pollutants emitted and SO_4 , NO_3 , and HNO_3 are secondary pollutants produced as a result of the in-transit chemistry mechanism. Each of these pollutant species was included in the CALPUFF model run. NO_x , HNO_3 , and SO_2 were modeled with gaseous deposition and SO_4 , NO_3 , and HNO_3 were modeled using particle deposition.

In addition, PM_{10} emissions were included in the CALPUFF modeling, with particle deposition invoked. A particle size distribution obtained from AP-42 Table 3.1-1 (Emission Factors for Large Uncontrolled Gas Turbines) was used to speciate the PM_{10} emissions. This distribution assumes all the particulate emissions are less than or equal to 1 micron. The distribution is given in Table 4-6.

<p align="center">Table 4-6</p> <p align="center">Gas Turbine Particle Size Distribution</p>		
Particle Size (μm)	Mass Weighted Particle Size (μm)	Particle Distribution (percent)
< 0.05	0.031	16
< 0.10	0.078	48
< 0.15	0.127	72
< 0.20	0.176	85
< 0.25	0.226	93
< 1.0	0.692	100

The CALPUFF model was run for each of the 5 years of meteorology to determine concentration and deposition values of SO_2 , SO_4 , NO_x , NO_3 , HNO_3 , and PM_{10} . CALPUFF hourly concentration output files were generated.

4.9.5.1 CALPOST Processing

The CALPOST processor was used to process the CALPUFF hourly concentration files to produce time averaged concentrations, and visibility results for comparison to specific significance or threshold values.

4.9.6 PSD Class I Increment Modeling Results

CALPOST was used to process the CALPUFF concentration file to compute maximum concentration values for SO_2 (3-hour, 24-hour, and annual averages), PM_{10} (24-hour, and annual averages) and NO_2 (annual average). The maximum predicted values compared with PSD Class I area significance levels are listed in Table 4-7. As is shown in Table 4-7 the maximum predicted concentrations at the Chassahowitzka NWR are all below the Class I significance levels.

Table 4-7 Maximum Predicted Concentrations at Chassahowitzka NWR			
Pollutant	Averaging Period	Maximum Predicted Concentration ($\mu\text{g}/\text{m}^3$)	Significance Level ($\mu\text{g}/\text{m}^3$)
SO ₂	Annual	0.014	0.1
	24-Hour	0.12	0.2
	3-Hour	0.47	1.0
PM ₁₀	Annual	0.007	0.2
	24-Hour	0.06	0.3
NO ₂	Annual	0.006	0.1

Digital copies of the model input and output files supporting these results are provided in digital form on the CD provided in Appendix D.

4.9.7 Regional Haze Modeling Results

An analysis of visibility impairment (regional haze) was performed using the CALPUFF predicted sulfate, nitrate, and particulate concentrations. This method for estimating visibility impairment evaluates potential extinction changes over a 24-hour averaging period.

For this analysis, the CALPUFF modeled concentrations of SO₄, NO₃, and fine particles (PM₁₀) were used to determine the change in light extinction from background conditions. CALPOST was used following the FLAG recommended screening mode (MVISBK=6) to process visibility parameters. This procedure computes extinction coefficients using seasonal relative humidity factors and background extinction data provided in the FLAG report, in combination with CALPUFF predicted particle species concentrations. The background extinction data and relative humidity factors for Chassahowitzka NWR are given in Table 4-8.

<p align="center">Table 4-8</p> <p align="center">Background Extinction Data and Relative Humidity Factors</p> <p align="center">for Chassahowitzka NWR</p>				
	Components of Dry Extinction			
Season	Hygroscopic (Mm⁻¹)	Non-Hygroscopic (Mm⁻¹)	Raleigh (Mm⁻¹)	Relative Humidity Factor
Winter	0.9	8.5	10.0	3.4
Spring	0.9	8.5	10.0	3.7
Summer	0.9	8.5	10.0	4.1
Fall	0.9	8.5	10.0	3.9

The background extinction components are provided for combined dry hygroscopic and non-hygroscopic components of extinction. The dry hygroscopic components are ammonium sulfate, and ammonium nitrate and the non-hygroscopic components are soil, organics, elemental carbon and coarse mass particles. The hygroscopic values were adjusted for the scattering coefficients of sulfate and nitrate particles, i.e., divided by three, and input to CALPOST as the variable BKSO4. The non-hygroscopic species were input directly into CALPOST as the variable BKSOIL.

CALPOST was then used to compute the daily (24-hour) light extinction change from the background conditions for each day in the 5-year period. The maximum predicted change in light extinction was 3.0 percent. Since the threshold for visibility impairment is 5 percent change in light extinction, the proposed CPV Facility will not adversely impact the visibility at the Chassahowitzka NWR. Digital copies of the model input and output files are provided on the CD included in Appendix D.

4.10 Summary of Project Impacts

Emissions from the proposed Project have been evaluated using appropriate modeling methods and source data. All impacts from the Facility operation are predicted to be below the applicable

standards or limits and in all cases are below the significance levels established for these limits. Table 4-9 summarizes the predicted impacts relative to the applicable standards or limits. Based on these results, the proposed Facility will not have a significant impact on any of the potentially impacted areas.

Table 4-9 CPV Pierce Project Summary of Applicable Limits and Predicted Impacts

Pollutant/AQVR	Averaging Period	NAAQS ($\mu\text{g}/\text{m}^3$)		PSD Class II ($\mu\text{g}/\text{m}^3$)				PSD Class I			
		Primary	Secondary	Increment	SILs	Predicted Impacts	Significant Impact?	Increment	SILs	Predicted Impact	Significant Impact?
Sulfur Dioxide (SO_2)	3-hour	N/A	1300 ^a	512 ^a	25	9.6	NO	25	1.0	0.47	NO
	24-hour	365 ^a (260)	N/A	91 ^a	5	2.5	NO	5	0.2	0.12	NO
	Annual	80 ^b (60)	N/A	20 ^b	1	0.06	NO	2	0.1	0.014	NO
Nitrogen Dioxides (NO_2)	Annual	100 ^b	100 ^b	25 ^b	1	0.05	NO	2.5	0.1	0.006	NO
Carbon Monoxide (CO)	1-hour ^a	40,000	N/A	N/A	2000	23	NO	N/A	N/A	N/A	N/A
	8-hour ^a	10,000	N/A	N/A	500	4.4	NO	N/A	N/A	N/A	N/A
Particulate (PM_{10})	24-hour	150 ^c	N/A	30 ^a	5	4.7	NO	8	0.3	0.06	NO
	Annual	50 ^b	N/A	17 ^b	1	0.2	NO	4	0.2	0.007	NO
Regional Haze ^d									5 %	3 %	NO

a Not to be exceeded more than once per year.

b Never to be exceeded.

c The pre-existing form is exceedance-based. The revised form is the 99th percentile.

d Regional Haze predicted for the Chassahowitzka NWR.

() SAAQS Concentration.

Section 5

Control Technology Analysis

5.0 CONTROL TECHNOLOGY ANALYSIS

A control technology analysis has been performed for the new power generation equipment based upon guidance presented in the draft EPA document, New Source Review Workshop Manual (October 1990). Control technology requirements for each pollutant depend upon the Project area's attainment status and the potential emissions of the pollutant. Air contaminants subject to non-attainment New Source Review (NSR) must apply Lowest Achievable Emission Rate (LAER) technology and those subject to PSD review must apply Best Available Control Technology (BACT).

Section 5.1 outlines the degree of control required (LAER or BACT) for each air contaminant, as determined in Section 3.0. Section 5.2 presents an overview of the "Top-Down" BACT assessment procedure used in this analysis. The procedure used in the economic analysis for technically feasible control options is detailed in Section 5.2.2. Sections 5.3 through 5.6 present control technology determinations for CO, SO₂, PM/PM₁₀ and NO_x respectively, for the proposed power generation equipment.

Note that throughout this section, "ppm" concentration levels for gaseous pollutants are parts per million by volume, dry basis, corrected to 15 percent O₂ content (ppmvd @ 15% O₂), unless otherwise noted.

5.1 Applicability of Control Technology Requirements

An applicability determination, as discussed in this section, is the process of determining the level of emissions control required for each applicable air pollutant. Control technology requirements are generally based upon the potential emissions from the new or modified source and the attainment status of the area in which the source is to be located. A detailed determination of applicable regulations, including control technology requirements under the PSD and non-attainment rules, is provided in Section 3.0. The following sections discuss the applicability of BACT and LAER for emissions from equipment included in this permit application.

5.1.1 PSD Contaminants Subject To BACT Under PSD Review

Pollutants subject to PSD review are subject to BACT analysis. BACT is defined as an emission limitation based on the maximum degree of reduction, on a case-by-case basis, taking into account energy, environmental and economic impacts. Based upon the regulatory applicability analysis in Section 3.0, the proposed Facility is considered a major source for PSD purposes since potential emissions exceed the major source threshold. Therefore, individual regulated pollutants are subject to PSD review, including the BACT requirement, unless potential annual emission rate increases are below the significant emission rates presented in 40 CFR 52.21(b)(23)(i) and summarized in Table 3-3. A PSD area is defined as an attainment area. Based upon these criteria, the federal BACT requirements for the proposed project apply to SO₂, PM/PM₁₀, CO, and NO_x emissions.

5.1.2 Non-Attainment Pollutants Subject To LAER

Emissions of pollutants subject to non-attainment NSR must be limited to LAER levels. LAER is defined as either the most stringent emission limitation contained in a State Implementation Plan (SIP) (unless it is demonstrated to not be achievable) or the most stringent emission limitation which is achieved in practice by the class or category of source, whichever is the most stringent without regard to cost. The Project location is classified as attainment or unclassifiable for all criteria pollutants. Therefore, LAER requirements, including a control technology determination, are not applicable for any pollutant.

5.2 Approach Used in BACT Analysis

As explained in Section 5.1, the new power generation equipment is subject to federal PSD BACT requirements for emissions of CO, SO₂, PM/PM₁₀, and NO_x. As previously stated, BACT defined under federal rules is the optimum level of control applied to pollutant emissions based upon consideration of energy, economic, and environmental factors. In a BACT analysis, the energy, economic, and environmental factors associated with each alternate control technology are evaluated, from the most stringent (top) technology and then proceeding to lesser degrees of control. The BACT analyses presented here consist of up to five steps for each pollutant, as outlined below.

5.2.1 Identification of Technically Feasible Control Options

The first step is identification of available technically feasible control technology options, including consideration of transferable and innovative control measures that may not have previously been applied to the source type under analysis. The minimum requirement for a BACT proposal is an option that meets federal NSPS limits or other minimum state or local requirements that would prevail in the absence of BACT decision-making, such as Reasonably Available Control Technology (RACT) or Florida emission standards. After elimination of technically infeasible control technologies, the remaining options are to be ranked from the top down by control effectiveness.

If there is only a single feasible option, or if the applicant is proposing the most stringent alternative, no further analysis is required. If two or more technically feasible options are identified, the next three steps are applied to identify and compare the energy, economic, and environmental impacts of the options. Technical considerations and site-specific sensitive issues will often play a role in BACT determinations. If the most stringent technology is rejected as BACT, the next most stringent technology is evaluated and so on.

In order to identify options for each class of equipment, a search of the EPA RACT/BACT/LAER Clearinghouse (RBLC) has been performed. Individual searches were performed for each pollutant emitted from the new power generation equipment. Results of the RBLC searches are summarized in Appendix E.

5.2.2 Economic (Cost-Effectiveness) Analysis

The cost-effectiveness evaluation relies on engineering estimates, vendor quotations, internal costing estimates, and environmental agency costing guidelines. The EPA guidance documents used in this analysis include the Office of Air Quality Planning and Standards (OAQPS) Control Cost Manual, (USEPA, EPA 450/B-96-001, February 1996) and Alternate Control Techniques Document—NO_x Emissions from Stationary Gas Turbines, (USEPA, EPA 453/R-93-007, January 1993). The basic principles and assumptions used in the economic analysis are summarized below.

The economic portion of the BACT review consists of computing the ratio of the annualized cost of each emission control option to the annual emission reduction it can produce, represented as

dollars per ton. The annualized cost of each emission control option has two components; the annualized total capital investment and the annual operating and maintenance cost.

The total capital investment (TCI) is the sum of the total direct costs (TDC) and total indirect costs. Direct costs are defined as the capital investment required to purchase equipment needed for the control system. Examples of direct costs include purchased equipment costs (PEC) and installation. Indirect costs include costs for site and building preparation, and contingency.

The PEC for a technically feasible control technology is based upon vendor quotations and engineering estimates for the control system specific to the proposed unit. Assumptions used to estimate elements of the TCI are provided as follows, unless site-specific values were available:

- Sales Tax - 6% of PEC;
- Freight - 4% of PEC;
- Installation - 35% of PEC;
- Engineering Costs - 5% of TDC; and
- Contingency - 3% of Direct and Indirect Costs.

These assumptions are based on recent guidance and comments provided by both EPA Region IV and FDEP for similar turbine installations. The indirect installation costs also include engineering, construction and field expenses, contractor fees, start-up and performance testing.

The capital recovery factor (CRF) is used to convert capital cost estimates into equivalent annualized costs. In order to annualize capital costs, an interest rate and project life must be estimated. When the CRF is multiplied by the capital investment, the product is the uniform end-of-year payment necessary to repay the investment in a defined amount of years. The CRF can be calculated based upon the following equation:

$$CRF = \frac{i * (1+i)^n}{(1+i)^n - 1}$$

Where i = interest rate and n = number of years of the investment.

A 7% nominal interest rate has been selected for this evaluation. The investment life, n , has been assumed equal to a ten-year payback period. These values are consistent with values presented

in the "OAQPS Control Cost Manual" and the latest update from William Vatauvuk's companion text. Therefore, the TCI has been amortized over a ten-year period at a 7% interest rate.

The total annual operating cost is defined as the expenses associated with the annual operation of the control equipment and is the sum of the direct annual costs and indirect annual costs. Direct annual costs include operating and supervisory labor, maintenance labor, and materials required to operate the control equipment. Direct annual costs also include catalyst replacement and utility costs. Indirect annual costs include overhead, property taxes, insurance and administration (including environmental reporting) associated with the operation of the control equipment. Assumptions used to estimate elements of the annual operating cost are as follows:

- Maintenance Labor - 1% of TCI;
- Maintenance Materials - 1% of TCI;
- Overhead - 60% of labor and maintenance materials;
- Property Tax - 1% of TCI;
- Insurance - 1% of TCI; and
- Administration - 2% of TCI.

Specific costing factors for feasible alternatives are identified in the appropriate pollutant-specific section. An economic analysis is not required if the most effective emission control option is proposed or if there are no technically feasible control options. An economic impact analysis was performed as part of the NO_x control technology review process and the CO control technology review.

5.2.3 Energy Impact Analysis

Two forms of energy impacts that may be associated with a control option can normally be quantified. Increases in energy consumption resulting from increased heat rate may be shown as incremental Btus or fuel consumed per year. Also, the installation of a control option may reduce the output and/or reliability of the proposed equipment. This reduction would result in assumed loss of revenue from "lost" electric power sales to the local utility.

5.2.4 Environmental Impact Analysis

The primary focus of the environmental impact analysis is the reduction in ambient concentrations of the pollutant being controlled. Increases or decreases in emissions of other

criteria or non-criteria air contaminants may occur with some technologies, and should also be identified. Non-air impacts, such as solid waste disposal and increased water consumption/treatment, may be an issue for some projects and control options.

5.2.5 BACT Proposal

The determination of BACT for each air pollutant and emissions unit is based on a review of the three impact categories and the technical factors that affect feasibility of the control alternatives under consideration. The methodology described above is applied to the proposed Facility for the following pollutants: CO, SO₂, PM/PM₁₀ and NO_x.

5.3 BACT Analysis for Carbon Monoxide

The proposed Project will consist of a combustion turbine and a non-supplementally fired HRSG. The formation of CO in the operation of a combustion turbine is the result of incomplete combustion of fuel. Several conditions can lead to incomplete combustion, including insufficient O₂ availability, poor air and fuel mixing, cold wall flame quenching, reduced combustion temperature, decreased combustion residence time and load reduction. By controlling the combustion process carefully, CO emissions can be minimized. The following sections address BACT elements for the proposed turbine.

5.3.1 Identification of Technically Feasible Control Options

The proposed GE model 7241FA turbine has inherently low CO emissions, due to the dry low-NO_x combustion technology employed. GE 7241FA turbine CO emissions on natural gas are among the lowest offered for utility-scale units across the anticipated load range of 50% to 100% load. Turbine emissions for each unit are guaranteed to be no more than 9 ppm for this load range during gas fired operation and no more than 20 ppm during oil-fired operation. The part-load emissions, in particular, compare favorably to other turbine models; some combustion turbine models have CO emissions of 100 ppm or greater at the 50% load level.

After combustion control, the only practical control method to reduce CO emissions from combustion turbine units is an oxidation catalyst. Exhaust gases from the combustion turbine are passed over a catalyst bed where excess air oxidizes the CO to carbon dioxide. CO reduction efficiencies in the range of 80 to 90 percent can be guaranteed, although CO reduction may be somewhat less than the design value at the very low inlet concentrations that are expected for the

proposed turbine. A location downstream of the turbine or within the HRSG may be identified that will provide temperatures appropriate for the effective oxidation catalyst operation. Since the temperature profile will change with changing turbine load, a catalyst would be placed for optimum performance at full-load while providing some lesser degree of control at other load points. Likewise, since catalyst temperature is critical to the oxidation process, the oxidation catalyst will not be effective during combustion turbine start-up until the catalyst temperature is elevated to the necessary level. No other technically feasible options are identified for combustion turbine CO control.

Drawbacks of the oxidation catalyst include added cost, reduced turbine output and efficiency due to increased back pressure, and the potential for increased PM_{10} and/or sulfuric acid mist emissions, as outlined in the following three subsections. For base-loaded units with the low emissions projected for these turbines, such controls may be ruled out as BACT, due to the high cost per ton of pollutant control. For this reason, the application of oxidation catalysts on turbines is limited; only five facility permits in the BACT/LAER Clearinghouse indicate the use of an oxidation catalyst as a control.

The energy losses associated with the use of an oxidation catalyst for CO control include reduced electrical output due to increased back-pressure, as well as the potential for lost generating capacity associated with any unplanned shutdowns for catalyst change-out, maintenance, and replacement.

A listing of economic, energy and environmental impacts associated with the proposed technology is provided under the following three subsections followed by the detailed proposal of BACT limits for the units.

5.3.2 Environmental Impacts of Technically Feasible CO Controls

Based upon modeling results, all predicted CO impacts fall well below significance levels defined in the PSD regulations. Therefore, the differences in emission rates with and without the catalyst do not correlate to meaningful differences in air quality impacts. A possible benefit of using catalysts would be the oxidation of VOCs as well as CO, although the proposed VOC emissions are already quite low (maximum of 1.4 ppm) and VOC control efficiencies have not generally been guaranteed for catalysts on combustion turbines at these low emission levels. A drawback of the higher temperature catalyst location needed to reduce VOC emissions is the increased oxidation of SO_2 to SO_3 . Higher SO_3 concentrations increase the potential for

formation of sulfuric acid mist and ammonium sulfate and sulfite with ammonia slip from the NO_x controls. These substances not only add to PM/PM₁₀ emissions, but also may condense and stick to the ductwork and stack, resulting in corrosion and increased maintenance.

5.3.3 Energy Impact of Oxidation Catalyst

The energy losses associated with the use of an oxidation catalyst for CO control include reduced electrical output (193 kW reduction, or a total of, 1,686,300 kW-hr lost per year assuming a 90% capacity factor) due to increased back-pressure, as well as the potential for lost generating capacity associated with any unplanned shutdowns for catalyst change-out, maintenance, and replacement. The increase in heat rate predicted to result from the catalyst, 9 Btu/kW-hr, corresponds to an additional 16,265 MMBtu fuel consumption per year.

5.3.4 Economic Impact of Oxidation Catalyst

The initial capital cost for the catalyst is \$861,280, based upon an estimate from a catalyst vendor that includes installation and contingency for the GE 7FA combustion turbine. Calculations of other costs used to derive an equivalent annual cost for the technology are detailed in Appendix E. The greatest factors in the annual operating cost are periodic catalyst replacement (a three-year guarantee is typical for a catalyst), lost revenue due to reduced turbine output and increased fuel cost due to adverse effect on turbine heat rate, or efficiency. Equivalent annual cost for this technology (annualized capital plus annual O&M costs) is \$352,436 per year. The uncontrolled CO emission levels of 9 ppm during natural gas firing and 20 ppm during oil firing can be reduced to 2 ppm and 4 ppm by an oxidation catalyst. Therefore, of the uncontrolled annual emissions of 156 tons of CO per year, an oxidation catalyst would control 125 tons (estimated 80% control efficiency) of CO per year. The annual operating scenario used in the calculation (turbine operation at 100% load for 8040 hours per year firing gas and 720 hours per year firing oil) is conservative since it maximizes the tons of CO available for control by the catalyst. Since the catalyst vendor does not guarantee CO removal during start-up, these emissions are not included in the calculation. The resulting cost-effectiveness per turbine is \$2,824 per ton, which is calculated as follows:

$$(\$352,436/\text{yr})/(124.8 \text{ tons CO controlled}/\text{yr}) = \$2,824/\text{ton CO}$$

5.3.5 BACT Proposal

The use of advanced dry low-NO_x turbine combustion technology is proposed as BACT for CO emissions. Therefore, the proposed CO emission limits are 9 ppm during natural gas firing for operating loads greater than 50% and 15 ppm during periods of power augmentation at 100% load. During distillate fuel oil firing the proposed limit is 20 ppm at 100% load. See Appendix C for CO concentrations at other loads.

The proposed BACT emission limits for CPV Pierce are the same as those approved by FDEP for the identical CPV Gulfcoast and CPV Atlantic projects in Florida. For each of those projects, FDEP concluded that the installation of an oxidation catalyst was not warranted because actual CO emission rates are expected to be much less than the proposed limits, and continuous emissions monitoring systems (CEMS) will be employed to verify this expected performance. However, in response to EPA comments regarding the previous CPV projects, FDEP established permit limits that restrict operation "... in power augmentation mode to 2000 hours unless CPV installs [an] oxidation catalyst or proves that actual performance is much better than guaranteed (thus rendering control not cost effective)".

CPV therefore also proposes to accept a temporary limit of 2000 operating hours per year in power augmentation mode and the use of CEMS to record actual CO emission rates for the CPV Pierce Project. It is expected that when actual CO emission rates from the GE 7241FA combined-cycle system are demonstrated in practice to be much lower than currently guaranteed, thus confirming that installation of an oxidation catalyst would not be cost-effective, CPV Pierce will request a permit modification and FDEP will rescind the 2000 hour limit on annual operations in the power augmentation mode.

5.4 BACT Analysis for Sulfur Dioxide

Strategies for the control of SO₂ emissions can be divided into pre- and post-combustion categories. Pre-combustion controls entail the use of low sulfur fuels or fuel sulfur removal. Post-combustion controls comprise various wet and dry flue gas de-sulfurization (FGD) processes. However, FGD alternatives are undesirable for use on combustion turbine power facilities due to high pressure drops across the device, and would be particularly impractical for the large flue gas volumes and low SO₂ concentrations.

The new power generation equipment will fire natural gas as the primary fuel (0.0065% sulfur by weight) and 0.05% sulfur distillate oil as back up, which is considered BACT for SO₂ emissions. Based on these clean fuels, the proposed maximum SO₂ emission rate for natural gas firing is 10 lb/hr and for distillate oil firing is 99 lb/hour.

5.5 BACT Analysis for Particulate Matter

5.5.1 Combustion Turbine

Particulate matter (PM/PM₁₀) emissions from combustion turbines are inherently very low, arising from impurities in combustion air and fuel, primarily from noncombustible metals present in trace quantities in liquid fuels. As a practical matter, turbine fuel specifications generally require that trace metals in the liquid fuel be kept to no more than a few parts per million to mitigate the potential deleterious action of PM/PM₁₀ on turbine blades. Other sources of PM/PM₁₀ include minerals in the injection water and PM/PM₁₀ present in the combustion air and NH₃/sulfur salt formation due to the presence of the SCR.

The use of clean burning fuels, such as natural gas, is considered to be the most effective means for controlling PM/PM₁₀ emissions from combustion equipment. Post-combustion controls, such as baghouses, scrubbers, and electrostatic precipitators are impractical due to the high pressure drops associated with these units and the low concentrations of PM/PM₁₀ present in the exhaust gas. A review of PM/PM₁₀ emission limits for combustion turbines presented in the RBLC search shows that only good combustion techniques and low-sulfur fuel have been used as controls for PM/PM₁₀ emissions.

Because the Facility plans to fire natural gas as the primary fuel and low sulfur (0.05%) distillate oil as the back-up fuel, the combination of clean fuels and good combustion is considered BACT for PM/PM₁₀ emissions. The proposed front and back half emission limits for PM/PM₁₀ are 19 lb/hr during natural gas firing, and 44 lb/hr during distillate oil firing, which includes ammonium sulfates due to the SCR catalyst.

5.5.2 Cooling and Waste Water Towers

PM/PM₁₀ emissions from the cooling towers occur because wet cooling towers provide direct contact between the cooling water and the air passing through the tower. Some of the liquid water may be entrained within the air stream and be carried out of the tower as "drift" droplets.

Therefore, the PM/PM₁₀ constituent (suspended and dissolved solids) of the drift droplets may be classified as an emission. Because drift droplets contain the same chemical impurities as the water circulating through the tower, these impurities can be converted into airborne emissions. To reduce drift from cooling towers, drift eliminators are usually incorporated into the tower design to prevent water droplets from leaving the tower and therefore reduce particulate emissions. The only alternative would be to reduce the solids content of the water, either by water treatment or by reducing the cycles of concentration. A review of PM/PM₁₀ emission limits for cooling towers, presented in the RBLC search, identifies drift eliminators as the most stringent control technique option for PM/PM₁₀ emissions.

Drift eliminators will be incorporated into both the cooling tower and waste water tower design specifications, which will limit drift from the cooling tower to less than 0.0005 percent of the circulating water flow rate.

5.6 BACT Analysis for Nitrogen Oxides

The formation of NO_x is determined by the interaction of chemical and physical processes occurring within the combustion chamber of the turbine. There are two principal forms of NO_x designated as "thermal" NO_x and "fuel" NO_x. Thermal NO_x formation is the result of oxidation of atmospheric nitrogen contained in the inlet gas in the high-temperature, post-flame region of the combustion zone. The major factors influencing thermal NO_x formation are temperature, concentrations of nitrogen and oxygen in the inlet air and residence time within the combustion zone. Fuel NO_x is formed by the oxidation of fuel-bound nitrogen. Fuel NO_x is responsible for only a small amount of the total NO_x formed in the combustion process. Adjusting the combustion process and/or installing post-combustion controls can control NO_x formation.

Typical gas turbines are designed to operate at a fuel to air ratio of 1.0. This is the point where the highest combustion temperature and quickest combustion reactions (including NO_x formation) occurs. Fuel-to-air ratios below 1.0 are referred to as fuel-lean mixtures (i.e., excess air in the combustion chamber) and fuel-to-air ratios above 1.0 are referred to as fuel-rich (i.e., excess fuel in the combustion chamber). The rate of NO_x production falls off dramatically as the flame temperature decreases. Very lean dry combustors can be used to control emissions.

Based upon this concept, lean combustors are designed to operate below the 1:1 ratio thereby reducing thermal NO_x formation within the combustion chamber. The lean combustors typically are two staged premixed combustors designed for use with natural gas fuel and capable of

operation on liquid fuel. The first stage serves to thoroughly mix the fuel and air and to deliver a uniform, lean, unburned fuel-air mixture to the second stage. The GE 7241FA turbine utilizes a dry low-NO_x combustion system, which produces expected uncontrolled NO_x emissions of 9 ppm during natural gas firing.

5.6.1 Identification of Technically Feasible Control Options


The "Top-Down" policy for BACT analysis starts at the lowest achievable emission rate (LAER) for NO_x. To determine the most stringent permit limit, a search of the RBLC was performed. For a limit to be considered LAER, it requires more than just the issuance of a permit. If a facility was never built or operated, or has not demonstrated compliance through stack testing and/or continuous emissions monitoring, the facility's emission limits have not been demonstrated to be achievable and are not considered LAER.


The most stringent permitted NO_x emission limit (LAER driven) for combustion turbines, at the time of this permit application, is 2.0 ppm for the 32 MW Federal Merchant Plant in Los Angeles. Goal Line, the owner, has requested recognition of 1.3 ppmvd NO_x as achieved in practice.

The new SCONO_x technology has been installed on a 32 MW natural gas-only plant using GE LM 2500 turbines. The facility is owned and operated by one of the parent companies of Goal Line Technologies, the SCONO_x technology developer. To date, this technology has achieved a NO_x emission rate comparable to those considered LAER or BACT at other facilities using SCR. The NO_x emission rate would not be lower with this technology based on information provided to date.

A recent assessment of the SCONO_x technology (Appendix E) determined that this technology was not technically feasible based in part on the recent experience with the technology on a small (5 MW) combustion turbine. The SCONO_x system on this turbine is not able to meet the vendor guarantees.

SCR is an add-on NO_x control technique that is placed in the exhaust stream following the gas turbine. SCR involves the injection of ammonia (NH₃) into the exhaust gas stream upstream of a catalyst bed. On the catalyst surface, NH₃ reacts with NO_x contained within the air to form nitrogen gas (N₂) and water (H₂O) in accordance with the following chemical equations:





The catalyst's active surface is usually a noble metal (platinum), base metal (titanium or vanadium) or a zeolite-based material. Metal based catalysts are usually applied as a coating over a metal or ceramic substrate. Zeolite catalysts are typically a homogeneous material that forms both the active surface and the substrate. The geometric configuration of the catalyst body is designed for maximum surface area and minimum obstruction of the flue gas flow path in order to achieve maximum conversion efficiency and minimum backpressure on the gas turbine. The most common configuration is a "honeycomb" design. In a typical NH_3 injection system, NH_3 is drawn from a storage tank, vaporized and injected upstream of the catalyst bed. Excess NH_3 which is not reacted in the catalyst bed and which is emitted from the stack is referred to as NH_3 slip.

An important factor that affects the performance of an SCR is operating temperature. The temperature range for standard base metal catalyst is between 400 and 800 °F. Since the effective operating temperatures of SCRs are below combustion turbine exit temperatures, SCR controls are typically only used on combined-cycle units.

5.6.2 Environmental Impacts of a SCR Control System

SCR is often considered BACT for NO_x emissions on natural gas-fired combined-cycle combustion turbines in ozone attainment areas. It has been argued that dry low- NO_x turbines should not apply additional SCR controls as it can have a negative environmental effect. An SCR system involves injecting anhydrous or aqueous ammonia (NH_3) into the flue gas upstream of a catalyst bed. On the catalyst surface, NH_3 reacts with NO_x contained within the air to form nitrogen gas and water. The following environmental issues are a result of the addition of SCR controls to a combustion turbine flue gas stream:

Ammonia Slip Impacts

Ammonia salts (fine particle) formation - the presence of an SCR catalyst will increase the conversion of SO_2 to SO_3 , which may then react with water to form sulfuric acid, or with ammonia slip to form ammonium sulfates and sulfites (fine particles), resulting in increased total particulate matter emissions. Ammonium salts are corrosive and can stick to the heat recovery surfaces, ductwork, or the stack at low temperatures. Increased particulate emissions effect visibility and can cause human health problems.

Acidifying deposition – NO_x emissions contribute to the formation of acid aerosols, while ammonia neutralizes atmospheric acidity. Once deposited, however, derivatives of both NO_x and ammonia can contribute to the acidification of terrestrial soils and surface waters.

Eutrophication – when deposited on water surfaces, oxidized or reduced nitrogen promotes the growth of aquatic plants, such as algae, and the resulting bacteria consumes the oxygen in the water.

Possible conversion to nitrous oxide (N₂O) – once deposited on soil, a small fraction of ammonia emissions is converted by soil microbes to N₂O, which is a greenhouse gas and which depletes stratospheric ozone.

Ammonia Storage and Handling

Storage/Handling – an anhydrous or aqueous ammonia storage tank will be required at a facility utilizing SCR controls. Ammonia is identified by EPA as an extremely hazardous substance. It is toxic if swallowed or inhaled and can irritate or burn the skin, eyes, nose or throat. Additionally, ammonia vapors may form an explosive mixture with air.

Applicable requirements – facilities that handle over 10,000 pounds of anhydrous ammonia or more than 20,000 pounds of ammonia in an aqueous solution of 20% ammonia or greater must prepare a Risk Management Plan (RMP) and implement a Risk Management Program to prevent accidental releases.

Catalyst Disposal

Spent catalyst waste – the catalyst in the SCR degrades over time and needs to be replaced, about once every three years. The amount of spent catalyst waste is dependent on several factors, including the amount of catalyst used in the system, the life of the catalyst, and the amount of spent catalyst recycling that occurs.

5.6.3 Energy Impacts of a SCR Control System

The installation of a SCR control system in the flue gas stream has several operating effects on the combustion turbine and are listed as follows:

Pressure Drop

The SCR unit causes a pressure drop in the flue gas stream and the resultant backpressure exerted on the combustion turbine decreases the power output.

Heat Rate Increase

The pressure drop effect will result in an increased heat rate for the turbine to supplement the power loss.

Fuel Use Increase

The increase in the heat rate of the turbine will require additional fuel usage.

Revenue Loss from Maintenance/Malfunctions

The facility may experience unplanned shutdowns for catalyst change-out, maintenance, and replacement. Downtime periods of combustion turbines result in revenue losses for a facility, since the turbines can only operate with the SCR controls working properly.

The following table is a demonstration of how the proposed SCR controls effects the performance of the GE 7421FA combustion turbine:

Table 5-1 Energy Impacts of SCR Controls			
Pressure Drop Across SCR System (inches H₂O)	Lost Output Due to Pressure Drop (kW-hr/yr)	Increased Heat Rate of Combustion Turbine (Btu/kW-hr)	Additional Fuel Consumption Due to Heat Rate Increase (MMBtu/yr)
3.7	4,082,160	24.7	37,310

Notes:

1. Increased heat rate based on pressure drop. Similar project experienced a 10 Btu/kw-hr increase due to a 1.5 pressure drop from a control device.
2. Annual lost electrical output and additional fuel consumption based on 8,760 hours of operation.

5.6.4 Economic Impact of SCR Control System

In addition to having technical problems, SCONO_x control technology is significantly more expensive than SCR. An economic analysis is provided in Appendix E. The estimated levelized cost per ton of NO_x removal for the SCONO_x technology is \$22,786/ton per year. The SCR annualized cost per ton, which is the proposed control technology for NO_x removal, totaled \$2,606/ton per year.

5.6.5 BACT Proposal

The SCONO_x control technology is not a demonstrated technology and SCR technology is significantly less expensive than SCONO_x for the same level of NO_x control. Therefore, the use of SCR technology is proposed as BACT for NO_x emissions from the combined cycle equipment. Proposed BACT emission limits are 3.5 ppm (24.0 lb/hr) NO_x during natural gas firing and 10 ppm (80.0 lb/hr) NO_x during distillate oil firing. The 3.5 ppmvd NO_x limit during natural gas firing has previously been accepted as BACT by the FDEP.

5.7 BACT Summary


This BACT analysis was based on similar recent analyses performed and submitted with other CPV applications. The FDEP has recently reviewed these applications and the proposed BACT and has concurred with the determinations. The following table summarizes the proposed BACT limits, assuming full load operations, for the proposed Facility.

Table 5-2 Summary of Proposed BACT Limits for the CPV Pierce Project

Pollutant	Control Technology	Proposed BACT Limit
Nitrogen Oxides	Low - NO _x Combustion Technology Selective Catalytic Reduction	3.5 ppmvd @ 15% O ₂ (gas) 10 ppmvd @ 15% O ₂ (oil)
Carbon Monoxide	Combustion Controls	9 ppmvd (gas) 15 ppmvd (power augmentation mode, temporarily limited to 2000 hr/yr) 20 ppmvd (oil)
Particulate Matter- Combined-Cycle System	Inherently Clean Fuels Combustion Controls	19 lb/hr (gas) 44 lb/hr (oil)
Particulate Matter- Cooling and Waste Water Towers	High Efficiency Mist Eliminators	0.0005% drift
Sulfur Dioxide and Sulfuric Acid Mist	Low Sulfur Fuels	0.0065% S (gas) 0.05% S (oil)

Appendix A

Air Permit Application Forms



Department of Environmental Protection

Division of Air Resources Management

APPLICATION FOR AIR PERMIT - TITLE V SOURCE

See Instructions for Form No. 62-210.900(1)

I. APPLICATION INFORMATION

Identification of Facility

1. Facility Owner/Company Name: CPV Pierce, Ltd.	
2. Site Name: CPV Pierce Power Generating Facility	
3. Facility Identification Number: [X] Unknown	
4. Facility Location: Street Address or Other Locator: City: Pierce County: Polk Zip Code:	
5. Relocatable Facility? [] Yes [X] No	6. Existing Permitted Facility? [] Yes [X] No

Application Contact

1. Name and Title of Application Contact: Patricia DiOrio; Manager, Development	
2. Application Contact Mailing Address: Organization/Firm: CPV Pierce, Ltd. Street Address: 35 Braintree Hill Office Park, Suite 107 City: Braintree State: MA Zip Code: 02184	
3. Application Contact Telephone Numbers: Telephone: (781) 848-0253 Fax: (781) 848-5804	

Application Processing Information (DEP Use)

1. Date of Receipt of Application:	4-18-01
2. Permit Number:	1050349-001-AC
3. PSD Number (if applicable):	PSD-FL-319
4. Siting Number (if applicable):	

Purpose of Application

Air Operation Permit Application

This Application for Air Permit is submitted to obtain: (Check one)

- ☐ Initial Title V air operation permit for an existing facility which is classified as a Title V source.
- ☐ Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number: _____

- ☐ Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number: _____

Operation permit number to be revised: _____

- ☐ Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.)

Operation permit number to be revised/corrected: _____

- ☐ Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.

Operation permit number to be revised: _____


Reason for revision: _____

Air Construction Permit Application

This Application for Air Permit is submitted to obtain: (Check one)

- ☒ Air construction permit to construct or modify one or more emissions units.
- ☐ Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.
- ☐ Air construction permit for one or more existing, but unpermitted, emissions units.

Owner/Authorized Representative or Responsible Official

1. Name and Title of Owner/Authorized Representative or Responsible Official: Gary Lambert, Executive Vice President
2. Owner/Authorized Representative or Responsible Official Mailing Address: Organization/Firm: CPV Pierce, Ltd. Street Address: 35 Braintree Hill Office Park, Suite 107 City: Braintree State: MA Zip Code: 02184
3. Owner/Authorized Representative or Responsible Official Telephone Numbers: Telephone: (781) 848-0253 Fax: (781) 848-5804
4. Owner/Authorized Representative or Responsible Official Statement: <i>I, the undersigned, am the owner or authorized representative*(check here [], if so) or the responsible official (check here [], if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.</i>  Signature APRIL 17, 2021 Date

* Attach letter of authorization if not currently on file.

Professional Engineer Certification

1. Professional Engineer Name: Scott G. Sumner Registration Number: 44352
2. Professional Engineer Mailing Address: Organization/Firm: TRC Street Address: 21 Technology Drive City: Irvine State: CA Zip Code: 92618
3. Professional Engineer Telephone Numbers: Telephone: (949) 727-9336 Fax: (949) 727-7399

4. Professional Engineer Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.


Signature

4-11-01
Date

(seal)

* Attach any exception to certification statement.

Scope of Application

Emissions Unit ID	Description of Emissions Unit	Permit Type	Processing Fee
--	General Electric 7241FA Combustion Turbine	AC1A	
--	Cooling Towers	AC1A	

Application Processing Fee

Check one: [☐] Attached - Amount: \$_____ [☐] Not Applicable

Construction/Modification Information**1. Description of Proposed Project or Alterations:**

Construction of an electrical power generation facility consisting of a combined-cycle system comprised of one 170-MW General Electric 7241 FA combustion turbine and heat recovery steam generator designed to power a steam turbine with an operational controlled generating capacity of 74.9 MW.

2. Projected or Actual Date of Commencement of Construction: To be determined**3. Projected Date of Completion of Construction: To be determined****Application Comment**

II. FACILITY INFORMATION

A. GENERAL FACILITY INFORMATION

Facility Location and Type

1. Facility UTM Coordinates: Zone: 17 East (km): 406.7 North (km): 3079.3			
2. Facility Latitude/Longitude: Latitude (DD/MM/SS): 27/50/5.34 Longitude (DD/MM/SS): 81/56/50.82			
3. Governmental Facility Code: 0	4. Facility Status Code: C	5. Facility Major Group SIC Code: 49	6. Facility SIC(s): 4911
7. Facility Comment (limit to 500 characters): CPV Pierce, Ltd. will install a power generating unit consisting of an efficient combustion turbine with heat recovery steam generator (HRSG). The gas turbine will provide approximately 170 MW of electrical power. The HRSG recovers otherwise lost heat from the gas turbine exhaust and provides steam energy to drive a steam turbine with an operationally controlled generating capacity of 74.9 MW. The new power generation equipment will be designed to meet federal Best Available Control Technology (BACT) standards, as appropriate for emissions control. The combustion turbine, HRSG, and steam turbine will be built on a 13 acre portion of the 75 acre Polk County property. The new power generation facility includes a 175-foot stack.			

Facility Contact

1. Name and Title of Facility Contact: Patricia DiOrio; Manager, Development
2. Facility Contact Mailing Address: Organization/Firm: CPV Pierce, Ltd. Street Address: 35 Braintree Hill Office Park, Suite 107 City: Braintree State: MA Zip Code: 02184
3. Facility Contact Telephone Numbers: Telephone: (781) 848-0253 Fax: (781) 848-5804

Facility Regulatory Classifications

Check all that apply:

1. <input type="checkbox"/> Small Business Stationary Source?	<input type="checkbox"/> Unknown
2. <input checked="" type="checkbox"/> Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)?	
3. <input type="checkbox"/> Synthetic Minor Source of Pollutants Other than HAPs?	
4. <input type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)?	
5. <input type="checkbox"/> Synthetic Minor Source of HAPs?	
6. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS?	
7. <input type="checkbox"/> One or More Emission Units Subject to NESHAP?	
8. <input type="checkbox"/> Title V Source by EPA Designation?	
9. Facility Regulatory Classifications Comment (limit to 200 characters): Combustion turbine subject to 40 CFR Part 60 Subpart GG.	

List of Applicable Regulations

Not Applicable	

B. FACILITY POLLUTANTS

List of Pollutants Emitted

[illegible]

C. FACILITY SUPPLEMENTAL INFORMATION

Supplemental Requirements

1. Area Map Showing Facility Location: [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable [] Waiver Requested
2. Facility Plot Plan: [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable [] Waiver Requested
3. Process Flow Diagram(s): [] Attached, Document ID: _____ [] Not Applicable [] Waiver Requested
4. Precautions to Prevent Emissions of Unconfined Particulate Matter: [] Attached, Document ID: _____ [] Not Applicable [] Waiver Requested
5. Fugitive Emissions Identification: [] Attached, Document ID: _____ [] Not Applicable [] Waiver Requested
6. Supplemental Information for Construction Permit Application: [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable
7. Supplemental Requirements Comment: Supplemental information includes air quality modeling study that demonstrates facility's maximum ambient air quality impacts are below Significant Impact Levels and emission control technology review that demonstrates facility's consistency with Best Available Control Technology requirements.

Additional Supplemental Requirements for Title V Air Operation Permit Applications

8. List of Proposed Insignificant Activities: <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
9. List of Equipment/Activities Regulated under Title VI: <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Equipment/Activities On site but Not Required to be Individually Listed <input type="checkbox"/> Not Applicable
10. Alternative Methods of Operation: <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements: <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
13. Risk Management Plan Verification: <input type="checkbox"/> Plan previously submitted to Chemical Emergency Preparedness and Prevention Office (CEPPO). Verification of submittal attached (Document ID:_____) or previously submitted to DEP (Date and DEP Office:_____) <input type="checkbox"/> Plan to be submitted to CEPPO (Date required:_____) <input type="checkbox"/> Not Applicable
14. Compliance Report and Plan: <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable
15. Compliance Certification (Hard-copy Required): <input type="checkbox"/> Attached, Document ID:_____ <input type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)

Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in This Section: (Check one)			
<input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
<input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
<input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): General Electric 107FA combustion turbine			
4. Emissions Unit Identification Number: ID: <input type="checkbox"/> ID Unknown			
5. Emissions Unit Status Code: C	6. Initial Startup Date: Fourth Quarter 2003	7. Emissions Unit Major Group SIC Code: 49	8. Acid Rain Unit? <input checked="" type="checkbox"/>
9. Emissions Unit Comment: (Limit to 500 Characters) Construction of a combined cycle power generation unit consisting of one 170-MW General Electric 7241FA combustion turbine and heat recovery steam generator designed to power a steam turbine with an operationally controlled generating capacity of 74.9 MW.			

Emissions Unit Control Equipment

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

Selective Catalytic Reduction (SCR) will be applied to the combined-cycle system.

2. Control Device or Method Code(s): 65

Emissions Unit Details

1. Package Unit:

Manufacturer: General Electric

Model Number: 7241FA

2. Generator Nameplate Rating:

170 MW

3. Incinerator Information:

Dwell Temperature:

°F

Dwell Time:

seconds

Incinerator Afterburner Temperature:

°F

B. EMISSIONS UNIT CAPACITY INFORMATION
(Regulated Emissions Units Only)**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	1,680 (natural gas)	1,898 (distillate) MMBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	hours/day	days/week
	weeks/year	8760 hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):		
Maximum heat input based on lower heating values of fuels:		
<ul style="list-style-type: none">• Natural gas - 20,958 Btu/lb• Distillate - 18,300 Btu/lb		

C. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)**List of Applicable Regulations**

Rule 62-204.220	Ambient Air Quality Protection
Rule 62-204.240	Ambient Air Quality Standards
Rule 62-204.260	Prevention of Significant Deterioration Increments
Rule 62-204.800	Federal Regulations Adopted by Reference
Rule 62-210.300	Permits Required
Rule 62-210.350	Public Notice and Comments
Rule 62-210.370	Reports
Rule 62-210.550	Stack Height Policy
Rule 62-210.650	Circumvention
Rule 62-210.700	Excess Emissions
Rule 62-210.900	Forms and Instructions
Rule 62-212.300	General Preconstruction Review Requirements
Rule 62-212.400	Prevention of Significant Deterioration
Rule 62-213	Operation Permits for Major Sources of Air Pollution
Rule 62-214	Requirements For Sources Subject To The Federal Acid Rain Program
Rule 62-296.320	General Pollutant Emission Limiting Standards
Rule 62-297.310	General Test Requirements
Rule 62-297.401	Compliance Test Methods
Rule 62-297.520	EPA Continuous Monitor Performance Specifications

C. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)**List of Applicable Regulations**

40 CFR 52.21	Prevention of Significant Deterioration
40 CFR 60	NSPS Subparts GG and Kb
40 CFR 60	Applicable sections of Subpart A, General Requirements
40 CFR 72	Acid Rain Permits (applicable sections)
40 CFR 73	Allowances (applicable sections)
40 CFR 75	Monitoring (applicable sections including applicable appendices)
40 CFR 77	Acid Rain Program-Excess Emissions (future applicable requirements)

D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram? See CPV-PI Appendix B. Drawing 99148-C1		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): Exhaust through a 175-foot stack			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 175 feet	7. Exit Diameter: 18.5 feet	
8. Exit Temperature: See CPV-PI °F	9. Actual Volumetric Flow Rate: See CPV-PI acfm	10. Water Vapor: See CPV-PI %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: 17 East (km): 406.7 North (km): 3079.3			
14. Emission Point Comment (limit to 200 characters): See CPV-PI, Appendix C for all operating conditions.			

E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)

Segment Description and Rate: Segment 1 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters): natural gas		
2. Source Classification Code (SCC): 20100201	3. SCC Units: Million Cubic Feet	
4. Maximum Hourly Rate: 1.91	5. Maximum Annual Rate: 16,714	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: 0.0065	8. Maximum % Ash:	9. Million Btu per SCC Unit: 881
10. Segment Comment (limit to 200 characters): Maximum Annual Rate based on operation at 8,760 hours/year		

Segment Description and Rate: Segment 2 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters): distillate oil		
2. Source Classification Code (SCC): 20100101	3. SCC Units: 1000 Gallons	
4. Maximum Hourly Rate: 14.71	5. Maximum Annual Rate: 10,592	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: 0.05	8. Maximum % Ash:	9. Million Btu per SCC Unit: 129.0
10. Segment Comment (limit to 200 characters): Maximum Annual Rate based on operation at 720 hours/year		

F. EMISSIONS UNIT POLLUTANTS
(All Emissions Units)

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
SO ₂			EL
NOX	65		EL
PM			EL
PM ₁₀			EL
CO			EL
VOC			EL

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: SO ₂	2. Total Percent Efficiency of Control:	
3. Potential Emissions: 10 (natural gas), 99 (distillate) lb/hour	75.8 tons/year	4. Synthetically Limited? []
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year		
6. Emission Factor: Reference: General Electric		7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Short term emissions: See CPV-PI Appendix C Values are maximum rates for all operating conditions Annual emissions: [(10 lb/hr) X (335 days/year) X (24 hr/day) + (99 lb/hr) X (30 days/year) X (24 hr/day)] / (2000 lb/ton) = 75.8 tons/year		
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Emissions are for worst case operating load condition. See CPV-PI, Appendix C for emissions at other load conditions		

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: Natural gas: 0.0065% (sulfur in fuel by weight) Distillate: 0.05% (sulfur in fuel by weight)	4. Equivalent Allowable Emissions: 10 (natural gas), 99 (distillate) lb/hour 75.8 tons/year.
5. Method of Compliance (limit to 60 characters): Fuel sampling	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Concentration limits apply for operating loads greater than 50%	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: NO _x	2. Total Percent Efficiency of Control:
3. Potential Emissions: 24.0 (natural gas), 80 (distillate) lb/hour 125.3 tons/year	4. Synthetically Limited? []
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: General Electric	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Short term emissions: See CPV-PI Appendix C Values are maximum rates for all operating conditions Annual emissions: $[(24.0 \text{ lb/hr}) \times (335 \text{ days/year}) \times (24 \text{ hr/day}) + (80 \text{ lb/hr}) \times (30 \text{ days/year}) \times (24 \text{ hr/day})] / (2000 \text{ lb/ton})$ = 125.3 tons/year	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
1. Requested Allowable Emissions and Units: Natural Gas: 3.5 ppmvd @ 15% O ₂ Distillate: 10 ppmvd @ 15% O ₂	4. Equivalent Allowable Emissions: 24.0 (natural gas), 80 (distillate) lb/hour 125.3 tons/year
5. Method of Compliance (limit to 60 characters): CEM - 3 hour block average	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Concentration limits apply for operating loads greater than 50%.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: PM	2. Total Percent Efficiency of Control:
3. Potential Emissions: 19 (natural gas), 44 (distillate) lb/hour 92.2 tons/year	4. Synthetically Limited? <input type="checkbox"/>
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: General Electric	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Short term emissions: See CPV-PI Appendix C Values are maximum rates for all operating conditions Annual emissions: $[(19 \text{ lb/hr}) \times (335 \text{ days/year}) \times (24 \text{ hr/day}) + (44 \text{ lb/hr}) \times (30 \text{ days/year}) \times (24 \text{ hr/day})] / (2000 \text{ lb/ton})$ = 92.2 tons/year	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 19 lb/hour (natural gas), 44 lb/hour (distillate)	4. Equivalent Allowable Emissions: 20 (natural gas), 44 (distillate) lb/hour 92.2 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test, USEPA Method 5	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Concentration limits apply for operating loads greater than 50%.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: PM ₁₀	2. Total Percent Efficiency of Control:
3. Potential Emissions: 19 (natural gas), 44 (distillate) lb/hour 92.2 tons/year	4. Synthetically Limited? []
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: General Electric	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Short term emissions: See CPV-PI Appendix C Values are maximum rates for all operating conditions Annual emissions: $[(19 \text{ lb/hr}) \times (335 \text{ days/year}) \times (24 \text{ hr/day}) + (44 \text{ lb/hr}) \times (30 \text{ days/year}) \times (24 \text{ hr/day})] / (2000 \text{ lb/ton})$ = 92.2 tons/year	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 19 lb/hour (natural gas), 44 lb/hour (distillate)	4. Equivalent Allowable Emissions: 19 (natural gas), 44 (distillate) lb/hour 92.2 tons/year
5. Method of Compliance (limit to 60 characters): Annual stack test, USEPA Method 5	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Concentration limits apply for operating loads greater than 50%.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: CO	2. Total Percent Efficiency of Control:
3. Potential Emissions: See CPV-PI Appendix C. lb/hour 226.2 tons/year	4. Synthetically Limited? []
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference: General Electric	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Short term emissions: See CPV-PI Appendix C Values are maximum rates at 100% operating load Annual emissions: $[(50 \text{ lb/hr}) \times (335 \text{ days/year}) \times (24 \text{ hr/day}) + (70 \text{ lb/hr}) \times (30 \text{ days/year}) \times (24 \text{ hr/day})] / (2000 \text{ lb/ton})$ $= 226.2 \text{ tons/year}$	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): Potential annual emission rate assumes continuous power augmentation when natural gas firing.	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 50 lbs/hr (natural gas), 70 lb/hr (distillate)	4. Equivalent Allowable Emissions: 50 lbs/hr (natural gas), 70 lb/hr (distillate), 226.2 tons/year
5. Method of Compliance (limit to 60 characters): 24-hr block average demonstrated by CEMS	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): See CPV-PI Appendix C.	

Emissions Unit Information Section 1 of 3

Pollutant Detail Information Page 6 of 6

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: VOC		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 3 (natural gas), 8 (distillate) lb/hour 14.9 tons/year		4. Synthetically Limited? []	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: Reference: General Electric		7. Emissions Method Code: 2	
8. Calculation of Emissions (limit to 600 characters): Short term emissions: See CPV-PI Appendix C Values are maximum rates for all operating conditions Annual emissions: $[(3 \text{ lb/hr}) \times (335 \text{ days/year}) \times (24 \text{ hr/day}) + (8 \text{ lb/hr}) \times (30 \text{ days/year}) \times (24 \text{ hr/day})] / (2000 \text{ lb/ton})$ = 14.9 tons/year			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code: OTHER		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: 1.4 ppmvw as CH ₄ (natural gas) 3.5 ppmvw as CH ₄ (distillate)		4. Equivalent Allowable Emissions: 3 (natural gas), 8 (distillate) lb/hour 14.9 tons/year	
1. Method of Compliance (limit to 60 characters): USEPA Method 25A			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Concentration limits apply for operating loads greater than 50%.			

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissions Limitation _____ of _____

1. Visible Emissions Subtype: VE20	2. Basis for Allowable Opacity: [X] Rule [] Other
3. Requested Allowable Opacity: Normal Conditions: 20% Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: Annual testing using USEPA Method 9	
5. Visible Emissions Comment (limit to 200 characters):	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)

Continuous Monitoring System: Continuous Monitor _____ of _____

1. Parameter Code: EM	2. Pollutant(s): NO _x , CO
3. CMS Requirement: [X] Rule	
4. Monitor Information: Manufacturer: Not yet determined Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):	

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)

Supplemental Requirements

1. Process Flow Diagram [] Attached, Document ID: _____ [] Not Applicable [] Waiver Requested
2. Fuel Analysis or Specification [] Attached, Document ID: _____ [] Not Applicable [] Waiver Requested
3. Detailed Description of Control Equipment [] Attached, Document ID: _____ [] Not Applicable [] Waiver Requested
4. Description of Stack Sampling Facilities [] Attached, Document ID: _____ [] Not Applicable [] Waiver Requested
5. Compliance Test Report [] Attached, Document ID: _____ [] Previously submitted, Date: _____ [X] Not Applicable
6. Procedures for Startup and Shutdown [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
7. Operation and Maintenance Plan [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
8. Supplemental Information for Construction Permit Application [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable
9. Other Information Required by Rule or Statute [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable
10. Supplemental Requirements Comment:

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)

Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in This Section: (Check one)			
<input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
<input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
<input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters):			
Fresh Water Cooling Tower			
4. Emissions Unit Identification Number:		<input checked="" type="checkbox"/> No ID	
ID:		<input type="checkbox"/> ID Unknown	
5. Emissions Unit Status Code:	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code:	8. Acid Rain Unit?
C	Fourth Quarter 2003	49	<input type="checkbox"/>
9. Emissions Unit Comment: (Limit to 500 Characters)			

Emissions Unit Control Equipment

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

High efficiency drift eliminators.

2. Control Device or Method Code(s): 15

Emissions Unit Details

1. Package Unit:	
Manufacturer: to be determined	Model Number:
2. Generator Nameplate Rating: MW	
3. Incinerator Information:	
Dwell Temperature:	°F
Dwell Time:	seconds
Incinerator Afterburner Temperature:	°F

B. EMISSIONS UNIT CAPACITY INFORMATION
(Regulated Emissions Units Only)**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr tons/day
3. Maximum Process or Throughput Rate:	75,000 gal/min
4. Maximum Production Rate:	
5. Requested Maximum Operating Schedule:	
	24 hours/day 7 days/week
	52 weeks/year 8760 hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters): Maximum process rate (Item 3) is cooling tower water circulation rate.	

C. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)

List of Applicable Regulations

D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram? Cooling Tower		2. Emission Point Type Code:	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 45 feet	7. Exit Diameter: 32.8 feet	
8. Exit Temperature: °F	9. Actual Volumetric Flow Rate: acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: 17 East (km): 406.6 North (km): 3079.1			
14. Emission Point Comment (limit to 200 characters): Cooling tower consists of 5 cells. Exhaust temperature and flow rate vary with changes in ambient temperature. UTM coordinates reference the middle cell.			

E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)

Segment Description and Rate: Segment 1 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Fresh water cooling tower re-circulation water flow rate.		
2. Source Classification Code (SCC):		3. SCC Units: 1000 gallons of water circulated
4. Maximum Hourly Rate: 4,500	5. Maximum Annual Rate: 39,420,000	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

Segment Description and Rate: Segment 2 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

F. EMISSIONS UNIT POLLUTANTS
(All Emissions Units)

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM/PM₁₀	015		NS

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: PM/PM ₁₀	2. Total Percent Efficiency of Control:
3. Potential Emissions: 0.79 lb/hour 3.5 tons/year	4. Synthetically Limited? []
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code: 3
8. Calculation of Emissions (limit to 600 characters): Short term emissions: See CPV-PI Appendix D-5 $[(0.79 \text{ lb/hr}) \times (8760 \text{ hr/year})] / (2000 \text{ lb/ton}) = 3.5 \text{ tons/year}$	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.0005% drift loss	4. Equivalent Allowable Emissions: 0.79 lb/hour 3.5 tons/year
5. Method of Compliance (limit to 60 characters): Cooling tower design and operation	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):	

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissions Limitation _____ of _____

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [] Rule [] Other
3. Requested Allowable Opacity: Normal Conditions: Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)

Continuous Monitoring System: Continuous Monitor _____ of _____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement: [] Rule	
4. Monitor Information: Manufacturer: Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):	

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)

Supplemental Requirements

1. Process Flow Diagram [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
2. Fuel Analysis or Specification [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
3. Detailed Description of Control Equipment [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable [] Waiver Requested
4. Description of Stack Sampling Facilities [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
5. Compliance Test Report [] Attached, Document ID: _____ [] Previously submitted, Date: _____ [X] Not Applicable
6. Procedures for Startup and Shutdown [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
7. Operation and Maintenance Plan [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
8. Supplemental Information for Construction Permit Application [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable
9. Other Information Required by Rule or Statute [] Attached, Document ID: _____ [X] Not Applicable
10. Supplemental Requirements Comment:

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)

Emissions Unit Description and Status

1. Type of Emissions Unit Addressed in This Section: (Check one)			
<input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.			
<input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.			
2. Regulated or Unregulated Emissions Unit? (Check one)			
<input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.			
<input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.			
3. Description of Emissions Unit Addressed in This Section (limit to 60 characters):			
Waste Water Tower			
4. Emissions Unit Identification Number:		<input checked="" type="checkbox"/> No ID <input type="checkbox"/> ID Unknown	
ID:			
5. Emissions Unit Status Code:	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code:	8. Acid Rain Unit?
C	Fourth Quarter 2003	49	<input type="checkbox"/>
9. Emissions Unit Comment: (Limit to 500 Characters)			
The waste water tower is a component of the zero water discharge system.			

Emissions Unit Control Equipment

<p>1. Control Equipment/Method Description (Limit to 200 characters per device or method):</p> <p>Special duty crossflow cooling tower with double drift eliminators and double louvers.</p>
<p>2. Control Device or Method Code(s): 15</p>

Emissions Unit Details

<p>1. Package Unit:</p> <p>Manufacturer: to be determined Model Number:</p>
<p>2. Generator Nameplate Rating: MW</p>
<p>3. Incinerator Information:</p> <p> Dwell Temperature: °F</p> <p> Dwell Time: seconds</p> <p> Incinerator Afterburner Temperature: °F</p>

B. EMISSIONS UNIT CAPACITY INFORMATION
(Regulated Emissions Units Only)**Emissions Unit Operating Capacity and Schedule**

1. Maximum Heat Input Rate:	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr tons/day
3. Maximum Process or Throughput Rate:	4,000 gal/min
4. Maximum Production Rate:	
5. Requested Maximum Operating Schedule:	
	24 hours/day 7 days/week
	52 weeks/year 8760 hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters): Maximum process rate (Item 3) is the estimated waste tower water circulation rate.	

C. EMISSIONS UNIT REGULATIONS
(Regulated Emissions Units Only)

List of Applicable Regulations

D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram? Cooling Tower		2. Emission Point Type Code:	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point):			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common:			
5. Discharge Type Code: V	6. Stack Height: 45 feet	7. Exit Diameter: 14.1 feet	
8. Exit Temperature: °F	9. Actual Volumetric Flow Rate: acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: 17 East (km): 406.6 North (km): 3079.0			
14. Emission Point Comment (limit to 200 characters): Waste cooling tower consists of two cells. Exhaust temperature and flow rate vary with changes in ambient temperature. UTM coordinates represent the location of one cell.			

E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)

Segment Description and Rate: Segment 1 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Waste water tower re-circulation flow rate.		
2. Source Classification Code (SCC):		3. SCC Units: 1000 gallons of water circulated
4. Maximum Hourly Rate: 240	5. Maximum Annual Rate: 2,102,400	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

Segment Description and Rate: Segment 2 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters):		
2. Source Classification Code (SCC):		3. SCC Units:
4. Maximum Hourly Rate:	5. Maximum Annual Rate:	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit:
10. Segment Comment (limit to 200 characters):		

F. EMISSIONS UNIT POLLUTANTS
(All Emissions Units)

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
PM/PM₁₀	015		NS

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: PM/PM ₁₀	2. Total Percent Efficiency of Control:
3. Potential Emissions: 1.09 lb/hour 4.76 tons/year	4. Synthetically Limited? <input type="checkbox"/> <input type="checkbox"/>
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: Reference:	7. Emissions Method Code: 3
8. Calculation of Emissions (limit to 600 characters): Short term emissions: See CPV-PI Appendix D-5 $[(1.09 \text{ lb/hr}) \times (8760 \text{ hr/year})] / (2000 \text{ lb/ton}) = 4.76 \text{ tons/year}$	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 1

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.0005% drift loss	4. Equivalent Allowable Emissions: 1.09 lb/hour 4.76 tons/year
5. Method of Compliance (limit to 60 characters): Tower design and operation	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters):	

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissions Limitation _____ of _____

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: [] Rule [] Other
3. Requested Allowable Opacity: Normal Conditions: Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance:	
5. Visible Emissions Comment (limit to 200 characters):	

I. CONTINUOUS MONITOR INFORMATION
(Only Regulated Emissions Units Subject to Continuous Monitoring)

Continuous Monitoring System: Continuous Monitor _____ of _____

1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement: [] Rule	
4. Monitor Information: Manufacturer: Model Number: Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment (limit to 200 characters):	

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)

Supplemental Requirements

1. Process Flow Diagram [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
2. Fuel Analysis or Specification [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
3. Detailed Description of Control Equipment [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable [] Waiver Requested
4. Description of Stack Sampling Facilities [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
5. Compliance Test Report [] Attached, Document ID: _____ [] Previously submitted, Date: _____ [X] Not Applicable
6. Procedures for Startup and Shutdown [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
7. Operation and Maintenance Plan [] Attached, Document ID: _____ [X] Not Applicable [] Waiver Requested
8. Supplemental Information for Construction Permit Application [X] Attached, Document ID: <u>CPV-PI</u> [] Not Applicable
9. Other Information Required by Rule or Statute [] Attached, Document ID: _____ [X] Not Applicable
10. Supplemental Requirements Comment:

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation [] Attached, Document ID: _____ [X] Not Applicable
12. Alternative Modes of Operation (Emissions Trading) [] Attached, Document ID: _____ [X] Not Applicable
13. Identification of Additional Applicable Requirements [] Attached, Document ID: _____ [X] Not Applicable
14. Compliance Assurance Monitoring Plan [] Attached, Document ID: _____ [X] Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable

Appendix B

Engineering Drawings



Appendix C

Air Pollutant Emissions

Appendix C-1

Combined-Cycle System Emissions

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 25 F

Relative Humidity: 60 %

50% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	15	pph
CO	9.0	ppmvd	CO	20.0	pph
UHC	7.0	ppmww	UHC	10.0	pph
VOC	1.4	ppmww	VOC	2.0	pph
SO2	1	ppmww	SO2	6	pph
SO3	0	ppmww	SO3	1	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	8	pph	Ammonia	8	pph
O2	12.9	%	O2	12.9	%
H2O	7.5	%	H2O	7.5	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 25 F

Relative Humidity: 60%

75% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	19	pph
CO	9.0	ppmvd	CO	25.0	pph
UHC	7.0	ppmvd	UHC	12.0	pph
VOC	1.4	ppmvd	VOC	2.4	pph
SO2	1	ppmvd	SO2	8	pph
SO3	0	ppmvd	SO3	1	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	10	pph	Ammonia	10	pph
O2	12.64	%	O2	12.64	%
H2O	7.69	%	H2O	7.69	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 25 F

Relative Humidity: 60%

100% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	24	pph
CO	9.0	ppmvd	CO	31.0	Pph
UHC	7.0	ppmvw	UHC	15.0	Pph
VOC	1.4	ppmvw	VOC	3.0	Pph
SO2	1	ppmvw	SO2	10	Pph
SO3	0	ppmvw	SO3	1	Pph
Sulfur Mist	1	pph	Sulfur Mist	1	Pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	Pph
PM10 Particulates	19	pph	PM10 Particulates	19	Pph
Ammonia	13	pph	Ammonia	13	Pph
O2	12.81	%	O2	12.81	%
H2O	7.53	%	H2O	7.53	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 59 F

Relative Humidity: 74%

50% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	14	pph
CO	9.0	ppmvd	CO	19.0	pph
UHC	7.0	ppmww	UHC	9.0	pph
VOC	1.4	ppmww	VOC	1.8	pph
SO2	1	ppmww	SO2	6	pph
SO3	0	ppmww	SO3	0	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	8	pph	Ammonia	8	pph
O2	12.91	%	O2	12.91	%
H2O	8.21	%	H2O	8.21	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 59 F

Relative Humidity: 74%

75% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	18.0	pph
CO	9.0	ppmvd	CO	23.0	pph
UHC	7.0	ppmww	UHC	11.0	pph
VOC	1.4	ppmww	VOC	2.2	pph
SO2	1	ppmww	SO2	8	pph
SO3	0	ppmww	SO3	0	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	10	pph	Ammonia	10	pph
O2	12.54	%	O2	12.54	%
H2O	8.54	%	H2O	8.54	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 59 F

Relative Humidity: 74%

100% Load METHANE

NOx	3.5	ppmvd@15%o2	NOx	23.0	pph
CO	9.0	ppmvd	CO	29.0	pph
UHC	7.0	ppmww	UHC	14.0	pph
VOC	1.4	ppmww	VOC	2.8	pph
SO2	1	ppmww	SO2	9	pph
SO3	0	ppmww	SO3	1	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	12	pph	Ammonia	12	pph
O2	12.59	%	O2	12.59	%
H2O	8.50	%	H2O	8.50	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel 100% Methane

Fuel LHV 21,515 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Steam Injection for Power Augmentation (3.5% of compressor flow)

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 59 F

Relative Humidity: 74%

100% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	23.0	pph
CO	15.0	ppmvd	CO	50.0	pph
UHC	7.0	ppmvw	UHC	15.0	pph
VOC	1.4	ppmvw	VOC	3.0	pph
SO2	1	ppmvw	SO2	10	pph
SO3	0	ppmvw	SO3	0	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	12	pph	Ammonia	12	pph
O2	11.67	%	O2	11.67	%
H2O	13.43	%	H2O	13.43	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 72 F

Relative Humidity: 73%

50% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	14.0	pph
CO	9.0	ppmvd	CO	19.0	pph
UHC	7.0	ppmvw	UHC	9.0	pph
VOC	1.4	ppmvw	VOC	1.8	pph
SO2	1	ppmvw	SO2	6	pph
SO3	0	ppmvw	SO3	0	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	7	pph	Ammonia	7	pph
O2	12.90	%	O2	12.90	%
H2O	8.77	%	H2O	8.77	%

APPENDIX C-1
CPV PIERCE, FL
COMBINED-CYCLE GAS TURBINE
EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 72 F

Relative Humidity: 73%

75% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	18.0	pph
CO	9.0	ppmvd	CO	23.0	pph
UHC	7.0	ppmvw	UHC	11.0	pph
VOC	1.4	ppmvw	VOC	2.2	pph
SO2	1	ppmvw	SO2	7	pph
SO3	0	ppmvw	SO3	1	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	9	pph	Ammonia	9	pph
O2	12.48	%	O2	12.48	%
H2O	9.14	%	H2O	9.14	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 72 F

Relative Humidity: 73%

100% Load **METHANE**

NOx 3.5 ppmvd @ 15% O2

CO 9.0 ppmvd

UHC 7.0 ppmvw

VOC 1.4 ppmvw

SO2 1 ppmvw

SO3 0 ppmvw

Sulfur Mist 1 pph

Front Half +
Sulfates
Partic. 9 pph

PM10
Particulates 19 pph

Ammonia 12 pph

O2 12.47 %

H2O 9.14 %

NOx 22 pph

CO 28.0 pph

UHC 14.0 pph

VOC 2.8 pph

SO2 9 pph

SO3 1 pph

Sulfur Mist 1 pph

Front Half +
Sulfates
Partic. 9 pph

PM10
Particulates 19 pph

Ammonia 12 pph

O2 12.47 %

H2O 9.14 %

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Steam Injection for Power Augmentation (3.5% of compressor flow)

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 72 F

Relative Humidity: 73%

100% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	23.0	pph
CO	15.0	ppmvd	CO	49.0	pph
UHC	7.0	ppmvw	UHC	14.0	pph
VOC	1.4	ppmvw	VOC	2.8	pph
SO2	1	ppmvw	SO2	9	pph
SO3	0	ppmvw	SO3	1	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	12	pph	Ammonia	12	pph
O2	11.49	%	O2	11.49	%
H2O	14.09	%	H2O	14.09	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 97 F

Relative Humidity: 70 %

50% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	13.0	pph
CO	9.0	ppmvd	CO	18.0	pph
UHC	7.0	ppmvw	UHC	9.0	pph
VOC	1.4	ppmvw	VOC	1.8	pph
SO2	1	ppmvw	SO2	6	pph
SO3	0	ppmvw	SO3	0	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	7	pph	Ammonia	7	pph
O2	12.70	%	O2	12.70	%
H2O	10.68	%	H2O	10.68	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NO_x reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 97 F

Relative Humidity: 70%

75% Load METHANE

NO _x	3.5	ppmvd@15%O ₂	NO _x	17.0	pph
CO	9.0	ppmvd	CO	21.0	pph
UHC	7.0	ppmw	UHC	11.0	pph
VOC	1.4	ppmw	VOC	2.2	pph
SO ₂	1	ppmw	SO ₂	7	pph
SO ₃	0	ppmw	SO ₃	0	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	9	pph	Ammonia	9	pph
O ₂	12.18	%	O ₂	12.18	%
H ₂ O	11.13	%	H ₂ O	11.13	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20.958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 97 F

Relative Humidity: 70%

100% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	20.0	pph
CO	9.0	ppmvd	CO	26.0	pph
UHC	7.0	ppmww	UHC	13.0	pph
VOC	1.4	ppmww	VOC	2.6	pph
SO2	1	ppmww	SO2	8	pph
SO3	0	ppmww	SO3	1	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	11	pph	Ammonia	11	pph
O2	12.06	%	O2	12.06	%
H2O	11.24	%	H2O	11.24	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: PG7241(FA)

Fuel 100% Methane

Fuel LHV 20,958 Btu/lb

Sulfur emission based on 0.0065 WT% Sulfur content in the fuel

Steam Injection for Power Augmentation (3.5% of compressor flow)

Gas Turbine @ base load

Fuel temperature 365 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 97 F

Relative Humidity: 70%

100% Load METHANE

NOx	3.5	ppmvd@15%O2	NOx	21.0	pph
CO	15.0	ppmvd	CO	45.0	pph
UHC	7.0	ppmvw	UHC	13.0	pph
VOC	1.4	ppmvw	VOC	2.6	pph
SO2	1	ppmvw	SO2	9	pph
SO3	0	ppmvw	SO3	0	pph
Sulfur Mist	1	pph	Sulfur Mist	1	pph
Front Half + Sulfates Partic.	9	pph	Front Half + Sulfates Partic.	9	pph
PM10 Particulates	19	pph	PM10 Particulates	19	pph
Ammonia	11	pph	Ammonia	11	pph
O2	11.05	%	O2	11.05	%
H2O	16.09	%	H2O	16.09	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 25 F

Relative Humidity: 60%

50% Load Distillate

NOx	10.0	ppmvd@15%O2	NOx	49	pph
CO	24.0	ppmvd	CO	53.0	pph
UHC	7.0	ppmww	UHC	10.0	pph
VOC	3.5	ppmww	VOC	5.0	pph
SO2	11	ppmww	SO2	62	pph
SO3	1	ppmww	SO3	4	pph
Sulfur Mist	7	pph	Sulfur Mist	7	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	41	pph	PM10 Particulates	41	pph
Ammonia	9	pph	Ammonia	9	pph
O2	11.65	%	O2	11.65	%
H2O	9.41	%	H2O	9.41	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 25 F

Relative Humidity: 60%

75% Load Distillate

NOx	10.0	ppmvd@15%O2	NOx	63.0	pph
CO	24.0	ppmvd	CO	65.0	Pph
UHC	7.0	ppmww	UHC	12.0	Pph
VOC	3.5	ppmww	VOC	6.0	Pph
SO2	12	ppmww	SO2	79	Pph
SO3	0	ppmww	SO3	5	Pph
Sulfur Mist	8	pph	Sulfur Mist	8	Pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	Pph
PM10 Particulates	42	pph	PM10 Particulates	42	Pph
Ammonia	12	pph	Ammonia	12	Pph
O2	11.18	%	O2	11.18	%
H2O	10.26	%	H2O	10.26	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NO_x reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NO_x control to 42 ppmvd @ 15% O₂ at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 80 F.

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 25 F

Relative Humidity: 60%

100% Load Distillate

NO _x <input type="text" value="10.0"/> ppmvd @ 15% O ₂	NO _x <input type="text" value="80.0"/> pph
CO <input type="text" value="20.0"/> ppmvd	CO <input type="text" value="70.0"/> pph
UHC <input type="text" value="7.0"/> ppmvw	UHC <input type="text" value="16.0"/> pph
VOC <input type="text" value="3.5"/> ppmvw	VOC <input type="text" value="8.0"/> pph
SO ₂ <input type="text" value="11"/> ppmvw	SO ₂ <input type="text" value="99"/> pph
SO ₃ <input type="text" value="1"/> ppmvw	SO ₃ <input type="text" value="6"/> pph
Sulfur Mist <input type="text" value="10"/> pph	Sulfur Mist <input type="text" value="10"/> pph
Front Half + Sulfates Partic. <input type="text" value="17"/> pph	Front Half + Sulfates Partic. <input type="text" value="17"/> pph
PM ₁₀ Particulates <input type="text" value="44"/> pph	PM ₁₀ Particulates <input type="text" value="44"/> pph
Ammonia <input type="text" value="15"/> pph	Ammonia <input type="text" value="15"/> pph
O ₂ <input type="text" value="11.46"/> %	O ₂ <input type="text" value="11.46"/> %
H ₂ O <input type="text" value="10.26"/> %	H ₂ O <input type="text" value="10.26"/> %

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 59 F

Relative Humidity: 74%

50% Load Distillate

NOx	10.0	ppmvd@15%O2	NOx	47	pph
CO	24	ppmvd	CO	52	pph
UHC	7.0	ppmvw	UHC	10.0	pph
VOC	3.5	ppmvw	VOC	5	pph
SO2	11	ppmvw	SO2	59	pph
SO3	1	ppmvw	SO3	4	pph
Sulfur Mist	6	pph	Sulfur Mist	6	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	40	pph	PM10 Particulates	40	pph
Ammonia	9	pph	Ammonia	9	pph
O2	11.75	%	O2	11.75	%
H2O	9.89	%	H2O	9.89	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 59 F

Relative Humidity: 74%

75% Load Distillate

NOx	10.0	ppmvd@15%O2	NOx	60.0	pph
CO	24.0	ppmvd	CO	62.0	pph
UHC	7.0	ppmvw	UHC	12.0	pph
VOC	3.5	ppmvw	VOC	6.0	pph
SO2	12	ppmvw	SO2	75	pph
SO3	0	ppmvw	SO3	5	pph
Sulfur Mist	8	pph	Sulfur Mist	8	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	42	pph	PM10 Particulates	42	pph
Ammonia	11	pph	Ammonia	11	pph
O2	11.18	%	O2	11.18	%
H2O	10.81	%	H2O	10.81	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 59 F

Relative Humidity: 74%

100% Load Distillate

Nox	10.0	ppmvd @ 15%O2	NOx	75.0	pph
CO	20.0	ppmvd	CO	66.0	pph
UHC	7.0	ppmvw	UHC	15.0	pph
VOC	3.5	ppmvw	VOC	7.5	pph
SO2	11	ppmvw	SO2	93	pph
SO3	1	ppmvw	SO3	6	pph
Sulfur Mist	10	pph	Sulfur Mist	10	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	44	pph	PM10 Particulates	44	pph
Ammonia	14	pph	Ammonia	14	pph
O2	11.22	%	O2	11.22	%
H2O	11.13	%	H2O	11.13	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 72 F

Relative Humidity: 73%

50% Load Distillate

NOx	10.0	ppmvd @ 15% O2	NOx	46.0	pph
CO	24.0	ppmvd	CO	51.0	pph
UHC	7.0	ppmvw	UHC	9.0	pph
VOC	3.5	ppmvw	VOC	4.5	pph
SO2	11	ppmvw	SO2	58	pph
SO3	0	ppmvw	SO3	4	pph
Sulfur Mist	6	pph	Sulfur Mist	6	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	40	pph	PM10 Particulates	40	pph
Ammonia	8	pph	Ammonia	8	pph
O2	11.81	%	O2	11.81	%
H2O	10.19	%	H2O	10.19	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 72 F

Relative Humidity: 73%

75% Load Distillate

NOx	10.0	ppmvd@15%O2	Nox	58.0	pph
CO	24.0	ppmvd	CO	60.0	pph
UHC	7.0	ppmvw	UHC	11.0	pph
VOC	3.5	ppmvw	VOC	5.5	pph
SO2	12	ppmvw	SO2	73	pph
SO3	0	ppmvw	SO3	5	pph
Sulfur Mist	8	pph	Sulfur Mist	8	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	42	pph	PM10 Particulates	42	pph
Ammonia	11	pph	Ammonia	11	pph
O2	11.17	%	O2	11.17	%
H2O	11.18	%	H2O	11.18	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 72 F

Relative Humidity: 73%

100% Load Distillate

NOx	10.0	ppmvd@15%O2	NOx	73.0	pph
CO	20.0	ppmvd	CO	63.0	pph
UHC	7.0	ppmvw	UHC	14.0	pph
VOC	3.5	ppmvw	VOC	7.0	pph
SO2	11	ppmvw	SO2	91	pph
SO3	1	ppmvw	SO3	5	pph
Sulfur Mist	10	pph	Sulfur Mist	10	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	44	pph	PM10 Particulates	44	pph
Ammonia	14	pph	Ammonia	14	pph
O2	11.09	%	O2	11.09	%
H2O	11.64	%	H2O	11.64	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ 50% load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 97 F

Relative Humidity: 70%

50% Load Distillate

NOx	10.0	ppmvd@15%O2	NOx	42.0	pph
CO	24.0	ppmvd	CO	49.0	pph
UHC	7.0	ppmww	UHC	9.0	pph
VOC	3.5	ppmww	VOC	4.5	pph
SO2	10	ppmww	SO2	53	pph
SO3	1	ppmww	SO3	4	pph
Sulfur Mist	6	pph	Sulfur Mist	6	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	40	pph	PM10 Particulates	40	pph
Ammonia	8	pph	Ammonia	8	pph
O2	11.91	%	O2	11.91	%
H2O	11.26	%	H2O	11.26	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ 75% load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 97 F

Relative Humidity: 70%

75% Load Distillate

NOx	10.0	ppmvd@15%O2	NOx	54.0	pph
CO	24.0	ppmvd	CO	57.0	pph
UHC	7.0	ppmww	UHC	11.0	pph
VOC	3.5	ppmww	VOC	5.5	pph
SO2	1.1	ppmww	SO2	68	pph
SO3	1	ppmww	SO3	4	pph
Sulfur Mist	7	pph	Sulfur Mist	7	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	41	pph	PM10 Particulates	41	pph
Ammonia	10	pph	Ammonia	10	pph
O2	11.15	%	O2	11.15	%
H2O	12.33	%	H2O	12.33	%

APPENDIX C-1 CPV PIERCE, FL COMBINED-CYCLE GAS TURBINE EMISSIONS (after SCR for NOx reduction)

Assumptions:

Gas Turbine: **PG7241(FA)**

Fuel Distillate, H/C ratio of 1.8

Fuel LHV 18,300 Btu/lb

Water injection for NOx control to 42 ppmvd @ 15% O2 at GT exhaust

Sulfur emission based on 0.05 WT% Sulfur content in the fuel

Gas Turbine @ base load

Fuel temperature 80 F

Site elevation: 155 ft

Site pressure: 14.62 psia

Ambient temperature: 97 F

Relative Humidity: 70%

100% Load Distillate

NOx	10.0	ppmvd@15%O2	NOx	67.0	pph
CO	20.0	ppmvd	CO	57.0	pph
UHC	7.0	ppmww	UHC	13.0	pph
VOC	3.5	ppmww	VOC	6.5	pph
SO2	11	ppmww	SO2	83	pph
SO3	1	ppmww	SO3	5	pph
Sulfur Mist	9	pph	Sulfur Mist	9	pph
Front Half + Sulfates Partic.	17	pph	Front Half + Sulfates Partic.	17	pph
PM10 Particulates	43	pph	PM10 Particulates	43	pph
Ammonia	12	pph	Ammonia	12	pph
O2	10.90	%	O2	10.90	%
H2O	12.96	%	H2O	12.96	%

Appendix C-2
Annual Emissions

CPV Pierce- Combined-Cycle Maximum Potential Annual Emissions									
	Units	NO _x	CO	VOC	SO ₂	SO ₃	PM	H ₂ SO ₄	NH ₃
Capacity Factor		100%	100%	100%	100%	100%	100%	100%	100%
		Controlled							5 ppm slip
Natural Gas									
Operating Period	Hours	8040	8040	8040	8040	8040	8040	8040	8040
Emission Rate	lb/hr	24.00	50.00	3.00	10.00	1.00	19.00	1.00	13.00
Annual Emissions	tons/year	96.48	201.00	12.06	40.20	4.02	76.38	4.02	52.26
Distillate									
Operating Period	Hours	720	720	720	720	720	720	720	720
Emission Rate	lb/hr	80.00	70.00	8.00	99.00	6.00	44.00	10.00	15.00
Annual Emissions	tons/year	28.80	25.20	2.88	35.64	2.16	15.84	3.60	5.40
Total Annual Emissions	tons/year	125.28	226.20	14.94	75.84	6.18	92.22	7.62	57.66

CPV Pierce- Combine-Cycle Maximum Actual Annual Emissions									
	Units	NO _x	CO	VOC	SO ₂	SO ₃	PM	H ₂ SO ₄	NH ₃
		Controlled							
Capacity Factor		100%	100%	100%	100%	100%	100%	100%	100%
Natural Gas (with PA)									
Operating Period	Hours	2000	2000	2000	2000	2000	2000	2000	2000
Emission Rate	lb/hr	23.00	49.00	2.80	9.00	1.00	19.00	1.00	12.00
Annual Emissions	tons/year	23.00	49.00	2.80	9.00	1.00	19.00	1.00	12.00
Natural Gas (without PA)									
Operating Period	Hours	6040	6040	6040	6040	6040	6040	6040	6040
Emission Rate	lb/hr	22.00	28.00	2.80	9.00	1.00	19.00	1.00	12.00
Annual Emissions	tons/year	66.44	84.56	8.46	27.18	3.02	57.38	3.02	36.24
Distillate									
Operating Period	Hours	720	720	720	720	720	720	720	720
Emission Rate	lb/hr	73.00	63.00	7.00	91.00	5.00	44.00	10.00	14.00
Annual Emissions	tons/year	26.28	22.68	2.52	32.76	1.80	15.84	3.60	5.04
Total Annual Emissions	tons/year	115.72	156.24	13.78	68.94	5.82	92.22	7.62	53.28

Max. emissions at 100% load and 72F

Appendix C-3

HAP Emissions

**CPV Pierce
Potential Hazardous Air Pollutants Emissions
Combined Cycle Turbine**

Maximum Heat Input, (Btu/hr):

Distillate Fuel Oil

1,898,000,000

Natural Gas

1,679,900,000

Potential Operating Hours

Distillate Fuel Oil

720

Natural Gas

8,040

Pollutant	Distillate Oil			Natural Gas			
	Emission Factor lb/MMBtu	Emission Rate lb/hr	Annual Emissions TPY	Emission Factor lb/MMBtu	Emission Rate lb/hr	Annual Emissions TPY	Total Annual Emissions TPY
				(a)			
Arsenic	1.10E-05	2.09E-02	7.52E-03				7.52E-03
Beryllium	3.10E-07	5.88E-04	2.12E-04				2.12E-04
Cadmium	4.80E-06	9.11E-03	3.28E-03				3.28E-03
Chromium	1.10E-05	2.09E-02	7.52E-03				7.52E-03
Lead	1.40E-05	2.66E-02	9.57E-03				9.57E-03
Manganese	7.90E-04	1.499	0.540				5.40E-01
Mercury	1.20E-06	2.28E-03	8.20E-04				8.20E-04
Nickel	4.60E-06	8.73E-03	3.14E-03				3.14E-03
Selenium	2.50E-05	0.0475	1.71E-02				1.71E-02
Acetaldehyde				4.00E-05	0.0672	0.2701	2.70E-01
Acrolein				6.40E-06	1.08E-02	4.32E-02	4.32E-02
1,3 Butadiene	1.60E-05	3.04E-02	1.09E-02	4.30E-07	7.22E-04	2.90E-03	1.38E-02
Benzene	5.50E-05	0.1044	3.76E-02	1.20E-05	2.02E-02	0.0810	1.19E-01
Ethylbenzene				3.20E-05	0.0538	0.2161	2.16E-01
Formaldehyde	2.80E-04	0.531	0.191	7.10E-04	1.193	4.795	4.99
Napthalene	3.50E-05	0.0664	2.39E-02	1.30E-06	2.2E-03	8.78E-03	3.27E-02
PAH	4.00E-05	0.0759	2.73E-02	2.20E-06	3.70E-03	1.49E-02	4.22E-02
Propylene Oxide				2.90E-05	0.0487	0.196	1.96E-01
Toluene				1.30E-04	0.2184	0.878	8.78E-01
Xylene				6.40E-05	0.1075	0.4322	4.32E-01
					Total HAPs		7.82

Hazardous air pollutant emission factors taken from USEPA document Compilation of Air Pollutant Emission Factors AP-42, Fifth Edition,

Volume I: Stationary Point and Area Sources, Section 3.1 Stationary Gas Turbines, dated 4/2/2000:

Table 3.1-3. Emission Factors for Hazardous Air Pollutants from Natural Gas-Fired Stationary Gas Turbines

Table 3.1-4. Emission Factors for Hazardous Air Pollutants from Distillate Oil-Fired Stationary Gas Turbines

Table 3.1-5. Emission Factors for Metallic Hazardous Air Pollutants from Distillate Oil-Fired Stationary Gas Turbines

Appendix C-4

Cooling And Waste Water Towers Particulate Emission Calculations

Competitive Power Ventures - Pierce Project Cooling Tower PM Emissions Calculations		
Parameter	Units	Value
Cooling Tower Circulating Flow*	gal/min	75,000
Drift Fraction of Circulating Flow*	percent	0.0005
Drift Rate	gal/min	0.375
Drift Rate	gal/hr	22.5
Water Density	lb/gal	8.33
Water Density Assumed for Cooling Water	lb/gal	8.33
Drift Rate	lb/min	3.12
Drift Rate	lb/hr	187.43
Convert lb/hr to g/s	g/s per lb/hr	0.126
Drift Rate	g/s	23.6
Dissolved & Suspended Solids in Water	mg/l	4200
Dissolved & Suspended Solids in Water	g/l	4.2
Convert Liters to Gallons	l/gal	3.785
Dissolved & Suspended Solids in Water	g/gal	15.90
PM Emissions	g/hr	357.7
PM Emissions	lb/hr	0.79
PM Emissions	g/s	0.099
Number of Cells		5
PM Emissions	g/s per cell	0.020
Annual Emissions	tons/year	3.45
* per Marley specification		

Competitive Power Ventures - Pierce Project Wasterwater Tower PM Emissions Calculations		
Parameter	Units	Value
Cooling Tower Circulating Flow*	gal/min (liquid)	4,000
Drift Fraction of Circulating Flow*	percent	0.0005
Drift Rate	gal/min (liquid)	0.02
Drift Rate	gal/hr (liquid)	1.2
Water Density	lb/gal	9.0489
Water Density Assumed for Cooling Water	lb/gal	9.0489
Drift Rate	lb/min (liquid)	0.18
Drift Rate	lb/hr (liquid)	10.86
TDS	ppm (weight)	100,000
PM emissions	lb/hr (solids)	1.09
Convert lb/hr to g/s	g/s per lb/hr	0.126
Drift Rate	g/s	0.137
Number of Cells		2
PM Emissions	g/s per cell	0.068
Annual Emissions	tons/year	4.76
* 1.09 lb/hr based on AEP-Proserv information		

Appendix D

Air Quality Modeling

Appendix D-1

BPIP Input and Output Files

Appendix D-1
BPIP Input File

CPV PIERCE POWER PLANT

0 7 3 8 .0000METERS 1.0 UTM Y 1

HRSG 1 .00

4 26.82
2.39 -5.98
2.39 5.98
40.48 5.98
40.48 -5.98

GTG 1 .00

8 11.89
40.48 -3.73
40.48 3.73
76.93 3.73
76.93 6.75
81.12 6.75
81.12 -6.72
76.93 -6.72
76.89 -3.86

STG 1 .00

8 8.53
39.01 -32.85
39.01 -20.09
43.94 -19.70
44.84 -21.80
67.92 -21.80
67.92 -30.76
44.84 -30.76
43.94 -32.85

COOLT 1 .00

4 9.45
-111.87 -29.89
-122.22 -19.55
-69.39 33.65
-59.04 23.30

ADMIN 1 .00

4 6.10
122.06 36.41
122.06 87.21
137.00 87.21
137.00 36.41

CONTROL 1 .00

4 6.10
55.80 24.05
55.80 36.00
88.66 36.00
88.66 24.05

WATER 1 .00

4 9.14
-24.78 4.63
-24.78 19.57
-12.83 19.57
-12.83 4.63

RAWWATER .00 12.20 14.53 -73.45 56.80
DEM WATER .00 21.34 17.43 -25.94 56.80
FUELOIL .00 15.24 19.38 37.02 56.80

STACK1	.00	53.34	0.0	0.0
CELL1	.00	13.72	-111.75	-19.42
CELL2	.00	13.72	-101.23	-8.73
CELL3	.00	13.72	-90.63	1.88
CELL4	.00	13.72	-80.03	12.48
CELL5	.00	13.72	-69.52	23.17
WASTE1	.00	13.72	-127.01	-34.15
WASTE2	.00	13.72	-122.70	-29.84

BEE-Line Software Version: 5.12

Input File - PIERCE.GEP
Input File - PIERCE.PIP
Output File - PIERCE.TAB
Output File - PIERCE.SUM
Output File - PIERCE.SO

BPIP (Dated: 95086)

DATE : 04/13/01
TIME : 14:51:28
CPV PIERCE POWER PLANT

BPIP PROCESSING INFORMATION:

The ST flag has been set for processing for an ISCST2 run.

Inputs entered in METERS will be converted to meters using
a conversion factor of 1.0000. Output will be in meters.

The UTM variable is set to UTM. The input is assumed to be in
UTM coordinates. BPIP will move the UTM origin to the first pair of
UTM coordinates read. The UTM coordinates of the new origin will
be subtracted from all the other UTM coordinates entered to form
this new local coordinate system.

Plant north is set to 0.00 degrees with respect to True North.

CPV PIERCE POWER PLANT

PRELIMINARY* GEP STACK HEIGHT RESULTS TABLE
(Output Units: meters)

Stack Name	Stack Height	Stack-Building Base Elevation Differences	Preliminary* GEP** EQN1	GEP Stack Height Value
STACK1	53.34	0.00	67.05	67.05
CELL1	13.72	0.00	23.63	65.00
CELL2	13.72	0.00	23.63	65.00
CELL3	13.72	0.00	47.54	65.00
CELL4	13.72	0.00	56.70	65.00
CELL5	13.72	0.00	64.86	65.00
WASTE1	13.72	0.00	23.63	65.00
WASTE2	13.72	0.00	23.63	65.00

* Results are based on Determinants 1 & 2 on pages 1 & 2 of the GEP Technical Support Document. Determinant 3 may be investigated for additional stack height credit. Final values result after Determinant 3 has been taken into consideration.

** Results were derived from Equation 1 on page 6 of GEP Technical Support Document. Values have been adjusted for any stack-building base elevation differences.

Note: Criteria for determining stack heights for modeling emission limitations for a source can be found in Table 3.1 of the GEP Technical Support Document.

BPIP (Dated: 95086)

DATE : 04/13/01

TIME : 14:51:28

CPV PIERCE POWER PLANT

BPIP output is in meters

SO BUILDHGT STACK1	26.82	26.82	26.82	26.82	26.82	26.82
SO BUILDHGT STACK1	26.82	26.82	26.82	26.82	26.82	26.82
SO BUILDHGT STACK1	26.82	26.82	26.82	26.82	26.82	26.82
SO BUILDHGT STACK1	26.82	26.82	26.82	26.82	26.82	26.82
SO BUILDHGT STACK1	26.82	26.82	26.82	26.82	26.82	26.82
SO BUILDHGT STACK1	26.82	26.82	26.82	26.82	26.82	26.82
SO BUILDWID STACK1	39.59	39.88	38.97	36.87	33.65	29.40
SO BUILDWID STACK1	24.27	18.39	11.96	18.39	24.27	29.40
SO BUILDWID STACK1	33.65	36.87	38.97	39.88	39.59	38.09
SO BUILDWID STACK1	39.59	39.88	38.97	36.87	33.65	29.40
SO BUILDWID STACK1	24.27	18.39	11.96	18.39	24.27	29.40
SO BUILDWID STACK1	33.65	36.87	38.97	39.88	39.59	38.09

SO BUILDHGT CELL1	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL1	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL1	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL1	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL1	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL1	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDWID CELL1	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID CELL1	45.18	55.20	63.54	69.95	74.24	76.27
SO BUILDWID CELL1	75.98	75.94	76.14	74.03	69.66	63.18
SO BUILDWID CELL1	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID CELL1	45.18	55.20	63.54	69.95	74.24	76.27
SO BUILDWID CELL1	75.98	75.94	76.14	74.03	69.66	63.18

SO BUILDHGT CELL2	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL2	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL2	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL2	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL2	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL2	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDWID CELL2	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID CELL2	45.18	55.20	63.54	69.95	74.24	76.27
SO BUILDWID CELL2	75.98	75.94	76.14	74.03	69.66	63.18
SO BUILDWID CELL2	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID CELL2	45.18	55.20	63.54	69.95	74.24	76.27
SO BUILDWID CELL2	75.98	75.94	76.14	74.03	69.66	63.18

SO BUILDHGT CELL3	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL3	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL3	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL3	12.20	12.20	12.20	21.34	21.34	21.34
SO BUILDHGT CELL3	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL3	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDWID CELL3	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID CELL3	45.18	55.20	63.54	69.95	74.24	76.27
SO BUILDWID CELL3	75.98	75.94	76.14	74.03	69.66	63.18
SO BUILDWID CELL3	14.57	14.60	14.49	17.39	17.41	17.38
SO BUILDWID CELL3	45.18	55.20	63.54	69.95	74.24	76.27
SO BUILDWID CELL3	75.98	75.94	76.14	74.03	69.66	63.18


SO BUILDHGT CELL4	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL4	9.45	9.45	9.45	9.45	9.45	9.45

SO BUILDHGT CELL4	9.45	9.45	9.45	9.45	9.45	12.20
SO BUILDHGT CELL4	12.20	12.20	9.45	21.34	21.34	21.34
SO BUILDHGT CELL4	9.45	9.45	9.45	26.82	26.82	9.45
SO BUILDHGT CELL4	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDWID CELL4	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID CELL4	45.18	55.20	63.54	69.95	74.24	76.27
SO BUILDWID CELL4	75.98	75.94	76.14	74.03	69.66	14.50
SO BUILDWID CELL4	14.57	14.60	33.29	17.39	17.41	17.38
SO BUILDWID CELL4	45.18	55.20	63.54	18.39	19.92	76.27
SO BUILDWID CELL4	75.98	75.94	76.14	74.03	69.66	63.18

SO BUILDHGT CELL5	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL5	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT CELL5	9.45	9.45	9.45	12.20	12.20	12.20
SO BUILDHGT CELL5	12.20	9.45	9.45	21.34	21.34	21.34
SO BUILDHGT CELL5	21.34	9.45	9.45	26.82	26.82	26.82
SO BUILDHGT CELL5	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDWID CELL5	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID CELL5	45.18	55.20	63.54	69.95	74.24	76.27
SO BUILDWID CELL5	75.98	75.94	76.14	14.60	14.57	14.50
SO BUILDWID CELL5	14.57	44.71	33.29	17.39	17.41	17.38
SO BUILDWID CELL5	17.51	55.20	63.54	18.39	24.27	25.36
SO BUILDWID CELL5	75.98	75.94	76.14	74.03	69.66	63.18

SO BUILDHGT WASTE1	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT WASTE1	9.45	9.45	9.45	0.00	0.00	0.00
SO BUILDHGT WASTE1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDHGT WASTE1	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT WASTE1	9.45	9.45	9.45	0.00	0.00	0.00
SO BUILDHGT WASTE1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID WASTE1	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID WASTE1	45.18	55.20	63.54	0.00	0.00	0.00
SO BUILDWID WASTE1	0.00	0.00	0.00	0.00	0.00	0.00
SO BUILDWID WASTE1	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID WASTE1	45.18	55.20	63.54	0.00	0.00	0.00
SO BUILDWID WASTE1	0.00	0.00	0.00	0.00	0.00	0.00

SO BUILDHGT WASTE2	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT WASTE2	9.45	9.45	9.45	9.45	9.45	0.00
SO BUILDHGT WASTE2	0.00	0.00	0.00	9.45	9.45	9.45
SO BUILDHGT WASTE2	9.45	9.45	9.45	9.45	9.45	9.45
SO BUILDHGT WASTE2	9.45	9.45	9.45	9.45	9.45	0.00
SO BUILDHGT WASTE2	0.00	0.00	0.00	9.45	9.45	9.45
SO BUILDWID WASTE2	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID WASTE2	45.18	55.20	63.54	69.95	74.24	0.00
SO BUILDWID WASTE2	0.00	0.00	0.00	74.03	69.66	63.18
SO BUILDWID WASTE2	54.78	44.71	33.29	20.86	21.37	33.79
SO BUILDWID WASTE2	45.18	55.20	63.54	69.95	74.24	0.00
SO BUILDWID WASTE2	0.00	0.00	0.00	74.03	69.66	63.18



TRC Environmental Corporation

5 Waterside Crossing
Windsor, CT 06095
(860) 289-8631

Competitive Power Ventures

Figure D-1

GEP Analysis Structures
CPV Pierce
Pierce, Florida

Date: April 10, 2001

Project No.31325

Appendix D-2

**Tampa International Airport
(Station I.D.:(12842) Windroses 1987-1991**






FIGURE 1 WINDROSE

STATION NO: 12842
PERIOD: 1987

NOTES:

DIAGRAM OF THE FREQUENCY OF
OCCURRENCE OF EACH WIND DIRECTION.
WIND DIRECTION IS THE DIRECTION
FROM WHICH THE WIND IS BLOWING.
EXAMPLE - WIND IS BLOWING FROM THE
NORTH 3.8 PERCENT OF THE TIME.

BEE-LINE
12842





WIND SPEED CLASS BOUNDARIES
(METERS/SECOND)

FIGURE 1 WINDROSE

STATION NO: 12842
PERIOD: 1988

NOTES:
DIAGRAM OF THE FREQUENCY OF
OCCURRENCE OF EACH WIND DIRECTION.
WIND DIRECTION IS THE DIRECTION
FROM WHICH THE WIND IS BLOWING.
EXAMPLE - WIND IS BLOWING FROM THE
NORTH 6.8 PERCENT OF THE TIME.

BEE - LINE





WIND SPEED CLASS BOUNDARIES
(METERS/SECOND)

FIGURE 1 WINDROSE

STATION NO: 12842
PERIOD: 1989

NOTES:
DIAGRAM OF THE FREQUENCY OF
OCCURRENCE OF EACH WIND DIRECTION.
WIND DIRECTION IS THE DIRECTION
FROM WHICH THE WIND IS BLOWING.
EXAMPLE - WIND IS BLOWING FROM THE
NORTH 10.6 PERCENT OF THE TIME.

BFE-LINE
1011-1111



WIND SPEED CLASS BOUNDARIES
(METERS/SECOND)

FIGURE 1 WINDROSE

STATION NO: 12842
PERIOD: 1990

NOTES:

DIAGRAM OF THE FREQUENCY OF
OCCURRENCE OF EACH WIND DIRECTION.
WIND DIRECTION IS THE DIRECTION
FROM WHICH THE WIND IS BLOWING.
EXAMPLE - WIND IS BLOWING FROM THE
NORTH 4.3 PERCENT OF THE TIME

BEE-LINE
SOLUTIONS





FIGURE 1 WINDROSE

STATION NO: 12842
PERIOD: 1991

NOTES:
DIAGRAM OF THE FREQUENCY OF
OCCURRENCE OF EACH WIND DIRECTION.
WIND DIRECTION IS THE DIRECTION
FROM WHICH THE WIND IS BLOWING.
EXAMPLE - WIND IS BLOWING FROM THE
NORTH 3.8 PERCENT OF THE TIME.

BEE - LINE
1 0 7 - 4 - 4 4 4




FIGURE 1 WINDROSE

STATION NO: 12842

PERIOD: 1987-1991

NOTES:

DIAGRAM OF THE FREQUENCY OF OCCURRENCE OF EACH WIND DIRECTION. WIND DIRECTION IS THE DIRECTION FROM WHICH THE WIND IS BLOWING. EXAMPLE - WIND IS BLOWING FROM THE NORTH 5.9 PERCENT OF THE TIME.

BEE LINE
.....

Appendix D-3

- **Input and Output Files In Support of Class II Modeling Analyses**
- **CALPUFF/CALMET Input and Output Files in Support of Class I Modeling Analyses**

(Reference attached compact disk)

Appendix D-4

Summary of ISCST Modeling Analyses for SIL Compliance

TABLE D-4
SUMMARY OF MODELED IMPACTS *
COMPETITIVE POWER VENTURES PIERCE PROJECT

Type of Fuel	Operating Scenarios				Maximum Predicted Single Source Impacts ($\mu\text{g}/\text{m}^3$)							
	No.	Ambient Temp.	Power	Load	SO ₂			NO ₂	PM ₁₀ ¹		CO	
		(deg F)	Aug.	(%)	3-Hour	24-Hour	Annual	Annual	24-Hour	Annual	1-Hour	8-Hour
Natural Gas	1	25	OFF	100	1.13	0.191	0.0107	0.0256	3.77	0.149	10.5	1.78
	2	25	OFF	75	1.42	0.358	0.0120	0.0286	3.90	0.149	12.5	2.46
	3	25	OFF	50	1.50	0.458	0.0115	0.0288	4.64	0.152	13.5	2.80
	4	59	OFF	100	1.10	0.221	0.0100	0.0257	3.77	0.149	10.6	1.83
	5	59	OFF	75	1.47	0.371	0.0119	0.0268	4.06	0.149	11.9	2.34
	6	59	OFF	50	1.47	0.450	0.0109	0.0255	4.61	0.152	12.6	2.62
	7	72	OFF	100	1.18	0.243	0.0109	0.0265	3.77	0.149	11.0	1.95
	8	72	OFF	75	1.37	0.347	0.0112	0.0288	4.09	0.149	12.6	2.49
	9	72	OFF	50	1.55	0.475	0.0117	0.0272	4.73	0.153	13.2	2.76
	10	97	OFF	100	1.17	0.254	0.0096	0.0241	3.86	0.149	10.8	1.93
	11	97	OFF	75	1.38	0.381	0.0108	0.0262	4.17	0.150	11.6	2.29
	12	97	OFF	50	1.55	0.475	0.0112	0.0243	4.73	0.154	12.5	2.63
Distillate Oil	13	25	OFF	100	5.99	0.878	0.0508	0.0411	3.77	0.149	12.7	2.12
	14	25	OFF	75	8.94	1.82	0.0618	0.0493	3.90	0.149	20.9	3.68
	15	25	OFF	50	9.56	2.48	0.0606	0.0479	4.35	0.150	23.1	4.33
	16	59	OFF	100	6.36	0.879	0.0516	0.0416	3.77	0.149	13.5	2.26
	17	59	OFF	75	8.69	1.78	0.0586	0.0468	3.90	0.149	20.4	3.59
	18	59	OFF	50	9.41	2.46	0.0590	0.0470	4.36	0.150	23.4	4.41
	19	72	OFF	100	6.58	0.898	0.0524	0.0422	3.77	0.149	13.7	2.28
	20	72	OFF	75	8.66	1.91	0.0580	0.0461	3.91	0.149	20.2	3.56
	21	72	OFF	50	9.41	2.46	0.0587	0.0466	4.37	0.150	23.3	4.40
	22	59	OFF	100	6.89	1.27	0.0518	0.0418	3.77	0.149	14.2	2.4
	23	59	OFF	75	8.49	1.96	0.0555	0.0440	3.93	0.149	20.2	3.66
	24	59	OFF	50	8.89	2.49	0.0543	0.0430	4.74	0.151	23.1	4.37
Gas	25	25	ON	100	1.16	0.199	0.0112	0.0257	3.77	0.149	17.4	2.98
Gas	26	25	ON	75	1.06	0.212	9.82E-03	0.0251	3.77	0.149	17.3	2.96
Gas	27	25	ON	50	1.20	0.247	0.0108	0.0253	3.77	0.149	17.9	3.18
Maximum					9.56	2.49	0.0618	0.0493	4.74	0.154	23.4	4.41
Significant Impact Levels					25.0	5.00	1.00	1.00	5.00	1.00	2,000	500
PSD Increment					512	91.0	20.0	25.0	30.0	17.0	N/A	N/A
NAAQS					1,300	365	80.0	100	150	50.0	40,000	10,000

¹ Maximum combined PM₁₀ impacts from the combined-cycle stack plus the five cooling tower emission cells and two wastewater treatment cells.

* These results reflect 175 ft stack height. Annual impacts are conservative estimates, not adjusted for limited hours of use for each fuel.

Appendix E
Control Technology Review

Appendix E-1A

**RBLC Search Results for Combustion Turbine
(Combined-cycle, NO_x, SO₂, CO, PM/PM₁₀, Natural Gas & Oil)**

**RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - NOx**

FACILITY	CITY	STATE	PERMIT	PROCESS	MW	PPM	CTRLDESC	BASIS
CITY OF ANAHEIM GAS TURBINE PROJECT		CA	09/15/1989	TURBINE, GAS, GE PGLM 5000	55	2.3	SCR, STEAM INJECTION, CO REACTOR	BACT-PSD
DUKE POWER CO LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	NC	12/20/1991	TURBINE, COMBUSTION	164	2.5	COMBUSTION CONTROL	BACT-PSD
GORHAM ENERGY LIMITED PARTNERSHIP	GORHAM	ME	12/04/1998	TURBINE, COMBINED CYCLE	900	2.5	SELECTIVE CATALYTIC REDUCTION. EMISSION IS FROM LAER	BACT-PSD
UNION OIL CO	RODEO	CA	03/03/1986	TURBINE, GAS & DUCT BURNER	54	2.5	SCR, STEAM INJECTION	BACT-PSD
WESTBROOK POWER LLC	WESTBROOK	ME	12/04/1998	TURBINE, COMBINED CYCLE, TWO	528	2.5	SELECTIVE CATALYTIC REDUCTION AND DRY LOW NOX BUR- NER	LAER
SEPCO	RIO LINDA	CA	10/05/1994	TURBINE, GAS COMBINED CYCLE GE MODEL 7	115	2.8	SELECTIVE CATALYTIC REDUCTION AND DRY LOW NOX COMBU	BACT
SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	CA	08/19/1994	TURBINE, GAS, COMBINED CYCLE LM6000	53	3.0	SELECTIVE CATALYTIC REDUCTION AND WATER INJECTION	BACT
SACRAMENTO POWER AUTHORITY CAMPBELL SOUP	SACRAMENTO	CA	08/19/1994	TURBINE GAS, COMBINE CYCLE SIEMENS V84.2	157	3.0	SELECTIVE CATALYTIC REDUCTION AND DRY LOW NOX COMBU	BACT
SACRAMENTO POWER AUTHORITY CAMPBELL SOUP	SACRAMENTO	CA	08/19/1994	TURBINE, GAS, COMBINED CYCLE, SIEMENS V84.2	157	3.0	SELECTIVE CATALYTIC REDUCTION AND DRY LOW NOX COMBUS	BACT
BERKSHIRE POWER DEVELOPMENT, INC.	AGAWAM	MA	09/22/1997	TURBINE, COMBUSTION, ABB GT24	224	3.1	DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD-ON NO	BACT-PSD
DIGHTON POWER ASSOCIATE, LP	DIGHTON	MA	10/06/1997	TURBINE, COMBUSTION, ABB GT11N2	166	3.5	DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD-ON NO	BACT-PSD
BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.	NEW YORK CITY	NY	06/06/1995	TURBINE, NATURAL GAS FIRED	240	3.5	SCR	LAER
CASCO RAY ENERGY CO	VEAZIE	ME	07/13/1998	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170	3.5	SELECTIVE CATALYTIC REDUCTION	BACT-PSD
GRANITE ROAD LIMITED		CA	05/06/1991	TURBINE, GAS, ELECTRIC GENERATION	58	3.5	SCR, STEAM INJECTION	BACT-PSD
MILLENNIUM POWER PARTNER, LP	CHARLTON	MA	02/02/1998	TURBINE, COMBUSTION, WESTINGHOUSE MODEL 50	317	3.5	DRY LOW NOX COMBUSTION TECHNOLOGY IN CONJUNCTION WIT	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NEWARK	NJ	05/01/1998	TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)	77	3.5	SCR	BACT-PSD
RUMFORD POWER ASSOCIATES	RUMFORD	ME	05/01/1998	TURBINE GENERATOR, COMBUSTION, NATURAL GAS	238	3.5	SCR AMMONIA INJECTION SYSTEM AND CATALYTIC REACTORTO	BACT-PSD
TIVERTON POWER ASSOCIATES	TIVERTON	RI	02/13/1998	COMBUSTION TURBINE, NATURAL GAS	265	3.5	SCR	LAER
ALABAMA POWER COMPANY - THEODORE COGENERATION	THEODORE	AL	03/18/1999	170 MW TURBINE W/ DUCT BURNER, HR BOILER, SCR	170	3.5	DLN COMBUSTOR IN CT, LNB IN DUCT BURNER, SCR	BACT-PSD
ALABAMA POWER PLANT BARRY	BUCKS	AL	08/07/1998	TURBINES, COMBUSTION, NATURAL GAS	510	3.5	NATURAL GAS, CT-DLN COMBUSTORS, DUCTBURNER, LOW NOX	BACT-PSD
LSP-COTTAGE GROVE, L.P.	COTTAGE GROVE	MN	03/01/1995	COMBUSTION TURBINE/GENERATOR	246	3.8	FUEL SELECTION, GOOD COMBUSTION	BACT-PSD
BADGER CREEK LIMITED		CA	10/30/1989	TURBINE, GAS COGENERATION	57	3.7	SCR, STEAM INJECTION	BACT-PSD
BLUE MOUNTAIN POWER, LP	RICHLAND	PA	07/31/1998	COMBUSTION TURBINE WITH HEAT RECOVERY BOIL	153	4.0	DRY LNB WITH SCR WATER INJECTION IN PLACE WHEN FIRING ON	LAER
EMPIRE DISTRICT ELECTRIC CO.	JOPLIN	MO	05/17/1994	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	168	4.3	NONE	BACT-PSD
ECOELECTRICA, L.P.	PENUELAS	PR	10/01/1996	TURBINES, COMBINED-CYCLE COGENERATION	481	4.4	STEAM/WATER INJECTION AND SELECTIVE CATALYTIC REDUCTIO	BACT-PSD
HERMISTON GENERATING CO	HERMISTON	OR	07/07/1994	TURBINES, NATURAL GAS (2)	212	4.5	SCR	BACT-PSD
LSP - COTTAGE GROVE, L.P.	COTTAGE GROVE	MN	11/10/1998	GENERATOR, COMBUSTION TURBINE & DUCT BURNE	1988	4.5	SELECTIVE CATALYTIC REDUCTION (SCR) WITH A NOX CEM AND A	BACT-PSD
PILGRIM ENERGY CENTER	ISLIP	NY		(2) WESTINGHOUSE W50105 TURBINES (EP #S 00001	175	4.5	STEAM INJECTION FOLLOWED BY SCR	BACT
PORTLAND GENERAL ELECTRIC CO.	BOARDMAN	OR	05/31/1994	TURBINES, NATURAL GAS (2)	215	4.5	SCR	BACT-PSD
SITHE/INDEPENDENCE POWER PARTNERS	OSWEGO	NY	11/24/1992	TURBINES, COMBUSTION (4) (NATURAL GAS) (1012 N	267	4.5	SCR AND DRY LOW NOX	BACT-OTHER
SOUTHWESTERN PUBLIC SERVICE COMPANY/CUNNINGHAM S	HOBBS	NM	02/15/1997	COMBUSTION TURBINE, NATURAL GAS	100	4.5	DRY LOW NOX COMBUSTION	BACT-PSD
WYANDOTTE ENERGY	WYANDOTTE	MI	02/08/1999	TURBINE, COMBINED CYCLE, POWER PLANT	500	4.5	SCR	BACT
PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	ARECIBO	PR	07/31/1995	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE E	248	4.8	FUEL SPEC. FIRING #2 FUEL OIL	BACT-PSD
BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT	PERRYMAN	MD		TURBINE, 140 MW NATURAL GAS FIRED ELECTRIC	140	5.0	DRY BURN LOW NOX BURNERS	BACT-PSD
CARSON ENERGY GROUP & CENTRAL VALLEY FINANCING AU	ELK GROVE	CA	07/23/1993	TURBINE, GAS, COMBINED CYCLE, GE LM6000	56	5.0	SELECTIVE CATALYTIC REDUCTION AND WATER INJECTION ALSO	BACT
CROCKETT COGENERATION - C&H SUGAR	CROCKETT	CA	10/05/1993	TURBINE, GAS, GENERAL ELECTRIC MODEL PG7221(240	5.0	DRY LOW-NOX COMBUSTERS AND A MITSUBISHI HEAVY INDUSTRI	BACT-OTHER
KALAMAZOO POWER LIMITED	COMSTOCK	MI	12/03/1991	TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS	226	5.0	DRY LOW NOX TURBINES	BACT-PSD
MOBILE ENERGY LLC	MOBILE	AL	01/05/1999	TURBINE, GAS, COMBINED CYCLE	168	5.1	SCR & DLN COMBUSTORS DURING GAS FIRING. STEAMWAT	BACT-PSD
KERN FRONT LIMITED	BAKERSFIELD	CA	11/04/1986	TURBINE, GAS, GENERAL ELECTRIC LM-2500	25	5.5	WATER INJECTION AND SELECTIVE CATALYTIC REDUCTION	BACT-OTHER
BRIDGEPORT ENERGY, LLC	BRIDGEPORT	CT	06/29/1998	TURBINES, COMBUSTION MODEL V84.3A, 2 SIEMES	260	6.0	DRY LOW NOX BURNER WITH SCR	BACT-PSD
SOUTH MISSISSIPPI ELECTRIC POWER ASSOC.	MOSELL	MS	04/09/1996	COMBUSTION TURBINE, COMBINED CYCLE	162	6.0	GOOD COMBUSTION CONTROLS	BACT-PSD
SUMAS ENERGY INC.	SUMAS	WA	06/25/1991	TURBINE, NATURAL GAS	88	6.0	SCR	BACT-PSD
AES PLACERITA, INC.		CA	07/02/1987	TURBINE, GAS	66	6.2	SCR, STEAM INJECTION	BACT-PSD
SIMPSON PAPER CO.		CA	06/22/1987	TURBINE, GAS	50	6.6	SCR, STEAM INJECTION	OTHER
MIDWAY - SUNSET PROJECT		CA	01/06/1987	TURBINE, GAS, 3	122	7.2	H2O INJECTION	BACT-PSD
SALINAS RIVER COGENERATION COMPANY		CA	11/19/1990	TURBINE, GAS, W/ HEAT RECOVERY STEAM GENERA	43	7.8	TURBINE DRY LOW NOX COMBUST SYS W/ SCR CNTRL SYS	BACT-PSD
SARGENT CANYON COGENERATION COMPANY		CA	11/19/1990	TURBINE, GAS W/ HEAT RECOVERY STEAM GENERA	43	8.0	TURBINE DRY LOW NOX COMBUST SYS W/ SCR CNTRL SYS	BACT-PSD
BASF CORPORATION	GEISMAR	LA	12/30/1997	TURBINE, COGEN UNIT 2, GE FRAME 6	42	8.0	STEAM INJECTION AND SCR TO LIMIT NOX TO 8 PPM FOR NATURA	BACT-PSD
CHAMPION INTERNATL CORP. & CHAMP. CLEAN ENERGY	BUCKSPORT	ME	09/14/1998	TURBINE, COMBINED CYCLE, NATURAL GAS	175	8.0		BACT-OTHER
RICHMOND POWER ENTERPRISE PARTNERSHIP	RICHMOND	VA	12/12/1989	TURBINE, GAS FIRED, 2	145	8.2	SCR, STEAM INJECTION	LAER
MOJAVE COGENERATION CO		CA	01/12/1989	TURBINE, GAS	61	8.4	FUEL SPEC: OIL FIRING LIMITED TO 11 H/D	BACT-PSD
CAROLINA POWER & LIGHT	GOLDSBORO	NC	04/11/1996	COMBUSTION TURBINE, 4 EACH	238	8.9	COMBUSTION CONTROL	BACT-PSD
LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	NJ	04/01/1991	TURBINES (NATURAL GAS) (2)	149	8.9	SCR, DRY LOW NOX BURNER	BACT-OTHER
NEWARK BAY COGENERATION PARTNERSHIP	NEWARK	NJ	11/01/1990	TURBINE, NATURAL GAS FIRED	73	8.9	STEAM INJECTION AND SCR	BACT-PSD
AIR LIQUIDE AMERICA CORPORATION	GEISMAR	LA	02/13/1998	TURBINE GAS, GE, 7ME 7	121	9.0	DRY LOW NOX TO LIMIT NOX EMISSION TO 9PPMV	BACT-PSD
BAF ENERGY		CA	07/08/1987	TURBINE, GENERATOR	111	9.0	SCR, STEAM INJECTION	BACT-PSD
BEAR ISLAND PAPER COMPANY, L.P.	ASHLAND	VA	10/30/1992	TURBINE, COMBUSTION GAS	59	9.0	SELECTIVE CATALYTIC REDUCTION (SCR)	BACT-PSD
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	CHESTERFIELD	VA	03/03/1992	TURBINE, COMBUSTION	147	9.0	SCR, STEAM INJECTION	BACT-PSD
DOSWELL LIMITED PARTNERSHIP		VA	05/04/1990	TURBINE, COMBUSTION	158	9.0	DRY COMBUSTOR TO 25 PPM SCR TO 9 PPM USING NAT GAS	OTHER
DUKE ENERGY NEW SOMYRNA BEACH POWER CO LP	CHARLOTTE NC (HEADQUARTERS)	FL	10/15/1999	TURBINE-GAS, COMBINED CYCLE	500	9.0	DLN GE DLN2.6 BURNERS	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	JOPLIN	MO	02/28/1995	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	89	9.0	GOOD COMBUSTION CONTROL	BACT-PSD
FORMOSA PLASTICS CORPORATION, BATON ROUGE PLANT	BATON ROUGE	LA	03/07/1997	TURBINE/HSRG, GAS COGENERATION	56	9.0	DRY LOW NOX BURNER/COMBUSTION DESIGN AND CONSTRUCTIO	BACT-PSD

RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - NOx

FACILITY	CITY	STATE	PERMIT	PROCESS	MW	PPM	CTRLDESC	BASIS
FORMOSA PLASTICS CORPORATION, LOUISIANA	BATON ROUGE	LA	03/02/1995	TURBINE/HRSO, GAS COGENERATION	58	9.0	DRY LOW NOX BURNER/COMBUSTION DESIGN AND CONTROL	LAER
KAMINE/BESICORP BEAVER FALLS COGENERATION FACILITY	BEAVER FALLS	NY	11/09/1992	TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW)	81	9.0	DRY LOW NOX OR SCR	BACT-OTHER
KAMINE/BESICORP CORNING L.P.	SOUTH CORNING	NY	11/05/1992	TURBINE, COMBUSTION (79 MW)	82	9.0	DRY LOW NOX OR SCR	BACT-OTHER
MID-GEORGIA COGEN.	KATHLEEN	GA	04/03/1996	COMBUSTION TURBINE (2), NATURAL GAS	116	9.0	DRY LOW NOX BURNER WITH SCR	BACT-PSD
NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO.	PROVIDENCE	RI	04/13/1992	TURBINE, GAS AND DUCT BURNER	170	9.0	SCR	BACT-PSD
NEVADA COGENERATION ASSOCIATES #2	LAS VEGAS	NV	01/17/1991	COMBINED-CYCLE POWER GENERATION	85	9.0	SELECTIVE CATALYTIC SYSTEM ON ONE UNIT	BACT-PSD
NEVADA POWER COMPANY, HARRY ALLEN PEAKING PLANT	LAS VEGAS	NV	09/18/1992	COMBUSTION TURBINE ELECTRIC POWER GENERAT	600	9.0	PRECISION CONTROL FOR THE LOW NOX COMBUSTOR	BACT-PSD
OCEAN STATE POWER	BURRILLVILLE	RI	12/13/1988	TURBINE, GAS, GE FRAME 7, 4 EA	132	9.0	SCR, H2O INJECTION	BACT-PSD
OLEANDER POWER PROJECT	BALTIMORE (HEADQUARTERS)	FL	10/01/1999	TURBINE-GAS, COMBINED CYCLE	190	9.0	DLN 2.6	BACT-PSD
PASNY/HOLTSVILLE COMBINED CYCLE PLANT	HOLTSVILLE	NY	09/01/1992	TURBINE, COMBUSTION GAS (150 MW)	143	9.0	DRY LOW NOX	BACT-OTHER
SARANAC ENERGY COMPANY	PLATTSBURGH	NY	07/31/1992	TURBINES, COMBUSTION (2) (NATURAL GAS)	140	9.0	SCR	BACT-OTHER
SUMAS ENERGY INC	SUMAS	WA	12/01/1990	TURBINE, GAS-FIRED	67	9.0	SELECTIVE CATALYTIC REDUCTION (SCR)	BACT-PSD
SUNLAW/INDUSTRIAL PARK 2		CA	06/28/1985	TURBINE, GAS W/2 FUEL OIL BACKUP, 2 EA, GE FRA	52	9.0	SCR, STEAM INJECTION	OTHER
SANTA ROSA ENERGY LLC	NORTHBROOK	FL	12/04/1998	TURBINE, COMBUSTION, NATURAL GAS	241	9.8	DRY LOW NOX BURNER	BACT-PSD
LAS VEGAS COGENERATION LTD PARTNERSHIP	NORTH LAS VEGAS	NV	10/18/1990	TURBINE, COMBUSTION COGENERATION	50	10.0	H2O INJECTION/SCR	BACT-PSD
TAMPA ELECTRIC COMPANY (TEC)	APOLLO BEACH	FL	10/15/1999	TURBINE, COMBUSTION, SIMPLE CYCLE	165	10.5	DLN	BACT-PSD
PEDRICKTOWN COGENERATION LIMITED PARTNERSHIP	OLDMANS TOWNSHIP	NJ	02/23/1990	TURBINE, NATURAL GAS FIRED	125	11.8	STEAM INJECTION AND SCR	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	FL	02/25/1994	TURBINE, NATURAL GAS (2)	189	12.0	DRY LOW NOX COMBUSTOR	BACT-PSD
ALABAMA POWER COMPANY	MCINTOSH	AL	12/17/1997	COMBUSTION TURBINE W/ DUCT BURNER (COMBINE	100	15.0	DRY LOW NOX BURNERS	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	FL	12/14/1992	TURBINE, GAS	152	15.0	DRY LOW NOX COMBUSTOR	BACT-PSD
GAINESVILLE REGIONAL UTILITIES	GAINESVILLE	FL	04/11/1995	SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL	74	15.0	DRY LOW NOX BURNERS GE FRAME UNIT, CAN ANNULAR COMBUS	BACT-PSD
KALAMAZOO POWER LIMITED	COMSTOCK	MI	12/03/1991	TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS	226	15.0	DRY LOW NOX TURBINES	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	INTERCESSION CITY	FL	04/07/1993	TURBINE, NATURAL GAS	109	15.0	DRY LOW NOX COMBUSTOR	BACT-PSD
PANDA-KATHLEEN, L.P.	LAKELAND	FL	06/01/1995	COMBINED CYCLE COMBUSTION TURBINE (TOTAL 11	75	15.0	DRY LOW NOX BURNER	BACT-PSD
PEPCO - CHALK POINT PLANT	EAGLE HARBOR	MD	06/25/1990	TURBINE, 84 MW NATURAL GAS FIRED ELECTRIC	84	15.0	QUIET COMBUSTION AND WATER INJECTION	BACT-PSD
PUBLIC SERVICE OF COLO - FORT ST VRAIN	PLATTEVILLE	CO	05/01/1996	COMBINED CYCLE TURBINES (2), NATURAL	471	15.0	DRY LOW NOX COMBUSTION SYSTEMS FOR TURBINES AND DUC	BACT-PSD
SEMINOLE HARDEE UNIT 3	FORT GREEN	FL	01/01/1998	COMBINED CYCLE COMBUSTION TURBINE	140	15.0	DRY LNB	BACT-PSD
SOUTHWESTERN PUBLIC SERVICE CO/CUNNINGHAM STATION	HOBBS	NM	11/04/1996	COMBUSTION TURBINE, NATURAL GAS	100	15.0	DRY LOW NOX COMBUSTION	BACT-PSD
TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	GA	12/18/1998	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160	15.0	USING 15% EXCESS AIR, NOX EMISSION IS BECAUSE OF NATURAL	BACT-PSD
TIGER BAY LP	FT. MEADE	FL	05/17/1993	TURBINE, GAS	202	15.0	DRY LOW NOX COMBUSTOR	BACT-PSD
WESTPLAINS ENERGY	PUEBLO	CO	06/14/1996	SIMPLE CYCLE TURBINE, NATURAL GAS	219	15.0	DRY LOW NOX COMBUSTION SYSTEM (DLN), COMMITMENT TOUPO	BACT-PSD
STAR ENTERPRISE	DELAWARE CITY	DE	03/30/1998	TURBINES, COMBINED CYCLE, 2	103	18.0	NITROGEN INJECTION WHILE FIRING SYNGAS AND STEAM INJECT	LAER
WEST CAMPUS COGENERATION COMPANY	COLLEGE STATION	TX	05/02/1994	GAS TURBINES	75	20.5	INTERNAL COMBUSTION CONTROLS	BACT-PSD
SC ELECTRIC AND GAS COMPANY - HAGOOD STATION	CHARLESTON	SC	12/11/1989	INTERNAL COMBUSTION TURBINE	110	21.7	WATER INJECTION	BACT-PSD
SOUTHERN MARYLAND ELECTRIC COOPERATIVE (SMECO)	EAGLE HARBOR	MD	10/01/1989	TURBINE, NATURAL GAS FIRED ELECTRIC	90	22.0	WATER INJECTION	BACT-PSD
ANITEC COGEN PLANT	BINGHAMTON	NY	07/07/1993	GE LM5000 COMBINED CYCLE GAS TURBINE EP #000	56	25.0	NO CONTROLS	BACT-OTHER
CHARLES LARSEN POWER PLANT	CITY OF OF LAKELAND	FL	07/25/1991	TURBINE, GAS, 1 EACH	80	25.0	WET INJECTION	BACT-PSD
CITY OF LAKELAND ELECTRIC AND WATER UTILITIES	LAKELAND	FL	07/10/1998	TURBINE, COMBUSTION, GAS FIRED W/ FUEL OIL ALS	272	25.0	DRY LOW NOX BURNERS FOR SIMPLE CYCLE, SCR WHEN C	BACT-PSD
COLORADO SPRINGS UTILITIES-NIXON POWER PLANT	FOUNTAIN	CO	06/30/1998	SIMPLE CYCLE TURBINE, NATURAL GAS	1122	25.0	DRY LOW NOX COMBUSTION	BACT-PSD
COMMONWEALTH ATLANTIC LTD PARTNERSHIP	CHESAPEAKE	VA	03/05/1991	TURBINE, NAT GAS & #2 OIL	192	25.0	H2O INJECTION & LOW NOX COMBUSTION, ANNUAL STACK TESTIN	BACT-PSD
FLORIDA POWER AND LIGHT	NORTH PALM BEACH	FL	06/05/1991	TURBINE, GAS, 4 EACH	400	25.0	LOW NOX COMBUSTORS	BACT-PSD
GEORGIA GULF CORPORATION	PLAQUEMINE	LA	03/28/1998	GENERATOR, NATURAL GAS FIRED TURBINE	140	25.0	CONTROL NOX USING STEAM INJECTION	BACT-PSD
GEORGIA POWER COMPANY, ROBINS TURBINE PROJECT	ROBINS AIR FORCE BASE	GA	05/13/1994	TURBINE, COMBUSTION, NATURAL GAS	80	25.0	WATER INJECTION, FUEL SPEC: NATURAL GAS	BACT-PSD
GEORGIA POWER COMPANY, ROBINS TURBINE PROJECT	ROBINS AIR FORCE BASE	GA	05/13/1994	TURBINE, COMBUSTION, NATURAL GAS	80	25.0	WATER INJECTION, FUEL SPEC: NATURAL GAS	BACT-PSD
HARTWELL ENERGY LIMITED PARTNERSHIP	HARTWELL	GA	07/28/1992	TURBINE, GAS FIRED (2 EACH)	227	25.0	MAXIMUM WATER INJECTION	BACT-PSD
JMC SELKIRK, INC.	SELKIRK	NY	11/21/1989	TURBINE, GE FRAME 7, GAS FIRED	80	25.0	STEAM INJECTION	BACT-PSD
KAMINE/BESICORP SYRACUSE LP	SOLVAY	NY	12/10/1994	SIEMENS V64.3 GAS TURBINE (EP #00001)	81	25.0	WATER INJECTION	BACT
LORDSBURG L.P.	LORDSBURG	NM	06/18/1997	TURBINE, NATURAL GAS-FIRED, ELEC. GEN.	100	25.0	DRY LOW-NOX TECHNOLOGY WHICH ADOPTS STAGED OR	SCH
MARCH POINT COGENERATION CO		WA	10/26/1990	TURBINE, GAS-FIRED	80	25.0	MASSIVE STEAM INJECTION	BACT-PSD
MEAD COATED BOARD, INC.	PHENIX CITY	AL	03/12/1987	COMBINED CYCLE TURBINE (25 MW)	71	25.0	FUEL OIL SULFUR CONTENT <=0.05% BY WEIGHT DRY LOW NOX C	BACT-PSD
PACIFIC THERMONETICS, INC.	CROCKETT	CA	12/10/1985	TURBINE, GAS, FRAME 7, 2 EA	127	25.0	QUIET COMBUSTOR FUEL SPEC: NATURAL GAS FIRING L LIMITED	BACT-PSD
PEABODY MUNICIPAL LIGHT PLANT	PEABODY	MA	11/30/1989	TURBINE, 38 MW NATURAL GAS FIRED	52	25.0	WATER INJECTION	BACT-OTHER
PEPCO - STATION A	DICKERSON	MD	05/31/1990	TURBINE, 124 MW NATURAL GAS FIRED	125	25.0	WATER INJECTION	BACT-PSD
PG & E, STATION T	SAN FRANCISCO	CA	08/25/1986	TURBINE, GAS, GE LM5000	50	25.0	STEAM INJECTION AT STEAM/FUEL RATIO = 1.7/1	BACT-PSD
PROJECT ORANGE ASSOCIATES	SYRACUSE	NY	12/01/1993	GE LM-5000 GAS TURBINE	89	25.0	STEAM INJECTION, FUEL SPEC: NATURAL GAS ONLY	BACT
SYRACUSE UNIVERSITY	SYRACUSE	NY	09/01/1989	TURBINE, GAS FIRED	79	25.0	STEAM INJECTION	OTHER
UNION CARBIDE CORPORATION	HAHNVILLE	LA	09/22/1995	GENERATOR, GAS TURBINE	164	25.0	DRY LOW NOX COMBUSTOR	BACT-PSD
WI ELECTRIC POWER CO.	CONCORD STATION	WI	10/18/1990	TURBINES, COMBUSTION, SIMPLE CYCLE, 4	75	25.0	H2O INJECTION	BACT-PSD
DELMARVA POWER	WILMINGTON	DE	09/27/1990	TURBINE, COMBUSTION	100	27.1	LOW NOX BURNER	BACT-PSD
ONEIDA COGENERATION FACILITY	ONEIDA	NY	02/26/1990	TURBINE, GE FRAME 6	52	32.0	COMBUSTION CONTROL	OTHER
CHAMPION INTERNATIONAL CORP.	SHELDON	TX	03/05/1985	TURBINE, GAS, 2	168	33.2		BACT-PSD
FULTON COGENERATION ASSOCIATES	FULTON	NY	01/29/1990	TURBINE, GE LM5000, GAS FIRED	63	36.0	H2O INJECTION	BACT-PSD

RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - NOx

FACILITY	CITY	STATE	PERMIT	PROCESS	MW	PPM	CTRLDESC	BASIS
KAMINE SYRACUSE COGENERATION CO.	SOLVAY	NY	09/01/1989	TURBINE, GAS FIRED	79	38.0	WATER INJECTION	OTHER
MIDWAY-SUNSET COGENERATION CO.		CA	01/27/1988	TURBINE, GE FRAME 7, 3 EA	75	38.4	H2O INJECTION, QUIET COMBUSTOR™	BACT-PSD
O'BRIEN COGENERATION	HARTFORD	CT	08/08/1988	TURBINE, GAS FIRED	82	39.0	WATER INJECTION	BACT-PSD
CAPITOL DISTRICT ENERGY CENTER	HARTFORD	CT	10/23/1989	ENGINE, GAS TURBINE	92	42.0	STEAM INJECTION	BACT-PSD
CITY UTILITIES OF SPRINGFIELD	SPRINGFIELD	MO	03/04/1991	GENERATION OF ELECTRICAL POWER	73	42.0	WATER INJECTION	BACT-PSD
CITY UTILITIES OF SPRINGFIELD	SPRINGFIELD	MO	03/08/1991	GENERATION OF ELECTRICAL POWER	94	42.0	WATER INJECTION	BACT-PSD
DELMARVA POWER	WILMINGTON	DE	08/23/1988	TURBINE, COMBUSTION, 2 EA	100	42.0	LOW NOX BURNER, WATER INJECTION	BACT-PSD
EMPIRE ENERGY - NIAGARA COGENERATION CO.	LOCKPORT	NY	05/02/1989	TURBINE, GR FRAME 6, 3 EA	52	42.0	STEAM INJECTION	BACT-PSD
FLORIDA POWER AND LIGHT	LAVOGROME	FL	03/14/1991	TURBINE, GAS, 4 EACH	240	42.0	COMBUSTION CONTROL	BACT-PSD
HOPEWELL COGENERATION LIMITED PARTNERSHIP		VA	07/01/1988	TURBINE, NAT GAS FIRED, 3 EA	129	42.0		BACT-PSD
INDECK-YERKES ENERGY SERVICES	TONAWANDA	NY	06/24/1992	GE FRAME 6 GAS TURBINE (EP #00001)	54	42.0	STEAM INJECTION	BACT
KAMINE SOUTH GLENS FALLS COGEN CO	SOUTH GLENS FALLS	NY	09/10/1992	GE FRAME 6 GAS TURBINE	82	42.0	WATER INJECTION	BACT
KAMINE/BESICORP NATURAL DAM LP	NATURAL DAM	NY	12/31/1991	GE FRAME 6 GAS TURBINE	83	42.0	STEAM INJECTION	BACT
LEDERLE LABORATORIES	PEARL RIVER	NY		(2) GAS TURBINES (EP #S 00101&102)	14	42.0	STEAM INJECTION	BACT-PSD
LOCKPORT COGEN FACILITY	LOCKPORT	NY	07/14/1993	(6) GE FRAME 6 TURBINES (EP #S 00001-00006)	53	42.0	STEAM INJECTION	BACT
MEGAN-RACINE ASSOCIATES, INC.	CANTON	NY	08/05/1989	GE LMS000-N COMBINED CYCLE GAS TURBINE	401	42.0	WATER INJECTION	BACT
MEGAN-RACINE ASSOCIATES, INC.	CANTON	NY	03/08/1989	TURBINE, LMS000	54	42.0	H2O INJECTION	BACT-PSD
MIDLAND COGENERATION VENTURE	MIDLAND	MI	02/16/1988	TURBINE, 12 TOTAL	123	42.0	STEAM INJECTION	BACT-PSD
THE DEXTER CORP.	WINDSOR LOCKS	CT	09/29/1989	TURBINE, NAT GAS & #2 FUEL OIL FIRED	69	42.0	STEAM INJECTION	BACT-PSD
VIRGINIA POWER	CHESTERFIELD	VA	04/15/1988	TURBINE, GE 2 EA	234	42.0	STEAM INJECTION W/MAXIMIZATION (NSPS SUBPART GG)	LAER
VIRGINIA POWER		VA	09/07/1989	TURBINE, GAS	164	42.0	H2O INJECTION, RECORD KEEPING OF FUEL N2 CONTENT	BACT-PSD
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #7 FRAME	131	44.8	H2O INJECTION	BACT-PSD
LONG ISLAND LIGHTING CO.		NY	11/01/1988	TURBINE, GE FRAME 7, 3 EA	75	55.0	WATER INJECTION	BACT-PSD
PROCTOR AND GAMBLE PAPER PRODUCTS CO (CHARMIN)	MEHOOPANY	PA	05/31/1995	TURBINE, NATURAL GAS	73	55.0	STEAM INJECTION	RACT
TRIGEN MITCHEL FIELD	HEMPSTEAD	NY	04/16/1993	GE FRAME 6 GAS TURBINE	53	80.0	STEAM INJECTION	BACT
ALASKA ELECTRICAL GENERATION & TRANSMISSION	BIG LAKE	AK	03/18/1987	TURBINE, NAT GAS FIRED	80	75.0	H2O INJECTION	BACT-PSD
CONTINENTAL ENERGY ASSOC.	HAZELTON	PA	07/26/1988	TURBINE, NAT GAS	98	75.0	STEAM INJECTION	BACT-PSD
SOUTHEAST PAPER CORP.	DUBLIN	GA	10/13/1987	TURBINE, COMBUSTION	68	100.0	STEAM INJECTION	BACT-PSD

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some PPM values were calculated using a conversion factor based on the F-Factor and molecular weight of NO_x: 1 (PPM) = (lb/mmBtu) * 271

lb/mmBtu values were also calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - CO

FACILITY	CITY	STATE	PERMIT	PROCESS	MW ¹	PPM ²	CTRLDESC	BASIS
PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	ARECIBO	PR	07/31/1995	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EA	248	1.0	MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND	BACT-PSD
HARTWELL ENERGY LIMITED PARTNERSHIP	HARTWELL	GA	07/28/1992	TURBINE, GAS FIRED (2 EACH)	227	1.8	MAXIMUM WATER INJECTION	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NEWARK	NJ	06/09/1993	TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)	77	1.8	OXIDATION CATALYST	OTHER
VIRGINIA POWER		VA	09/07/1989	TURBINE, GAS	164	2.1		BACT-PSD
SC ELECTRIC AND GAS COMPANY - HAGOOD STATION	CHARLESTON	SC	12/11/1989	INTERNAL COMBUSTION TURBINE	110	2.7	GOOD COMBUSTION PRACTICES	BACT-PSD
CHARLES LARSEN POWER PLANT	CITY OF OF LAKELAND	FL	07/25/1991	TURBINE, GAS, 1 EACH	80	3.0	FUEL SPEC: NATURAL GAS	BACT-PSD
SARANAC ENERGY COMPANY	PLATTSBURGH	NY	07/31/1992	TURBINES, COMBUSTION (2) (NATURAL GAS)	140	3.0	OXIDATION CATALYST	BACT-OTHER
TIGER BAY LP	FT. MEADE	FL	05/17/1993	TURBINE, GAS	202	3.0	GOOD COMBUSTION PRACTICES	BACT-PSD
WYANDOTTE ENERGY	WYANDOTTE	MI	02/08/1999	TURBINE, COMBINED CYCLE, POWER PLANT	500	3.0	CATALYTIC OXIDIZER	LAER
BLUE MOUNTAIN POWER, LP	RICHLAND	PA	07/31/1996	COMBUSTION TURBINE WITH HEAT RECOVERY BOILER	153	3.1	OXIDATION CATALYST 16 PPM @ 15% O2 WHEN FIRING NO	OTHER
BERKSHIRE POWER DEVELOPMENT, INC.	AGAWAM	MA	09/22/1997	TURBINE, COMBUSTION, ABB GT24	224	3.6	DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD	BACT-PSD
FLORIDA POWER AND LIGHT	NORTH PALM BEACH	FL	06/05/1991	TURBINE, CG, 4 EACH	400	3.6	LOW NOX COMBUSTORS	BACT-PSD
AES PLACERITA, INC.		CA	03/10/1986	TURBINE & RECOVERY BOILER	65	3.7	OXIDATION CATALYST	BACT-PSD
BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.	NEW YORK CITY	NY	06/06/1995	TURBINE, NATURAL GAS FIRED	240	4.0	OXIDATION CATALYST	LAER
CAROLINA POWER & LIGHT	GOLDSBORO	NC	04/11/1996	COMBUSTION TURBINE, 4 EACH	238	4.3	COMBUSTION CONTROL	BACT-PSD
CHAMPION INTERNATIONAL CORP.	SHELDON	TX	03/05/1985	TURBINE, GAS, 2	168	5.3		BACT-PSD
PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	ARECIBO	PR	07/31/1995	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EA	248	5.3	MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND	BACT-PSD
CROCKETT COGENERATION - C&H SUGAR	CROCKETT	CA	10/05/1993	TURBINE, GAS, GENERAL ELECTRIC MODEL PG7221(F	240	5.9	ENGELHARD OXIDATION CATALYST	BACT-OTHER
PUBLIC SERVICE OF COLO.-FORT ST VRAIN	PLATTEVILLE	CO	05/01/1996	COMBINED CYCLE TURBINES (2), NATURAL	471	5.9	GOOD COMBUSTION CONTROL PRACTICES, COMMITMENT	BACT-PSD
SUMAS ENERGY INC.	SUMAS	WA	08/25/1991	TURBINE, NATURAL GAS	88	6.0	CO CATALYST	BACT-PSD
KISSIMEE UTILITY AUTHORITY	INTERCESSION CITY	FL	04/07/1993	TURBINE, NATURAL GAS	109	6.1	DRY LOW NOX COMBUSTOR	BACT-PSD
PASNY/HOLTSVILLE COMBINED CYCLE PLANT	HOLTSVILLE	NY	09/01/1992	TURBINE, COMBUSTION GAS (150 MW)	143	8.5	COMBUSTION CONTROL	BACT-OTHER
DOSWELL LIMITED PARTNERSHIP		VA	05/04/1990	TURBINE, COMBUSTION	158	8.8	COMBUSTOR DESIGN & OPERATION	OTHER
FULTON COGENERATION ASSOCIATES	FULTON	NY	01/29/1990	TURBINE, GE LM5000, GAS FIRED	63	8.9	COMBUSTION CONTROL	BACT-PSD
KAMINE/BESICORP NATURAL DAM LP	NATURAL DAM	NY	12/31/1991	GE FRAME 6 GAS TURBINE	63	8.9	NO CONTROLS	BACT-OTHER
CHAMPION INTERNATL CORP. & CHAMP. CLEAN ENER	BUCKSPORT	ME	09/14/1998	TURBINE, COMBINED CYCLE, NATURAL GAS	175	9.0	NONE	BACT-OTHER
FLORIDA POWER AND LIGHT	LAVOGROME REPOWER	FL	03/14/1991	TURBINE, GAS, 4 EACH	240	9.0	FUEL SPEC: NATURAL GAS AS FUEL	BACT-PSD
KAMINE SOUTH GLENS FALLS COGEN CO	SOUTH GLENS FALLS	NY	09/10/1992	GE FRAME 6 GAS TURBINE	82	9.0	NO CONTROLS	BACT-OTHER
KAMINE/BESICORP BEAVER FALLS COGENERATION FA	BEAVER FALLS	NY	11/09/1992	TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW)	81	9.5	COMBUSTION CONTROLS	BACT-OTHER
KAMINE/BESICORP SYRACUSE LP	SOLVAY	NY	12/10/1994	SIEMENS V64.3 GAS TURBINE (EP #00001)	81	9.5	NO CONTROLS	BACT-OTHER
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #6 FRAME	82	9.6	COMBUSTION CONTROL	BACT-PSD
BRIDGEPORT ENERGY, LLC	BRIDGEPORT	CT	06/29/1998	TURBINES, COMBUSTION MODEL V84.3A, 2 SIEMES	260	10.0	PRE-MIX FUEL FAIR TO OPTIMIZE EFFICIENCY ACTUAL EM	BACT-PSD
INDECK-YERKES ENERGY SERVICES	TONAWANDA	NY	06/24/1992	GE FRAME 6 GAS TURBINE (EP #00001)	54	10.0	NO CONTROLS	BACT-OTHER
LOCKPORT COGEN FACILITY	LOCKPORT	NY	07/14/1993	(6) GE FRAME 6 TURBINES (EP #S 00001-00006)	53	10.0	NO CONTROLS	BACT-OTHER
LONG ISLAND LIGHTING CO.		NY	11/01/1988	TURBINE, GE FRAME 7, 3 EA	75	10.0	COMBUSTION CONTROL	OTHER
MID-GEORGIA COGEN.	KATHLEEN	GA	04/03/1996	COMBUSTION TURBINE (2), NATURAL GAS	116	10.0	COMPLETE COMBUSTION	BACT-PSD
PILGRIM ENERGY CENTER	ISLIP	NY		(2) WESTINGHOUSE W501DS TURBINES (EP #S 000018	175	10.0		BACT-OTHER
SUNLAW/INDUSTRIAL PARK 2		CA	06/28/1985	TURBINE, GAS W/#2 FUEL OIL BACKUP, 2 EA, GE FRA	52	10.0	MFG GUARANTEE ON CO EMISSIONS	OTHER
SYCAMORE COGENERATION CO.	BAKERSFIELD	CA	03/06/1987	TURBINE, GAS FIRED, 4 EA	75	10.0	CO OXIDIZING CATALYST, COMBUSTION CONTROL	BACT-PSD
TRIGEN MITCHEL FIELD	HEMPSTEAD	NY	04/16/1993	GE FRAME 6 GAS TURBINE	53	10.0	NO CONTROLS	BACT-OTHER
WESTPLAINS ENERGY	PUEBLO	CO	06/14/1996	SIMPLE CYCLE TURBINE, NATURAL GAS	219	10.0	DRY LOW NOX COMBUSTION SYSTEM (DLN), COMMITMENT	BACT-PSD
BEAR ISLAND PAPER COMPANY, L.P.	ASHLAND	VA	10/30/1992	TURBINE, COMBUSTION GAS	59	10.3	GOOD COMBUSTION	BACT-PSD
PORTSIDE ENERGY CORP.	PORTAGE	IN	05/13/1996	TURBINE, NATURAL GAS-FIRED	83	10.8	GOOD COMBUSTION AND EMISSIONS NOT TO EXCEED 10 F	BACT-PSD
EMPIRE ENERGY - NIAGARA COGENERATION CO.	LOCKPORT	NY	05/02/1989	TURBINE, GR FRAME 6, 3 EA	52	10.7	COMBUSTION CONTROL	BACT-PSD
HOPEWELL COGENERATION LIMITED PARTNERSHIP		VA	07/01/1988	TURBINE, NAT GAS FIRED, 3 EA	129	10.9	STEAM INJECTION	BACT-PSD
NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO	PROVIDENCE	RI	04/13/1992	TURBINE, GAS AND DUCT BURNER	170	11.0	NONE	BACT-PSD
SEPCO	RIO LINDA	CA	10/05/1994	TURBINE, GAS COMBINED CYCLE GE MODEL 7	115	11.6	OXIDATION CATALYST	BACT
LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	NJ	04/01/1991	TURBINES (NATURAL GAS) (2)	149	11.6	TURBINE DESIGN	BACT-OTHER
MEGAN-RACINE ASSOCIATES, INC.	CANTON	NY	08/05/1989	GE LM5000-N COMBINED CYCLE GAS TURBINE	401	11.6	NO CONTROLS	BACT-OTHER
MEGAN-RACINE ASSOCIATES, INC.	CANTON	NY	03/08/1989	TURBINE, LM5000	54	11.8	COMBUSTION CONTROL	OTHER
MIDLAND COGENERATION VENTURE	MIDLAND	MI	02/16/1988	TURBINE, 12 TOTAL	123	11.8	TURBINE DESIGN	BACT-PSD
DUKE ENERGY NEW SOMYRNA BEACH POWER CO. LP	CHARLOTTE NC (HEADQ	FL	10/15/1999	TURBINE-GAS, COMBINED CYCLE	500	12.0	GOOD COMBUSTION	BACT-PSD
GRANITE ROAD LIMITED		CA	05/08/1991	TURBINE, GAS, ELECTRIC GENERATION	58	12.0	SCR, STEAM INJECTION	BACT-PSD
OLEANDER POWER PROJECT	BALTIMORE (HEADQUAR	FL	10/01/1999	TURBINE-GAS, COMBINED CYCLE	190	12.0	GOOD COMBUSTION	BACT-PSD
TIVERTON POWER ASSOCIATES	TIVERTON	RI	02/13/1988	COMBUSTION TURBINE, NATURAL GAS	285	12.0	GOOD COMBUSTION	BACT-PSD

RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - CO

FACILITY	CITY	STATE	PERMIT	PROCESS	MW	PPM	CTRLDESC	BASIS
KAMINE SYRACUSE COGENERATION CO.	SOLVAY	NY	09/01/1989	TURBINE, GAS FIRED	79	12.5	COMBUSTION CONTROL	OTHER
SITHE/INDEPENDENCE POWER PARTNERS	OSWEGO	NY	11/24/1992	TURBINES, COMBUSTION (4) (NATURAL GAS) (1012 M	267	13.0	COMBUSTION CONTROLS	BACT-OTHER
TIGER BAY LP	FT. MEADE	FL	05/17/1993	TURBINE, GAS	202	13.5	GOOD COMBUSTION PRACTICES	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	FL	12/14/1992	TURBINE, GAS	152	15.0	GOOD COMBUSTION PRACTICES	BACT-PSD
DELMARVA POWER	WILMINGTON	DE	08/23/1988	TURBINE, COMBUSTION, 2 EA	100	15.0	GOOD COMBUSTION PRACTICES	BACT-PSD
GEORGIA POWER COMPANY, ROBINS TURBINE PROJ	ROBINS AIR FORCE BAS	GA	05/13/1994	TURBINE, COMBUSTION, NATURAL GAS	80	15.0	FUEL SPEC: LOW SULFUR FUEL (.3% AVG) FUEL 0.1	BACT-PSD
HERMISTON GENERATING CO.	HERMISTON	OR	07/07/1994	TURBINES, NATURAL GAS (2)	212	15.0	GOOD COMBUSTION PRACTICES	BACT-PSD
MEAD COATED BOARD, INC.	PHENIX CITY	AL	03/12/1997	COMBINED CYCLE TURBINE (25 MW)	71	15.0	PRIMARY FUEL IS NATURAL GAS WITH BACKUP FUEL AS	BACT-PSD
PORTLAND GENERAL ELECTRIC CO.	BOARDMAN	OR	05/31/1994	TURBINES, NATURAL GAS (2)	215	15.0	GOOD COMBUSTION PRACTICES	BACT-PSD
PSI ENERGY, INC. WABASH RIVER STATION	WEST TERRE HAUTE	IN	05/27/1993	COMBINED CYCLE SYNGAS TURBINE	222	15.0	OPERATION PRACTICES AND GOOD COMBUSTION, COMBIN	BACT-PSD
PUBLIC SERVICE OF COLO.-FORT ST VRAIN	PLATTEVILLE	CO	05/01/1996	COMBINED CYCLE TURBINES (2), NATURAL	471	15.0	GOOD COMBUSTION CONTROL PRACTICES, COMMITMENT	BACT-PSD
RUMFORD POWER ASSOCIATES	RUMFORD	ME	05/01/1998	TURBINE GENERATOR, COMBUSTION, NATURAL GAS	238	15.0	GE DRY LOW-NOX COMBUSTOR DESIGN, GOOD COMBUSTI	BACT-PSD
SUMAS ENERGY INC	SUMAS	WA	12/01/1990	TURBINE, GAS-FIRED	67	15.0	CO CATALYST	BACT-PSD
TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	GA	12/18/1998	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160	15.0	USING 15% EXCESS AIR. CO EMISSION IS BECAUSE OF NA	BACT-PSD
WESTBROOK POWER LLC	WESTBROOK	ME	12/04/1998	TURBINE, COMBINED CYCLE, TWO	528	15.0	USING 15 % EXCESS AIR.	BACT-PSD
LORDSBURG L.P.	LORDSBURG	NM	06/18/1997	TURBINE, NATURAL GAS-FIRED, ELEC. GEN.	100	15.0	DRY LOW-NOX TECHNOLOGY BY MAINTAINING PROPER AIR	BACT-PSD
UNION CARBIDE CORPORATION	HAHNVILLE	LA	09/22/1995	GENERATOR, GAS TURBINE	184	15.4	NO ADD-ON CONTROL	GOOD COMBUSTI
FORMOSA PLASTICS CORPORATION, BATON ROUGE P	BATON ROUGE	LA	03/07/1997	TURBINE/HSRG, GAS COGENERATION	56	15.8	COMBUSTION DESIGN AND CONSTRUCTION.	BACT-PSD
PROJECT ORANGE ASSOCIATES	SYRACUSE	NY	12/01/1993	GE LM-5000 GAS TURBINE	69	17.0	NO CONTROLS	BACT-OTHER
MOBILE ENERGY LLC	MOBILE	AL	01/05/1999	TURBINE, GAS, COMBINED CYCLE	168	17.8	GOOD COMBUSTION PRACTICES	BACT-PSD
DUKE POWER CO. LINCOLN COMBUSTION TURBINE ST	LOWESVILLE	NC	12/20/1991	TURBINE, COMBUSTION	164	20.0	COMBUSTION CONTROL	BACT-PSD
BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT	PERRYMAN	MD		TURBINE, 140 MW NATURAL GAS FIRED ELECTRIC	140	20.0	GOOD COMBUSTION PRACTICES	BACT-PSD
CASCO RAY ENERGY CO	VEAZIE	ME	07/13/1998	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170	20.0	15% EXCESS AIR	BACT-PSD
KALAMAZOO POWER LIMITED	COMSTOCK	MI	12/03/1991	TURBINE, GAS-FIRED, 2. W/ WASTE HEAT BOILERS	226	20.0	DRY LOW NOX TURBINES	BACT-PSD
SEMINOLE HARDEE UNIT 3	FORT GREEN	FL	01/01/1996	COMBINED CYCLE COMBUSTION TURBINE	140	20.0	DRY LNB	GOOD COMBUSTION PRA
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	CHESTERFIELD	VA	03/03/1992	TURBINE, COMBUSTION	147	23.5	FURNACE DESIGN	BACT-PSD
AIR LIQUIDE AMERICA CORPORATION	GEISMAR	LA	02/13/1998	TURBINE GAS, GE, 7ME 7	121	25.0	GOOD EQUIPMENT DESIGN, PROPER COMBUSTION TECHNI	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	FL	02/25/1994	TURBINE, NATURAL GAS (2)	189	25.0	GOOD COMBUSTION PRACTICES	BACT-PSD
JMC SELKIRK, INC.	SELKIRK	NY	11/21/1989	TURBINE, GE FRAME 7, GAS FIRED	80	25.0	COMBUSTION CONTROL	BACT-PSD
OCEAN STATE POWER	BURRILLVILLE	RI	12/13/1988	TURBINE, GAS, GE FRAME 7, 4 EA	132	25.0		BACT-PSD
PANDA-KATHLEEN, L.P.	LAKELAND	FL	06/01/1995	COMBINED CYCLE COMBUSTION TURBINE (TOTAL 115	75	25.0	COMBUSTION CONTROLS STANDARD ONLY APPLIES IF GE	BACT-PSD
ALABAMA POWER PLANT BARRY	BUCKS	AL	08/07/1998	TURBINES, COMBUSTION, NATURAL GAS	510	25.4	EFFICIENT COMBUSTION	BACT-PSD
NEVADA POWER COMPANY, HARRY ALLEN PEAKING PL	LAS VEGAS	NV	09/18/1992	COMBUSTION TURBINE ELECTRIC POWER GENERATI	75	25.8	PRECISION CONTROL FOR THE LOW NOX COMBUSTOR	BACT-PSD
NEVADA COGENERATION ASSOCIATES #1	LAS VEGAS	NV	01/17/1991	COMBINED-CYCLE POWER GENERATION	85	26.2	CATALYTIC CONVERTER	BACT-PSD
SOUTH MISSISSIPPI ELECTRIC POWER ASSOC.	MOSELL	MS	04/09/1996	COMBUSTION TURBINE, COMBINED CYCLE	162	26.3	GOOD COMBUSTION CONTROLS	BACT-PSD
COLORADO SPRINGS UTILITIES-NIXON POWER PLANT	FOUNTAIN	CO	06/30/1998	SIMPLE CYCLE TURBINE, NATURAL GAS	1122	30.0	DRY LOW NOX COMBUSTION	BACT-PSD
COMMONWEALTH ATLANTIC LTD PARTNERSHIP	CHESAPEAKE	VA	03/05/1991	TURBINE, NAT GAS & #2 OIL	192	30.0	COMBUSTION CONTROLS, ANNUAL STACK TESTING	BACT-PSD
CITY OF LAKELAND ELECTRIC AND WATER UTILITIES	LAKELAND	FL	07/10/1998	TURBINE, COMBUSTION, GAS FIRED W/ FUEL OIL ALS	272	31.2	DRY LOW NOX BURNERS FOR SIMPLE CYCLE.	SCR V BACT-PSD
MILLENNIUM POWER PARTNER, LP	CHARLTON	MA	02/02/1998	TURBINE, COMBUSTION, WESTINGHOUSE MODEL 501	317	31.2	DRY LOW NOX COMBUSTION TECHNOLOGY IN CONJUNCTI	BACT-PSD
ECOELECTRICA, L.P.	PENUELAS	PR	10/01/1996	TURBINES, COMBINED-CYCLE COGENERATION	461	33.0	COMBUSTION CONTROLS.	BACT-PSD
VIRGINIA POWER	CHESTERFIELD	VA	04/15/1988	TURBINE, GE, 2 EA	234	33.2	EQUIPMENT DESIGN	LAER
ANITEC COGEN PLANT	BINGHAMTON	NY	07/07/1993	GE LM5000 COMBINED CYCLE GAS TURBINE EP #0000	56	36.0	BAFFLE CHAMBER	SEE NOTE #4
MARCH POINT COGENERATION CO		WA	10/26/1990	TURBINE, GAS-FIRED	80	37.0	GOOD COMBUSTION	BACT-PSD
CAROLINA COGENERATION CO., INC.	NEW BERN	NC	07/11/1986	TURBINE, GAS, PEAT FIRED	52	37.0	PROPER OPERATION	BACT-PSD
CARSON ENERGY GROUP & CENTRAL VALLEY FINAN	ELK GROVE	CA	07/23/1993	TURBINE, GAS SIMPLE CYCLE LM6000	56	39.5	OXIDATION CATALYST	BACT
INDECK ENERGY COMPANY	SILVER SPRINGS	NY	05/12/1993	GE FRAME 8 GAS TURBINE EP #00001	61	40.0	NO CONTROLS	BACT-OTHER
ONEIDA COGENERATION FACILITY	ONEIDA	NY	02/26/1990	TURBINE, GE FRAME 6	52	40.0	COMBUSTION CONTROL	OTHER
PEABODY MUNICIPAL LIGHT PLANT	PEABODY	MA	11/30/1989	TURBINE, 38 MW NATURAL GAS FIRED	52	40.0	GOOD COMBUSTION PRACTICES	BACT-OTHER
GAINESVILLE REGIONAL UTILITIES	GAINESVILLE	FL	04/11/1995	OIL FIRED COMBUSTION TURBINE	74	42.0	FUEL SPEC: LOW S OIL 0.05% S	BACT-PSD
CAPITOL DISTRICT ENERGY CENTER	HARTFORD	CT	10/23/1989	ENGINE, GAS TURBINE	92	49.8		BACT-PSD
THE DEXTER CORP.	WINDSOR LOCKS	CT	09/29/1989	TURBINE, NAT GAS & #2 FUEL OIL FIRED	69	49.8		BACT-PSD
SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	CA	08/19/1994	TURBINE, GAS, COMBINED CYCLE LM6000	53	50.0	OXIDATION CATALYST	BACT
WEST CAMPUS COGENERATION COMPANY	COLLEGE STATION	TX	05/02/1994	GAS TURBINES	75	50.6	INTERNAL COMBUSTION CONTROLS	BACT
CARSON ENERGY GROUP & CENTRAL VALLEY FINAN	ELK GROVE	CA	07/23/1993	TURBINE, GAS, COMBINED CYCLE, GE LM6000	450	50.7	SELECTIVE CATALYTIC REDUCTION AND WATER INJECTION	BACT
FORMOSA PLASTICS CORPORATION	BATON ROUGE	LA	09/20/1990	TURBINE, GAS-FIRED, 2	73	53.1	COMBUSTION CONTROL	BACT-PSD

**RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - CO**

FACILITY	CITY	STATE	PERMIT	PROCESS	MW ¹	PPM ²	CTRLDESC	BASIS
SIMPSON PAPER CO.		CA	06/22/1987	TURBINE, GAS	50	61.0	COMBUSTION CONTROLS	OTHER
EMPIRE DISTRICT ELECTRIC CO.	JOPLIN	MO	02/28/1995	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	89	61.2	GOOD COMBUSTION CONTROL	BACT-PSD
MIDWAY-SUNSET COGENERATION CO.		CA	01/27/1988	TURBINE, GE FRAME 7, 3 EA	75	69.7	GOOD COMBUSTION PRACTICES	BACT-PSD
PROJECT ORANGE ASSOCIATES	SYRACUSE	NY	12/01/1993	GE LM-5000 GAS TURBINE	69	74.4	NO CONTROLS	BACT-OTHER
SYRACUSE UNIVERSITY	SYRACUSE	NY	09/01/1989	TURBINE, GAS FIRED	79	75.7	CATALYTIC OXIDATION	OTHER
GEORGIA GULF CORPORATION	PLAQUEMINE	LA	03/26/1996	GENERATOR, NATURAL GAS FIRED TURBINE	140	88.0	GOOD COMBUSTION PRACTICE AND PROPER OPERATION	BACT-PSD

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some PPM values were calculated using a conversion factor based on the F-Factor and molecular weight of CO: 1 (PPM) = (lb/mmBtu) * 445

lb/mmBtu values were also calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - SO₂

FACILITY	CITY	STATE	PERMIT	PROCESS	MW ¹	lb/mmBtu ²	CTRLDESC	BASIS
ECOELECTRICA, L.P.	PENUELAS	PR	10/01/1996	TURBINES, COMBINED-CYCLE COGENERATION	461	0.00014	MAINTAIN EACH TURBINE IN GOOD WORKING	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	JOPLIN	MO	05/17/1994	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	1345	0.00011	LOW SULFUR CONTENT & COMBUSTION CONT	BACT-PSD
PROCTOR AND GAMBLE PAPER PRODUCTS C	MEHOOPANY	PA	05/31/1995	TURBINE, NATURAL GAS	73	0.00014	STEAM INJECTION	RACT
PUERTO RICO ELECTRIC POWER AUTHORITY	ARECIBO	PR	07/31/1995	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE E	248	0.00035	MAINTAIN EACH TURBINE IN GOOD WORKING	BACT-PSD
CAROLINA POWER & LIGHT	GOLDSBORO	NC	04/11/1996	COMBUSTION TURBINE, 4 EACH	238	0.00052	COMBUSTION CONTROL	BACT-PSD
DUKE POWER CO. LINCOLN COMBUSTION TU	LOWESVILLE	NC	12/20/1991	TURBINE, COMBUSTION	164	0.00053	COMBUSTION CONTROL	BACT-PSD
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #6 FRAME	62	0.00058	FUEL SPEC: LOW S FUEL	BACT-PSD
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #7 FRAME	131	0.00059	FUEL SPEC: LOW S FUEL	BACT-PSD
FLORIDA POWER CORPORATION POLK COUN	BARTOW	FL	02/25/1994	TURBINE, NATURAL GAS (2)	189	0.00066	FUEL SPEC: LOW SULFUR IN NATURAL GAS	BACT-PSD
CAROLINA POWER AND LIGHT CO.	DARLINGTON	SC	09/23/1991	TURBINE, I.C.	80	0.00078	FUEL SPEC: LOW SULFUR FUEL	BACT-PSD
CHAMPION INTERNATIONAL CORP.	SHELDON	TX	03/05/1985	TURBINE, GAS, 2	168	0.00085		BACT-PSD
WEST CAMPUS COGENERATION COMPANY	COLLEGE STATION	TX	05/02/1994	GAS TURBINES	75	0.0011	INTERNAL COMBUSTION CONTROLS	BACT
SC ELECTRIC AND GAS COMPANY - HAGOOD	CHARLESTON	SC	12/11/1989	INTERNAL COMBUSTION TURBINE	110	0.0011	GOOD COMBUSTION PRACTICES	BACT-PSD
BERKSHIRE POWER DEVELOPMENT, INC.	AGAWAM	MA	09/22/1997	TURBINE, COMBUSTION, ABB GT24	224	0.0022	DRY LOW NOX COMBUSTION TECHNOLOGY W	BACT-PSD
DIGHTON POWER ASSOCIATE, LP	DIGHTON	MA	10/06/1997	TURBINE, COMBUSTION, ABB GT11N2	166	0.0023	DRY LOW NOX COMBUSTION TECHNOLOGY W	BACT-PSD
MILLENNIUM POWER PARTNER, LP	CHARLTON	MA	02/02/1998	TURBINE, COMBUSTION, WESTINGHOUSE MODEL 50	317	0.0023	DRY LOW NOX COMBUSTION TECHNOLOGY IN	BACT-PSD
BEAR ISLAND PAPER COMPANY, L.P.	ASHLAND	VA	10/30/1992	TURBINE, COMBUSTION GAS	59	0.0032	FUEL SPEC: LOW SULFUR FUEL	BACT-PSD
CASCO RAY ENERGY CO	VEAZIE	ME	07/13/1998	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170	0.0060		BACT-PSD
TIVERTON POWER ASSOCIATES	TIVERTON	RI	02/13/1998	COMBUSTION TURBINE, NATURAL GAS	265	0.0060	FUEL SPEC: NATURAL GAS FIRED	BACT-PSD
WESTBROOK POWER LLC	WESTBROOK	ME	12/04/1998	TURBINE, COMBINED CYCLE, TWO	528	0.0060		BACT-PSD
CHAMPION INTERNATL CORP. & CHAMP. CLEA	BUCKSPORT	ME	09/14/1998	TURBINE, COMBINED CYCLE, NATURAL GAS	175	0.0086		BACT-OTHER
MIDLAND COGENERATION VENTURE	MIDLAND	MI	02/16/1988	TURBINE, 12 TOTAL	123	0.016	FUEL SPEC: NAT GAS FUEL	BACT-PSD
FLORIDA POWER AND LIGHT	NORTH PALM BEACH	FL	06/05/1991	TURBINE, GAS, 4 EACH	400	0.029	FUEL SPEC: NATURAL GAS AS FUEL	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	FL	12/14/1992	TURBINE, GAS	152	0.033	FUEL SPEC: LOW SULFUR IN NATURAL GAS	BACT-PSD
COMMONWEALTH ATLANTIC LTD PARTNERSH	CHESAPEAKE	VA	03/05/1991	TURBINE, NAT GAS & #2 OIL	192	0.057	FUEL SPEC: LOW SULFUR FUEL & NAT GAS	BACT-PSD
DOSWELL LIMITED PARTNERSHIP		VA	05/04/1990	TURBINE, COMBUSTION	158	0.059	FUEL SPEC: LOW SULFUR FUELS, NAT GAS	OTHER
DELMARVA POWER	WILMINGTON	DE	09/27/1990	TURBINE, COMBUSTION	100	0.070	FUEL SPEC: SULFUR IN FUEL	BACT-PSD

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some lb/mmBtu values were calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - PM/PM10**

FACILITY	CITY	STATE	PERMIT	PROCESS	MW	lb/mmBtu	CTRLDESC	BASIS
MIDLAND COGENERATION VENTURE	MIDLAND	MI	02/16/1988	TURBINE, 12 TOTAL	123	0.00051	FUEL SPEC: NAT GAS FUEL	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	JOPLIN	MO	05/17/1994	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	1345	0.00052	NONE	BACT-PSD
BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.	NEW YORK CITY	NY	06/06/1995	TURBINE, NATURAL GAS FIRED	240	0.0013		LAER
LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	NJ	04/01/1991	TURBINES (NATURAL GAS) (2)	149	0.0023	TURBINE DESIGN	BACT-OTHER
PUBLIC SERVICE OF COLO.-FORT ST VRAIN	PLATTEVILLE	CO	05/01/1996	COMBINED CYCLE TURBINES (2), NATURAL	471	0.0024	FUEL SPEC: COMBUSTION OF PIPE LINE QUALITY GAS. CLOSE	BACT-PSD
CHAMPION INTERNATIONAL CORP.	SHELDON	TX	03/05/1985	TURBINE, GAS, 2	168	0.0030	LOW NOX BURNERS	BACT-PSD
ECOELECTRICA, L.P.	PENUELAS	PR	10/01/1996	TURBINES, COMBINED-CYCLE COGENERATION	461	0.0033	MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND IMP	BACT-PSD
LILCO SHOREHAM	HICKSVILLE	NY	05/10/1993	(3) GE FRAME 7 TURBINES (EP #S 00007-9)	106	0.0035	NO CONTROLS	BACT-OTHER
DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	NC	12/20/1991	TURBINE, COMBUSTION	164	0.0038	COMBUSTION CONTROL	BACT-PSD
PILGRIM ENERGY CENTER	ISLIP	NY		(2) WESTINGHOUSE W50105 TURBINES (EP #S 00001	175	0.0039		BACT-OTHER
COMMONWEALTH ATLANTIC LTD PARTNERSHIP	CHESAPEAKE	VA	03/05/1991	TURBINE, NAT GAS & #2 OIL	192	0.0039	FUEL SPEC: LOW ASH FUEL	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	JOPLIN	MO	02/28/1995	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	89	0.0039	GOOD COMBUSTION CONTROL	BACT-PSD
MEAD COATED BOARD, INC.	PHENIX CITY	AL	03/12/1997	COMBINED CYCLE TURBINE (25 MW)	71	0.0044	PRIMARY FUEL IS NATURAL GAS WITH BACKUP FUEL AS DISTIL	BACT-PSD
NEVADA COGENERATION ASSOCIATES #1	LAS VEGAS	NV	01/17/1991	COMBINED-CYCLE POWER GENERATION	85	0.0044	FUEL SPEC: BURN NATURAL GAS	BACT-PSD
CAROLINA POWER & LIGHT	GOLDSBORO	NC	04/11/1996	COMBUSTION TURBINE, 4 EACH	238	0.0047	COMBUSTION CONTROL	BACT-PSD
PACIFIC THERMONETICS, INC.	CROCKETT	CA	04/06/1989	BURNER, HRSG, 2	53	0.0048	FUEL SPEC: NAT GAS USE ONLY	OTHER
VIRGINIA POWER		VA	09/07/1989	TURBINE, GAS	164	0.0048		BACT-PSD
INDECK ENERGY COMPANY	SILVER SPRINGS	NY	05/12/1993	GE FRAME 6 GAS TURBINE EP #00001	61	0.0050	NO CONTROLS	BACT-OTHER
KAMINE/BESICORP CARTHAGE L.P.	CARTHAGE	NY	01/18/1994	GE FRAME 6 GAS TURBINE	61	0.0050	FUEL SPEC: SULFUR CONTENT NOT TO EXCEED 0.20% BY WEI	BACT-OTHER
MILLENNIUM POWER PARTNER, LP	CHARLTON	MA	02/02/1998	TURBINE, COMBUSTION, WESTINGHOUSE MODEL 501	317	0.0050	DRY LOW NOX COMBUSTION TECHNOLOGY IN CONJUNCTION	BACT-PSD
NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO.	PROVIDENCE	RI	04/13/1992	TURBINE, GAS AND DUCT BURNER	170	0.0050	NONE	BACT-PSD
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #8 FRAME	62	0.0050	COMBUSTION CONTROL	BACT-PSD
HERMISTON GENERATING CO.	HERMISTON	OR	07/07/1994	TURBINES, NATURAL GAS (2)	212	0.0053	GOOD COMBUSTION PRACTICES	BACT-PSD
LSP-COTTAGE GROVE, L.P.	COTTAGE GROVE	MN	03/01/1995	COMBUSTION TURBINE/GENERATOR	246	0.0054	FUEL SELECTION: GOOD COMBUSTION	BACT-PSD
ANITEC COGEN PLANT	BINGHAMTON	NY	07/07/1993	GE LM5000 COMBINED CYCLE GAS TURBINE EP #0000	56	0.0055	NO CONTROLS	BACT-OTHER
TIGER BAY LP	FT. MEADE	FL	05/17/1993	TURBINE, GAS	202	0.0056	GOOD COMBUSTION PRACTICES	BACT-PSD
FLORIDA POWER AND LIGHT	NORTH PALM BEACH	FL	06/05/1991	TURBINE, GAS, 4 EACH	400	0.0056	COMBUSTION CONTROL	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	FL	02/25/1994	TURBINE, NATURAL GAS (2)	189	0.0060	GOOD COMBUSTION PRACTICES	BACT-PSD
CHARLES LARSEN POWER PLANT	CITY OF OF LAKELAND	FL	07/25/1991	TURBINE, GAS, 1 EACH	80	0.0060	COMBUSTION CONTROL	BACT-PSD
EMPIRE ENERGY - NIAGARA COGENERATION CO.	LOCKPORT	NY	05/02/1989	TURBINE, GR FRAME 6, 3 EA	52	0.0060	COMBUSTION CONTROL	BACT-PSD
KAMINE/BESICORP NATURAL DAM LP	NATURAL DAM	NY	12/31/1991	GE FRAME 6 GAS TURBINE	63	0.0060	STEAM INJECTION	BACT
LONG ISLAND LIGHTING CO.		NY	11/01/1988	TURBINE, GE FRAME 7, 3 EA	75	0.0060	COMBUSTION CONTROL	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NEWARK	NJ	06/09/1993	TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)	77	0.0060	TURBINE DESIGN	BACT-PSD
ONEIDA COGENERATION FACILITY	ONEIDA	NY	02/26/1990	TURBINE, GE FRAME 6	52	0.0060	COMBUSTION CONTROL	OTHER
SOUTH MISSISSIPPI ELECTRIC POWER ASSOC.	MOSELL	MS	04/09/1996	COMBUSTION TURBINE, COMBINED CYCLE	162	0.0062	GOOD COMBUSTION CONTROLS	BACT-PSD
SEMINOLE HARDEE UNIT 3	FORT GREEN	FL	01/01/1996	COMBINED CYCLE COMBUSTION TURBINE	140	0.0063	DRY LNB FUEL SPEC: LOW S OIL, LIMITE	BACT-PSD
HARTWELL ENERGY LIMITED PARTNERSHIP	HARTWELL	GA	07/28/1992	TURBINE, GAS FIRED (2 EACH)	227	0.0064	FUEL SPEC: CLEAN BURNING FUELS	BACT-PSD
CHAMPION INTERNATL CORP. & CHAMP. CLEAN ENERGY	BUCKSPORT	ME	09/14/1998	TURBINE, COMBINED CYCLE, NATURAL GAS	175	0.0064	NONE	BACT-OTHER
LORDSBURG L.P.	LORDSBURG	NM	06/18/1997	TURBINE, NATURAL GAS-FIRED, ELEC. GEN.	100	0.0066	WATER INJECTION	BACT-PSD
JMC SELKIRK, INC.	SELKIRK	NY	11/21/1989	TURBINE, GE FRAME 7, GAS FIRED	80	0.0070	COMBUSTION CONTROL	BACT-PSD
KAMINE/BESICORP BEAVER FALLS COGENERATION FACILITY	BEAVER FALLS	NY	11/09/1992	TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW)	81	0.0077	COMBUSTION CONTROLS	BACT-OTHER
SARANAC ENERGY COMPANY	PLATTSBURGH	NY	07/31/1992	TURBINES, COMBUSTION (2) (NATURAL GAS)	140	0.0080	SCR	BACT-OTHER
FLORIDA POWER AND LIGHT	LAVOGROME	FL	03/14/1991	TURBINE, GAS, 4 EACH	240	0.0080	COMBUSTION CONTROL	BACT-PSD
KISSIMEE UTILITY AUTHORITY	INTERCESSION CITY	FL	04/07/1983	TURBINE, NATURAL GAS	109	0.0081	GOOD COMBUSTION PRACTICES	BACT-PSD
SITH/INDEPENDENCE POWER PARTNERS	OSWEGO	NY	11/24/1992	TURBINES, COMBUSTION (4) (NATURAL GAS) (1012 M	267	0.0082	FUEL SPEC: USE OF NATURAL GAS	BACT-OTHER
LSP - COTTAGE GROVE, L.P.	COTTAGE GROVE	MN	11/10/1998	GENERATOR, COMBUSTION TURBINE & DUCT BURNE	249	0.0089	COMBUSTING NATURAL GAS	BACT-PSD
MOBILE ENERGY LLC	MOBILE	AL	01/05/1999	TURBINE, GAS, COMBINED CYCLE	168	0.0089	COMBUSTION OF CLEAN FUELS	BACT-PSD
TIVERTON POWER ASSOCIATES	TIVERTON	RI	02/13/1988	COMBUSTION TURBINE, NATURAL GAS	265	0.0089	GOOD COMBUSTION	BACT-PSD
O'BRIEN COGENERATION	HARTFORD	CT	08/08/1988	TURBINE, GAS FIRED	62	0.0090	GOOD COMBUSTION PRACTICES	BACT-PSD
DIGHTON POWER ASSOCIATE, LP	DIGHTON	MA	10/06/1997	TURBINE, COMBUSTION, ABB GT11N2	166	0.0094	DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD-ON	BACT-PSD
BERKSHIRE POWER DEVELOPMENT, INC.	AGAWAM	MA	09/22/1997	TURBINE, COMBUSTION, ABB GT24	224	0.0097	DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR ADD-ON	BACT-PSD
PORTSIDE ENERGY CORP.	PORTAGE	IN	05/13/1996	TURBINE, NATURAL GAS-FIRED	63	0.0099	NONE	BACT-PSD
TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	GA	12/18/1998	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160	0.010	PM EMISSION IS BECAUSE OF NATURAL GAS.	BACT-PSD
TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	GA	12/18/1998	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160	0.010	PM EMISSION IS BECAUSE OF NATURAL GAS.	BACT-PSD
KAMINE SOUTH GLENS FALLS COGEN CO	SOUTH GLENS FALLS	NY	09/10/1992	GE FRAME 6 GAS TURBINE	62	0.010	NO CONTROLS	BACT-OTHER
GRAYS FERRY CO. GENERATION PARTNERSHIP	PHILADELPHIA	PA	11/04/1992	TURBINE (NATURAL GAS & OIL)	144	0.010	DRY LOW NOX BURNER, COMBUSTION CONTROL	BACT-OTHER

RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Natural Gas) - PM/PM10

FACILITY	CITY	STATE	PERMIT	PROCESS	MW	lb/mmBtu	CTRLDESC	BASIS
VIRGINIA POWER	CHESTERFIELD	VA	04/15/1988	TURBINE, GE 2 EA	234	0.011	EQUIPMENT DESIGN	LAER
ALABAMA POWER PLANT BARRY	BUCKS	AL	08/07/1998	TURBINES, COMBUSTION, NATURAL GAS	510	0.011	NATURAL GAS ONLY, EFFICIENT COMBUSTION	BACT-PSD
INDECK-YERKES ENERGY SERVICES	TONAWANDA	NY	06/24/1992	GE FRAME 6 GAS TURBINE (EP #00001)	54	0.012	NO CONTROLS	BACT-OTHER
NEVADA POWER COMPANY, HARRY ALLEN PEAKING PLANT	LAS VEGAS	NV	09/18/1992	COMBUSTION TURBINE ELECTRIC POWER GENERATOR	75	0.012	PRECISION CONTROL FOR THE COMBUSTOR	BACT-PSD
GAINESVILLE REGIONAL UTILITIES	GAINESVILLE	FL	04/11/1995	SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL	74	0.012	FUEL SPEC: LOW SULFUR FUELS	BACT-PSD
ALABAMA POWER COMPANY - THEODORE COGENERATION	THEODORE	AL	03/18/1999	170 MW TURBINE W/ DUCT BURNER, HR BOILER, SCR	170	0.012	COMBUSTION OF NATURAL GAS ONLY	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	FL	12/14/1992	TURBINE, GAS	152	0.014	GOOD COMBUSTION PRACTICES	BACT-PSD
KAMINE/BESICORP SYRACUSE LP	SOLVAY	NY	12/10/1994	SIEMENS V64.3 GAS TURBINE (EP #00001)	81	0.014	NO CONTROLS	BACT-OTHER
UNION CARBIDE CORPORATION	HAHNVILLE	LA	09/22/1995	GENERATOR, GAS TURBINE	164	0.014	NO CONTROL	CLEAN FUEL
THE DEXTER CORP.	WINDSOR LOCKS	CT	09/29/1989	TURBINE, NAT GAS & #2 FUEL OIL FIRED	69	0.014		BACT-PSD
PROJECT ORANGE ASSOCIATES	SYRACUSE	NY	12/01/1993	GE LM-5000 GAS TURBINE	69	0.014	NO CONTROLS	BACT-OTHER
PASNY/HOLTSVILLE COMBINED CYCLE PLANT	HOLTSVILLE	NY	09/01/1992	TURBINE, COMBUSTION GAS (150 MW)	143	0.016	COMBUSTION CONTROL	BACT-OTHER
MOJAVE COGENERATION CO.		CA	01/12/1989	TURBINE, GAS	81	0.017	FUEL SPEC: OIL FIRING LIMITED TO 11 H/D	BACT-PSD
TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	GA	12/18/1998	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160	0.017	PM IS BECAUSE OF FUEL OIL. WHEN GROSS OUTPUT IS BELOW	BACT-PSD
GEORGIA GULF CORPORATION	PLAQUEMINE	LA	03/26/1996	GENERATOR, NATURAL GAS FIRED TURBINE	140	0.019	GOOD COMBUSTION PRACTICE AND PROPER OPERATION	BACT-PSD
AIR LIQUIDE AMERICA CORPORATION	GEISMAR	LA	02/13/1998	TURBINE GAS, GE, 7ME 7	121	0.019	GOOD COMBUSTION PRACTICES AND USE CLEAN NATURAL GAS	BACT-PSD
MID-GEORGIA COGEN.	KATHLEEN	GA	04/03/1996	COMBUSTION TURBINE (2), NATURAL GAS	118	0.019	CLEAN FUEL	BACT-PSD
WEST CAMPUS COGENERATION COMPANY	COLLEGE STATION	TX	05/02/1994	GAS TURBINES	75	0.020	INTERNAL COMBUSTION CONTROLS	BACT
SYRACUSE UNIVERSITY	SYRACUSE	NY	09/01/1989	TURBINE, GAS FIRED	79	0.020	COMBUSTION CONTROL	OTHER
TRIGEN MITCHEL FIELD	HEMPSTEAD	NY	04/18/1993	GE FRAME 6 GAS TURBINE	53	0.021	NO CONTROLS	BACT-OTHER
LOCKPORT COGEN FACILITY	LOCKPORT	NY	07/14/1993	(6) GE FRAME 6 TURBINES (EP #S 00001-00006)	53	0.021	STEAM INJECTION	BACT
KAMINE/BESICORP CORNING L.P.	SOUTH CORNING	NY	11/05/1992	TURBINE, COMBUSTION (79 MW)	82	0.024	DRY LOW NOX OR SCR	BACT-OTHER
FULTON COGEN PLANT	FULTON	NY	09/15/1994	GE LM5000 GAS TURBINE	63	0.024	FUEL SPEC: SULFUR CONTENT NOT TO EXCEED 0.3% BY WEIGHT	BACT-OTHER
FULTON COGENERATION ASSOCIATES	FULTON	NY	01/29/1990	TURBINE, GE LM5000, GAS FIRED	63	0.024		BACT-PSD
DOSWELL LIMITED PARTNERSHIP		VA	05/04/1990	TURBINE, COMBUSTION	158	0.026	FUEL SPEC: CLEAN BURNING FUEL, NAT GAS & DIST. #2 OIL	OTHER
MEGAN-RACINE ASSOCIATES, INC	CANTON	NY	08/05/1989	GE LM5000-N COMBINED CYCLE GAS TURBINE	401	0.028	NO CONTROLS	BACT-OTHER
MEGAN-RACINE ASSOCIATES, INC.	CANTON	NY	03/06/1989	TURBINE, LM5000	54	0.028		BACT-PSD
BEAR ISLAND PAPER COMPANY, L.P.	ASHLAND	VA	10/30/1992	TURBINE, COMBUSTION GAS	59	0.036	FUEL SPEC: CLEAN BURN FUEL	BACT-PSD
PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	ARECIBO	PR	07/31/1995	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE E	248	0.036	MAINTAIN EACH TURBINE IN GOOD WORKING ORDER AND IMP	BACT-PSD
PEABODY MUNICIPAL LIGHT PLANT	PEABODY	MA	11/30/1989	TURBINE, 38 MW OIL FIRED	52	0.050	FUEL SPECIFICATION: NO. 2 LIGHT OIL	BACT-OTHER
SC ELECTRIC AND GAS COMPANY - HAGOOD STATION	CHARLESTON	SC	12/11/1989	INTERNAL COMBUSTION TURBINE	110	0.051	FUEL SPEC: LOW ASH CONTENT FUELS	BACT-PSD
KAMINE SYRACUSE COGENERATION CO.	SOLVAY	NY	09/01/1989	TURBINE, GAS FIRED	79	0.053	COMBUSTION CONTROL	OTHER
CASCO RAY ENERGY CO	VEAZIE	ME	07/13/1998	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170	0.060	NONE	BACT-PSD
WESTBROOK POWER LLC	WESTBROOK	ME	12/04/1998	TURBINE, COMBINED CYCLE, TWO	528	0.060	NONE	BACT-PSD
WI ELECTRIC POWER CO.	CONCORD STATION	WI	10/18/1990	TURBINES, COMBUSTION, SIMPLE CYCLE, 4	75	0.065	GOOD COMBUSTION	BACT-PSD
SOUTHEAST PAPER CORP.	DUBLIN	GA	10/13/1987	TURBINE, COMBUSTION	68	0.10		OTHER

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some lb/mmBtu values were calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Fuel Oil) - NOx

FACILITY	CITY	STATE	PERMIT	PROCESS	MW	PPM	CTRLDESC	BASIS
BROOKLYN NAVY YARD COGENERATION PARTNERS L.P.	NEW YORK CITY	NY	06/06/1995	TURBINE, OIL FIRED	240	10.0	FUEL SPEC: DISTILLATE #2 FUEL OIL	BACT-PSD
GAINESVILLE REGIONAL UTILITIES	GAINESVILLE	FL	04/11/1995	SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL B-UP	74	15.0	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	CHESTERFIELD	VA	03/03/1992	TURBINE, COMBUSTION	140	15.0		
BEAR ISLAND PAPER COMPANY, L.P.	ASHLAND	VA	10/30/1992	TURBINE, COMBUSTION GAS	59	15.0		91 80.8
KALAMAZOO POWER LIMITED	COMSTOCK	MI	12/03/1991	TURBINE, GAS-FIRED, 2, W/ WASTE HEAT BOILERS	226	15.0	DRY LOW NOX TURBINES	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NEWARK	NJ	06/09/1993	TURBINES, COMBUSTION, KEROSENE-FIRED (2)	80	16.0	COMBUSTION CONTROL	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP	NEWARK	NJ	11/01/1990	TURBINE, KEROSENE FIRED	73	16.2	STEAM INJECTION AND SCR	BACT-PSD
MID-GEORGIA COGEN	KATHLEEN	GA	04/03/1996	COMBUSTION TURBINE (2), FUEL OIL	116	20.0	WATER INJECTION WITH SCR	BACT-PSD
SARANAC ENERGY COMPANY	PLATTSBURGH	NY	07/31/1992	BURNERS, DUCT (2)	69	20.6	COMBUSTION CONTROL	BACT-PSD
LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	NJ	04/01/1991	TURBINES (#2 FUEL OIL) (2)	149	21.1	FUEL SPEC: NO. 2 FUEL OIL AS FUEL	BACT-PSD
MEAD COATED BOARD, INC.	PHENIX CITY	AL	03/12/1997	COMBINED CYCLE TURBINE (25 MW)	71	25.0	FUEL OIL SULFUR CONTENT <=0.05% BY WEIGHT	BACT-PSD
SAVANNAH ELECTRIC AND POWER CO		GA	02/12/1992	TURBINES, 8	129	25.0	MAX WATER INJECTION	BACT-PSD
HARTWELL ENERGY LIMITED PARTNERSHIP	HARTWELL	GA	07/28/1992	TURBINE, OIL FIRED (2 EACH)	230	25.0	MAXIMUM WATER INJECTION	BACT-PSD
PEPCO - CHALK POINT PLANT	EAGLE HARBOR	MD	06/25/1990	TURBINE, 105 MW OIL FIRED ELECTRIC	105	25.0	DRY PREMIX BURNER	BACT-PSD
OKLAHOMA MUNICIPAL POWER AUTHORITY	PONCA CITY	OK	12/17/1992	TURBINE, COMBUSTION	58	25.0	COMBUSTION CONTROLS	BACT-OTHER
PATOWMACK POWER PARTNERS, LIMITED PARTNERSHIP	LEESBURG	VA	09/15/1993	TURBINE, COMBUSTION, SIEMENS MODEL V84 2, 3	146	28.9	WET INJECTION	BACT-PSD
FULTON COGEN PLANT	FULTON	NY	09/15/1994	GE LM5000 GAS TURBINE	63	36.0	WATER INJECTION	BACT
PEABODY MUNICIPAL LIGHT PLANT	PEABODY	MA	11/30/1989	TURBINE, 38 MW OIL FIRED	52	40.0	WATER INJECTION	BACT-OTHER
STAR ENTERPRISE	DELAWARE CITY	DE	03/30/1996	TURBINES, COMBINED CYCLE, 2	103	42.0	COMBUSTION CONTROL	BACT-PSD
CHARLES LARSEN POWER PLANT	CITY OF OF LAKELAND	FL	07/25/1991	TURBINE, OIL, 1 EACH	80	42.0	WET INJECTION	BACT-PSD
FLORIDA POWER GENERATION	DEBARY	FL	10/18/1991	TURBINE, OIL, 6 EACH	93	42.0	WET INJECTION	BACT-PSD
TIGER BAY LP	FT. MEADE	FL	05/17/1993	TURBINE, OIL	231	42.0	WATER INJECTION	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	INTERCESSION CITY	FL	04/07/1993	TURBINE, FUEL OIL	116	42.0	WATER INJECTION	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	FL	12/14/1992	TURBINE, OIL	146	42.0	STEAM INJECTION	BACT-PSD
TECO POLK POWER STATION	BARTOW	FL	02/24/1994	TURBINE, FUEL OIL	221	42.0	WET INJECTION	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	FL	02/25/1994	TURBINE, FUEL OIL (2)	216	42.0	WATER INJECTION	BACT-PSD
FLORIDA POWER CORPORATION	INTERCESSION CITY	FL	08/17/1992	TURBINE, OIL	129	42.0	WET INJECTION	BACT-PSD
GAINESVILLE REGIONAL UTILITIES	GAINESVILLE	FL	04/11/1995	OIL FIRED COMBUSTION TURBINE	74	42.0	WATER INJECTION	BACT-PSD
KENTUCKY UTILITIES COMPANY	MERCER	KY	03/10/1992	TURBINE, #2 FUEL OIL/NATURAL GAS (8)	188	42.0	WATER INJECTION	BACT-PSD
EAST KENTUCKY POWER COOPERATIVE		KY	03/24/1993	TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED	187	42.0	WATER INJECTION	SEE NOTES
PASNY/HOLTSVILLE COMBINED CYCLE PLANT	HOLTSVILLE	NY	09/01/1992	TURBINE, COMBUSTION GAS (150 MW)	143	42.0	WATER INJECTOR	BACT-OTHER
KAMINE/BESICORP CARTHAGE L.P.	CARTHAGE	NY	01/18/1994	GE FRAME 6 GAS TURBINE	61	42.0	STEAM INJECTION	BACT
EMPIRE DISTRICT ELECTRIC CO	JOPLIN	MO	05/17/1994	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	168	49.5	LOW NOX BURNERS, AND WATER INJECTION	BACT-PSD
KAMINE/BESICORP BEAVER FALLS COGENERATION FACILITY	BEAVER FALLS	NY	11/09/1992	TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW)	81	55.0	DRY LOW NOX OR SCR	BACT-OTHER
PEPCO - CHALK POINT PLANT	EAGLE HARBOR	MD	06/25/1990	TURBINE, 84 MW OIL FIRED ELECTRIC	84	58.0	QUIET COMBUSTION AND WATER INJECTION	BACT-PSD
CAROLINA POWER AND LIGHT	HARTSVILLE	SC	08/31/1994	STATIONARY GAS TURBINE	190	62.0	FUEL SPEC: FUEL QUALITY	BACT-PSD
FLORIDA POWER AND LIGHT	NORTH PALM BEACH	FL	06/05/1991	TURBINE, OIL, 2 EACH	400	65.0	LOW NOX COMBUSTORS	BACT-PSD
BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT	PERRYMAN	MD		TURBINE, 140 MW OIL FIRED ELECTRIC	140	65.0	WATER INJECTION	BACT-PSD
OKLAHOMA MUNICIPAL POWER AUTHORITY	PONCA CITY	OK	12/17/1992	TURBINE, COMBUSTION	58	65.0	COMBUSTION CONTROLS	BACT-OTHER
HOPEWELL COGENERATION LIMITED PARTNERSHIP		VA	07/01/1988	TURBINE, OIL FIRED, 3 EA	129	65.0		BACT-PSD
DOSWELL LIMITED PARTNERSHIP		VA	05/04/1990	TURBINE, COMBUSTION	158	65.0	STEAM INJECTION & FUEL SPEC. USE OF #2 OIL	OTHER
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #7 FRAME	133	67.2		
KALAELOE PARTNERS, L.P.		HI	03/09/1990	TURBINE, LSFO, 2	225	69.0	STEAM INJECTION AT 1.3 TO 1 STEAM TO FUEL RATIO	BACT-PSD
CAROLINA POWER & LIGHT	GOLDSBORO	NC	04/11/1996	COMBUSTION TURBINE, 4 EACH	236	69.0	WATER INJECTION; FUEL SPEC: 0.04% N FUEL OIL	BACT-PSD
PEPCO - STATION A	DICKERSON	MD	05/31/1990	TURBINE, 124 MW OIL FIRED	125	77.0	WATER INJECTION	BACT-PSD
SOUTHERN MARYLAND ELECTRIC COOPERATIVE (SMECO)	EAGLE HARBOR	MD	10/01/1989	TURBINE, OIL FIRED ELECTRIC	90	142.8	WATER INJECTION	BACT-PSD
UNION ELECTRIC CO	WEST ALTON	MO	05/08/1979	CONSTRUCTION OF A NEW OIL FIRED COMBUSTION TURBINE	78	494.5	WATER INJECTION FOR NOX EMISSIONS	BACT-PSD

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some PPM values were calculated using a conversion factor based on the F-Factor and molecular weight of NO₂: 1 (PPM) = (lb/mmBtu) * 257

lb/mmBtu values were also calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Fuel Oil) - CO**

FACILITY	CITY	STATE	PERMIT	PROCESS	MW	PPM	CTRLDESC	BASIS
GORHAM ENERGY LIMITED PARTNERSHIP	GORHAM	ME	12/04/1998	TURBINE, COMBINED CYCLE	900	5.0	0.05% SULFUR DISTILLATE OIL #2 IS USED.	EMISSION IS FROM BACT-PSD
BROOKLYN NAVY YARD COGENERATION PARTNERSHIP	NEW YORK CITY	NY	06/06/1995	TURBINE, OIL FIRED	240	5.0	COMBUSTION DESIGN	BACT-PSD
UNION ELECTRIC CO	WEST ALTON	MO	05/06/1979	CONSTRUCTION OF A NEW OIL FIRED COMBUSTION	622	9.0		BACT-PSD
SAVANNAH ELECTRIC AND POWER CO.		GA	02/12/1992	TURBINES, 8	129	9.0	WATER INJECTION	BACT-PSD
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #7 FRAME	133	9.2		
SELKIRK COGENERATION PARTNERS, L.P.	SELKIRK	NY	06/18/1992	COMBUSTION TURBINES (2) (252 MW)	147	10.0	COMBUSTION CONTROLS	BACT-OTHER
INDECK-OSWEGO ENERGY CENTER	OSWEGO	NY	10/06/1994	GE FRAME 6 GAS TURBINE	533	10.0	NO CONTROLS	BACT-OTHER
HOPEWELL COGENERATION LIMITED PARTNERSHIP		VA	07/01/1988	TURBINE, OIL FIRED, 3 EA	129	10.5		BACT-PSD
MEGAN-RACINE ASSOCIATES, INC.	CANTON	NY	03/06/1989	TURBINE, LM5000	54	11.0		
FLORIDA POWER CORPORATION	INTERCESSION CITY	FL	08/17/1992	TURBINE, OIL	233	17.9	GOOD COMBUSTION PRACTICES	BACT-PSD
CAROLINA POWER & LIGHT	GOLDSBORO	NC	04/11/1996	COMBUSTION TURBINE, 4 EACH	238	18.0	COMBUSTION DESIGN	BACT-PSD
KENTUCKY UTILITIES COMPANY	MERCER	KY	03/10/1992	TURBINE, #2 FUEL OIL/NATURAL GAS (8)	188	21.2	COMBUSTION CONTROL	BACT-PSD
EAST KENTUCKY POWER COOPERATIVE		KY	03/24/1993	TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED	187	21.3	PROPER COMBUSTION TECHNIQUES	BACT-OTHER
FLORIDA POWER CORPORATION	INTERCESSION CITY	FL	08/17/1992	TURBINE, OIL	129	22.2	GOOD COMBUSTION PRACTICES	BACT-PSD
TIGER BAY LP	FT. MEADE	FL	05/17/1993	TURBINE, OIL	231	22.5	WATER INJECTION	BACT-PSD
CHARLES LARSEN POWER PLANT	CITY OF OF LAKE LAND	FL	07/25/1991	TURBINE, OIL, 1 EACH	80	25.0	COMBUSTION CONTROL	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	FL	12/14/1992	TURBINE, OIL	146	25.0	GOOD COMBUSTION PRACTICES	BACT-PSD
HARTWELL ENERGY LIMITED PARTNERSHIP	HARTWELL	GA	07/28/1992	TURBINE, OIL FIRED (2 EACH)	230	25.0	FUEL SPEC: CLEAN BURNING FUELS	BACT-PSD
SELKIRK COGENERATION PARTNERS, L.P.	SELKIRK	NY	06/18/1992	COMBUSTION TURBINE (79 MW)	147	25.0	COMBUSTION CONTROL	BACT-OTHER
LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	NJ	04/01/1991	TURBINES (#2 FUEL OIL) (2)	149	25.4	COMBUSTOR WATER INJECTOR, WATER INJECTION	BACT-PSD
SARANAC ENERGY COMPANY	PLATTSBURGH	NY	07/31/1992	BURNERS, DUCT (2)	69	25.4	COMBUSTION DESIGN	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP	NEWARK	NJ	11/01/1990	TURBINE, KEROSENE FIRED	73	26.6	CATALYTIC OXIDATION	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	INTERCESSION CITY	FL	04/07/1993	TURBINE, FUEL OIL	116	29.6	GOOD COMBUSTION PRACTICES	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY	BARTOW	FL	02/25/1994	TURBINE, FUEL OIL (2)	216	30.0	GOOD COMBUSTION PRACTICES	BACT-PSD
MID-GEORGIA COGEN.	KATHLEEN	GA	04/03/1996	COMBUSTION TURBINE (2), FUEL OIL	116	30.0	WATER INJECTION	BACT-OTHER
FLORIDA POWER GENERATION	DEBARY	FL	10/18/1991	TURBINE, OIL, 6 EACH	93	30.7	GOOD COMBUSTION	BACT-PSD
FLORIDA POWER AND LIGHT	NORTH PALM BEACH	FL	06/05/1991	TURBINE, OIL, 2 EACH	400	33.0	WET INJECTION	BACT-PSD
TECO POLK POWER STATION	BARTOW	FL	02/24/1994	TURBINE, FUEL OIL	221	40.0	GOOD COMBUSTION	BACT-PSD
UNION ELECTRIC CO	WEST ALTON	MO	05/06/1979	CONSTRUCTION OF A NEW OIL FIRED COMBUSTION	78	71.9	GOOD COMBUSTION PRACTICES	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	JOPLIN	MO	05/17/1994	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	168	92.6	COMBUSTION DESIGN	BACT-PSD
ECOELECTRICA, L.P.	PENUELAS	PR	10/01/1996	TURBINES, COMBINED-CYCLE COGENERATION	461	100.0	COMBUSTION DESIGN	BACT-PSD
FULTON COGEN PLANT	FULTON	NY	09/15/1994	GE LM5000 GAS TURBINE	83	107.0	NO CONTROLS	BACT-OTHER
CAROLINA POWER AND LIGHT	HARTSVILLE	SC	08/31/1994	STATIONARY GAS TURBINE	190	115.2	COMBUSTION DESIGN	BACT-PSD

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some PPM values were calculated using a conversion factor based on the F-Factor and molecular weight of CO: 1 (PPM) = (lb/mmBtu) * 423

lb/mmBtu values were also calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Fuel Oil) - SO₂

FACILITY	CITY	STATE	PERMIT	PROCESS	MW ¹	lb/mmBtu ²	CTRLDESC	BASIS
GORHAM ENERGY LIMITED PARTNERSHIP	GORHAM	ME	12/04/1998	TURBINE, COMBINED CYCLE	900	0.00068	0.05% SULFUR DISTILLATE OIL #2 USED.	BACT-PSD
MOJAVE COGENERATION CO.		CA	01/12/1989	TURBINE, GAS	61	0.0012	FUEL SPEC: OIL FIRING LIMITED TO 11 H/D	BACT-PSD
TECO POLK POWER STATION	BARTOW	FL	02/24/1994	TURBINE, FUEL OIL	221	0.048	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
VIRGINIA POWER		VA	09/07/1989	TURBINE, GAS	164	0.051	FUEL SPEC: 0.06% BY WT ANN AVG S FUEL, G	BACT-PSD
WI ELECTRIC POWER CO.	CONCORD STATION	WI	10/18/1990	TURBINES, COMBUSTION, SIMPLE CYCLE, 4	75	0.052	FUEL SPEC: 0.05% S OIL ALLOWED ONLY IF NA	BACT-PSD
FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	FL	02/25/1994	TURBINE, FUEL OIL (2)	216	0.054	FUEL SPEC: LOW SULFUR FUEL OIL (MAX 0.05	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	INTERCESSION CITY	FL	04/07/1993	TURBINE, FUEL OIL	116	0.056	FUEL SPEC: LOW SULFUR FUEL	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	FL	12/14/1992	TURBINE, OIL	146	0.060	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
BALTIMORE GAS & ELECTRIC - PERRYMAN PLANT	PERRYMMAN	MD		TURBINE, 140 MW OIL FIRED ELECTRIC	140	0.078	FUEL SPEC: LOW SULFUR OIL (0.05%)	BACT-PSD
GAINESVILLE REGIONAL UTILITIES	GAINESVILLE	FL	04/11/1995	OIL FIRED COMBUSTION TURBINE	74	0.090	FUEL SPEC: LOW S OIL 0.05% S	BACT-PSO
THE DEXTER CORP.	WINDSOR LOCKS	CT	09/29/1989	TURBINE, NAT GAS & #2 FUEL OIL FIRED	69	0.12	FUEL SPEC: LOW SULFUR FUEL - 0.28%	BACT-PSD
CAROLINA POWER & LIGHT	GOLDSBORO	NC	04/11/1996	COMBUSTION TURBINE, 4 EACH	238	0.16	FUEL SPEC: 0.15% S FUEL OIL	BACT-PSD
O'BRIEN COGENERATION	HARTFORD	CT	08/08/1988	TURBINE, GAS FIRED	62	0.19	FUEL SPEC: LOW S OIL, ANNUAL FUEL LIMIT	BACT-PSD
DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	NC	12/20/1991	TURBINE, COMBUSTION	156	0.19	FUEL SPEC: 0.2% SULFUR FUEL OIL	BACT-PSD
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #7 FRAME	133	0.21	FUEL SPEC: LOW S FUEL	BACT-PSD
HOPEWELL COGENERATION LIMITED PARTNERSHIP		VA	07/01/1988	TURBINE, OIL FIRED, 3 EA	129	0.21	FUEL SPEC: SULFUR CONTENT OF FUEL	BACT-PSO
BEAR ISLAND PAPER COMPANY, L.P.	ASHLAND	VA	10/30/1992	TURBINE, COMBUSTION GAS	59	0.21	FUEL SPEC: LOW SULFUR FUEL	BACT-PSO
FLORIDA POWER CORPORATION	INTERCESSION CITY	FL	08/17/1992	TURBINE, OIL	129	0.22	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
FLORIDA POWER CORPORATION	INTERCESSION CITY	FL	08/17/1992	TURBINE, OIL	233	0.22	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
DOSWELL LIMITED PARTNERSHIP		VA	05/04/1990	TURBINE, COMBUSTION	158	0.22	USING #2 OIL	OTHER
KALAELOE PARTNERS, L.P.		HI	03/09/1990	TURBINE, LSFO, 2	225	0.27		BACT-PSD
FLORIDA POWER AND LIGHT	NORTH PALM BEACH	FL	06/05/1991	TURBINE, OIL, 2 EACH	400	0.29	FUEL SPEC: NO. 2 FUEL OIL	BACT-PSD
KENTUCKY UTILITIES COMPANY	MERCER	KY	03/10/1992	TURBINE, #2 FUEL OIL/NATURAL GAS (8)	188	0.30	FUEL SPEC: LOW SULFUR FUEL (0.3% SULFUR	BACT-PSO
CAPITOL DISTRICT ENERGY CENTER	HARTFORD	CT	10/23/1989	ENGINE, GAS TURBINE	92	0.31	FUEL SPEC: LOW S OIL	BACT-PSO
VIRGINIA POWER	CHESTERFIELD	VA	04/15/1988	TURBINE, GE, 2 EA	234	0.33	FUEL SPEC: 0.3% BY WT SULFUR LIMIT ON FUEL	LAER
EAST KENTUCKY POWER COOPERATIVE		KY	03/24/1993	TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED	187	0.34	FUEL SPEC: LOW SULFUR FUEL (0.3% SULFUR	SEE NOTES
FLORIDA POWER GENERATION	DEBARY	FL	10/18/1991	TURBINE, OIL, 6 EACH	93	0.75	FUEL SPEC: #2 FUEL OIL	BACT-PSD

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some lb/mmBtu values were calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

**RACT/BACT/LAER Clearinghouse Search Results
Combustion Turbines (Fuel Oil) - PM/PM10**

FACILITY	CITY	STATE	PERMIT	PROCESS	MW ¹	lb/mmBtu ²	CTRLDESC	BASIS
SELKIRK COGENERATION PARTNERS, L.P.	SELKIRK	NY	06/18/1992	COMBUSTION TURBINES (2) (252 MW)	147	0.004	0.5 % SULFUR DISTILLATE OIL #2 IS USED.	BACT-PSD
KAMINE/BESICORP CARTHAGE L.P.	CARTHAGE	NY	01/18/1994	GE FRAME 6 GAS TURBINE	61	0.005	FUEL SPEC: SULFUR CONTENT NOT TO EXCEED	BACT-OTHER
SAVANNAH ELECTRIC AND POWER CO.		GA	02/12/1992	TURBINES, 8	129	0.006	FUEL SPEC: FUEL LIMITED AND 0.3 % S	BACT-PSD
PILGRIM ENERGY CENTER	ISLIP	NY		(2) WESTINGHOUSE W501D5 TURBINES (EP #S 00001&2)	175	0.007	FUEL SPEC: SULFUR CONTENT NOT TO EXCEED	BACT-OTHER
INDECK-OSWEGO ENERGY CENTER	OSWEGO	NY	10/06/1994	GE FRAME 6 GAS TURBINE	67	0.008	FUEL SPEC: SULFUR CONTENT NOT TO EXCEED	BACT-OTHER
TECO POLK POWER STATION	BARTOW	FL	02/24/1994	TURBINE, FUEL OIL	221	0.009	GOOD COMBUSTION	BACT-PSD
CAROLINA POWER & LIGHT	GOLDSBORO	NC	04/11/1996	COMBUSTION TURBINE, 4 EACH	238	0.009	WATER INJECTION FOR NOX EMISSIONS	BACT-PSD
TECO POLK POWER STATION	BARTOW	FL	02/24/1994	TURBINE, FUEL OIL	221	0.009	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
FLORIDA POWER CORPORATION	INTERCESSION CITY	FL	08/17/1992	TURBINE, OIL	233	0.009	GOOD COMBUSTION PRACTICES	BACT-PSD
TIGER BAY LP	FT. MEADE	FL	05/17/1993	TURBINE, OIL	231	0.009	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #7 FRAME	133	0.009		
FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	FL	02/25/1994	TURBINE, FUEL OIL (2)	216	0.010	GOOD COMBUSTION PRACTICES	BACT-PSD
GAINESVILLE REGIONAL UTILITIES	GAINESVILLE	FL	04/11/1995	SIMPLE CYCLE COMBUSTION TURBINE, GAS/NO 2 OIL B-UP	74	0.012	FUEL SPEC: LOW SULFUR FUEL	BACT-OTHER
SAVANNAH ELECTRIC AND POWER CO.		GA	02/12/1992	TURBINES, 8	122	0.012	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
OKLAHOMA MUNICIPAL POWER AUTHORITY	PONCA CITY	OK	12/17/1992	TURBINE, COMBUSTION	58	0.013	FUEL SPEC: USE OF DISTILLATE FUEL	BACT-OTHER
CAROLINA POWER AND LIGHT	HARTSVILLE	SC	08/31/1994	STATIONARY GAS TURBINE	190	0.014	0.05% SULFUR DISTILLATE OIL #2 USED.	BACT-PSD
FLORIDA POWER CORPORATION	INTERCESSION CITY	FL	08/17/1992	TURBINE, OIL	129	0.015	GOOD COMBUSTION PRACTICES	BACT-PSD
HARTWELL ENERGY LIMITED PARTNERSHIP	HARTWELL	GA	07/28/1992	TURBINE, OIL FIRED (2 EACH)	230	0.016	FUEL SPEC: CLEAN BURNING FUELS	BACT-PSD
COMMONWEALTH ATLANTIC LTD PARTNERSHIP	CHESAPEAKE	VA	03/05/1991	TURBINE, NAT GAS & #2 OIL	175	0.016	FUEL SPEC: LOW ASH FUEL, GRADE 76 #2 OIL	BACT-PSD
ECOELECTRICA, L.P.	PENUELAS	PR	10/01/1996	TURBINES, COMBINED-CYCLE COGENERATION	461	0.016	FUEL SPEC: 0.2% SULFUR FUEL OIL	BACT-PSD
KISSIMMEE UTILITY AUTHORITY	INTERCESSION CITY	FL	04/07/1993	TURBINE, FUEL OIL	116	0.016	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
FLORIDA POWER AND LIGHT	NORTH PALM BEACH	FL	06/05/1991	TURBINE, OIL, 2 EACH	400	0.019	MAX WATER INJECTION	BACT-PSD
FLORIDA POWER GENERATION	DEBARY	FL	10/18/1991	TURBINE, OIL, 6 EACH	93	0.020	WATER INJECTION	BACT-PSD
NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NEWARK	NJ	06/09/1993	TURBINES, COMBUSTION, KEROSENE-FIRED (2)	80	0.023		BACT-PSD
FULTON COGEN PLANT	FULTON	NY	09/15/1994	GE LM5000 GAS TURBINE	63	0.024	FUEL SPEC: SULFUR CONTENT NOT TO EXCEED	BACT-OTHER
CHARLES LARSEN POWER PLANT	CITY OF OF LAKEAND	FL	07/25/1991	TURBINE, OIL, 1 EACH	80	0.025	COMBUSTION CONTROL	BACT-PSD
LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	NJ	04/01/1991	TURBINES (#2 FUEL OIL) (2)	149	0.026	FUEL SPEC: LOW SULFUR OIL (0.05%)	BACT-PSD
EMPIRE DISTRICT ELECTRIC CO.	JOPLIN	MO	05/17/1994	INSTALL TWO NEW SIMPLE-CYCLE TURBINES	168	0.028	FUEL SPEC: 0.2% SULFUR FUEL OIL	BACT-PSD
KAMINE/BESICORP BEAVER FALLS COGENERATION F	BEAVER FALLS	NY	11/09/1992	TURBINE, COMBUSTION (NAT. GAS & OIL FUEL) (79MW)	81	0.030	COMBUSTION CONTROLS	BACT-OTHER
PANDA-ROSEMARY CORP.	ROANOKE RAPIDS	NC	09/06/1989	TURBINE, COMBUSTION, #6 FRAME	64	0.033		
HOPEWELL COGENERATION LIMITED PARTNERSHIP		VA	07/01/1988	TURBINE, OIL FIRED, 3 EA	129	0.034		BACT-PSD
CAPITOL DISTRICT ENERGY CENTER	HARTFORD	CT	10/23/1989	ENGINE, GAS TURBINE	92	0.035		
EAST KENTUCKY POWER COOPERATIVE		KY	03/24/1993	TURBINES (5), #2 FUEL OIL AND NAT. GAS FIRED	187	0.036	PROPER COMBUSTION TECHNIQUES	BACT-OTHER
KALAELOE PARTNERS, L.P.		HI	03/09/1990	TURBINE, LSFO, 2	225	0.044		BACT-PSD
KENTUCKY UTILITIES COMPANY	MERCER	KY	03/10/1992	TURBINE, #2 FUEL OIL/NATURAL GAS (8)	168	0.045	COMBUSTION CONTROL	BACT-PSD
AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	FL	12/14/1992	TURBINE, OIL	146	0.047	GOOD COMBUSTION PRACTICES	BACT-PSD
PEABODY MUNICIPAL LIGHT PLANT	PEABODY	MA	11/30/1989	TURBINE, 38 MW OIL FIRED	52	0.050	QUIET COMBUSTION AND WATER INJECTION	BACT-PSD
MID-GEORGIA COGEN.	KATHLEEN	GA	04/03/1996	COMBUSTION TURBINE (2), FUEL OIL	116	0.059	PROPER COMBUSTION TECHNIQUE	BACT-OTHER
UNION ELECTRIC CO	WEST ALTON	MO	05/06/1979	CONSTRUCTION OF A NEW OIL FIRED COMBUSTION TURBINE	78	0.064		BACT-PSD
MID-GEORGIA COGEN.	KATHLEEN	GA	04/03/1996	COMBUSTION TURBINE (2), FUEL OIL	116	55.000	CLEAN FUEL	BACT-PSD

1) Some MW were converted from mmBtu/hr, KW, HP and BHP, assuming a heat rate of 8,000 Btu/KW-hr

2) Some lb/mmBtu values were calculated from lb/hr, lb/yr or ton/yr values

All turbines less than 50 MW and above 100 PPM were removed from this list

Appendix E-1B

RBLC Search Results – Cooling Towers – PM/PM₁₀

RACT/BACT/LAER Clearinghouse Search Results
Cooling Towers - PM/PM10

FACILITY	CITY	STATE	PERMIT	PROCESS	EMISSIONS	UNIT	CTRLDESC	% EFF	BASIS
LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	NJ	09/04/1992	COOLING TOWER, MECHANICAL DRAFT	0.9	LB/H	DRIFT ELIMINATOR		BACT-PSD
TEXACO REFINING AND MARKETING, INC.	BAKERSFIELD	CA	01/19/1996	COOLING TOWER	1.3	LB/H	CELLULAR TYPE DRIFT ELIMINATOR	75.0	BACT-OTHER
CROWN/VISTA ENERGY PROJECT (CVEP)	WEST DEPTFORD	NJ	10/01/1993	COOLING TOWER (2)	5.9	LB/H	DRIFT ELIMINATOR	0.0	BACT-PSD
FLORIDA POWER CORPORATION	CRYSTAL RIVER	FL	08/30/1990	COOLING TOWER, 4 EACH	0.004	% OF CIRC WAT	DRIFT ELIMINATOR		BACT-PSD

Appendix E-2

**Environmental Review Of The Canal Station
Redevelopment Project**

Excerpt from::

ENVIRONMENTAL REVIEW OF THE
CANAL STATION REDEVELOPMENT PROJECT

Tech Environmental, Inc.

June 20, 2000

The SCONOx system uses a catalyst bed to oxidize NO to NO₂ and absorb the NO₂ onto the surface of the catalyst during the "oxidation/absorption" cycle. The catalyst is divided into a number of sections, each of which is equipped with isolation dampers so that some sections can be regenerated while the plant is operating. A catalyst "regeneration" cycle is required periodically and involves passing hydrogen gas mixed with steam over the catalyst surface, producing nitrogen gas and water vapor. Since hydrogen and nitrogen are present in a high temperature environment, the formation of ammonia during the regeneration cycle is likely, since these conditions are similar to the Haber process of nitrogen fixation used to chemically create ammonia.⁸ Neither Goal Line nor AAP have presented any test data to prove that SCONOx does not emit ammonia.

⁸ Hiller and Herber, Principles of Chemistry, McGraw-Hill, 1960, p. 246.

Since small amounts of sulfur dioxide (SO_2) will blind (contaminate) the catalyst bed and cause it to stop working, SO_2 must be removed upstream of the SCONOx catalyst, and this is accomplished using the SCOSOx system. SCOSOx uses an oxidation/absorption cycle with a separate catalyst and a regeneration cycle with hydrogen gas just as the SCONOx system does.

The sulfur is not however permanently removed from the exhaust gas, but instead is most often re-emitted downstream of the SCONOx catalyst in the form of hydrogen sulfide (H_2S) and SO_2 according to Goal Line's technical literature.⁹ The regeneration chemistry favors H_2S when operating temperatures are below 500°F , and it favors SO_2 when temperatures are highest. H_2S is an exceptionally poisonous gas and is hazardous at low concentrations. If a SCONOx/SCOSOx system were to be used on Unit 2, the 134 tons per year of potential SO_2 emissions from the combustion turbines could convert to 71 tons per year of H_2S if the regeneration cycle did not consistently operate at temperatures above 500°F . Even at high temperatures, some H_2S emissions may occur. Goal Line and AAP have presented no information on H_2S concentrations in the exhaust gas leaving a SCONOx/SCOSOx system.

A recent BACT analysis for a large (350 MW) combustion turbine project in the State¹⁰ documented that SCONOx may impose an energy penalty twice that of SCR on a large power-generating unit, namely a 4 MW penalty for the SCONOx system (equipment electrical use, regeneration gas steam, and performance loss due to pressure drop). Coupled with the fact that the claimed zero-ammonia benefit of SCONOx remains undemonstrated and the likelihood that SCONOx creates another toxic air pollutant, hydrogen sulfide (H_2S), it has not been proven that SCONOx, on balance, offers environmental and energy benefits over SCR.

SCONOx is installed on only two turbine facilities at present: a single 30 MW gas turbine in Vernon, California owned and operated by a partner in the SCONOx technology and a 5 MW gas turbine at the Genetics Institute (G.I.). Only the Genetics Institute plant is providing independent information on how SCONOx is performing on a commercial turbine application.

⁹ MacDoonald, R. and Debbage, L., "The SCONOx Catalytic Absorption System for Natural Gas Fired Power Plants," presented at Power-Gen International '97 Dallas, TX, December, 1997, page 8.

¹⁰ Cabot LNG Corporation, "Supplemental BACT Analysis on SCONOx for the Island End Cogeneration Plant," DEP Application MBR-97-COM-014, January 25, 2000.

And, given the overly optimistic information Goal Line has disseminated over the past year about the performance and commercial availability of SCONOx, we believe the Genetics Institute test data provide the best source of reliable information on how well SCONOx performs.

At the Northeast Energy and Commerce Association (NECA) meeting that was held on May 16-17, 2000 in Boxboro, the Manager for Environmental Engineering and Compliance at the Genetics Institute, Mr. Robert McGinnis, gave a presentation on how SCONOx is working at his facility. Although it has been nine months since SCONOx was installed and this is the simplest commercial application for SCONOx (a small combustion turbine), there are still unresolved problems with the SCONOx system, and it is not consistently meeting the NO_x emissions limits promised by Goal Line and written into the facility's permit. In addition, we note that no SCONOx system has ever been built or installed for large (100 MW) turbines.

During the NECA conference, G.I. gave conference attendees a tour of the plant. At the time, the turbine was burning natural gas and the SCONOx system was emitting 9 ppm of NO_x, or 360% of the 2.5 ppm permit limit. Mr. McGinnis has since determined that the turbine combustors were not properly tuned and the inlet concentration of NO_x to the SCONOx system was about 50% higher than it was designed for. This incident has, however, revealed that the SCONOx system does not consistently achieve the 90% NO_x removal rates demonstrated in practice by SCR systems. Mr. McGinnis notes that when the inlet concentration to SCONOx is 20 ppm of NO_x, the outlet concentration is about 2 ppm (90% removal). However, higher inlet concentrations cause a substantial degradation in SCONOx performance. When fired with distillate oil, the turbine emits about 50 ppm, and SCONOx, thus far, emits 20 ppm of NO_x, only a 60% removal rate. So far, the SCONOx system has been exceeding the ultimate 15 ppm NO_x limit for oil-firing in the DEP permit.

If the turbine was not running twice as clean as the manufacturer's guarantee (only 50 ppm of NO_x versus the guaranteed emissions of 96 ppm), NO_x emissions from the SCONOx system would be even higher. This same situation carries over to gas-fired operation. Mr. McGinnis

notes that here again the turbine is generally cleaner than expected, emitting only 17 ppm of NO_x versus 25 ppm guaranteed and helping to lower the NO_x emitted by SCONOx.

In the past year, the SCONOx unit at G.I. has had a recurring problem with leaking dampers. Goal Line has redesigned the dampers three times. Goal Line has also been washing the catalyst blocks (there are 45 separate modules in the system for this single 5 MW turbine) every 2 to 2-1/2 months, which is more frequently than G.I. expected. Washing involves catalyst block removal, soaking in a potassium carbonate solution, and reinstallation of each block. Not only does catalyst washing involve substantial costs in terms of labor and wastewater disposal, during this maintenance period the turbine unit has to be shutdown. Availability of the turbine unit has been as low as 75% during some months according to G.I. The loss of electrical generation for unscheduled maintenance (e.g., to wash catalysts in order to stay within permit limits) greatly concerns G.I. and raises questions about the commercial reliability of SCONOx for much larger turbines in electric generating stations. Mr. McGinnis summed up the situation by stating that after nine months of experimentation, it is not clear if SCONOx will really work as promised over the long term.

One of the first steps of a BACT analysis, is to determine if a control technology option is "technically feasible." According to U.S. EPA guidance,¹¹ to be technically feasible a control technology must have been commercially demonstrated, i.e., installed and operated successfully on a source similar to the one under review. As discussed above, SCONOx has not been installed and operated on any large (100+ MW) turbine project similar to the Canal Redevelopment Project, and in the only independent commercial installation to date (a small 5 MW turbine), it has not yet been successful in consistently meeting permit limits. Thus, it is concluded that SCONOx is not technically feasible for the repowering of Unit 2 at Canal Station.

In summary, while SCONOx is a promising new technology being developed for commercial use, it is not the Best Available Control Technology for the repowering of Canal Unit 2 because:

¹¹ U.S. EPA, "New Source Review Workshop Manual," Research Triangle Park, NC, 1990.

- (1) The only independent commercial application of SCONOx on a combustion turbine has not consistently met its ultimate permit emission limits,
- (2) The only independent commercial application of SCONOx on a combustion turbine has not demonstrated a level of reliability, availability and performance equal to that of SCR,
- (3) SCONOx has never been built for, installed and operated on a large (100+ MW) turbine unit,
- (4) SCONOx is not technically feasible for the Project by EPA guidelines,
- (5) It has not been proven that SCONOx, on balance, offers environmental and energy benefits over SCR.

Appendix E-3

- **Engelhard – Budgetary Proposal
for CO Catalyst**
- **SCR Cost Information**
- **SCONO_x Cost Information**

ENGELHARD

101 WOOD AVENUE
ISELIN, NJ 08830
732-205-5000

POWER GENERATION SALES:
ENGELHARD CORPORATION
2205 CHEQUERS COURT
BEL AIR, MD 21015
PHONE 410-569-0297
FAX 410-569-1841
E-Mail fred.booth@engelhard.com

DATE:	August 2, 2000	NO. PAGES	3
-------	----------------	-----------	---

TO:	TRC ENVIRONMENTAL ATTN: Dave Shotts	via e-mail
-----	--	------------

ATTN:	ENGELHARD Nancy Ellison
-------	----------------------------

FROM:	Fred Booth	Ph 410-569-0297 // FAX 410-569-1841
-------	------------	-------------------------------------

RE: GE 7FA Combined Cycle Project
CO Catalyst - Engelhard Budgetary Proposal EPB00893

We provide Engelhard Budgetary Proposal EPB00893 for One (1) Engelhard Camet® CO Catalyst system for the above project. This is per e-mail request on August 1, 2000.

Catalyst selection and pricing are based on:

- Given Data for Siemens V84.2 combustion turbine;
- CO reduction from noted inlet levels to 2 ppmvd @ 15% O₂ (NG) and 4 ppmvd @ 15% O₂ (Oil);
- Three (3) year Performance Guarantee - expected life 5 - 7 years;
- Meet assumed HRSG inside liner dimensions of 67 ft H x 26 ft W;
- Scope: Normal to HRSG supplier - Catalyst modules with internal frame and tongue seals with interface engineering only.
- By others: Duct / catalyst housing (including any transitions), internal insulation, grooved internal liner sheets, and frame supports and bottom pedestals are provided by others, along with catalyst loading door, personnel manway and sample ports.

We request the opportunity to work with you on this project.

Sincerely yours,

ENGELHARD CORPORATION



Frederick A. Booth
Senior Sales Engineer

ENGELHARD

TRC
CO Oxidation Catalyst – GE 7FA Combined Cycle
Engelhard Budgetary Proposal EPB00893
August 2, 2000

ENGELHARD CORPORATION CAMET® CATALYTIC OXIDATION SYSTEM

Engelhard Corporation, ("Engelhard"), offers to supply the CAMET® metal substrate catalytic oxidation system ("CO System") based upon Buyer's technical data and site conditions provided.

DELIVERABLES: Equipment and services consisting of:

1. Catalyst modules;
2. Removable and replaceable sample catalysts;
3. Internal support frame and internal tongue seals;
4. Drawings showing installation details, loadings, and support requirements;
5. Installation and operating manuals;
6. Technical service for inspection of equipment installation performed by others - Five (5) days total and two (2) trips are provided.

<u>BUDGET PRICE:</u>	Per Unit	Delivery: FOB, plant gate, job site
	CO System	\$ 560,000 – Per Turbine
	Replacement CO Catalyst Modules	\$ 480,000 – Per Turbine

SPENT CATALYST

Engelhard agrees to support buyer's efforts in the disposal of spent catalyst and potential metal reclaim from spent catalyst. The catalyst proposed contains platinum group metals, and unless contaminated in operation by others, is not a hazardous material. Buyer may receive credit for recovered platinum metals based upon the quantity of platinum group metals recovered and the world price of platinum group metals then in effect, net of recovery cost and disposal costs.

WARRANTY AND GUARANTEE:

Mechanical Warranty:	Twelve (12) months from date of start up or eighteen (18) months from date of delivery, whichever is earlier.
Performance Guarantee:	Thirty-six (36) months of operation from date of start up provided start up is no later than ninety (90) days from date of delivery. Catalyst warranty is prorated over the guaranteed life.
Expected Life:	Five – Seven Years

DOCUMENT / MATERIAL DELIVERY SCHEDULE

Drawings for Approval	3 – 4 weeks after notice to proceed with complete engineering specifications and Engelhard receipt of all engineering details.
Frame and Seals	16 weeks after release
Catalyst Modules	20 - 24 weeks after release

CO SYSTEM DESIGN BASIS:

Gas Flow from:	GE 7FA Combustion Turbine
Gas Flow:	Assumed Horizontal
Fuel:	Natural Gas and Oil
Gas Flow Rate (At catalyst face):	Gas Velocities must be within $\pm 25\%$ of the mean velocity at the catalyst face
Temperature (At catalyst face):	All Gas Temperatures must be within $\pm 20^{\circ}\text{F}$ of given average temperatures at all points at the catalyst face
CO Concentration (At catalyst face):	See Performance Data
CO Outlet:	To 2 ppmvd @ 15% O ₂ (NG) / 4 ppmvd @ 15% O ₂ (NG)

ENGELHARD

TRC
CO Oxidation Catalyst – GE 7FA Combined Cycle
Engelhard Budgetary Proposal EPB00893
August 2, 2000

CATALYST MODULES

The CO Catalyst is manufactured with a special stainless steel foil substrate which is corrugated and coated with an alumina washcoat. The washcoat is impregnated with platinum group metals. The catalyzed foil is folded and encased in welded steel frames, approximately 2 ft. square, to form individual modules. Two of the modules are provided with four (4) replaceable test buttons; eight (8) total buttons provided.

INTERNAL SUPPORT FRAME & SEALS

The internal support frame and internal tongue seals are fabricated from standard structural steel members and shapes. Mechanical tongue and groove expansion seals around the perimeter of the frame and inside the liner sheet prevent bypass around the catalyst. Design accommodates movement of the frame due to thermal expansion while maintaining a continuous seal. The internal frame system interfaces with two types of customer provided connections; ductplate mounted slide plates and liner sheet grooves, both designed by Engelhard.

Dimensions:

Inside Liner Width	(A)	26 ft
Inside Liner Height	(B)	67 ft
Catalyst + frame depth	(C)	18" est.




Table A - Performance Data

Refer to separate attachment – file TRC-GE7FA-DATA-080200-ENGELHARD-CO-0.xls

From: Howard Hurwitz [hhurwitz@roe.com]
Sent: Tuesday, July 25, 2000 8:46 AM
To: llabrie@trccos.com
Cc: sfinnerty@cpowerventures.com; Nabil Keddiss
Subject: SCR cost information

Larry: Information from Engelhard Corporation, supplier of SCR catalyst for combustion turbine applications, is as follows

Scope of Supply

Internal catalyst support frames - installed inside internally insulated casing (by others)

NOxCat SCR catalyst modules

Ammonia Delivery System including AIG, manifold with flow control valves, air dilution skid, controls, etc.

Excluding

Ammonia Storage Tank

HRS G Casing

Field piping

Foundations

Utilities

Cost Information

SCR System Described Above - \$950,000

Ammonia Storage Tank - \$110,000

Replacement Catalyst (3 year life guarantee) - \$520,000

Please let me know if this is sufficient information.

Howard Hurwitz
Burns and Roe Enterprises
(201) 986-4311

From: Nabil Keddis [nkeddis@roe.com]
Sent: Wednesday, July 26, 2000 9:29 AM
To: llabrie@trccos.com
Cc: Sfinnrty@cpowerventures.com
Subject: CPV- Gule Coast Project; Cost Estimate for Sconox Equipment

Lari:

The following information was verbally provided by ABB, as a cost estimate basis for the SCONOX equipment (manufactured by Goalline), based on the following parameters:

a) Natural Gas firing

Emission: NOx
Current: 9.0 ppmvd, 61.00 lb/hr
Required: 3.0 ppmvd, 20.00 lb/hr
Estimated Cost: \$ 14,000,000.00

b) Oil Firing (with water injection)

Emission: NOx
Current: 42.0 ppmvd, 341.00 lb/hr
Required: 10.0 ppmvd, 81.00 lb/hr
Estimated Cost: \$ 16,000,000.00

The delivery schedule for the equipment is: 8 - 10 months.

The estimated cost of installation is: \$ 1,500,000.00

Duration for installation is approximately 60 (sixty) days.

As soon as I receive ABB quotation I'll forward a copy to you and Sean.

Sconox Base

Direct Costs

a) Capital Cost	\$	14,000,000
b) Taxes (3%)	\$	420,000
c) Freight (4%)	\$	-
Purchased Equip Cost	\$	14,420,000
 Installation	 \$	 1,700,000
Total Direct Costs	\$	16,120,000

Engineering Costs	\$	200,000
Contingency	\$	250,000

Total Capital Investment	\$	16,570,000
---------------------------------	-----------	-------------------

Direct Annual Costs

Maintenance	\$	331,400
Steam & Natural Gas	\$	406,400
Pressure Drop	\$	129,360
Catalyst Replacement	\$	190,000

Total Annual Direct Costs	\$	1,057,160
----------------------------------	-----------	------------------

Indirect Annual Costs

Overhead	\$	198,840	60% of maintenance
Property Tax	\$	0	No property taxes
Insurance	\$	165,700	1% of TCI
Administration	\$	125,000	

Total Annual Investment	\$	1,546,700
--------------------------------	-----------	------------------

Capital Recovery Factor	0.1424	10 yrs & 7% interest
-------------------------	--------	----------------------

Total Capital Required	\$	16,570,000
Total Annual Costs	\$	1,546,700

Total Annualized Costs	\$	3,906,268
-------------------------------	-----------	------------------

Appendix E-4

- **Table E-1 – CPV Pierce CO Catalyst**
- **Table E-2 – CPV Pierce SCR
to Achieve 3.5 ppm NO_x**
- **Table E-3 – CPV Pierce SCONOX
to Achieve 3.5 ppm NO_x**

**Table E-1. CPV Pierce
CO Catalyst**

COST COMPONENT:	COST:
DIRECT COSTS	
Purchased Equipment Costs	
CO Catalyst (Engelhard Budgetary Quote)	\$560,000
Sales Tax (6% of purchased equipment costs)	\$33,600
Freight (4% of purchased equipment costs)	\$22,400
Subtotal-Purchased Equipment Costs (PEC)	\$616,000
Direct Installation Costs	
Installation/Foundation (35% of Catalyst Capital Cost)	\$196,000
Subtotal-Direct Installation Costs	\$196,000
TOTAL DIRECT COSTS (TDC)	\$812,000
INDIRECT INSTALLATION COSTS	
Engineering Costs (5% of PEC)	\$30,800
Contingency (3%)	\$18,480
TOTAL INDIRECT COSTS	\$49,280
TOTAL CAPITAL INVESTMENT (TCI)	\$861,280
DIRECT ANNUAL COSTS	
100% Capacity factor	
8,760 Equivalent Operating Hours per Year (per CTG)	
720 Oil-Fired operating hours/year	
Maintenance Materials and Labor (2% of TCI)	\$17,226
Replacement Catalyst (3 Year Service Life)	\$182,880
\$ 480,000 * Capital Recovery Factor (0.3880 for n = 3 & i = 7%)	
3 Guaranteed catalyst life	
7.00% Interest Rate	
0.381 Capital Recovery Factor	
Pressure Drop Derate (Lost Revenue From Sale Of Power)	\$0
Fuel Penalty (Increase Fuel Consumption due to back pressure heat rate impact)	\$36,592
1.81E+09 Annual CTG output, kW-hr	
9 Btu/kW-hr	
16,263 mmBtu/yr natural gas	
2.25 \$/mmBtu natural gas	
Catalyst Disposal	\$16,667
\$ 50,000 at the end of catalyst guaranteed life	
TOTAL DIRECT ANNUAL COSTS	\$253,364
INDIRECT ANNUAL COSTS	
Overhead (60% of labor and maintenance materials)	\$10,335
Property Tax (1% of TCI)	\$8,613
Insurance (1% of TCI)	\$8,613
Administration (2% of TCI)	\$17,226
TOTAL INDIRECT ANNUAL COSTS	\$44,787
TOTAL ANNUAL COSTS	\$298,151
CAPITAL RECOVERY FACTOR, CFR = $(i * (1+i)^n) / ((1+i)^n - 1)$	
10 Equipment Life (years)	
7 Interest Rate (%)	
Capital Recovery Factor	0.1424
CAPITAL RECOVERY COSTS	
TOTAL CAPITAL REQUIREMENT	\$861,280
CATALYST REPLACEMENT COST	-\$480,000
TOTAL CAPITAL REQUIREMENT MINUS CATALYST REPLACEMENT COST	\$381,280
TOTAL ANNUALIZED CAPITAL REQUIREMENT	\$54,286
TOTAL ANNUALIZED COST (Total annual O&M cost and annualized capital cost)	\$352,436
BASELINE POTENTIAL CO EMISSIONS (TPY) FROM TURBINE	156.0
Uncontrolled General Electric 7FA Turbine Emissions = 9 ppm on gas for 6040 hr/yr (no power augmentation)/ 15 ppm on gas for 2000 hr/yr (power augmentation)/20 ppm on oil for 720 hr/yr	
TONS OF CO REMOVED PER YEAR	124.8
Controlled General Electric 7FA Turbine Emissions = assume 80% control efficiency	
COST-EFFECTIVENESS	
ENVIRONMENTAL BASIS (\$ per ton of CO removed)	\$2,824

**Table E-2. CPV Pierce
SCR to achieve 3.5 ppm NO_x**

COST COMPONENT	COST
DIRECT COSTS	
<i>Purchased Equipment Costs</i>	
SCR Catalyst System	950,000
Sales Tax (6% of equipment costs)	57,000
Freight (4% of equipment costs)	38,000
<i>Subtotal-Purchased Equipment Costs (PEC)</i>	1,045,000
TOTAL DIRECT COSTS (TDC)	1,045,000
INDIRECT INSTALLATION COSTS	
Engineering Costs (5% of PEC)	52,250
Contingency (3%)	31,350
Construction, Contractor, Startup, Testing (18%)	188,100
TOTAL CAPITAL INVESTMENT (TCI)	1,285,350
DIRECT ANNUAL COSTS	
Maintenance Materials and Labor (2% of TCI)	25,707
Ammonia Cost	27,763
Catalyst Pressure Derate	145,697
Catalyst Replacement (based on total SCR catalyst replacement cost every 3 years)	173,333
Catalyst Disposal (Amortized Over 5 Year Period)	8,333
TOTAL ANNUAL DIRECT COSTS	380,833
INDIRECT ANNUAL COSTS	
Overhead (60% of maintenance materials and labor)	15,424
Property Tax (1% of TCI)	12,854
Insurance (1% of TCI)	12,854
Administration (2% of TCI)	25,707
TOTAL INDIRECT ANNUAL COSTS	66,838
TOTAL ANNUAL INVESTMENT	447,671
CAPITAL RECOVERY FACTOR, $CFR = (i * (1+i)^n) / ((1+i)^n - 1)$	
Equipment Life (years) = 10	
Interest Rate (%) = 7	
Capital Recovery Factor	0.1424
CAPITAL RECOVERY COSTS	
TOTAL CAPITAL REQUIREMENT	1,285,350
TOTAL ANNUAL CAPITAL REQUIREMENT	183,005
TOTAL ANNUALIZED COST (Total annual O&M cost and annualized capital cost)	630,676
BASELINE POTENTIAL NO_x EMISSIONS (TPY) FROM TURBINE	
Emissions based on 100% load at 72°F, 6040 hrs no PA, 2000 hrs w/PA, 720 hr:	
	Uncontrolled 358
	Controlled 116
ANNUAL TONS OF NO_x REMOVED	242
COST-EFFECTIVENESS	
ENVIRONMENTAL BASIS (\$ per ton of NO _x removed)	2,606

**Table E-3. CPV Pierce
SCONOX to achieve 3.5 ppm NO_x**

COST COMPONENT	COST
DIRECT COSTS	
<i>Purchased Equipment Costs</i>	
SCONOX System	16,000,000
Sales Tax (6% of equipment costs)	960,000
Freight (4% of equipment costs)	640,000
Subtotal-Purchased Equipment Costs (PEC)	17,600,000
<i>Direct Installation Costs</i>	
Construction	1,700,000
TOTAL DIRECT COSTS (TDC)	19,300,000
INDIRECT INSTALLATION COSTS	
Engineering Costs (5% of PEC)	880,000
Contingency (3%)	528,000
Construction, Contractor, Startup, Testing (18%)	3,168,000
TOTAL CAPITAL INVESTMENT (TCI)	23,348,000
DIRECT ANNUAL COSTS	
Maintenance Materials and Labor	331,400
Regeneration Natural Gas and Steam	406,400
Catalyst Pressure Derate	129,360
Catalyst Replacment	190,000
TOTAL ANNUAL DIRECT COSTS	1,057,160
INDIRECT ANNUAL COSTS	
Overhead (60% of maintenance materials and labor)	198,840
Property Tax (1% of TCI)	233,480
Insurance (1% of TCI)	233,480
Administration (2% of TCI)	466,960
TOTAL INDIRECT ANNUAL COSTS	1,132,760
TOTAL ANNUAL INVESTMENT	2,189,920
CAPITAL RECOVERY FACTOR, CFR $= (i * (1+i)^n) / ((1+i)^n - 1)$	
Equipment Life (years) = 10	
Interest Rate (%) = 7	
Capital Recovery Factor	0.1424
CAPITAL RECOVERY COSTS	
TOTAL CAPITAL REQUIREMENT	23,348,000
TOTAL ANNUAL CAPITAL REQUIREMENT	3,324,230
TOTAL ANNUALIZED COST (Total annual O&M cost and annualized capital cost)	5,514,150
BASELINE POTENTIAL NO_x EMISSIONS (TPY) FROM TURBINE	
Emissions based on 100% load at 72°F, 6040 hrs no PA, 2000 hrs w/PA, 720 hrs	
	Uncontrolled
	Controlled
ANNUAL TONS OF NO_x REMOVED	358
	116
	242
COST-EFFECTIVENESS	
ENVIRONMENTAL BASIS (\$ per ton of NO _x removed)	22,786