

Bruce B. Ferguson, CIH

Registration

Certified Industrial Hygienist, ABIH

Fields of Competence

Overall direction and management of projects; extensive experience in air quality testing and studies; industrial hygiene investigations and air quality studies; professional services associated with management of hazardous waste and asbestos; expert witness for environmental matters; research projects associated with chromatographic analysis and reduced sulfur analysis.

Experience Summary

Broadly based experience as a consultant and researcher. Extensive training in environmental regulations in all media; compliance management project experience in pulp and paper, chemicals and petrochemicals, oil and gas production, food and electronics manufacturing. Dr. Ferguson has directed more than 800 source emission tests for hydrocarbons and sulfur species from petroleum refineries, kraft pulp mills and steel mills. Directed over 250 routine emission tests at refineries, foundries, pharmaceutical plants, magnetic tape coating plants and high density urban areas. Directed over 400 tests utilizing EPA Reference Methods of Particulate, NO_x, SO₂, and other routine compounds.

Credentials

B. S., Chemistry/Mathematics – Athens College (1968)
M. S., Physical Chemistry – Vanderbilt University (1973)
Ph.D., Physical Chemistry – Vanderbilt University (1974)
American Chemical Society
Air Pollution Control Association

Employment History

1983-Present	WESTON
1977-1983	Harmon Engineering and Testing
1974-1977	PBR Electronics
1972-1973	College Grove Smelter

Key Projects

Project Manager for site assessments and surveys for the Navy Assessment and Control of Installation Pollutants (NACIP) program. Projects were conducted in South Carolina, Tennessee and Texas. The multi-faceted programs encompassed a variety of waste disposal practices and waste site locations at various Naval Installations.

Served as Project Manager for a \$517,000 three year NASA contract at Marshall Space Flight Center in Alabama. He directed the efforts of seven full time people to monitor contamination of controlled environments, compressed gases, fuel, life support gases, source emissions, wastewater, plating solutions and rocket booster propellants. As Senior Scientist on the project, he developed a technique to trap and analyze hydrocarbons from contaminated areas in the sub ppb range.

Project Director for asbestos survey and abatement project for the development of methods/technology for containment and/or remedial action at Wright-Patterson Air Force Base. Such methods involve testing, identification and recording of potential hazards, documentation and program implementation.

Principal-in-Charge for a full-scale asbestos survey of 10 U. S. Army installations covering 2.2 million sq. ft. in the Republic of Korea. Major work tasks included the characterization of various hazards and prioritization of recommendations for the development of treatment methods.

Professional Profile

Served as Principal Investigator for a U. S. Army Project to develop a transportable gas chromatograph-mass spectrometer. The instrument was used to monitor emissions from solid rocket firings.

Served as Principal Scientist for two EPA contracts in Research Triangle Park, North Carolina. He directed laboratory and field evaluations of EPA Reference Methods 15 and 16. Other tasks under these contracts involved long-term evaluation of process rate monitors; review and editing of QA procedures for EPA Reference Methods 13A and 13B; long-term laboratory and field evaluation of CO and H₂S CEM's and report review.

Principal Investigator for a multi-year EPA contract for development of source tests methodology for reduced sulfur compounds at kraft pulp mills and petroleum refineries. Tasks assigned involved evaluating methodology, developing new methodology and field validating the new procedures. As a result of the contract, new methodology was presented in the Federal Register.

Served as Project Director for a project requiring claims documentation testing on an indoor air quality cleaning device. Testing was performed on the device in a closed chamber to demonstrate the reduction and removal deficiency for such compounds as light weight hydrocarbons, formaldehyde, sulfur dioxide, hydrogen sulfide and other common pollutants. The project resulted in information submitted to the Federal Trade Commission to document the manufacturer's claim.

Served as Project Director for developing VOC emission inventories and for defining Reasonably Available Control Technology (RACT) for VOC emissions; developed permit documentation for VOC incinerators and conducted equipment evaluation and cost studies for projects. These projects have been performed for such clients as Upjohn Chemical, Republic Steel, Richmond Gravure, Southern Wood Piedmont and International Paper Company.

Prepared RCRA-required ground water sampling, monitoring and compliance plans for companies such as Prestolite, Wolverine, Courtaulds, Fruehauf and TR Miller Company in Alabama; Merck Pharmaceuticals, International Paper Company and Mount Pine Wood Treating in Texas, Missouri, Virginia, Georgia, Mississippi, Louisiana and Arkansas.

Directed efforts of a commercial laboratory to obtain accreditation for all parameters by the American Industrial Hygiene Association. Directed the firm's

participation in the NIOSH proficiency analytical testing programs and the EPA Round Robin test programs, and subsequent accreditation under the National Institute of Standards and Technology's (NIST) National Voluntary Laboratory Accreditation Program (NVLAP).

Publications

Elam, D. E. and B. B. Ferguson. (1985) "Quality Assurance Aspects of Total Reduced Sulfur Continuous Emission Monitoring Systems." Continuous Emission Monitor Specialty Conference of the Air Pollution Control Association. Baltimore, MD.

Ferguson, B. B. (1985) "TRS Continuous Emission Monitoring in the Pulp and Paper Industry - One Year Later." Engineering Foundation Conference on Source Testing, Santa Barbara, CA.

Margeson, J. H., J. E. Knoll, M. R. Midgett, B. B. Ferguson and P. J. Schworer. (1985) "A Manual Method for Measurement of Reduced Sulfur Compounds." J. of the Air Pollution Control Association, 35(12), 1280.

Elam, D. E. and B. B. Ferguson. (1983) "Quality Assurance Requirements of Total Reduced Sulfur Emission Testing." Specialty Conference on Measurement and Monitoring of Non-Criteria (Toxic) Contaminants in Air. Air Pollution Control Association, Chicago, IL.

Ferguson, B. B. (1982) "Role of Analytical Laboratory in Hazardous Waste Management." The Second Ohio Environmental Engineering Conference.

Reece, J. W., A. R. Barbin, J. D. Sterrett and B. B. Ferguson. (1981) "Cyclonic Flow in a Venturi." The 2nd Symposium on Flow: Its Measurement and Control in Science and Industry. St. Louis, MO. Sponsored by ASME and ISA.

Lee A. Cecchi

Fields of Competence

Operations of Gas Chromatograph (GC) and associated equipment for source emission evaluation; performance specifications (PS) 1-5 on continuous emission monitoring systems (CEMS); coordination and performance of source sampling according to EPA and NIOSH methodology; data quality assurance; data reduction; report preparation; working knowledge of various IBM compatible software and of statistical analysis system (SAS) programming.

Experience Summary

Experienced in EPA Reference Methods 1-7, 10, 15, 16, 18, 25, 25A, and PS 1-5. Prepared quotations, coordinated and conducted projects associated with total reduced sulfur (TRS) emission testing. Coordinated and conducted projects involving on-site analysis of organic compounds by GC. Repair and modification of instruments in the field. Compiled emission, compliance, and PS test reports.

Credentials

B.S., Vocational Agriculture – Auburn University (1982)
M.S., Animal Science – Auburn University (1986)
Phi Kappa Phi
Kappa Delta Pi
Gamma Sigma Delta
Alpha Tau Alpha

Employment History

1987-Present	WESTON
1986-1987	Royal Sausage Company
1984-1986	Auburn University
1982-1983	Hinton Beef and Provision

Key Projects

Coordinated and conducted mill-wide inventory of TRS emissions in kraft pulping operations in Florida,

Kentucky and South Carolina. Data utilized for odor reduction and modeling.

Coordinated and served as test team leader of an emission inventory study of units associated with carbon black manufacturing facilities in Arkansas, Louisiana, and West Virginia. Test parameters included: SO₂, NO_x, O₂, CO₂, CO, methane, acetylene and TRS.

Coordinated and served as test team leader for on-site isopropanol emission and scrubber efficiency testing using EPA Method 18 at a gunpowder manufacturing facility.

Served as test team leader in acetone and isopropanol condenser efficiency testing using EPA Method 18 at a copper rod facility.

Successfully solved another test team's technical problems involving EPA Methods 25 and 25A at a circuit board manufacturing facility.

Coordinated and served as test team leader for conducting fiber removal efficiency tests on digester blow gas cyclones.

Coordinated and solely conducted PS test in Idaho. Test parameters included EPA reference methodology to fulfill requirements of PS 1-5.

Served as test team leader in TRS testing in order to locate sulfidity loss problems at a facility in New Hampshire. Successfully located the primary source of sulfur loss.

Successfully modified existing equipment for EPA Method 25A analysis. Successfully modified existing equipment for carbon disulfide in toluene analysis. Significantly reduced carbon disulfide analysis time.

Coordinated and served as test team leader for conducting TRS compliance and PS tests on recovery boilers, smelt dissolving tank vents, tall oil reactors,

Professional Profile

and lime kilns for numerous clients in Alabama, Arkansas, Florida, Georgia, Kentucky, Louisiana, Maine, Mississippi, South Carolina and Texas.

Significantly decreased data reduction time by designing and implementing electronic spreadsheets for velocity, particulate, NO_x, SO₂ and TRS calculations.

Publications

Cecchi, L. A., D. L. Huffman, W. R. Egbert and W. R. Jones (1987). "Chemical and Physical Characteristics of Beef Chuck Muscles." (In Review).

Cecchi, L. A., D. L. Huffman, P. M. Brown, W. R. Egbert and W. R. Jones, (1986). "Chemical and Physical Analyses for Characterization of Beef Chuck Muscles." Proc Recip Meat Conference. (In Press).

Cecchi, L.A., D. L. Huffman and J. C. Cortay (1985). "Processing of Hams After Various Conditioning Times." J. of Animal Science. 61:19 (Abstric.)

Cecchi, L. A., D. L. Huffman and J. C. Cortay (1985). "Hot Processing of Hams Proves Successful." Highlights of Agricultural Research. 32(4):13.

Michael E. Steele

Fields of Competence

Project management; supervision and performance of air quality testing; preparation of emission inventories; financial analysis; engineering evaluation of emission control equipment.

Experience Summary

Mr. Steele has diverse experience in chemical engineering and process design in both the manufacturing sector and in environmental pollution control. He specializes in standard reference method testing, emission inventories, odor abatement studies, permit assistance, proposal preparation and engineering evaluations for a variety of industrial and government clients.

Credentials

B. S., Chemical Engineering – Pennsylvania State University (1981)
M. B. A., Operations Research and Production Management – University of Pittsburgh (1982)
Source Evaluation Society

Employment History

1986-Present	WESTON
1983-1986	Martin Marietta Energy Systems, Inc.
1982-1983	Union Carbide Corporation

Key Projects

Project Manager on an incinerator evaluation study for a circuit board manufacturer. Specific responsibilities included evaluation of the incinerator, recommendations for remedial action, supervision of the field testing effort and report preparation. Served

as client's representative at meetings with the state regulatory agency.

Project Manager for a reasonably available control technology (RACT) evaluation for volatile organic compound (VOC) emissions from an offset printing facility. Specific responsibilities included determining the current status of production and emissions, determining VOC collection strategies and control options. Various methods of reducing the VOC from the air were considered in light of maintaining product quality and the economics of the control.

Project Manager for a mill-wide inventory at a large southern pulp and paper mill. Specific responsibilities included the coordination and supervision of the testing effort which encompassed 19 sources and 9 parameters. In addition, performance specification testing on four total reduced sulfur (TRS) and two sulfur dioxide (SO₂) continuous emission monitoring systems (CEMS) were also required. Preparation, field testing and report submittal were completed to the client's approval within the required 30 days.

Publications

Steele, M. E. and O. Fick, (1988) "Reasonably Available Control Technology for VOC Control from a Lithographic Printing Facility." Presented at the TAPPI Environmental Conference, Charleston, SC.



APPENDIX B - NCG INCINERATOR - TRS FIELD DATA

INSTRUMENT DATA

CLIENT QFT
 SOURCE TDCW

PROJECT NO. 0414-09-a
 DATE 1/25

GAS PRESSURE/FLOW	TEMPERATURE	COLUMNS
H ₂ : <u>30 psi</u>	TRAILER: <u>70°F</u>	SAMPLE LOOP: <u>6" U.D. 1.000</u>
AIR: <u>19 psi</u>	DETECTOR: <u>110°C</u>	BHT: <u>100 1/4 x 6'</u>
N ₂ -1: <u>30 psi</u>	COLUMN: <u>65°C</u>	DE: <u>13.45 100 1/4 x 1'</u>
N ₂ -2:		

TIMER PROGRAM					INTEGRATOR PROGRAM				
EVENT	1	2	3	4					
PROGRAM	1	2	3	4					
CIRCUIT	1	2	3	4					
ON (min)	0	1	1	5					
ON (sec)	03	48	61	30					
VARY (min)	1000	600	600	600					
OFF (min)	0	1	1	5					
OFF (sec)	05	50	54	35					
VARY (min)	600	600	600	600					
REMARKS									

IST: METH #

RUN PRMTRS

ZERO = 10
 ITT 2t = 4
 ZHT SP = 0.5
 PK WD = 0.04
 THRSH = 2
 QR REJ = 5000

RPRT OPTNS

- 2. RF UNC PKS= 0.0000
- 3. MUL FACTOR= 1.0000
- 4. PK HEIGHT MODE NO
- 5. EXTEND RT NC
- 6. RPRT UNC PKS NC

TIME TAB

1.74 INTG # = 9
 2.00 PK WD = 0.16
 2.10 INTG # = -9
 5.18 STOP

Page ____ of ____

SAMPLE #7
SUBSTRATE TGAED

TEST DATE NO. 0414-09-01

1/24

H₂S

CHIC 1

TIME CONC % CONC RESPONSE CURVE NO. DIFF

0714	4.44	1.43×10^7	4.91	+1
0742	1.85	1.55×10^6	1.83	-1
1124	3.27	5.66×10^6	3.22	-1
1142	1.10	5.75×10^5	1.17	+1

SLOPE 2.26 Y int 4.01×10^5

CONC @ 5000 = 0.14

CFD ppm CURVE NO. 1

TIME	CONC	RESPONSE	CHIC	%
			CONC	DIFF
0714	2.63	2.63×10^6	2.77	+5
0742	1.00	4.24×10^5	1.02	+2
1124	1.78	1.01×10^6	1.04	-8
1142	0.63	1.79×10^5	0.64	+1

SLOPE 1.87 Y int 4.09×10^5
CONC @ 5000 = 0.09

MOCN

CHIC

TIME CONC RESPONSE CURVE NO. DIFF

0714	2.02	1.63×10^6	2.08	+3
0742	0.77	2.34×10^5	0.77	0
1124	1.37	4.41×10^5	1.31	-4
1142	0.48	9.06×10^4	0.48	0

SLOPE 1.90 Y int 3.82×10^5

CONC @ 5000 = 0.10

CFD ppm CURVE NO. 1

TIME	CONC	RESPONSE	CHIC	%
0714	1.44	1.22×10^6	1.63	+6
0742	0.65	2.43×10^5	0.57	-4
1124	0.97	4.92×10^5	0.88	-9
1142				

SLOPE 1.65 Y int 10.08×10^5
CONC @ 5000 = 0.05

RUN SUMMARY

RUN NO	1-1	1-13	1-C
AVG MEAS TRS CONC, ppm	<0.43	<0.43	<0.43
SYS CORR FACTOR	.972	.972	.972
CORR TRS CONC, ppm	<0.44	<0.44	<0.44
OXYGEN CONC, %	18.7	18.8	18.5
OXYGEN CORR FACTOR	4.78	5.00	4.40
OXYGEN CORRECTED TRS, ppm	<2.10	<2.20	<1.94

Page ____ of ____

TWR-09-9/84

2-02

WESTON
SCIENCE INSTRUMENTS

REDUCED SULFUR FIELD DATA

Client Georgia Pacific Source ESCIW Date 4/3
 Cal Curve 1 Inst Data 1 Recovery Data 1 Analyst AC

TIME	H ₂ S AREA	H ₂ S CONC (ppm)	CH ₃ SH AREA	CH ₃ SH CONC (ppm)	DMS AREA	DMS CONC (ppm)	DMDS AREA	DMDS CONC (ppm)	TRS
0814	NP	<0.14	DP	<0.10	DP	<0.09	DP	<0.05	<0.43
0824									
0830									
0836									
0842									
0844									
0854									
0900									
0906									
0912	▼		▼		▼		▼		
0918	DP	<0.14	DP	<0.10	DP	<0.09	DP	<0.05	<0.43
0924									
0930									
0936									
0942									
0944									
0954									
1000									
1006			▼		▼		▼		
1012									
1014	NP	<0.14	DP	<0.10	DP	<0.09	DP	<0.05	<0.43
1024									
1030									
1036									
1042									
1044									
1054									
1100									
1106									
1112	▼		▼		▼		▼		

SEARCHED _____
INDEXED _____
SERIALIZED _____
FILED _____

0414-09-01

		H ₂ C			
			CHLC		
1124	3.27	5.65×10^6	3.14	-4	
1142	1.12	8.75×10^5	1.12	-4	
1F12	4.92	1.61×10^7	4.45	+1	
1F30	1.84	2.03×10^6	1.88	+8	

STAGE 2.14 1.475 4.82 x 10⁻⁸

CONC 1 $\delta_{000} = 0.13$

CPO DMS CIVIC NO. 2

TIME	CONE	RESPONSE	CALC CONC	% DIFF
1124	1.74	1.01×10^6	1.69	-5
1145	0.63	1.79×10^5	0.62	-1
1151	2.08	2.30×10^6	2.75	+3
1530	1.00	4.30×10^5	1.03	+3

$$\text{SLOPE } 1.74 \quad \text{Y int } 4.00 \times 10^5$$

1124	1.37	10.41×10^5	1.31	-4
1142	0.48	9.66×10^4	0.48	0
1512	2.06	1.56×10^6	2.11	-2
1530	0.77	2.43×10^5	0.78	-2

SLOPE 1.86 Y int 3.84×10^5

COSC 3 $\text{FOOD} = 0.10$

C.P.D. DMD5 CURVE NO. 2

TIME	CONC	RESPONSE	CALC CONC	%
1124	0.97	4.92×10^5	0.92	-5
1512	1.46	1.03×10^6	1.51	+3
1530	0.55	2.38×10^5	0.56	+2

$$\text{SLOPE } \frac{1.49}{\text{CONC } \text{M}} = 0.04$$

RUN SUMMARY

RUN NO	2-A	2-B	2-C	
Avg NEPS TRS CONC, ppm	<0.39	<0.39	<0.39	
SYS CORR FACTOR	.880	.880	.880	
CORR TRS CONC, ppm	<0.44	<0.44	<0.44	
OXYGEN CONC, %	18.7	18.1	18.9	
OXYGEN CORR FACTOR	3.43	3.74	5.24	
OXYGEN CORRECTED TRS, ppm	<1.73	<1.67	<2.31	

REDUCED SULFUR FIELD DATA

Client #1 Source Ind. Date 1/25
 Cal Curve 1 Inst Data 1 Recovery Data 2 Analyst C

TIME	H ₂ S AREA	H ₂ S CONC (ppm)	CH ₃ SH AREA	CH ₃ SH CONC (ppm)	DMS AREA	DMS CONC (ppm)	DMDS AREA	DMDS CONC (ppm)	TRS
1206	ND	<0.13	1012	<0.10	22	<0.05	22	<0.04	<0.34
1212									
1218									
1224									
1230									
1236									
1242									
1248									
1254									
1300	ND		↓	↓	↓	↓	↓	↓	
1306	20	<0.13	20	<0.10	20	<0.05	20	<0.04	<0.34
1312									
1318									
1324									
1330									
1336									
1342									
1348									
1354	↓		↓	↓	↓	↓	↓	↓	
1400	ND								
1406	20	<0.13	20	<0.10	20	<0.05	20	<0.04	<0.34
1412									
1418									
1424									
1430									
1436									
1442									
1448									
1454									
1500	↓		↓	↓	↓	↓	↓	↓	

CLIENT 97
SOURCE TACIDDATE 04/4/09-011/24

1425 3
 TIME CONC RESPONSE CONC DIFF
 1512 2.68 2.36×10^6 2.72 +1
 1530 1.00 4.30×10^5 1.03 +3
 1906 1.61 8.82×10^5 1.65 -4
 1924 0.66 1.94×10^5 0.64 -1

SLOPE 2.14 Y int 4.78×10^5
 CONC @ 5000 = 0.12

GPD DMS CURVE NO. 3

TIME	CONC	RESPONSE	CALC CONC	DIFF
1512	2.68	2.36×10^6	2.72	+1
1530	1.00	4.30×10^5	1.03	+3
1906	1.61	8.82×10^5	1.65	-4
1924	0.66	1.94×10^5	0.64	-1

SLOPE 1.76 Y int 4.08×10^5
 CONC @ 5000 = 0.06

2MDS 3
 TIME CONC RESPONSE CONC DIFF
 1512 2.06 1.50×10^6 2.11 +2
 1530 0.77 2.43×10^5 0.77 0
 1906 1.23 5.30×10^5 1.18 -4
 1924 0.50 1.10×10^5 0.51 +1

SLOPE 1.85 Y int 3.40×10^5
 CONC @ 5000 = 0.10

GPD DMS CURVE NO. 3

TIME	CONC	RESPONSE	CALC CONC	DIFF
1512	1.46	1.03×10^6	1.50	+2
1530	0.85	2.38×10^5	0.86	+3
1906	0.88	4.30×10^5	0.84	-5

SLOPE 1.50 Y int 5.62×10^5
 CONC @ 5000 = 0.04

RUN SUMMARY

RUN NO	3-A	3-B	3-C
AVG MEAS TRS CONC, ppm	20.38	20.38	20.38
SYS CORR FACTOR	.880	.880	.880
CORR TPS CONC, ppm	20.43	20.43	20.43
OXYGEN CONC, %	18.8	18.8	18.8
OXYGEN CORR FACTOR	5.00	5.00	5.00
OXYGEN CORRECTED TRS, ppm	22.15	22.15	22.15

Page 1 of 1

TAR-09-3/84

2 06

WESTON

DEMONSTRATION

REDUCED SULFUR FIELD DATA

Client 771Source INCWDate 1/25Cal Curve 3Inst Data 1Recovery Data 3Analyst CC

TIME	H ₂ S AREA	H ₂ S CONC (ppm)	CH ₃ SH AREA	CH ₃ SH CONC (ppm)	DMS AREA	DMS CONC (ppm)	DMDS AREA	DMDS CONC (ppm)	TRS
1600	1.03×10^4	0.17	DD	< 0.10	DD	< 0.08	DD	< 0.04	
1606	1.09×10^4	0.18							
1612	DD	< 0.12							< 0.38
1615									
1624									
1630									
1636	2.12×10^4	0.24							
1642	DD								
1644									
1654									
1700	DD	< 0.12	DD	< 0.10	DD	< 0.08	DD	< 0.04	< 0.38
1706									
1712									
1714									
1724									
1730									
1736									
1744									
1746									
1754	↓		↓		↓		↓		
1800	DD	< 0.12	DD	< 0.10	DD	< 0.08	DD	< 0.04	< 0.38
1806									
1812									
1814									
1824									
1830									
1836									
1842									
1848									
1854	↓		↓		↓		↓		

BEST AVAILABLE COPY

WHEN 070012910 Pacific
SIGHTED Town

WHERE 0414-09-01
DATE 1/26/90

COMPOUND	RT	RAD	WELL	DPS	PPM
RETENTION RATE (mL/min)	886.3	370.3	481.7	263.4	76
ENTER NUMBER	89-38090	28-40474	82-40477	82-40478	
RETENTION TIME (min)	0.59	1.54	2.11	3.90	29.99
TYPE	RT(m)	RAD(m)	WELL(m)	DPS(m)	PPM(m)
0718	183	145	4.84	1.41	1.46 1.43 1.43 x10 ⁷
			2.02	1.48	1.59 1.53 1.53 x10 ⁶
			2.63	2.89	2.65 2.44 2.103 x10 ⁶
			1.44	1.38	1.18 1.09 1.22 x10 ⁶
0742	480	142	1.85	1.63	1.58 1.64 1.66 x10 ⁶
			0.77	2.30	2.30 2.32 2.34 x10 ⁵
			1.00	4.09	4.38 4.24 4.24 x10 ⁵
			0.55	-	2.30 2.49 2.43 x10 ⁵
1124	271	142	3.27	5.62	5.58 5.55 5.55 x10 ⁶
			1.37	6.37	6.49 6.34 4.41 x10 ⁵
			1.78	1.01	1.02 1.01 1.01 x10 ⁶
			0.97	4.97	4.82 4.98 4.92 x10 ⁵
1142	767	N24	1.10	5.45	5.04 5.71 5.75 x10 ⁵
			0.48	9.43	10.4 9.15 9.610 x10 ⁴
			0.103	1.92	1.46 1.59 1.79 x10 ⁵
			0.34	-	- - -
1512	180	142	4.92	1.45	1.51 1.50 1.51 x10 ⁷
			2.04	1.51	1.58 1.58 1.54 x10 ⁶
			2.68	2.30	2.34 2.34 2.36 x10 ⁶
			1.40	1.05	1.04 9.88 1.03 x10 ⁶

Page of

PACIFIC RUBBER CO.

Total gas concentration in ppm:

Concentration (mL/min)

$$\text{H}_2 = 1240 \text{ mL} \times \frac{22.4 \text{ L}}{94.2 \text{ g/mole}} \times \frac{460 + 75}{492} \times \frac{29.92}{29.99} = \underline{\underline{886.5 \text{ mL}}} \text{ min}$$

$$\text{N}_2 = 733 \text{ mL} \times \frac{22.4 \text{ L}}{94.2 \text{ g/mole}} \times \frac{460 + 75}{492} \times \frac{29.92}{29.99} = \underline{\underline{370.3 \text{ mL}}} \text{ min}$$

$$\text{O}_2 = 1231 \text{ mL} \times \frac{22.4 \text{ L}}{94.2 \text{ g/mole}} \times \frac{460 + 75}{492} \times \frac{29.92}{29.99} = \underline{\underline{481.7 \text{ mL}}} \text{ min}$$

$$\text{H}_2S = 1022 \text{ mL} \times \frac{22.4 \text{ L}}{94.2 \text{ g/mole}} \times \frac{460 + 75}{492} \times \frac{29.92}{29.99} = \underline{\underline{263.6 \text{ mL}}} \text{ min}$$

$$\text{CH}_4 = \text{_____} \text{ mL} \times \frac{22.4 \text{ L}}{94.2 \text{ g/mole}} \times \frac{460 + 75}{492} \times \frac{29.92}{29.99} = \text{_____ mL} \text{ min}$$

$$\text{CO}_2 = \text{_____} \text{ mL} \times \frac{22.4 \text{ L}}{94.2 \text{ g/mole}} \times \frac{460 + 75}{492} \times \frac{29.92}{29.99} = \text{_____ mL} \text{ min}$$

BEST AVAILABLE COPY

971
FDCIN

0414-09-01

1/24

PERMEATION RATE (ml/min)		R ₁	R ₂	R ₃	R ₄	Avg.	STD.
TUBE NUMBER		89-38090	28-40474	82-40477	82-40478		
PERMEATION TIME (min)		0.59	1.54	3.11	3.90	29.99	
TIME (min.)	FLOW (ml/min.)	COND. (ppm)	AVER. (ml/sec)				
1830	4.82	H ₂ S	1.84	1.90	2.20	1.63	2.03 $\times 10^6$
		methyl	0.77	2.67	2.22	2.60	2.43 $\times 10^6$
		DMS	1.00	4.25	4.35	4.30	4.30 $\times 10^5$
		DMDS	0.65	2.45	2.57	2.12	2.38 $\times 10^5$
1906	3.00	H ₂ S	2.84	4.74	4.74	4.91	4.80 $\times 10^6$
		methyl	1.23	5.40	5.60	4.94	5.30 $\times 10^5$
		DMS	1.61	2.67	4.75	8.89	4.8 $\times 10^5$
		DMDS	0.84	-	4.30	4.24	4.30 $\times 10^5$
1924	7.35	H ₂ S	1.21	10.77	10.83	10.54	10.71 $\times 10^5$
		methyl	0.50	1.04	1.15	1.12	1.10 $\times 10^5$
		DMS	0.06	-	1.90	1.98	1.94 $\times 10^5$
		DMDS	0.30	-	-	-	-

Page _____ of _____

BEST AVAILABLE COPY

CHARGE

~~up P~~

NOTE

Incid

0414-09-01

1/25/90

TIME	NET AREA	AVE AREA	MERS CONC	REMARKS/NOTES
0810	7.27×10^6			
0811	7.44×10^6	7.29×10^6	3.64	TRACE \Rightarrow Cx65-
0812	7.13×10^6			
0755	7.57×10^6			
0756	7.57×10^6	7.62×10^6	3.71	TRACE \Rightarrow CC
0757	7.73×10^6			
				Recovery = 98.1 %

TIME	NET AREA	AVE AREA	MERS CONC	REMARKS/NOTES
1155	5.19×10^6			
1157	5.20×10^6	5.19×10^6	3.13	TRACE \Rightarrow Cx65-
1158	5.17×10^6			
1201	5.53×10^6			
1202	5.54×10^6	5.53×10^6	3.22	TRACE \Rightarrow CC
1203	5.52×10^6			
				Recovery = 97.2 %

BEST AVAILABLE COPY

CLIENT 97P
SOURCE END-12TEST NO. 0414-09-011/26

	TRACE	DILUENT	TOTAL	INSTRUMENT DATE
TDE. READING	2/7	2/7	2/7	CALIBRATION NUMBER
TICK (L/min)				TDE BEGIN/TDE END
COND (ppm)	↓	↓	↓	PRE/POST RUN NO.
TDE	NEW AREA	AVE AREA	MEAS CONC	REMARKS/NOTES
1544	3.30×10^6			
1548	3.52×10^6	3.59×10^6	2.57	TRACE \Rightarrow SYSTEM
1547	3.90×10^6			
1549	4.81×10^6			
1550	4.62×10^6	4.76×10^6	2.92	TRACE \Rightarrow GC
1553	4.84×10^6			
				Recovery = 88.0%

	TRACE	DILUENT	TOTAL	INSTRUMENT DATE
TDE. READING	2/7	2/7	2/7	CALIBRATION NUMBER
TICK (L/min)				TDE BEGIN/TDE END
COND (ppm)	↓	↓	↓	PRE/POST RUN NO. #3
TDE	NEW AREA	AVE AREA	MEAS CONC	REMARKS/NOTES
1937	9.41×10^6			
1939	9.47×10^6	9.39×10^6	3.91	TRACE \Rightarrow SYSTEM
1941	9.30×10^6			
1944	1.17×10^7			
1948	1.10×10^7	1.14×10^7	4.27	TRACE \Rightarrow GC
1949	1.15×10^7			
				Recovery = 91.6%

PROJECT DATA

CLIENT

Georgia Pacific

PROJECT NO. 0414-09-01

SOURCE

TDCI

DATE

1/26

ITEM NO.		TOTAL 1	TOTAL 2	TOTAL 3	TOTAL 4	MEAN
TYPE						
Ambient	CO ₂	0.0	0.0			
TIR	TOTAL	20.8	20.8			
	O ₂	20.8	20.8			
RUN 1A	CO ₂	1.0	1.0	1.0		
0814-0914	TOTAL	19.7	19.6	19.7		
	O ₂	18.7	18.6	18.7		18.7
RUN 1B	CO ₂	1.0	1.2	1.0		
0914-1016	TOTAL	19.8	20.0	19.8		
	O ₂	18.8	18.8	18.8		18.8
RUN 1C	CO ₂	1.2	1.2	1.2		
1016-1118	TOTAL	19.7	19.7	19.7		
	O ₂	18.5	18.5	18.5		18.5
RUN 2A	CO ₂	1.0	1.0	1.0		
1206-1306	TOTAL	19.2	19.1	19.2		
	O ₂	18.2	18.1	18.2		18.2
RUN 2B	CO ₂	1.0	1.0	1.0		
1306-1406	TOTAL	19.1	19.2	19.1		
	O ₂	18.1	18.2	18.1		18.1
RUN 2C	CO ₂	1.0	1.0	1.0		
1406-1506	TOTAL	19.9	19.8	19.9		
	O ₂	18.9	18.8	18.9		18.9

ORSA/TM DATA

CLIENT SP PROJECT NO. 0414-09-01SOURCE Tecin DATE 3/25

Run No.	Time	TRIAL 1	TRIAL 2	TRIAL 3	TRIAL 4	MEAN
Ambient	CO ₂	0.0				
FIRE	TOTAL	20.4				
	O ₂	20.4				
Run 3A	CO ₂	4.0	1.0	1.0		
1600-1700	TOTAL	19.4	19.4	19.4		
	O ₂	18.4	18.4	18.4		18.4
Run 3B	CO ₂	1.10	1.10	1.0		
1700-1800	TOTAL	19.9	19.9	19.8		
	O ₂	18.8	18.8	18.8		18.8
Run 3C	CO ₂	1.0	1.0	1.0		
1800-1900	TOTAL	19.7	19.8	19.8		
	O ₂	18.7	18.8	18.8		18.8
	CO ₂					
	TOTAL					
	O ₂					
	CO ₂					
	TOTAL					
	O ₂					

Page 1 of 1



APPENDIX C. NCG INCINERATOR - PARTICULATE FIELD DATA AND
LABORATORY DATA

PRELIMINARY VELOCITY DATA


CLIENT Georgia Pacific
SOURCE Incinerator

ATC PROJECT NO. 0414-09
DATE 1-23-90

DUCT DATA

Dist from far wall to outside of port	<u>91</u>	in.	Equivalent diameter $\frac{2 \times \text{depth} \times \text{width}}{\text{depth} + \text{width}}$	Dist from ports to nearest disturbance up-stream ft <u>150</u>
Nipple length	<u>53</u>	in.		down-stream <u>00</u>
Depth of duct	<u>38</u>	in.		
Width of duct (rec)	<u>—</u>	in. ²	$2(\frac{1}{()} + \frac{1}{()})$	dia <u>19.9</u> <u>7.6</u>
Area of duct	<u>788</u>	ft ²		

LOCATION OF TRAVERSE POINTS



CIRCULAR DUCTS

Traverse point number on a diameter	(Percent of stack diameter from inside wall to traverse point)					
	2	4	6	8	10	12
1	14.6	6.7	4.4	3.2	2.6	2.1
2	85.4	25.0	14.6	10.5	8.2	6.7
3	75.0	29.6	19.4	14.6	11.8	
4	93.3	70.4	32.3	22.6	17.7	
5	85.4	67.7	34.2	25.0		
6	95.6	80.6	65.8	35.6		
7	89.5	77.4	64.4			
8	96.8	85.4	75.0			
9	91.8	82.3				
10	97.4	88.2				
11		93.3				
12		97.9				


RECTANGULAR DUCTS

	2	3	4	5	6	7	8	9	10	11	12
1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3	83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8	
4	87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2		
5	90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5			
6	91.7	78.6	68.8	61.1	55.0	50.0	45.8				
7	92.9	81.3	72.2	65.0	59.1	54.2					
8	93.8	83.3	75.0	68.2	62.5						
9	94.4	85.0	77.3	70.8							
10	95.0	86.4	79.2								
11		95.5	87.5								
12			95.8								

MEASUREMENTS

Traverse Point	% of Diameter	Distance from inside wall	Distance from outside of port
1	4.4	1.7	54.7
2	14.6	5.5	58.5
3	29.6	11.2	64.2
4	70.4	26.8	79.8
5	85.4	32.5	85.5
6	95.6	36.3	89.3
7			
8			
9			
10			
11			
12			

SKETCH OF DUCT



PARTICULATE CALCULATIONS

Client: Georgia Pacific
 Weston Project No: 0414-09-01
 Source: NCG Incinerator

Date: 1/25/90

	INPUT DATA	Run 1	Run 2	Run 3	Mean
Sampling Time, min	(Theta)	60	60	60	60
Stack Area, ft ²	(As)	7.88	7.88	7.88	7.88
Barometric Pressure, in Hg	(Pb)	29.77	29.77	29.77	29.77
Stack Pressure, in Hg	(Ps)	29.98	29.98	29.98	29.98
Pitot Tube Coefficient	(Cp)	.84	.84	.84	.84
Meter Correction Factor	(Y)	1.013	1.013	1.013	1.013
Nozzle Diameter, in	(Dn)	.247	.247	.247	.247
Meter Volume, ft ³	(Vm)	56.483	57.900	56.375	56.919
Meter Temperature, F	(Tm)	84	89	95	89
Meter Orifice Pressure, in H2O	(Delta H)	2.908	2.951	2.964	2.941
Volume H2O Collected, mL	(Vlc)	82.1	81.8	93.4	85.8
CO ₂ Concentration, %	(CO ₂)	1.0	1.0	1.0	1.0
O ₂ Concentration, %	(O ₂)	18.7	18.8	18.5	18.7
Average Sq Rt Velo Head, in H2O ^{1/2}	(Delta P ^{1/2})ave	1.152	1.149	1.145	1.149
Stack Temperature, F	(Ts)	466	496	529	497
Particulate Collected, g	(Mn)	.0840	.1737	.0586	.1054

CALCULATED DATA					
Standard Meter Volume, ft ³	(Vmstd)	55.665	56.487	54.448	55.533
Standard Water Volume, ft ³	(Vwstd)	3.864	3.850	4.396	4.037
Moisture Fraction	(BWS)	.065	.064	.075	.068
Mol Wt of Stack Gas	(Ms)	28.2	28.2	28.1	28.2
Average Stack Gas Velocity, ft/sec	(Vs)	86.6	87.7	89.1	87.8
Stack Gas Flow @ Stack Cond, ft ³ /min	(Qs)	4.09E+4	4.15E+4	4.21E+4	4.15E+4
Stack Gas Flow @ Std Cond, ft ³ /min	(Qs)	2.19E+4	2.15E+4	2.09E+4	2.14E+4
Isokinetic Sampling Rate, %	(%I)	101	104	103	103
Particulate Conc @ Std Cond, gr/ft ³	(Cs)	.023	.047	.017	.029
Particulate Emission Rate, lb/hr	(PMR)	4.353	8.715	2.963	5.343

PARTICULATE FIELD DATA

Client: Georgia Pacific
 Weston Project No: 0414-09-01
 Source: NCG Incinerator
 Date: 1/25/90
 Run#: 1

PORT POINT NO.	DGM READING Vm(ft ³ /3)	DELTA P in. H2O	DELTA P SQUARE ROOT	DELTA H IN. H2O	PROBE TEMP (F)	AVG DGM TEMP (F)	STACK TEMP (F)	IMP OUT (F)	HOT BOX TEMP (F)	SAMPLE TRAIN VAC (in Hg)
1/1	513.990	1.50	1.22	3.22	239	75	450	63	249	5.0
2	519.500	1.40	1.18	3.00	250	79	456	54	255	5.0
3	524.500	1.50	1.22	3.30	241	81	478	61	252	5.0
4	530.200	1.20	1.10	2.64	246	83	465	64	252	5.0
5	533.600	1.30	1.14	2.86	247	84	468	64	252	5.0
6	538.600	.99	.99	2.18	244	84	464	68	253	5.0
2/1	541.800	1.20	1.10	2.64	235	82	456	66	243	5.0
2	547.800	1.50	1.22	3.30	234	86	485	56	251	5.0
3	551.810	1.50	1.22	3.30	234	87	470	58	252	5.0
4	556.600	1.50	1.22	3.30	241	88	477	61	246	5.0
5	562.400	1.30	1.14	2.86	240	88	455	60	248	5.0
6	566.100	1.10	1.05	2.30	234	87	470	61	247	5.0
	570.473									

DGM READING Vm: 56.483
 AVG DELTA P: 1.33
 AVG DELTA H: 2.91
 AVG SQT DELTA P: 1.15
 AVG DGM TEMP: 84
 AVG STACK TEMP: 466

PARTICULATE DATA

CLIENT

George Pacific
Mississippi

WORK ORDER NO

0414-01-01

DATE 1-24-90

SITE CODE

SAMPLE POINT

0810

END TIME

0910

SAMPLING SITE

Tallula

CONTROL DEVICE

none

SAMPLE NUMBER

17-5,6

SAMPLE CONSOLE

4

SAMPLE CASE

AMBIENT TEMP

60

WEATHER

HAZE

WIND SPEED/DIRECTION

E 5-10

WESTON TEST PERSONNEL

KU, SS

OBSERVERS

SKETCH OF
STACK

Stack Dimensions 38" Orifice ΔH 1.843

Sample Time (min/pt) 5.0 Meter Corr. Factor 1.013

Net Sample Time (min) 60 Pitot Tube # 8' #1

Pitot Press. (in Hg) 29.99 Pitot Factor 0.84

Stack Press. (in Hg) 29.98 Nozzle ID # 247

Stack Temp DB/WB (°F) 437 Noz Dia Pretest (in) 0.247

Assumed Mois (%) 7% Noz Dia Posttest (in) 0.247

Pretest Leak Check .014% @ 1545s Avg Noz Dia (in) 0.247

Posttest/Leak Check .014% @ 1545s Filter Type/Number 900507

Final Gas Meter Reading 570.473 Silica gel # 1 / 17.1

Initial Gas Meter Reading 513.990 Δ Condensate (ml) 65 + 7.1

Δ Meter Reading 56.48

Orsat: Method of Collection TRS/injected sample

	RUN 1	RUN 2	RUN 3	AVG
%CO ₂	1.0	1.0	1.0	1.0
%O ₂	18.7	18.7	18.7	18.7
% CO	—	—	—	—

FIELD DATA

705 509
247

CLIENT Georgia Pacific WORK ORDER NO. 0414-09-01
SOURCE Spicerator DATE 1-24-79 RUN # ONE

NOTES/REMARKS:

$$\Delta H = \Delta P [(893.94) (C_p)^2 (FDA)^2 (\Delta H @) (Dn)^4 \left(\frac{T_m}{T_s} \right)]$$

Difficult conditions

Dust & steam plume across site.

$$K = 2.15 \rightarrow 2.2$$

Client: Georgia Pacific
 Weston Project No: 0414-09-01
 Source: NCG Incinerator
 Date: 1/25/90
 Run#: 2

PORT POINT NO.	DGM READING Vm(ft^3)	DELTA P in. H2O	DELTA P SQUARE ROOT	DELTA H IN. H2O	PROBE (F)	AVG DGM TEMP (F)	STACK TEMP (F)	IMP OUT (F)	HOT BOX TEMP (F)	TRAIN VAC (in Hg)
1/1	570.855	1.50	1.22	3.30	244	-82	478	47	235	5.0
2	575.900	1.50	1.22	3.30	250	85	488	46	239	5.0
3	581.400	1.40	1.18	3.10	250	88	502	54	244	5.0
4	587.510	1.30	1.14	2.92	250	89	493	56	246	5.0
5	590.200	1.30	1.14	2.92	250	88	496	55	245	5.0
6	595.850	1.10	1.05	2.50	245	91	489	56	245	5.0
2/1	600.000	1.30	1.14	2.92	240	88	494	57	233	5.0
2	605.300	1.50	1.22	3.30	247	91	494	56	243	5.0
3	609.900	1.50	1.22	3.30	248	90	510	57	244	5.0
4	615.160	1.10	1.05	2.50	249	93	486	62	244	5.0
5	619.700	1.40	1.18	3.10	248	93	533	62	245	5.0
6	625.700	1.00	1.00	2.25	245	93	486	62	242	5.0
	628.755									

DGM READING Vm: 57.900
 AVG DELTA P: 1.33
 AVG DELTA H: 2.95
 AVG SQT DELTA P: 1.15
 AVG DGM TEMP: 89
 AVG STACK TEMP: 496

BEST AVAILABLE COPY

OWNER
Georgia Pacific
OPERATOR
TransportREPORT DATE
04/14/01-01
PAGE
1-25-90

DATE Thu DAY/NIGHT 015C END TIME 1100
 SAMPLING SITE 101st & 1st CONTROL DEVICE NONE
 SAMPLING TYPE FF-5-6 SAMPLE CONSOLE # 4 SAMPLE CUP
 AMBIENT TEMP 70 WEATHER RAZE/FOG WIND SPEED/DIRECTION E 5-10
 WESTON TEST PERSONNEL RJ, SS OBSERVERS _____

SKETCH OF STACK
 Stack Dimensions 38" Orifice ΔH 1.843
 Sample Time (min/pt) 5.0 Meter Corr. Factor 1.013
 Net Sample Time (min) 60 Pitot Tube # 8' #1
 Baro Press. (in Hg) 29.99 Pitot Factor 0.84
 Stack Press. (in Hg) 29.98 Nozzle ID # 0.247
 Stack Temp DB/WB (°F) 265 Noz Dia Pretest (in) 0.247
 Assumed Mois (%) 5% Noz Dia Posttest (in) 0.247
 Pretest Leak Check 6.01@15' Hg Avg Noz Dia (in) 0.247
 Posttest Leak Check 6.01@15' Hg Filter Type/Number 700513
 Final Gas Meter Reading 628.755 Silica gel # 21
 Initial Gas Meter Reading 570.855 Δ Condensate (mL) 81.8
 Δ Meter Reading 57.900

Orsat Method of Collection TAS / Integrated Sampling

	RUN 1	RUN 2	RUN 3	AVG
%CO ₂	1.0	1.0	1.0	1.0
%O ₂	18.7	18.7	18.7	18.7
% CO	—	—	—	—

Page 1 of 1

BEST AVAILABLE COPY

CLIENT Georgia Pacific

WORK ORDER NO. 0418-0^c-4

STRUCTURE Tracheata

DATE 1-25-90

RUN #: 2

NOTES/REMARKS:

$$\Delta H = \Delta P [(893.94) (C_p)^2 (FDA)^2 (\Delta H_{\text{at}}) (Dn)^4 \left(\frac{T_m}{T_s}\right)]$$

$$\mu = 2.75$$

P A R T I C U L A T E F I E L D D A T A

Client: Georgia Pacific
 Weston Project No: 0414-09-01
 Source: NCG Incinerator
 Date: 1/25/90
 Run#: 3

PORT POINT NO.	DGM READING Vm(ft ³ /3)	DELTA P in. H2O	DELTA P SQUARE ROOT	DELTA H in. H2O	PROBE TEMP (F)	AVG DGM TEMP (F)	STACK TEMP (F)	IMP OUT (F)	HOT BOX TEMP (F)	SAMPLE TRAIN VAC (in Hg)
1/1	629.100	1.40	1.18	3.15	190	87	500	58	230	3.5
2	634.050	1.50	1.22	3.38	219	92	520	53	247	4.0
3	639.020	1.40	1.18	3.15	237	94	535	59	261	4.5
4	643.850	1.30	1.14	2.93	250	95	525	61	261	4.5
5	649.270	1.20	1.10	2.70	247	96	518	61	260	4.0
6	653.240	1.20	1.10	2.70	250	95	500	61	260	4.0
2/1	657.675	1.40	1.18	3.15	250	93	515	66	252	4.5
2	662.450	1.50	1.22	3.38	224	96	515	64	259	4.5
3	668.490	1.20	1.10	2.70	234	97	545	64	261	4.0
4	672.650	1.00	1.00	2.25	228	97	565	65	257	3.5
5	676.348	1.50	1.22	3.38	232	98	553	67	259	5.0
6	681.000	1.20	1.10	2.70	225	98	555	70	259	4.0
					685.475					

DGM READING Vm: 56.375
 AVG DELTA P: 1.32
 AVG DELTA H: 2.96
 AVG SQT DELTA P: 1.15
 AVG DGM TEMP: 95
 AVG STACK TEMP: 529

CLIENT Georgia Pacific WORK ORDER NO. 0414-01-01
 SOURCE The Woodstock DATE 1-25-90

RUN # Three START TIME 11:30 END TIME 12:30
 SAMPLING SITE Plataforma CONTROL DEVICE 10 ft
 SAMPLING TYPE H-SL SAMPLE CONSOLE # 4 SAMPLE CASE #
 AMBIENT TEMP 75 WEATHER Fog WIND SPEED/DIRECTION E-5G
 WESTON TEST PERSONNEL KOJ, SS OBSERVERS

SKETCH OF STACK
 Stack Dimensions 38" Orifice ΔH 1.843
 Sample Time (min)/ft) 5.0 Meter Corr. Factor 1.013
 Net Sample Time (min) 60 Pilot Tube # 8' #1
 Baro Press. (in Hg) 29.99 Pilot Factor 0.84
 Stack Press. (in Hg) 29.98 Nozzle ID # 0.247
 Stack Temp DB/WB (°F) 500 Noz Dia Pretest (in) 0.247
 Assumed Mois (%) 5% Noz Dia Posttest (in) 0.247
 Pretest Leak Check C.01 @ 12" Avg Noz Dia (in) 0.247
 Posttest Leak Check C.01 @ 12" Filter Type/Number 90251
 Final Gas Meter Reading 685.475 Silica gel # 3
 Initial Gas Meter Reading 629.100 Δ Condensate (mL) 93.4
 Δ Meter Reading 56.375

Orsat: Method of Collection Integrated Bag

	RUN 1	RUN 2	RUN 3	AVG
%CO ₂	1.0	1.0	1.0	1.0
%O ₂	18.5	18.5	18.5	18.5
% CO				

FIELD DATA

CLIENT Bengal Tropic WORK ORDER NO. 0414-09-01
SOURCE WCFrig 00000 DATE 1-35-80 RUN # Three

NOTES/REMARKS:

$$\Delta H = \Delta P [(893.94) (C_p)^2 (FDA)^2 (\Delta H@) (D_n)^4 \left(\frac{T_m}{T_s} \right)],$$

$$\mu = 2.25$$

Page _____ of _____

SAMPLE RECOVERY AND INTEGRITY

CLIENT Georgian PacificPROJECT NUMBER 04/4-09SOURCE IncineratorSAMPLE DATE 1-25-90SAMPLE PERSONNEL SS, 15RECOVERY DATE RECOVERY PERSONNEL SS, 15

MOISTURE DATA

Final Volume in Impingers (mL)

RUN # 1RUN # 2RUN # 3

Initial Volume in Impingers (mL)

265267278

Net Volume Increase (mL)

200200200

Silica Gel Number

656778

Final Silica Gel Wt (g)

123

Initial Silica Gel Wt (g)

236.6249.3238.7

Δ Wt (g)

219.5234.5223.3

Total Moisture (mL)

17.114.815.482.181.893.4

IMPINGER NUMBER

Run # 1 Final Wt135125545

Initial Wt

100100045

Δ Wt

3525545Run # 2 Final Wt155110245

Initial Wt

100100045

Δ Wt

5510245Run # 3 Final Wt140115345

Initial Wt

100100045

Δ Wt

6015345

SAMPLE RECOVERY

Filter Number

RUN # 1RUN # 2RUN # 3

Filter Cont. No/Wash Cont. No.

900509900513900512

Filter Container Sealed (Y/N)

123


Probe Wash Level Mark? (Y/N)

YYY

Solvent Blank Cont. No.

YYY

NOTES:



TEST TEAM LEADER

Inter-Office Memorandum



Auburn Operations

TO: Mike Steele

FROM: Bruce Ferguson *(initials)*

PROJECT: G. P. Palatka

SUBJECT: Results for Samples Submitted to Lab on 26 January 1990

DATE: 07 February 1990

W.O. NO.: 0414-09-01
0033-70-03-0010

ACTION:

RESULTS AND DISCUSSION

Attached are the results for samples submitted to the laboratory on 26 January 1990 for particulate analysis. The following table summarizes the results.

<u>Sample ID</u>	<u>Net Particulate Wt. (grams)</u>
Run 1	0.0840
Run 2	0.1737
Run 3	0.0586
Blank Wash	0.0012
Blank Filter	0.0004

Final filter weight for the samples was obtained by taking the average of nine weights. This was due to the inconsistency of the weights possibly caused by salts on the filters.

ANALYTICAL METHODOLOGY

The analysis was performed following EPA Method 5. Acetone was used to rinse the sample bottles.

QUALITY ASSURANCE AND QUALITY CONTROL

All glassware was thoroughly cleaned before use. The blank wash and blank filter were analyzed at the same time and under the same conditions as the samples. The analytical balance used was calibrated prior to use and an NBS Class S 100 gram weight was weighed and recorded after every tenth weighing. Tongs were used while handling the beakers.

sr

METHOD 5

LABORATORY DATA

CLIENT G. P. Palatka

WESTON W.O. # 0414-09-01

Condition of Sample on Arrival? GOOD

GOOD GOOD GOOD

Liquid Levels Marked? (Y/N) Y

Y Y Y Y

Filter Container Sealed? (Y/N) Y

Y Y Y Y

WESTON Laboratory Number CD447

CD448 CD449 CD450

Laboratory Personnel Taking Custody Belinda Castee & Ken Dixon

Date Received in Laboratory 26 January 1990

SAMPLE IDENTIFICATION	Initial Wt. #1 Initial Wt. #2 Initial Wt. #3 Initial Wt. #4 Avg. Initial Wt.	Final Wt. (L) #1 Final Wt. (L) #2 Final Wt. (L) #3 Final Wt. (L) #4 Avg. Final Wt. (L)	Final Wt. (F) #1 Final Wt. (F) #2 Final Wt. (F) #3 Final Wt. (F) #4 Avg. Final Wt. (F)	Δ Final (L) & Initial Wts. - Liquid Blank - Liquid Particulate Wt.	Δ Final (F) & Final (L) Wts. - Filter Weight - Filter Blank - Filter Particulate Wt. - Net Particulate Wt.
Laboratory # <u>CD447</u>	<u>98.3878</u>	<u>98.4164</u>			<u>0.0290</u> <u>0.4956</u>
Beaker # <u>1'</u>	<u>98.3874</u>	<u>98.4168</u>			<u>0.0008</u> <u>0.4394</u>
Liquid Volume <u>97ml</u>					<u>0.0004</u>
Field Run # <u>1</u>					<u>0.0282</u> <u>0.0558</u>
Filter # <u>900509</u>	<u>98.3876</u>	<u>98.4166</u>	<u>98.9122</u>		<u>0.0840</u>
Laboratory # <u>CD448</u>	<u>101.8173</u>	<u>101.8682</u>			<u>0.0509</u> <u>0.5636</u>
Beaker # <u>2'</u>	<u>101.8169</u>	<u>101.8677</u>			<u>0.0012</u> <u>0.4392</u>
Liquid Volume <u>155ml</u>					<u>0.0004</u>
Field Run # <u>2</u>					<u>0.0497</u> <u>0.1240</u>
Filter # <u>900513</u>	<u>101.8171</u>	<u>101.8680</u>	<u>102.4316</u>		<u>0.1737</u>
Laboratory # <u>CD449</u>	<u>98.3337</u>	<u>98.3580</u>			<u>0.0242</u> <u>0.4770</u>
Beaker # <u>3'</u>	<u>98.3335</u>	<u>98.3575</u>			<u>0.0006</u> <u>0.4416</u>
Liquid Volume <u>81ml</u>					<u>0.0004</u>
Field Run # <u>3</u>					<u>0.0236</u> <u>0.0350</u>
Filter # <u>900512</u>	<u>98.3336</u>	<u>98.3578</u>	<u>98.8348</u>		<u>0.0586</u>
Laboratory # <u>CD450</u>	<u>107.8823</u>	<u>107.8836</u>	<u>108.3215</u>	<u>0.0012</u>	<u>0.4380</u>
Beaker # <u>7912</u>	<u>107.8828</u>	<u>107.8841</u>	<u>108.3220</u>		<u>0.4376</u>
Liquid Volume <u>151ml</u>					
Field Run # <u>Blank (Acetone)</u>					
Filter # <u>900514</u>	<u>107.8826</u>	<u>107.8838</u>	<u>108.3218</u>	<u>0.0012</u>	<u>0.0004</u>

Note: (L) = Addition of Liquid to Avg. Initial Wt.

(F) = Addition of Filter to Avg. Final Wt. (L)

All Weights are Recorded in Grams

Analyst/Date Belinda Castee 1/2/90 Laboratory Supervisor/Date (Signature)

Page 1 of 1

CHAIN-OF-CUSTODY FORM

CLIENT Hearns Pacific PROJECT NO. 041409-01
FACILITY Paper mill DATE 1-25-90
DESCRIPTION OF SAMPLES Methanol 5
NAME OF INDIVIDUAL COLLECTING SAMPLES Scott Slacum

	<u>RECEIVED BY</u>	<u>RECEIVED FROM</u>	<u>DATE</u>	<u>TIME</u>	<u>NO. SAMPLES</u>
1.	Kendall Dijon S. Slocum		1/26/90	5:00 pm	54
2.					
3.					
4.					



**APPENDIX D. NCG INCINERATOR - SULFUR DIOXIDE AND VISIBLE EMISSION
FIELD DATA**

SULFUR DIOXIDE FIELD DATA

Client: Georgia Pacific
 Weston Project No.: 0414-09-01
 Source: NCG Incinerator
 Date: 1/25/90

MCF: 1.052

	RUN 1	RUN 2	RUN 3
Sampling Time Start:	0830	0910	0945
Sampling Time End:	0900	0940	1015
<u>Net Sample Time (Min):</u>	30	30	30
Pre-Test Leak Check:	OK	OK	OK
Post-Test Leak Check:	OK	OK	DK
Final Gas Meter Reading (cf):	52.15	50.20	50.05
Init. Gas Meter Reading (cf):	.00	.00	.00
Delta Meter Reading (cf):	52.15	50.20	50.05
Dry Gas Meter Temp 1:	80	82	82
Dry Gas Meter Temp 2:	81	82	82
Dry Gas Meter Temp 3:	81	82	82
Dry Gas Meter Temp 4:	82	82	82
<u>Average Dry Gas Meter Temp:</u>	81	82	82
Barometric Pressure (in. Hg.):	29.99	29.99	29.99
Stack Pressure (in. Hg.):	—	—	—
<u>Stack Temp (F):</u>	500	500	500
Delta Condensate (g) Imp 1:	—	—	—
Imp 2:	—	—	—
Imp 3:	—	—	—
Imp 4:	—	—	—
Initial Silica Gel Weight:	—	—	—
Final Silica Gel Weight:	—	—	—
Silica Gel Delta Weight (g):	—	—	—
<u>Total Moisture Volume (mL)</u>	N/A	N/A	N/A
CO2 Concentration (%):			
SO2 Concentration (%):			
CO Concentration (%):	N/A	N/A	N/A

SULFUR DIOXIDE LAB DATA

Client: Georgia Pacific
 Weston Project No: 0414-09-01
 Source: NCG Incinerator
 Date: 1/25/90
 Analyst: Cecchi/Slocum

	RUN 1A	RUN 1B	RUN 2A	RUN 2B	RUN 3A	RUN 3B	MEAN
Vm standard (DL)	53.6	53.6	51.5	51.5	51.4	51.4	52.2
V solution	100.0	100.0	100.0	100.0	100.0	100.0	100.0
Va	2.0	2.0	2.0	2.0	2.0	2.0	2.0
Vt	21.4	21.2	19.8	19.8	16.2	16.1	19.1
Vtb	.0	.0	.0	.0	.0	.0	.0
Normality of Titrant	.0101	.0101	.0101	.0101	.0101	.0101	.0101
Concentration SO ₂ ppm	2409	2387	2320	2320	1904	1892	2206
Concentration SO ₂ lb/DSCF	4.00E-4	3.96E-4	3.85E-4	3.85E-4	3.16E-4	3.14E-4	3.66E-4
Vol. Flow at Std. Cond. (ft ³ /min)							
Mass Emission SO ₂ lb/hr							

NORMALITY CALCULATION

	RUN 1	RUN 2	MEAN
Acid Volume (ml)	5.0	5.0	5.0
Acid Normality (N)	.020	.020	.020
BaCl ₂ Volume (ml)	9.9	10.0	10.0
BaCl ₂ Normality:			.0101

6.4

04/14/09-01

INC.

1-25-80

3

1.052

1 2 3

Sampling Time Start	8:30	9:10	9:45
Sampling Time End	9:00	9:40	10:15
Net Sample Time (Min)	30	35	30
Pre-test Leak Check	OK	OK	OK
Post-Test Leak Check	OK	OK	OK
Final Gas Meter Reading (L)	52.150	50.200	50.050
Initial Gas Meter Reading (L)	0.00	0.00	6.00
M Meter Reading (L)	52.150	50.200	50.150
Dry Gas Meter Temp 1	80	82	82
2	81	/	/
3	81	/	/
4	82	/	/
Avg	81	82	82
Barometric Pressure (in. Hg.)	29.99	29.99	29.99
Stack Pressure (in. Hg.)			
Stack Temp (°F)	500	500	500
Condensate (g) Imp 1			
Imp 2			
Imp 3			
Imp 4			
Silica Gel & Weight (g)			
Total Moisture Volume (mL)			
CO ₂ Concentration (%)			
O ₂ Concentration (%)			
CO Concentration (%)			

NOTES:

Page ____ of ____

TMR-22-1/35

WESTON
DURACONTRONICS

BEST AVAILABLE COPY

CLIENT #1

WORK ORDER NO.

0414-09-01

CONC RT ID#2

LC

DATE 1/25

	V _m (std)	V _t	V _a	V _{soln}	V _b	Normality of BaCl ₂
V _m (std)	53.65	51.55	51.39			liters
V _t	100	100	100			mL
V _a	2	2	2			mL
V _b /V _t	21.4/21.2	19.8/19.8	18.2/16.1			mL
N _{std} /V _b	0	0	0			mL
Normality of BaCl ₂	.0101					normal
C _{SO₂}	2429	2330/2330	1910/1900			ppm
C _{SO₂}	2400					

$$C_{SO_2} = \frac{1.202 \times 10^4 (V_t - V_b) N}{V_m (\text{std})}$$

C_{SO₂} = Concentration SO₂ (ppm)V_t = Volume BaCl₂ used to titrate sample (mL)V_b = Volume BaCl₂ used to titrate blank (mL)V_{soln} = Total Volume of solution (mL)V_a = Volume of solution titrated (mL)N = Normality of BaCl₂V_m (std) = Standard dry gas volume used to collect sample

$$17.64 \times V_m \times \text{mcf} \times \frac{B_p}{T_m}$$

$$C_{SO_2} (\text{lb/DSCF}) = C_{SO_2} (\text{ppm}) \times 1.66 \times 10^{-7}$$

Calculate normality by the equation:

$$\text{volume std acid} \times \text{normality std acid} = \text{normality of BaCl}_2 \times \text{volume BaCl}_2$$

$$V_{acid_1} = \text{_____} \quad N_{acid_1} = \text{_____} \quad \text{mL} \quad \text{BaCl}_2_1 = \text{_____}$$

$$V_{acid_2} = \text{_____} \quad N_{acid_2} = \text{_____} \quad \text{mL} \quad \text{BaCl}_2_2 = \text{_____}$$

CLIENT Georgia Pacific

WORK ORDER NO.

PROJECT IncineratorTEST T.G.DATE 1-24-90

	TEST	RUN 1	RUN 2	MEAN	QUALITY CATEGORY	UNITS
V _t /V _{tb}				21×10^{-3} 18.4		liter
V _t				100		mL
V _t /V _{b2}				10.0		mL
V _t /V _{b2}				5.9/5.9		mL
V _t /V _{b2}				0.0/0.0		mL
Normality of Titrant	01.005	01.005	01.005	01.005	01.005	normal
C _{SO₂}				904.4 / 904		ppm
C _{SO₂}						

$$C_{SO_2} = \frac{1.202 \times 10^4 (V_t - V_{tb}) N \left(\frac{V_{soln}}{V_a} \right)}{V_m (\text{std})}$$

$$\frac{904}{899.9} = 1.004$$

100.4 % acc.

LOT 0584 7XXY

C_{SO₂} = Concentration SO₂ (ppm)V_t = Volume BaCL₂ used to titrate sample (mL)V_{tb} = Volume BaCL₂ used to titrate blank (mL)V_{soln} = Total Volume of solution (mL)V_a = Volume of solution titrated (mL)N = Normality of BaCL₂V_m (std) = Standard dry gas volume used to collect sample

$$17.64 \times V_m \times \text{mcf} \times \frac{B_p}{T_m}$$

$$C_{SO_2} (\text{lb/DSCF}) = C_{SO_2} (\text{ppm}) \times 1.66 \times 10^{-7}$$

Calculate normality by the equation:

volume std acid x normality std acid = normality of BaCL₂ x volume BaCL₂

$$V_{acid1} = 5.0 \quad N_{acid1} = 0.02 \quad \text{mL BaCL}_2 = 9.9$$

$$V_{acid2} = 5.0 \quad N_{acid2} = 0.02 \quad \text{mL BaCL}_2 = 10.0$$

Informed simultaneously with FPA - Method 15, Particulate and Visible Emission Observation

SOURCE NAME <i>Okeechobee - Pacific Corp.</i>	OBSERVATION DATE 1-25-90	START TIME 8:00 AM	STOP TIME 9:30 AM
ADDRESS POB 919	SEC MIN 0 15 30 45	SEC MIN 0 15 30 45	
SR 216	1 0 0 0 0 31	0 0 0 0 0 0	
CITY Palatka STATE FL ZIP 32178	2 0 0 0 0 32	0 0 0 0 0 0	
PHONE 904/325-2001	3 0 0 0 2 33	0 0 0 0 0 0	
PROCESS EQUIPMENT Batch Distiller, MEE, Crankcase Stripper System	4 0 0 0 2 34	0 0 0 0 0 0	
CONTROL EQUIPMENT NCG Incinerator	5 0 0 0 0 35	0 0 0 0 0 0	
DESCRIBE EMISSION POINT round stack	6 0 0 0 0 36	0 0 0 0 0 0	
START Same	7 0 0 0 0 37	0 0 0 0 0 0	
HEIGHT ABOVE GROUND LEVEL START 250' STOP 250'	8 0 0 0 0 38	0 0 0 0 0 0	
DISTANCE FROM OBSERVER START 300 ft STOP 300 ft	9 0 0 0 0 39	0 0 0 0 0 0	
DESCRIBE EMISSIONS START more STOP more	10 0 0 0 0 40	0 0 0 0 0 0	
EMISSION COLOR START grey STOP	11 0 0 0 0 41	0 0 0 0 0 0	
WATER DROPLETS PRESENT: NO <input checked="" type="checkbox"/> YES <input type="checkbox"/>	12 0 0 0 0 42	0 0 0 0 0 0	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START stack outlet STOP same	13 0 0 0 0 43	0 0 0 0 0 0	
DESCRIBE BACKGROUND START cloudy STOP cloudy overcast	14 0 0 0 0 44	0 0 0 0 0 0	
BACKGROUND COLOR START GREY STOP GREY	15 0 0 0 0 45	0 0 0 0 0 0	
WIND SPEED START 2 MPH STOP 2 MPH	16 0 0 0 0 46	0 0 0 0 0 0	
AMBIENT TEMP. START 70°F STOP 70°F	17 0 0 0 0 47	0 0 0 0 0 0	
WET BULB TEMP. — RH percent —	18 0 0 0 0 48	0 0 0 0 0 0	
Source Layout Sketch	Draw North Arrow		
AVERAGE OPACITY FOR HIGHEST PERIOD 0 % NUMBER OF READINGS ABOVE 5 % WERE 0			
RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0			
OBSERVER'S NAME (PRINT) MARVIN SIMMONS			
COMMENTS	Summary of Aver. Opacity	OBSERVER'S SIGNATURE <i>M. Simmons</i>	DATE 1/25/90
	Set Number	Opacity	
		Sum	Average
	1	0	0 (0)
	2	0	0 (0)
	3	0	0 (0)
	4	0	0 (0)
	5	0	0 (0)
	6	0	0 (0)
	7	0	0 (0)
	8	0	0 (0)
	9	0	0 (0)
	10	0	0 (0)
	Avg.	0	0



APPENDIX E. NCG INCINERATOR - PROCESS DATA

DATE - JAN 23 1990

NATURAL GAS

B-3465

JAN 25 1990

No. 3

TIME	Liq. % Solids Cenco	Liq. to Noz. PSI	No. Liq. Noz. in Service	S.B. Oil PSI	No. of S.B. in Service	L.B. Oil PSI	No. of L.B. in Service	Feed-water PSI	Drum PSI	Green Liquor Titration	Green Liquor Sulfid-ity	No. 1 Spout Water GPM	No. 2 Spout Water GPM	No. 3 Spout Water GPM	No. 4 Spout Water GPM	No. 5 Spout Water GPM	No. 6 Spout Water GPM	Spout Cocli Water Temp.
7:00 A.M.		18	10	75	0	41	0	1630	1360	-		18	18	18	18	18	23	124
8:00 A.M.		17 ¹ / ₂	10	75	0	41	0	1660	1380	102								
9:00 A.M.		17 ¹ / ₂	10	75	0	41	0	1660	1360	102		18	18	18	18	18	23	122
10:00 A.M.		17 ¹ / ₂	10	75	0	41	0	1700	1360	101								
11:00 A.M.		17 ¹ / ₂	10	75	0	41	0	1710	1370	97		18	18	18	18	18	23	122
12:00 Noon		17 ¹ / ₂	10	75	0	41	0	1580	1360	99								
1:00 P.M.		17	10	75	0	41	0	1700	1350	101		18	18	18	18	18	23	128
2:00 P.M.		17	10	75	0	41	0	1700	1370	98								
3:00 P.M.		17	10	75	0	41	0	1700	1360	98		18	18	18	18	18	23	168
4:00 P.M.		17	10	75	0	40	0	1700	1360	100								
5:00 P.M.		17	10	75	0	40	0	1700	1360	100		18	18	18	18	18	23	168
6:00 P.M.		17	10	75	0	40	0	1700	1360	100								
7:00 P.M.		17	10	75	0	40	0	1700	1360	100		18	18	18	18	18	23	168
8:00 P.M.		17	10	75	0	40	0	1700	1360	100								
9:00 P.M.																		
10:00 P.M.																		
11:00 P.M.																		
12:00 Mid.																		
1:00 A.M.																		
2:00 A.M.																		
3:00 A.M.																		
4:00 A.M.																		
5:00 A.M.																		
6:00 A.M.																		
Operators: 7-3			Sig.					Walton				Sig.					Sig.	

01

02

Best Available Copy

NO. 2

JAN 25 1980

TIME	S.C. Mix Tank Level	F.D. Fan Discharge Press.	Primary Duct Press.	Primary Belt Press.	Sec. Duct Press.	Sec. Belt Press.	Super heater Differ- ential	Furnace Draft	Boiler Inlet Differ- ential	Econ. Outlet Differ- ential	Econ. Inlet Differ- ential	Prec. Inlet Draft	Prec. Outlet Draft	Stack Press.	Prim. Air Flow	Sec. Air Flow	Total Air Flow	Flue Gas Combust. X	Flue Gas Oxygen %	T.R.S. PPM	SO ₂ PPM	I.D. Fao Speed		
2:00 A.M.	15.5	12.5	9.0	3.0	8.5	8.5	.16	-4	.50	.25	.10	2.2	3.5	5.5	13.5	3.8	21	90	26	176	418	16.7	450	
8:00 A.M.	15.5	13.0	4.5	3.5	8.5	8.5	.22	-3	.40	.55	.11	2.2	4.0	5.5	12.5	37	19	90	28	205	411	6.6	460	
9:00 A.M.	15.5	13.0	4.0	3.0	8.5	8.5	.46	-2	.40	1.70	.17	2.4	4.0	6.0	13.5	38	18	89	30	213	3.2	2.6	460	
10:00 A.M.	15.5	13.0	3.5	2.5	8.5	8.5	.40	-4	.40	.50	.11	2.0	4.0	6.0	13.0	39	16	90	30	211	3.7	815	470	
11:00 A.M.	15.5	13.0	3.5	3.5	8.5	8.5	.46	-2	.20	.50	.11	2.3	4.0	6.5	14.0	38	21	91	30	210	315	13.1	460	
12:00 Noon	15.5	13.0	4.5	3.5	8.5	8.5	.22	-3	.50	.40	.10	2.2	3.5	6.0	14.0	37	21	91	30	1.90	3.0	3.9	460	
1:00 P.M.	15.5	13.0	4.0	3.0	8.5	8.5	.22	-1	.35	.45	.11	2.3	4.0	6.5	14.5	37	21	92	30	1155	5.8	-13	465	
2:00 P.M.	15.5	13.0	4.0	3.0	8.5	8.5	.00	-7	.50	.25	.12	2.3	4.0	6.5	15.0	37	21	92	32	2140	7519	239	475	
3:00 P.M.	15.5	13.0	4.0	3.0	8.5	8.5	.2	-8	.25	.25	.10	8.3	3.5	6.5	11	36	11	88	310	259	164	-2	160	
4:00 P.M.	15.5	12.5	4.5	3.5	8.5	8.5	.1	-1	.50	.10	.9	2.1	4.0	6.0	14.1	36	16	88	22	257	5414	450		
5:00 P.M.	15.5	12.5	4.0	3.5	8.5	8.5	.2	-2	.45	.0	.10	2.2	4.0	6.0	15	36	16	88	32	152	114	27.8	460	
6:00 P.M.	15.5	12.5	4.0	3.5	8.5	8.5	.11	-2	.02	.18	.50	1.2	2.3	4.0	6.0	15	36	6	88	32	158	5.4	32.2	460
7:00 P.M.	15.5	12.5	4.5	4.0	8.5	8.5	.11	-2	.50	.50	.11	2.3	4.0	6.0	15	36	16	88	32	186	211	7.1	1150	
8:00 P.M.	15.5	12.5	4.5	4.0	8.5	8.5	.4	-1	.01	.48	.50	.11	2.3	4.0	6.0	15	36	16	88	32	200	24	118	450
9:00 P.M.																								
10:00 P.M.																								
11:00 P.M.																								
12:00 M																								
1:00 A.M.																								
2:00 A.M.																								
3:00 A.M.																								
4:00 A.M.																								
5:00 A.M.																								
6:00 A.M.																								
Operator: 7-1	Scorby	Sig.	Operator: 3-11	M. Elton	Sig.	Operator: 11-7	Sig.																	
Remarks:			Remarks:																					

C1

O

C2

Best Available Copy

JAN 25 1990

101

NO. 1

TIME	Green Liquor Density	Diss. Tank Level	Drum Level	Feed- water Flow	Feed- water Temp.	Steam Flow N lb/hr	Primary Steam Temp.	Inter. Steam Temp.	Final Steam Temp.	% Solids to Moa.	S.C. Mix Tk.	Final Liquid Temp.	Inlet Air Temp.	Heated Air Temp.	Boiler Outlet Temp.	Econ. Temp.	I.D. Inlet Temp.	I.D. Drive Oil Temp.	Liq. to Nozzles G.P.M.	S.C. Screw Feeder Speed	S.E. Oil Flow	L.S. Oil Flow	
7:00 A.M.	116.0	603	+3	712	272	610	725	605	810	1315	232	254.2	103	349	-	464	374	135	384	0	0	0	
8:00 A.M.	116.9	592	+2	80	278	620	700	610	870	1340	660	232	251.6	103	349	-	410	374	135	384	0	0	0
9:00 A.M.	116.5	55	0	87	275	600	700	610	840	1340	232	251.8	105	349	-	411	373	135	384	0	0	0	
10:00 A.M.	115.3	55	0	82	275	590	720	620	870	1340	650	232	251.5	106	350	-	419	377	135	383	0	0	0
11:00 A.M.	116.0	53	0	80	275	585	740	600	880	1330	231	251.8	107	349	-	407	374	135	383	0	0	0	
12:00 Noon	116.3	55	-4	100	275	620	730	600	870	1315	231	254.8	108	350	-	411	374	135	382	0	0	0	
1:00 P.M.	116.3	55	+1	80	272	610	730	600	870	1310	231	254.5	112	350	-	409	372	135	384	0	0	0	
2:00 P.M.	116.2	56	0	80	276	580	780	610	860	1335	231	252.2	111	350	-	419	376	136	384	0	0	0	
3:00 P.M.	115.6	55	-0	88	280	600	730	600	860	1330	231	251	113	351	415	374	135	385	0	0	0		
4:00 P.M.	115.6	55	+0	88	280	620	700	600	850	1320	660	231	252	115	351	418	372	135	383	0	0	0	
5:00 P.M.	116.3	55	-0	86	280	600	780	600	850	1320	231	252	116	351	415	372	135	385	0	0	0		
6:00 P.M.	116.1	55	-0	80	280	600	760	600	860	1340	65.8	231	252	116	350	417	375	135	385	0	0	0	
7:00 P.M.	115.8	55	-0	86	280	620	720	600	880	1300	231	252	112	352	416	375	135	385	0	0	0		
8:00 P.M.	116.0	55	-0	88	280	620	700	600	870	1300	231	252	111	351	417	375	135	386	0	0	0		
9:00 P.M.																							
10:00 P.M.																							
11:00 P.M.																							
12:00 M																							
1:00 A.M.																							
2:00 A.M.																							
3:00 A.M.																							
4:00 A.M.																							
5:00 A.M.																							
6:00 A.M.																							

Operator: 7-3 Sevory

Sig.

Operator: 3-11 Walton

Sig.

Operator: 11-7

Sig.

Remarks:

Remarks:

Remarks:

CT

O

HP

Best Available Copy

JAN 25 1990

TIME	Drop. Steam Frcns.	Drop. Vacuum lb/hr	Cand. Cond.	Surface Temp.	Inter-Cond. Temp.	Vad From Boilout Tank GPM	Wk. Liq. Stg. Tank Level	Wk. Lq. Fed to Evap G.P.M.	Evap. Fnd. Liq. Solids	Evap. Shmmer Level	Drop. Prdt. Flow GPM	Drop. Prdt. Solids	Drop. Prdt. "Bo.	Temp. 50% Food Liq.	Temp. 34% Food Liq. to Storage	Cand. Steam Frcns.	Cand. Steam Frcns. 1b/hr	Vad Liq. to Cand. Solids	Liq. Solids To #2 Conc.	Cand. Prdt. Liq. Solids	SOL. Liq. Stg.% Level	Min Frcn. Level	Hgt. Sig. Tank Level	
7:00 A.M.	44	3000	24	93	84	75	25.0	730	10.1	70%	210	50.0	285	150	220	53	5400	610	50.0	-	61.5	19.0	22.5	28.0
8:00 A.M.	44	2600	24	94	83	75	25.0	730	10.2	70%	200	49.5	284	153	220	53	5700	610	50.0	-	61.5	18.0	23.0	28.2
9:00 A.M.	44	2800	24	96	84	75	25.0	730	10.2	70%	210	50.0	283	150	220	53	5400	610	50.0	-	61.5	17.0	22.0	28.5
10:00 A.M.	44	2800	24	96	86	75	25'	730	10.2	70%	210	49.5	284	150	220	53	5200	610	50.0	-	61.0	16.0	22.0	28.8
11:00 A.M.	44	2800	24	96	84	75	25'	730	10.1	70%	210	50.0	284	150	220	53	5600	610	50.0	-	61.0	14.0	21.0	29.0
12:00 P.M.	44	2800	24	96	88	75	25'	730	10.2	70%	200	50.0	284	150	220	53	5700	610	50.0	-	61.0	14.0	21.0	29.2
1:00 P.M.	44	3000	24	97	90	75	25'	730	10.2	70%	200	50.0	284	150	220	53	5400	610	50.0	-	61.0	14.0	21.0	29.7
2:00 P.M.	44	2800	24	96	90	75	25'	730	10.3	70%	190	51.5	283	152	220	53	5400	610	50.0	-	61.0	13.0	21.0	30.0
3:00 P.M.	HH	2800	24	96	90	75	25	230	10.3	70	010	50	294	154	218	53	5400	610	50.0	61	13.0	20.0	30.0	
4:00 P.M.	HH	2800	24	96	90	75	25	730	10.3	70	190	50	290	154	218	53	5500	610	50.0	61	13	20	30.0	
5:00 P.M.	HH	2800	24	96	90	75	25	730	10.3	70	210	50	290	154	218	53	5500	610	50.0	61	13	20	30.0	
6:00 P.M.	HH	2800	24	96	90	75	25	730	10.0	70	100	51	292	151	218	53	5500	610	50.0	61	13	20	30.0	
7:00 P.M.	HH	2800	24	96	88	75	25	730	10.0	70	110	51	290	154	218	53	5500	610	50.0	61	13	20	31	
8:00 P.M.	HH	2800	24	91	88	25	25	730	10.0	70	210	51	294	154	218	53	6600	610	50.0	61	13	20	32	
9:00 P.M.																								
10:00 P.M.																								
11:00 P.M.																								
12:00 M.D.																								
1:00 A.M.																								
2:00 A.M.																								
3:00 A.M.																								
4:00 A.M.																								
5:00 A.M.																								
6:00 A.M.																								

Operator: 7-3 Security

Sign.

Operator: 3 - 11 M. Wilson

Sign.

Operator: 11-7

Sign

Remarks:
 37.9.220 37.8.220
 37.8.220 37.0.220
 37.0.220 37.8.220
 37.8.220 37.8.220
 37.8.220 37.8.220

3-38.0
 4-37.8
 5-37.8
 6-37.8
 7-37.9
 8-37.9
 9-
 10-

37.8°F @ 220°F = 61.75 gal @ 11.1# / gal

$$\frac{610 \text{ gal}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times .50\% \text{ solids} \times \frac{10.4 \text{ #}}{\text{gal}} = 190,320 \text{ lb dry bus/hr}$$

May allowable
259,121

CR
CP

Best Available Copy

digester room report - cost center no. 5

COOK NO.	DMS. NO.	TESTS			POUNDS ACTIVE ALKALI	DIGESTER CHARGE - GAL.	CHIP SILO NO.	TONS OF CHIPS IN	CHIPS IN	STEAM IN	FULL PRESS.	MAX. TEMP.	MIN. HELD	START SLOW	OPERATOR - SHIFT NO. 1			OPERATOR - SHIFT NO. 2			OPERATOR - SHIFT NO. 3			DATE - DAY OF WEEK - MONTH - DATE	
		A	B	C											81	82	83	84	85	86	87	88	89		
		81	82	83	84	85	86	87	88	89	8A	8B	8C	8D	8E	8F	8G	8H	8I	8J	8K	8L	8M	8N	8O
2563-1	790				8770		11	-	525		350		700		1										
69 9	790				1380		11	517	515		35		735		2										
2565-12	790				5934		9	448	610		705		700												3
2561-4	790	910	264		8770		10	473	610		350		730		1										
64 7	790				8720		10	422	625		350		810		1										
67 13	790				9314		8	411	640		367		810												3
68 3	790				1380		11	500	630		368		820		2										
69 10	79				7431		9	450	710		365		840												3
70 6	79				2970		10	512	711		361		711		1										
71 5	78				1130		11	-	720		366		900		2										
72 1	79				9740		10	-	800		352		920		1										
73 9	79				11959		8	-	805		355		980												3
(2562-9)	79				11503		8	1000	780		350		920		3	1	1	1	1	1	1	1	1	1	
74 8	77687258				12260		11	-	820		360		920												
75 12	76				9833		9	-	820		351		1000												3
76 2	76				9410		10	-	830		361		1028		1										
77 13	76				10061		8	-	830		351		1028												3
78 4	79				11860		11	561	905		367		1038												
79 10	76				9918		9	503	920		361		110												2
80 7	76				11200		10	-	925		365		1030		2										
81 3	7790-330				11200		11	57.9	950		365		1120		2										
82 6	77				9220		10	-	1010		363		1130		1										
83 9	77				12098		9	-	1020		363		1130												3
84 5	77				9240		11	-	1040		363		1210		1										
2585-12	77				9918		9	-	1050		363		1220												3
REMARKS - NO. 1 SHIFT		REMARKS - NO. 2 SHIFT		REMARKS - NO. 3 SHIFT																					

F-3735 (3-17-83)

1 2 3
2 8 5

digester room report - cost center no. 5

COOK NO.	DIG. NO.	TESTS			POUNDS ACTIVE ALKALI	DIGESTER CHARGE GALS.			CHIP BILD NO.	TONS OF CHIPS	STATISTICS						REMARKS:	
		A	B	C		WHITE LIQUOR	BLACK LIQUOR	TOTAL LIQUOR			CHIPS IN	STEAM IN	FULL PRESS.	MAR. TEMP.	MIN. HELD	START BLOW	BLOW #1	BLOW #2
2611	5	.77				9020			10	537	500	354	630	1				
2	11	.77				9700			9	669	505	349	645				3	3
3	2	774	.77	88	350	9020			11	550	525	350	655	.1				
4	8	.77				9329			7	684	500	352	740	1				
5	1	.77				11700			10	559	600	354	710	1				
6	9	.77				11828			8	713	600	350	730				3	
7	4	.77				11710			11	-	405	356	740	2				
8	12	.77				9700			9	666	405	354	735				3	
9	7	.77				11700			10	-	645					2		
2620	13	.77				9700			9	-	645					3		
1	3	.77				9020			11	527	650							
2	10	.77				9595			7	-	615					2		
3	5	70	.77	88	250	9020			10	526	740					1		
4	11	.77				9700			9	684	720					3		
5	6	.77				9220			11	-	725					1		
6	2	.77				9020			10	528	755					1		
7	9	.77						8								3		
8	1	.77						11								1		
9																		
2630	1																	
2																		
3																		
4																		
5																		
REMARKS - NO. 1 SHIFT		REMARKS - NO. 2 SHIFT			REMARKS - NO. 3 SHIFT													

F-3735 (3-17-83)

digester room report - cost center no. 5

CODE NO.	DIB. NO.	TESTS			POUNDS ACTIVE ALKALI	DIGESTER CHARGE - GALS.	CHIP SILO NO.	TONS OF CHIPS	OPERATOR - SHIFT NO. 1			OPERATOR - SHIFT NO. 2			OPERATOR - SHIFT NO. 3			DAY OF WEEK - MONTH - DATE	
		A	B	C					X SULF- PHI- DIY	WHITE LIQUOR	BLACK LIQUOR	TOTAL LIQUOR	CHIP SILO NO.	TONS OF CHIPS	CHIPS IN	STEAM IN	FULL PRESS.	MAX. TEMP.	MIN. HELD
																			REMARKS:
25861	77				1700			10	54.1	11/0		225		105		2			
878	77	90	27.9		9329			7	-	11/13		212		105		1			
882	77				1700			11	-	11/05		227		105		2			
8913	77				9100			8	-	11/80		200		110		3			
904	77				9010			10	-	10/22		216		150		1			
9110	77				9200			9	494	1020		223		155		3			
927	77				11700			11	-	1220		251		200		2			
939	77				10728			8	-	1210		255		230		3			
9512	77				1700			9	630	1000		354		314		3			
966	77	90	28.9		11960			11	-	11/10		358		235		2		Examiner didn't print Chips, and RY 544	
975	77				11700			10	576	125		360		310		2			
983	77				9020			10	523	120		?		7		1		15/05 long time on 7-3 SAH but didn't print	
9813	77				1700			9	664	150		353		350		3			
992	77				9330			11	533	225		351		350		1			
260010	77				9595			7	41.1	235		354		325		2			
012	77				1700			10	-	245		353		420		2			
021	77				1700			11	592	305		356		440		2		402	
039	77				11627			8	76.9	312		352		510		3		on hold 345 to 405 B	
044	77	77	27.0		9020			10	547	322		353		500		1			
0512	77	-			9700			9	672	412		351		540		3			
067	77				1700			11	-	32		351		495		2			
073	77				1700			10	558	412		353		495		1			
0813	77				9595			7	-	414		356		605		2			
096	77				11960			11	570	414		354		610		2			
261010	77				9700			9	646	415		361		615		3			
REMARKS - NO. 1 SHIFT		REMARKS - NO. 2 SHIFT		REMARKS - NO. 3 SHIFT															

P-3735 (3-17-83)

CR

O

OO

P-3593

JAN 25 1990

DATE

NCG SYSTEM

HRS NO.	PRE-EVAPS						ACCUMULATOR		STRIPPER				INCINERATION									
	B.L. FLOW GPM			% SOL IN	% SOL OUT	IMM. UQ. TK	VACUM IN. Hg	HOG EJECT. ON/OFF	COOLING TOWER WATER TEMP.	Avg. TEMP.	FLASH TANK FLOW	FEED TANK LEVEL	COND. FLOW IN	STM. FLOW IN	PRESS	REFLUX TEMP OUT	V= VENT		C= COLLECT		B= BURN	
	#1 EVAP HW	#2 EVAP HW	#3 EVAP HW	#4 EVAP HW	PRE EVAP HW	BLOW HEAT COND.	STRIP. FEED TK.	TURP. COND.	SYS. NOx	STRIP. NOx												
7	2900	16.1	18.7	44.0	23.5	OFF	94	20.7	4000	9.5	180	21000	9.0	190	C	C	C	C	C	C	B	B
8	3200	15.8	18.7	44.0	23.5	"	88	210	4500	9.0	180	21000	9.0	195	C	C	C	C	C	C	B	B
9	3200	16.3	18.5	45.0	24.0	"	88	185	4500	9.0	180	21000	9.0	195	C	C	C	C	C	C	B	B
10	3200	16.3	18.3	45.5	24.0	"	86	190	4000	9.0	180	21000	9.0	195	C	C	C	C	C	C	B	B
11	3200	16.1	18.6	46.0	23.5	"	86	198	4500	9.0	180	21000	9.0	195	C	C	C	C	C	C	B	B
12	3000	16.2	18.6	46.5	24.0	"	88	185	4500	9.0	180	21000	9.0	195	C	C	C	C	C	C	B	B
1	3000	16.3	18.7	46.5	24.0	"	88	178	4500	9.0	180	21000	9.0	195	C	C	C	C	C	C	B	
2	3000	16.0	18.4	46.5	24.5	"	86	180	3500	9.5	180	21000	9.0	195	C	C	C	C	C	C	B	B
3	3000	15.9	18.7	46.5	24	OFF	86	190	4000	9.1	180	21000	9.0	195	C	C	C	C	C	C	B	B
4	3000	16.2	18.3	46.0	24.5	"	85	180	3000	9.0	180	21000	9.0	190	C	C	C	C	C	C	B	B
5	3000	16.2	18.6	46.0	24.0	"	85	185	4000	8.6	180	21000	9.0	190	C	C	C	C	C	C	B	B
6	3000	16.2	18.7	46.0	24.0	"	85	200	4000	8.6	180	21000	9.0	190	C	C	C	C	C	C	B	B
7	3000	16.2	18.8	46	23.5	"	87	200	4500	9.8	180	21000	9.0	195	C	C	C	C	C	C	R	B
8	3000	16.2	18.5	46	23.5	"	88	205	5000	9.0	180	21000	9.0	195	C	C	C	C	C	C	B	B
9																						
10																						
11																						
12																						
1																						
2																						
3																						
4																						
5																						
6																						
7 - 3 : OPERATOR				3 - 11 : OPERATOR				11 - 7 : OPERATOR														


C1

C0

P-3782		NO. 3 EVAPORATORS								NO. 2 EVAPORATORS								NO. 1 EVAPORATORS								DATE: JAN 23 1990					
HOURS	FEED LIQUOR	TOTAL FEED	VAC.	STM.	STEAM	COND	PRODUCT LIQUOR		TOTAL FEED	VAC.	STM.	STEAM	COND	PRODUCT LIQUOR		TOTAL FEED	VAC.	STM.	STEAM	COND	PRODUCT LIQUOR		JNFIL.	FILT.	NO. 1 HEAVY LIQ.	NO. 2 HEAVY LIQ.					
		Liq.		IN.	#/IN	H/HR	H ₂ O	OF	GPM	IN.	#/IN	H/HR	H ₂ O	OF	Be'	OF	GPM	IN.	#/IN	H/HR	H ₂ O	OF	Be'	OF	FT.	FT.	FT.	FT.			
7	16.5	188	610	26.5	45	39000		29.0	212	620	260	45	40000		28.2	212	350	250	37	28000		29.1	212	9.0	16.0	19.0	12.0				
8	16.3	189	610	26.5	45	38000		29.0	212	620	260	45	38000		28.1	212	350	250	37	28000		29.2	212	12.5	12.0	19.0	10.0				
9	17.1	188	610	26.5	45	38000		28.9	212	620	245	45	39000		28.3	212	350	250	37	29000		29.0	212	14.0	16.5	19.0	10.0				
10	16.6	188	610	26.5	45	38000		28.7	212	620	245	45	39000		28.3	212	350	250	37	29000		28.9	212	15.5	16.0	19.0	10.5				
11	16.7	188	610	26.5	45	37000		28.7	212	620	245	45	39000		28.3	212	350	250	37	28000		29.1	212	15.0	17.5	19.0	11.5				
12	16.8	188	610	26.5	45	38000		28.8	212	620	245	45	38000		28.2	212	350	250	37	28000		29.5	212	15.5	17.5	19.0	12.0				
1	17.0	188	610	26.5	45	38000		28.8	212	620	245	45	39000		28.2	212	350	250	37	28000		29.4	212	12.5	17.5	19.0	12.0				
2	17.1	188	610	26.5	45	38000		29.0	212	620	250	45	38500		28.1	212	350	250	37	28000		29.6	212	12.0	18.0	19.0	12.0				
3	17.1	188	610	25.5	45	38000		29.3	212	620	25	45	37000		27.8	220	350	25	37	28000		29.2	220	10	17	14	12				
4	17.2	188	610	2	45	39000		28.8	212	620	25	45	46000		28.2	220	350	25	37	28000		27.1	220	11	16.5	17	11.5				
5	17.3	188	610	26.5	45	40000		29.0	212	620	24.5	45	39500		27.8	220	350	25	37	28500		29.0	220	10	16.5	16.5	13.5				
6	17.2	188	610	25	45	37000		29.0	212	620	24.5	45	39500		27.8	220	350	25	37	47000		29.1	220	11	14.5	16.5	14				
7	17.3	188	610	26.5	45	39000		29.1	212	620	24.5	45	39000		27.9	220	350	25	37	29000		29.2	220	10	15	16.5	15				
8	17.3	188	610	26.5	45	39500		29.2	212	620	25	45	39500		27.8	220	350	25	37	38500		29.2	220	13	15	16.5	15				
9																															
10																															
11																															
12																															
1																															
2																															
3																															
4																															
5																															
6																															
7 - 3 : OPERATOR				3 - 11 : OPERATOR								11 - 7 : OPERATOR																			


NCG INCINERATOR TEMPERATURE

25 JANUARY 1990




NCG COMPLIANCE TESTING TEMPERATURES

25 JANUARY 1990



NCG INCINERATOR TEMPERATURE

25 JANUARY 1990



START	STOP	DURATION	TEMPERATURE BELOW 1200 DEGREES
-------	------	----------	--------------------------------

TEMPERATURE ABOVE 1200 DEGREES ENTIRE 24 HOUR PERIOD

GEORGIA-PACIFIC CORPORATION
PALATKA OPERATIONS

25-Jan-98

NCG VALVE REPORT

START	STOP	DURATION	VALVE NAME	REASON FOR VENTING
-------	------	----------	------------	--------------------

NO VALVES VENTED ENTIRE 24 HOUR PERIOD



APPENDIX F. SPECIFIC CONDITIONS FOR THE INCINERATOR

Tampa, Florida

Specific Conditions for the Incinerator

1. The sources are permitted to operate continuously (i.e., 8760 hrs/year).
2. The emissions from the digester system (consisting of 13 digester systems); the multiple effect evaporation system (consisting of 4 multiple effect evaporator systems); and the NSPS condensate stripper system shall be collected and incinerated in the TRS incinerator. Note that each digester system includes the turpentine condenser system, blow heat accumulator, etc.; and that each multiple effect evaporator system includes the concentrator, the pre-evaporator, hotwells, etc. Actual mass emissions from each system shall be determined prior to and after any future changes, meaning those changes to the permitted systems not specifically authorized by these permits.
3. TRS emissions from the TRS incinerator shall not exceed 5 ppmv on dry basis at standard conditions corrected to 10% oxygen as a 12-hour average. Mass TRS emissions from the TRS incinerator shall exceed neither 0.12 lb/hr nor 0.53 ton/year. The mass TRS emissions are the maximum permitted aggregate total mass emissions allowed for the permitted sources. TRS emissions shall be determined by EPA Methods 1, 2, 3, and either 16 or 16A. No objectionable odor shall be emitted from the TRS incinerator.
4. Particulate emissions from the TRS incinerator (AC 54-142291) shall be limited as follows:
 - a. Visible emissions from the TRS incinerator (AC54-142291) shall not exceed 5% opacity (no visible emissions) except that visible emissions of up to 20% opacity are allowed for not more than three minutes in any one hour. Visible emissions from the TRS incinerator shall be determined using DER Method 9.
 - b. Mass particulate emissions from the TRS incinerator (AC 54-142291) shall neither exceed 5.5 lbs/hour nor 24.1 tons/year as measured by EPA Methods 1, 2, 3, and 5. Testing for compliance with the mass particulate emission limitation shall be exempt from the compliance testing schedule applicable to the other regulated pollutants emitted by the TRS incinerator. Instead, testing for compliance with the mass particulate emission limitation shall be completed not later than May 12, 1989, and subsequent testing shall be conducted at intervals of not longer than every 5 years thereafter, unless shorter testing intervals are ordered by the Department.
5. SO₂ emissions from the TRS incinerator shall exceed neither 1200 lbs/hr nor 3434 tons/year. SO₂ emissions shall be determined by EPA Methods 1, 2, 3, and 6.



**APPENDIX G. EPA REFERENCE METHOD 16 ANALYTICAL
METHODOLOGY**

TEST PROCEDURES

REFERENCE METHOD 16 ANALYTICAL METHODOLOGY

Total reduced sulfur (TRS) testing is performed using the general techniques and procedures described in EPA Method 16. This section describes the instrumentation, equipment and procedures used by WESTON to conduct reduced sulfur emission testing in accordance with the guidelines given in the Method. Compounds of interest include hydrogen sulfide (H_2S), methyl mercaptan (MeSH), dimethyl sulfide (DMS), and dimethyl disulfide (DMDS) from kraft pulp mill sources. The equipment and techniques described herein have been evaluated by WESTON personnel and have been found acceptable to measure reduced sulfur emissions from regulated sources.

A continuous gas sample is extracted from the emission source; scrubbed through a cold, buffered citrate solution (to remove particulate, moisture and sulfur dioxide); transported to the mobile laboratory through an inert sample line; and analyzed by gas chromatographic separation with flame photometric detection.

EQUIPMENT AND INSTRUMENTATION


As shown in Figure 1, the system consists of a Teflon-lined probe, a cold, liquid scrubber, a nylon sample transfer line, a gas chromatograph, an integrator/chart recorder, a standard gas generator and the associated pumps, valves and gases. This configuration is used regardless of the source tested, but the GC conditions may be changed to achieve the desired separation of compounds.

The Teflon-lined, stainless steel probe (of sufficient length to monitor the gas stream without wall effects) is used to extract a gas sample from the emission source. The probe assembly is configured to allow the introduction of a trace gas at the tip of the probe to evaluate the performance of the entire analytical system, and the tip is directed away from stack gas flow to minimize particulate and moisture entrainment. The probe outlet is plumbed directly to the sample conditioning system.



The sample conditioning system consists of two 250-mL Teflon impingers containing a citrate buffer solution. The Teflon sample line drops directly into the first Teflon impinger which contains approximately a 2 molar solution of potassium citrate at a pH of 5.4 to 5.8. At this pH, SO_2 is selectively removed without affecting the reduced sulfur compounds. The impingers are emersed in an ice bath to reduce the gas temperature to 4 to 5°C thus condensing the moisture. Particulate matter is also removed by the impingers as the gas is washed with the citrate solution.

The sample conditioning system (cold, citrate buffer) is located as close to the sample port as practical to remove moisture and particulate from the sample before transport through sample lines to the mobile laboratory. This method of sample conditioning provides better recovery of reduced sulfur compounds than heating the sample and/or diluting with dry air. The citrate buffer solution removed moisture and particulate matter which may absorb H_2S during transport to the GC. By conditioning the sample at the source, loss of reduced sulfur compounds in the sample transport system is minimized.

FIGURE 1. SCHEMATIC DRAWING OF TRS ANALYTICAL SYSTEM



- NOTES:
1. Trace gas from the TRACE GAS DILUTION UNIT is routed either to the trace gas inlet (B) or to the gas chromatograph inlet (A) to check the recovery through the system.
 2. Calibration gas from the DYNACALIBRATOR is routed to the gas chromatograph (A) during calibration.
 3. All portions of the system except SAMPLE CONDITIONING are located in the mobile laboratory.



The conditioning system has been evaluated by WESTON personnel and has been found to quantitatively pass all reduced sulfur compounds of concern. Recovery of H₂S through the scrubber is demonstrated before and after each sample run.

The dry (approximately one percent moisture) gas is filtered through a microfibre filter before transport to the mobile laboratory through an unheated, nylon sample line. Nylon has been shown to be inert to the reduced sulfur compounds of concern and 200 meters of sample line may be used to transport the sample with greater than 95 percent efficiency.

The sample gas is transported to the mobile laboratory at 1.5 to 2.0 L/min by a diaphragm pump. With a sample line of 170 m x 4 mm ID tubing, the sample residence time is less than two minutes. Forty to sixty mL/min of sample gas are forced through the gas sampling valve and the excess gas is vented through the constant pressure device. The constant pressure device ensures that all samples and calibration gas are analyzed under the same conditions.

The gas chromatograph is equipped with a flame photometric detector. The carrier gas flow is reversed to achieve separation of all reduced sulfur compounds on the 2 m x 3 mm OD Carbosorb B HT 100 column. Column No. 2 is a 5 cm 3 mm OD Teflon tube packed with Carbosorb B HT 100. The ten-port valve is used to inject the sample from the sample loop. The valves are solenoid operated and the switching of each is controlled by digital valve interfaces triggered by the electronic timer. A precolumn is not normally required for the separation and a 1.6 mm OD Teflon line is used instead. The sample loop is the length of a 3 mm OD Teflon tube. Varying the length of this tube changes the amount of sample that is analyzed during any injection. Figure 2 shows a typical chromatogram generated by the gas chromatograph.

The peak areas are measured with an electronic integrator. The concentration of sulfur in the gas is proportional to the peak area as well as peak height. A strip chart recording of the peaks is obtained simultaneously on the same instrument. All charts are maintained as a permanent record of each project.

The gas chromatograph is field calibrated for each of the reduced sulfur compounds of concern. Calibration gas is generated using a VICI-Metronics Model 230 Dynacalibrator. As shown in the schematic drawing of Figure 1, the gas flow through the chamber and the diluent may be varied to produce a 100-fold change in the calibration gas concentrations. Permeation devices for each reduced sulfur compound, purchased from VICI-Metronics, are gravimetrically certified by the vendor to permeate at a known rate.

A known concentration of H₂S to evaluate system performance is generated by diluting 100 ppm H₂S with dry air using matched rotameters. A 5-10 ppm H₂S concentration is injected at the probe and then at the gas chromatograph to determine the loss of H₂S through the system. Because the trace gas goes through the citrate scrubber, the system recovery also includes moisture correction so that all results are reported on a dry basis.

Oxygen concentration is monitored on a continuous basis at the outlet of the GC vent with a Teledyne Model 320 oxygen analyzer. This measurement is an excellent indicator of leaks.

Best Available Copy

H_2 Flow = 50 mL/min

Air Flow = 110 mL/min

N_2 1 Flow = 25 mL/min

N_2 2 Flow = 45 mL/min

Attenuation = 2^5

Chart Speed = 1.0 cm/min

= 0.5 cm/min at 2.0 min

Trailer Temp: 26°C

Detector Temp: 115°C

Column Temp: 50°C

Columns: 7' x 1/8" BHT 100

18" x 1/8" PPE

Event 1: 0.01 min, Start, Inject

Event 2: 2.00 min, Load

Event 3: 2.00 min Reverse Flow BHT 100 column


Event 4: 5.50 min Forward Flow BHT 100 column

RT 0.67 min = H_2S

RT 1.67 min = CH_3SH

RT 3.20 min = DMS

RT 4.79 min = DMDS



RUN # 38

RT	AREA TYPE	AR/HT	ARE%
0.67	5709400 ↓BBB	0.059	43.153
1.67	3928700 ↓ BV	0.121	29.694
3.20	1502600 ↓ BV	0.162	11.357
4.79	2029890 ↓ PV	0.282	15.795

TOTAL AREA= 1.3231E+07

MUL FACTOR= 1.0000E+00

FIGURE 2. TYPICAL CHROMATOGRAM OF REDUCED SULFUR COMPOUNDS

All rotameters in the system are used to measure consistency of flow and not actually to measure the gas flow. All critical gas flows (Dynacalibrator, trace gas, etc.) are measured at each time of use with a soap bubble-flow tube and a stopwatch. The calibration curves for noncritical rotameters are verified periodically by the soap bubble-flow tube method.

METHODOLOGY

Before testing begins, the GC is checked thoroughly for proper operation. A standard gas (a mixture of all reduced sulfur compounds) is injected several times to verify compound retention times and to check the peak area with previously obtained calibration curves.

Before testing on a source actually begins, the sample line is placed in position from the sampling port to the GC set-up and rinsed thoroughly with acetic acid, water and acetone to clean the surface. The sampling system is leak checked by capping the probe and pulling a 10 in. Hg vacuum on the entire system. The sample flow rate at the pump outlet is measured with a soap bubble flow tube. A leak free system is defined as one having a leak rate of less than two percent of the sample flow rate. Because the sampling pump has a maximum vacuum capacity of 10 in. Hg and the normal vacuum in the system is less than 2 in. Hg, the leak check procedure subjects the system to significantly more rigorous conditions than during normal sampling. The entire system is operated under slight vacuum and any leaks during a run are indicated by an increase in oxygen content and/or a reduction in the recovery of H₂S through the system.

The train is then completely assembled and the probe is inserted into the source. The probe is allowed to reach thermal equilibrium while gas is being pulled through the system. An excess of a known concentration of H₂S is injected at the probe tip and pulled through the entire analytical system and then injected at the GC to check the recovery throughout the clean system. After the recovery has stabilized, the standard gas is disconnected from the probe and source gas is collected for a minimum of 15 minutes to ensure the sample line is properly conditioned before TRS concentrations are recorded.

Calibration curves are prepared for each compound before each test begins and verified after each run. Each gas concentration is injected at least three times to ensure instrument stability. The resulting calibration curves are made from the mean response of three injections at least three concentrations. All gas flow rates from the dynacalibrator are measured at the time of use using the soap bubble flow tube technique.

At the end of each sampling run, an H₂S standard is again injected at the probe to check sample loss in the system. Trace gas recovery is evaluated by injecting 5-10 ppm H₂S gas stream at the probe tip and recovering that sample through the sample conditioning and sample transport subsystems. The same gas stream was then introduced directly to the GC sample loop. The ratio of concentrations (based on calibration curves prepared from certified permeation devices) corrects for TRS loss, sample line leakage and moisture in the system. This factor is then used to adjust all measured reduced sulfur compound concentrations to provide results on a dry basis.

If moisture collection is excessive or if the scrubbing solution appears spent, the citrate buffer in the impingers may be changed. Under normal circumstances, one batch of scrubbing solution is sufficient for three 3-hour runs. Exceptions are noted on the field data sheets.

DATA MANIPULATION AND CALCULATION

Peak areas for the compounds of concern are transcribed from the integrator output to data sheets by the instrument operator. All integrator tapes are filed and the "Source Data" sheet is considered to be the record of the test. The instrument operating conditions, calibration data and recovery data are also transcribed from the integrator tape to the appropriate data sheets.

Data reduction is accomplished by referral to calibration curves generated from the analysis of known concentrations of each compound. Calibration curves fit the general equation of $Y = aX^b$. Coefficients of this equation are determined using a Hewlett Packard 15-C calculator programmed with a linear least squares program to give the best fit of the points. Correlation coefficients (R^2 values) are typically 0.98 or better. Copies of calibration curves used for data calculation are included in the appropriate appendix of the report.

The following information is provided as a guide to the reader to demonstrate the method of calculating TRS concentrations from raw data. The general procedure involves the preparation of a calibration curve for each compound of interest from gravimetrically certified permeation devices and then the calculation of source concentrations using the curve generated. Hypothetical data is included as an example.

The permeant concentration in a diluent gas stream is given by the equation:

$$C = \frac{24.04P}{MF}$$

Where:

- C = concentration, ppm
- P = device permeation rate, ng/min
- F = diluent flow rate, mL/min
- M = molecular weight of permeant
- 24.04 = molar volume at 20°C and 760 mm Hg

At least three permeant concentrations are used to construct a calibration curve. Each calibration point is considered valid when the mean peak area of three successive injections does not differ by more than five percent from the peak areas contributing to the mean. The slope of the calibration curve is given by the equation:

$$Y = aX^b \text{ or } \log Y = b \log X$$

Where:

- Y = response for concentration X
- b = slope
- a = constant

In theory, the slope of the calibration curve should be 2.00. Normally calibration curves have slopes between 1.6 and 2.2. Slopes of less than 1.6 may be acceptable if the measured concentrations are clearly within the linear region of the calibration curve. An example calculation is provided in Table 1.

Each calibration curve is checked after each run for drift. If the calculated concentration exceeds the known concentration by more than ten percent, a new calibration curve is constructed. Sample concentrations must be calculated from the curve which yield the greatest concentration values.

The "three successive injections" criterion outlined in the calibration section is also applicable to trace gas recovery. The equation defining trace gas recovery is:

$$\% \text{ Recovery} = \frac{\text{Conc of trace gas recovered through the system}}{\text{Conc of trace gas measured at GC}} \times 100\%$$

The system correction factor is calculated by the following equation:

$$\text{System Correction Factor} = \frac{100}{\% \text{ Recovery}}$$

The concentration of the trace gas recovered through the system should be within 20 percent of the known TRS concentrations. Recovery values of less than 80 percent are normally unacceptable.

All measured concentrations are multiplied by the system correction factor; thus all data are corrected for line losses and are expressed on a dry basis.

QUALITY ASSURANCE

All QC calibrations are performed using gases generated from certified permeation devices. The emission rate of ± 2 percent. The emission rate is determined in a constant temperature chamber at a temperature which is traceable to NBS standard. The constant temperature chamber of the WESTON Dynacalibrator is certified by the vendor at the same temperature as the permeation device certification. All permeation devices are periodically replaced to ensure that they are used only during the recommended lifetime. The known emission rate coupled with the accurate measurement of the dilution gas flow ensures accurate generation of standard concentrations.

After preparation of a calibration curve from the linear least squares best fit the data, the mean response obtained for each gas concentration is used to calculate the concentration equivalent to the response. The calculated concentration should vary less than 10 percent from the known concentration except at the lower end of the curve. Near the detection limit for each compound, variation may be more due to variation in integration.

The sample system integrity is verified through routine leak checks and determination of the recovery of H₂S through the entire sampling and analysis system. Recovery studies are conducted before and after each 3-hour run to ensure that at least 80 percent of the H₂S injected at the probe tip is recovered at the GC. All source concentrations are corrected for the lower recovery value.

All rotameters are calibrated with an appropriate soap bubble flowmeter under actual operating conditions. Calibration graphs are prepared for field use. All flows are verified during the testing to ensure that all flows remain constant. The actual measured flows are used in the calculations.

TABLE 1. EXAMPLE CALCULATION

Calibration Point	1	2	3	4
Known Concentration ^a	10.5	6.41	2.92	1.39
Peak Areas ^b				
1	1.36×10^7	5.08×10^6	1.19×10^6	3.01×10^5
2	1.32×10^7	5.04×10^6	1.17×10^6	3.13×10^5
3	1.33×10^7	5.11×10^6	1.19×10^6	3.08×10^5
Mean Peak Area ^b	1.34×10^7	5.08×10^6	1.18×10^6	3.07×10^5
Difference of Individual Peak Areas From Mean Peak Area				
1	1.5%	0	<1%	2%
2	1.5%	<1%	<1%	2%
3	<1%	<1%	<1%	<1%
Calculated Concentration	10.6	6.33	2.89	1.40
Difference Between Known Concentration and Calculated Concentration	<1%	1.2%	1%	<1%

The slope of this H₂S calibration curve is 1.86.

^appm, based on permeation rates and diluent flow.

^buv-sec.

Pressures and flows are observed continuously and recorded during all testing to ensure uniform operation. Periodic leak checks are performed to ensure system integrity. Any unreasonable results are immediately verified by checking the recovery of a standard gas.

All proceedings are recorded on preprinted data sheets. Daily summaries of the testing are prepared at the end of each day to consolidate the data. The data sheets and all integrator outputs remain on file at WESTON for a period of three years after the test.

The gas chromatographic columns and conditions are sufficient to obtain separation of all the reduced sulfur compounds. The method has been found to be free of interferences from carbon monoxide, carbon dioxide, and hydrocarbons. Sulfur dioxide interference is eliminated by the citrate scrubber at the source. The cold, citrate scrubber eliminates moisture interference by reducing the dew point of the gas to less than 4°C and the recovery studies correct the sample concentrations to dry conditions.

EVALUATION OF CARBON DIOXIDE INTERFERENCE

The response of a flame photometric detector (FPD) is known to be depressed by carbon monoxide (CO) and carbon dioxide (CO₂). Since CO is normally present in emission sources at concentrations of less than 200 ppm and since it responds on the analytical GC column in the same way as CO₂, it is not necessary to check for interference. It is, however, important to demonstrate that CO₂ does not depress the instrument response to the reduced sulfur compounds because CO₂ is present in many emission sources at high concentrations (up to approximately 20 percent).

On 23 August 1983, the WESTON TRS analytical system was evaluated to document the lack of interference by CO₂. The gas chromatograph, valving, and timing the operation of the system was identical to that described in this method. The instrument conditions shown on Figure 3 were used during the experiment.

Because CO₂ elutes from the column before H₂S, it is the only reduced sulfur compound that could be affected by CO₂ in the gas. To demonstrate a lack of interference, a gravimetrically certified H₂S in nitrogen and then the same concentration was generated in 16 percent CO₂ and 84 percent nitrogen. Both samples were analyzed repetitively to compare the response of H₂S in the presence of CO₂.

Five successive injections of 8.15 ppm H₂S in nitrogen gave the following peak areas (all multiplied by 10³ uv-sec):

2.664	
2.636	Mean = 2.631
2.611	Std Dev = 0.021
2.627	
2.617	

Five successive injections of 8.15 ppm H₂S in 16 percent CO₂, 84 percent nitrogen gave the following peak areas (all multiplied by 10 uv-sec):

2.608	
2.633	Mean = 2.616
2.627	Std Dev = 0.013
2.611	
2.601	

The 0.57 percent decrease in response (equivalent to 0.3 percent concentration) between the two samples is not significant at the 95 percent confidence level. It is, therefore, concluded that the FPD response to H₂S is unaffected by CO₂ at the concentrations normally measured in emission sources.

EVALUATION OF TRS LOSS THROUGH NYLON SAMPLE LINES

On 26 June 1989, the WESTON TRS analytical system was evaluated to document the recovery of hydrogen sulfide (H₂S), methyl mercaptan (MeSH), dimethyl sulfide (DMS), and dimethyl disulfide (DMDS) through nylon sample lines. The gas chromatograph, valving, timing, and operation of the system was identical to that previously described.

Client ATC Date 8/26/83
Source CO₂ Information Study Analyst DE

Page 1 of 1

FIGURE 3. INSTRUMENT CONDITIONS USED DURING INTERFERENCE STUDIES

A sampling train was constructed by plumbing a Teflon-lined, stainless-steel probe to a pair of Teflon impingers, containing 2 M citrate buffer pH 5.4 to 5.8, maintained in an ice bath. The outlet of the second impinger was plumbed to a Balston AQ filter which was attached to 500 feet of 1/4 inch nylon sample line. The sample line was connected to the vacuum side of a KNF Kneuberger pump equipped with Viton valves and diaphragm. The KNF Kneuberger pump was operating at a flow rate of approximately 1 liter per minute. The outlet of the pump was discharged into a constant pressure bottle to maintain a sufficient flow to charge the sample loop of the gas chromatograph.

A gas cylinder containing H₂S, MeSH, DMS, and DMDS was used for the recovery evaluation. The gas was introduced at the probe tip and recovered through 500 feet of nylon sample line. The gas was then introduced directly to the gas chromatograph via the pump and constant pressure bottle. Three consecutive injections were obtained with a difference of less than ± 5 percent and are summarized below:

	<u>H₂S</u>	<u>MeSH</u>	<u>DMS</u>	<u>DMDS</u>
Instrument Response, $\times 10^4$ uv-sec				
Injection 1	7.29	3.49	3.12	3.56
Injection 2	7.28	3.41	3.17	3.54
Injection 3	7.32	3.41	3.22	3.60
Mean	7.30	3.44	3.17	3.57
Calculated Concentration, ppm				
	10.77	9.36	9.42	8.02

The cylinder gas was then plumbed directly to the constant pressure bottle and three consecutive injections were obtained with a difference of less than ± 5 percent. Those results are summarized below:

	<u>H₂S</u>	<u>MeSH</u>	<u>DMS</u>	<u>DMDS</u>
Instrument Response, $\times 10^4$ uv-sec				
Injection 1	7.87	3.90	3.64	3.94
Injection 2	7.90	3.92	3.63	4.02
Injection 3	7.94	3.94	3.64	4.13
Mean	7.90	3.92	3.64	4.03
Calculated Concentration, ppm				
	11.35	10.17	10.3	8.54

Recovery values based on the calculated concentrations measured directly to the gas chromatograph and after recovering the cylinder gas through the sample line are provided below:

	<u>H₂S</u>	<u>MeSH</u>	<u>DMS</u>	<u>DMDS</u>
Recovery through nylon sample line, percent	95	92	91	94



APPENDIX H. CERTIFICATION AND CALIBRATIONS

CERTIFICATE

The permeation rate of the DYNACAL® PERMEATION DEVICE listed below
is certified traceable to N.B.S. standards.

CHEMICAL FILL	:	HYDROGEN SULFIDE
DEVICE TYPE	:	WAFER DEVICE
LENGTH/GEOMETRY	:	30T3 WAFER
PART NUMBER	:	147-533-0110
METHOD OF CERTIFICATION	:	GRAVIMETRIC
CERTIFICATION NUMBER	:	89-38090

RATE: 1240 NG/MIN +/- 5% AT 50 DEG C

NOTE:

DATE: 29 SEPTEMBER 1989

BY: Deanna Reiss

VICI

VICI Metronics

2991 Corvin Drive

Santa Clara, California 95051 U.S.A.

(408) 737-0550 Telex 35-2129

INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.B.S. standards.

Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with a purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit time has been achieved. Temperature control and accuracy are better than $\pm 0.05^\circ\text{C}$, referenced against temperature standards traceable to the National Bureau of Standards. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.B.S. traceable weight standards. Gravimetric permeation rate determinations are continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

Validation of the certification procedures and standards at VICI Metronics is accomplished by routine certification of Standard Reference Material (SRM) permeation devices obtained from the National Bureau of Standards.

CERTIFICATE

The permeation rate of the DYNACAL® PERMEATION DEVICE listed below
is certified traceable to N.B.S. standards.

CHEMICAL FILL	:	METHYL MERCAPTAN
DEVICE TYPE	:	STANDARD EMISSION TUBE
LENGTH/GEOMETRY	:	4.0 CM.
PART NUMBER	:	117-040-6000
METHOD OF CERTIFICATION	:	GRAVIMETRIC
CERTIFICATION NUMBER	:	28-40474

RATE: 733 NG/MIN +/- 2% AT 50 DEG C.

NOTE:

DATE: 13 SEPTEMBER 1989

BY: Oleann Lewis

VICI

VICI Metronics

2991 Corvin Drive

Santa Clara, California 95051 U.S.A.

(408) 737-0550 Telex: 35-2129

INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.B.S. standards.

Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with a purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit time has been achieved. Temperature control and accuracy are better than $\pm 0.05^\circ\text{C}$, referenced against temperature standards traceable to the National Bureau of Standards. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.B.S. traceable weight standards. Gravimetric permeation rate determinations are continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

Validation of the certification procedures and standards at VICI Metronics is accomplished by routine certification of Standard Reference Material (SRM) permeation devices obtained from the National Bureau of Standards.

CERTIFICATE

The permeation rate of the DYNACAL® PERMEATION DEVICE listed below
is certified traceable to N.B.S. standards.

CHEMICAL FILL	:	DIMETHYL SULFIDE
DEVICE TYPE	:	HIGH EMISSION TUBE
LENGTH/GEOMETRY	:	3.0 CM.
PART NUMBER	:	107-030-6200
METHOD OF CERTIFICATION	:	GRAVIMETRIC
CERTIFICATION NUMBER	:	82-40477

RATE: 1231 NG/MIN +/- 2% AT 50 DEG C

NOTE:

DATE: 13 SEPTEMBER 1989

BY: *Blema Reini*

VICI

VICI Metronics

2991 Corvin Drive

Santa Clara, California 95051 U.S.A.

(408) 737-0550 Telex: 35-2129

INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.B.S. standards.

Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with a purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit time has been achieved. Temperature control and accuracy are better than $\pm 0.05^\circ\text{C}$, referenced against temperature standards traceable to the National Bureau of Standards. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.B.S. traceable weight standards. Gravimetric permeation rate determinations are continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

Validation of the certification procedures and standards at VICI Metronics is accomplished by routine certification of Standard Reference Material (SRM) permeation devices obtained from the National Bureau of Standards.

CERTIFICATE

The permeation rate of the DYNACAL® PERMEATION DEVICE listed below
is certified traceable to N.B.S. standards.

CHEMICAL FILL	:	DIMETHYL SULFIDE
DEVICE TYPE	:	HIGH EMISSION TUBE
LENGTH/GEOMETRY	:	3.0 CM.
PART NUMBER	:	107-030-E200
METHOD OF CERTIFICATION	:	GRAVIMETRIC
CERTIFICATION NUMBER	:	82-40477

RATE: 1231 NG/MIN +/- 2% AT 50 DEG C

NOTE:

DATE: 13 SEPTEMBER 1989

BY: Oliver Reim

VICI

VICI Metronics

2991 Corvin Drive

Santa Clara, California 95051 U.S.A.

(408) 737-0550 Telex: 35-2129

INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.B.S. standards.

Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with a purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit time has been achieved. Temperature control and accuracy are better than $\pm 0.05^\circ\text{C}$, referenced against temperature standards traceable to the National Bureau of Standards. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.B.S. traceable weight standards. Gravimetric permeation rate determinations are continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

Validation of the certification procedures and standards at VICI Metronics is accomplished by routine certification of Standard Reference Material (SRM) permeation devices obtained from the National Bureau of Standards.

CERTIFICATE

The permeation rate of the DYNACAL® PERMEATION DEVICE listed below
is certified traceable to N.B.S. standards.

CHEMICAL FILL	:	DIMETHYL DISULFIDE
DEVICE TYPE	:	HIGH EMISSION TUBE
LENGTH/GEOMETRY	:	20.8 CM.
PART NUMBER	:	107-200-6301
METHOD OF CERTIFICATION	:	GRAVIMETRIC
CERTIFICATION NUMBER	:	82-40478

RATE: 1022 NG/MIN +/- 2% AT 50 DEG C

NOTE:

DATE: 13 SEPTEMBER 1989

BY: John Davis

VICI

VICI Metronics

2991 Corvin Drive

Santa Clara, California 95051 U.S.A.

(408) 737-0550 Telex: 35-2129

INDIVIDUAL DEVICE CERTIFICATION

The gravimetric method measures the weight loss per unit of time at the certification temperature. Traceability is thus established by the use of temperature and weight standards traceable to N.B.S. standards.

Individual certification is accomplished by: (1) maintaining the device in a constant temperature chamber with a purge flow of dry nitrogen, and (2) weighing periodically on a semi-microanalytical balance, accurate to the nearest 0.01 mg, until a steady weight loss per unit time has been achieved. Temperature control and accuracy are better than $\pm 0.05^\circ\text{C}$, referenced against temperature standards traceable to the National Bureau of Standards. The semi-microanalytical balances are routinely serviced and calibrated by an independent service organization using N.B.S. traceable weight standards. Gravimetric permeation rate determinations are continued until the standard error of the permeation rate meets the required accuracy at the 95% confidence level.

Validation of the certification procedures and standards at VICI Metronics is accomplished by routine certification of Standard Reference Material (SRM) permeation devices obtained from the National Bureau of Standards.

A0-4

CALIBRATION SHEET

Customer : Roy F. Weston Serial : 81082
Date : 1/30/89

CALCULATION DATA FOR RUN:	1	2	3	
1. Barometric Pressure, P(B):	30.03	30.03	30.03	
2. Orifice Setting, Delta H :	2.00	0.75	6.00	
3. Finial Reading (Test) :	86.673	97.619	108.797	
4. Initial Reading (Test) :	75.787	87.024	93.182	
5. Volume, V(T) Cubic Feet :	10.886	10.595	10.615	
6. Temp Initial T(T(I)) F :	70	72	73	
7. Temp Finial T(T(F)) F :	71	73	73	
8. Finial Reading (Box) :	14.746	25.657	36.687	
9. Initial Reading (Box) :	4.000	15.100	26.206	
10. Volume, V(B) Cubic Feet :	10.746	10.557	10.481	
11. Temp Initial T(B(I)) F :	72	76	79	
12. Temp Final T(B(F)) F :	76	79	84	
13. Elapsed Time, Minutes :	14.0	22.0	8.0	
Delta H(a)	: 1.8403	1.8008	1.8873	1.843
Gamma	: 1.0147	1.0112	1.0140	1.013

Calibration Performed By : William D. Ballard

8-06

POST METER CALIBRATION

CLIENT Georgia Pacific PROJECT NUMBER 0414-09-04 ΔH 2.5 HIGHEST VACUUM 5.0
 DATE 1-29-90 CONSOLE # 4NT METER # PB 27.70 γ_{STD} 0.985 CALIBRATED BY R.J.

<u>ΔH</u>	<u>Θ</u>	VAC	STANDARD METER						DRY TEST METER					
			V _{SF}	V _{SI}	V _s	T _{SL} TSF	T _s	P _s	V _D F	V _D I	V _D	T _D I T _{DF}	T _D	
2.5	15	6.0	618.730	605.380	13.350	70 72	71	.005	715.175	702.990	13.078	72 76	74	
			628.563	618.730	9.833	72			724.812	715.175	9.637	76 78		
2.5	12	6.0	639.300	628.563	10.737	72	72	.005	735.338	724.812	10.526	78 79	78.5	

$$\bar{\gamma} = \frac{V_s (P_b + P_s/13.6)(T_d + 460)}{V_d (P_b + \Delta H/13.6)(T_s + 460)} \gamma_{STD}$$

$$\Delta H@ = 0.0319 \Delta H \frac{(T_s + 460)\Theta^2}{P_b (T_d + 460) [V_s \gamma_{STD}]}$$

<u>ΔH</u>	<u>$\bar{\gamma}$ CALCULATION</u>	<u>$\bar{\gamma}$</u>	<u>ΔH@ CALCULATION</u>	<u>ΔH@</u>
2.5	$\frac{(\Theta + 13.6)(T_s + 460)}{(\Theta + 13.6)(T_d + 460)}$	1.00501	$\frac{0.0319 (\Theta + 460)}{(\Theta + 460) [(\Theta + 460)(T_d + 460)]}$	1.81255
2.5		1.00830		1.8132
2.5		1.00831		1.8097
		1.00711		1.8168

3 IS THIS $\bar{\gamma}$ WITHIN 5%? YES

4 ARE INDIVIDUAL VALUES FOR $\bar{\gamma} \pm 2\%$ FROM $\bar{\gamma}$? YES

DATA CHECKED BY /DATE: K.W.

- 1) LEAK CHECK STANDARD METER UP TO COARSE ADJUST VALVE UNDER POSITIVE PRESSURE - 0.5 INCHES H₂O.
- 2) ALLOW 15 MINUTE WARM-UP BEFORE BEGINNING CALIBRATION AND RE-VERIFY ΔH AND VACUUM.
- 3) MAINTAIN CONSTANT ΔH.

DATE: 1-10-90

DRY GAS METER IDENTIFICATION: #3

BAROMETRIC PRESSURE (P_b): 30.14 / 30.18 in. Hg

SINGER DRY GAS METER.

APPROXIMATE FLOW RATE (\bar{Q}) cfm	SPIROMETER (WET METER) GAS VOLUME (V_s) liters	DRY GAS METER VOLUME (V_{ds}) liters	TEMPERATURES			DRY GAS METER PRESSURE (Δp) in. H ₂ O	TIME (θ) min.	FLOW RATE (\bar{Q}) cfm	METER METER COEFFICIENT (γ_{ds})	AVERAGE METER COEFFICIENT (γ_{av})		
			SPIROMETER (WET METER) (t_s) °F P_{s2}	INLET (t_1) °F P_{s1}	OUTLET (t_2) °F P_{s2}							
1.5 0.40	1.500	4.04	0.00	69.98	78	78	77	78	78	1.6	42.38	1.65
	2.00	4.70	0.00	74.100	78	78	78	78	78	1.6	51	1.48
	2.00	5.02	0.00	82.100	78	78	78	78	78	1.6	58	1.45
1.0000 0.60	3.00	4.40	0.00	37.120	78	78	78	78	78	1.7	32	1.22
	4.40	4.98	0.00	15.30	78	78	78	78	78	1.4	12.5	1.21
	4.98	5.34	0.00	13.50	78	78	78	78	78	1.4	9	1.19
2.500 0.80	2.00	0.00		78	78	78	78	78	1.4			
1.00												
1.20												

$$\bar{Q} = 17.65 \cdot \frac{V_s}{\theta} \cdot \frac{P_b}{(t_s + 460)}$$

$$\gamma_{ds} = \frac{V_s}{V_{dg}} \cdot \frac{(t_s + 460)}{(t_d + 460)} \cdot \frac{P_b}{(P_b + \frac{\Delta p}{13.6})}$$

Figure 5.8. Example data sheet for calibration of a standard dry gas meter for method 5 sampling equipment (English units).



APPENDIX I. EXAMPLE CALCULATIONS

EXAMPLE CALCULATIONS FOR NCG INCINERATOR

(The data used for sample calculations are from Run 1)

I. Calculation for Meter Pressure (Pm), in. Hg

$$P_m = P_{bar} + (\text{avg. delta } H)/13.6 \quad \text{where, } P_{bar} = \text{barometric pressure, in. Hg}$$

$\Delta H = \text{pressure differential of orifice, in. H}_2\text{O}$

$$P_m = \frac{29.77 \text{ in. Hg} + 2.91 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.98 \text{ in. Hg}$$

II. Calculation for Standard Meter Volume (Vmstd), ft^3

$$Vm_{std} = \frac{17.64 \times Y \times V_m \times P_m}{T_m} \quad \text{where, } Y = \text{meter correction factor}$$

$V_m = \text{meter volume, ft}^3$
 $T_m = \text{meter temperature, deg R}$
 $P_m = \text{meter pressure, in. Hg}$

$$Vm_{std} = \frac{17.64 \times 1.01 \times 56.48 \text{ ft}^3 \times 29.98 \text{ in. Hg}}{543.67 \text{ deg R}} = 55.665 \text{ ft}^3$$

III. Calculation for Standard Wet Volume (Vwstd), ft^3

$$Vw_{std} = .04707 \times V_{lc} \quad \text{where, } V_{lc} = \text{volume of water collected, ml.}$$

$$Vw_{std} = .04707 \times 82.10 = 3.864 \text{ ft}^3$$

IV. Calculation for Moisture Content (BWS)

$$BWS = \frac{Vw_{std}}{(Vw_{std} + Vm_{std})} = .065$$

V. Calculation for Molecular Weight (Ms)

$$Ms = [0.44 CO_2 + 0.32 O_2 + 0.28 (100 - CO_2 - O_2)] (1 - BWS) + 18 BWS$$

$$Ms = [0.44 \times 1 + 0.32 \times 18.70 + 0.28 (100 - 18.70 - 18.70)] (1 - .06) + 18(.06) = 28.2$$

VI. Calculation of Average Velocity (Vs), ft/sec

$$Vs = 85.49 \times \frac{C_p \times \sqrt{\Delta P_{avg}} \times \sqrt{\frac{T_s}{P_s \times M_s}}}{}$$

where, C_p = pitot tube coefficient
 ΔP = velocity head of stack gas, in. H₂O
 T_s = absolute stack temperature, deg R
 P_s = absolute stack gas pressure, in. Hg
 M_s = molecular weight of stack gas

$$Vs = \frac{85.49 \times \sqrt{\frac{926.17 \text{ deg R}}{29.98 \text{ in. Hg} \times 28.20 \text{ lb/lb-mole}}} \times .84 \times 1.15 \sqrt{\text{in. H}_2\text{O}}}{\text{sec} \quad (\text{deg R}) \quad (\text{in. H}_2\text{O})} = 86.6 \text{ ft/sec}$$

VII. Calculation of Average Stack Gas Flow at Stack Conditions (Q_a), ft³/min

$$Q_a = 60 \times Vs \times A_s \quad \text{where, } Vs = \text{stack gas velocity, ft/sec}$$

$$Q_a = 60 \times \frac{86.57 \text{ ft/sec} \times 7.88 \text{ ft}^2}{\text{min}} \quad A_s = \text{cross-sectional area of stack, ft}^2$$

$$Q_a = 4.09E+4 \text{ ft}^3/\text{min}$$

VIII. Average Stack Gas Flow at standard conditions (Q_s), Ft³/min

$$Q_s = 17.64 \times Q_a \times \frac{(1 - BWS)}{T_s} \times \frac{P_s}{}$$

where, Q_a = average stack gas flow at stack conditions, ft³/min
 BWS = moisture content
 P_s = absolute stack gas pressure, in. Hg
 T_s = absolute stack temperature, deg R

$$Q_s = 17.64 \times \frac{40932.29}{\text{in. Hg}} \times \frac{\text{ft}^3}{\text{min}} \times (1 - .06) \times \frac{29.98 \text{ in. Hg}}{926.17 \text{ deg R}}$$

$$Q_s = 2.19E+4 \text{ ft}^3/\text{min}$$

IX. Percent Isokinetic Sampling (% I)

$$\frac{0.0945 \times T_s \times V_{mstd}}{P_s \times V_s \times A_n \times \theta \times (1 - BWS)}$$

where, T_s = average stack temperature, deg R
 V_{mstd} = standard meter volume, ft³
 P_s = stack gas pressure, in.Hg
 V_s = stack gas velocity, ft/sec
 A_n = cross-sectional area of nozzle, ft²
 θ = total sampling time, min
BWS = moisture content

$$\frac{0.0945 \times 926.17 \text{ deg R} \times .55.66 \text{ ft}^3}{29.98 \times 86.57 \text{ ft/sec} \times .00 \text{ ft}^2 \times 60 \text{ min} \times (1 - .06)}$$

$$% I = 100.5$$

X. Particulate Concentration at standard conditions (Cs), grain/ft³

$$\frac{M_n}{C_s = 15.4 \times V_{mstd}}$$
 where, M_n = particulate matter collected, g
 V_{mstd} = standard meter volume, ft³

$$\frac{.0840 \text{ g}}{C_s = 15.4 \times 55.66 \text{ ft}^3} = .023 \text{ grain/ft}^3$$

XI. Particulate Emission Rate (PMR), lb/hr

$$PMR = 0.00857 \times C_s \times Q_s$$

where, C_s = particulate conc. at standard cond., grains/ft³
 Q_s = average stack gas flow at standard conditions, ft³/min

$$PMR = 0.00857 \times .02 \frac{\text{grains}}{\text{ft}^3} \times 21855.33 \frac{\text{ft}^3}{\text{min}}$$

$$PMR = 4.353$$

EXAMPLE SO₂ CALCULATIONS FOR NCG INCINERATOR
 GP - PALATKA, FLORIDA
 WESTON WORK ORDER No. 0414-09-01

STANDARD METER VOLUME, V_{MSTD}

$$V_{MSTD} = K_1 \frac{V_M P_M}{T_M}$$

WHERE: $K_1 = 17.64^{\circ}\text{R}/\text{in Hg}$
 $\gamma = \text{DGM CALIBRATION FACTOR}$
 $V_M = \text{DRY GAS VOLUME AS MEASURED BY}$
 $\quad \quad \quad \text{THE DRY GAS METER, DL}$
 $P_M = \text{BAROMETRIC PRESSURE AT THE EXIT}$
 $\quad \quad \quad \text{ORIFICE OF THE DGM, IN HG}$
 $T_M = \text{AVERAGE DGM ABSOLUTE TEMP., } ^{\circ}\text{R}$

RUN 1, NCG INCINERATOR

$$V_{MSTD} = (17.64 \frac{\text{deg R}}{\text{in Hg}})(1.052) \left(\frac{52.15 \text{ L} \times 29.99 \frac{\text{in Hg}}{\text{deg F}}}{541.9^{\circ}\text{F}} \right)$$

$$V_{MSTD} = 53.6 \text{ L}$$

CONCENTRATION OF SULFUR DIOXIDE (SO₂), ppm

$$C_{SO_2} = \frac{K_2 (V_T - V_{TB}) N}{V_{MSTD} V_A}$$

WHERE: $K_2 = 1.202 \times 10^4 \frac{\mu\text{L}}{\text{ml}}$
 $V_T = \text{VOLUME BaCl}_2 \text{ USED TO TITRATE}$
 $\quad \quad \quad \text{SAMPLE, mL}$
 $V_{TB} = \text{VOLUME BaCl}_2 \text{ USED TO TITRATE}$
 $\quad \quad \quad \text{BLANK, mL}$
 $N = \text{NORMALITY OF BaCl}_2$
 $V_{SOLN} = \text{TOTAL VOLUME OF SOLUTION, mL}$
 $V_A = \text{VOLUME OF SOLUTION TREATED, mL}$
 $V_{MSTD} = \text{STANDARD METER VOLUME, DL}$

First Titration, Run 1

$$C_{SO_2} = \frac{(1.202 \times 10^4 \frac{\mu\text{L}}{\text{ml}})(21.4 \text{ mL} - 0.0 \text{ mL})(0.0101)(100 \text{ mL})}{(53.6 \text{ L})(2 \text{ mL})}$$

$$C_{SO_2} = 2409 \frac{\mu\text{L}}{\text{L}} (\text{ppm})$$

$$\hookrightarrow 2409 \text{ ppm} \times 1.66 \times 10^{-7} \frac{\text{lb/DSCF}}{\text{ppm}} \times 2.19 \times 10^4 \frac{\text{DSCF}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}}$$

CONVERSION
 To lb/hr

$$525 \text{ lb/hr}$$

9 04

From Particulate
 Sampling.